

# NYISO TRANSFER LIMITATIONS

Thursday ,May 24, 2018 to Saturday ,November 23, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>E13THSTA-FARRAGUT_345_45</b>					FWD	
Sun 11/26/2017	to	Thu 05/31/2018	<u>UPDATED</u>	<u>by CONED</u>	<u>05/22/2018</u>	(Import)
0001	Continuous	2359				<b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW	
					TTC with All Lines In Service 4600 MW	
<b>W49TH_ST-E13THSTA_345_M54</b>					FWD	
Sun 11/26/2017	to	Thu 05/31/2018	<u>UPDATED</u>	<u>by CONED</u>	<u>05/22/2018</u>	(Import)
0001	Continuous	2359				<b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW	
					TTC with All Lines In Service 4600 MW	
<b>HUDSONP_-FARRAGUT_345_B3402</b>					FWD	
Mon 01/15/2018	to	Sat 06/30/2018	<u>EXT FORCE</u>	<u>by CE</u>	<u>05/22/2018</u>	(Import) (Export)
0001	Continuous	2359				<b>2100 MW 1350 MW</b>
Work scheduled by: ConEd					SCH - PJ - NY	
					Impacts Total Transfer Capability 0 MW 0 MW	
					TTC with All Lines In Service 2100 MW 1350 MW	
<b>HUDSONP_-FARRAGUT_345_B3402 &amp; MARION_-FARRAGUT_345_C3403</b>					FWD	
Mon 01/15/2018	to	Sat 06/30/2018				(Import) (Export)
0001		2359				<b>2050 MW 1300 MW</b>
Work scheduled by:					SCH - PJ - NY	
					Impacts Total Transfer Capability 50 MW 50 MW	
					TTC with All Lines In Service 2100 MW 1350 MW	
<b>MARION_-FARRAGUT_345_C3403</b>					FWD	
Mon 01/15/2018	to	Sat 06/30/2018	<u>EXT FORCE</u>	<u>by CE</u>	<u>05/22/2018</u>	(Import) (Export)
0001	Continuous	2359				<b>2100 MW 1350 MW</b>
Work scheduled by: ConEd					SCH - PJ - NY	
					Impacts Total Transfer Capability 0 MW 0 MW	
					TTC with All Lines In Service 2100 MW 1350 MW	
<b>S.RIPLEY-DUNKIRK_230_68</b>					FWD	
Wed 02/07/2018	to	Mon 06/04/2018	<u>UPDATED</u>	<u>by NYISO</u>	<u>05/14/2018</u>	(Import) (Export)
1629	Continuous	2000				<b>1950 MW 1350 MW</b>
Work scheduled by: NYISO					SCH - PJ - NY	
					Impacts Total Transfer Capability 150 MW 0 MW	
					TTC with All Lines In Service 2100 MW 1350 MW	
<b>CHAT_DC_GC1</b>					FWD	
Sat 04/14/2018	to	Wed 05/23/2018	<u>UPDATED</u>	<u>by HQ</u>	<u>04/11/2018</u>	(Import)
0100	Continuous	1510				<b>2850 MW</b>
Work scheduled by: HQ					MOSES SOUTH	
					Impacts Total Transfer Capability 300 MW	
					TTC with All Lines In Service 3150 MW	

# NYISO TRANSFER LIMITATIONS

Thursday ,May 24, 2018 to Saturday ,November 23, 2019

Seasonal Limits

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CHAT_DC_GC1</b>					REV	
Sat 04/14/2018	to	Wed 05/23/2018	<b>UPDATED</b>	<b>by HQ</b>	<b>04/11/2018</b>	(Export)
0100	Continuous	1510				<b>500 MW</b>
Work scheduled by: HQ					SCH - HQ - NY	500 MW
					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1000 MW
<b>STLAWRNC-MOSES_230_L33P</b>					FWD	REV
Mon 04/30/2018	to	Fri 07/27/2018	<b>EXT FORCE</b>	<b>by IESO</b>	<b>05/11/2018</b>	(Import) (Export)
0456	Continuous	1600				<b>2000 MW 1600 MW</b>
Work scheduled by: IESO					SCH - OH - NY	<b>2000 MW 1600 MW</b>
					Impacts Total Transfer Capability	0 MW 0 MW
					TTC with All Lines In Service	2000 MW 1600 MW
<b>SCH-HQ-NYISO_LIMIT_1200</b>					FWD	
Thu 05/10/2018	to	Fri 05/25/2018				(Import)
1500	Continuous	2100				<b>1200 MW</b>
Work scheduled by: HQ					SCH - HQ - NY	<b>1200 MW</b>
					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	1500 MW
<b>ERIE E_-S.RIPLEY_230_69 &amp; WETHSRFD-S.PERRY_230_85</b>					FWD	
Sat 05/12/2018	to	Fri 06/01/2018				(Import)
0700		1500				<b>2850 MW</b>
Work scheduled by:					DYSINGER EAST	<b>2850 MW</b>
					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW
<b>S.PERRY_-MEYER_230_87</b>					FWD	
Sat 05/12/2018	to	Fri 06/01/2018	<b>UPDATED</b>	<b>by NYSEG</b>	<b>02/15/2018</b>	(Import)
0700	Continuous	1500				<b>2850 MW</b>
Work scheduled by: NYSEG					DYSINGER EAST	<b>2850 MW</b>
					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW
<b>WETHSRFD-S.PERRY_230_85</b>					FWD	
Sat 05/12/2018	to	Fri 06/01/2018	<b>UPDATED</b>	<b>by NYSEG</b>	<b>02/15/2018</b>	(Import)
0700	Continuous	1500				<b>2850 MW</b>
Work scheduled by: NYSEG					DYSINGER EAST	<b>2850 MW</b>
					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW
<b>MARCY_765_345_AT2</b>					FWD	
Mon 05/14/2018	to	Sat 05/19/2018	<b>UPDATED</b>	<b>by NYPA</b>	<b>05/16/2018</b>	(Import)
0500	Continuous	2300				<b>1700 MW</b>
Work scheduled by: NYPA					MOSES SOUTH	<b>1700 MW</b>
					Impacts Total Transfer Capability	1450 MW
					TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 24, 2018 to Saturday ,November 23, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
<b>SCH-NE-NYISO_LIMIT_400</b>					(Import)	
Mon 05/14/2018	to	Mon 05/21/2018	<u>UPDATED</u>	<u>by ISONE</u> <u>05/11/2018</u>	SCH - NE - NY	<b>600 MW</b>
1500	Continuous	1859			Impacts Total Transfer Capability	800 MW
Work scheduled by: ISONE					TTC with All Lines In Service	1400 MW
<b>SCH-NYISO-NE_LIMIT_1100</b>						REV
Mon 05/14/2018	to	Mon 05/21/2018	<u>UPDATED</u>	<u>by ISONE</u> <u>05/11/2018</u>	SCH - NE - NY	<b>1300 MW</b>
1500	Continuous	1859			Impacts Total Transfer Capability	300 MW
Work scheduled by: ISONE					TTC with All Lines In Service	1600 MW
<b>NRTH1385-NOR HBR_138_601 &amp; NRTH1385-NOR HBR_138_603</b>					FWD	REV
Tue 05/15/2018	to	Tue 05/22/2018			(Import)	(Export)
0600		1923			SCH - NPX_1385	<b>0 MW</b> <b>0 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	200 MW 200 MW
					TTC with All Lines In Service	200 MW 200 MW
<b>NRTH1385-NOR HBR_138_602 &amp; NRTH1385-NOR HBR_138_603</b>					FWD	REV
Tue 05/15/2018	to	Tue 05/22/2018			(Import)	(Export)
0600		1923			SCH - NPX_1385	<b>0 MW</b> <b>0 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	200 MW 200 MW
					TTC with All Lines In Service	200 MW 200 MW
<b>NRTH1385-NOR HBR_138_603</b>					FWD	REV
Tue 05/15/2018	to	Tue 05/22/2018	<u>EXTENDED</u>	<u>by LI</u> <u>05/17/2018</u>	SCH - NPX_1385	<b>100 MW</b> <b>100 MW</b>
0600	Continuous	1923			Impacts Total Transfer Capability	100 MW 100 MW
Work scheduled by: LI					TTC with All Lines In Service	200 MW 200 MW
<b>NRTH1385-NRTHPORT_138_NNC</b>					FWD	REV
Tue 05/15/2018	to	Tue 05/22/2018	<u>EXTENDED</u>	<u>by LI</u> <u>05/17/2018</u>	SCH - NPX_1385	<b>0 MW</b> <b>0 MW</b>
0600	Continuous	1923			Impacts Total Transfer Capability	200 MW 200 MW
Work scheduled by: LI					TTC with All Lines In Service	200 MW 200 MW
<b>NRTH1385-NOR HBR_138_601 &amp; NRTH1385-NOR HBR_138_602</b>					FWD	REV
Tue 05/15/2018	to	Tue 05/22/2018			(Import)	(Export)
0600		1933			SCH - NPX_1385	<b>0 MW</b> <b>0 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	200 MW 200 MW
					TTC with All Lines In Service	200 MW 200 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 24, 2018 to Saturday ,November 23, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
<b>NRTH1385-NOR HBR__138_602</b>							
Tue 05/15/2018	to	Tue 05/22/2018	<b>EXTENDED</b>	<b>by LI</b>	<b>05/17/2018</b>		
0600	Continuous	1933				SCH - NPX_1385	<b>100 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR HBR__138_601</b>							
Tue 05/15/2018	to	Tue 05/22/2018	<b>EXTENDED</b>	<b>by LI</b>	<b>05/17/2018</b>		
0600	Continuous	1952				SCH - NPX_1385	<b>100 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
<b>MILLWOOD_345KV_18</b>						FWD	
Sat 05/19/2018	to	Sat 05/19/2018				(Import)	
0001	Continuous	0030				UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	1350 MW
						TTC with All Lines In Service	5700 MW
<b>MASSENA_-MARCY___765_MSU1</b>						FWD	
Sat 05/19/2018	to	Sat 05/19/2018	<b>UPDATED</b>	<b>by NYPA</b>	<b>05/16/2018</b>	(Import)	
2100	Continuous	2300				CENTRAL EAST - VC	<b>2265 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	710 MW
						TTC with All Lines In Service	2975 MW
<b>MASSENA_-MARCY___765_MSU1</b>						FWD	
Sat 05/19/2018	to	Sat 05/19/2018	<b>UPDATED</b>	<b>by NYPA</b>	<b>05/16/2018</b>	(Import)	
2100	Continuous	2300				MOSES SOUTH	<b>500 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	2650 MW
						TTC with All Lines In Service	3150 MW
<b>MASSENA_-MARCY___765_MSU1</b>						FWD	REV
Sat 05/19/2018	to	Sat 05/19/2018	<b>UPDATED</b>	<b>by NYPA</b>	<b>05/16/2018</b>	(Import)	(Export)
2100	Continuous	2300				SCH - HQ - NY	<b>475 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	1025 MW
						TTC with All Lines In Service	1500 MW
<b>SCH-HQ-NYISO_LIMIT_0</b>						FWD	
Sat 05/19/2018	to	Sat 05/19/2018	<b>UPDATED</b>	<b>by NYPA</b>	<b>05/16/2018</b>	(Import)	
2100	Continuous	2300				SCH - HQ - NY	<b>0 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	1500 MW
						TTC with All Lines In Service	1500 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 24, 2018 to Saturday ,November 23, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						REV
<b>SCH-NYISO-HQ_LIMIT_0</b>						(Export)
Sat 05/19/2018	to	Sat 05/19/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/16/2018</u>	
2100	Continuous	2300				SCH - HQ - NY
Work scheduled by: NYPA						Impacts Total Transfer Capability
						TTC with All Lines In Service
						0 MW
						1000 MW
						1000 MW
<hr/>						
<b>SPRNBK_345KV_RS3 &amp; SPRNBK_345KV_RS4</b>						FWD
						(Import)
Sun 05/20/2018	to	Sun 05/20/2018				SPR/DUN-SOUTH
2130		2200				<b>3200 MW</b>
Work scheduled by:						Impacts Total Transfer Capability
						TTC with All Lines In Service
						1400 MW
						4600 MW
<hr/>						
<b>SCH-HQ-NYISO_LIMIT_1400</b>						FWD
						(Import)
Mon 05/21/2018	to	Thu 05/24/2018	<u>UPDATED</u>	<u>by HQ</u>	<u>04/11/2018</u>	SCH - HQ - NY
0700	Continuous	2359				<b>1400 MW</b>
Work scheduled by: HQ						Impacts Total Transfer Capability
						TTC with All Lines In Service
						100 MW
						1500 MW
<hr/>						
<b>CLAY_-EDIC_345_1-16</b>						FWD
						(Import)
Mon 05/21/2018	to	Fri 05/25/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/01/2018</u>	OSWEGO EXPORT
0700	Continuous	1530				<b>4850 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability
						TTC with All Lines In Service
						400 MW
						5250 MW
<hr/>						
<b>MOSES_-ADIRNDCK_230_MA2</b>						FWD
						(Import)
Mon 05/21/2018	to	Fri 05/25/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/10/2018</u>	MOSES SOUTH
0700	Continuous	1730				<b>2100 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability
						TTC with All Lines In Service
						1050 MW
						3150 MW
<hr/>						
<b>FRASANNX-COOPERS_345_UCC2-41</b>						FWD
						(Import)
Mon 05/21/2018	to	Fri 06/01/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/10/2018</u>	CENTRAL EAST - VC
0700	Continuous	1730				<b>2500 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability
						TTC with All Lines In Service
						475 MW
						2975 MW
<hr/>						
<b>MARCY_-FRASANNX_345_UCC2-41</b>						FWD
						(Import)
Mon 05/21/2018	to	Fri 06/01/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/10/2018</u>	CENTRAL EAST - VC
0700	Continuous	1730				<b>2500 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability
						TTC with All Lines In Service
						475 MW
						2975 MW
<hr/>						
						ARR: 19

# NYISO TRANSFER LIMITATIONS

Thursday ,May 24, 2018 to Saturday ,November 23, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SCH-NYISO-NE_LIMIT_900</b>					REV	
Mon 05/21/2018	to	Mon 05/21/2018	<b>CANCELLED</b>	<b>by ISONE</b>	<b>05/20/2018</b>	(Export)
0730	Continuous	1859				<b>1100 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1600 MW
<b>FROST_BR-LONG_MTN_345_352</b>					FWD	REV
Mon 05/21/2018	to	Tue 05/22/2018	<b>CANCELLED</b>	<b>by ISONE</b>	<b>05/20/2018</b>	(Import) (Export)
0730	Continuous	1600				<b>1150 MW 1600 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability	250 MW 0 MW
					TTC with All Lines In Service	1400 MW 1600 MW
<b>SCH-NYISO-NE_LIMIT_1200</b>					REV	
Mon 05/21/2018	to	Tue 05/22/2018	<b>CANCELLED</b>	<b>by ISONE</b>	<b>05/20/2018</b>	(Export)
1900	Continuous	1600				<b>1400 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	1600 MW
<b>LADENTWN-BUCHAN_S_345_Y88</b>					FWD	REV
Tue 05/22/2018	to	Wed 05/23/2018	<b>UPDATED</b>	<b>by CONED</b>	<b>05/20/2018</b>	(Import)
0500	Continuous	0300				<b>4800 MW</b>
Work scheduled by: ORU					UPNY CONED	900 MW
					Impacts Total Transfer Capability	5700 MW
					TTC with All Lines In Service	5700 MW
<b>N.SCTLND-ALPS_____345_2 &amp; NRTH1385-NOR HBR__138_603</b>					FWD	REV
Tue 05/22/2018	to	Tue 05/22/2018				(Import) (Export)
0800		1923				<b>0 MW 0 MW</b>
Work scheduled by:					SCH - NPX_1385	200 MW 200 MW
					Impacts Total Transfer Capability	200 MW 200 MW
					TTC with All Lines In Service	200 MW 200 MW
<b>N.SCTLND-ALPS_____345_2 &amp; NRTH1385-NOR HBR__138_602</b>					FWD	REV
Tue 05/22/2018	to	Tue 05/22/2018				(Import) (Export)
0800		1933				<b>0 MW 0 MW</b>
Work scheduled by:					SCH - NPX_1385	200 MW 200 MW
					Impacts Total Transfer Capability	200 MW 200 MW
					TTC with All Lines In Service	200 MW 200 MW
<b>N.SCTLND-ALPS_____345_2 &amp; NRTH1385-NOR HBR__138_601</b>					FWD	REV
Tue 05/22/2018	to	Tue 05/22/2018				(Import) (Export)
0800		1952				<b>0 MW 0 MW</b>
Work scheduled by:					SCH - NPX_1385	200 MW 200 MW
					Impacts Total Transfer Capability	200 MW 200 MW
					TTC with All Lines In Service	200 MW 200 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 24, 2018 to Saturday ,November 23, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
<b>N. SCTLND-ALPS</b> _____ <b>345_2</b>		FWD	REV
Tue 05/22/2018 to Thu 05/24/2018		(Import)	(Export)
0800 Continuous 1500		<b>SCH - NE - NY</b>	<b>750 MW 1350 MW</b>
Work scheduled by: NGrid		Impacts Total Transfer Capability	650 MW 250 MW
		TTC with All Lines In Service	1400 MW 1600 MW
<hr/>			
<b>N. SCTLND-ALPS</b> _____ <b>345_2</b>		FWD	REV
Tue 05/22/2018 to Thu 05/24/2018		(Import)	(Export)
0800 Continuous 1500		<b>SCH - NPX_1385</b>	<b>100 MW 100 MW</b>
Work scheduled by: NGrid		Impacts Total Transfer Capability	100 MW 100 MW
		TTC with All Lines In Service	200 MW 200 MW
<hr/>			
<b>DENNINGSON-NORFOLK</b> _____ <b>115_4</b>		FWD	REV
Tue 05/22/2018 to Tue 05/22/2018	<b><u>CANCELLED by NGrid 05/22/2018</u></b>	(Import)	(Export)
0815 Daily(No Weekends) 1615		<b>SCH - HQ_CEDARS</b>	<b>150 MW 40 MW</b>
Work scheduled by: NGrid	<b>ARR: 38</b>	Impacts Total Transfer Capability	40 MW 0 MW
		TTC with All Lines In Service	190 MW 40 MW
<hr/>			
<b>BECK</b> _____ <b>-NIAGARA</b> _____ <b>345_PA302</b>		FWD	REV
Wed 05/23/2018 to Thu 05/24/2018		(Import)	(Export)
0500 Continuous 1800		<b>SCH - OH - NY</b>	<b>900 MW 800 MW</b>
Work scheduled by: IESO		Impacts Total Transfer Capability	1100 MW 800 MW
		TTC with All Lines In Service	2000 MW 1600 MW
<hr/>			
<b>SCH-NE-NYISO_LIMIT_400</b>		FWD	
Wed 05/23/2018 to Thu 05/24/2018	<b><u>CANCELLED by ISONE 05/22/2018</u></b>	(Import)	
0700 Continuous 1500		<b>SCH - NE - NY</b>	<b>600 MW</b>
Work scheduled by: ISONE		Impacts Total Transfer Capability	800 MW
		TTC with All Lines In Service	1400 MW
<hr/>			
<b>SCH-NYISO-NE_LIMIT_700</b>			REV
Wed 05/23/2018 to Thu 05/24/2018	<b><u>CANCELLED by ISONE 05/22/2018</u></b>		(Export)
0700 Continuous 1500		<b>SCH - NE - NY</b>	<b>900 MW</b>
Work scheduled by: ISONE		Impacts Total Transfer Capability	700 MW
		TTC with All Lines In Service	1600 MW
<hr/>			
<b>SCH-NYISO-HQ_LIMIT_800</b>			REV
Fri 05/25/2018 to Thu 05/31/2018			(Export)
0001 Continuous 1600		<b>SCH - HQ - NY</b>	<b>800 MW</b>
Work scheduled by: HQ		Impacts Total Transfer Capability	200 MW
		TTC with All Lines In Service	1000 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 24, 2018 to Saturday ,November 23, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

WOOD\_ST\_-PLSNTVLE\_345\_Y87

Fri 05/25/2018 to Fri 05/25/2018  
 0301 Continuous 0330  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

DUNWODIE\_345KV\_6

Fri 05/25/2018 to Fri 05/25/2018  
 0301 Continuous 1830  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

DUNWODIE\_345KV\_8

Fri 05/25/2018 to Fri 05/25/2018  
 0301 Continuous 1830  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

PLSNTVLE-DUNWODIE\_345\_W90

Fri 05/25/2018 to Fri 05/25/2018  
 0301 Continuous 1830  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

WOOD\_ST\_-PLSNTVLE\_345\_Y87

Fri 05/25/2018 to Fri 05/25/2018  
 1800 Continuous 1830  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

PLSNTVLE-DUNWODIE\_345\_W89

Sat 05/26/2018 to Sat 05/26/2018  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

WOOD\_ST\_-PLSNTVLE\_345\_Y86

Sat 05/26/2018 to Sat 05/26/2018  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 24, 2018 to Saturday ,November 23, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>EFISHKIL-WOOD_ST__345_F38</b>				FWD
Sat 05/26/2018	to	Sat 05/26/2018		(Import)
0001	Continuous	2330	UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 1700 MW
				TTC with All Lines In Service 5700 MW
<b>PLSNTVLE-DUNWODIE_345_W89</b>				FWD
Sat 05/26/2018	to	Sat 05/26/2018		(Import)
2300	Continuous	2330	UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 1700 MW
				TTC with All Lines In Service 5700 MW
<b>WOOD_ST_-PLSNTVLE_345_Y86</b>				FWD
Sat 05/26/2018	to	Sat 05/26/2018		(Import)
2300	Continuous	2330	UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 1700 MW
				TTC with All Lines In Service 5700 MW
<b>EASTVIEW-SPRNBRK__345_W78</b>				FWD
Mon 05/28/2018	to	Tue 05/29/2018	<b><u>UPDATED</u> by CONED 05/16/2018</b>	(Import)
0300	Continuous	0200	UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 1350 MW
				TTC with All Lines In Service 5700 MW
<b>MILLWOOD-EASTVIEW_345_W85</b>				FWD
Mon 05/28/2018	to	Tue 05/29/2018	<b><u>UPDATED</u> by CONED 05/16/2018</b>	(Import)
0300	Continuous	0200	UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 1350 MW
				TTC with All Lines In Service 5700 MW
<b>SPRNBRK__345KV_RNS3</b>				FWD
Mon 05/28/2018	to	Tue 05/29/2018	<b><u>UPDATED</u> by CONED 05/16/2018</b>	(Import)
0300	Continuous	0200	SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
<b>SCH-NE-NYISO_LIMIT_400</b>				FWD
Mon 05/28/2018	to	Mon 05/28/2018		(Import)
0600	Continuous	1800	SCH - NE - NY	<b>600 MW</b>
Work scheduled by: ISONE				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 1400 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 24, 2018 to Saturday ,November 23, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-NE_LIMIT_1100				REV
Mon 05/28/2018	to	Mon 05/28/2018		(Export)
0600	Continuous	1800	SCH - NE - NY	<b>1300 MW</b>
Work scheduled by: ISONE				Impacts Total Transfer Capability 300 MW
				TTC with All Lines In Service 1600 MW
SCH-IMO-NYISO_LIMIT_1000				FWD
Tue 05/29/2018	to	Fri 06/01/2018	<u>UPDATED</u> <u>by NYISO</u> <u>05/15/2018</u>	(Import)
0500	Continuous	1700	SCH - OH - NY	<b>1300 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability 700 MW
				TTC with All Lines In Service 2000 MW
STLAWRNC-MOSES___230_L33P				FWD REV
Tue 05/29/2018	to	Fri 06/01/2018	<u>CANCELLED</u> <u>by NYPA</u> <u>05/24/2018</u>	(Import) (Export)
0700	Continuous	2000	SCH - OH - NY	<b>2000 MW 1600 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability 0 MW 0 MW
				TTC with All Lines In Service 2000 MW 1600 MW
BROWNFLS-TAYLORVL_115_4				FWD REV
Tue 05/29/2018	to	Sat 06/02/2018		(Import) (Export)
0700	Continuous	1800	SCH - HQ_CEDARS	<b>70 MW 40 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability 120 MW 0 MW
<b>ARR: 38</b>				TTC with All Lines In Service 190 MW 40 MW
NEPTUNE_-DUFFYAVE_345_NEPTUNE				FWD
Wed 05/30/2018	to	Wed 05/30/2018		(Import)
0600	Continuous	1000	SCH - PJM_NEPTUNE	<b>0 MW</b>
Work scheduled by: LI				Impacts Total Transfer Capability 660 MW
				TTC with All Lines In Service 660 MW
NEWBRDGE-DUFFYAVE_345_501				FWD
Wed 05/30/2018	to	Wed 05/30/2018		(Import)
0600	Continuous	1000	SCH - PJM_NEPTUNE	<b>0 MW</b>
Work scheduled by: LI				Impacts Total Transfer Capability 660 MW
				TTC with All Lines In Service 660 MW
NEWBRDGE_345_138_BK_1				FWD
Wed 05/30/2018	to	Wed 05/30/2018		(Import)
0600	Continuous	1000	SCH - PJM_NEPTUNE	<b>375 MW</b>
Work scheduled by: LI				Impacts Total Transfer Capability 285 MW
				TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 24, 2018 to Saturday ,November 23, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event Name	Start Date	End Date	Time	Duration	Work Scheduled by	ARR	SCH	FWD	REV
<b>NEWBRDGE_345_138_BK_2</b>	Wed 05/30/2018	Wed 05/30/2018	0600	Continuous	LI		PJM_NEPTUNE	(Import)	
				1000				<b>375 MW</b>	
							Impacts Total Transfer Capability	285 MW	
							TTC with All Lines In Service	660 MW	
<b>DENNISON-ROSEMNTB_115_2/22</b>	Thu 05/31/2018	Thu 05/31/2018	0800	Daily(No Weekends)	NGrid	<b>38</b>	HQ_CEDARS	(Import)	(Export)
				1630				<b>95 MW</b>	<b>40 MW</b>
							Impacts Total Transfer Capability	95 MW	0 MW
							TTC with All Lines In Service	190 MW	40 MW
<b>MARCY_SO_SERIES_COMP_I/S</b>	Fri 06/01/2018	Wed 10/31/2018	1800	Continuous	NYISO		CENTRAL EAST - VC	(Import)	
				2359				<b>2740 MW</b>	
							Impacts Total Transfer Capability	235 MW	
							TTC with All Lines In Service	2975 MW	
<b>SCH-IMO_NY_NIAG_CB_3122_W/BB</b>	Sat 06/02/2018	Sat 06/02/2018	0500	Continuous	NYPA		OH - NY	(Import)	(Export)
				1700				<b>1700 MW</b>	<b>1400 MW</b>
							Impacts Total Transfer Capability	300 MW	200 MW
							TTC with All Lines In Service	2000 MW	1600 MW
<b>SCH-NYISO-HQ_LIMIT_800</b>	Sat 06/02/2018	Sat 06/02/2018	0700	Continuous	HQ		HQ - NY	(Export)	
				1800				<b>800 MW</b>	
							Impacts Total Transfer Capability	200 MW	
							TTC with All Lines In Service	1000 MW	
<b>BROWNFLS-TAYLORVL_115_3</b>	Mon 06/04/2018	Sat 06/09/2018	0700	Continuous	NGrid	<b>38</b>	HQ_CEDARS	(Import)	(Export)
				1800				<b>70 MW</b>	<b>40 MW</b>
							Impacts Total Transfer Capability	120 MW	0 MW
							TTC with All Lines In Service	190 MW	40 MW
<b>LEEDS_345_LEEDS SVC</b>	Mon 06/04/2018	Fri 06/15/2018	0800	Continuous	NGrid		CENTRAL EAST - VC	(Import)	
				1500				<b>2950 MW</b>	
							Impacts Total Transfer Capability	25 MW	
							TTC with All Lines In Service	2975 MW	

# NYISO TRANSFER LIMITATIONS

Thursday ,May 24, 2018 to Saturday ,November 23, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**LEEDS\_\_\_345\_LEEDS SVC & MARCY\_SO\_SERIES\_COMP\_I/S**

Mon 06/04/2018 to Fri 06/15/2018  
0800 1500

Work scheduled by:

FWD  
(Import)  
CENTRAL EAST - VC **2715 MW**  
Impacts Total Transfer Capability 260 MW  
TTC with All Lines In Service 2975 MW

**SCH-NYISO-HQ\_LIMIT\_800**

Mon 06/04/2018 to Mon 06/04/2018  
0830 Continuous 1830

Work scheduled by: HQ

REV  
(Export)  
SCH - HQ - NY **800 MW**  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 1000 MW

**BROWNFLS-TAYLORVL\_115\_4**

Mon 06/11/2018 to Sat 06/16/2018  
0700 Continuous 1800

Work scheduled by: NGrid

**ARR: 38**

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS **70 MW 40 MW**  
Impacts Total Transfer Capability 120 MW 0 MW  
TTC with All Lines In Service 190 MW 40 MW

**NIAGARA\_-ROCHESTR\_345\_NR2**

Mon 06/18/2018 to Thu 06/21/2018  
0500 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

**BROWNFLS-TAYLORVL\_115\_3**

Mon 06/18/2018 to Sat 06/23/2018  
0700 Continuous 1800

Work scheduled by: NGrid

**ARR: 38**

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS **70 MW 40 MW**  
Impacts Total Transfer Capability 120 MW 0 MW  
TTC with All Lines In Service 190 MW 40 MW

**S.RIPLEY-DUNKIRK\_230\_68**

Fri 06/22/2018 to Sat 02/01/2020  
2000 Continuous 0000

Work scheduled by: NYISO

**UPDATED by NYISO 05/14/2018**

FWD REV  
(Import) (Export)  
SCH - PJ - NY **1950 MW 1350 MW**  
Impacts Total Transfer Capability 150 MW 0 MW  
TTC with All Lines In Service 2100 MW 1350 MW

**SCH-NYISO-IMO\_NIAGARA\_CB\_3022**

Thu 06/28/2018 to Thu 06/28/2018  
0500 Continuous 1700

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **1300 MW 1150 MW**  
Impacts Total Transfer Capability 700 MW 450 MW  
TTC with All Lines In Service 2000 MW 1600 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 24, 2018 to Saturday ,November 23, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARCY\_\_\_765\_345\_AT1** FWD  
 (Import)  
 Sat 08/04/2018 to Sun 08/05/2018 **UPDATED by NYPA 04/17/2018**  
 0500 Continuous 1730  
 Work scheduled by: NYPA **ARR: 19**  
 MOSES SOUTH **1750 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 3150 MW

**MARCY\_\_\_765\_345\_AT2** FWD  
 (Import)  
 Tue 09/04/2018 to Sun 09/09/2018  
 0500 Continuous 1730  
 Work scheduled by: NYPA **ARR: 19**  
 MOSES SOUTH **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

**CLRKSCRN-OAKDALE\_\_345\_36** FWD  
 (Import)  
 Thu 09/06/2018 to Fri 09/07/2018  
 0700 Continuous 1530  
 Work scheduled by: NYSEG  
 CENTRAL EAST - VC **2650 MW**  
 Impacts Total Transfer Capability 325 MW  
 TTC with All Lines In Service 2975 MW

**FRASER\_-GILBOA\_\_345\_GF5-35** FWD  
 (Import)  
 Mon 09/10/2018 to Fri 10/05/2018  
 0700 Continuous 1730  
 Work scheduled by: NYPA  
 CENTRAL EAST - VC **2650 MW**  
 Impacts Total Transfer Capability 325 MW  
 TTC with All Lines In Service 2975 MW

**ROSETON\_-ROCKTVRN\_345\_311** FWD  
 (Import)  
 Mon 09/10/2018 to Fri 09/28/2018  
 0800 Continuous 1600  
 Work scheduled by: CHGE  
 UPNY CONED **4400 MW**  
 Impacts Total Transfer Capability 1300 MW  
 TTC with All Lines In Service 5700 MW

**MARCY\_\_\_345KV\_CSC** FWD  
 (Import)  
 Tue 09/11/2018 to Tue 09/11/2018  
 0500 Continuous 1730  
 Work scheduled by: NYPA  
 CENTRAL EAST - VC **2925 MW**  
 Impacts Total Transfer Capability 50 MW  
 TTC with All Lines In Service 2975 MW

**MARCY\_\_\_345KV\_CSC & MARCY\_SO\_SERIES\_COMP\_I/S** FWD  
 (Import)  
 Tue 09/11/2018 to Tue 09/11/2018  
 0500 1730  
 Work scheduled by:  
 CENTRAL EAST - VC **2690 MW**  
 Impacts Total Transfer Capability 285 MW  
 TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 24, 2018 to Saturday ,November 23, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARCY\_\_\_765\_345\_AT2**

Tue 09/11/2018 to Tue 09/11/2018  
0500 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

**NIAGARA\_345\_230\_AT4**

Fri 09/14/2018 to Fri 09/14/2018  
0500 Continuous 1700

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **2000 MW 1400 MW**  
Impacts Total Transfer Capability 0 MW 200 MW  
TTC with All Lines In Service 2000 MW 1600 MW

**DUNWODIE-MOTTHAVN\_345\_71**

Sat 09/15/2018 to Mon 09/17/2018  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_3**

Sat 09/15/2018 to Mon 09/17/2018  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_5**

Sat 09/15/2018 to Mon 09/17/2018  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**NIAGARA\_-ROCHESTR\_345\_NR2**

Mon 09/17/2018 to Fri 09/21/2018  
0500 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

**MOSES\_-ADIRNDCK\_230\_MAL**

Mon 09/17/2018 to Fri 09/21/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 24, 2018 to Saturday ,November 23, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA__345_230_AT4			FWD	REV
			(Import)	(Export)
Mon 09/24/2018	to	Fri 09/28/2018		
0500	Continuous	1700	SCH - OH - NY	<b>2000 MW</b> <b>1400 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	0 MW 200 MW
			TTC with All Lines In Service	2000 MW 1600 MW
MOSES__-ADIRNDCK_230_MAI			FWD	
			(Import)	
Mon 09/24/2018	to	Fri 09/28/2018		
0700	Continuous	1530	MOSES SOUTH	<b>2100 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	1050 MW
			TTC with All Lines In Service	3150 MW
CLAY__-EDIC__345_2-15			FWD	
			(Import)	
Mon 09/24/2018	to	Fri 09/28/2018		
0700	Continuous	1700	OSWEGO EXPORT	<b>4850 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	400 MW
			TTC with All Lines In Service	5250 MW
WATRCURE_345_230_BK 1			FWD	REV
			(Import)	(Export)
Mon 09/24/2018	to	Thu 09/27/2018		
0800	Continuous	1530	SCH - PJ - NY	<b>2100 MW</b> <b>1350 MW</b>
Work scheduled by: NYSEG			Impacts Total Transfer Capability	0 MW 0 MW
			TTC with All Lines In Service	2100 MW 1350 MW
BECK__-NIAGARA_345_PA302			FWD	REV
			(Import)	(Export)
Mon 10/01/2018	to	Fri 10/05/2018		
0500	Continuous	1700	SCH - OH - NY	<b>900 MW</b> <b>800 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	1100 MW 800 MW
			TTC with All Lines In Service	2000 MW 1600 MW
MOSES__-ADIRNDCK_230_MA2			FWD	
			(Import)	
Mon 10/01/2018	to	Wed 10/03/2018		
0700	Continuous	1530	MOSES SOUTH	<b>2100 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	1050 MW
			TTC with All Lines In Service	3150 MW
PANNELL_-CLAY__345_1			FWD	
			(Import)	
Mon 10/01/2018	to	Fri 10/05/2018		
0700	Continuous	1700	WEST CENTRAL	<b>1300 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	950 MW
			TTC with All Lines In Service	2250 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 24, 2018 to Saturday ,November 23, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event ID	Start Date	End Date	Time	Duration	Work by	Transfer Type	Impact	TTC
HUDSONP_-FARRAGUT_345_B3402	Tue 10/02/2018	Tue 11/13/2018	0001	Continuous	2359	PJM	SCH - PJ - NY	2100 MW
							Impacts Total Transfer Capability	0 MW
							TTC with All Lines In Service	2100 MW
MARCY_765_345_AT2	Thu 10/04/2018	Fri 10/05/2018	0500	Continuous	1730	NYPA	MOSES SOUTH	1700 MW
							Impacts Total Transfer Capability	1450 MW
							TTC with All Lines In Service	3150 MW
MOSES_-ADIRNDCK_230_MA1	Mon 10/08/2018	Fri 10/12/2018	0700	Continuous	1530	NYPA	MOSES SOUTH	2100 MW
							Impacts Total Transfer Capability	1050 MW
							TTC with All Lines In Service	3150 MW
CHAT_DC_GC2	Mon 10/08/2018	Fri 11/23/2018	0700	Continuous	1700	HQ	MOSES SOUTH	2850 MW
							Impacts Total Transfer Capability	300 MW
							TTC with All Lines In Service	3150 MW
CHAT_DC_GC2	Mon 10/08/2018	Fri 11/23/2018	0700	Continuous	1700	HQ	SCH - HQ - NY	500 MW
							Impacts Total Transfer Capability	500 MW
							TTC with All Lines In Service	1000 MW
CHATGUAY-MASSENA_765_7040	Sat 10/13/2018	Sat 10/27/2018	0100	Continuous	1730	NYPA	MOSES SOUTH	1550 MW
							Impacts Total Transfer Capability	1600 MW
							TTC with All Lines In Service	3150 MW
CHATGUAY-MASSENA_765_7040	Sat 10/13/2018	Sat 10/27/2018	0100	Continuous	1730	NYPA	SCH - HQ - NY	0 MW
							Impacts Total Transfer Capability	1500 MW
							TTC with All Lines In Service	1500 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 24, 2018 to Saturday ,November 23, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MARCY___765_345_AT1</b>		FWD	
Sat 10/13/2018	to Sat 10/27/2018	(Import)	
0100	Continuous 1730	MOSES SOUTH	<b>1750 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability	1400 MW
		TTC with All Lines In Service	3150 MW
<b>MARCY___765_345_AT2</b>		FWD	
Sat 10/13/2018	to Sat 10/27/2018	(Import)	
0100	Continuous 1730	MOSES SOUTH	<b>1700 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability	1450 MW
		TTC with All Lines In Service	3150 MW
<b>MASSENA_-MARCY___765_MSU1</b>		FWD	
Sat 10/13/2018	to Sat 10/27/2018	(Import)	
0100	Continuous 1730	CENTRAL EAST - VC	<b>2265 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability	710 MW
		TTC with All Lines In Service	2975 MW
<b>MASSENA_-MARCY___765_MSU1</b>		FWD	
Sat 10/13/2018	to Sat 10/27/2018	(Import)	
0100	Continuous 1730	MOSES SOUTH	<b>500 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability	2650 MW
		TTC with All Lines In Service	3150 MW
<b>MASSENA_-MARCY___765_MSU1</b>		FWD	
Sat 10/13/2018	to Sat 10/27/2018	(Import) (Export)	
0100	Continuous 1730	SCH - HQ - NY	<b>475 MW 1000 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability	1025 MW 0 MW
		TTC with All Lines In Service	1500 MW 1000 MW
<b>MASSENA_-MARCY___765_MSU1 &amp; CHATGUAY-MASSENA_765_7040</b>		FWD	
Sat 10/13/2018	to Sat 10/27/2018	(Import)	
0100	1730	MOSES SOUTH	<b>500 MW</b>
Work scheduled by:		Impacts Total Transfer Capability	2650 MW
		TTC with All Lines In Service	3150 MW
<b>MASSENA_-MARCY___765_MSU1 &amp; MARCY_SO_SERIES_COMP_I/S</b>		FWD	
Sat 10/13/2018	to Sat 10/27/2018	(Import)	
0100	1730	CENTRAL EAST - VC	<b>2080 MW</b>
Work scheduled by:		Impacts Total Transfer Capability	895 MW
		TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 24, 2018 to Saturday ,November 23, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**MOSES -MASSENA\_230\_MMS1 & MOSES -MASSENA\_230\_MMS2**

Sat 10/13/2018 to Sat 10/27/2018  
 0100 1730

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	<b>850 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	650 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

-----  
**STONYRDG-HILLSIDE\_230\_72**

Wed 10/17/2018 to Thu 10/18/2018  
 0800 Continuous 1530

Work scheduled by: NYSEG

	FWD
	(Import)
DYSINGER EAST	<b>2850 MW</b>
Impacts Total Transfer Capability	300 MW
TTC with All Lines In Service	3150 MW

-----  
**LINDN\_CG-LNDVFT\_345\_V-3022**

Mon 10/22/2018 to Thu 10/25/2018  
 0800 Continuous 1500

Work scheduled by: PJM

	FWD	REV
	(Import)	(Export)
SCH - PJM_VFT	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

-----  
**LEEDS -HURLYAVE\_345\_301**

Mon 10/22/2018 to Fri 11/16/2018  
 0800 Continuous 1600

Work scheduled by: CHGE

	FWD
	(Import)
UPNY CONED	<b>4100 MW</b>
Impacts Total Transfer Capability	1600 MW
TTC with All Lines In Service	5700 MW

-----  
**KINTIGH -ROCHESTR\_345\_SRL-39**

Mon 10/29/2018 to Fri 11/02/2018  
 0500 Continuous 1700

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	<b>1700 MW</b>
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

-----  
**MOSES -ADIRNDCK\_230\_MA1**

Mon 10/29/2018 to Fri 11/02/2018  
 0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>2100 MW</b>
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	3150 MW

-----  
**NEPTUNE -DUFFYAVE\_345\_NEPTUNE**

Sat 11/03/2018 to Sun 11/18/2018  
 0001 Continuous 1800

Work scheduled by: LI

	FWD
	(Import)
SCH - PJM_NEPTUNE	<b>0 MW</b>
Impacts Total Transfer Capability	660 MW
TTC with All Lines In Service	660 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 24, 2018 to Saturday ,November 23, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>NEWBRDGE-DUFFYAVE_345_501</b>			FWD	
Sat 11/03/2018	to	Sun 11/18/2018	(Import)	
0001	Continuous	1800	SCH - PJM_NEPTUNE	<b>0 MW</b>
Work scheduled by: LI			Impacts Total Transfer Capability	660 MW
			TTC with All Lines In Service	660 MW
<b>NEWBRDGE_345_138_BK_1</b>			FWD	
Sat 11/03/2018	to	Sun 11/18/2018	(Import)	
0001	Continuous	1800	SCH - PJM_NEPTUNE	<b>375 MW</b>
Work scheduled by: LI			Impacts Total Transfer Capability	285 MW
			TTC with All Lines In Service	660 MW
<b>NEWBRDGE_345_138_BK_2</b>			FWD	
Sat 11/03/2018	to	Sun 11/18/2018	(Import)	
0001	Continuous	1800	SCH - PJM_NEPTUNE	<b>375 MW</b>
Work scheduled by: LI			Impacts Total Transfer Capability	285 MW
			TTC with All Lines In Service	660 MW
<b>MOSES__-ADIRNDCK_230_MA1</b>			FWD	
Mon 11/05/2018	to	Fri 11/09/2018	(Import)	
0700	Continuous	1530	MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW
			TTC with All Lines In Service	3150 MW
<b>FROST_BR-LONG_MTN_345_352</b>			FWD	REV
Sun 11/11/2018	to	Sun 11/11/2018	(Import)	(Export)
0700	Continuous	1800	SCH - NE - NY	<b>1300 MW 1600 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW 0 MW
			TTC with All Lines In Service	1400 MW 1600 MW
<b>SCH-NE-NYISO_LIMIT_1000</b>			FWD	
Sun 11/11/2018	to	Sun 11/11/2018	(Import)	
0700	Continuous	1800	SCH - NE - NY	<b>1200 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	200 MW
			TTC with All Lines In Service	1400 MW
<b>MARCY__345KV_CSC</b>			FWD	
Fri 11/16/2018	to	Sat 11/17/2018	(Import)	
0500	Continuous	1730	CENTRAL EAST - VC	<b>2925 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	50 MW
			TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 24, 2018 to Saturday ,November 23, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARCY\_\_\_765\_345\_AT2**

Fri 11/16/2018 to Sat 11/17/2018  
0500 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

Mon 11/19/2018 to Wed 11/21/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Mon 11/26/2018 to Fri 11/30/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**HURLYAVE-ROSETON\_\_345\_303**

Mon 11/26/2018 to Fri 12/21/2018  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 5700 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Mon 12/03/2018 to Fri 12/07/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Mon 12/10/2018 to Fri 12/14/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**MARCY\_\_\_765\_345\_AT2**

Mon 12/17/2018 to Fri 12/21/2018  
0500 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 24, 2018 to Saturday ,November 23, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**MOSES\_\_\_-ADIRNDCK\_230\_MAL**

Wed 12/26/2018 to Fri 12/28/2018  
 0700 Continuous 1530

Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

-----  
**LEEDS\_\_\_345\_LEEDS SVC**

Mon 03/11/2019 to Fri 03/22/2019  
 0800 Continuous 1600

Work scheduled by: NGrid

FWD  
 (Import)  
 CENTRAL EAST - VC **2950 MW**  
 Impacts Total Transfer Capability 25 MW  
 TTC with All Lines In Service 2975 MW