

NYISO TRANSFER LIMITATIONS

Saturday ,May 26, 2018 to Monday ,November 25, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

E13THSTA-FARRAGUT_345_45					FWD	
Sun 11/26/2017	to	Fri 05/25/2018	<u>UPDATED</u>	<u>by CONED</u>	<u>05/22/2018</u>	(Import)
0001	Continuous	0819				3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW	
					TTC with All Lines In Service 4600 MW	
W49TH_ST-E13THSTA_345_M54					FWD	
Sun 11/26/2017	to	Thu 05/31/2018	<u>UPDATED</u>	<u>by CONED</u>	<u>05/22/2018</u>	(Import)
0001	Continuous	2359				3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW	
					TTC with All Lines In Service 4600 MW	
HUDSONP_-FARRAGUT_345_B3402					FWD	
Mon 01/15/2018	to	Sat 06/30/2018	<u>EXT FORCE</u>	<u>by CE</u>	<u>05/22/2018</u>	(Import) (Export)
0001	Continuous	2359				2100 MW 1350 MW
Work scheduled by: ConEd					SCH - PJ - NY	
					Impacts Total Transfer Capability 0 MW 0 MW	
					TTC with All Lines In Service 2100 MW 1350 MW	
HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403					FWD	
Mon 01/15/2018	to	Sat 06/30/2018				(Import) (Export)
0001		2359				2050 MW 1300 MW
Work scheduled by:					SCH - PJ - NY	
					Impacts Total Transfer Capability 50 MW 50 MW	
					TTC with All Lines In Service 2100 MW 1350 MW	
MARION_-FARRAGUT_345_C3403					FWD	
Mon 01/15/2018	to	Sat 06/30/2018	<u>EXT FORCE</u>	<u>by CE</u>	<u>05/22/2018</u>	(Import) (Export)
0001	Continuous	2359				2100 MW 1350 MW
Work scheduled by: ConEd					SCH - PJ - NY	
					Impacts Total Transfer Capability 0 MW 0 MW	
					TTC with All Lines In Service 2100 MW 1350 MW	
S.RIPLEY-DUNKIRK_230_68					FWD	
Wed 02/07/2018	to	Mon 06/04/2018	<u>UPDATED</u>	<u>by NYISO</u>	<u>05/14/2018</u>	(Import) (Export)
1629	Continuous	2000				1950 MW 1350 MW
Work scheduled by: NYISO					SCH - PJ - NY	
					Impacts Total Transfer Capability 150 MW 0 MW	
					TTC with All Lines In Service 2100 MW 1350 MW	
CHAT_DC_GC1					FWD	
Sat 04/14/2018	to	Wed 05/23/2018	<u>UPDATED</u>	<u>by HQ</u>	<u>04/11/2018</u>	(Import)
0100	Continuous	1510				2850 MW
Work scheduled by: HQ					MOSES SOUTH	
					Impacts Total Transfer Capability 300 MW	
					TTC with All Lines In Service 3150 MW	

NYISO TRANSFER LIMITATIONS

Saturday ,May 26, 2018 to Monday ,November 25, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC1						REV	
Sat 04/14/2018	to	Wed 05/23/2018	UPDATED	by HQ	04/11/2018	SCH - HQ - NY	(Export)
0100	Continuous	1510				Impacts Total Transfer Capability	500 MW
Work scheduled by: HQ						TTC with All Lines In Service	1000 MW
STLAWRNC-MOSES 230_L33P						FWD	REV
Mon 04/30/2018	to	Fri 07/27/2018	EXT FORCE	by IESO	05/11/2018	SCH - OH - NY	(Import) (Export)
0456	Continuous	1600				Impacts Total Transfer Capability	2000 MW 1600 MW
Work scheduled by: IESO						TTC with All Lines In Service	2000 MW 1600 MW
SCH-HQ-NYISO_LIMIT_1200						FWD	
Thu 05/10/2018	to	Thu 05/24/2018				SCH - HQ - NY	(Import)
1500	Continuous	2346				Impacts Total Transfer Capability	1200 MW
Work scheduled by: HQ						TTC with All Lines In Service	300 MW 1500 MW
ERIE E -S.RIPLEY_230_69 & WETHSRFD-S.PERRY_230_85						FWD	
Sat 05/12/2018	to	Fri 06/01/2018				DYSINGER EAST	(Import)
0700		1500				Impacts Total Transfer Capability	2850 MW
Work scheduled by:						TTC with All Lines In Service	300 MW 3150 MW
S.PERRY_-MEYER_230_87						FWD	
Sat 05/12/2018	to	Fri 06/01/2018	UPDATED	by NYSEG	02/15/2018	DYSINGER EAST	(Import)
0700	Continuous	1500				Impacts Total Transfer Capability	2850 MW
Work scheduled by: NYSEG						TTC with All Lines In Service	300 MW 3150 MW
WETHSRFD-S.PERRY_230_85						FWD	
Sat 05/12/2018	to	Fri 06/01/2018	UPDATED	by NYSEG	02/15/2018	DYSINGER EAST	(Import)
0700	Continuous	1500				Impacts Total Transfer Capability	2850 MW
Work scheduled by: NYSEG						TTC with All Lines In Service	300 MW 3150 MW
SCH-NE-NYISO_LIMIT_400						FWD	
Mon 05/14/2018	to	Mon 05/21/2018	UPDATED	by ISONE	05/11/2018	SCH - NE - NY	(Import)
1500	Continuous	1859				Impacts Total Transfer Capability	600 MW
Work scheduled by: ISONE						TTC with All Lines In Service	800 MW 1400 MW

NYISO TRANSFER LIMITATIONS

Saturday ,May 26, 2018 to Monday ,November 25, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-NE_LIMIT_1100					REV	
Mon 05/14/2018	to	Mon 05/21/2018	UPDATED	by ISONE	05/11/2018	(Export)
1500	Continuous	1859				1300 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	1600 MW
NRTH1385-NOR HBR_138_601 & NRTH1385-NOR HBR_138_603					FWD	REV
Tue 05/15/2018	to	Tue 05/22/2018				(Import) (Export)
0600		1923				0 MW 0 MW
Work scheduled by:					Impacts Total Transfer Capability	200 MW 200 MW
					TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR_138_602 & NRTH1385-NOR HBR_138_603					FWD	REV
Tue 05/15/2018	to	Tue 05/22/2018				(Import) (Export)
0600		1923				0 MW 0 MW
Work scheduled by:					Impacts Total Transfer Capability	200 MW 200 MW
					TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR_138_603					FWD	REV
Tue 05/15/2018	to	Tue 05/22/2018	EXTENDED	by LI	05/17/2018	(Import) (Export)
0600	Continuous	1923				100 MW 100 MW
Work scheduled by: LI					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NRTHPORT_138_NNC					FWD	REV
Tue 05/15/2018	to	Tue 05/22/2018	EXTENDED	by LI	05/17/2018	(Import) (Export)
0600	Continuous	1923				0 MW 0 MW
Work scheduled by: LI					Impacts Total Transfer Capability	200 MW 200 MW
					TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR_138_601 & NRTH1385-NOR HBR_138_602					FWD	REV
Tue 05/15/2018	to	Tue 05/22/2018				(Import) (Export)
0600		1933				0 MW 0 MW
Work scheduled by:					Impacts Total Transfer Capability	200 MW 200 MW
					TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR_138_602					FWD	REV
Tue 05/15/2018	to	Tue 05/22/2018	EXTENDED	by LI	05/17/2018	(Import) (Export)
0600	Continuous	1933				100 MW 100 MW
Work scheduled by: LI					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW

NYISO TRANSFER LIMITATIONS

Saturday ,May 26, 2018 to Monday ,November 25, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
NRTH1385-NOR HBR__138_601							
Tue 05/15/2018	to	Tue 05/22/2018	<u>EXTENDED</u>	<u>by LI</u>	<u>05/17/2018</u>		
0600	Continuous	1952				SCH - NPX_1385	100 MW
Work scheduled by: LI						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
SCH-HQ-NYISO_LIMIT_1400						FWD	
Mon 05/21/2018	to	Thu 05/24/2018	<u>UPDATED</u>	<u>by HQ</u>	<u>04/11/2018</u>	(Import)	
0700	Continuous	2359				SCH - HQ - NY	1400 MW
Work scheduled by: HQ						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	1500 MW
CLAY__-EDIC__345_1-16						FWD	
Mon 05/21/2018	to	Fri 05/25/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/01/2018</u>	(Import)	
0700	Continuous	1530				OSWEGO EXPORT	4850 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	400 MW
						TTC with All Lines In Service	5250 MW
MOSES__-ADIRNDCK_230_MA2						FWD	
Mon 05/21/2018	to	Fri 05/25/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/10/2018</u>	(Import)	
0700	Continuous	1730				MOSES SOUTH	2100 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	1050 MW
						TTC with All Lines In Service	3150 MW
FRASANNX-COOPERS__345_UCC2-41						FWD	
Mon 05/21/2018	to	Fri 06/01/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/10/2018</u>	(Import)	
0700	Continuous	1730				CENTRAL EAST - VC	2500 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	475 MW
						TTC with All Lines In Service	2975 MW
MARCY__-FRASANNX_345_UCC2-41						FWD	
Mon 05/21/2018	to	Fri 06/01/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/10/2018</u>	(Import)	
0700	Continuous	1730				CENTRAL EAST - VC	2500 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	475 MW
						TTC with All Lines In Service	2975 MW
LADENTWN-BUCHAN_S_345_Y88						FWD	
Tue 05/22/2018	to	Wed 05/23/2018	<u>UPDATED</u>	<u>by CONED</u>	<u>05/20/2018</u>	(Import)	
0500	Continuous	0300				UPNY CONED	4800 MW
Work scheduled by: ORU						Impacts Total Transfer Capability	900 MW
						TTC with All Lines In Service	5700 MW

NYISO TRANSFER LIMITATIONS

Saturday ,May 26, 2018 to Monday ,November 25, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>N.SCTLND-ALPS _____ 345_2 & NRTH1385-NOR HBR _____ 138_603</p> <p>Tue 05/22/2018 to Tue 05/22/2018 0800 1923</p> <p>Work scheduled by:</p>	<table border="0" style="width: 100%;"> <tr> <td style="width: 15%;"></td> <td style="width: 15%; text-align: right;">FWD</td> <td style="width: 15%; text-align: right;">REV</td> </tr> <tr> <td></td> <td style="text-align: right;">(Import)</td> <td style="text-align: right;">(Export)</td> </tr> <tr> <td>SCH - NPX_1385</td> <td style="text-align: right;">0 MW</td> <td style="text-align: right;">0 MW</td> </tr> <tr> <td>Impacts Total Transfer Capability</td> <td style="text-align: right;">200 MW</td> <td style="text-align: right;">200 MW</td> </tr> <tr> <td>TTC with All Lines In Service</td> <td style="text-align: right;">200 MW</td> <td style="text-align: right;">200 MW</td> </tr> </table>		FWD	REV		(Import)	(Export)	SCH - NPX_1385	0 MW	0 MW	Impacts Total Transfer Capability	200 MW	200 MW	TTC with All Lines In Service	200 MW	200 MW
	FWD	REV														
	(Import)	(Export)														
SCH - NPX_1385	0 MW	0 MW														
Impacts Total Transfer Capability	200 MW	200 MW														
TTC with All Lines In Service	200 MW	200 MW														
<p>N.SCTLND-ALPS _____ 345_2 & NRTH1385-NOR HBR _____ 138_602</p> <p>Tue 05/22/2018 to Tue 05/22/2018 0800 1933</p> <p>Work scheduled by:</p>	<table border="0" style="width: 100%;"> <tr> <td style="width: 15%;"></td> <td style="width: 15%; text-align: right;">FWD</td> <td style="width: 15%; text-align: right;">REV</td> </tr> <tr> <td></td> <td style="text-align: right;">(Import)</td> <td style="text-align: right;">(Export)</td> </tr> <tr> <td>SCH - NPX_1385</td> <td style="text-align: right;">0 MW</td> <td style="text-align: right;">0 MW</td> </tr> <tr> <td>Impacts Total Transfer Capability</td> <td style="text-align: right;">200 MW</td> <td style="text-align: right;">200 MW</td> </tr> <tr> <td>TTC with All Lines In Service</td> <td style="text-align: right;">200 MW</td> <td style="text-align: right;">200 MW</td> </tr> </table>		FWD	REV		(Import)	(Export)	SCH - NPX_1385	0 MW	0 MW	Impacts Total Transfer Capability	200 MW	200 MW	TTC with All Lines In Service	200 MW	200 MW
	FWD	REV														
	(Import)	(Export)														
SCH - NPX_1385	0 MW	0 MW														
Impacts Total Transfer Capability	200 MW	200 MW														
TTC with All Lines In Service	200 MW	200 MW														
<p>N.SCTLND-ALPS _____ 345_2 & NRTH1385-NOR HBR _____ 138_601</p> <p>Tue 05/22/2018 to Tue 05/22/2018 0800 1952</p> <p>Work scheduled by:</p>	<table border="0" style="width: 100%;"> <tr> <td style="width: 15%;"></td> <td style="width: 15%; text-align: right;">FWD</td> <td style="width: 15%; text-align: right;">REV</td> </tr> <tr> <td></td> <td style="text-align: right;">(Import)</td> <td style="text-align: right;">(Export)</td> </tr> <tr> <td>SCH - NPX_1385</td> <td style="text-align: right;">0 MW</td> <td style="text-align: right;">0 MW</td> </tr> <tr> <td>Impacts Total Transfer Capability</td> <td style="text-align: right;">200 MW</td> <td style="text-align: right;">200 MW</td> </tr> <tr> <td>TTC with All Lines In Service</td> <td style="text-align: right;">200 MW</td> <td style="text-align: right;">200 MW</td> </tr> </table>		FWD	REV		(Import)	(Export)	SCH - NPX_1385	0 MW	0 MW	Impacts Total Transfer Capability	200 MW	200 MW	TTC with All Lines In Service	200 MW	200 MW
	FWD	REV														
	(Import)	(Export)														
SCH - NPX_1385	0 MW	0 MW														
Impacts Total Transfer Capability	200 MW	200 MW														
TTC with All Lines In Service	200 MW	200 MW														
<p>N.SCTLND-ALPS _____ 345_2</p> <p>Tue 05/22/2018 to Thu 05/24/2018 0800 Continuous 1500</p> <p>Work scheduled by: NGrid</p>	<table border="0" style="width: 100%;"> <tr> <td style="width: 15%;"></td> <td style="width: 15%; text-align: right;">FWD</td> <td style="width: 15%; text-align: right;">REV</td> </tr> <tr> <td></td> <td style="text-align: right;">(Import)</td> <td style="text-align: right;">(Export)</td> </tr> <tr> <td>SCH - NE - NY</td> <td style="text-align: right;">750 MW</td> <td style="text-align: right;">1350 MW</td> </tr> <tr> <td>Impacts Total Transfer Capability</td> <td style="text-align: right;">650 MW</td> <td style="text-align: right;">250 MW</td> </tr> <tr> <td>TTC with All Lines In Service</td> <td style="text-align: right;">1400 MW</td> <td style="text-align: right;">1600 MW</td> </tr> </table>		FWD	REV		(Import)	(Export)	SCH - NE - NY	750 MW	1350 MW	Impacts Total Transfer Capability	650 MW	250 MW	TTC with All Lines In Service	1400 MW	1600 MW
	FWD	REV														
	(Import)	(Export)														
SCH - NE - NY	750 MW	1350 MW														
Impacts Total Transfer Capability	650 MW	250 MW														
TTC with All Lines In Service	1400 MW	1600 MW														
<p>N.SCTLND-ALPS _____ 345_2</p> <p>Tue 05/22/2018 to Thu 05/24/2018 0800 Continuous 1500</p> <p>Work scheduled by: NGrid</p>	<table border="0" style="width: 100%;"> <tr> <td style="width: 15%;"></td> <td style="width: 15%; text-align: right;">FWD</td> <td style="width: 15%; text-align: right;">REV</td> </tr> <tr> <td></td> <td style="text-align: right;">(Import)</td> <td style="text-align: right;">(Export)</td> </tr> <tr> <td>SCH - NPX_1385</td> <td style="text-align: right;">100 MW</td> <td style="text-align: right;">100 MW</td> </tr> <tr> <td>Impacts Total Transfer Capability</td> <td style="text-align: right;">100 MW</td> <td style="text-align: right;">100 MW</td> </tr> <tr> <td>TTC with All Lines In Service</td> <td style="text-align: right;">200 MW</td> <td style="text-align: right;">200 MW</td> </tr> </table>		FWD	REV		(Import)	(Export)	SCH - NPX_1385	100 MW	100 MW	Impacts Total Transfer Capability	100 MW	100 MW	TTC with All Lines In Service	200 MW	200 MW
	FWD	REV														
	(Import)	(Export)														
SCH - NPX_1385	100 MW	100 MW														
Impacts Total Transfer Capability	100 MW	100 MW														
TTC with All Lines In Service	200 MW	200 MW														
<p>DENNISON-NORFOLK _____ 115_4</p> <p>Tue 05/22/2018 to Tue 05/22/2018 CANCELLED by NGrid 05/22/2018</p> <p>0815 Daily(No Weekends) 1615</p> <p>Work scheduled by: NGrid ARR: 38</p>	<table border="0" style="width: 100%;"> <tr> <td style="width: 15%;"></td> <td style="width: 15%; text-align: right;">FWD</td> <td style="width: 15%; text-align: right;">REV</td> </tr> <tr> <td></td> <td style="text-align: right;">(Import)</td> <td style="text-align: right;">(Export)</td> </tr> <tr> <td>SCH - HQ_CEDARS</td> <td style="text-align: right;">150 MW</td> <td style="text-align: right;">40 MW</td> </tr> <tr> <td>Impacts Total Transfer Capability</td> <td style="text-align: right;">40 MW</td> <td style="text-align: right;">0 MW</td> </tr> <tr> <td>TTC with All Lines In Service</td> <td style="text-align: right;">190 MW</td> <td style="text-align: right;">40 MW</td> </tr> </table>		FWD	REV		(Import)	(Export)	SCH - HQ_CEDARS	150 MW	40 MW	Impacts Total Transfer Capability	40 MW	0 MW	TTC with All Lines In Service	190 MW	40 MW
	FWD	REV														
	(Import)	(Export)														
SCH - HQ_CEDARS	150 MW	40 MW														
Impacts Total Transfer Capability	40 MW	0 MW														
TTC with All Lines In Service	190 MW	40 MW														
<p>BECK _____ -NIAGARA _____ 345_PA302</p> <p>Wed 05/23/2018 to Thu 05/24/2018</p> <p>0500 Continuous 1800</p> <p>Work scheduled by: IESO</p>	<table border="0" style="width: 100%;"> <tr> <td style="width: 15%;"></td> <td style="width: 15%; text-align: right;">FWD</td> <td style="width: 15%; text-align: right;">REV</td> </tr> <tr> <td></td> <td style="text-align: right;">(Import)</td> <td style="text-align: right;">(Export)</td> </tr> <tr> <td>SCH - OH - NY</td> <td style="text-align: right;">900 MW</td> <td style="text-align: right;">800 MW</td> </tr> <tr> <td>Impacts Total Transfer Capability</td> <td style="text-align: right;">1100 MW</td> <td style="text-align: right;">800 MW</td> </tr> <tr> <td>TTC with All Lines In Service</td> <td style="text-align: right;">2000 MW</td> <td style="text-align: right;">1600 MW</td> </tr> </table>		FWD	REV		(Import)	(Export)	SCH - OH - NY	900 MW	800 MW	Impacts Total Transfer Capability	1100 MW	800 MW	TTC with All Lines In Service	2000 MW	1600 MW
	FWD	REV														
	(Import)	(Export)														
SCH - OH - NY	900 MW	800 MW														
Impacts Total Transfer Capability	1100 MW	800 MW														
TTC with All Lines In Service	2000 MW	1600 MW														

NYISO TRANSFER LIMITATIONS

Saturday ,May 26, 2018 to Monday ,November 25, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_400				FWD
Wed 05/23/2018	to	Thu 05/24/2018	CANCELLED by ISONE 05/22/2018	(Import)
0700	Continuous	1500		600 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 1400 MW
SCH-NYISO-NE_LIMIT_700				REV
Wed 05/23/2018	to	Thu 05/24/2018	CANCELLED by ISONE 05/22/2018	(Export)
0700	Continuous	1500		900 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability 700 MW
				TTC with All Lines In Service 1600 MW
SCH-NYISO-HQ_LIMIT_800				REV
Fri 05/25/2018	to	Thu 05/31/2018		(Export)
0001	Continuous	1600		800 MW
Work scheduled by: HQ				Impacts Total Transfer Capability 200 MW
				TTC with All Lines In Service 1000 MW
WOOD_ST_-PLSNTVLE_345_Y87				FWD
Fri 05/25/2018	to	Fri 05/25/2018	CANCELLED by ConEd 05/25/2018	(Import)
0301	Continuous	0330		4000 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1700 MW
				TTC with All Lines In Service 5700 MW
DUNWODIE_345KV_6				FWD
Fri 05/25/2018	to	Fri 05/25/2018	CANCELLED by ConEd 05/25/2018	(Import)
0301	Continuous	1830		3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_8				FWD
Fri 05/25/2018	to	Fri 05/25/2018	CANCELLED by ConEd 05/25/2018	(Import)
0301	Continuous	1830		3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
PLSNTVLE-DUNWODIE_345_W90				FWD
Fri 05/25/2018	to	Fri 05/25/2018	CANCELLED by ConEd 05/25/2018	(Import)
0301	Continuous	1830		4000 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1700 MW
				TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Saturday ,May 26, 2018 to Monday ,November 25, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

WOOD_ST_-PLSNTVLE_345_Y87				FWD
Fri 05/25/2018	to	Fri 05/25/2018	CANCELLED by ConEd 05/25/2018	(Import)
1800	Continuous	1830	UPNY CONED	4000 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1700 MW
				TTC with All Lines In Service 5700 MW
PLSNTVLE-DUNWODIE_345_W89				FWD
Sat 05/26/2018	to	Sat 05/26/2018		(Import)
0001	Continuous	0030	UPNY CONED	4000 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1700 MW
				TTC with All Lines In Service 5700 MW
WOOD_ST_-PLSNTVLE_345_Y86				FWD
Sat 05/26/2018	to	Sat 05/26/2018		(Import)
0001	Continuous	0030	UPNY CONED	4000 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1700 MW
				TTC with All Lines In Service 5700 MW
EFISHKIL-WOOD_ST__345_F38				FWD
Sat 05/26/2018	to	Sat 05/26/2018		(Import)
0001	Continuous	2330	UPNY CONED	4000 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1700 MW
				TTC with All Lines In Service 5700 MW
PLSNTVLE-DUNWODIE_345_W89				FWD
Sat 05/26/2018	to	Sat 05/26/2018		(Import)
2300	Continuous	2330	UPNY CONED	4000 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1700 MW
				TTC with All Lines In Service 5700 MW
EASTVIEW-SPRNBK__345_W78				FWD
Mon 05/28/2018	to	Tue 05/29/2018	UPDATED by CONED 05/16/2018	(Import)
0300	Continuous	0200	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1350 MW
				TTC with All Lines In Service 5700 MW
MILLWOOD-EASTVIEW_345_W85				FWD
Mon 05/28/2018	to	Tue 05/29/2018	UPDATED by CONED 05/16/2018	(Import)
0300	Continuous	0200	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1350 MW
				TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Saturday ,May 26, 2018 to Monday ,November 25, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>				
SPRNBK__345KV_RNS3				FWD
Mon 05/28/2018	to	Tue 05/29/2018	UPDATED by CONED 05/16/2018	(Import)
0300	Continuous	0200		3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
<hr/>				
SCH-NE-NYISO_LIMIT_400				FWD
Mon 05/28/2018	to	Mon 05/28/2018		(Import)
0600	Continuous	1800		600 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 1400 MW
<hr/>				
SCH-NYISO-NE_LIMIT_1100				REV
Mon 05/28/2018	to	Mon 05/28/2018		(Export)
0600	Continuous	1800		1300 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability 300 MW
				TTC with All Lines In Service 1600 MW
<hr/>				
SCH-IMO-NYISO_LIMIT_1000				FWD
Tue 05/29/2018	to	Fri 06/01/2018	UPDATED by NYISO 05/15/2018	(Import)
0500	Continuous	1700		1300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 700 MW
				TTC with All Lines In Service 2000 MW
<hr/>				
STLAWRNC-MOSES__230_L33P				FWD REV
Tue 05/29/2018	to	Fri 06/01/2018	CANCELLED by NYPA 05/24/2018	(Import) (Export)
0700	Continuous	2000		2000 MW 1600 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 0 MW 0 MW
				TTC with All Lines In Service 2000 MW 1600 MW
<hr/>				
BROWNFLS-TAYLORVL_115_4				FWD REV
Tue 05/29/2018	to	Sat 06/02/2018		(Import) (Export)
0700	Continuous	1800		70 MW 40 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 120 MW 0 MW
				TTC with All Lines In Service 190 MW 40 MW
<hr/>				
NEPTUNE_-DUFFYAVE_345_NEPTUNE				FWD
Wed 05/30/2018	to	Wed 05/30/2018		(Import)
0600	Continuous	1000		0 MW
Work scheduled by: LI				Impacts Total Transfer Capability 660 MW
				TTC with All Lines In Service 660 MW

ARR: 38

NYISO TRANSFER LIMITATIONS

Saturday ,May 26, 2018 to Monday ,November 25, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE-DUFFYAVE_345_501			FWD	
Wed 05/30/2018	to	Wed 05/30/2018	(Import)	
0600	Continuous	1000	SCH - PJM_NEPTUNE	0 MW
Work scheduled by: LI			Impacts Total Transfer Capability	660 MW
			TTC with All Lines In Service	660 MW
NEWBRDGE_345_138_BK_1			FWD	
Wed 05/30/2018	to	Wed 05/30/2018	(Import)	
0600	Continuous	1000	SCH - PJM_NEPTUNE	375 MW
Work scheduled by: LI			Impacts Total Transfer Capability	285 MW
			TTC with All Lines In Service	660 MW
NEWBRDGE_345_138_BK_2			FWD	
Wed 05/30/2018	to	Wed 05/30/2018	(Import)	
0600	Continuous	1000	SCH - PJM_NEPTUNE	375 MW
Work scheduled by: LI			Impacts Total Transfer Capability	285 MW
			TTC with All Lines In Service	660 MW
DENNISON-ROSEMNTB_115_2/22			FWD	REV
Thu 05/31/2018	to	Thu 05/31/2018	(Import)	(Export)
0800	Daily(No Weekends)	1630	SCH - HQ_CEDARS	95 MW 40 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	95 MW 0 MW
			TTC with All Lines In Service	190 MW 40 MW
			ARR: 38	
MARCY_SO_SERIES_COMP_I/S			FWD	
Fri 06/01/2018	to	Wed 10/31/2018	(Import)	
1800	Continuous	2359	CENTRAL EAST - VC	2740 MW
Work scheduled by: NYISO			Impacts Total Transfer Capability	235 MW
			TTC with All Lines In Service	2975 MW
SCH-IMO_NY_NIAG_CB_3122_W/BB			FWD	REV
Sat 06/02/2018	to	Sat 06/02/2018	(Import)	(Export)
0500	Continuous	1700	SCH - OH - NY	1700 MW 1400 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	300 MW 200 MW
			TTC with All Lines In Service	2000 MW 1600 MW
SCH-NYISO-HQ_LIMIT_800				REV
Sat 06/02/2018	to	Sat 06/02/2018		(Export)
0700	Continuous	1800	SCH - HQ - NY	800 MW
Work scheduled by: HQ			Impacts Total Transfer Capability	200 MW
			TTC with All Lines In Service	1000 MW

NYISO TRANSFER LIMITATIONS

Saturday ,May 26, 2018 to Monday ,November 25, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BROWNFLS-TAYLORVL_115_3

Mon 06/04/2018 to Sat 06/09/2018
0700 Continuous 1800

Work scheduled by: NGrid

ARR: 38

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	70 MW	40 MW
Impacts Total Transfer Capability	120 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

LEEDS_345_LEEDS SVC

Mon 06/04/2018 to Fri 06/15/2018
0800 Continuous 1500

Work scheduled by: NGrid

	FWD
	(Import)
CENTRAL EAST - VC	2950 MW
Impacts Total Transfer Capability	25 MW
TTC with All Lines In Service	2975 MW

LEEDS_345_LEEDS SVC & MARCY_SO_SERIES_COMP_I/S

Mon 06/04/2018 to Fri 06/15/2018
0800 1500

Work scheduled by:

	FWD
	(Import)
CENTRAL EAST - VC	2715 MW
Impacts Total Transfer Capability	260 MW
TTC with All Lines In Service	2975 MW

SCH-NYISO-HQ_LIMIT_800

Mon 06/04/2018 to Mon 06/04/2018
0830 Continuous 1830

Work scheduled by: HQ

	REV
	(Export)
SCH - HQ - NY	800 MW
Impacts Total Transfer Capability	200 MW
TTC with All Lines In Service	1000 MW

BROWNFLS-TAYLORVL_115_4

Mon 06/11/2018 to Sat 06/16/2018
0700 Continuous 1800

Work scheduled by: NGrid

ARR: 38

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	70 MW	40 MW
Impacts Total Transfer Capability	120 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

NIAGARA_-ROCHESTR_345_NR2

Mon 06/18/2018 to Thu 06/21/2018
0500 Continuous 1700

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	1700 MW
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

BROWNFLS-TAYLORVL_115_3

Mon 06/18/2018 to Sat 06/23/2018
0700 Continuous 1800

Work scheduled by: NGrid

ARR: 38

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	70 MW	40 MW
Impacts Total Transfer Capability	120 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

NYISO TRANSFER LIMITATIONS

Saturday ,May 26, 2018 to Monday ,November 25, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
S. RIPLEY-DUNKIRK__230_68						
Fri 06/22/2018	to	Sat 02/01/2020	<u>UPDATED</u>	<u>by NYISO</u>	<u>05/14/2018</u>	
2000	Continuous	0000				
Work scheduled by: NYISO					SCH - PJ - NY	1950 MW
					Impacts Total Transfer Capability	150 MW
					TTC with All Lines In Service	2100 MW
						1350 MW
SCH-NYISO-IMO_NIAGARA_CB_3022						
Thu 06/28/2018	to	Thu 06/28/2018				
0500	Continuous	1700				
Work scheduled by: NYPA					SCH - OH - NY	1300 MW
					Impacts Total Transfer Capability	700 MW
					TTC with All Lines In Service	2000 MW
						1600 MW
MARCY__765_345_AT1						
Sat 08/04/2018	to	Sun 08/05/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>04/17/2018</u>	
0500	Continuous	1730				
Work scheduled by: NYPA					MOSES SOUTH	1750 MW
					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	3150 MW
MARCY__765_345_AT2						
Tue 09/04/2018	to	Sun 09/09/2018				
0500	Continuous	1730				
Work scheduled by: NYPA					MOSES SOUTH	1700 MW
					Impacts Total Transfer Capability	1450 MW
					TTC with All Lines In Service	3150 MW
CLRKSCRN-OAKDALE__345_36						
Thu 09/06/2018	to	Fri 09/07/2018				
0700	Continuous	1530				
Work scheduled by: NYSEG					CENTRAL EAST - VC	2650 MW
					Impacts Total Transfer Capability	325 MW
					TTC with All Lines In Service	2975 MW
FRASER_-GILBOA__345_GF5-35						
Mon 09/10/2018	to	Fri 10/05/2018				
0700	Continuous	1730				
Work scheduled by: NYPA					CENTRAL EAST - VC	2650 MW
					Impacts Total Transfer Capability	325 MW
					TTC with All Lines In Service	2975 MW
ROSETON_-ROCKTVRN_345_311						
Mon 09/10/2018	to	Fri 09/28/2018				
0800	Continuous	1600				
Work scheduled by: CHGE					UPNY CONED	4400 MW
					Impacts Total Transfer Capability	1300 MW
					TTC with All Lines In Service	5700 MW

NYISO TRANSFER LIMITATIONS

Saturday ,May 26, 2018 to Monday ,November 25, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___345KV_CSC		FWD	
Tue 09/11/2018	to Tue 09/11/2018	(Import)	
0500	Continuous 1730	CENTRAL EAST - VC	2925 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	50 MW
		TTC with All Lines In Service	2975 MW
MARCY___345KV_CSC & MARCY_SO_SERIES_COMP_I/S		FWD	
Tue 09/11/2018	to Tue 09/11/2018	(Import)	
0500	1730	CENTRAL EAST - VC	2690 MW
Work scheduled by:		Impacts Total Transfer Capability	285 MW
		TTC with All Lines In Service	2975 MW
MARCY___765_345_AT2		FWD	
Tue 09/11/2018	to Tue 09/11/2018	(Import)	
0500	Continuous 1730	MOSES SOUTH	1700 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	1450 MW
		TTC with All Lines In Service	3150 MW
NIAGARA__345_230_AT4		FWD	REV
Fri 09/14/2018	to Fri 09/14/2018	(Import)	(Export)
0500	Continuous 1700	SCH - OH - NY	2000 MW 1400 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	0 MW 200 MW
		TTC with All Lines In Service	2000 MW 1600 MW
DUNWODIE-MOTTHAVN_345_71		FWD	
Sat 09/15/2018	to Mon 09/17/2018	(Import)	
0001	Continuous 0200	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability	800 MW
		TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_3		FWD	
Sat 09/15/2018	to Mon 09/17/2018	(Import)	
0001	Continuous 0200	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability	800 MW
		TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_5		FWD	
Sat 09/15/2018	to Mon 09/17/2018	(Import)	
0001	Continuous 0200	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability	800 MW
		TTC with All Lines In Service	4600 MW

ARR: 19

NYISO TRANSFER LIMITATIONS

Saturday ,May 26, 2018 to Monday ,November 25, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-ROCHESTR_345_NR2			FWD	
Mon 09/17/2018	to	Fri 09/21/2018	(Import)	
0500	Continuous	1700	DYSINGER EAST	1700 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1450 MW
			TTC with All Lines In Service	3150 MW
MOSES_-ADIRNDCK_230_MAI			FWD	
Mon 09/17/2018	to	Fri 09/21/2018	(Import)	
0700	Continuous	1530	MOSES SOUTH	2100 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1050 MW
			TTC with All Lines In Service	3150 MW
NIAGARA_345_230_AT4			FWD	REV
Mon 09/24/2018	to	Fri 09/28/2018	(Import)	(Export)
0500	Continuous	1700	SCH - OH - NY	2000 MW 1400 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	0 MW 200 MW
			TTC with All Lines In Service	2000 MW 1600 MW
MOSES_-ADIRNDCK_230_MAI			FWD	
Mon 09/24/2018	to	Fri 09/28/2018	(Import)	
0700	Continuous	1530	MOSES SOUTH	2100 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1050 MW
			TTC with All Lines In Service	3150 MW
CLAY_-EDIC_345_2-15			FWD	
Mon 09/24/2018	to	Fri 09/28/2018	(Import)	
0700	Continuous	1700	OSWEGO EXPORT	4850 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	400 MW
			TTC with All Lines In Service	5250 MW
WATRCURE_345_230_BK 1			FWD	REV
Mon 09/24/2018	to	Thu 09/27/2018	(Import)	(Export)
0800	Continuous	1530	SCH - PJ - NY	2100 MW 1350 MW
Work scheduled by: NYSEG			Impacts Total Transfer Capability	0 MW 0 MW
			TTC with All Lines In Service	2100 MW 1350 MW
BECK_-NIAGARA_345_PA302			FWD	REV
Mon 10/01/2018	to	Fri 10/05/2018	(Import)	(Export)
0500	Continuous	1700	SCH - OH - NY	900 MW 800 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1100 MW 800 MW
			TTC with All Lines In Service	2000 MW 1600 MW

NYISO TRANSFER LIMITATIONS

Saturday ,May 26, 2018 to Monday ,November 25, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -ADIRNDCK_230_MA2

Mon 10/01/2018 to Wed 10/03/2018
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

PANNELL -CLAY_345_1

Mon 10/01/2018 to Fri 10/05/2018
0700 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

HUDSONP -FARRAGUT_345_B3402

Tue 10/02/2018 to Tue 11/13/2018
0001 Continuous 2359

Work scheduled by: PJM

FWD REV
(Import) (Export)
SCH - PJ - NY **2100 MW 1350 MW**
Impacts Total Transfer Capability 0 MW 0 MW
TTC with All Lines In Service 2100 MW 1350 MW

MARCY_765_345_AT2

Thu 10/04/2018 to Fri 10/05/2018
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

MOSES -ADIRNDCK_230_MA1

Mon 10/08/2018 to Fri 10/12/2018
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

CHAT_DC_GC2

Mon 10/08/2018 to Fri 11/23/2018
0700 Continuous 1700

Work scheduled by: HQ

FWD
(Import)
MOSES SOUTH **2850 MW**
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 3150 MW

CHAT_DC_GC2

Mon 10/08/2018 to Fri 11/23/2018
0700 Continuous 1700

Work scheduled by: HQ

REV
(Export)
SCH - HQ - NY **500 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1000 MW

NYISO TRANSFER LIMITATIONS

Saturday ,May 26, 2018 to Monday ,November 25, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHATGUAY-MASSENA__765_7040

Sat 10/13/2018 to Sat 10/27/2018
 0100 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **1550 MW**
 Impacts Total Transfer Capability 1600 MW
 TTC with All Lines In Service 3150 MW

CHATGUAY-MASSENA__765_7040

Sat 10/13/2018 to Sat 10/27/2018
 0100 Continuous 1730
 Work scheduled by: NYPA

FWD REV
 (Import) (Export)
 SCH - HQ - NY **0 MW 0 MW**
 Impacts Total Transfer Capability 1500 MW 1000 MW
 TTC with All Lines In Service 1500 MW 1000 MW

MARCY__765_345_AT1

Sat 10/13/2018 to Sat 10/27/2018
 0100 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1750 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 3150 MW

MARCY__765_345_AT2

Sat 10/13/2018 to Sat 10/27/2018
 0100 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

MASSENA_-MARCY__765_MSU1

Sat 10/13/2018 to Sat 10/27/2018
 0100 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2265 MW**
 Impacts Total Transfer Capability 710 MW
 TTC with All Lines In Service 2975 MW

MASSENA_-MARCY__765_MSU1

Sat 10/13/2018 to Sat 10/27/2018
 0100 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **500 MW**
 Impacts Total Transfer Capability 2650 MW
 TTC with All Lines In Service 3150 MW

MASSENA_-MARCY__765_MSU1

Sat 10/13/2018 to Sat 10/27/2018
 0100 Continuous 1730
 Work scheduled by: NYPA

FWD REV
 (Import) (Export)
 SCH - HQ - NY **475 MW 1000 MW**
 Impacts Total Transfer Capability 1025 MW 0 MW
 TTC with All Lines In Service 1500 MW 1000 MW

NYISO TRANSFER LIMITATIONS

Saturday ,May 26, 2018 to Monday ,November 25, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040

Sat 10/13/2018 to Sat 10/27/2018
 0100 1730

Work scheduled by:

FWD
 (Import)
MOSES SOUTH 500 MW
 Impacts Total Transfer Capability 2650 MW
 TTC with All Lines In Service 3150 MW

MASSENA -MARCY 765_MSU1 & MARCY_SO_SERIES_COMP_I/S

Sat 10/13/2018 to Sat 10/27/2018
 0100 1730

Work scheduled by:

FWD
 (Import)
CENTRAL EAST - VC 2080 MW
 Impacts Total Transfer Capability 895 MW
 TTC with All Lines In Service 2975 MW

MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2

Sat 10/13/2018 to Sat 10/27/2018
 0100 1730

Work scheduled by:

FWD REV
 (Import) (Export)
SCH - HQ - NY 850 MW 0 MW
 Impacts Total Transfer Capability 650 MW 1000 MW
 TTC with All Lines In Service 1500 MW 1000 MW

STONYRDG-HILLSIDE 230_72

Wed 10/17/2018 to Thu 10/18/2018
 0800 Continuous 1530

Work scheduled by: NYSEG

FWD
 (Import)
DYSINGER EAST 2850 MW
 Impacts Total Transfer Capability 300 MW
 TTC with All Lines In Service 3150 MW

LINDN_CG-LNDVFT 345_V-3022

Mon 10/22/2018 to Thu 10/25/2018
 0800 Continuous 1500

Work scheduled by: PJM

FWD REV
 (Import) (Export)
SCH - PJM_VFT 0 MW 0 MW
 Impacts Total Transfer Capability 315 MW 315 MW
 TTC with All Lines In Service 315 MW 315 MW

LEEDS -HURLYAVE 345_301

Mon 10/22/2018 to Fri 11/16/2018
 0800 Continuous 1600

Work scheduled by: CHGE

FWD
 (Import)
UPNY CONED 4100 MW
 Impacts Total Transfer Capability 1600 MW
 TTC with All Lines In Service 5700 MW

KINTIGH -ROCHESTR 345_SRL-39

Mon 10/29/2018 to Fri 11/02/2018
 0500 Continuous 1700

Work scheduled by: NYPA

FWD
 (Import)
DYSINGER EAST 1700 MW
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Saturday ,May 26, 2018 to Monday ,November 25, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES ___-ADIRNDCK_230_MA1

Mon 10/29/2018 to Fri 11/02/2018
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
MOSES SOUTH 2100 MW
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Sat 11/03/2018 to Sun 11/18/2018
 0001 Continuous 1800
 Work scheduled by: LI

FWD
 (Import)
SCH - PJM_NEPTUNE 0 MW
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE-DUFFYAVE_345_501

Sat 11/03/2018 to Sun 11/18/2018
 0001 Continuous 1800
 Work scheduled by: LI

FWD
 (Import)
SCH - PJM_NEPTUNE 0 MW
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_1

Sat 11/03/2018 to Sun 11/18/2018
 0001 Continuous 1800
 Work scheduled by: LI

FWD
 (Import)
SCH - PJM_NEPTUNE 375 MW
 Impacts Total Transfer Capability 285 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_2

Sat 11/03/2018 to Sun 11/18/2018
 0001 Continuous 1800
 Work scheduled by: LI

FWD
 (Import)
SCH - PJM_NEPTUNE 375 MW
 Impacts Total Transfer Capability 285 MW
 TTC with All Lines In Service 660 MW

MOSES ___-ADIRNDCK_230_MA1

Mon 11/05/2018 to Fri 11/09/2018
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
MOSES SOUTH 2300 MW
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

FROST_BR-LONG_MTN_345_352

Sun 11/11/2018 to Sun 11/11/2018
 0700 Continuous 1800
 Work scheduled by: ISONE

FWD REV
 (Import) (Export)
SCH - NE - NY 1300 MW 1600 MW
 Impacts Total Transfer Capability 100 MW 0 MW
 TTC with All Lines In Service 1400 MW 1600 MW

NYISO TRANSFER LIMITATIONS

Saturday ,May 26, 2018 to Monday ,November 25, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_1000

Sun 11/11/2018 to Sun 11/11/2018
 0700 Continuous 1800
 Work scheduled by: ISONE

FWD
 (Import)
 SCH - NE - NY **1200 MW**
 Impacts Total Transfer Capability 200 MW
 TTC with All Lines In Service 1400 MW

MARCY_345KV_CSC

Fri 11/16/2018 to Sat 11/17/2018
 0500 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2925 MW**
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 2975 MW

MARCY_765_345_AT2

Fri 11/16/2018 to Sat 11/17/2018
 0500 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

MOSES-ADIRNDCK_230_MA1

Mon 11/19/2018 to Wed 11/21/2018
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MOSES-ADIRNDCK_230_MA2

Mon 11/26/2018 to Fri 11/30/2018
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

HURLYAVE-ROSETON_345_303

Mon 11/26/2018 to Fri 12/21/2018
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4100 MW**
 Impacts Total Transfer Capability 1600 MW
 TTC with All Lines In Service 5700 MW

MOSES-ADIRNDCK_230_MA2

Mon 12/03/2018 to Fri 12/07/2018
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Saturday ,May 26, 2018 to Monday ,November 25, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA2

Mon 12/10/2018 to Fri 12/14/2018
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MARCY___765_345_AT2

Mon 12/17/2018 to Fri 12/21/2018
 0500 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

ARR: 19

MOSES___-ADIRNDCK_230_MA1

Wed 12/26/2018 to Fri 12/28/2018
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

LEEDS___345_LEEDS SVC

Mon 03/11/2019 to Fri 03/22/2019
 0800 Continuous 1600
 Work scheduled by: NGrid

FWD
 (Import)
 CENTRAL EAST - VC **2950 MW**
 Impacts Total Transfer Capability 25 MW
 TTC with All Lines In Service 2975 MW