

NYISO TRANSFER LIMITATIONS

Sunday ,December 02, 2018 to Tuesday ,June 02, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

	FWD	REV
HUDSONP_-FARRAGUT_345_B3402		
Mon 01/15/2018 to Mon 04/01/2019		(Import) (Export)
0001 Continuous 2359		
<u>EXT FORCE</u> by <u>CONED</u> <u>12/02/2018</u>		
Work scheduled by: ConEd	SCH - PJ - NY	2600 MW 1300 MW
	Impacts Total Transfer Capability	0 MW 250 MW
	TTC with All Lines In Service	2600 MW 1550 MW
HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403		
Mon 01/15/2018 to Mon 04/01/2019		(Import) (Export)
0001 2359		
<u>EXT FORCE</u> by <u>CONED</u> <u>12/02/2018</u>		
Work scheduled by:	SCH - PJ - NY	2000 MW 1300 MW
	Impacts Total Transfer Capability	600 MW 250 MW
	TTC with All Lines In Service	2600 MW 1550 MW
MARION_-FARRAGUT_345_C3403		
Mon 01/15/2018 to Mon 04/01/2019		(Import) (Export)
0001 Continuous 2359		
<u>EXT FORCE</u> by <u>CONED</u> <u>12/02/2018</u>		
Work scheduled by: ConEd	SCH - PJ - NY	2600 MW 1300 MW
	Impacts Total Transfer Capability	0 MW 250 MW
	TTC with All Lines In Service	2600 MW 1550 MW
STLAWRNC-MOSES_230_L33P		
Mon 04/30/2018 to Fri 12/31/2021		(Import) (Export)
0456 Continuous 2359		
<u>EXT FORCE</u> by <u>IESO</u> <u>08/21/2018</u>		
Work scheduled by: IESO	SCH - OH - NY	1750 MW 1900 MW
	Impacts Total Transfer Capability	0 MW 0 MW
	TTC with All Lines In Service	1750 MW 1900 MW
DUNWODIE_345KV_6		
Mon 10/22/2018 to Sat 12/22/2018		FWD (Import)
0301 Continuous 0200		
<u>UPDATED</u> by <u>CE</u> <u>10/04/2018</u>		
Work scheduled by: ConEd	SPR/DUN-SOUTH	3800 MW
	Impacts Total Transfer Capability	800 MW
	TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_8		
Mon 10/22/2018 to Sat 12/22/2018		FWD (Import)
0301 Continuous 0200		
<u>UPDATED</u> by <u>CE</u> <u>10/04/2018</u>		
Work scheduled by: ConEd	SPR/DUN-SOUTH	3800 MW
	Impacts Total Transfer Capability	800 MW
	TTC with All Lines In Service	4600 MW
PLSNTVLE-DUNWODIE_345_W90		
Mon 10/22/2018 to Sat 12/22/2018		FWD (Import)
0301 Continuous 0200		
<u>UPDATED</u> by <u>CE</u> <u>10/04/2018</u>		
Work scheduled by: ConEd	UPNY CONED	4000 MW
	Impacts Total Transfer Capability	1700 MW
	TTC with All Lines In Service	5700 MW

NYISO TRANSFER LIMITATIONS

Sunday ,December 02, 2018 to Tuesday ,June 02, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						FWD	REV
S.RIPLEY-DUNKIRK__230_68						(Import)	(Export)
Mon 10/22/2018	to	Fri 12/14/2018	UPDATED	by PJM	11/20/2018	2600 MW	1300 MW
0800	Continuous	2000				Impacts Total Transfer Capability	0 MW 250 MW
Work scheduled by: PJM						TTC with All Lines In Service	2600 MW 1550 MW
<hr/>						FWD	
SCH-IMO-NYISO_LIMIT_1400						(Import)	
Thu 11/01/2018	to	Mon 12/31/2018				1700 MW	
0001	Continuous	2359				Impacts Total Transfer Capability	50 MW
Work scheduled by: IESO						TTC with All Lines In Service	1750 MW
<hr/>							REV
SCH-NYISO-IMO_LIMIT_1600							(Export)
Thu 11/01/2018	to	Mon 12/31/2018				1900 MW	
0001	Continuous	2359				Impacts Total Transfer Capability	0 MW
Work scheduled by: IESO						TTC with All Lines In Service	1900 MW
<hr/>						FWD	
SCH-IMO-NYISO_LIMIT_1300						(Import)	
Thu 11/15/2018	to	Thu 12/20/2018	UPDATED	by NYPA	11/20/2018	1600 MW	
0500	Continuous	2359				Impacts Total Transfer Capability	150 MW
Work scheduled by: NYPA						TTC with All Lines In Service	1750 MW
<hr/>						FWD	REV
LONG_MTN-PLSNTVLY_345_398						(Import)	(Export)
Mon 11/26/2018	to	Thu 12/06/2018	UPDATED	by CONED	11/21/2018	700 MW	1300 MW
0001	Continuous	0030				Impacts Total Transfer Capability	700 MW 300 MW
Work scheduled by: ConEd						TTC with All Lines In Service	1400 MW 1600 MW
<hr/>						FWD	REV
LONG_MTN-PLSNTVLY_345_398						(Import)	(Export)
Mon 11/26/2018	to	Thu 12/06/2018	UPDATED	by CONED	11/21/2018	100 MW	100 MW
0001	Continuous	0030				Impacts Total Transfer Capability	100 MW 100 MW
Work scheduled by: ConEd						TTC with All Lines In Service	200 MW 200 MW
<hr/>							REV
SCH-NYISO-NE_LIMIT_700							(Export)
Mon 11/26/2018	to	Thu 12/06/2018	UPDATED	by CONED	11/21/2018	900 MW	
0001	Continuous	0030				Impacts Total Transfer Capability	700 MW
Work scheduled by: ConEd						TTC with All Lines In Service	1600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,December 02, 2018 to Tuesday ,June 02, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event ID	Start Date	End Date	Time	Duration	Work Scheduled by	Impact	TTC	FWD	REV
MOSES -ADIRNDCK_230_MA2	Mon 11/26/2018	Fri 11/30/2018	0700	Continuous	1530	NYPA	MOSES SOUTH	2300 MW	
							Impacts Total Transfer Capability	850 MW	
							TTC with All Lines In Service	3150 MW	
SHOR_NPX-SHOREHAM_138_CSC	Mon 11/26/2018	Fri 12/07/2018	0700	Continuous	1600	LI	SCH - NPX_CSC	0 MW	0 MW
							Impacts Total Transfer Capability	330 MW	330 MW
							TTC with All Lines In Service	330 MW	330 MW
HURLYAVE-ROSETON_345_303	Mon 11/26/2018	Fri 12/21/2018	0800	Continuous	1600	CHGE	UPNY CONED	4100 MW	
							Impacts Total Transfer Capability	1600 MW	
							TTC with All Lines In Service	5700 MW	
SCH-IMO-NYISO_LIMIT_1050	Tue 11/27/2018	Wed 11/28/2018	0800	Continuous	1400	NYSEG	SCH - OH - NY	1350 MW	
							Impacts Total Transfer Capability	400 MW	
							TTC with All Lines In Service	1750 MW	
HOMR_NYW-PIERC_NY_345_48	Wed 11/28/2018	Wed 12/05/2018	1305	Continuous	1600	PJM	SCH - PJ - NY	2500 MW	1300 MW
							Impacts Total Transfer Capability	100 MW	250 MW
							TTC with All Lines In Service	2600 MW	1550 MW
SCH-IMO-NYISO_LIMIT_300	Thu 11/29/2018	Thu 11/29/2018	0800	Daily(No Weekends)	1100	NGrid	SCH - OH - NY	600 MW	
							Impacts Total Transfer Capability	1150 MW	
							TTC with All Lines In Service	1750 MW	
SCH-NYISO-HQ_LIMIT_800	Thu 11/29/2018	Thu 12/06/2018	2001	Continuous	1800	HQ	SCH - HQ - NY	800 MW	
							Impacts Total Transfer Capability	200 MW	
							TTC with All Lines In Service	1000 MW	

NYISO TRANSFER LIMITATIONS

Sunday ,December 02, 2018 to Tuesday ,June 02, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event ID	Start Date	End Date	Time	Frequency	Duration	Work Scheduled by	Update Info	Impact Zone	FWD (Import)	Impacts Total Transfer Capability	TTC with All Lines In Service	REV (Export)
SCH-IMO-NYISO_LIMIT_1050	Fri 11/30/2018	Fri 11/30/2018	0800	Daily	1200	(No Weekends)	UPDATED by NGRID 11/28/2018	SCH - OH - NY	1350 MW	400 MW	1750 MW	
SCH-IMO-NYISO_LIMIT_700	Sat 12/01/2018	Wed 12/05/2018	0500	Continuous	2300		UPDATED by NYISO 11/29/2018	SCH - OH - NY	1000 MW	750 MW	1750 MW	
CLRKSCRN-OAKDALE_345_36	Sat 12/01/2018	Sat 12/01/2018	0700	Daily	1800		UPDATED by NYSEG 11/14/2018	CENTRAL EAST - VC	2650 MW	325 MW	2975 MW	
DUNWODIE-MOTTHAVN_345_72	Sun 12/02/2018	Thu 12/06/2018	0001	Continuous	0159			SPR/DUN-SOUTH	3800 MW	800 MW	4600 MW	
DUNWODIE_345KV_7	Sun 12/02/2018	Thu 12/06/2018	0001	Continuous	0159			SPR/DUN-SOUTH	3800 MW	800 MW	4600 MW	
OSWEGO_COMPLEX_AVR_O/S	Sun 12/02/2018	Sun 12/02/2018	0900	Continuous	0930			CENTRAL EAST - VC	2870 MW	105 MW	2975 MW	
BECK-NIAGARA_345_PA302	Mon 12/03/2018	Wed 12/05/2018	0500	Continuous	1900			SCH - OH - NY	1100 MW	650 MW	1750 MW	950 MW

NYISO TRANSFER LIMITATIONS

Sunday ,December 02, 2018 to Tuesday ,June 02, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -ADIRNDCK_230_MA2					FWD	
Mon 12/03/2018	to	Fri 12/07/2018			(Import)	
0700	Continuous	1530		MOSES SOUTH	2300 MW	
Work scheduled by: NYPA					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
DUNWODIE-SHORE_RD_345_Y50					FWD	
Thu 12/06/2018	to	Wed 12/12/2018			(Import)	
0201	Continuous	0200		CONED - LIPA	800 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability	700 MW
					TTC with All Lines In Service	1500 MW
DUNWODIE_345KV_4					FWD	
Thu 12/06/2018	to	Wed 12/12/2018			(Import)	
0201	Continuous	0200		SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
SHORE_RD_345_138_BK 1					FWD	
Thu 12/06/2018	to	Wed 12/12/2018			(Import)	
0201	Continuous	0200		CONED - LIPA	1350 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability	150 MW
					TTC with All Lines In Service	1500 MW
SHORE_RD_345_138_BK 2					FWD	
Thu 12/06/2018	to	Wed 12/12/2018			(Import)	
0201	Continuous	0200		CONED - LIPA	1350 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability	150 MW
					TTC with All Lines In Service	1500 MW
CHATGUAY-MASSENA_765_7040					FWD	
Sat 12/08/2018	to	Sat 12/08/2018	UPDATED	by NYPA	11/16/2018	(Import)
0700	Continuous	2300				
Work scheduled by: HQ					MOSES SOUTH	1550 MW
					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	3150 MW
CHATGUAY-MASSENA_765_7040					FWD	REV
Sat 12/08/2018	to	Sat 12/08/2018	UPDATED	by NYPA	11/16/2018	(Import) (Export)
0700	Continuous	2300				
Work scheduled by: HQ					SCH - HQ - NY	0 MW 0 MW
					Impacts Total Transfer Capability	1500 MW 1000 MW
					TTC with All Lines In Service	1500 MW 1000 MW

NYISO TRANSFER LIMITATIONS

Sunday ,December 02, 2018 to Tuesday ,June 02, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
BROWNFLS-TAYLORVL_115_4					
Sat 12/08/2018	to	Sat 12/08/2018			
0800	Continuous	1600			
Work scheduled by: NGrid			ARR: 38		
				SCH - HQ_CEDARS	100 MW
				Impacts Total Transfer Capability	99 MW
				TTC with All Lines In Service	199 MW
BROWNFLS-TAYLORVL_115_3					
Sun 12/09/2018	to	Sun 12/09/2018			
0700	Continuous	1700			
Work scheduled by: NGrid			ARR: 38		
				SCH - HQ_CEDARS	100 MW
				Impacts Total Transfer Capability	99 MW
				TTC with All Lines In Service	199 MW
BROWNFLS-TAYLORVL_115_3 & TAYLORVL-LOWVILLE_115_5 & CLIMAX__-TAYLORVL_115_8					
Sun 12/09/2018	to	Sun 12/09/2018			
0700		1700			
Work scheduled by:			ARR: 38		
				SCH - HQ_CEDARS	120 MW
				Impacts Total Transfer Capability	79 MW
				TTC with All Lines In Service	199 MW
TAYLORVL-LOWVILLE_115_5					
Sun 12/09/2018	to	Sun 12/09/2018			
0700	Continuous	1700			
Work scheduled by: NGrid			ARR: 38		
				SCH - HQ_CEDARS	199 MW
				Impacts Total Transfer Capability	0 MW
				TTC with All Lines In Service	199 MW
MOSES__-ADIRNDCK_230_MA2					
Mon 12/10/2018	to	Fri 12/14/2018			
0700	Continuous	1530			
Work scheduled by: NYPA					
				MOSES SOUTH	2300 MW
				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
WOOD_ST_-PLSNTVLE_345_Y87					
Mon 12/17/2018	to	Mon 01/28/2019	UPDATED	by CE	10/04/2018
0001	Continuous	0200			
Work scheduled by: ConEd					
				UPNY CONED	4000 MW
				Impacts Total Transfer Capability	1700 MW
				TTC with All Lines In Service	5700 MW
MARCY___345KV_CSC					
Mon 12/17/2018	to	Tue 12/18/2018			
0500	Continuous	1730			
Work scheduled by: NYPA					
				CENTRAL EAST - VC	2925 MW
				Impacts Total Transfer Capability	50 MW
				TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Sunday ,December 02, 2018 to Tuesday ,June 02, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT2

Mon 12/17/2018 to Fri 12/21/2018
0500 Continuous 1730

UPDATED by NYPA 11/09/2018

Work scheduled by: NYPA

ARR: 19

MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

FWD
(Import)

SCRIBA_-VOLNEY___345_21

Mon 12/17/2018 to Tue 12/18/2018
0600 Continuous 1730

UPDATED by NGRID 08/14/2018

Work scheduled by: NGrid

OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

FWD
(Import)

SPRNBRK__345KV_RNS5

Tue 12/18/2018 to Tue 12/18/2018
0001 Continuous 0030

Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

FWD
(Import)

SPRNBRK_-W49TH_ST_345_M51

Tue 12/18/2018 to Wed 12/19/2018
0001 Continuous 0200

Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

FWD
(Import)

SPRNBRK__345KV_RNS5

Wed 12/19/2018 to Wed 12/19/2018
0130 Continuous 0200

Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

FWD
(Import)

FRASANNX-COOPERS__345_UCC2-41

Sat 12/22/2018 to Wed 12/26/2018
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

FWD
(Import)

MARCY___-FRASANNX_345_UCC2-41

Sat 12/22/2018 to Wed 12/26/2018
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

FWD
(Import)

NYISO TRANSFER LIMITATIONS

Sunday ,December 02, 2018 to Tuesday ,June 02, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -ADIRNDCK_230_MA1				FWD
Wed 12/26/2018	to	Fri 12/28/2018	CANCELLED by NYPA 11/29/2018	(Import)
0700	Continuous	1530		MOSES SOUTH 2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW
EDIC -FRASER_345_EF24-40				FWD
Thu 12/27/2018	to	Mon 12/31/2018		(Import)
0700	Continuous	1730		CENTRAL EAST - VC 2500 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 475 MW
				TTC with All Lines In Service 2975 MW
BECK -NIAGARA_230_PA27				FWD
Sat 12/29/2018	to	Sat 12/29/2018	CANCELLED by NYPA 11/28/2018	(Import) (Export)
0500	Continuous	1700		SCH - OH - NY 1750 MW 1900 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 0 MW 0 MW
				TTC with All Lines In Service 1750 MW 1900 MW
SPRNBRK_345KV_RS3 & SPRNBRK_345KV_RS4				FWD
Tue 01/01/2019	to	Wed 01/02/2019		(Import)
0001		0200		SPR/DUN-SOUTH 3800 MW
Work scheduled by:				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
EFISHKIL-WOOD_ST_345_F39				FWD
Wed 01/02/2019	to	Wed 01/02/2019	UPDATED by CE 10/04/2018	(Import)
0001	Continuous	0030		UPNY CONED 4000 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1700 MW
				TTC with All Lines In Service 5700 MW
MOSES -ADIRNDCK_230_MA2				FWD
Wed 01/02/2019	to	Fri 01/04/2019		(Import)
0700	Continuous	1730		MOSES SOUTH 2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW
HURLYAVE-ROSETON_345_303				FWD
Wed 01/02/2019	to	Fri 01/11/2019	08/20/2018	(Import)
0800	Continuous	1600		UPNY CONED 4100 MW
Work scheduled by: CHGE				Impacts Total Transfer Capability 1600 MW
				TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Sunday ,December 02, 2018 to Tuesday ,June 02, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EFISHKIL-WOOD_ST__345_F39				FWD	
Thu 01/03/2019	to	Thu 01/03/2019	<u>UPDATED</u> <u>by CE</u> <u>10/04/2018</u>	(Import)	
0230	Continuous	0300		UPNY CONED	4000 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	1700 MW
				TTC with All Lines In Service	5700 MW
SCH-NE-NYISO_LIMIT_1100				FWD	
Mon 01/07/2019	to	Thu 01/10/2019		(Import)	
0700	Continuous	1600		SCH - NE - NY	1300 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	1400 MW
MOSES__-ADIRNDCK_230_MA1				FWD	
Mon 01/07/2019	to	Fri 01/11/2019		(Import)	
0700	Continuous	1500		MOSES SOUTH	2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
BECK__-PACKARD_230_BP76				FWD	REV
Wed 01/09/2019	to	Wed 01/09/2019		(Import)	(Export)
0800	Daily(No Weekends)	1500		SCH - OH - NY	1700 MW 1500 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	50 MW 400 MW
				TTC with All Lines In Service	1750 MW 1900 MW
BECK__-PACKARD_230_BP76 & STLAWRNC-MOSES__230_L33P				FWD	REV
Wed 01/09/2019	to	Wed 01/09/2019		(Import)	(Export)
0800		1500		SCH - OH - NY	900 MW 1150 MW
Work scheduled by:				Impacts Total Transfer Capability	850 MW 750 MW
				TTC with All Lines In Service	1750 MW 1900 MW
SPRNBK_-TREMONT__345_X28				FWD	
Mon 01/14/2019	to	Mon 01/14/2019		(Import)	
0001	Continuous	0100		SPR/DUN-SOUTH	4200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	400 MW
				TTC with All Lines In Service	4600 MW
MOSES__-ADIRNDCK_230_MA2				FWD	
Mon 01/14/2019	to	Fri 01/18/2019		(Import)	
0700	Continuous	1500		MOSES SOUTH	2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,December 02, 2018 to Tuesday ,June 02, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LEEDS___-HURLYAVE_345_301

Mon 01/14/2019 to Fri 01/25/2019
0800 Continuous 1600

Work scheduled by: CHGE

08/20/2018

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 1600 MW
TTC with All Lines In Service 5700 MW

SPRNBRK_-TREMONT__345_X28

Fri 01/18/2019 to Fri 01/18/2019
2200 Continuous 2300

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **4200 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_6

Mon 01/21/2019 to Mon 01/28/2019
0001 Continuous 0200

Work scheduled by: ConEd

UPDATED by CE 10/04/2018

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_8

Mon 01/21/2019 to Mon 01/28/2019
0001 Continuous 0200

Work scheduled by: ConEd

UPDATED by CE 10/04/2018

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

PLSNTVLE-DUNWODIE_345_W90

Mon 01/21/2019 to Mon 01/28/2019
0001 Continuous 0200

Work scheduled by: ConEd

UPDATED by CE 10/04/2018

FWD
(Import)
UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1700 MW
TTC with All Lines In Service 5700 MW

MOSES___-ADIRNDCK_230_MA2

Mon 01/21/2019 to Fri 01/25/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA1

Mon 01/28/2019 to Fri 02/01/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,December 02, 2018 to Tuesday ,June 02, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LEEDS___-HURLYAVE_345_301

Mon 01/28/2019 to Fri 02/08/2019
0800 Continuous 1600

Work scheduled by: CHGE

11/13/2018

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 1600 MW
TTC with All Lines In Service 5700 MW

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4

Tue 01/29/2019 to Sun 02/03/2019
0001 0300

Work scheduled by:

FWD
(Import)
UPNY CONED **3800 MW**
Impacts Total Transfer Capability 1900 MW
TTC with All Lines In Service 5700 MW

PLSNTVLY-EFISHKIL_345_F36

Sun 02/03/2019 to Wed 02/06/2019
0301 Continuous 0300

Work scheduled by: ConEd

UPDATED by CONED 11/21/2018

FWD
(Import)
UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1700 MW
TTC with All Lines In Service 5700 MW

MOSES___-ADIRNDCK_230_MA2

Mon 02/04/2019 to Thu 02/07/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4

Wed 02/06/2019 to Wed 02/06/2019
0330 0400

Work scheduled by:

FWD
(Import)
UPNY CONED **3800 MW**
Impacts Total Transfer Capability 1900 MW
TTC with All Lines In Service 5700 MW

EASTVIEW-SPRNBRK___345_W79

Thu 02/07/2019 to Thu 02/07/2019
0001 Continuous 0030

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1350 MW
TTC with All Lines In Service 5700 MW

BUCHAN_N-EASTVIEW_345_W93

Thu 02/07/2019 to Fri 02/08/2019
0001 Continuous 0300

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1350 MW
TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Sunday ,December 02, 2018 to Tuesday ,June 02, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ADIRNDCK-CHASLAKE_230_13

Thu 02/07/2019 to Thu 02/07/2019
0800 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

EASTVIEW-SPRNBK_345_W79

Fri 02/08/2019 to Fri 02/08/2019
0230 Continuous 0300

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1350 MW
TTC with All Lines In Service 5700 MW

MOSES__-ADIRNDCK_230_MA1

Fri 02/08/2019 to Fri 02/08/2019
0800 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MOSES__-ADIRNDCK_230_MA2

Mon 02/11/2019 to Fri 02/15/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MOSES__-ADIRNDCK_230_MA2

Tue 02/19/2019 to Fri 02/22/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MOSES__-ADIRNDCK_230_MA1

Mon 02/25/2019 to Fri 03/01/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4

Fri 03/01/2019 to Fri 03/01/2019
0001 2130

Work scheduled by:

FWD
(Import)
UPNY CONED **3800 MW**
Impacts Total Transfer Capability 1900 MW
TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Sunday ,December 02, 2018 to Tuesday ,June 02, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LONG_MTN-PLSNTVLY_345_398	FWD	REV
Fri 03/01/2019 to Sun 05/19/2019 UPDATED by CONED 11/28/2018 0001 Continuous 2359 Work scheduled by: ConEd	SCH - NE - NY Impacts Total Transfer Capability TTC with All Lines In Service	(Import) (Export) 700 MW 1300 MW 700 MW 300 MW 1400 MW 1600 MW
LONG_MTN-PLSNTVLY_345_398 Fri 03/01/2019 to Sun 05/19/2019 UPDATED by CONED 11/28/2018 0001 Continuous 2359 Work scheduled by: ConEd	SCH - NPX_1385 Impacts Total Transfer Capability TTC with All Lines In Service	(Import) (Export) 100 MW 100 MW 100 MW 100 MW 200 MW 200 MW
EASTVIEW-SPRNBK_345_W64 Mon 03/04/2019 to Mon 03/04/2019 0001 Continuous 0030 Work scheduled by: ConEd	UPNY CONED Impacts Total Transfer Capability TTC with All Lines In Service	FWD (Import) 4350 MW 1350 MW 5700 MW
MILLWOOD-EASTVIEW_345_W99 Mon 03/04/2019 to Thu 03/07/2019 0001 Continuous 2359 Work scheduled by: ConEd	UPNY CONED Impacts Total Transfer Capability TTC with All Lines In Service	FWD (Import) 4350 MW 1350 MW 5700 MW
PLSNTVLY-EFISHKIL_345_F37 Mon 03/04/2019 to Wed 03/06/2019 UPDATED by CONED 11/28/2018 0201 Continuous 0300 Work scheduled by: ConEd	UPNY CONED Impacts Total Transfer Capability TTC with All Lines In Service	FWD (Import) 4000 MW 1700 MW 5700 MW
MOSES -ADIRNDCK_230_MA1 Mon 03/04/2019 to Fri 03/08/2019 0700 Continuous 1500 Work scheduled by: NYPA	MOSES SOUTH Impacts Total Transfer Capability TTC with All Lines In Service	FWD (Import) 2300 MW 850 MW 3150 MW
EASTVIEW-SPRNBK_345_W64 Thu 03/07/2019 to Thu 03/07/2019 2330 Continuous 2359 Work scheduled by: ConEd	UPNY CONED Impacts Total Transfer Capability TTC with All Lines In Service	FWD (Import) 4350 MW 1350 MW 5700 MW

NYISO TRANSFER LIMITATIONS

Sunday ,December 02, 2018 to Tuesday ,June 02, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>STLAWRNC-MOSES 230_L33P & STLAWRNC-MOSES 230_L34P</p> <p>Mon 03/11/2019 to Mon 03/11/2019 0700 1530</p> <p>Work scheduled by:</p>	<p>FWD (Import)</p> <p>MOSES SOUTH 2700 MW</p> <p>Impacts Total Transfer Capability 450 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>STLAWRNC-MOSES 230_L34P</p> <p>Mon 03/11/2019 to Mon 03/11/2019 0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p>FWD REV (Import) (Export)</p> <p>SCH - OH - NY 1750 MW 1900 MW</p> <p>Impacts Total Transfer Capability 0 MW 0 MW</p> <p>TTC with All Lines In Service 1750 MW 1900 MW</p>
<p>LEEDS 345_LEEDS SVC</p> <p>Mon 03/11/2019 to Fri 03/22/2019 0800 Continuous 1600</p> <p>Work scheduled by: NGrid</p>	<p>FWD (Import)</p> <p>CENTRAL EAST - VC 2950 MW</p> <p>Impacts Total Transfer Capability 25 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p>MOSES -ADIRNDCK_230_MA1</p> <p>Tue 03/12/2019 to Fri 03/15/2019 0700 Continuous 1500</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import)</p> <p>MOSES SOUTH 2300 MW</p> <p>Impacts Total Transfer Capability 850 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>MARCY 765_345_AT1</p> <p>Mon 03/18/2019 to Fri 03/22/2019 0500 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import)</p> <p>MOSES SOUTH 1750 MW</p> <p>Impacts Total Transfer Capability 1400 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>MARCY 345KV_CSC</p> <p>Mon 04/01/2019 to Sun 04/07/2019 0500 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import)</p> <p>CENTRAL EAST - VC 2925 MW</p> <p>Impacts Total Transfer Capability 50 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p>VOLNEY -MARC_345_19</p> <p>Mon 04/01/2019 to Wed 04/10/2019 0500 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import)</p> <p>CENTRAL EAST - VC 2825 MW</p> <p>Impacts Total Transfer Capability 150 MW</p> <p>TTC with All Lines In Service 2975 MW</p>

ARR: 19

ARR: 19

NYISO TRANSFER LIMITATIONS

Sunday ,December 02, 2018 to Tuesday ,June 02, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

VOLNEY__-MARCY___345_19				FWD	
Mon 04/01/2019	to	Wed 04/10/2019		(Import)	
0500	Continuous	1730	OSWEGO EXPORT	4900 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	350 MW	
			TTC with All Lines In Service	5250 MW	
PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4				FWD	
Wed 04/03/2019	to	Sat 04/13/2019		(Import)	
0001		0300	UPNY CONED	3800 MW	
Work scheduled by:			Impacts Total Transfer Capability	1900 MW	
			TTC with All Lines In Service	5700 MW	
PLSNTVLY-EFISHKIL_345_F37				FWD	
Thu 04/04/2019	to	Mon 04/08/2019	<u>UPDATED</u> <u>by CONED</u> <u>11/28/2018</u>	(Import)	
0001	Continuous	0200	UPNY CONED	4000 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	1700 MW	
			TTC with All Lines In Service	5700 MW	
DUNWODIE-MOTTHAVN_345_71				FWD	
Fri 04/05/2019	to	Thu 05/09/2019		(Import)	
0001	Continuous	2359	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
NIAGARA_-ROCHESTR_345_NR2				FWD	
Fri 04/05/2019	to	Fri 04/05/2019		(Import)	
0500	Continuous	1700	DYSINGER EAST	1700 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1450 MW	
			TTC with All Lines In Service	3150 MW	
LINDN_CG-LNDVFT___345_V-3022				FWD	REV
Sun 04/07/2019	to	Fri 04/12/2019		(Import)	(Export)
1400	Continuous	1800	SCH - PJM_VFT	0 MW	0 MW
Work scheduled by: PJM			Impacts Total Transfer Capability	315 MW	315 MW
			TTC with All Lines In Service	315 MW	315 MW
PLSNTVLE-DUNWODIE_345_W89				FWD	
Mon 04/08/2019	to	Fri 05/10/2019		(Import)	
0001	Continuous	2359	UPNY CONED	4000 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	1700 MW	
			TTC with All Lines In Service	5700 MW	

NYISO TRANSFER LIMITATIONS

Sunday ,December 02, 2018 to Tuesday ,June 02, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___345KV_CSC

Thu 04/11/2019 to Wed 04/17/2019
0500 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC **2925 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

MARCY___-EDIC___345_UE1-7

Thu 04/11/2019 to Sat 04/20/2019
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19&16

FWD

(Import)

OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

GILBOA__-N.SCTLND_345_GNS-1

Fri 04/12/2019 to Fri 04/12/2019
1330 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC **2520 MW**
Impacts Total Transfer Capability 455 MW
TTC with All Lines In Service 2975 MW

EDIC___-FRASER___345_EF24-40

Mon 04/22/2019 to Fri 04/26/2019
0500 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

MARCY___765_345_AT2

Mon 04/22/2019 to Fri 04/26/2019
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

FRASANX-COOPERS__345_UCC2-41

Mon 04/29/2019 to Fri 05/03/2019 **UPDATED by NYPA 08/22/2018**
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

MARCY___-FRASANX_345_UCC2-41

Mon 04/29/2019 to Fri 05/03/2019 **UPDATED by NYPA 08/22/2018**
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Sunday ,December 02, 2018 to Tuesday ,June 02, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA1

Mon 04/29/2019 to Fri 05/03/2019
 0700 Continuous 1500

Work scheduled by: NYPA

FWD
 (Import)
MOSES SOUTH 2300 MW
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

HUDSONTP-W49TH_ST_345_Y56

Wed 05/01/2019 to Tue 05/07/2019
 0600 Continuous 1800

Work scheduled by: PJM

FWD
 (Import)
SCH - PJM_HTP 0 MW
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

KINTIGH_-ROCHESTR_345_SRI-39

Mon 05/06/2019 to Fri 05/10/2019
 0600 Continuous 1700

Work scheduled by: NYPA

UPDATED by NYSEG 11/08/2018

FWD
 (Import)
DYSINGER EAST 1400 MW
 Impacts Total Transfer Capability 1750 MW
 TTC with All Lines In Service 3150 MW

ROSETON_-ROCKTVRN_345_311

Mon 05/06/2019 to Sat 06/01/2019
 0800 Continuous 1600

Work scheduled by: CHGE

FWD
 (Import)
UPNY CONED 4400 MW
 Impacts Total Transfer Capability 1300 MW
 TTC with All Lines In Service 5700 MW

NIAGARA_-ROCHESTR_345_NR2

Mon 05/13/2019 to Fri 05/17/2019
 0600 Continuous 1700

Work scheduled by: NYPA

FWD
 (Import)
DYSINGER EAST 1400 MW
 Impacts Total Transfer Capability 1750 MW
 TTC with All Lines In Service 3150 MW

ADIRNDCK-PORTER___230_12

Mon 05/20/2019 to Fri 05/24/2019
 0700 Continuous 1530

Work scheduled by: NYPA

FWD
 (Import)
MOSES SOUTH 2100 MW
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW

PANNELL_-CLAY_____345_1

Mon 05/20/2019 to Fri 05/24/2019
 0700 Continuous 1530

Work scheduled by: NYPA

FWD
 (Import)
WEST CENTRAL 1300 MW
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

NYISO TRANSFER LIMITATIONS

Sunday ,December 02, 2018 to Tuesday ,June 02, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PANNELL_-CLAY_____345_2

Mon 06/03/2019 to Fri 06/07/2019
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

MOSES_-ADIRNDCK_230_MA2

Mon 06/24/2019 to Fri 06/28/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

MOSES_-ADIRNDCK_230_MA2

Mon 07/08/2019 to Fri 07/12/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

ADIRNDCK-CHASLAKE_230_13

Mon 07/08/2019 to Fri 07/12/2019
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

MARCY_____765_345_AT2

Sat 08/03/2019 to Sun 08/04/2019
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

MOSES_-ADIRNDCK_230_MA1

Mon 08/12/2019 to Mon 08/12/2019 **UPDATED by NYPA 10/10/2018**
0700 Continuous 1459

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

MARCY_____765_345_AT1

Tue 09/03/2019 to Tue 09/03/2019
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1750 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,December 02, 2018 to Tuesday ,June 02, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___-N.SCTLND_345_18

Wed 09/04/2019 to Wed 09/04/2019
0500 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 11/06/2018

ARR: 19

FWD

(Import)

CENTRAL EAST - VC **2090 MW**
Impacts Total Transfer Capability 885 MW
TTC with All Lines In Service 2975 MW

MARCY___345KV_CSC

Wed 09/04/2019 to Wed 09/04/2019
0500 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 11/06/2018

FWD

(Import)

CENTRAL EAST - VC **2925 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

MOSES___-ADIRNDCK_230_MA2

Wed 09/04/2019 to Wed 09/04/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

ADIRNDCK-PORTER___230_12

Wed 09/04/2019 to Wed 09/04/2019
0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

ADIRNDCK-CHASLAKE_230_13

Thu 09/05/2019 to Thu 09/05/2019
0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

NIAGARA_-ROCHESTR_345_NR2

Mon 09/09/2019 to Sat 09/21/2019
0500 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

LEEDS___345KV_R395

Mon 09/09/2019 to Mon 09/09/2019
0700 Continuous 0730

Work scheduled by: NYPA

FWD

(Import)

UPNY CONED **3800 MW**
Impacts Total Transfer Capability 1900 MW
TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Sunday ,December 02, 2018 to Tuesday ,June 02, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

GILBOA -LEEDS 345_GL3

Mon 09/09/2019 to Fri 09/27/2019
 0700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2200 MW**
 Impacts Total Transfer Capability 775 MW
 TTC with All Lines In Service 2975 MW

MARCY -N.SCTLND 345_18

Wed 09/11/2019 to Fri 09/13/2019
 0500 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 CENTRAL EAST - VC **2090 MW**
 Impacts Total Transfer Capability 885 MW
 TTC with All Lines In Service 2975 MW

MOSES -ADIRNDCK 230_MA2

Mon 09/16/2019 to Fri 09/20/2019
 0700 Continuous 1500
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2100 MW**
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW

GOETHALS 345KV_5

Fri 09/20/2019 to Tue 09/24/2019
 0001 Continuous 2359
 Work scheduled by: ConEd

STATEN ISLAND
 Impacts Total Transfer Capability
 TTC with All Lines In Service

ROCHESTR-PANNELL 345_RP2

Mon 09/23/2019 to Mon 09/30/2019
 0500 Continuous 1700
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

KINTIGH -ROCHESTR 345_SR1-39

Mon 09/23/2019 to Fri 09/27/2019
 0600 Continuous 1700
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **1400 MW**
 Impacts Total Transfer Capability 1750 MW
 TTC with All Lines In Service 3150 MW

SPRNBK -W49TH_ST 345_M51

Wed 09/25/2019 to Fri 11/01/2019
 0001 Continuous 2359
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,December 02, 2018 to Tuesday ,June 02, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LEEDS___345KV_R395		FWD	
Fri 09/27/2019	to	Fri 09/27/2019	(Import)
1700	Continuous	1730	
Work scheduled by: NYPA		UPNY CONED	3800 MW
		Impacts Total Transfer Capability	1900 MW
		TTC with All Lines In Service	5700 MW
CLAY___-EDIC___345_1-16		FWD	
Mon 09/30/2019	to	Fri 10/04/2019	(Import)
0700	Continuous	1530	
Work scheduled by: NYPA		OSWEGO EXPORT	4850 MW
		Impacts Total Transfer Capability	400 MW
		TTC with All Lines In Service	5250 MW
LEEDS___-HURLYAVE_345_301		FWD	
Mon 09/30/2019	to	Sat 10/26/2019	(Import)
0800	Continuous	1600	
Work scheduled by: CHGE		UPNY CONED	4100 MW
		Impacts Total Transfer Capability	1600 MW
		TTC with All Lines In Service	5700 MW
CLAY___-EDIC___345_2-15		FWD	
Mon 10/07/2019	to	Thu 10/17/2019	(Import)
0700	Continuous	1530	
Work scheduled by: NYPA		OSWEGO EXPORT	4850 MW
		Impacts Total Transfer Capability	400 MW
		TTC with All Lines In Service	5250 MW
MARCY___-N.SCTLND_345_18		FWD	
Wed 10/09/2019	to	Fri 10/11/2019	(Import)
0500	Continuous	1730	
Work scheduled by: NYPA		CENTRAL EAST - VC	2090 MW
		Impacts Total Transfer Capability	885 MW
		TTC with All Lines In Service	2975 MW
CHATGUAY-MASSENA___765_7040		FWD	
Sat 10/12/2019	to	Sat 10/26/2019	(Import)
0100	Continuous	1900	
Work scheduled by: NYPA		MOSES SOUTH	1550 MW
		Impacts Total Transfer Capability	1600 MW
		TTC with All Lines In Service	3150 MW
CHATGUAY-MASSENA___765_7040		FWD	REV
Sat 10/12/2019	to	Sat 10/26/2019	(Import) (Export)
0100	Continuous	1900	
Work scheduled by: NYPA		SCH - HQ - NY	0 MW 0 MW
		Impacts Total Transfer Capability	1500 MW 1000 MW
		TTC with All Lines In Service	1500 MW 1000 MW

ARR: 19

NYISO TRANSFER LIMITATIONS

Sunday ,December 02, 2018 to Tuesday ,June 02, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>MARCY___765_345_AT1</p> <p>Sat 10/12/2019 to Sat 10/26/2019 0100 Continuous 1900</p> <p>Work scheduled by: NYPA</p>	<p>ARR: 19</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH 1750 MW</p> <p>Impacts Total Transfer Capability 1400 MW</p> <p>TTC with All Lines In Service 3150 MW</p>															
<p>MARCY___765_345_AT2</p> <p>Sat 10/12/2019 to Sat 10/26/2019 0100 Continuous 1900</p> <p>Work scheduled by: NYPA</p>	<p>ARR: 19</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH 1700 MW</p> <p>Impacts Total Transfer Capability 1450 MW</p> <p>TTC with All Lines In Service 3150 MW</p>															
<p>MASSENA_-MARCY___765_MSU1</p> <p>Sat 10/12/2019 to Sat 10/26/2019 0100 Continuous 1900</p> <p>Work scheduled by: NYPA</p>		<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC 2265 MW</p> <p>Impacts Total Transfer Capability 710 MW</p> <p>TTC with All Lines In Service 2975 MW</p>															
<p>MASSENA_-MARCY___765_MSU1</p> <p>Sat 10/12/2019 to Sat 10/26/2019 0100 Continuous 1900</p> <p>Work scheduled by: NYPA</p>		<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH 500 MW</p> <p>Impacts Total Transfer Capability 2650 MW</p> <p>TTC with All Lines In Service 3150 MW</p>															
<p>MASSENA_-MARCY___765_MSU1</p> <p>Sat 10/12/2019 to Sat 10/26/2019 0100 Continuous 1900</p> <p>Work scheduled by: NYPA</p>		<table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 60%;"></td> <td style="width: 20%; text-align: right;">FWD</td> <td style="width: 20%; text-align: right;">REV</td> </tr> <tr> <td></td> <td style="text-align: right;">(Import)</td> <td style="text-align: right;">(Export)</td> </tr> <tr> <td>SCH - HQ - NY</td> <td style="text-align: right;">475 MW</td> <td style="text-align: right;">1000 MW</td> </tr> <tr> <td>Impacts Total Transfer Capability</td> <td style="text-align: right;">1025 MW</td> <td style="text-align: right;">0 MW</td> </tr> <tr> <td>TTC with All Lines In Service</td> <td style="text-align: right;">1500 MW</td> <td style="text-align: right;">1000 MW</td> </tr> </table>		FWD	REV		(Import)	(Export)	SCH - HQ - NY	475 MW	1000 MW	Impacts Total Transfer Capability	1025 MW	0 MW	TTC with All Lines In Service	1500 MW	1000 MW
	FWD	REV															
	(Import)	(Export)															
SCH - HQ - NY	475 MW	1000 MW															
Impacts Total Transfer Capability	1025 MW	0 MW															
TTC with All Lines In Service	1500 MW	1000 MW															
<p>MASSENA_-MARCY___765_MSU1 & CHATGUAY-MASSENA_765_7040</p> <p>Sat 10/12/2019 to Sat 10/26/2019 0100 1900</p> <p>Work scheduled by:</p>		<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH 500 MW</p> <p>Impacts Total Transfer Capability 2650 MW</p> <p>TTC with All Lines In Service 3150 MW</p>															
<p>MOSES_-MASSENA_230_MMS1 & MOSES_-MASSENA_230_MMS2</p> <p>Sat 10/12/2019 to Sat 10/26/2019 0100 1900</p> <p>Work scheduled by:</p>		<table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 60%;"></td> <td style="width: 20%; text-align: right;">FWD</td> <td style="width: 20%; text-align: right;">REV</td> </tr> <tr> <td></td> <td style="text-align: right;">(Import)</td> <td style="text-align: right;">(Export)</td> </tr> <tr> <td>SCH - HQ - NY</td> <td style="text-align: right;">850 MW</td> <td style="text-align: right;">0 MW</td> </tr> <tr> <td>Impacts Total Transfer Capability</td> <td style="text-align: right;">650 MW</td> <td style="text-align: right;">1000 MW</td> </tr> <tr> <td>TTC with All Lines In Service</td> <td style="text-align: right;">1500 MW</td> <td style="text-align: right;">1000 MW</td> </tr> </table>		FWD	REV		(Import)	(Export)	SCH - HQ - NY	850 MW	0 MW	Impacts Total Transfer Capability	650 MW	1000 MW	TTC with All Lines In Service	1500 MW	1000 MW
	FWD	REV															
	(Import)	(Export)															
SCH - HQ - NY	850 MW	0 MW															
Impacts Total Transfer Capability	650 MW	1000 MW															
TTC with All Lines In Service	1500 MW	1000 MW															

NYISO TRANSFER LIMITATIONS

Sunday ,December 02, 2018 to Tuesday ,June 02, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA__345_230_AT4

Wed 10/23/2019 to Wed 12/18/2019
 0500 Continuous 1700
 Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	1900 MW	1400 MW
Impacts Total Transfer Capability	0 MW	350 MW
TTC with All Lines In Service	1900 MW	1750 MW

HURLYAVE-ROSETON__345_303

Mon 11/04/2019 to Fri 12/06/2019
 0800 Continuous 1600
 Work scheduled by: CHGE

	FWD
	(Import)
UPNY CONED	4100 MW
Impacts Total Transfer Capability	1600 MW
TTC with All Lines In Service	5700 MW

PANNELL_-CLAY____345_2

Wed 11/06/2019 to Fri 11/22/2019
 0700 Continuous 1530
 Work scheduled by: NYPA

	FWD
	(Import)
WEST CENTRAL	1300 MW
Impacts Total Transfer Capability	950 MW
TTC with All Lines In Service	2250 MW

MARCY___-N.SCTLND_345_18

Thu 11/07/2019 to Fri 11/08/2019
 0500 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

	FWD
	(Import)
CENTRAL EAST - VC	2090 MW
Impacts Total Transfer Capability	885 MW
TTC with All Lines In Service	2975 MW

MARCY___345KV_CSC

Thu 11/07/2019 to Fri 11/08/2019
 0500 Continuous 1730
 Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	2925 MW
Impacts Total Transfer Capability	50 MW
TTC with All Lines In Service	2975 MW

MOSES___-ADIRNDCK_230_MA2

Tue 11/12/2019 to Fri 11/15/2019
 0700 Continuous 1500
 Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 11/18/2019 to Fri 11/22/2019
 0700 Continuous 1500
 Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,December 02, 2018 to Tuesday ,June 02, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA2

Mon 11/25/2019 to Wed 11/27/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 12/02/2019 to Fri 12/06/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA1

Mon 12/09/2019 to Fri 12/13/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 12/16/2019 to Mon 12/16/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA1

Tue 12/17/2019 to Fri 12/20/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

LADENTWN-BUCHAN_S_345_Y88

Wed 01/15/2020 to Thu 02/13/2020
0001 Continuous 2359

Work scheduled by: ORU

11/05/2018

FWD
(Import)
UPNY CONED **4800 MW**
Impacts Total Transfer Capability 900 MW
TTC with All Lines In Service 5700 MW

FRASANX-COOPERS__345_UCC2-41

Mon 04/27/2020 to Sun 05/31/2020
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

ARR: 19

NYISO TRANSFER LIMITATIONS

Sunday ,December 02, 2018 to Tuesday ,June 02, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___-FRASANX_345_UCC2-41

FWD

Mon 04/27/2020 to Sun 05/31/2020
 0700 Continuous 1530

(Import)

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC 2500 MW
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW