

# NYISO TRANSFER LIMITATIONS

Tuesday ,December 04, 2018 to Thursday ,June 04, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
<b>HUDSONP_-FARRAGUT_345_B3402</b>						
Mon 01/15/2018	to	Mon 04/01/2019	<u>EXT FORCE</u>	<u>by CONED</u>	<u>12/02/2018</u>	
0001	Continuous	2359				
Work scheduled by: ConEd					SCH - PJ - NY	<b>2600 MW</b>
					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	2600 MW
<b>HUDSONP_-FARRAGUT_345_B3402 &amp; MARION_-FARRAGUT_345_C3403</b>						
Mon 01/15/2018	to	Mon 04/01/2019				
0001		2359				
Work scheduled by:					SCH - PJ - NY	<b>2000 MW</b>
					Impacts Total Transfer Capability	600 MW
					TTC with All Lines In Service	2600 MW
<b>MARION_-FARRAGUT_345_C3403</b>						
Mon 01/15/2018	to	Mon 04/01/2019	<u>EXT FORCE</u>	<u>by CONED</u>	<u>12/02/2018</u>	
0001	Continuous	2359				
Work scheduled by: ConEd					SCH - PJ - NY	<b>2600 MW</b>
					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	2600 MW
<b>STLAWRNC-MOSES____230_L33P</b>						
Mon 04/30/2018	to	Fri 12/31/2021	<u>EXT FORCE</u>	<u>by IESO</u>	<u>08/21/2018</u>	
0456	Continuous	2359				
Work scheduled by: IESO					SCH - OH - NY	<b>1750 MW</b>
					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	1750 MW
<b>DUNWODIE_345KV_6</b>						
Mon 10/22/2018	to	Sat 12/22/2018	<u>UPDATED</u>	<u>by CE</u>	<u>10/04/2018</u>	
0301	Continuous	0200				
Work scheduled by: ConEd					SPR/DUN-SOUTH	<b>3800 MW</b>
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>DUNWODIE_345KV_8</b>						
Mon 10/22/2018	to	Sat 12/22/2018	<u>UPDATED</u>	<u>by CE</u>	<u>10/04/2018</u>	
0301	Continuous	0200				
Work scheduled by: ConEd					SPR/DUN-SOUTH	<b>3800 MW</b>
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>PLSNTVLE-DUNWODIE_345_W90</b>						
Mon 10/22/2018	to	Sat 12/22/2018	<u>UPDATED</u>	<u>by CE</u>	<u>10/04/2018</u>	
0301	Continuous	0200				
Work scheduled by: ConEd					UPNY CONED	<b>4000 MW</b>
					Impacts Total Transfer Capability	1700 MW
					TTC with All Lines In Service	5700 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,December 04, 2018 to Thursday ,June 04, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
<b>S.RIPLEY-DUNKIRK__230_68</b>							
Mon 10/22/2018	to	Fri 12/14/2018	<u>UPDATED</u>	<u>by PJM</u>	<u>11/20/2018</u>		
0800	Continuous	2000				SCH - PJ - NY	<b>2600 MW</b>
Work scheduled by: PJM						Impacts Total Transfer Capability	0 MW
						TTC with All Lines In Service	2600 MW
							1550 MW
<b>SCH-IMO-NYISO_LIMIT_1400</b>							
						FWD	
						(Import)	
Thu 11/01/2018	to	Mon 12/31/2018				SCH - OH - NY	<b>1700 MW</b>
0001	Continuous	2359				Impacts Total Transfer Capability	50 MW
Work scheduled by: IESO						TTC with All Lines In Service	1750 MW
<b>SCH-NYISO-IMO_LIMIT_1600</b>							
							REV
							(Export)
Thu 11/01/2018	to	Mon 12/31/2018				SCH - OH - NY	<b>1900 MW</b>
0001	Continuous	2359				Impacts Total Transfer Capability	100 MW
Work scheduled by: IESO						TTC with All Lines In Service	2000 MW
<b>SCH-IMO-NYISO_LIMIT_1300</b>							
						FWD	
						(Import)	
Thu 11/15/2018	to	Thu 12/20/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>11/20/2018</u>	SCH - OH - NY	<b>1600 MW</b>
0500	Continuous	2359				Impacts Total Transfer Capability	150 MW
Work scheduled by: NYPA						TTC with All Lines In Service	1750 MW
<b>LONG_MTN-PLSNTVLY_345_398</b>							
						FWD	REV
						(Import)	(Export)
Mon 11/26/2018	to	Thu 12/06/2018	<u>UPDATED</u>	<u>by CONED</u>	<u>11/21/2018</u>	SCH - NE - NY	<b>700 MW</b>
0001	Continuous	0030				Impacts Total Transfer Capability	700 MW
Work scheduled by: ConEd						TTC with All Lines In Service	1400 MW
							1800 MW
<b>LONG_MTN-PLSNTVLY_345_398</b>							
						FWD	REV
						(Import)	(Export)
Mon 11/26/2018	to	Thu 12/06/2018	<u>UPDATED</u>	<u>by CONED</u>	<u>11/21/2018</u>	SCH - NPX_1385	<b>100 MW</b>
0001	Continuous	0030				Impacts Total Transfer Capability	100 MW
Work scheduled by: ConEd						TTC with All Lines In Service	200 MW
							200 MW
<b>SCH-NYISO-NE_LIMIT_700</b>							
							REV
							(Export)
Mon 11/26/2018	to	Thu 12/06/2018	<u>UPDATED</u>	<u>by CONED</u>	<u>11/21/2018</u>	SCH - NE - NY	<b>900 MW</b>
0001	Continuous	0030				Impacts Total Transfer Capability	900 MW
Work scheduled by: ConEd						TTC with All Lines In Service	1800 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,December 04, 2018 to Thursday ,June 04, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES -ADIRNDCK\_230\_MA2**

Mon 11/26/2018 to Fri 11/30/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**SHOR\_NPX-SHOREHAM\_138\_CSC**

Mon 11/26/2018 to Fri 12/07/2018  
0700 Continuous 1600

Work scheduled by: LI

FWD REV  
(Import) (Export)  
SCH - NPX\_CSC **0 MW 0 MW**  
Impacts Total Transfer Capability 330 MW 330 MW  
TTC with All Lines In Service 330 MW 330 MW

**HURLYAVE-ROSETON\_345\_303**

Mon 11/26/2018 to Fri 12/21/2018  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 5700 MW

**HOMR\_NYW-PIERC\_NY\_345\_48**

Wed 11/28/2018 to Wed 12/05/2018  
1305 Continuous 1600

Work scheduled by: PJM

**EXT FORCE by PJM 11/30/2018**

FWD REV  
(Import) (Export)  
SCH - PJ - NY **2500 MW 1300 MW**  
Impacts Total Transfer Capability 100 MW 250 MW  
TTC with All Lines In Service 2600 MW 1550 MW

**SCH-IMO-NYISO\_LIMIT\_300**

Thu 11/29/2018 to Thu 11/29/2018  
0800 Daily(No Weekends) 1100

Work scheduled by: NGrid

**UPDATED by NYISO 11/27/2018**

FWD  
(Import)  
SCH - OH - NY **600 MW**  
Impacts Total Transfer Capability 1150 MW  
TTC with All Lines In Service 1750 MW

**SCH-NYISO-HQ\_LIMIT\_800**

Thu 11/29/2018 to Thu 12/06/2018  
2001 Continuous 1800

Work scheduled by: HQ

REV  
(Export)  
SCH - HQ - NY **800 MW**  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 1000 MW

**SCH-IMO-NYISO\_LIMIT\_1050**

Fri 11/30/2018 to Fri 11/30/2018  
0800 Daily(No Weekends) 1200

Work scheduled by: NGrid

**UPDATED by NGRID 11/28/2018**

FWD  
(Import)  
SCH - OH - NY **1350 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 1750 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,December 04, 2018 to Thursday ,June 04, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO-NYISO\_LIMIT\_700

Sat 12/01/2018 to Sun 12/02/2018  
0500 Continuous 2300

**UPDATED by NYISO 11/29/2018**

Work scheduled by: NYISO

FWD  
(Import)  
SCH - OH - NY **1000 MW**  
Impacts Total Transfer Capability 750 MW  
TTC with All Lines In Service 1750 MW

CLRKSCRN-OAKDALE\_345\_36

Sat 12/01/2018 to Sat 12/01/2018  
0700 Daily 1800

**UPDATED by NYSEG 11/14/2018**

Work scheduled by: NYSEG

FWD  
(Import)  
CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

DUNWODIE-MOTTHAVN\_345\_72

Sun 12/02/2018 to Thu 12/06/2018  
0001 Continuous 0159

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

DUNWODIE\_345KV\_7

Sun 12/02/2018 to Thu 12/06/2018  
0001 Continuous 0159

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

OSWEGO\_COMPLEX\_AVR\_O/S

Sun 12/02/2018 to Sun 12/02/2018  
0900 Continuous 0930

Work scheduled by: Gen

FWD  
(Import)  
CENTRAL EAST - VC **2870 MW**  
Impacts Total Transfer Capability 105 MW  
TTC with All Lines In Service 2975 MW

BECK\_-NIAGARA\_345\_PA302

Mon 12/03/2018 to Wed 12/05/2018  
0500 Continuous 1900

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **1100 MW 950 MW**  
Impacts Total Transfer Capability 650 MW 1050 MW  
TTC with All Lines In Service 1750 MW 2000 MW

MOSES\_-ADIRNDCK\_230\_MA2

Mon 12/03/2018 to Fri 12/07/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,December 04, 2018 to Thursday ,June 04, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE-SHORE\_RD\_345\_Y50**

Thu 12/06/2018 to Wed 12/12/2018  
 0201 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 CONED - LIPA **800 MW**  
 Impacts Total Transfer Capability 700 MW  
 TTC with All Lines In Service 1500 MW

**DUNWODIE\_345KV\_4**

Thu 12/06/2018 to Wed 12/12/2018  
 0201 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**SHORE\_RD\_345\_138\_BK 1**

Thu 12/06/2018 to Wed 12/12/2018  
 0201 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 CONED - LIPA **1350 MW**  
 Impacts Total Transfer Capability 150 MW  
 TTC with All Lines In Service 1500 MW

**SHORE\_RD\_345\_138\_BK 2**

Thu 12/06/2018 to Wed 12/12/2018  
 0201 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 CONED - LIPA **1350 MW**  
 Impacts Total Transfer Capability 150 MW  
 TTC with All Lines In Service 1500 MW

**CHATGUAY-MASSENA\_\_765\_7040**

Sat 12/08/2018 to Sat 12/08/2018 **UPDATED by NYPA 11/16/2018**  
 0700 Continuous 2300  
 Work scheduled by: HQ

FWD  
 (Import)  
 MOSES SOUTH **1550 MW**  
 Impacts Total Transfer Capability 1600 MW  
 TTC with All Lines In Service 3150 MW

**CHATGUAY-MASSENA\_\_765\_7040**

Sat 12/08/2018 to Sat 12/08/2018 **UPDATED by NYPA 11/16/2018**  
 0700 Continuous 2300  
 Work scheduled by: HQ

FWD REV  
 (Import) (Export)  
 SCH - HQ - NY **0 MW 0 MW**  
 Impacts Total Transfer Capability 1500 MW 1000 MW  
 TTC with All Lines In Service 1500 MW 1000 MW

**BROWNFLS-TAYLORVL\_115\_4**

Sat 12/08/2018 to Sat 12/08/2018  
 0800 Continuous 1600  
 Work scheduled by: NGrid **ARR: 38**

FWD REV  
 (Import) (Export)  
 SCH - HQ\_CEDARS **100 MW 100 MW**  
 Impacts Total Transfer Capability 99 MW 0 MW  
 TTC with All Lines In Service 199 MW 100 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,December 04, 2018 to Thursday ,June 04, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**CEDARS\_\_-ROSEMNTB\_115\_2/22**

Sat 12/08/2018 to Sat 12/08/2018  
0800 Continuous 1600

Work scheduled by: HQ

**ARR: 38**

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	<b>95 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	104 MW	0 MW
TTC with All Lines In Service	199 MW	100 MW

**DENNISON-ROSEMNTB\_115\_2/22**

Sat 12/08/2018 to Sat 12/08/2018  
0800 Continuous 1600

Work scheduled by: HQ

**ARR: 38**

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	<b>95 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	104 MW	0 MW
TTC with All Lines In Service	199 MW	100 MW

**SCH-NYISO-HQ\_CEDARS\_LIMIT\_0**

Sat 12/08/2018 to Sat 12/08/2018  
0800 Continuous 1600

Work scheduled by: HQ

		REV
		(Export)
SCH - HQ_CEDARS		<b>0 MW</b>
Impacts Total Transfer Capability		100 MW
TTC with All Lines In Service		100 MW

**CLRKSCRN-OAKDALE\_\_345\_36**

Sun 12/09/2018 to Sun 12/09/2018  
0700 Continuous 1600

Work scheduled by: NYSEG

	FWD
	(Import)
CENTRAL EAST - VC	<b>2650 MW</b>
Impacts Total Transfer Capability	325 MW
TTC with All Lines In Service	2975 MW

**BROWNFLS-TAYLORVL\_115\_3**

Sun 12/09/2018 to Sun 12/09/2018  
0700 Continuous 1700

Work scheduled by: NGrid

**ARR: 38**

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	99 MW	0 MW
TTC with All Lines In Service	199 MW	100 MW

**BROWNFLS-TAYLORVL\_115\_3 & TAYLORVL-LOWVILLE\_115\_5 & CLIMAX\_\_-TAYLORVL\_115\_8**

Sun 12/09/2018 to Sun 12/09/2018  
0700 Continuous 1700

Work scheduled by:

**ARR: 38**

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	<b>120 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	79 MW	0 MW
TTC with All Lines In Service	199 MW	100 MW

**TAYLORVL-LOWVILLE\_115\_5**

Sun 12/09/2018 to Sun 12/09/2018  
0700 Continuous 1700

Work scheduled by: NGrid

**ARR: 38**

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	<b>199 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	199 MW	100 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,December 04, 2018 to Thursday ,June 04, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Transfer Limitation	Start Date	End Date	Time	Work Scheduled by	Transfer Capability	Impacts	TTC
<b>SCH-IMO-NYISO_LIMIT_900</b>	Mon 12/10/2018	Mon 12/10/2018	0600 - 1800	NGrid	1200 MW	550 MW	1750 MW
<b>FIVEMILE-STOLLERD_345_29</b>	Mon 12/10/2018	Wed 12/12/2018	0700 - 1555	NGrid	2600 MW	0 MW	2600 MW
<b>MOSES__-ADIRNDCK_230_MA2</b>	Mon 12/10/2018	Fri 12/14/2018	0700 - 1530	NYPA	2300 MW	850 MW	3150 MW
<b>WOOD_ST_-PLSNTVLE_345_Y87</b>	Mon 12/17/2018	Mon 01/28/2019	0001 - 0200	ConEd	4000 MW	1700 MW	5700 MW
<b>MARCY___345KV_CSC</b>	Mon 12/17/2018	Tue 12/18/2018	0500 - 1730	NYPA	2925 MW	50 MW	2975 MW
<b>MARCY___765_345_AT2</b>	Mon 12/17/2018	Fri 12/21/2018	0500 - 1730	NYPA	1700 MW	1450 MW	3150 MW
<b>SCRIBA__-VOLNEY___345_21</b>	Mon 12/17/2018	Tue 12/18/2018	0600 - 1730	NGrid	5250 MW	0 MW	5250 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,December 04, 2018 to Thursday ,June 04, 2020

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			FWD
SPRNBRK__345KV_RNS5			(Import)
Tue 12/18/2018	to	Tue 12/18/2018	
0001	Continuous	0030	SPR/DUN-SOUTH <b>3200 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability 1400 MW
			TTC with All Lines In Service 4600 MW
<hr/>			
SPRNBRK_-W49TH_ST_345_M51			FWD
			(Import)
Tue 12/18/2018	to	Wed 12/19/2018	
0001	Continuous	0200	SPR/DUN-SOUTH <b>3200 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability 1400 MW
			TTC with All Lines In Service 4600 MW
<hr/>			
SPRNBRK__345KV_RNS5			FWD
			(Import)
Wed 12/19/2018	to	Wed 12/19/2018	
0130	Continuous	0200	SPR/DUN-SOUTH <b>3200 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability 1400 MW
			TTC with All Lines In Service 4600 MW
<hr/>			
FRASANX-COOPERS__345_UCC2-41			FWD
			(Import)
Sat 12/22/2018	to	Wed 12/26/2018	
0700	Continuous	1730	CENTRAL EAST - VC <b>2500 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability 475 MW
<b>ARR: 19</b>			TTC with All Lines In Service 2975 MW
<hr/>			
MARCY_-FRASANX_345_UCC2-41			FWD
			(Import)
Sat 12/22/2018	to	Wed 12/26/2018	
0700	Continuous	1730	CENTRAL EAST - VC <b>2500 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability 475 MW
<b>ARR: 19</b>			TTC with All Lines In Service 2975 MW
<hr/>			
MOSES_-ADIRNDCK_230_MA1			FWD
			(Import)
Wed 12/26/2018	to	Fri 12/28/2018	
0700	Continuous	1530	<b>CANCELLED by NYPA 11/29/2018</b> MOSES SOUTH <b>2300 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability 850 MW
			TTC with All Lines In Service 3150 MW
<hr/>			
EDIC_-FRASER__345_EF24-40			FWD
			(Import)
Thu 12/27/2018	to	Mon 12/31/2018	
0700	Continuous	1730	CENTRAL EAST - VC <b>2500 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability 475 MW
			TTC with All Lines In Service 2975 MW



# NYISO TRANSFER LIMITATIONS

Tuesday ,December 04, 2018 to Thursday ,June 04, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK\_\_345KV\_RS3 & SPRNBK\_\_345KV\_RS4  
 Tue 01/01/2019 to Wed 01/02/2019  
 0001 0200

Work scheduled by:

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

EFISHKIL-WOOD\_ST\_\_345\_F39  
 Wed 01/02/2019 to Wed 01/02/2019  
 0001 Continuous 0030

Work scheduled by: ConEd

UPDATED by CE 10/04/2018

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

MOSES\_\_-ADIRNDCK\_230\_MA2  
 Wed 01/02/2019 to Fri 01/04/2019  
 0700 Continuous 1730

Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

HURLYAVE-ROSETON\_\_345\_303  
 Wed 01/02/2019 to Fri 01/11/2019  
 0800 Continuous 1600

Work scheduled by: CHGE

08/20/2018

FWD  
 (Import)  
 UPNY CONED **4100 MW**  
 Impacts Total Transfer Capability 1600 MW  
 TTC with All Lines In Service 5700 MW

EFISHKIL-WOOD\_ST\_\_345\_F39  
 Thu 01/03/2019 to Thu 01/03/2019  
 0230 Continuous 0300

Work scheduled by: ConEd

UPDATED by CE 10/04/2018

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

SCH-NE-NYISO\_LIMIT\_1100  
 Mon 01/07/2019 to Thu 01/10/2019  
 0700 Continuous 1600

Work scheduled by: ISONE

FWD  
 (Import)  
 SCH - NE - NY **1300 MW**  
 Impacts Total Transfer Capability 100 MW  
 TTC with All Lines In Service 1400 MW

MOSES\_\_-ADIRNDCK\_230\_MA1  
 Mon 01/07/2019 to Fri 01/11/2019  
 0700 Continuous 1500

Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,December 04, 2018 to Thursday ,June 04, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BECK___-PACKARD__230_BP76</b>				FWD	REV
Wed 01/09/2019	to	Wed 01/09/2019		(Import)	(Export)
0800	Daily(No Weekends)	1500	SCH - OH - NY	<b>1700 MW</b>	<b>1500 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability	50 MW 500 MW
				TTC with All Lines In Service	1750 MW 2000 MW
<b>BECK___-PACKARD__230_BP76 &amp; STLAWRNC-MOSES___230_L33P</b>				FWD	REV
Wed 01/09/2019	to	Wed 01/09/2019		(Import)	(Export)
0800		1500	SCH - OH - NY	<b>900 MW</b>	<b>1150 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	850 MW 850 MW
				TTC with All Lines In Service	1750 MW 2000 MW
<b>SPRNBRK_-TREMONT__345_X28</b>				FWD	
Mon 01/14/2019	to	Mon 01/14/2019		(Import)	
0001	Continuous	0100	SPR/DUN-SOUTH	<b>4200 MW</b>	
Work scheduled by: ConEd				Impacts Total Transfer Capability	400 MW
				TTC with All Lines In Service	4600 MW
<b>MOSES___-ADIRNDCK_230_MA2</b>				FWD	
Mon 01/14/2019	to	Fri 01/18/2019		(Import)	
0700	Continuous	1500	MOSES SOUTH	<b>2300 MW</b>	
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
<b>LEEDS___-HURLYAVE_345_301</b>				FWD	
Mon 01/14/2019	to	Fri 01/25/2019	<b>08/20/2018</b>	(Import)	
0800	Continuous	1600	UPNY CONED	<b>4100 MW</b>	
Work scheduled by: CHGE				Impacts Total Transfer Capability	1600 MW
				TTC with All Lines In Service	5700 MW
<b>SPRNBRK_-TREMONT__345_X28</b>				FWD	
Fri 01/18/2019	to	Fri 01/18/2019		(Import)	
2200	Continuous	2300	SPR/DUN-SOUTH	<b>4200 MW</b>	
Work scheduled by: ConEd				Impacts Total Transfer Capability	400 MW
				TTC with All Lines In Service	4600 MW
<b>DUNWODIE_345KV_6</b>				FWD	
Mon 01/21/2019	to	Mon 01/28/2019	<b>UPDATED by CE 10/04/2018</b>	(Import)	
0001	Continuous	0200	SPR/DUN-SOUTH	<b>3800 MW</b>	
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,December 04, 2018 to Thursday ,June 04, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE\_345KV\_8**

Mon 01/21/2019 to Mon 01/28/2019  
0001 Continuous 0200

**UPDATED by CE 10/04/2018**

Work scheduled by: ConEd

FWD  
(Import)  
**3800 MW**  
SPR/DUN-SOUTH  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**PLSNTVLE-DUNWODIE\_345\_W90**

Mon 01/21/2019 to Mon 01/28/2019  
0001 Continuous 0200

**UPDATED by CE 10/04/2018**

Work scheduled by: ConEd

FWD  
(Import)  
**4000 MW**  
UPNY CONED  
Impacts Total Transfer Capability 1700 MW  
TTC with All Lines In Service 5700 MW

**MOSES\_\_-ADIRNDCK\_230\_MA2**

Mon 01/21/2019 to Fri 01/25/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
**2300 MW**  
MOSES SOUTH  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**MOSES\_\_-ADIRNDCK\_230\_MA1**

Mon 01/28/2019 to Fri 02/01/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
**2300 MW**  
MOSES SOUTH  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**LEEDS\_\_-HURLYAVE\_345\_301**

Mon 01/28/2019 to Fri 02/08/2019  
0800 Continuous 1600

Work scheduled by: CHGE

**11/13/2018**

FWD  
(Import)  
**4100 MW**  
UPNY CONED  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 5700 MW

**PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4**

Tue 01/29/2019 to Sun 02/03/2019  
0001 0300

Work scheduled by:

FWD  
(Import)  
**3800 MW**  
UPNY CONED  
Impacts Total Transfer Capability 1900 MW  
TTC with All Lines In Service 5700 MW

**PLSNTVLY-EFISHRIL\_345\_F36**

Sun 02/03/2019 to Wed 02/06/2019  
0301 Continuous 0300

Work scheduled by: ConEd

**UPDATED by CONED 11/21/2018**

FWD  
(Import)  
**4000 MW**  
UPNY CONED  
Impacts Total Transfer Capability 1700 MW  
TTC with All Lines In Service 5700 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,December 04, 2018 to Thursday ,June 04, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 02/04/2019 to Thu 02/07/2019

(Import)

0700 Continuous 1500

MOSES SOUTH

**2300 MW**

Work scheduled by: NYPA

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

-----  
**PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4**

FWD

Wed 02/06/2019 to Wed 02/06/2019

(Import)

0330 0400

UPNY CONED

**3800 MW**

Work scheduled by:

Impacts Total Transfer Capability 1900 MW

TTC with All Lines In Service 5700 MW

-----  
**EASTVIEW-SPRNBRK\_\_345\_W79**

FWD

Thu 02/07/2019 to Thu 02/07/2019

(Import)

0001 Continuous 0030

UPNY CONED

**4350 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 1350 MW

TTC with All Lines In Service 5700 MW

-----  
**BUCHAN\_N-EASTVIEW\_345\_W93**

FWD

Thu 02/07/2019 to Fri 02/08/2019

(Import)

0001 Continuous 0300

UPNY CONED

**4350 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 1350 MW

TTC with All Lines In Service 5700 MW

-----  
**ADIRNDCK-CHASLAKE\_230\_13**

FWD

Thu 02/07/2019 to Thu 02/07/2019

(Import)

0800 Continuous 1530

MOSES SOUTH

**2300 MW**

Work scheduled by: NYPA

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

-----  
**EASTVIEW-SPRNBRK\_\_345\_W79**

FWD

Fri 02/08/2019 to Fri 02/08/2019

(Import)

0230 Continuous 0300

UPNY CONED

**4350 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 1350 MW

TTC with All Lines In Service 5700 MW

-----  
**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

FWD

Fri 02/08/2019 to Fri 02/08/2019

(Import)

0800 Continuous 1500

MOSES SOUTH

**2300 MW**

Work scheduled by: NYPA

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,December 04, 2018 to Thursday ,June 04, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MOSES -ADIRNDCK_230_MA2</b>				FWD	
Mon 02/11/2019	to	Fri 02/15/2019		(Import)	
0700	Continuous	1500	MOSES SOUTH	<b>2300 MW</b>	
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
<b>MOSES -ADIRNDCK_230_MA2</b>				FWD	
Tue 02/19/2019	to	Fri 02/22/2019		(Import)	
0700	Continuous	1500	MOSES SOUTH	<b>2300 MW</b>	
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
<b>MOSES -ADIRNDCK_230_MA1</b>				FWD	
Mon 02/25/2019	to	Fri 03/01/2019		(Import)	
0700	Continuous	1500	MOSES SOUTH	<b>2300 MW</b>	
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
<b>PLSNTVLY_345KV_RN5 &amp; PLSNTVLY_345KV_RN4</b>				FWD	
Fri 03/01/2019	to	Mon 03/04/2019		(Import)	
0001		0200	UPNY CONED	<b>3800 MW</b>	
Work scheduled by:				Impacts Total Transfer Capability	1900 MW
				TTC with All Lines In Service	5700 MW
<b>LONG_MTN-PLSNTVLY_345_398</b>				FWD	REV
Fri 03/01/2019	to	Sun 05/19/2019	<b>UPDATED by CONED 11/28/2018</b>	(Import)	(Export)
0001	Continuous	2359	SCH - NE - NY	<b>700 MW</b>	<b>1300 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	700 MW 500 MW
				TTC with All Lines In Service	1400 MW 1800 MW
<b>LONG_MTN-PLSNTVLY_345_398</b>				FWD	REV
Fri 03/01/2019	to	Sun 05/19/2019	<b>UPDATED by CONED 11/28/2018</b>	(Import)	(Export)
0001	Continuous	2359	SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	100 MW 100 MW
				TTC with All Lines In Service	200 MW 200 MW
<b>EASTVIEW-SPRNBK_345_W64</b>				FWD	
Mon 03/04/2019	to	Mon 03/04/2019		(Import)	
0001	Continuous	0030	UPNY CONED	<b>4350 MW</b>	
Work scheduled by: ConEd				Impacts Total Transfer Capability	1350 MW
				TTC with All Lines In Service	5700 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,December 04, 2018 to Thursday ,June 04, 2020

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MILLWOOD-EASTVIEW_345_W99</b>				FWD
Mon 03/04/2019	to	Thu 03/07/2019		(Import)
0001	Continuous	2359	UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 1350 MW
				TTC with All Lines In Service 5700 MW
<b>PLSNTVLY-EFISHKIL_345_F37</b>				FWD
Mon 03/04/2019	to	Wed 03/06/2019	<b>UPDATED by CONED 11/28/2018</b>	(Import)
0201	Continuous	0300	UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 1700 MW
				TTC with All Lines In Service 5700 MW
<b>MOSES__-ADIRNDCK_230_MA1</b>				FWD
Mon 03/04/2019	to	Fri 03/08/2019		(Import)
0700	Continuous	1500	MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW
<b>EASTVIEW-SPRNBK__345_W64</b>				FWD
Thu 03/07/2019	to	Thu 03/07/2019		(Import)
2330	Continuous	2359	UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 1350 MW
				TTC with All Lines In Service 5700 MW
<b>STLAWRNC-MOSES__230_L33P &amp; STLAWRNC-MOSES__230_L34P</b>				FWD
Mon 03/11/2019	to	Mon 03/11/2019		(Import)
0700		1530	MOSES SOUTH	<b>2700 MW</b>
Work scheduled by:				Impacts Total Transfer Capability 450 MW
				TTC with All Lines In Service 3150 MW
<b>STLAWRNC-MOSES__230_L34P</b>				FWD      REV
Mon 03/11/2019	to	Mon 03/11/2019		(Import) (Export)
0700	Continuous	1530	SCH - OH - NY	<b>1750 MW 1900 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability 0 MW 100 MW
				TTC with All Lines In Service 1750 MW 2000 MW
<b>LEEDS__345_LEEDS SVC</b>				FWD
Mon 03/11/2019	to	Fri 03/22/2019		(Import)
0800	Continuous	1600	CENTRAL EAST - VC	<b>2950 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability 25 MW
				TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,December 04, 2018 to Thursday ,June 04, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES\_\_\_-ADIRNDCK\_230\_MA1

Tue 03/12/2019 to Fri 03/15/2019  
 0700 Continuous 1500  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

MARCY\_\_\_765\_345\_AT1

Mon 03/18/2019 to Fri 03/22/2019  
 0500 Continuous 1530  
 Work scheduled by: NYPA

ARR: 19

FWD  
 (Import)  
 MOSES SOUTH **1750 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 3150 MW

MARCY\_\_\_345KV\_CSC

Mon 04/01/2019 to Sun 04/07/2019  
 0500 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2925 MW**  
 Impacts Total Transfer Capability 50 MW  
 TTC with All Lines In Service 2975 MW

VOLNEY\_-MARCY\_\_\_345\_19

Mon 04/01/2019 to Wed 04/10/2019  
 0500 Continuous 1730  
 Work scheduled by: NYPA

ARR: 19

FWD  
 (Import)  
 CENTRAL EAST - VC **2825 MW**  
 Impacts Total Transfer Capability 150 MW  
 TTC with All Lines In Service 2975 MW

VOLNEY\_-MARCY\_\_\_345\_19

Mon 04/01/2019 to Wed 04/10/2019  
 0500 Continuous 1730  
 Work scheduled by: NYPA

ARR: 19

FWD  
 (Import)  
 OSWEGO EXPORT **4900 MW**  
 Impacts Total Transfer Capability 350 MW  
 TTC with All Lines In Service 5250 MW

PLSNTVLY-EFISHKIL\_345\_F37

Thu 04/04/2019 to Mon 04/08/2019  
 0001 Continuous 0200  
 Work scheduled by: ConEd

UPDATED by CONED 11/28/2018

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

DUNWODIE-MOTTHAVN\_345\_71

Fri 04/05/2019 to Thu 05/09/2019  
 0001 Continuous 2359  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,December 04, 2018 to Thursday ,June 04, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NIAGARA\_-ROCHESTR\_345\_NR2**

Fri 04/05/2019 to Fri 04/05/2019  
0500 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

**LINDN\_CG-LNDVFT\_\_\_345\_V-3022**

Sun 04/07/2019 to Fri 04/12/2019  
1400 Continuous 1800

Work scheduled by: PJM

FWD REV  
(Import) (Export)  
SCH - PJM\_VFT **0 MW 0 MW**  
Impacts Total Transfer Capability 315 MW 315 MW  
TTC with All Lines In Service 315 MW 315 MW

**PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4**

Mon 04/08/2019 to Sat 04/13/2019  
0001 0300

Work scheduled by:

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1900 MW  
TTC with All Lines In Service 5700 MW

**PLSNTVLE-DUNWODIE\_345\_W89**

Mon 04/08/2019 to Fri 05/10/2019  
0001 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1700 MW  
TTC with All Lines In Service 5700 MW

**MARCY\_\_\_345KV\_CSC**

Thu 04/11/2019 to Wed 04/17/2019  
0500 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2925 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

**MARCY\_-EDIC\_\_\_345\_UE1-7**

Thu 04/11/2019 to Sat 04/20/2019  
0500 Continuous 1730

Work scheduled by: NYPA

**ARR: 19&16**

FWD  
(Import)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

**GILBOA\_-N.SCTLND\_345\_GNS-1**

Fri 04/12/2019 to Fri 04/12/2019  
1330 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2520 MW**  
Impacts Total Transfer Capability 455 MW  
TTC with All Lines In Service 2975 MW



# NYISO TRANSFER LIMITATIONS

Tuesday ,December 04, 2018 to Thursday ,June 04, 2020

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p><b>EDIC</b> ___ -<b>FRASER</b> ___ <b>345_EF24-40</b></p> <p>Mon 04/22/2019 to Fri 04/26/2019</p> <p style="padding-left: 40px;">0500 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC <b>2500 MW</b></p> <p>Impacts Total Transfer Capability 475 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p><b>MARCY</b> ___ <b>765_345_AT2</b></p> <p>Mon 04/22/2019 to Fri 04/26/2019</p> <p style="padding-left: 40px;">0500 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH <b>1700 MW</b></p> <p>Impacts Total Transfer Capability 1450 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p><b>FRASANX-COOPERS</b> ___ <b>345_UCC2-41</b></p> <p>Mon 04/29/2019 to Fri 05/03/2019</p> <p style="padding-left: 40px;">0500 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC <b>2500 MW</b></p> <p>Impacts Total Transfer Capability 475 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p><b>MARCY</b> ___ -<b>FRASANX</b> ___ <b>345_UCC2-41</b></p> <p>Mon 04/29/2019 to Fri 05/03/2019</p> <p style="padding-left: 40px;">0500 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC <b>2500 MW</b></p> <p>Impacts Total Transfer Capability 475 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p><b>MOSES</b> ___ -<b>ADIRNDCK</b> ___ <b>230_MA1</b></p> <p>Mon 04/29/2019 to Fri 05/03/2019</p> <p style="padding-left: 40px;">0700 Continuous 1500</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH <b>2300 MW</b></p> <p>Impacts Total Transfer Capability 850 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p><b>HUDSONTP-W49TH_ST</b> ___ <b>345_Y56</b></p> <p>Wed 05/01/2019 to Tue 05/07/2019</p> <p style="padding-left: 40px;">0600 Continuous 1800</p> <p>Work scheduled by: PJM</p>	<p style="text-align: right;">FWD (Import)</p> <p>SCH - PJM_HTP <b>0 MW</b></p> <p>Impacts Total Transfer Capability 660 MW</p> <p>TTC with All Lines In Service 660 MW</p>
<p><b>KINTIGH</b> ___ -<b>ROCHESTR</b> ___ <b>345_SR1-39</b></p> <p>Mon 05/06/2019 to Fri 05/10/2019</p> <p style="padding-left: 40px;">0600 Continuous 1700</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>DYSINGER EAST <b>1400 MW</b></p> <p>Impacts Total Transfer Capability 1750 MW</p> <p>TTC with All Lines In Service 3150 MW</p>

# NYISO TRANSFER LIMITATIONS

Tuesday ,December 04, 2018 to Thursday ,June 04, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROSETON\_-ROCKTVRN\_345\_311

FWD

Mon 05/06/2019 to Sat 06/01/2019

(Import)

0800 Continuous 1600

UPNY CONED **4400 MW**

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5700 MW

Work scheduled by: CHGE

NIAGARA\_-ROCHESTR\_345\_NR2

FWD

Mon 05/13/2019 to Fri 05/17/2019

(Import)

0600 Continuous 1700

DYSINGER EAST **1400 MW**

Impacts Total Transfer Capability 1750 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

ADIRNDCK-PORTER\_230\_12

FWD

Mon 05/20/2019 to Fri 05/24/2019

(Import)

0700 Continuous 1530

MOSES SOUTH **2100 MW**

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

PANNELL\_-CLAY\_345\_1

FWD

Mon 05/20/2019 to Fri 05/24/2019

(Import)

0700 Continuous 1530

WEST CENTRAL **1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

Work scheduled by: NYPA

PANNELL\_-CLAY\_345\_2

FWD

Mon 06/03/2019 to Fri 06/07/2019

(Import)

0700 Continuous 1530

WEST CENTRAL **1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

Work scheduled by: NYPA

MOSES\_-ADIRNDCK\_230\_MA2

FWD

Mon 06/24/2019 to Fri 06/28/2019

(Import)

0700 Continuous 1500

MOSES SOUTH **2100 MW**

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

MOSES\_-ADIRNDCK\_230\_MA2

FWD

Mon 07/08/2019 to Fri 07/12/2019

(Import)

0700 Continuous 1500

MOSES SOUTH **2100 MW**

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

# NYISO TRANSFER LIMITATIONS

Tuesday ,December 04, 2018 to Thursday ,June 04, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ADIRNDCK-CHASLAKE\_230\_13

Mon 07/08/2019 to Fri 07/12/2019  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

MARCY\_765\_345\_AT2

Sat 08/03/2019 to Sun 08/04/2019  
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

MOSES-ADIRNDCK\_230\_MA1

Mon 08/12/2019 to Mon 08/12/2019  
0700 Continuous 1459

Work scheduled by: NYPA

UPDATED by NYPA 10/10/2018

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

MARCY\_765\_345\_AT1

Tue 09/03/2019 to Tue 09/03/2019  
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
MOSES SOUTH **1750 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 3150 MW

MARCY-N.SCTLND\_345\_18

Wed 09/04/2019 to Wed 09/04/2019  
0500 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 11/06/2018

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **2090 MW**  
Impacts Total Transfer Capability 885 MW  
TTC with All Lines In Service 2975 MW

MARCY\_345KV\_CSC

Wed 09/04/2019 to Wed 09/04/2019  
0500 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 11/06/2018

FWD  
(Import)  
CENTRAL EAST - VC **2925 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

MOSES-ADIRNDCK\_230\_MA2

Wed 09/04/2019 to Wed 09/04/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,December 04, 2018 to Thursday ,June 04, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ADIRNDCK-PORTER\_\_\_230\_12

Wed 09/04/2019 to Wed 09/04/2019  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

ADIRNDCK-CHASLAKE\_230\_13

Thu 09/05/2019 to Thu 09/05/2019  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

NIAGARA\_-ROCHESTR\_345\_NR2

Mon 09/09/2019 to Sat 09/21/2019  
0500 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

LEEDS\_\_\_345KV\_R395

Mon 09/09/2019 to Mon 09/09/2019  
0700 Continuous 0730

Work scheduled by: NYPA

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1900 MW  
TTC with All Lines In Service 5700 MW

GILBOA\_-LEEDS\_\_\_345\_GL3

Mon 09/09/2019 to Fri 09/27/2019  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2200 MW**  
Impacts Total Transfer Capability 775 MW  
TTC with All Lines In Service 2975 MW

MARCY\_\_\_-N.SCTLND\_345\_18

Wed 09/11/2019 to Fri 09/13/2019  
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **2090 MW**  
Impacts Total Transfer Capability 885 MW  
TTC with All Lines In Service 2975 MW

MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 09/16/2019 to Fri 09/20/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,December 04, 2018 to Thursday ,June 04, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**GOETHALS\_345KV\_5**

Fri 09/20/2019 to Tue 09/24/2019  
 0001 Continuous 2359  
 Work scheduled by: ConEd

STATEN ISLAND  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

-----  
**ROCHESTR-PANNELL\_345\_RP2**

Mon 09/23/2019 to Mon 09/30/2019  
 0500 Continuous 1700  
 Work scheduled by: NYPA

FWD  
 (Import)  
 DYSINGER EAST **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

-----  
**KINTIGH\_-ROCHESTR\_345\_SRL-39**

Mon 09/23/2019 to Fri 09/27/2019  
 0600 Continuous 1700  
 Work scheduled by: NYPA

FWD  
 (Import)  
 DYSINGER EAST **1400 MW**  
 Impacts Total Transfer Capability 1750 MW  
 TTC with All Lines In Service 3150 MW

-----  
**SPRNBRK\_345KV\_RNS5**

Wed 09/25/2019 to Wed 09/25/2019  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

-----  
**SPRNBRK\_-W49TH\_ST\_345\_M51**

Wed 09/25/2019 to Sat 11/02/2019  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

-----  
**LEEDS\_345KV\_R395**

Fri 09/27/2019 to Fri 09/27/2019  
 1700 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 1900 MW  
 TTC with All Lines In Service 5700 MW

-----  
**CLAY\_-EDIC\_345\_1-16**

Mon 09/30/2019 to Fri 10/04/2019  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 OSWEGO EXPORT **4850 MW**  
 Impacts Total Transfer Capability 400 MW  
 TTC with All Lines In Service 5250 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,December 04, 2018 to Thursday ,June 04, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>LEEDS -HURLYAVE_345_301</b>		FWD	
Mon 09/30/2019	to Sat 10/26/2019	(Import)	
0800	Continuous 1600	UPNY CONED	<b>4100 MW</b>
Work scheduled by: CHGE		Impacts Total Transfer Capability	1600 MW
		TTC with All Lines In Service	5700 MW
<b>CLAY -EDIC_345_2-15</b>		FWD	
Mon 10/07/2019	to Thu 10/17/2019	(Import)	
0700	Continuous 1530	OSWEGO EXPORT	<b>4850 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability	400 MW
		TTC with All Lines In Service	5250 MW
<b>MARCY -N.SCTLND_345_18</b>		FWD	
Wed 10/09/2019	to Fri 10/11/2019	(Import)	
0500	Continuous 1730	CENTRAL EAST - VC	<b>2090 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability	885 MW
<b>ARR: 19</b>		TTC with All Lines In Service	2975 MW
<b>CHATGUAY-MASSENA_765_7040</b>		FWD	
Sat 10/12/2019	to Sat 10/26/2019	(Import)	
0100	Continuous 1900	MOSES SOUTH	<b>1550 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability	1600 MW
		TTC with All Lines In Service	3150 MW
<b>CHATGUAY-MASSENA_765_7040</b>		FWD	REV
Sat 10/12/2019	to Sat 10/26/2019	(Import)	(Export)
0100	Continuous 1900	SCH - HQ - NY	<b>0 MW 0 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability	1500 MW 1000 MW
		TTC with All Lines In Service	1500 MW 1000 MW
<b>MARCY_765_345_AT1</b>		FWD	
Sat 10/12/2019	to Sat 10/26/2019	(Import)	
0100	Continuous 1900	MOSES SOUTH	<b>1750 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability	1400 MW
<b>ARR: 19</b>		TTC with All Lines In Service	3150 MW
<b>MARCY_765_345_AT2</b>		FWD	
Sat 10/12/2019	to Sat 10/26/2019	(Import)	
0100	Continuous 1900	MOSES SOUTH	<b>1700 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability	1450 MW
<b>ARR: 19</b>		TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,December 04, 2018 to Thursday ,June 04, 2020

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p><b>MASSENA -MARCY 765_MSU1</b></p> <p>Sat 10/12/2019 to Sat 10/26/2019 0100 Continuous 1900</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC <b>2265 MW</b></p> <p>Impacts Total Transfer Capability 710 MW</p> <p>TTC with All Lines In Service 2975 MW</p>															
<p><b>MASSENA -MARCY 765_MSU1</b></p> <p>Sat 10/12/2019 to Sat 10/26/2019 0100 Continuous 1900</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH <b>500 MW</b></p> <p>Impacts Total Transfer Capability 2650 MW</p> <p>TTC with All Lines In Service 3150 MW</p>															
<p><b>MASSENA -MARCY 765_MSU1</b></p> <p>Sat 10/12/2019 to Sat 10/26/2019 0100 Continuous 1900</p> <p>Work scheduled by: NYPA</p>	<table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 60%;"></td> <td style="width: 20%; text-align: right;">FWD</td> <td style="width: 20%; text-align: right;">REV</td> </tr> <tr> <td></td> <td style="text-align: right;">(Import)</td> <td style="text-align: right;">(Export)</td> </tr> <tr> <td>SCH - HQ - NY</td> <td style="text-align: right;"><b>475 MW</b></td> <td style="text-align: right;"><b>1000 MW</b></td> </tr> <tr> <td>Impacts Total Transfer Capability</td> <td style="text-align: right;">1025 MW</td> <td style="text-align: right;">0 MW</td> </tr> <tr> <td>TTC with All Lines In Service</td> <td style="text-align: right;">1500 MW</td> <td style="text-align: right;">1000 MW</td> </tr> </table>		FWD	REV		(Import)	(Export)	SCH - HQ - NY	<b>475 MW</b>	<b>1000 MW</b>	Impacts Total Transfer Capability	1025 MW	0 MW	TTC with All Lines In Service	1500 MW	1000 MW
	FWD	REV														
	(Import)	(Export)														
SCH - HQ - NY	<b>475 MW</b>	<b>1000 MW</b>														
Impacts Total Transfer Capability	1025 MW	0 MW														
TTC with All Lines In Service	1500 MW	1000 MW														
<p><b>MASSENA -MARCY 765_MSU1 &amp; CHATGUAY-MASSENA 765_7040</b></p> <p>Sat 10/12/2019 to Sat 10/26/2019 0100 1900</p> <p>Work scheduled by:</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH <b>500 MW</b></p> <p>Impacts Total Transfer Capability 2650 MW</p> <p>TTC with All Lines In Service 3150 MW</p>															
<p><b>MOSES -MASSENA 230_MMS1 &amp; MOSES -MASSENA 230_MMS2</b></p> <p>Sat 10/12/2019 to Sat 10/26/2019 0100 1900</p> <p>Work scheduled by:</p>	<table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 60%;"></td> <td style="width: 20%; text-align: right;">FWD</td> <td style="width: 20%; text-align: right;">REV</td> </tr> <tr> <td></td> <td style="text-align: right;">(Import)</td> <td style="text-align: right;">(Export)</td> </tr> <tr> <td>SCH - HQ - NY</td> <td style="text-align: right;"><b>850 MW</b></td> <td style="text-align: right;"><b>0 MW</b></td> </tr> <tr> <td>Impacts Total Transfer Capability</td> <td style="text-align: right;">650 MW</td> <td style="text-align: right;">1000 MW</td> </tr> <tr> <td>TTC with All Lines In Service</td> <td style="text-align: right;">1500 MW</td> <td style="text-align: right;">1000 MW</td> </tr> </table>		FWD	REV		(Import)	(Export)	SCH - HQ - NY	<b>850 MW</b>	<b>0 MW</b>	Impacts Total Transfer Capability	650 MW	1000 MW	TTC with All Lines In Service	1500 MW	1000 MW
	FWD	REV														
	(Import)	(Export)														
SCH - HQ - NY	<b>850 MW</b>	<b>0 MW</b>														
Impacts Total Transfer Capability	650 MW	1000 MW														
TTC with All Lines In Service	1500 MW	1000 MW														
<p><b>NIAGARA 345_230_AT4</b></p> <p>Wed 10/23/2019 to Wed 12/18/2019 0500 Continuous 1700</p> <p>Work scheduled by: NYPA</p>	<table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 60%;"></td> <td style="width: 20%; text-align: right;">FWD</td> <td style="width: 20%; text-align: right;">REV</td> </tr> <tr> <td></td> <td style="text-align: right;">(Import)</td> <td style="text-align: right;">(Export)</td> </tr> <tr> <td>SCH - OH - NY</td> <td style="text-align: right;"><b>1900 MW</b></td> <td style="text-align: right;"><b>1400 MW</b></td> </tr> <tr> <td>Impacts Total Transfer Capability</td> <td style="text-align: right;">0 MW</td> <td style="text-align: right;">350 MW</td> </tr> <tr> <td>TTC with All Lines In Service</td> <td style="text-align: right;">1900 MW</td> <td style="text-align: right;">1750 MW</td> </tr> </table>		FWD	REV		(Import)	(Export)	SCH - OH - NY	<b>1900 MW</b>	<b>1400 MW</b>	Impacts Total Transfer Capability	0 MW	350 MW	TTC with All Lines In Service	1900 MW	1750 MW
	FWD	REV														
	(Import)	(Export)														
SCH - OH - NY	<b>1900 MW</b>	<b>1400 MW</b>														
Impacts Total Transfer Capability	0 MW	350 MW														
TTC with All Lines In Service	1900 MW	1750 MW														
<p><b>SPRNBRK 345KV_RNS5</b></p> <p>Sat 11/02/2019 to Sat 11/02/2019 0130 Continuous 0200</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>SPR/DUN-SOUTH <b>3200 MW</b></p> <p>Impacts Total Transfer Capability 1400 MW</p> <p>TTC with All Lines In Service 4600 MW</p>															

# NYISO TRANSFER LIMITATIONS

Tuesday ,December 04, 2018 to Thursday ,June 04, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HURLYAVE-ROSETON\_\_345\_303

Mon 11/04/2019 to Fri 12/06/2019  
0800 Continuous 1600

Work scheduled by: CHGE

FWD

(Import)

UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 5700 MW

PANNELL\_-CLAY\_\_\_\_345\_2

Wed 11/06/2019 to Fri 11/22/2019  
0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

MARCY\_\_\_-N.SCTLND\_345\_18

Thu 11/07/2019 to Fri 11/08/2019  
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

CENTRAL EAST - VC **2090 MW**  
Impacts Total Transfer Capability 885 MW  
TTC with All Lines In Service 2975 MW

MARCY\_\_\_345KV\_CSC

Thu 11/07/2019 to Fri 11/08/2019  
0500 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC **2925 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

MOSES\_\_\_-ADIRNDCK\_230\_MA2

Tue 11/12/2019 to Fri 11/15/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 11/18/2019 to Fri 11/22/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 11/25/2019 to Wed 11/27/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW



# NYISO TRANSFER LIMITATIONS

Tuesday ,December 04, 2018 to Thursday ,June 04, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 12/02/2019 to Fri 12/06/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

MOSES\_\_\_-ADIRNDCK\_230\_MA1

Mon 12/09/2019 to Fri 12/13/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 12/16/2019 to Mon 12/16/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

MOSES\_\_\_-ADIRNDCK\_230\_MA1

Tue 12/17/2019 to Fri 12/20/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

LADENTWN-BUCHAN\_S\_345\_Y88

Wed 01/15/2020 to Thu 02/13/2020  
0001 Continuous 2359

Work scheduled by: ORU

11/05/2018

FWD  
(Import)  
UPNY CONED **4800 MW**  
Impacts Total Transfer Capability 900 MW  
TTC with All Lines In Service 5700 MW

FRASANX-COOPERS\_345\_UCC2-41

Mon 04/27/2020 to Sun 05/31/2020  
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

MARCY\_\_\_-FRASANX\_345\_UCC2-41

Mon 04/27/2020 to Sun 05/31/2020  
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW