

NYISO TRANSFER LIMITATIONS

Friday ,December 07, 2018 to Sunday ,June 07, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
HUDSONP_-FARRAGUT_345_B3402						
Mon 01/15/2018	to	Mon 04/01/2019	<u>EXT FORCE</u>	<u>by CONED</u>	<u>12/02/2018</u>	
0001	Continuous	2359				
Work scheduled by: ConEd					SCH - PJ - NY	2600 MW
					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	2600 MW
HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403						
Mon 01/15/2018	to	Mon 04/01/2019				
0001		2359				
Work scheduled by:					SCH - PJ - NY	2000 MW
					Impacts Total Transfer Capability	600 MW
					TTC with All Lines In Service	2600 MW
MARION_-FARRAGUT_345_C3403						
Mon 01/15/2018	to	Mon 04/01/2019	<u>EXT FORCE</u>	<u>by CONED</u>	<u>12/02/2018</u>	
0001	Continuous	2359				
Work scheduled by: ConEd					SCH - PJ - NY	2600 MW
					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	2600 MW
STLAWRNC-MOSES____230_L33P						
Mon 04/30/2018	to	Fri 12/31/2021	<u>EXT FORCE</u>	<u>by IESO</u>	<u>08/21/2018</u>	
0456	Continuous	2359				
Work scheduled by: IESO					SCH - OH - NY	1750 MW
					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	1750 MW
DUNWODIE_345KV_6						
Mon 10/22/2018	to	Sat 12/22/2018	<u>UPDATED</u>	<u>by CE</u>	<u>10/04/2018</u>	
0301	Continuous	0200				
Work scheduled by: ConEd					SPR/DUN-SOUTH	3800 MW
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_8						
Mon 10/22/2018	to	Sat 12/22/2018	<u>UPDATED</u>	<u>by CE</u>	<u>10/04/2018</u>	
0301	Continuous	0200				
Work scheduled by: ConEd					SPR/DUN-SOUTH	3800 MW
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
PLSNTVLE-DUNWODIE_345_W90						
Mon 10/22/2018	to	Sat 12/22/2018	<u>UPDATED</u>	<u>by CE</u>	<u>10/04/2018</u>	
0301	Continuous	0200				
Work scheduled by: ConEd					UPNY CONED	4000 MW
					Impacts Total Transfer Capability	1700 MW
					TTC with All Lines In Service	5700 MW

NYISO TRANSFER LIMITATIONS

Friday ,December 07, 2018 to Sunday ,June 07, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						FWD	REV
S.RIPLEY-DUNKIRK__230_68						(Import)	(Export)
Mon 10/22/2018	to	Fri 12/14/2018	<u>UPDATED</u>	<u>by PJM</u>	<u>11/20/2018</u>	2600 MW	1300 MW
0800	Continuous	2000				Impacts Total Transfer Capability	0 MW 250 MW
Work scheduled by: PJM						TTC with All Lines In Service	2600 MW 1550 MW
<hr/>						FWD	
SCH-IMO-NYISO_LIMIT_1400						(Import)	
Thu 11/01/2018	to	Fri 12/07/2018				1700 MW	
0001	Continuous	2359				Impacts Total Transfer Capability	50 MW
Work scheduled by: IESO						TTC with All Lines In Service	1750 MW
<hr/>							REV
SCH-NYISO-IMO_LIMIT_1600							(Export)
Thu 11/01/2018	to	Fri 12/07/2018				1900 MW	
0001	Continuous	2359				Impacts Total Transfer Capability	100 MW
Work scheduled by: IESO						TTC with All Lines In Service	2000 MW
<hr/>						FWD	
SCH-IMO-NYISO_LIMIT_1300						(Import)	
Thu 11/15/2018	to	Thu 12/20/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>11/20/2018</u>	1600 MW	
0500	Continuous	2359				Impacts Total Transfer Capability	150 MW
Work scheduled by: NYPA						TTC with All Lines In Service	1750 MW
<hr/>						FWD	REV
LONG_MTN-PLSNTVLY_345_398						(Import)	(Export)
Mon 11/26/2018	to	Tue 12/04/2018	<u>UPDATED</u>	<u>by CONED</u>	<u>11/21/2018</u>	700 MW	1300 MW
0001	Continuous	0030				Impacts Total Transfer Capability	700 MW 500 MW
Work scheduled by: ConEd						TTC with All Lines In Service	1400 MW 1800 MW
<hr/>						FWD	REV
LONG_MTN-PLSNTVLY_345_398						(Import)	(Export)
Mon 11/26/2018	to	Tue 12/04/2018	<u>UPDATED</u>	<u>by CONED</u>	<u>11/21/2018</u>	100 MW	100 MW
0001	Continuous	0030				Impacts Total Transfer Capability	100 MW 100 MW
Work scheduled by: ConEd						TTC with All Lines In Service	200 MW 200 MW
<hr/>							REV
SCH-NYISO-NE_LIMIT_700							(Export)
Mon 11/26/2018	to	Tue 12/04/2018	<u>UPDATED</u>	<u>by CONED</u>	<u>11/21/2018</u>	900 MW	
0001	Continuous	0030				Impacts Total Transfer Capability	900 MW
Work scheduled by: ConEd						TTC with All Lines In Service	1800 MW

NYISO TRANSFER LIMITATIONS

Friday ,December 07, 2018 to Sunday ,June 07, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SHOR_NPX-SHOREHAM_138_CSC					FWD	REV
Mon 11/26/2018	to	Fri 12/07/2018			(Import)	(Export)
0700	Continuous	1600		SCH - NPX_CSC	0 MW	0 MW
Work scheduled by: LI					Impacts Total Transfer Capability	330 MW
					TTC with All Lines In Service	330 MW
HURLYAVE-ROSETON_345_303					FWD	
Mon 11/26/2018	to	Fri 12/21/2018			(Import)	
0800	Continuous	1600		UPNY CONED	4100 MW	
Work scheduled by: CHGE					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	5700 MW
HOMR_NYW-PIERC_NY_345_48					FWD	REV
Wed 11/28/2018	to	Wed 12/05/2018	<u>EXT FORCE</u>	<u>by PJM</u>	<u>11/30/2018</u>	(Import) (Export)
1305	Continuous	1600				
Work scheduled by: PJM					SCH - PJ - NY	2500 MW
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	2600 MW
SCH-NYISO-HQ_LIMIT_800						REV
Thu 11/29/2018	to	Mon 12/10/2018				(Export)
2001	Continuous	1800		SCH - HQ - NY		800 MW
Work scheduled by: HQ					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	1000 MW
SCH-IMO-NYISO_LIMIT_700					FWD	
Sat 12/01/2018	to	Sun 12/02/2018	<u>UPDATED</u>	<u>by NYISO</u>	<u>11/29/2018</u>	(Import)
0500	Continuous	2300				
Work scheduled by: NYISO					SCH - OH - NY	1000 MW
					Impacts Total Transfer Capability	750 MW
					TTC with All Lines In Service	1750 MW
DUNWODIE-MOTTHAVN_345_72					FWD	
Sun 12/02/2018	to	Fri 12/07/2018	<u>EXTENDED</u>	<u>by CONED</u>	<u>12/05/2018</u>	(Import)
0001	Continuous	0159				
Work scheduled by: ConEd					SPR/DUN-SOUTH	3800 MW
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_7					FWD	
Sun 12/02/2018	to	Fri 12/07/2018	<u>EXTENDED</u>	<u>by CONED</u>	<u>12/05/2018</u>	(Import)
0001	Continuous	0159				
Work scheduled by: ConEd					SPR/DUN-SOUTH	3800 MW
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Friday ,December 07, 2018 to Sunday ,June 07, 2020

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

OSWEGO_COMPLEX_AVR_O/S

Sun 12/02/2018 to Sun 12/02/2018
0900 Continuous 0930

Work scheduled by: Gen

FWD
(Import)
CENTRAL EAST - VC **2870 MW**
Impacts Total Transfer Capability 105 MW
TTC with All Lines In Service 2975 MW

BECK -NIAGARA 345_PA302

Mon 12/03/2018 to Wed 12/05/2018
0500 Continuous 1900

Work scheduled by: NYPA

FWD REV
(Import) (Export)
SCH - OH - NY **1100 MW 950 MW**
Impacts Total Transfer Capability 650 MW 1050 MW
TTC with All Lines In Service 1750 MW 2000 MW

MOSES -ADIRNDCK_230_MA2

Mon 12/03/2018 to Fri 12/07/2018
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

DUNWODIE-SHORE_RD_345_Y50

Fri 12/07/2018 to Thu 12/13/2018 **UPDATED by CONED 12/05/2018**
0201 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
CONED - LIPA **800 MW**
Impacts Total Transfer Capability 700 MW
TTC with All Lines In Service 1500 MW

DUNWODIE_345KV_4

Fri 12/07/2018 to Thu 12/13/2018 **UPDATED by CONED 12/05/2018**
0201 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

SHORE_RD_345_138_BK 1

Fri 12/07/2018 to Thu 12/13/2018 **UPDATED by CONED 12/05/2018**
0201 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
CONED - LIPA **1350 MW**
Impacts Total Transfer Capability 150 MW
TTC with All Lines In Service 1500 MW

SHORE_RD_345_138_BK 2

Fri 12/07/2018 to Thu 12/13/2018 **UPDATED by CONED 12/05/2018**
0201 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
CONED - LIPA **1350 MW**
Impacts Total Transfer Capability 150 MW
TTC with All Lines In Service 1500 MW

NYISO TRANSFER LIMITATIONS

Friday ,December 07, 2018 to Sunday ,June 07, 2020

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						
NRTH1385-NOR HBR__138_602					FWD	REV
Sat 12/08/2018 to Sat 12/08/2018					(Import) (Export)	
0700	Continuous	1100		SCH - NPX_1385	100 MW	100 MW
Work scheduled by: LI					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
<hr/>						
CHATGUAY-MASSENA__765_7040					FWD	
Sat 12/08/2018 to Sat 12/08/2018					(Import)	
0700	Continuous	2300	<u>UPDATED</u>	<u>by NYPA</u>	<u>11/16/2018</u>	MOSES SOUTH
Work scheduled by: HQ					Impacts Total Transfer Capability	1550 MW
					TTC with All Lines In Service	1600 MW
<hr/>						
CHATGUAY-MASSENA__765_7040					FWD	REV
Sat 12/08/2018 to Sat 12/08/2018					(Import) (Export)	
0700	Continuous	2300	<u>UPDATED</u>	<u>by NYPA</u>	<u>11/16/2018</u>	SCH - HQ - NY
Work scheduled by: HQ					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	1500 MW
<hr/>						
BROWNFLS-TAYLORVL_115_4					FWD	REV
Sat 12/08/2018 to Sat 12/08/2018					(Import) (Export)	
0800	Continuous	1600		SCH - HQ_CEDARS	100 MW	100 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	99 MW
					TTC with All Lines In Service	0 MW
						199 MW
						100 MW
<hr/>						
CEDARS__-ROSEMNTB_115_2/22					FWD	REV
Sat 12/08/2018 to Sat 12/08/2018					(Import) (Export)	
0800	Continuous	1600		SCH - HQ_CEDARS	95 MW	100 MW
Work scheduled by: HQ					Impacts Total Transfer Capability	104 MW
					TTC with All Lines In Service	0 MW
						199 MW
						100 MW
<hr/>						
DENNISON-ROSEMNTB_115_2/22					FWD	REV
Sat 12/08/2018 to Sat 12/08/2018					(Import) (Export)	
0800	Continuous	1600		SCH - HQ_CEDARS	95 MW	100 MW
Work scheduled by: HQ					Impacts Total Transfer Capability	104 MW
					TTC with All Lines In Service	0 MW
						199 MW
						100 MW
<hr/>						
SCH-NYISO-HQ_CEDARS_LIMIT_0						REV
Sat 12/08/2018 to Sat 12/08/2018					(Export)	
0800	Continuous	1600		SCH - HQ_CEDARS		0 MW
Work scheduled by: HQ					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	100 MW

NYISO TRANSFER LIMITATIONS

Friday ,December 07, 2018 to Sunday ,June 07, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CLRKSCRN-OAKDALE__345_36

Sun 12/09/2018 to Sun 12/09/2018
 0700 Continuous 1600
 Work scheduled by: NYSEG

FWD
 (Import)
 CENTRAL EAST - VC **2650 MW**
 Impacts Total Transfer Capability 325 MW
 TTC with All Lines In Service 2975 MW

BROWNFLS-TAYLORVL_115_3

Sun 12/09/2018 to Sun 12/09/2018
 0700 Continuous 1700
 Work scheduled by: NGrid

ARR: 38

FWD REV
 (Import) (Export)
 SCH - HQ_CEDARS **100 MW 100 MW**
 Impacts Total Transfer Capability 99 MW 0 MW
 TTC with All Lines In Service 199 MW 100 MW

BROWNFLS-TAYLORVL_115_3 & TAYLORVL-LOWVILLE_115_5 & CLIMAX__TAYLORVL_115_8

Sun 12/09/2018 to Sun 12/09/2018
 0700 1700
 Work scheduled by:

ARR: 38

FWD REV
 (Import) (Export)
 SCH - HQ_CEDARS **120 MW 100 MW**
 Impacts Total Transfer Capability 79 MW 0 MW
 TTC with All Lines In Service 199 MW 100 MW

TAYLORVL-LOWVILLE_115_5

Sun 12/09/2018 to Sun 12/09/2018
 0700 Continuous 1700
 Work scheduled by: NGrid

ARR: 38

FWD REV
 (Import) (Export)
 SCH - HQ_CEDARS **199 MW 100 MW**
 Impacts Total Transfer Capability 0 MW 0 MW
 TTC with All Lines In Service 199 MW 100 MW

SCH-IMO-NYISO_LIMIT_900

Mon 12/10/2018 to Mon 12/10/2018
 0600 Continuous 1800
 Work scheduled by: NGrid

FWD
 (Import)
 SCH - OH - NY **1200 MW**
 Impacts Total Transfer Capability 550 MW
 TTC with All Lines In Service 1750 MW

FIVEMILE-STOLLERD_345_29

Mon 12/10/2018 to Wed 12/12/2018
 0700 Continuous 1555
 Work scheduled by: NGrid

FWD REV
 (Import) (Export)
 SCH - PJ - NY **2600 MW 1300 MW**
 Impacts Total Transfer Capability 0 MW 250 MW
 TTC with All Lines In Service 2600 MW 1550 MW

MOSES__-ADIRNDCK_230_MA2

Mon 12/10/2018 to Fri 12/14/2018
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,December 07, 2018 to Sunday ,June 07, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event ID	Start Date	End Date	Time	Frequency	Work Scheduled by	Update Info	Transfer Capability	Impacts	TTC
SCH-IMO-NYISO_LIMIT_1000	Tue 12/11/2018	Tue 12/11/2018	0800	Daily(No Weekends)	1600		FWD (Import)	SCH - OH - NY	1300 MW
								Impacts Total Transfer Capability	450 MW
								TTC with All Lines In Service	1750 MW
HOMR_NYW-PIERC_NY_345_48	Tue 12/11/2018	Tue 12/11/2018	1200	Continuous	1600		FWD (Import) REV (Export)	SCH - PJ - NY	2500 MW 1300 MW
								Impacts Total Transfer Capability	100 MW 250 MW
								TTC with All Lines In Service	2600 MW 1550 MW
WOOD_ST_-PLSNTVLE_345_Y87	Mon 12/17/2018	Mon 01/28/2019	0001	Continuous	0200	UPDATED by CE 10/04/2018	FWD (Import)	UPNY CONED	4000 MW
								Impacts Total Transfer Capability	1700 MW
								TTC with All Lines In Service	5700 MW
MARCY___345KV_CSC	Mon 12/17/2018	Tue 12/18/2018	0500	Continuous	1730		FWD (Import)	CENTRAL EAST - VC	2925 MW
								Impacts Total Transfer Capability	50 MW
								TTC with All Lines In Service	2975 MW
MARCY___765_345_AT2	Mon 12/17/2018	Fri 12/21/2018	0500	Continuous	1730	UPDATED by NYPA 11/09/2018	FWD (Import)	MOSES SOUTH	1700 MW
								Impacts Total Transfer Capability	1450 MW
						ARR: 19		TTC with All Lines In Service	3150 MW
SCRIBA_-VOLNEY_345_21	Mon 12/17/2018	Wed 12/19/2018	0600	Continuous	1730	UPDATED by NGRID 12/07/2018	FWD (Import)	OSWEGO EXPORT	5250 MW
								Impacts Total Transfer Capability	0 MW
								TTC with All Lines In Service	5250 MW
SCH-IMO-NYISO_LIMIT_850	Mon 12/17/2018	Fri 12/21/2018	0800	Continuous	1600		FWD (Import)	SCH - OH - NY	1150 MW
								Impacts Total Transfer Capability	600 MW
								TTC with All Lines In Service	1750 MW

NYISO TRANSFER LIMITATIONS

Friday ,December 07, 2018 to Sunday ,June 07, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-IMO_LIMIT_900			REV
Mon 12/17/2018	to	Fri 12/21/2018	(Export)
0800	Continuous	1600	SCH - OH - NY 1200 MW
Work scheduled by: IESO			Impacts Total Transfer Capability 800 MW
			TTC with All Lines In Service 2000 MW
SPRNBRK_345KV_RNS5			FWD
Tue 12/18/2018	to	Tue 12/18/2018	(Import)
0001	Continuous	0030	SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 1400 MW
			TTC with All Lines In Service 4600 MW
SPRNBRK_-W49TH_ST_345_M51			FWD
Tue 12/18/2018	to	Wed 12/19/2018	(Import)
0001	Continuous	0200	SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 1400 MW
			TTC with All Lines In Service 4600 MW
STLAWRNC-MOSES_230_L33P & STLAWRNC-MOSES_230_L34P			FWD
Tue 12/18/2018	to	Tue 12/18/2018	(Import)
0800		1600	MOSES SOUTH 2700 MW
Work scheduled by:			Impacts Total Transfer Capability 450 MW
			TTC with All Lines In Service 3150 MW
SCH-IMO-NYISO_LIMIT_700			FWD
Tue 12/18/2018	to	Wed 12/19/2018	(Import)
0800	Daily	1600	SCH - OH - NY 1000 MW
Work scheduled by: IESO			Impacts Total Transfer Capability 750 MW
			TTC with All Lines In Service 1750 MW
SCH-NYISO-IMO_LIMIT_700			REV
Tue 12/18/2018	to	Wed 12/19/2018	(Export)
0800	Daily	1600	SCH - OH - NY 1000 MW
Work scheduled by: IESO			Impacts Total Transfer Capability 1000 MW
			TTC with All Lines In Service 2000 MW
STLAWRNC-MOSES_230_L34P			FWD REV
Tue 12/18/2018	to	Wed 12/19/2018	(Import) (Export)
0800	Daily	1600	SCH - OH - NY 1750 MW 1900 MW
Work scheduled by: IESO			Impacts Total Transfer Capability 0 MW 100 MW
			TTC with All Lines In Service 1750 MW 2000 MW

NYISO TRANSFER LIMITATIONS

Friday ,December 07, 2018 to Sunday ,June 07, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
SPRNBK__345KV_RNS5			FWD
Wed 12/19/2018	to	Wed 12/19/2018	(Import)
0130	Continuous	0200	
Work scheduled by: ConEd			
		SPR/DUN-SOUTH	3200 MW
		Impacts Total Transfer Capability	1400 MW
		TTC with All Lines In Service	4600 MW
<hr/>			
STLAWRNC-MOSES__230_L33P & STLAWRNC-MOSES__230_L34P			FWD
Wed 12/19/2018	to	Wed 12/19/2018	(Import)
0800		1600	
Work scheduled by:			
		MOSES SOUTH	2700 MW
		Impacts Total Transfer Capability	450 MW
		TTC with All Lines In Service	3150 MW
<hr/>			
FRASANNX-COOPERS__345_UCC2-41			FWD
Sat 12/22/2018	to	Wed 12/26/2018	(Import)
0700	Continuous	1730	
Work scheduled by: NYPA			
		ARR: 19	
		CENTRAL EAST - VC	2500 MW
		Impacts Total Transfer Capability	475 MW
		TTC with All Lines In Service	2975 MW
<hr/>			
MARCY__-FRASANNX_345_UCC2-41			FWD
Sat 12/22/2018	to	Wed 12/26/2018	(Import)
0700	Continuous	1730	
Work scheduled by: NYPA			
		ARR: 19	
		CENTRAL EAST - VC	2500 MW
		Impacts Total Transfer Capability	475 MW
		TTC with All Lines In Service	2975 MW
<hr/>			
EDIC__-FRASER__345_EF24-40			FWD
Thu 12/27/2018	to	Mon 12/31/2018	(Import)
0700	Continuous	1730	
Work scheduled by: NYPA			
		CENTRAL EAST - VC	2500 MW
		Impacts Total Transfer Capability	475 MW
		TTC with All Lines In Service	2975 MW
<hr/>			
SPRNBK__345KV_RS3 & SPRNBK__345KV_RS4			FWD
Tue 01/01/2019	to	Wed 01/02/2019	(Import)
0001		0200	
Work scheduled by:			
		SPR/DUN-SOUTH	3800 MW
		Impacts Total Transfer Capability	800 MW
		TTC with All Lines In Service	4600 MW
<hr/>			
EFISHKIL-WOOD_ST__345_F39			FWD
Wed 01/02/2019	to	Wed 01/02/2019	(Import)
0001	Continuous	0030	
Work scheduled by: ConEd			
		UPDATED by CE 10/04/2018	
		UPNY CONED	4000 MW
		Impacts Total Transfer Capability	1700 MW
		TTC with All Lines In Service	5700 MW

NYISO TRANSFER LIMITATIONS

Friday ,December 07, 2018 to Sunday ,June 07, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA2					FWD
Wed 01/02/2019	to	Fri 01/04/2019			(Import)
0700	Continuous	1730		MOSES SOUTH	2300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 850 MW
					TTC with All Lines In Service 3150 MW
HURLYAVE-ROSETON__345_303					FWD
Wed 01/02/2019	to	Fri 01/11/2019	<u>08/20/2018</u>		(Import)
0800	Continuous	1600		UPNY CONED	4100 MW
Work scheduled by: CHGE					Impacts Total Transfer Capability 1600 MW
					TTC with All Lines In Service 5700 MW
EFISHKIL-WOOD_ST__345_F39					FWD
Thu 01/03/2019	to	Thu 01/03/2019	<u>UPDATED</u>	<u>by CE</u>	<u>10/04/2018</u>
0230	Continuous	0300			
Work scheduled by: ConEd					(Import)
					UPNY CONED 4000 MW
					Impacts Total Transfer Capability 1700 MW
					TTC with All Lines In Service 5700 MW
SCH-NE-NYISO_LIMIT_1100					FWD
Mon 01/07/2019	to	Thu 01/10/2019			(Import)
0700	Continuous	1600		SCH - NE - NY	1300 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability 100 MW
					TTC with All Lines In Service 1400 MW
MOSES___-ADIRNDCK_230_MA1					FWD
Mon 01/07/2019	to	Fri 01/11/2019			(Import)
0700	Continuous	1500		MOSES SOUTH	2300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 850 MW
					TTC with All Lines In Service 3150 MW
BECK___-PACKARD_230_BP76					FWD
Tue 01/08/2019	to	Sat 01/12/2019			(Import) (Export)
0700	Continuous	1700		SCH - OH - NY	1700 MW 1500 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 50 MW 500 MW
					TTC with All Lines In Service 1750 MW 2000 MW
BECK___-PACKARD_230_BP76 & STLAWRNC-MOSES___230_L33P					FWD
Tue 01/08/2019	to	Sat 01/12/2019			(Import) (Export)
0700		1700		SCH - OH - NY	900 MW 1150 MW
Work scheduled by:					Impacts Total Transfer Capability 850 MW 850 MW
					TTC with All Lines In Service 1750 MW 2000 MW

NYISO TRANSFER LIMITATIONS

Friday ,December 07, 2018 to Sunday ,June 07, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BECK ___- PACKARD __ 230 _BP76					
Wed 01/09/2019 to Wed 01/09/2019	CANCELLED	by NGrid	12/07/2018		
0800 Daily(No Weekends) 1500				SCH - OH - NY	FWD (Import) REV (Export)
Work scheduled by: NGrid				Impacts Total Transfer Capability	1700 MW 1500 MW
				TTC with All Lines In Service	50 MW 500 MW
					1750 MW 2000 MW
<hr/>					
SPRNBRK _- TREMONT __ 345 _X28					FWD (Import)
Mon 01/14/2019 to Mon 01/14/2019				SPR/DUN-SOUTH	4200 MW
0001 Continuous 0100				Impacts Total Transfer Capability	400 MW
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW
<hr/>					
MOSES ___- ADIRNDCK _230_MA2					FWD (Import)
Mon 01/14/2019 to Fri 01/18/2019				MOSES SOUTH	2300 MW
0700 Continuous 1500				Impacts Total Transfer Capability	850 MW
Work scheduled by: NYPA				TTC with All Lines In Service	3150 MW
<hr/>					
LEEDS ___- HURLYAVE _345_301					FWD (Import)
Mon 01/14/2019 to Fri 01/25/2019			08/20/2018	UPNY CONED	4100 MW
0800 Continuous 1600				Impacts Total Transfer Capability	1600 MW
Work scheduled by: CHGE				TTC with All Lines In Service	5700 MW
<hr/>					
SPRNBRK _- TREMONT __ 345 _X28					FWD (Import)
Fri 01/18/2019 to Fri 01/18/2019				SPR/DUN-SOUTH	4200 MW
2200 Continuous 2300				Impacts Total Transfer Capability	400 MW
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW
<hr/>					
DUNWODIE _345KV_6					FWD (Import)
Mon 01/21/2019 to Mon 01/28/2019	UPDATED	by CE	10/04/2018	SPR/DUN-SOUTH	3800 MW
0001 Continuous 0200				Impacts Total Transfer Capability	800 MW
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW
<hr/>					
DUNWODIE _345KV_8					FWD (Import)
Mon 01/21/2019 to Mon 01/28/2019	UPDATED	by CE	10/04/2018	SPR/DUN-SOUTH	3800 MW
0001 Continuous 0200				Impacts Total Transfer Capability	800 MW
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Friday ,December 07, 2018 to Sunday ,June 07, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLE-DUNWODIE_345_W90

Mon 01/21/2019 to Mon 01/28/2019
0001 Continuous 0200

Work scheduled by: ConEd

UPDATED by CE 10/04/2018

FWD
(Import)
UPNY CONED 4000 MW
Impacts Total Transfer Capability 1700 MW
TTC with All Lines In Service 5700 MW

MOSES-ADIRNDCK_230_MA2

Mon 01/21/2019 to Fri 01/25/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH 2300 MW
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MOSES-ADIRNDCK_230_MA1

Mon 01/28/2019 to Fri 02/01/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH 2300 MW
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

LEEDS-HURLYAVE_345_301

Mon 01/28/2019 to Fri 02/08/2019
0800 Continuous 1600

Work scheduled by: CHGE

11/13/2018

FWD
(Import)
UPNY CONED 4100 MW
Impacts Total Transfer Capability 1600 MW
TTC with All Lines In Service 5700 MW

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4

Tue 01/29/2019 to Sun 02/03/2019
0001 0300

Work scheduled by:

FWD
(Import)
UPNY CONED 3800 MW
Impacts Total Transfer Capability 1900 MW
TTC with All Lines In Service 5700 MW

PLSNTVLY-EFISHKIL_345_F36

Sun 02/03/2019 to Wed 02/06/2019
0301 Continuous 0300

Work scheduled by: ConEd

UPDATED by CONED 11/21/2018

FWD
(Import)
UPNY CONED 4000 MW
Impacts Total Transfer Capability 1700 MW
TTC with All Lines In Service 5700 MW

MOSES-ADIRNDCK_230_MA2

Mon 02/04/2019 to Thu 02/07/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH 2300 MW
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,December 07, 2018 to Sunday ,June 07, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4

FWD

Wed 02/06/2019 to Wed 02/06/2019
0330 0400

(Import)

UPNY CONED **3800 MW**
Impacts Total Transfer Capability 1900 MW
TTC with All Lines In Service 5700 MW

Work scheduled by:

EASTVIEW-SPRNBK__345_W79

FWD

Thu 02/07/2019 to Thu 02/07/2019
0001 Continuous 0030

(Import)

UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1350 MW
TTC with All Lines In Service 5700 MW

Work scheduled by: ConEd

BUCHAN_N-EASTVIEW_345_W93

FWD

Thu 02/07/2019 to Fri 02/08/2019
0001 Continuous 0300

(Import)

UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1350 MW
TTC with All Lines In Service 5700 MW

Work scheduled by: ConEd

ADIRNDCK-CHASLAKE_230_13

FWD

Thu 02/07/2019 to Thu 02/07/2019
0800 Continuous 1530

(Import)

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

EASTVIEW-SPRNBK__345_W79

FWD

Fri 02/08/2019 to Fri 02/08/2019
0230 Continuous 0300

(Import)

UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1350 MW
TTC with All Lines In Service 5700 MW

Work scheduled by: ConEd

MOSES__-ADIRNDCK_230_MA1

FWD

Fri 02/08/2019 to Fri 02/08/2019
0800 Continuous 1500

(Import)

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

MOSES__-ADIRNDCK_230_MA2

FWD

Mon 02/11/2019 to Fri 02/15/2019
0700 Continuous 1500

(Import)

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

NYISO TRANSFER LIMITATIONS

Friday ,December 07, 2018 to Sunday ,June 07, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA2				FWD
Tue 02/19/2019 to Fri 02/22/2019				(Import)
0700	Continuous	1500		MOSES SOUTH 2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW
<hr/>				
MOSES___-ADIRNDCK_230_MAI				FWD
Mon 02/25/2019 to Fri 03/01/2019				(Import)
0700	Continuous	1500		MOSES SOUTH 2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW
<hr/>				
PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4				FWD
Fri 03/01/2019 to Mon 03/04/2019				(Import)
0001		0200		UPNY CONED 3800 MW
Work scheduled by:				Impacts Total Transfer Capability 1900 MW
				TTC with All Lines In Service 5700 MW
<hr/>				
LONG_MTN-PLSNTVLY_345_398				FWD
Fri 03/01/2019 to Sun 05/19/2019				(Import) (Export)
0001	Continuous	2359	UPDATED by CONED 11/28/2018	SCH - NE - NY 700 MW 1300 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 700 MW 500 MW
				TTC with All Lines In Service 1400 MW 1800 MW
<hr/>				
LONG_MTN-PLSNTVLY_345_398				FWD
Fri 03/01/2019 to Sun 05/19/2019				(Import) (Export)
0001	Continuous	2359	UPDATED by CONED 11/28/2018	SCH - NPX_1385 100 MW 100 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 100 MW 100 MW
				TTC with All Lines In Service 200 MW 200 MW
<hr/>				
EASTVIEW-SPRNBRK___345_W64				FWD
Mon 03/04/2019 to Mon 03/04/2019				(Import)
0001	Continuous	0030		UPNY CONED 4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1350 MW
				TTC with All Lines In Service 5700 MW
<hr/>				
MILLWOOD-EASTVIEW_345_W99				FWD
Mon 03/04/2019 to Thu 03/07/2019				(Import)
0001	Continuous	2359		UPNY CONED 4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1350 MW
				TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Friday ,December 07, 2018 to Sunday ,June 07, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY-EFISHKIL_345_F37				FWD
Mon 03/04/2019	to	Wed 03/06/2019	UPDATED by CONED 11/28/2018	(Import)
0201	Continuous	0300	UPNY CONED	4000 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1700 MW
				TTC with All Lines In Service 5700 MW
MOSES -ADIRNDCK_230_MAI				FWD
Mon 03/04/2019	to	Fri 03/08/2019		(Import)
0700	Continuous	1500	MOSES SOUTH	2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW
EASTVIEW-SPRNBK_345_W64				FWD
Thu 03/07/2019	to	Thu 03/07/2019		(Import)
2330	Continuous	2359	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1350 MW
				TTC with All Lines In Service 5700 MW
STLAWRNC-MOSES_230_L33P & STLAWRNC-MOSES_230_L34P				FWD
Mon 03/11/2019	to	Mon 03/11/2019		(Import)
0700		1530	MOSES SOUTH	2700 MW
Work scheduled by:				Impacts Total Transfer Capability 450 MW
				TTC with All Lines In Service 3150 MW
STLAWRNC-MOSES_230_L34P				FWD
Mon 03/11/2019	to	Mon 03/11/2019		(Import) (Export)
0700	Continuous	1530	SCH - OH - NY	1750 MW 1900 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 0 MW 100 MW
				TTC with All Lines In Service 1750 MW 2000 MW
LEEDS_345_LEEDS SVC				FWD
Mon 03/11/2019	to	Fri 03/22/2019		(Import)
0800	Continuous	1600	CENTRAL EAST - VC	2950 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 25 MW
				TTC with All Lines In Service 2975 MW
MOSES -ADIRNDCK_230_MAI				FWD
Tue 03/12/2019	to	Fri 03/15/2019		(Import)
0700	Continuous	1500	MOSES SOUTH	2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,December 07, 2018 to Sunday ,June 07, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT1

Mon 03/18/2019 to Fri 03/22/2019
0500 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1750 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 3150 MW

MARCY___345KV_CSC

Mon 04/01/2019 to Sun 04/07/2019
0500 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2925 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

VOLNEY_-MARCY___345_19

Mon 04/01/2019 to Wed 04/10/2019
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2825 MW**
Impacts Total Transfer Capability 150 MW
TTC with All Lines In Service 2975 MW

VOLNEY_-MARCY___345_19

Mon 04/01/2019 to Wed 04/10/2019
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
OSWEGO EXPORT **4900 MW**
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 5250 MW

PLSNTVLY-EFISHKIL_345_F37

Thu 04/04/2019 to Mon 04/08/2019
0001 Continuous 0200

Work scheduled by: ConEd

UPDATED by CONED 11/28/2018

FWD
(Import)
UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1700 MW
TTC with All Lines In Service 5700 MW

DUNWODIE-MOTTHAVN_345_71

Fri 04/05/2019 to Thu 05/09/2019
0001 Continuous 2359

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

NIAGARA_-ROCHESTR_345_NR2

Fri 04/05/2019 to Fri 04/05/2019
0500 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,December 07, 2018 to Sunday ,June 07, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Line ID	Start Date	End Date	Time	Work Scheduled by	Transfer Capability	FWD	REV
LINDN_CG-LNDVFT_345_V-3022	Sun 04/07/2019	Fri 04/12/2019	1400 Continuous 1800	PJM	SCH - PJM_VFT	0 MW	0 MW
					Impacts Total Transfer Capability	315 MW	315 MW
					TTC with All Lines In Service	315 MW	315 MW
PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4	Mon 04/08/2019	Sat 04/13/2019	0001 0300		UPNY CONED	3800 MW	
					Impacts Total Transfer Capability	1900 MW	
					TTC with All Lines In Service	5700 MW	
PLSNTVLE-DUNWODIE_345_W89	Mon 04/08/2019	Fri 05/10/2019	0001 Continuous 2359	ConEd	UPNY CONED	4000 MW	
					Impacts Total Transfer Capability	1700 MW	
					TTC with All Lines In Service	5700 MW	
MARCY_345KV_CSC	Thu 04/11/2019	Wed 04/17/2019	0500 Continuous 1730	NYPA	CENTRAL EAST - VC	2925 MW	
					Impacts Total Transfer Capability	50 MW	
					TTC with All Lines In Service	2975 MW	
MARCY_-EDIC_345_UE1-7	Thu 04/11/2019	Sat 04/20/2019	0500 Continuous 1730	NYPA	OSWEGO EXPORT	5250 MW	
					Impacts Total Transfer Capability	0 MW	
					TTC with All Lines In Service	5250 MW	
							ARR: 19&16
GILBOA_-N.SCTLND_345_GNS-1	Fri 04/12/2019	Fri 04/12/2019	1330 Continuous 1530	NYPA	CENTRAL EAST - VC	2520 MW	
					Impacts Total Transfer Capability	455 MW	
					TTC with All Lines In Service	2975 MW	
EDIC_-FRASER_345_EF24-40	Mon 04/22/2019	Fri 04/26/2019	0500 Continuous 1730	NYPA	CENTRAL EAST - VC	2500 MW	
					Impacts Total Transfer Capability	475 MW	
					TTC with All Lines In Service	2975 MW	

NYISO TRANSFER LIMITATIONS

Friday ,December 07, 2018 to Sunday ,June 07, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT2

Mon 04/22/2019 to Fri 04/26/2019
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

FRASANX-COOPERS__345_UCC2-41

Mon 04/29/2019 to Fri 05/03/2019
0500 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 08/22/2018

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

MARCY___-FRASANX_345_UCC2-41

Mon 04/29/2019 to Fri 05/03/2019
0500 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 08/22/2018

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

MOSES___-ADIRNDCK_230_MA1

Mon 04/29/2019 to Fri 05/03/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

HUDSONTP-W49TH_ST_345_Y56

Wed 05/01/2019 to Tue 05/07/2019
0600 Continuous 1800

Work scheduled by: PJM

FWD
(Import)
SCH - PJM_HTP **0 MW**
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

KINTIGH_-ROCHESTR_345_SR1-39

Mon 05/06/2019 to Fri 05/10/2019
0600 Continuous 1700

Work scheduled by: NYPA

UPDATED by NYSEG 11/08/2018

FWD
(Import)
DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

ROSETON_-ROCKTVRN_345_311

Mon 05/06/2019 to Sat 06/01/2019
0800 Continuous 1600

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4400 MW**
Impacts Total Transfer Capability 1300 MW
TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Friday ,December 07, 2018 to Sunday ,June 07, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-ROCHESTR_345_NR2

Mon 05/13/2019 to Fri 05/17/2019
0600 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

ADIRNDCK-PORTER_230_12

Mon 05/20/2019 to Fri 05/24/2019
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

PANNELL_-CLAY_345_1

Mon 05/20/2019 to Fri 05/24/2019
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

PANNELL_-CLAY_345_2

Mon 06/03/2019 to Fri 06/07/2019
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

MOSES_-ADIRNDCK_230_MA2

Mon 06/24/2019 to Fri 06/28/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

MOSES_-ADIRNDCK_230_MA2

Mon 07/08/2019 to Fri 07/12/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

ADIRNDCK-CHASLAKE_230_13

Mon 07/08/2019 to Fri 07/12/2019
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,December 07, 2018 to Sunday ,June 07, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT2

Sat 08/03/2019 to Sun 08/04/2019
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MAI

Mon 08/12/2019 to Mon 08/12/2019
0700 Continuous 1459

Work scheduled by: NYPA

UPDATED by NYPA 10/10/2018

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

MARCY___765_345_AT1

Tue 09/03/2019 to Tue 09/03/2019
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1750 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 3150 MW

MARCY___-N.SCTLND_345_18

Wed 09/04/2019 to Wed 09/04/2019
0500 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 11/06/2018

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2090 MW**
Impacts Total Transfer Capability 885 MW
TTC with All Lines In Service 2975 MW

MARCY___345KV_CSC

Wed 09/04/2019 to Wed 09/04/2019
0500 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 11/06/2018

FWD
(Import)
CENTRAL EAST - VC **2925 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

MOSES___-ADIRNDCK_230_MA2

Wed 09/04/2019 to Wed 09/04/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

ADIRNDCK-PORTER___230_12

Wed 09/04/2019 to Wed 09/04/2019
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,December 07, 2018 to Sunday ,June 07, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ADIRNDCK-CHASLAKE_230_13

Thu 09/05/2019 to Thu 09/05/2019
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH 2100 MW
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

NIAGARA -ROCHESTR_345_NR2

Mon 09/09/2019 to Sat 09/21/2019
0500 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST 1400 MW
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

LEEDS___345KV_R395

Mon 09/09/2019 to Mon 09/09/2019
0700 Continuous 0730

Work scheduled by: NYPA

FWD
(Import)
UPNY CONED 3800 MW
Impacts Total Transfer Capability 1900 MW
TTC with All Lines In Service 5700 MW

GILBOA -LEEDS___345_GL3

Mon 09/09/2019 to Fri 09/27/2019
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC 2200 MW
Impacts Total Transfer Capability 775 MW
TTC with All Lines In Service 2975 MW

MARCY___-N.SCTLND_345_18

Wed 09/11/2019 to Fri 09/13/2019
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC 2090 MW
Impacts Total Transfer Capability 885 MW
TTC with All Lines In Service 2975 MW

MOSES___-ADIRNDCK_230_MA2

Mon 09/16/2019 to Fri 09/20/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH 2100 MW
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

GOETHALS_345KV_5

Fri 09/20/2019 to Tue 09/24/2019
0001 Continuous 2359

Work scheduled by: ConEd

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Friday ,December 07, 2018 to Sunday ,June 07, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROCHESTR-PANNELL__345_RP2

Mon 09/23/2019 to Mon 09/30/2019
0500 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

KINTIGH_-ROCHESTR_345_SR1-39

Mon 09/23/2019 to Fri 09/27/2019
0600 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

SPRNBK__345KV_RNS5

Wed 09/25/2019 to Wed 09/25/2019
0001 Continuous 0030

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

SPRNBK_-W49TH_ST_345_M51

Wed 09/25/2019 to Sat 11/02/2019
0001 Continuous 0200

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

LEEDS__345KV_R395

Fri 09/27/2019 to Fri 09/27/2019
1700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

UPNY CONED **3800 MW**
Impacts Total Transfer Capability 1900 MW
TTC with All Lines In Service 5700 MW

CLAY_-EDIC__345_1-16

Mon 09/30/2019 to Fri 10/04/2019
0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

OSWEGO EXPORT **4850 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 5250 MW

LEEDS_-HURLYAVE_345_301

Mon 09/30/2019 to Sat 10/26/2019
0800 Continuous 1600

Work scheduled by: CHGE

FWD

(Import)

UPNY CONED **4100 MW**
Impacts Total Transfer Capability 1600 MW
TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Friday ,December 07, 2018 to Sunday ,June 07, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CLAY -EDIC 345_2-15		FWD	
Mon 10/07/2019	to Thu 10/17/2019	(Import)	
0700	Continuous 1530	OSWEGO EXPORT	4850 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	400 MW
		TTC with All Lines In Service	5250 MW
MARCY -N.SCTLND 345_18		FWD	
Wed 10/09/2019	to Fri 10/11/2019	(Import)	
0500	Continuous 1730	CENTRAL EAST - VC	2090 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	885 MW
		TTC with All Lines In Service	2975 MW
CHATGUAY-MASSENA 765_7040		FWD	
Sat 10/12/2019	to Sat 10/26/2019	(Import)	
0100	Continuous 1900	MOSES SOUTH	1550 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	1600 MW
		TTC with All Lines In Service	3150 MW
CHATGUAY-MASSENA 765_7040		FWD	REV
Sat 10/12/2019	to Sat 10/26/2019	(Import)	(Export)
0100	Continuous 1900	SCH - HQ - NY	0 MW 0 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	1500 MW 1000 MW
		TTC with All Lines In Service	1500 MW 1000 MW
MARCY 765_345_AT1		FWD	
Sat 10/12/2019	to Sat 10/26/2019	(Import)	
0100	Continuous 1900	MOSES SOUTH	1750 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	1400 MW
		TTC with All Lines In Service	3150 MW
MARCY 765_345_AT2		FWD	
Sat 10/12/2019	to Sat 10/26/2019	(Import)	
0100	Continuous 1900	MOSES SOUTH	1700 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	1450 MW
		TTC with All Lines In Service	3150 MW
MASSENA -MARCY 765_MSU1		FWD	
Sat 10/12/2019	to Sat 10/26/2019	(Import)	
0100	Continuous 1900	CENTRAL EAST - VC	2265 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	710 MW
		TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Friday ,December 07, 2018 to Sunday ,June 07, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA -MARCY 765_MSU1			FWD	
Sat 10/12/2019	to	Sat 10/26/2019	(Import)	
0100	Continuous	1900	MOSES SOUTH	500 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	2650 MW
			TTC with All Lines In Service	3150 MW
MASSENA -MARCY 765_MSU1			FWD	REV
Sat 10/12/2019	to	Sat 10/26/2019	(Import)	(Export)
0100	Continuous	1900	SCH - HQ - NY	475 MW 1000 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1025 MW 0 MW
			TTC with All Lines In Service	1500 MW 1000 MW
MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040			FWD	
Sat 10/12/2019	to	Sat 10/26/2019	(Import)	
0100		1900	MOSES SOUTH	500 MW
Work scheduled by:			Impacts Total Transfer Capability	2650 MW
			TTC with All Lines In Service	3150 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2			FWD	REV
Sat 10/12/2019	to	Sat 10/26/2019	(Import)	(Export)
0100		1900	SCH - HQ - NY	850 MW 0 MW
Work scheduled by:			Impacts Total Transfer Capability	650 MW 1000 MW
			TTC with All Lines In Service	1500 MW 1000 MW
NIAGARA 345_230_AT4			FWD	REV
Wed 10/23/2019	to	Wed 12/18/2019	(Import)	(Export)
0500	Continuous	1700	SCH - OH - NY	1900 MW 1400 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	0 MW 350 MW
			TTC with All Lines In Service	1900 MW 1750 MW
SPRNBK 345KV_RNS5			FWD	
Sat 11/02/2019	to	Sat 11/02/2019	(Import)	
0130	Continuous	0200	SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	1400 MW
			TTC with All Lines In Service	4600 MW
HURLYAVE-ROSETON 345_303			FWD	
Mon 11/04/2019	to	Fri 12/06/2019	(Import)	
0800	Continuous	1600	UPNY CONED	4100 MW
Work scheduled by: CHGE			Impacts Total Transfer Capability	1600 MW
			TTC with All Lines In Service	5700 MW

NYISO TRANSFER LIMITATIONS

Friday ,December 07, 2018 to Sunday ,June 07, 2020

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PANNELL_-CLAY_345_2

Wed 11/06/2019 to Fri 11/22/2019
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

MARCY_-N.SCTLND_345_18

Thu 11/07/2019 to Fri 11/08/2019
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2090 MW**
Impacts Total Transfer Capability 885 MW
TTC with All Lines In Service 2975 MW

MARCY_345KV_CSC

Thu 11/07/2019 to Fri 11/08/2019
0500 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2925 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

MOSES_-ADIRNDCK_230_MA2

Tue 11/12/2019 to Fri 11/15/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MOSES_-ADIRNDCK_230_MA2

Mon 11/18/2019 to Fri 11/22/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MOSES_-ADIRNDCK_230_MA2

Mon 11/25/2019 to Wed 11/27/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MOSES_-ADIRNDCK_230_MA2

Mon 12/02/2019 to Fri 12/06/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,December 07, 2018 to Sunday ,June 07, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA1

Mon 12/09/2019 to Fri 12/13/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 12/16/2019 to Mon 12/16/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA1

Tue 12/17/2019 to Fri 12/20/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

LADENTWN-BUCHAN_S_345_Y88

Wed 01/15/2020 to Thu 02/13/2020
0001 Continuous 2359

Work scheduled by: ORU

11/05/2018

FWD
(Import)
UPNY CONED **4800 MW**
Impacts Total Transfer Capability 900 MW
TTC with All Lines In Service 5700 MW

FRASANNX-COOPERS__345_UCC2-41

Mon 04/27/2020 to Sun 05/31/2020
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

MARCY___-FRASANNX_345_UCC2-41

Mon 04/27/2020 to Sun 05/31/2020
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW