

# NYISO TRANSFER LIMITATIONS

Saturday ,December 08, 2018 to Monday ,June 08, 2020

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

	FWD	REV
<b>HUDSONP_-FARRAGUT_345_B3402</b>		
Mon 01/15/2018 to Mon 04/01/2019		(Import) (Export)
0001 Continuous 2359		
<u>EXT FORCE</u> <u>by CONED</u> <u>12/02/2018</u>		
SCH - PJ - NY	<b>2600 MW</b>	<b>1300 MW</b>
Impacts Total Transfer Capability	0 MW	250 MW
TTC with All Lines In Service	2600 MW	1550 MW
Work scheduled by: ConEd		
<b>HUDSONP_-FARRAGUT_345_B3402 &amp; MARION_-FARRAGUT_345_C3403</b>		
Mon 01/15/2018 to Mon 04/01/2019		(Import) (Export)
0001 2359		
SCH - PJ - NY	<b>2000 MW</b>	<b>1300 MW</b>
Impacts Total Transfer Capability	600 MW	250 MW
TTC with All Lines In Service	2600 MW	1550 MW
Work scheduled by:		
<b>MARION_-FARRAGUT_345_C3403</b>		
Mon 01/15/2018 to Mon 04/01/2019		(Import) (Export)
0001 Continuous 2359		
<u>EXT FORCE</u> <u>by CONED</u> <u>12/02/2018</u>		
SCH - PJ - NY	<b>2600 MW</b>	<b>1300 MW</b>
Impacts Total Transfer Capability	0 MW	250 MW
TTC with All Lines In Service	2600 MW	1550 MW
Work scheduled by: ConEd		
<b>STLAWRNC-MOSES_230_L33P</b>		
Mon 04/30/2018 to Fri 12/31/2021		(Import) (Export)
0456 Continuous 2359		
<u>EXT FORCE</u> <u>by IESO</u> <u>08/21/2018</u>		
SCH - OH - NY	<b>1750 MW</b>	<b>1900 MW</b>
Impacts Total Transfer Capability	0 MW	100 MW
TTC with All Lines In Service	1750 MW	2000 MW
Work scheduled by: IESO		
<b>DUNWODIE_345KV_6</b>		
Mon 10/22/2018 to Sat 12/22/2018		(Import)
0301 Continuous 0200		
<u>UPDATED</u> <u>by CE</u> <u>10/04/2018</u>		
SPR/DUN-SOUTH	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	
Work scheduled by: ConEd		
<b>DUNWODIE_345KV_8</b>		
Mon 10/22/2018 to Sat 12/22/2018		(Import)
0301 Continuous 0200		
<u>UPDATED</u> <u>by CE</u> <u>10/04/2018</u>		
SPR/DUN-SOUTH	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	
Work scheduled by: ConEd		
<b>PLSNTVLE-DUNWODIE_345_W90</b>		
Mon 10/22/2018 to Sat 12/22/2018		(Import)
0301 Continuous 0200		
<u>UPDATED</u> <u>by CE</u> <u>10/04/2018</u>		
UPNY CONED	<b>4000 MW</b>	
Impacts Total Transfer Capability	1700 MW	
TTC with All Lines In Service	5700 MW	
Work scheduled by: ConEd		

# NYISO TRANSFER LIMITATIONS

Saturday ,December 08, 2018 to Monday ,June 08, 2020

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>							FWD	REV
<b>S.RIPLEY-DUNKIRK__230_68</b>							(Import)	(Export)
Mon 10/22/2018	to	Fri 12/14/2018	<u>UPDATED</u>	<u>by PJM</u>	<u>11/20/2018</u>	SCH - PJ - NY	<b>2600 MW</b>	<b>1300 MW</b>
0800	Continuous	2000				Impacts Total Transfer Capability	0 MW	250 MW
Work scheduled by: PJM						TTC with All Lines In Service	2600 MW	1550 MW
<hr/>							FWD	
<b>SCH-IMO-NYISO_LIMIT_1400</b>							(Import)	
Thu 11/01/2018	to	Fri 12/07/2018				SCH - OH - NY	<b>1700 MW</b>	
0001	Continuous	2359				Impacts Total Transfer Capability	50 MW	
Work scheduled by: IESO						TTC with All Lines In Service	1750 MW	
<hr/>								REV
<b>SCH-NYISO-IMO_LIMIT_1600</b>								(Export)
Thu 11/01/2018	to	Fri 12/07/2018				SCH - OH - NY		<b>1900 MW</b>
0001	Continuous	2359				Impacts Total Transfer Capability		100 MW
Work scheduled by: IESO						TTC with All Lines In Service		2000 MW
<hr/>							FWD	
<b>SCH-IMO-NYISO_LIMIT_1300</b>							(Import)	
Thu 11/15/2018	to	Thu 12/20/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>11/20/2018</u>	SCH - OH - NY	<b>1600 MW</b>	
0500	Continuous	2359				Impacts Total Transfer Capability	150 MW	
Work scheduled by: NYPA						TTC with All Lines In Service	1750 MW	
<hr/>							FWD	REV
<b>LONG_MTN-PLSNTVLY_345_398</b>							(Import)	(Export)
Mon 11/26/2018	to	Tue 12/04/2018	<u>UPDATED</u>	<u>by CONED</u>	<u>11/21/2018</u>	SCH - NE - NY	<b>700 MW</b>	<b>1300 MW</b>
0001	Continuous	0030				Impacts Total Transfer Capability	700 MW	500 MW
Work scheduled by: ConEd						TTC with All Lines In Service	1400 MW	1800 MW
<hr/>							FWD	REV
<b>LONG_MTN-PLSNTVLY_345_398</b>							(Import)	(Export)
Mon 11/26/2018	to	Tue 12/04/2018	<u>UPDATED</u>	<u>by CONED</u>	<u>11/21/2018</u>	SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
0001	Continuous	0030				Impacts Total Transfer Capability	100 MW	100 MW
Work scheduled by: ConEd						TTC with All Lines In Service	200 MW	200 MW
<hr/>								REV
<b>SCH-NYISO-NE_LIMIT_700</b>								(Export)
Mon 11/26/2018	to	Tue 12/04/2018	<u>UPDATED</u>	<u>by CONED</u>	<u>11/21/2018</u>	SCH - NE - NY		<b>900 MW</b>
0001	Continuous	0030				Impacts Total Transfer Capability		900 MW
Work scheduled by: ConEd						TTC with All Lines In Service		1800 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,December 08, 2018 to Monday ,June 08, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
<b>SHOR_NPX-SHOREHAM_138_CSC</b>						
Mon 11/26/2018	to	Fri 12/07/2018				
0700	Continuous	1600			SCH - NPX_CSC	<b>0 MW 0 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability	330 MW 330 MW
					TTC with All Lines In Service	330 MW 330 MW
<b>HURLYAVE-ROSETON_345_303</b>					FWD	
Mon 11/26/2018	to	Fri 12/21/2018			(Import)	
0800	Continuous	1600			UPNY CONED	<b>4100 MW</b>
Work scheduled by: CHGE					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	5700 MW
<b>HOMR_NYW-PIERC_NY_345_48</b>					FWD	REV
Wed 11/28/2018	to	Wed 12/05/2018	<u>EXT FORCE</u>	<u>by PJM</u>	<u>11/30/2018</u>	(Import) (Export)
1305	Continuous	1600			SCH - PJ - NY	<b>2500 MW 1300 MW</b>
Work scheduled by: PJM					Impacts Total Transfer Capability	100 MW 250 MW
					TTC with All Lines In Service	2600 MW 1550 MW
<b>SCH-NYISO-HQ_LIMIT_800</b>						REV
Thu 11/29/2018	to	Mon 12/10/2018				(Export)
2001	Continuous	1800			SCH - HQ - NY	<b>800 MW</b>
Work scheduled by: HQ					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	1000 MW
<b>DUNWODIE-MOTTHAVN_345_72</b>					FWD	
Sun 12/02/2018	to	Fri 12/07/2018	<u>EXTENDED</u>	<u>by CONED</u>	<u>12/05/2018</u>	(Import)
0001	Continuous	0159			SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>DUNWODIE_345KV_7</b>					FWD	
Sun 12/02/2018	to	Fri 12/07/2018	<u>EXTENDED</u>	<u>by CONED</u>	<u>12/05/2018</u>	(Import)
0001	Continuous	0159			SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>BECK_-NIAGARA_345_PA302</b>					FWD	REV
Mon 12/03/2018	to	Wed 12/05/2018				(Import) (Export)
0500	Continuous	1900			SCH - OH - NY	<b>1100 MW 950 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	650 MW 1050 MW
					TTC with All Lines In Service	1750 MW 2000 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,December 08, 2018 to Monday ,June 08, 2020

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MOSES -ADIRNDCK_230_MA2</b>					FWD
Mon 12/03/2018	to	Fri 12/07/2018			(Import)
0700	Continuous	1530		MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 850 MW
					TTC with All Lines In Service 3150 MW
<b>DUNWODIE-SHORE_RD_345_Y50</b>					FWD
Fri 12/07/2018	to	Thu 12/13/2018	<b>UPDATED</b>	<b>by CONED 12/05/2018</b>	(Import)
0201	Continuous	0200		CONED - LIPA	<b>800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 700 MW
					TTC with All Lines In Service 1500 MW
<b>DUNWODIE_345KV_4</b>					FWD
Fri 12/07/2018	to	Thu 12/13/2018	<b>UPDATED</b>	<b>by CONED 12/05/2018</b>	(Import)
0201	Continuous	0200		SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
<b>SHORE_RD_345_138_BK 1</b>					FWD
Fri 12/07/2018	to	Thu 12/13/2018	<b>UPDATED</b>	<b>by CONED 12/05/2018</b>	(Import)
0201	Continuous	0200		CONED - LIPA	<b>1350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 150 MW
					TTC with All Lines In Service 1500 MW
<b>SHORE_RD_345_138_BK 2</b>					FWD
Fri 12/07/2018	to	Thu 12/13/2018	<b>UPDATED</b>	<b>by CONED 12/05/2018</b>	(Import)
0201	Continuous	0200		CONED - LIPA	<b>1350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 150 MW
					TTC with All Lines In Service 1500 MW
<b>NRTH1385-NOR HBR_138_602</b>					FWD      REV
Sat 12/08/2018	to	Sat 12/08/2018			(Import) (Export)
0700	Continuous	1100		SCH - NPX_1385	<b>100 MW    100 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability 100 MW    100 MW
					TTC with All Lines In Service 200 MW    200 MW
<b>CHATGUAY-MASSENA_765_7040</b>					FWD
Sat 12/08/2018	to	Sat 12/08/2018	<b>UPDATED</b>	<b>by NYPA 11/16/2018</b>	(Import)
0700	Continuous	2300		MOSES SOUTH	<b>1550 MW</b>
Work scheduled by: HQ					Impacts Total Transfer Capability 1600 MW
					TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,December 08, 2018 to Monday ,June 08, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					FWD	REV
CHATGUAY-MASSENA__765_7040					(Import)	(Export)
Sat 12/08/2018	to	Sat 12/08/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>11/16/2018</u>	
0700	Continuous	2300				
Work scheduled by: HQ					SCH - HQ - NY	<b>0 MW</b>
					Impacts Total Transfer Capability	1500 MW
					TTC with All Lines In Service	1500 MW
<hr/>					FWD	REV
BROWNFLS-TAYLORVL_115_4					(Import)	(Export)
Sat 12/08/2018	to	Sat 12/08/2018				
0800	Continuous	1600				
Work scheduled by: NGrid					SCH - HQ_CEDARS	<b>100 MW</b>
					Impacts Total Transfer Capability	99 MW
					TTC with All Lines In Service	199 MW
						<b>100 MW</b>
ARR: 38						0 MW
<hr/>					FWD	REV
CEDARS__-ROSEMNTB_115_2/22					(Import)	(Export)
Sat 12/08/2018	to	Sat 12/08/2018	<u>CANCELLED</u>	<u>by HQ</u>	<u>12/08/2018</u>	
0800	Continuous	1600				
Work scheduled by: HQ					SCH - HQ_CEDARS	<b>95 MW</b>
					Impacts Total Transfer Capability	104 MW
					TTC with All Lines In Service	199 MW
						<b>100 MW</b>
ARR: 38						0 MW
<hr/>					FWD	REV
DENNISON-ROSEMNTB_115_2/22					(Import)	(Export)
Sat 12/08/2018	to	Sat 12/08/2018	<u>CANCELLED</u>	<u>by HQ</u>	<u>12/08/2018</u>	
0800	Continuous	1600				
Work scheduled by: HQ					SCH - HQ_CEDARS	<b>95 MW</b>
					Impacts Total Transfer Capability	104 MW
					TTC with All Lines In Service	199 MW
						<b>100 MW</b>
ARR: 38						0 MW
<hr/>					FWD	REV
SCH-NYISO-HQ_CEDARS_LIMIT_0					(Export)	
Sat 12/08/2018	to	Sat 12/08/2018	<u>CANCELLED</u>	<u>by HQ</u>	<u>12/08/2018</u>	
0800	Continuous	1600				
Work scheduled by: HQ					SCH - HQ_CEDARS	<b>0 MW</b>
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	100 MW
<hr/>					FWD	REV
CLRKSCRN-OAKDALE__345_36					(Import)	
Sun 12/09/2018	to	Sun 12/09/2018				
0700	Continuous	1600				
Work scheduled by: NYSEG					CENTRAL EAST - VC	<b>2650 MW</b>
					Impacts Total Transfer Capability	325 MW
					TTC with All Lines In Service	2975 MW
<hr/>					FWD	REV
BROWNFLS-TAYLORVL_115_3					(Import)	(Export)
Sun 12/09/2018	to	Sun 12/09/2018				
0700	Continuous	1700				
Work scheduled by: NGrid					SCH - HQ_CEDARS	<b>100 MW</b>
					Impacts Total Transfer Capability	99 MW
					TTC with All Lines In Service	199 MW
						<b>100 MW</b>
ARR: 38						0 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,December 08, 2018 to Monday ,June 08, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**BROWNFLS-TAYLORVL\_115\_3 & TAYLORVL-LOWVILLE\_115\_5 & CLIMAX\_\_-TAYLORVL\_115\_8**

Sun 12/09/2018 to Sun 12/09/2018  
0700 1700

Work scheduled by: **ARR: 38**

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	<b>120 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	79 MW	0 MW
TTC with All Lines In Service	199 MW	100 MW

**TAYLORVL-LOWVILLE\_115\_5**

Sun 12/09/2018 to Sun 12/09/2018  
0700 Continuous 1700

Work scheduled by: NGrid **ARR: 38**

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	<b>199 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	199 MW	100 MW

**SCH-IMO-NYISO\_LIMIT\_900**

Mon 12/10/2018 to Mon 12/10/2018  
0600 Continuous 1800

Work scheduled by: NGrid

	FWD
	(Import)
SCH - OH - NY	<b>1200 MW</b>
Impacts Total Transfer Capability	550 MW
TTC with All Lines In Service	1750 MW

**FIVEMILE-STOLLERD\_345\_29**

Mon 12/10/2018 to Wed 12/12/2018  
0700 Continuous 1555

Work scheduled by: NGrid

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2600 MW</b>	<b>1300 MW</b>
Impacts Total Transfer Capability	0 MW	250 MW
TTC with All Lines In Service	2600 MW	1550 MW

**MOSES\_\_-ADIRNDCK\_230\_MA2**

Mon 12/10/2018 to Fri 12/14/2018  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>2300 MW</b>
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

**SCH-IMO-NYISO\_LIMIT\_1000**

Tue 12/11/2018 to Tue 12/11/2018  
0800 Daily(No Weekends) 1600

Work scheduled by: NGrid

	FWD
	(Import)
SCH - OH - NY	<b>1300 MW</b>
Impacts Total Transfer Capability	450 MW
TTC with All Lines In Service	1750 MW

**HOMR\_NYW-PIERC\_NY\_345\_48**

Tue 12/11/2018 to Tue 12/11/2018  
1200 Continuous 1600

Work scheduled by: PJM

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2500 MW</b>	<b>1300 MW</b>
Impacts Total Transfer Capability	100 MW	250 MW
TTC with All Lines In Service	2600 MW	1550 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,December 08, 2018 to Monday ,June 08, 2020

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>WOOD_ST_-PLSNTVLE_345_Y87</b>					FWD
Mon 12/17/2018	to	Mon 01/28/2019	<b>UPDATED</b>	<b>by CE</b>	(Import)
0001	Continuous	0200		<b>10/04/2018</b>	
Work scheduled by: ConEd					UPNY CONED <b>4000 MW</b>
					Impacts Total Transfer Capability 1700 MW
					TTC with All Lines In Service 5700 MW
<hr/>					
<b>MARCY___345KV_CSC</b>					FWD
Mon 12/17/2018	to	Tue 12/18/2018			(Import)
0500	Continuous	1730			
Work scheduled by: NYPA					CENTRAL EAST - VC <b>2925 MW</b>
					Impacts Total Transfer Capability 50 MW
					TTC with All Lines In Service 2975 MW
<hr/>					
<b>MARCY___765_345_AT2</b>					FWD
Mon 12/17/2018	to	Fri 12/21/2018	<b>UPDATED</b>	<b>by NYPA</b>	(Import)
0500	Continuous	1730		<b>11/09/2018</b>	
Work scheduled by: NYPA					MOSES SOUTH <b>1700 MW</b>
					Impacts Total Transfer Capability 1450 MW
					TTC with All Lines In Service 3150 MW
<hr/>					
<b>SCRIBA_-VOLNEY___345_21</b>					FWD
Mon 12/17/2018	to	Wed 12/19/2018	<b>UPDATED</b>	<b>by NGRID</b>	(Import)
0600	Continuous	1730		<b>12/07/2018</b>	
Work scheduled by: NGrid					OSWEGO EXPORT <b>5250 MW</b>
					Impacts Total Transfer Capability 0 MW
					TTC with All Lines In Service 5250 MW
<hr/>					
<b>SCH-IMO-NYISO_LIMIT_850</b>					FWD
Mon 12/17/2018	to	Fri 12/21/2018			(Import)
0800	Continuous	1600			
Work scheduled by: IESO					SCH - OH - NY <b>1150 MW</b>
					Impacts Total Transfer Capability 600 MW
					TTC with All Lines In Service 1750 MW
<hr/>					
<b>SCH-NYISO-IMO_LIMIT_900</b>					REV
Mon 12/17/2018	to	Fri 12/21/2018			(Export)
0800	Continuous	1600			
Work scheduled by: IESO					SCH - OH - NY <b>1200 MW</b>
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 2000 MW
<hr/>					
<b>SPRNBRK___345KV_RNS5</b>					FWD
Tue 12/18/2018	to	Tue 12/18/2018			(Import)
0001	Continuous	0030			
Work scheduled by: ConEd					SPR/DUN-SOUTH <b>3200 MW</b>
					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,December 08, 2018 to Monday ,June 08, 2020

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SPRNBK_-W49TH_ST_345_M51</b>			FWD
Tue 12/18/2018	to	Wed 12/19/2018	(Import)
0001	Continuous	0200	<b>SPR/DUN-SOUTH 3200 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability 1400 MW
			TTC with All Lines In Service 4600 MW
<b>STLAWRNC-MOSES_230_L33P &amp; STLAWRNC-MOSES_230_L34P</b>			FWD
Tue 12/18/2018	to	Tue 12/18/2018	(Import)
0800		1600	<b>MOSES SOUTH 2700 MW</b>
Work scheduled by:			Impacts Total Transfer Capability 450 MW
			TTC with All Lines In Service 3150 MW
<b>SCH-IMO-NYISO_LIMIT_700</b>			FWD
Tue 12/18/2018	to	Wed 12/19/2018	(Import)
0800	Daily	1600	<b>SCH - OH - NY 1000 MW</b>
Work scheduled by: IESO			Impacts Total Transfer Capability 750 MW
			TTC with All Lines In Service 1750 MW
<b>SCH-NYISO-IMO_LIMIT_700</b>			REV
Tue 12/18/2018	to	Wed 12/19/2018	(Export)
0800	Daily	1600	<b>SCH - OH - NY 1000 MW</b>
Work scheduled by: IESO			Impacts Total Transfer Capability 1000 MW
			TTC with All Lines In Service 2000 MW
<b>STLAWRNC-MOSES_230_L34P</b>			FWD REV
Tue 12/18/2018	to	Wed 12/19/2018	(Import) (Export)
0800	Daily	1600	<b>SCH - OH - NY 1750 MW 1900 MW</b>
Work scheduled by: IESO			Impacts Total Transfer Capability 0 MW 100 MW
			TTC with All Lines In Service 1750 MW 2000 MW
<b>SPRNBK_345KV_RNS5</b>			FWD
Wed 12/19/2018	to	Wed 12/19/2018	(Import)
0130	Continuous	0200	<b>SPR/DUN-SOUTH 3200 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability 1400 MW
			TTC with All Lines In Service 4600 MW
<b>STLAWRNC-MOSES_230_L33P &amp; STLAWRNC-MOSES_230_L34P</b>			FWD
Wed 12/19/2018	to	Wed 12/19/2018	(Import)
0800		1600	<b>MOSES SOUTH 2700 MW</b>
Work scheduled by:			Impacts Total Transfer Capability 450 MW
			TTC with All Lines In Service 3150 MW



# NYISO TRANSFER LIMITATIONS

Saturday ,December 08, 2018 to Monday ,June 08, 2020

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**FRASANX-COOPERS\_\_345\_UCC2-41**

Sat 12/22/2018 to Wed 12/26/2018  
0700 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

**MARCY\_\_-FRASANX\_345\_UCC2-41**

Sat 12/22/2018 to Wed 12/26/2018  
0700 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

**EDIC\_\_-FRASER\_\_345\_EF24-40**

Thu 12/27/2018 to Mon 12/31/2018  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

**SPRNBRK\_\_345KV\_RS3 & SPRNBRK\_\_345KV\_RS4**

Tue 01/01/2019 to Wed 01/02/2019  
0001 0200

Work scheduled by:

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**EFISHKIL-WOOD\_ST\_\_345\_F39**

Wed 01/02/2019 to Wed 01/02/2019  
0001 Continuous 0030

Work scheduled by: ConEd

**UPDATED by CE 10/04/2018**

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1700 MW  
TTC with All Lines In Service 5700 MW

**MOSES\_\_-ADIRNDCK\_230\_MA2**

Wed 01/02/2019 to Fri 01/04/2019  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**HURLYAVE-ROSETON\_\_345\_303**

Wed 01/02/2019 to Fri 01/11/2019  
0800 Continuous 1600

Work scheduled by: CHGE

**08/20/2018**

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 5700 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,December 08, 2018 to Monday ,June 08, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>EFISHKIL-WOOD_ST__345_F39</b>				FWD	
Thu 01/03/2019	to	Thu 01/03/2019	<u>UPDATED</u> <u>by CE</u> <u>10/04/2018</u>	(Import)	
0230	Continuous	0300		UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	1700 MW
				TTC with All Lines In Service	5700 MW
<b>SCH-NE-NYISO_LIMIT_1100</b>				FWD	
Mon 01/07/2019	to	Thu 01/10/2019		(Import)	
0700	Continuous	1600		SCH - NE - NY	<b>1300 MW</b>
Work scheduled by: ISONE				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	1400 MW
<b>MOSES__-ADIRNDCK_230_MA1</b>				FWD	
Mon 01/07/2019	to	Fri 01/11/2019		(Import)	
0700	Continuous	1500		MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
<b>BECK__-PACKARD_230_BP76</b>				FWD	REV
Tue 01/08/2019	to	Sat 01/12/2019		(Import)	(Export)
0700	Continuous	1700		SCH - OH - NY	<b>1700 MW 1500 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability	50 MW 500 MW
				TTC with All Lines In Service	1750 MW 2000 MW
<b>BECK__-PACKARD_230_BP76 &amp; STLAWRNC-MOSES__230_L33P</b>				FWD	REV
Tue 01/08/2019	to	Sat 01/12/2019		(Import)	(Export)
0700		1700		SCH - OH - NY	<b>900 MW 1150 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	850 MW 850 MW
				TTC with All Lines In Service	1750 MW 2000 MW
<b>BECK__-PACKARD_230_BP76</b>				FWD	REV
Wed 01/09/2019	to	Wed 01/09/2019	<u>CANCELLED</u> <u>by NGrid</u> <u>12/07/2018</u>	(Import)	(Export)
0800	Daily(No Weekends)	1500		SCH - OH - NY	<b>1700 MW 1500 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability	50 MW 500 MW
				TTC with All Lines In Service	1750 MW 2000 MW
<b>SPRNBRK_-TREMONT__345_X28</b>				FWD	
Mon 01/14/2019	to	Mon 01/14/2019		(Import)	
0001	Continuous	0100		SPR/DUN-SOUTH	<b>4200 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	400 MW
				TTC with All Lines In Service	4600 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,December 08, 2018 to Monday ,June 08, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Mon 01/14/2019 to Fri 01/18/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**LEEDS\_\_\_-HURLYAVE\_345\_301**

Mon 01/14/2019 to Fri 01/25/2019  
0800 Continuous 1600

Work scheduled by: CHGE

**08/20/2018**

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 5700 MW

**SPRNBK\_-TREMONT\_\_345\_X28**

Fri 01/18/2019 to Fri 01/18/2019  
2200 Continuous 2300

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **4200 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_6**

Mon 01/21/2019 to Mon 01/28/2019  
0001 Continuous 0200

Work scheduled by: ConEd

**UPDATED by CE 10/04/2018**

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_8**

Mon 01/21/2019 to Mon 01/28/2019  
0001 Continuous 0200

Work scheduled by: ConEd

**UPDATED by CE 10/04/2018**

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**PLSNTVLE-DUNWODIE\_345\_W90**

Mon 01/21/2019 to Mon 01/28/2019  
0001 Continuous 0200

Work scheduled by: ConEd

**UPDATED by CE 10/04/2018**

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1700 MW  
TTC with All Lines In Service 5700 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Mon 01/21/2019 to Fri 01/25/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,December 08, 2018 to Monday ,June 08, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**MOSES\_\_-ADIRNDCK\_230\_MA1**

FWD

Mon 01/28/2019 to Fri 02/01/2019  
 0700 Continuous 1500

Work scheduled by: NYPA

(Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

-----  
**LEEDS\_\_-HURLYAVE\_345\_301**

FWD

Mon 01/28/2019 to Fri 02/08/2019  
 0800 Continuous 1600

Work scheduled by: CHGE

11/13/2018

(Import)  
 UPNY CONED **4100 MW**  
 Impacts Total Transfer Capability 1600 MW  
 TTC with All Lines In Service 5700 MW

-----  
**PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4**

FWD

Tue 01/29/2019 to Sun 02/03/2019  
 0001 0300

Work scheduled by:

(Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 1900 MW  
 TTC with All Lines In Service 5700 MW

-----  
**PLSNTVLY-EFISHKIL\_345\_F36**

FWD

Sun 02/03/2019 to Wed 02/06/2019  
 0301 Continuous 0300

Work scheduled by: ConEd

UPDATED by CONED 11/21/2018

(Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

-----  
**MOSES\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 02/04/2019 to Thu 02/07/2019  
 0700 Continuous 1500

Work scheduled by: NYPA

(Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

-----  
**PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4**

FWD

Wed 02/06/2019 to Wed 02/06/2019  
 0330 0400

Work scheduled by:

(Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 1900 MW  
 TTC with All Lines In Service 5700 MW

-----  
**EASTVIEW-SPRNBK\_\_345\_W79**

FWD

Thu 02/07/2019 to Thu 02/07/2019  
 0001 Continuous 0030

Work scheduled by: ConEd

(Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1350 MW  
 TTC with All Lines In Service 5700 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,December 08, 2018 to Monday ,June 08, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**BUCHAN\_N-EASTVIEW\_345\_W93**

Thu 02/07/2019 to Fri 02/08/2019  
 0001 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1350 MW  
 TTC with All Lines In Service 5700 MW

**ADIRNDCK-CHASLAKE\_230\_13**

Thu 02/07/2019 to Thu 02/07/2019  
 0800 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

**EASTVIEW-SPRNBK\_345\_W79**

Fri 02/08/2019 to Fri 02/08/2019  
 0230 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1350 MW  
 TTC with All Lines In Service 5700 MW

**MOSES\_\_-ADIRNDCK\_230\_MA1**

Fri 02/08/2019 to Fri 02/08/2019  
 0800 Continuous 1500  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

**MOSES\_\_-ADIRNDCK\_230\_MA2**

Mon 02/11/2019 to Fri 02/15/2019  
 0700 Continuous 1500  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

**MOSES\_\_-ADIRNDCK\_230\_MA2**

Tue 02/19/2019 to Fri 02/22/2019  
 0700 Continuous 1500  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

**MOSES\_\_-ADIRNDCK\_230\_MA1**

Mon 02/25/2019 to Fri 03/01/2019  
 0700 Continuous 1500  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,December 08, 2018 to Monday ,June 08, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4**

Fri 03/01/2019 to Mon 03/04/2019  
 0001 0200

Work scheduled by:

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 1900 MW  
 TTC with All Lines In Service 5700 MW

-----  
**LONG\_MTN-PLSNTVLY\_345\_398**

Fri 03/01/2019 to Sun 05/19/2019 **UPDATED by CONED 11/28/2018**  
 0001 Continuous 2359

Work scheduled by: ConEd

FWD REV  
 (Import) (Export)  
 SCH - NE - NY **700 MW 1300 MW**  
 Impacts Total Transfer Capability 700 MW 500 MW  
 TTC with All Lines In Service 1400 MW 1800 MW

-----  
**LONG\_MTN-PLSNTVLY\_345\_398**

Fri 03/01/2019 to Sun 05/19/2019 **UPDATED by CONED 11/28/2018**  
 0001 Continuous 2359

Work scheduled by: ConEd

FWD REV  
 (Import) (Export)  
 SCH - NPX\_1385 **100 MW 100 MW**  
 Impacts Total Transfer Capability 100 MW 100 MW  
 TTC with All Lines In Service 200 MW 200 MW

-----  
**EASTVIEW-SPRNBK\_\_345\_W64**

Mon 03/04/2019 to Mon 03/04/2019  
 0001 Continuous 0030

Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1350 MW  
 TTC with All Lines In Service 5700 MW

-----  
**MILLWOOD-EASTVIEW\_345\_W99**

Mon 03/04/2019 to Thu 03/07/2019  
 0001 Continuous 2359

Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1350 MW  
 TTC with All Lines In Service 5700 MW

-----  
**PLSNTVLY-EFISHKIL\_345\_F37**

Mon 03/04/2019 to Wed 03/06/2019 **UPDATED by CONED 11/28/2018**  
 0201 Continuous 0300

Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

-----  
**MOSES\_\_-ADIRNDCK\_230\_MAL**

Mon 03/04/2019 to Fri 03/08/2019  
 0700 Continuous 1500

Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,December 08, 2018 to Monday ,June 08, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>EASTVIEW-SPRNBK__345_W64</b>			FWD	
Thu 03/07/2019	to	Thu 03/07/2019	(Import)	
2330	Continuous	2359	UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	1350 MW
			TTC with All Lines In Service	5700 MW
<b>STLAWRNC-MOSES__230_L33P &amp; STLAWRNC-MOSES__230_L34P</b>			FWD	
Mon 03/11/2019	to	Mon 03/11/2019	(Import)	
0700		1530	MOSES SOUTH	<b>2700 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	450 MW
			TTC with All Lines In Service	3150 MW
<b>STLAWRNC-MOSES__230_L34P</b>			FWD	REV
Mon 03/11/2019	to	Mon 03/11/2019	(Import)	(Export)
0700	Continuous	1530	SCH - OH - NY	<b>1750 MW 1900 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	0 MW 100 MW
			TTC with All Lines In Service	1750 MW 2000 MW
<b>LEEDS__345_LEEDS SVC</b>			FWD	
Mon 03/11/2019	to	Fri 03/22/2019	(Import)	
0800	Continuous	1600	CENTRAL EAST - VC	<b>2950 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability	25 MW
			TTC with All Lines In Service	2975 MW
<b>MOSES__-ADIRNDCK_230_MAI</b>			FWD	
Tue 03/12/2019	to	Fri 03/15/2019	(Import)	
0700	Continuous	1500	MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW
			TTC with All Lines In Service	3150 MW
<b>MARCY__765_345_AT1</b>			FWD	
Mon 03/18/2019	to	Fri 03/22/2019	(Import)	
0500	Continuous	1530	MOSES SOUTH	<b>1750 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	1400 MW
			TTC with All Lines In Service	3150 MW
<b>MARCY__345KV_CSC</b>			FWD	
Mon 04/01/2019	to	Sun 04/07/2019	(Import)	
0500	Continuous	1730	CENTRAL EAST - VC	<b>2925 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	50 MW
			TTC with All Lines In Service	2975 MW

ARR: 19

# NYISO TRANSFER LIMITATIONS

Saturday ,December 08, 2018 to Monday ,June 08, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>VOLNEY -MARCY 345_19</b>				FWD	
Mon 04/01/2019	to	Wed 04/10/2019		(Import)	
0500	Continuous	1730		CENTRAL EAST - VC	<b>2825 MW</b>
Work scheduled by: NYPA			<b>ARR: 19</b>	Impacts Total Transfer Capability	150 MW
				TTC with All Lines In Service	2975 MW
<b>VOLNEY -MARCY 345_19</b>				FWD	
Mon 04/01/2019	to	Wed 04/10/2019		(Import)	
0500	Continuous	1730		OSWEGO EXPORT	<b>4900 MW</b>
Work scheduled by: NYPA			<b>ARR: 19</b>	Impacts Total Transfer Capability	350 MW
				TTC with All Lines In Service	5250 MW
<b>PLSNTVLY-EFISHKIL 345_F37</b>				FWD	
Thu 04/04/2019	to	Mon 04/08/2019	<b>UPDATED by CONED 11/28/2018</b>	(Import)	
0001	Continuous	0200		UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	1700 MW
				TTC with All Lines In Service	5700 MW
<b>DUNWODIE-MOTTHAVN 345_71</b>				FWD	
Fri 04/05/2019	to	Thu 05/09/2019		(Import)	
0001	Continuous	2359		SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
<b>NIAGARA -ROCHESTR 345_NR2</b>				FWD	
Fri 04/05/2019	to	Fri 04/05/2019		(Import)	
0500	Continuous	1700		DYSINGER EAST	<b>1700 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	1450 MW
				TTC with All Lines In Service	3150 MW
<b>LINDN_CG-LNDVFT 345_V-3022</b>				FWD	REV
Sun 04/07/2019	to	Fri 04/12/2019		(Import) (Export)	
1400	Continuous	1800		SCH - PJM_VFT	<b>0 MW 0 MW</b>
Work scheduled by: PJM				Impacts Total Transfer Capability	315 MW 315 MW
				TTC with All Lines In Service	315 MW 315 MW
<b>PLSNTVLY 345KV_RN5 &amp; PLSNTVLY 345KV_RN4</b>				FWD	
Mon 04/08/2019	to	Sat 04/13/2019		(Import)	
0001		0300		UPNY CONED	<b>3800 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	1900 MW
				TTC with All Lines In Service	5700 MW



# NYISO TRANSFER LIMITATIONS

Saturday ,December 08, 2018 to Monday ,June 08, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLE-DUNWODIE\_345\_W89

Mon 04/08/2019 to Fri 05/10/2019  
 0001 Continuous 2359  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

MARCY\_345KV\_CSC

Thu 04/11/2019 to Wed 04/17/2019  
 0500 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2925 MW**  
 Impacts Total Transfer Capability 50 MW  
 TTC with All Lines In Service 2975 MW

MARCY\_-EDIC\_345\_UE1-7

Thu 04/11/2019 to Sat 04/20/2019  
 0500 Continuous 1730  
 Work scheduled by: NYPA

**ARR: 19&16**

FWD  
 (Import)  
 OSWEGO EXPORT **5250 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 5250 MW

GILBOA\_-N.SCTLND\_345\_GNS-1

Fri 04/12/2019 to Fri 04/12/2019  
 1330 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2520 MW**  
 Impacts Total Transfer Capability 455 MW  
 TTC with All Lines In Service 2975 MW

EDIC\_-FRASER\_345\_EF24-40

Mon 04/22/2019 to Fri 04/26/2019  
 0500 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2500 MW**  
 Impacts Total Transfer Capability 475 MW  
 TTC with All Lines In Service 2975 MW

MARCY\_765\_345\_AT2

Mon 04/22/2019 to Fri 04/26/2019  
 0500 Continuous 1730  
 Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
 MOSES SOUTH **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

FRASANNX-COOPERS\_345\_UCC2-41

Mon 04/29/2019 to Fri 05/03/2019 **UPDATED by NYPA 08/22/2018**  
 0500 Continuous 1730  
 Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
 CENTRAL EAST - VC **2500 MW**  
 Impacts Total Transfer Capability 475 MW  
 TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,December 08, 2018 to Monday ,June 08, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY\_\_\_-FRASANNX\_345\_UCC2-41

FWD

Mon 04/29/2019 to Fri 05/03/2019  
0500 Continuous 1730

UPDATED by NYPA 08/22/2018

(Import)

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

MOSES\_\_\_-ADIRNDCK\_230\_MAI

FWD

Mon 04/29/2019 to Fri 05/03/2019  
0700 Continuous 1500

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

HUDSONTP-W49TH\_ST\_345\_Y56

FWD

Wed 05/01/2019 to Tue 05/07/2019  
0600 Continuous 1800

Work scheduled by: PJM

SCH - PJM\_HTP **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

KINTIGH\_-ROCHESTR\_345\_SR1-39

FWD

Mon 05/06/2019 to Fri 05/10/2019  
0600 Continuous 1700

UPDATED by NYSEG 11/08/2018

(Import)

Work scheduled by: NYPA

DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

ROSETON\_-ROCKTVRN\_345\_311

FWD

Mon 05/06/2019 to Sat 06/01/2019  
0800 Continuous 1600

Work scheduled by: CHGE

UPNY CONED **4400 MW**  
Impacts Total Transfer Capability 1300 MW  
TTC with All Lines In Service 5700 MW

NIAGARA\_-ROCHESTR\_345\_NR2

FWD

Mon 05/13/2019 to Fri 05/17/2019  
0600 Continuous 1700

Work scheduled by: NYPA

DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

ADIRNDCK-PORTER\_\_\_230\_12

FWD

Mon 05/20/2019 to Fri 05/24/2019  
0700 Continuous 1530

Work scheduled by: NYPA

MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,December 08, 2018 to Monday ,June 08, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PANNELL\_-CLAY\_\_\_\_\_345\_1

Mon 05/20/2019 to Fri 05/24/2019  
0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

PANNELL\_-CLAY\_\_\_\_\_345\_2

Mon 06/03/2019 to Fri 06/07/2019  
0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 06/24/2019 to Fri 06/28/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 07/08/2019 to Fri 07/12/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

ADIRNDCK-CHASLAKE\_230\_13

Mon 07/08/2019 to Fri 07/12/2019  
0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

MARCY\_\_\_\_\_765\_345\_AT2

Sat 08/03/2019 to Sun 08/04/2019  
0500 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

ARR: 19

MOSES\_\_\_-ADIRNDCK\_230\_MA1

Mon 08/12/2019 to Mon 08/12/2019  
0700 Continuous 1459

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

**UPDATED by NYPA 10/10/2018**

# NYISO TRANSFER LIMITATIONS

Saturday ,December 08, 2018 to Monday ,June 08, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARCY\_\_\_765\_345\_AT1**

Tue 09/03/2019 to Tue 09/03/2019  
0500 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
MOSES SOUTH **1750 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 3150 MW

**MARCY\_\_\_-N.SCTLND\_345\_18**

Wed 09/04/2019 to Wed 09/04/2019  
0500 Continuous 1730

Work scheduled by: NYPA

**UPDATED by NYPA 11/06/2018**

**ARR: 19**

FWD  
(Import)  
CENTRAL EAST - VC **2090 MW**  
Impacts Total Transfer Capability 885 MW  
TTC with All Lines In Service 2975 MW

**MARCY\_\_\_345KV\_CSC**

Wed 09/04/2019 to Wed 09/04/2019  
0500 Continuous 1730

Work scheduled by: NYPA

**UPDATED by NYPA 11/06/2018**

FWD  
(Import)  
CENTRAL EAST - VC **2925 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Wed 09/04/2019 to Wed 09/04/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

**ADIRNDCK-PORTER\_\_\_230\_12**

Wed 09/04/2019 to Wed 09/04/2019  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

**ADIRNDCK-CHASLAKE\_230\_13**

Thu 09/05/2019 to Thu 09/05/2019  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

**NIAGARA\_-ROCHESTR\_345\_NR2**

Mon 09/09/2019 to Sat 09/21/2019  
0500 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,December 08, 2018 to Monday ,June 08, 2020

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**LEEDS\_\_\_345KV\_R395**

Mon 09/09/2019 to Mon 09/09/2019  
0700 Continuous 0730

Work scheduled by: NYPA

FWD

(Import)

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1900 MW  
TTC with All Lines In Service 5700 MW

**GILBOA\_-LEEDS\_\_\_345\_GL3**

Mon 09/09/2019 to Fri 09/27/2019  
0700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC **2200 MW**  
Impacts Total Transfer Capability 775 MW  
TTC with All Lines In Service 2975 MW

**MARCY\_\_\_-N.SCTLND\_345\_18**

Wed 09/11/2019 to Fri 09/13/2019  
0500 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

FWD

(Import)

CENTRAL EAST - VC **2090 MW**  
Impacts Total Transfer Capability 885 MW  
TTC with All Lines In Service 2975 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Mon 09/16/2019 to Fri 09/20/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

**GOETHALS\_345KV\_5**

Fri 09/20/2019 to Tue 09/24/2019  
0001 Continuous 2359

Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**ROCHESTR-PANNELL\_\_\_345\_RP2**

Mon 09/23/2019 to Mon 09/30/2019  
0500 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**KINTIGH\_-ROCHESTR\_345\_SRL-39**

Mon 09/23/2019 to Fri 09/27/2019  
0600 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,December 08, 2018 to Monday ,June 08, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**SPRNBRK\_\_345KV\_RNS5**

Wed 09/25/2019 to Wed 09/25/2019  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

-----  
**SPRNBRK\_-W49TH\_ST\_345\_M51**

Wed 09/25/2019 to Sat 11/02/2019  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

-----  
**LEEDS\_\_345KV\_R395**

Fri 09/27/2019 to Fri 09/27/2019  
 1700 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 1900 MW  
 TTC with All Lines In Service 5700 MW

-----  
**CLAY\_\_-EDIC\_\_345\_1-16**

Mon 09/30/2019 to Fri 10/04/2019  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 OSWEGO EXPORT **4850 MW**  
 Impacts Total Transfer Capability 400 MW  
 TTC with All Lines In Service 5250 MW

-----  
**LEEDS\_\_-HURLYAVE\_345\_301**

Mon 09/30/2019 to Sat 10/26/2019  
 0800 Continuous 1600  
 Work scheduled by: CHGE

FWD  
 (Import)  
 UPNY CONED **4100 MW**  
 Impacts Total Transfer Capability 1600 MW  
 TTC with All Lines In Service 5700 MW

-----  
**CLAY\_\_-EDIC\_\_345\_2-15**

Mon 10/07/2019 to Thu 10/17/2019  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 OSWEGO EXPORT **4850 MW**  
 Impacts Total Transfer Capability 400 MW  
 TTC with All Lines In Service 5250 MW

-----  
**MARCY\_\_-N.SCTLND\_345\_18**

Wed 10/09/2019 to Fri 10/11/2019  
 0500 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2090 MW**  
 Impacts Total Transfer Capability 885 MW  
 TTC with All Lines In Service 2975 MW

ARR: 19

# NYISO TRANSFER LIMITATIONS

Saturday ,December 08, 2018 to Monday ,June 08, 2020

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**CHATGUAY-MASSENA\_\_765\_7040**

Sat 10/12/2019 to Sat 10/26/2019  
 0100 Continuous 1900

Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **1550 MW**  
 Impacts Total Transfer Capability 1600 MW  
 TTC with All Lines In Service 3150 MW

-----  
**CHATGUAY-MASSENA\_\_765\_7040**

Sat 10/12/2019 to Sat 10/26/2019  
 0100 Continuous 1900

Work scheduled by: NYPA

FWD REV  
 (Import) (Export)  
 SCH - HQ - NY **0 MW 0 MW**  
 Impacts Total Transfer Capability 1500 MW 1000 MW  
 TTC with All Lines In Service 1500 MW 1000 MW

-----  
**MARCY\_\_765\_345\_AT1**

Sat 10/12/2019 to Sat 10/26/2019  
 0100 Continuous 1900

Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
 MOSES SOUTH **1750 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 3150 MW

-----  
**MARCY\_\_765\_345\_AT2**

Sat 10/12/2019 to Sat 10/26/2019  
 0100 Continuous 1900

Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
 MOSES SOUTH **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

-----  
**MASSENA\_-MARCY\_\_765\_MSU1**

Sat 10/12/2019 to Sat 10/26/2019  
 0100 Continuous 1900

Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2265 MW**  
 Impacts Total Transfer Capability 710 MW  
 TTC with All Lines In Service 2975 MW

-----  
**MASSENA\_-MARCY\_\_765\_MSU1**

Sat 10/12/2019 to Sat 10/26/2019  
 0100 Continuous 1900

Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **500 MW**  
 Impacts Total Transfer Capability 2650 MW  
 TTC with All Lines In Service 3150 MW

-----  
**MASSENA\_-MARCY\_\_765\_MSU1**

Sat 10/12/2019 to Sat 10/26/2019  
 0100 Continuous 1900

Work scheduled by: NYPA

FWD REV  
 (Import) (Export)  
 SCH - HQ - NY **475 MW 1000 MW**  
 Impacts Total Transfer Capability 1025 MW 0 MW  
 TTC with All Lines In Service 1500 MW 1000 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,December 08, 2018 to Monday ,June 08, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MASSENA\_-MARCY\_ 765\_MSU1 & CHATGUAY-MASSENA\_ 765\_7040**

Sat 10/12/2019 to Sat 10/26/2019  
0100 1900

Work scheduled by:

FWD  
(Import)  
MOSES SOUTH **500 MW**  
Impacts Total Transfer Capability 2650 MW  
TTC with All Lines In Service 3150 MW

**MOSES\_-MASSENA\_ 230\_MMS1 & MOSES\_-MASSENA\_ 230\_MMS2**

Sat 10/12/2019 to Sat 10/26/2019  
0100 1900

Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - HQ - NY **850 MW 0 MW**  
Impacts Total Transfer Capability 650 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

**NIAGARA\_ 345\_230\_AT4**

Wed 10/23/2019 to Wed 12/18/2019  
0500 Continuous 1700

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **1900 MW 1400 MW**  
Impacts Total Transfer Capability 0 MW 350 MW  
TTC with All Lines In Service 1900 MW 1750 MW

**SPRNBRK\_ 345KV\_RNS5**

Sat 11/02/2019 to Sat 11/02/2019  
0130 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

**HURLYAVE-ROSETON\_ 345\_303**

Mon 11/04/2019 to Fri 12/06/2019  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 5700 MW

**PANNELL\_-CLAY\_ 345\_2**

Wed 11/06/2019 to Fri 11/22/2019  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

**MARCY\_-N.SCTLND\_ 345\_18**

Thu 11/07/2019 to Fri 11/08/2019  
0500 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2090 MW**  
Impacts Total Transfer Capability 885 MW  
TTC with All Lines In Service 2975 MW

**ARR: 19**



# NYISO TRANSFER LIMITATIONS

Saturday ,December 08, 2018 to Monday ,June 08, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY\_\_\_345KV\_CSC

Thu 11/07/2019 to Fri 11/08/2019  
0500 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2925 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

MOSES\_\_\_-ADIRNDCK\_230\_MA2

Tue 11/12/2019 to Fri 11/15/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 11/18/2019 to Fri 11/22/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 11/25/2019 to Wed 11/27/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 12/02/2019 to Fri 12/06/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

MOSES\_\_\_-ADIRNDCK\_230\_MA1

Mon 12/09/2019 to Fri 12/13/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 12/16/2019 to Mon 12/16/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,December 08, 2018 to Monday ,June 08, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

Tue 12/17/2019 to Fri 12/20/2019  
 0700 Continuous 1500

Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

-----  
**LADENTWN-BUCHAN\_S\_345\_Y88**

Wed 01/15/2020 to Thu 02/13/2020  
 0001 Continuous 2359

Work scheduled by: ORU

11/05/2018

FWD  
 (Import)  
 UPNY CONED **4800 MW**  
 Impacts Total Transfer Capability 900 MW  
 TTC with All Lines In Service 5700 MW

-----  
**FRASANNX-COOPERS\_\_345\_UCC2-41**

Mon 04/27/2020 to Sun 05/31/2020  
 0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
 CENTRAL EAST - VC **2500 MW**  
 Impacts Total Transfer Capability 475 MW  
 TTC with All Lines In Service 2975 MW

-----  
**MARCY\_\_\_-FRASANNX\_345\_UCC2-41**

Mon 04/27/2020 to Sun 05/31/2020  
 0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
 CENTRAL EAST - VC **2500 MW**  
 Impacts Total Transfer Capability 475 MW  
 TTC with All Lines In Service 2975 MW