

NYISO TRANSFER LIMITATIONS

Monday ,December 10, 2018 to Wednesday,June 10, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
HUDSONP_-FARRAGUT_345_B3402							
Mon 01/15/2018	to	Mon 04/01/2019	<u>EXT FORCE</u>	<u>by CONED</u>	<u>12/02/2018</u>		
0001	Continuous	2359				SCH - PJ - NY	2600 MW 1300 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	0 MW 250 MW
						TTC with All Lines In Service	2600 MW 1550 MW
HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403							
Mon 01/15/2018	to	Mon 04/01/2019				SCH - PJ - NY	2000 MW 1300 MW
0001		2359				Impacts Total Transfer Capability	600 MW 250 MW
Work scheduled by:						TTC with All Lines In Service	2600 MW 1550 MW
MARION_-FARRAGUT_345_C3403							
Mon 01/15/2018	to	Mon 04/01/2019	<u>EXT FORCE</u>	<u>by CONED</u>	<u>12/02/2018</u>		
0001	Continuous	2359				SCH - PJ - NY	2600 MW 1300 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	0 MW 250 MW
						TTC with All Lines In Service	2600 MW 1550 MW
STLAWRNC-MOSES____230_L33P							
Mon 04/30/2018	to	Fri 12/31/2021	<u>EXT FORCE</u>	<u>by IESO</u>	<u>08/21/2018</u>		
0456	Continuous	2359				SCH - OH - NY	1750 MW 1900 MW
Work scheduled by: IESO						Impacts Total Transfer Capability	0 MW 100 MW
						TTC with All Lines In Service	1750 MW 2000 MW
DUNWODIE_345KV_6							
Mon 10/22/2018	to	Sat 12/22/2018	<u>UPDATED</u>	<u>by CE</u>	<u>10/04/2018</u>		
0301	Continuous	0200				SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_8							
Mon 10/22/2018	to	Sat 12/22/2018	<u>UPDATED</u>	<u>by CE</u>	<u>10/04/2018</u>		
0301	Continuous	0200				SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
PLSNTVLE-DUNWODIE_345_W90							
Mon 10/22/2018	to	Sat 12/22/2018	<u>UPDATED</u>	<u>by CE</u>	<u>10/04/2018</u>		
0301	Continuous	0200				UPNY CONED	4000 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	1700 MW
						TTC with All Lines In Service	5700 MW

NYISO TRANSFER LIMITATIONS

Monday ,December 10, 2018 to Wednesday,June 10, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
S.RIPLEY-DUNKIRK__230_68							
Mon 10/22/2018	to	Tue 12/18/2018	EXTENDED	by PJM	12/10/2018		
0800	Continuous	2000				SCH - PJ - NY	2600 MW
Work scheduled by: PJM						Impacts Total Transfer Capability	0 MW
						TTC with All Lines In Service	2600 MW
							1550 MW
SCH-IMO-NYISO_LIMIT_1400							
						FWD	
						(Import)	
Thu 11/01/2018	to	Fri 12/07/2018				SCH - OH - NY	1700 MW
0001	Continuous	2359				Impacts Total Transfer Capability	50 MW
Work scheduled by: IESO						TTC with All Lines In Service	1750 MW
SCH-NYISO-IMO_LIMIT_1600							
							REV
							(Export)
Thu 11/01/2018	to	Fri 12/07/2018				SCH - OH - NY	1900 MW
0001	Continuous	2359				Impacts Total Transfer Capability	100 MW
Work scheduled by: IESO						TTC with All Lines In Service	2000 MW
SCH-IMO-NYISO_LIMIT_1300							
						FWD	
						(Import)	
Thu 11/15/2018	to	Thu 12/20/2018	UPDATED	by NYPA	11/20/2018	SCH - OH - NY	1600 MW
0500	Continuous	2359				Impacts Total Transfer Capability	150 MW
Work scheduled by: NYPA						TTC with All Lines In Service	1750 MW
SHOR_NPX-SHOREHAM_138_CSC							
						FWD	REV
						(Import)	(Export)
Mon 11/26/2018	to	Fri 12/07/2018				SCH - NPX_CSC	0 MW
0700	Continuous	1600				Impacts Total Transfer Capability	330 MW
Work scheduled by: LI						TTC with All Lines In Service	330 MW
HURLYAVE-ROSETON__345_303							
						FWD	
						(Import)	
Mon 11/26/2018	to	Fri 12/21/2018				UPNY CONED	4100 MW
0800	Continuous	1600				Impacts Total Transfer Capability	1600 MW
Work scheduled by: CHGE						TTC with All Lines In Service	5700 MW
HOMR_NYW-PIERC_NY_345_48							
						FWD	REV
						(Import)	(Export)
Wed 11/28/2018	to	Wed 12/05/2018	EXT FORCE	by PJM	11/30/2018	SCH - PJ - NY	2500 MW
1305	Continuous	1600				Impacts Total Transfer Capability	100 MW
Work scheduled by: PJM						TTC with All Lines In Service	2600 MW
							1550 MW

NYISO TRANSFER LIMITATIONS

Monday ,December 10, 2018 to Wednesday,June 10, 2020

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-HQ_LIMIT_800

Thu 11/29/2018 to Mon 12/10/2018
 2001 Continuous 1800
 Work scheduled by: HQ

SCH - HQ - NY
 Impacts Total Transfer Capability 200 MW
 TTC with All Lines In Service 1000 MW

REV
 (Export)

800 MW

DUNWODIE-MOTTHAVN_345_72

Sun 12/02/2018 to Fri 12/07/2018 **EXTENDED** **by CONED** **12/05/2018**
 0001 Continuous 0159
 Work scheduled by: ConEd

SPR/DUN-SOUTH
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

FWD
 (Import)

3800 MW

DUNWODIE_345KV_7

Sun 12/02/2018 to Fri 12/07/2018 **EXTENDED** **by CONED** **12/05/2018**
 0001 Continuous 0159
 Work scheduled by: ConEd

SPR/DUN-SOUTH
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

FWD
 (Import)

3800 MW

BECK__-NIAGARA_345_PA302

Mon 12/03/2018 to Wed 12/05/2018
 0500 Continuous 1900
 Work scheduled by: NYPA

SCH - OH - NY
 Impacts Total Transfer Capability 650 MW 1050 MW
 TTC with All Lines In Service 1750 MW 2000 MW

FWD REV
 (Import) (Export)

1100 MW 950 MW

MOSES__-ADIRNDCK_230_MA2

Mon 12/03/2018 to Fri 12/07/2018
 0700 Continuous 1530
 Work scheduled by: NYPA

MOSES SOUTH
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

FWD
 (Import)

2300 MW

DUNWODIE-SHORE_RD_345_Y50

Fri 12/07/2018 to Thu 12/13/2018 **UPDATED** **by CONED** **12/05/2018**
 0201 Continuous 0200
 Work scheduled by: ConEd

CONED - LIPA
 Impacts Total Transfer Capability 700 MW
 TTC with All Lines In Service 1500 MW

FWD
 (Import)

800 MW

DUNWODIE_345KV_4

Fri 12/07/2018 to Thu 12/13/2018 **UPDATED** **by CONED** **12/05/2018**
 0201 Continuous 0200
 Work scheduled by: ConEd

SPR/DUN-SOUTH
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

FWD
 (Import)

3800 MW

NYISO TRANSFER LIMITATIONS

Monday ,December 10, 2018 to Wednesday, June 10, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					FWD
SHORE_RD_345_138_BK 1					(Import)
Fri 12/07/2018	to	Thu 12/13/2018	<u>UPDATED</u>	<u>by CONED</u>	<u>12/05/2018</u>
0201	Continuous	0200			
Work scheduled by: ConEd					CONED - LIPA 1350 MW
					Impacts Total Transfer Capability 150 MW
					TTC with All Lines In Service 1500 MW
<hr/>					FWD
SHORE_RD_345_138_BK 2					(Import)
Fri 12/07/2018	to	Thu 12/13/2018	<u>UPDATED</u>	<u>by CONED</u>	<u>12/05/2018</u>
0201	Continuous	0200			
Work scheduled by: ConEd					CONED - LIPA 1350 MW
					Impacts Total Transfer Capability 150 MW
					TTC with All Lines In Service 1500 MW
<hr/>					FWD REV
NRTH1385-NOR HBR_138_602					(Import) (Export)
Sat 12/08/2018	to	Sat 12/08/2018			
0700	Continuous	1100			
Work scheduled by: LI					SCH - NPX_1385 100 MW 100 MW
					Impacts Total Transfer Capability 100 MW 100 MW
					TTC with All Lines In Service 200 MW 200 MW
<hr/>					FWD
CHATGUAY-MASSENA_765_7040					(Import)
Sat 12/08/2018	to	Sat 12/08/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>11/16/2018</u>
0700	Continuous	2300			
Work scheduled by: HQ					MOSES SOUTH 1550 MW
					Impacts Total Transfer Capability 1600 MW
					TTC with All Lines In Service 3150 MW
<hr/>					FWD REV
CHATGUAY-MASSENA_765_7040					(Import) (Export)
Sat 12/08/2018	to	Sat 12/08/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>11/16/2018</u>
0700	Continuous	2300			
Work scheduled by: HQ					SCH - HQ - NY 0 MW 0 MW
					Impacts Total Transfer Capability 1500 MW 1000 MW
					TTC with All Lines In Service 1500 MW 1000 MW
<hr/>					FWD REV
BROWNFLS-TAYLORVL_115_4					(Import) (Export)
Sat 12/08/2018	to	Sat 12/08/2018			
0800	Continuous	1600			
Work scheduled by: NGrid					SCH - HQ_CEDARS 100 MW 100 MW
					Impacts Total Transfer Capability 99 MW 0 MW
					TTC with All Lines In Service 199 MW 100 MW
<hr/>					FWD REV
CEDARS_-ROSEMNTB_115_2/22					(Import) (Export)
Sat 12/08/2018	to	Sat 12/08/2018	<u>CANCELLED</u>	<u>by HQ</u>	<u>12/08/2018</u>
0800	Continuous	1600			
Work scheduled by: HQ					SCH - HQ_CEDARS 95 MW 100 MW
					Impacts Total Transfer Capability 104 MW 0 MW
					TTC with All Lines In Service 199 MW 100 MW

NYISO TRANSFER LIMITATIONS

Monday ,December 10, 2018 to Wednesday,June 10, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DENNISON-ROSEMNTB_115_2/22					FWD	REV
Sat 12/08/2018	to	Sat 12/08/2018	CANCELLED by HQ	12/08/2018	(Import)	(Export)
0800	Continuous	1600			95 MW	100 MW
Work scheduled by: HQ					SCH - HQ_CEDARS	
					Impacts Total Transfer Capability	104 MW
					TTC with All Lines In Service	199 MW
					ARR: 38	100 MW
<hr/>						
SCH-NYISO-HQ_CEDARS_LIMIT_0						REV
Sat 12/08/2018	to	Sat 12/08/2018	CANCELLED by HQ	12/08/2018		(Export)
0800	Continuous	1600			0 MW	
Work scheduled by: HQ					SCH - HQ_CEDARS	
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	100 MW
<hr/>						
CLRKSCRN-OAKDALE__345_36					FWD	
Sun 12/09/2018	to	Sun 12/09/2018			(Import)	
0700	Continuous	1600			2650 MW	
Work scheduled by: NYSEG					CENTRAL EAST - VC	
					Impacts Total Transfer Capability	325 MW
					TTC with All Lines In Service	2975 MW
<hr/>						
BROWNFLS-TAYLORVL_115_3					FWD	REV
Sun 12/09/2018	to	Sun 12/09/2018			(Import)	(Export)
0700	Continuous	1700			100 MW	100 MW
Work scheduled by: NGrid					SCH - HQ_CEDARS	
					Impacts Total Transfer Capability	99 MW
					TTC with All Lines In Service	199 MW
					ARR: 38	100 MW
<hr/>						
BROWNFLS-TAYLORVL_115_3 & TAYLORVL-LOWVILLE_115_5 & CLIMAX_-TAYLORVL_115_8					FWD	REV
Sun 12/09/2018	to	Sun 12/09/2018			(Import)	(Export)
0700		1700			120 MW	100 MW
Work scheduled by:					SCH - HQ_CEDARS	
					Impacts Total Transfer Capability	79 MW
					TTC with All Lines In Service	199 MW
					ARR: 38	100 MW
<hr/>						
TAYLORVL-LOWVILLE_115_5					FWD	REV
Sun 12/09/2018	to	Sun 12/09/2018			(Import)	(Export)
0700	Continuous	1700			199 MW	100 MW
Work scheduled by: NGrid					SCH - HQ_CEDARS	
					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	199 MW
					ARR: 38	100 MW
<hr/>						
SCH-IMO-NYISO_LIMIT_900					FWD	
Mon 12/10/2018	to	Tue 12/11/2018			(Import)	
0600	Continuous	1200			1200 MW	
Work scheduled by: NGrid					SCH - OH - NY	
					Impacts Total Transfer Capability	550 MW
					TTC with All Lines In Service	1750 MW

NYISO TRANSFER LIMITATIONS

Monday ,December 10, 2018 to Wednesday,June 10, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FIVEMILE-STOLLERD_345_29		FWD	REV
		(Import)	(Export)
Mon 12/10/2018	to Wed 12/12/2018		
0700	Continuous 1555	SCH - PJ - NY	2600 MW 1300 MW
Work scheduled by: NGrid		Impacts Total Transfer Capability	0 MW 250 MW
		TTC with All Lines In Service	2600 MW 1550 MW
MOSES__-ADIRNDCK_230_MA2		FWD	
		(Import)	
Mon 12/10/2018	to Fri 12/14/2018		
0700	Continuous 1530	MOSES SOUTH	2300 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	850 MW
		TTC with All Lines In Service	3150 MW
SCH-IMO-NYISO_LIMIT_1000		FWD	
		(Import)	
Tue 12/11/2018	to Tue 12/11/2018	CANCELLED by NGrid 12/10/2018	
0800	Daily(No Weekends) 1600	SCH - OH - NY	1300 MW
Work scheduled by: NGrid		Impacts Total Transfer Capability	450 MW
		TTC with All Lines In Service	1750 MW
HOMR_NYW-PIERC_NY_345_48		FWD	REV
		(Import)	(Export)
Tue 12/11/2018	to Tue 12/11/2018	CANCELLED by PJM 12/10/2018	
1200	Continuous 1600	SCH - PJ - NY	2500 MW 1300 MW
Work scheduled by: PJM		Impacts Total Transfer Capability	100 MW 250 MW
		TTC with All Lines In Service	2600 MW 1550 MW
LEEDS__-HURLYAVE_345_301		FWD	
		(Import)	
Wed 12/12/2018	to Wed 12/12/2018		
0800	Continuous 1400	UPNY CONED	4100 MW
Work scheduled by: CHGE		Impacts Total Transfer Capability	1600 MW
		TTC with All Lines In Service	5700 MW
SCH-IMO-NYISO_LIMIT_1000		FWD	
		(Import)	
Wed 12/12/2018	to Wed 12/12/2018	12/10/2018	
0800	Continuous 1600	SCH - OH - NY	1300 MW
Work scheduled by: NGrid		Impacts Total Transfer Capability	450 MW
		TTC with All Lines In Service	1750 MW
WOOD_ST_-PLSNTVLE_345_Y87		FWD	
		(Import)	
Mon 12/17/2018	to Mon 01/28/2019	UPDATED by CE 10/04/2018	
0001	Continuous 0200	UPNY CONED	4000 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability	1700 MW
		TTC with All Lines In Service	5700 MW

NYISO TRANSFER LIMITATIONS

Monday ,December 10, 2018 to Wednesday,June 10, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
MARCY___345KV_CSC			FWD
Mon 12/17/2018	to	Tue 12/18/2018	(Import)
0500	Continuous	1730	
Work scheduled by: NYPA			
		CENTRAL EAST - VC	2925 MW
		Impacts Total Transfer Capability	50 MW
		TTC with All Lines In Service	2975 MW
<hr/>			
MARCY___765_345_AT2			FWD
Mon 12/17/2018	to	Fri 12/21/2018	(Import)
0500	Continuous	1730	
Work scheduled by: NYPA		UPDATED by NYPA 11/09/2018	
		MOSES SOUTH	1700 MW
		Impacts Total Transfer Capability	1450 MW
		TTC with All Lines In Service	3150 MW
<hr/>			
SCRIBA_-VOLNEY___345_21			FWD
Mon 12/17/2018	to	Wed 12/19/2018	(Import)
0600	Continuous	1730	
Work scheduled by: NGrid		UPDATED by NGRID 12/07/2018	
		OSWEGO EXPORT	5250 MW
		Impacts Total Transfer Capability	0 MW
		TTC with All Lines In Service	5250 MW
<hr/>			
SCH-IMO-NYISO_LIMIT_850			FWD
Mon 12/17/2018	to	Fri 12/21/2018	(Import)
0800	Continuous	1600	
Work scheduled by: IESO			
		SCH - OH - NY	1150 MW
		Impacts Total Transfer Capability	600 MW
		TTC with All Lines In Service	1750 MW
<hr/>			
SCH-NYISO-IMO_LIMIT_900			REV
Mon 12/17/2018	to	Fri 12/21/2018	(Export)
0800	Continuous	1600	
Work scheduled by: IESO			
		SCH - OH - NY	1200 MW
		Impacts Total Transfer Capability	800 MW
		TTC with All Lines In Service	2000 MW
<hr/>			
SPRNBRK___345KV_RNS5			FWD
Tue 12/18/2018	to	Tue 12/18/2018	(Import)
0001	Continuous	0030	
Work scheduled by: ConEd			
		SPR/DUN-SOUTH	3200 MW
		Impacts Total Transfer Capability	1400 MW
		TTC with All Lines In Service	4600 MW
<hr/>			
SPRNBRK_-W49TH_ST_345_M51			FWD
Tue 12/18/2018	to	Wed 12/19/2018	(Import)
0001	Continuous	0200	
Work scheduled by: ConEd			
		SPR/DUN-SOUTH	3200 MW
		Impacts Total Transfer Capability	1400 MW
		TTC with All Lines In Service	4600 MW
<hr/>			

NYISO TRANSFER LIMITATIONS

Monday ,December 10, 2018 to Wednesday,June 10, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STLAWRNC-MOSES 230_L33P & STLAWRNC-MOSES 230_L34P			FWD
Tue 12/18/2018	to	Tue 12/18/2018	(Import)
0800		1600	MOSES SOUTH 2700 MW
Work scheduled by:			Impacts Total Transfer Capability 450 MW
			TTC with All Lines In Service 3150 MW
SCH-IMO-NYISO_LIMIT_700			FWD
Tue 12/18/2018	to	Wed 12/19/2018	(Import)
0800	Daily	1600	SCH - OH - NY 1000 MW
Work scheduled by: IESO			Impacts Total Transfer Capability 750 MW
			TTC with All Lines In Service 1750 MW
SCH-NYISO-IMO_LIMIT_700			REV
Tue 12/18/2018	to	Wed 12/19/2018	(Export)
0800	Daily	1600	SCH - OH - NY 1000 MW
Work scheduled by: IESO			Impacts Total Transfer Capability 1000 MW
			TTC with All Lines In Service 2000 MW
STLAWRNC-MOSES 230_L34P			FWD REV
Tue 12/18/2018	to	Wed 12/19/2018	(Import) (Export)
0800	Daily	1600	SCH - OH - NY 1750 MW 1900 MW
Work scheduled by: IESO			Impacts Total Transfer Capability 0 MW 100 MW
			TTC with All Lines In Service 1750 MW 2000 MW
SPRNBK_345KV_RNS5			FWD
Wed 12/19/2018	to	Wed 12/19/2018	(Import)
0130	Continuous	0200	SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 1400 MW
			TTC with All Lines In Service 4600 MW
STLAWRNC-MOSES 230_L33P & STLAWRNC-MOSES 230_L34P			FWD
Wed 12/19/2018	to	Wed 12/19/2018	(Import)
0800		1600	MOSES SOUTH 2700 MW
Work scheduled by:			Impacts Total Transfer Capability 450 MW
			TTC with All Lines In Service 3150 MW
HOMR_NYW-PIERC_NY_345_48			FWD REV
Fri 12/21/2018	to	Fri 12/21/2018	(Import) (Export)
1200	Continuous	1600	SCH - PJ - NY 2500 MW 1300 MW
Work scheduled by: PJM			Impacts Total Transfer Capability 100 MW 250 MW
			TTC with All Lines In Service 2600 MW 1550 MW

NYISO TRANSFER LIMITATIONS

Monday ,December 10, 2018 to Wednesday,June 10, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASANX-COOPERS__345_UCC2-41

Sat 12/22/2018 to Wed 12/26/2018
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

MARCY__-FRASANX_345_UCC2-41

Sat 12/22/2018 to Wed 12/26/2018
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

EDIC__-FRASER__345_EF24-40

Thu 12/27/2018 to Mon 12/31/2018
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

SPRNBRK__345KV_RS3 & SPRNBRK__345KV_RS4

Tue 01/01/2019 to Wed 01/02/2019
0001 0200

Work scheduled by:

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

EFISHKIL-WOOD_ST__345_F39

Wed 01/02/2019 to Wed 01/02/2019
0001 Continuous 0030

Work scheduled by: ConEd

UPDATED by CE 10/04/2018

FWD
(Import)
UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1700 MW
TTC with All Lines In Service 5700 MW

MOSES__-ADIRNDCK_230_MA2

Wed 01/02/2019 to Fri 01/04/2019
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

HURLYAVE-ROSETON__345_303

Wed 01/02/2019 to Fri 01/11/2019
0800 Continuous 1600

Work scheduled by: CHGE

08/20/2018

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 1600 MW
TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Monday ,December 10, 2018 to Wednesday,June 10, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EFISHKIL-WOOD_ST__345_F39				FWD	
Thu 01/03/2019	to	Thu 01/03/2019	<u>UPDATED</u> <u>by CE</u> <u>10/04/2018</u>	(Import)	
0230	Continuous	0300		UPNY CONED	4000 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	1700 MW
				TTC with All Lines In Service	5700 MW
SCH-NE-NYISO_LIMIT_1100				FWD	
Mon 01/07/2019	to	Thu 01/10/2019		(Import)	
0700	Continuous	1600		SCH - NE - NY	1300 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	1400 MW
MOSES__-ADIRNDCK_230_MA1				FWD	
Mon 01/07/2019	to	Fri 01/11/2019		(Import)	
0700	Continuous	1500		MOSES SOUTH	2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
BECK__-PACKARD_230_BP76				FWD	REV
Tue 01/08/2019	to	Sat 01/12/2019		(Import)	(Export)
0700	Continuous	1700		SCH - OH - NY	1700 MW 1500 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	50 MW 500 MW
				TTC with All Lines In Service	1750 MW 2000 MW
BECK__-PACKARD_230_BP76 & STLAWRNC-MOSES__230_L33P				FWD	REV
Tue 01/08/2019	to	Sat 01/12/2019		(Import)	(Export)
0700		1700		SCH - OH - NY	900 MW 1150 MW
Work scheduled by:				Impacts Total Transfer Capability	850 MW 850 MW
				TTC with All Lines In Service	1750 MW 2000 MW
BECK__-PACKARD_230_BP76				FWD	REV
Wed 01/09/2019	to	Wed 01/09/2019	<u>CANCELLED</u> <u>by NGrid</u> <u>12/07/2018</u>	(Import)	(Export)
0800	Daily(No Weekends)	1500		SCH - OH - NY	1700 MW 1500 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	50 MW 500 MW
				TTC with All Lines In Service	1750 MW 2000 MW
SPRNBRK_-TREMONT__345_X28				FWD	
Mon 01/14/2019	to	Mon 01/14/2019		(Import)	
0001	Continuous	0100		SPR/DUN-SOUTH	4200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	400 MW
				TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Monday ,December 10, 2018 to Wednesday,June 10, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA2

Mon 01/14/2019 to Fri 01/18/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

LEEDS___-HURLYAVE_345_301

Mon 01/14/2019 to Fri 01/25/2019
0800 Continuous 1600

Work scheduled by: CHGE

08/20/2018

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 1600 MW
TTC with All Lines In Service 5700 MW

SPRNBK_-TREMONT__345_X28

Fri 01/18/2019 to Fri 01/18/2019
2200 Continuous 2300

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **4200 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_6

Mon 01/21/2019 to Mon 01/28/2019
0001 Continuous 0200

Work scheduled by: ConEd

UPDATED by CE 10/04/2018

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_8

Mon 01/21/2019 to Mon 01/28/2019
0001 Continuous 0200

Work scheduled by: ConEd

UPDATED by CE 10/04/2018

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

PLSNTVLE-DUNWODIE_345_W90

Mon 01/21/2019 to Mon 01/28/2019
0001 Continuous 0200

Work scheduled by: ConEd

UPDATED by CE 10/04/2018

FWD
(Import)
UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1700 MW
TTC with All Lines In Service 5700 MW

MOSES___-ADIRNDCK_230_MA2

Mon 01/21/2019 to Fri 01/25/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Monday ,December 10, 2018 to Wednesday,June 10, 2020

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES__-ADIRNDCK_230_MA1

Mon 01/28/2019 to Fri 02/01/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

LEEDS__-HURLYAVE_345_301

Mon 01/28/2019 to Fri 02/08/2019
0800 Continuous 1600

Work scheduled by: CHGE

11/13/2018

FWD

(Import)

UPNY CONED **4100 MW**
Impacts Total Transfer Capability 1600 MW
TTC with All Lines In Service 5700 MW

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4

Tue 01/29/2019 to Sun 02/03/2019
0001 0300

Work scheduled by:

FWD

(Import)

UPNY CONED **3800 MW**
Impacts Total Transfer Capability 1900 MW
TTC with All Lines In Service 5700 MW

PLSNTVLY-EFISHKIL_345_F36

Sun 02/03/2019 to Wed 02/06/2019
0301 Continuous 0300

Work scheduled by: ConEd

UPDATED by CONED 11/21/2018

FWD

(Import)

UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1700 MW
TTC with All Lines In Service 5700 MW

MOSES__-ADIRNDCK_230_MA2

Mon 02/04/2019 to Thu 02/07/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4

Wed 02/06/2019 to Wed 02/06/2019
0330 0400

Work scheduled by:

FWD

(Import)

UPNY CONED **3800 MW**
Impacts Total Transfer Capability 1900 MW
TTC with All Lines In Service 5700 MW

EASTVIEW-SPRNBK__345_W79

Thu 02/07/2019 to Thu 02/07/2019
0001 Continuous 0030

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1350 MW
TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Monday ,December 10, 2018 to Wednesday,June 10, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BUCHAN_N-EASTVIEW_345_W93

Thu 02/07/2019 to Fri 02/08/2019
 0001 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

ADIRNDCK-CHASLAKE_230_13

Thu 02/07/2019 to Thu 02/07/2019
 0800 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

EASTVIEW-SPRNBK_345_W79

Fri 02/08/2019 to Fri 02/08/2019
 0230 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

MOSES__-ADIRNDCK_230_MA1

Fri 02/08/2019 to Fri 02/08/2019
 0800 Continuous 1500
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MOSES__-ADIRNDCK_230_MA2

Mon 02/11/2019 to Fri 02/15/2019
 0700 Continuous 1500
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MOSES__-ADIRNDCK_230_MA2

Tue 02/19/2019 to Fri 02/22/2019
 0700 Continuous 1500
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MOSES__-ADIRNDCK_230_MA1

Mon 02/25/2019 to Fri 03/01/2019
 0700 Continuous 1500
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Monday ,December 10, 2018 to Wednesday,June 10, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4

Fri 03/01/2019 to Mon 03/04/2019
0001 0200

Work scheduled by:

FWD
(Import)
UPNY CONED **3800 MW**
Impacts Total Transfer Capability 1900 MW
TTC with All Lines In Service 5700 MW

LONG_MTN-PLSNTVLY_345_398

Fri 03/01/2019 to Sun 05/19/2019 UPDATED by CONED 11/28/2018
0001 Continuous 2359

Work scheduled by: ConEd

FWD REV
(Import) (Export)
SCH - NE - NY **700 MW 1300 MW**
Impacts Total Transfer Capability 700 MW 500 MW
TTC with All Lines In Service 1400 MW 1800 MW

LONG_MTN-PLSNTVLY_345_398

Fri 03/01/2019 to Sun 05/19/2019 UPDATED by CONED 11/28/2018
0001 Continuous 2359

Work scheduled by: ConEd

FWD REV
(Import) (Export)
SCH - NPX_1385 **100 MW 100 MW**
Impacts Total Transfer Capability 100 MW 100 MW
TTC with All Lines In Service 200 MW 200 MW

EASTVIEW-SPRNBK__345_W64

Mon 03/04/2019 to Mon 03/04/2019
0001 Continuous 0030

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1350 MW
TTC with All Lines In Service 5700 MW

MILLWOOD-EASTVIEW_345_W99

Mon 03/04/2019 to Thu 03/07/2019
0001 Continuous 2359

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1350 MW
TTC with All Lines In Service 5700 MW

PLSNTVLY-EFISHKIL_345_F37

Mon 03/04/2019 to Wed 03/06/2019 UPDATED by CONED 11/28/2018
0201 Continuous 0300

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1700 MW
TTC with All Lines In Service 5700 MW

MOSES__-ADIRNDCK_230_MAL

Mon 03/04/2019 to Fri 03/08/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Monday ,December 10, 2018 to Wednesday,June 10, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EASTVIEW-SPRNBRK__345_W64

Thu 03/07/2019 to Thu 03/07/2019
 2330 Continuous 2359
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

STLAWRNC-MOSES__230_L33P & STLAWRNC-MOSES__230_L34P

Mon 03/11/2019 to Mon 03/11/2019
 0700 1530
 Work scheduled by:

FWD
 (Import)
 MOSES SOUTH **2700 MW**
 Impacts Total Transfer Capability 450 MW
 TTC with All Lines In Service 3150 MW

STLAWRNC-MOSES__230_L34P

Mon 03/11/2019 to Mon 03/11/2019
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD REV
 (Import) (Export)
 SCH - OH - NY **1750 MW 1900 MW**
 Impacts Total Transfer Capability 0 MW 100 MW
 TTC with All Lines In Service 1750 MW 2000 MW

LEEDS__345_LEEDS SVC

Mon 03/11/2019 to Fri 03/22/2019
 0800 Continuous 1600
 Work scheduled by: NGrid

FWD
 (Import)
 CENTRAL EAST - VC **2950 MW**
 Impacts Total Transfer Capability 25 MW
 TTC with All Lines In Service 2975 MW

MOSES__-ADIRNDCK_230_MAI

Tue 03/12/2019 to Fri 03/15/2019
 0700 Continuous 1500
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MARCY__765_345_AT1

Mon 03/18/2019 to Fri 03/22/2019
 0500 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **1750 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 3150 MW

ARR: 19

MARCY__345KV_CSC

Mon 04/01/2019 to Sun 04/07/2019
 0500 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2925 MW**
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Monday ,December 10, 2018 to Wednesday,June 10, 2020

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

VOLNEY -MARCY 345_19				FWD	
Mon 04/01/2019	to	Wed 04/10/2019		(Import)	
0500	Continuous	1730	CENTRAL EAST - VC	2825 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	150 MW	
			TTC with All Lines In Service	2975 MW	
VOLNEY -MARCY 345_19				FWD	
Mon 04/01/2019	to	Wed 04/10/2019		(Import)	
0500	Continuous	1730	OSWEGO EXPORT	4900 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	350 MW	
			TTC with All Lines In Service	5250 MW	
PLSNTVLY-EFISHKIL 345_F37				FWD	
Thu 04/04/2019	to	Mon 04/08/2019	<u>UPDATED</u> <u>by CONED</u> <u>11/28/2018</u>	(Import)	
0001	Continuous	0200	UPNY CONED	4000 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	1700 MW	
			TTC with All Lines In Service	5700 MW	
DUNWODIE-MOTTHAVN 345_71				FWD	
Fri 04/05/2019	to	Thu 05/09/2019		(Import)	
0001	Continuous	2359	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
NIAGARA -ROCHESTR 345_NR2				FWD	
Fri 04/05/2019	to	Fri 04/05/2019		(Import)	
0500	Continuous	1700	DYSINGER EAST	1700 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1450 MW	
			TTC with All Lines In Service	3150 MW	
LINDN_CG-LNDVFT 345_V-3022				FWD	REV
Sun 04/07/2019	to	Fri 04/12/2019		(Import)	(Export)
1400	Continuous	1800	SCH - PJM_VFT	0 MW	0 MW
Work scheduled by: PJM			Impacts Total Transfer Capability	315 MW	315 MW
			TTC with All Lines In Service	315 MW	315 MW
PLSNTVLY 345KV_RN5 & PLSNTVLY 345KV_RN4				FWD	
Mon 04/08/2019	to	Sat 04/13/2019		(Import)	
0001		0300	UPNY CONED	3800 MW	
Work scheduled by:			Impacts Total Transfer Capability	1900 MW	
			TTC with All Lines In Service	5700 MW	

NYISO TRANSFER LIMITATIONS

Monday ,December 10, 2018 to Wednesday,June 10, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLE-DUNWODIE_345_W89

Mon 04/08/2019 to Fri 05/10/2019
 0001 Continuous 2359
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 1700 MW
 TTC with All Lines In Service 5700 MW

MARCY_345KV_CSC

Thu 04/11/2019 to Wed 04/17/2019
 0500 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2925 MW**
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 2975 MW

MARCY_-EDIC_345_UE1-7

Thu 04/11/2019 to Sat 04/20/2019
 0500 Continuous 1730
 Work scheduled by: NYPA

ARR: 19&16

FWD
 (Import)
 OSWEGO EXPORT **5250 MW**
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 5250 MW

GILBOA_-N.SCTLND_345_GNS-1

Fri 04/12/2019 to Fri 04/12/2019
 1330 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2520 MW**
 Impacts Total Transfer Capability 455 MW
 TTC with All Lines In Service 2975 MW

EDIC_-FRASER_345_EF24-40

Mon 04/22/2019 to Fri 04/26/2019
 0500 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2500 MW**
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

MARCY_765_345_AT2

Mon 04/22/2019 to Fri 04/26/2019
 0500 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

FRASANNX-COOPERS_345_UCC2-41

Mon 04/29/2019 to Fri 05/03/2019
 0500 Continuous 1730
 Work scheduled by: NYPA

UPDATED by NYPA 08/22/2018

ARR: 19

FWD
 (Import)
 CENTRAL EAST - VC **2500 MW**
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Monday ,December 10, 2018 to Wednesday,June 10, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY -FRASANNX_345_UCC2-41

Mon 04/29/2019 to Fri 05/03/2019
0500 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 08/22/2018

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

MOSES -ADIRNDCK_230_MAI

Mon 04/29/2019 to Fri 05/03/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

HUDSONTP-W49TH_ST_345_Y56

Wed 05/01/2019 to Tue 05/07/2019
0600 Continuous 1800

Work scheduled by: PJM

FWD
(Import)
SCH - PJM_HTP **0 MW**
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

KINTIGH -ROCHESTR_345_SR1-39

Mon 05/06/2019 to Fri 05/10/2019
0600 Continuous 1700

Work scheduled by: NYPA

UPDATED by NYSEG 11/08/2018

FWD
(Import)
DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

ROSETON -ROCKTVRN_345_311

Mon 05/06/2019 to Sat 06/01/2019
0800 Continuous 1600

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4400 MW**
Impacts Total Transfer Capability 1300 MW
TTC with All Lines In Service 5700 MW

NIAGARA -ROCHESTR_345_NR2

Mon 05/13/2019 to Fri 05/17/2019
0600 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

ADIRNDCK-PORTER_230_12

Mon 05/20/2019 to Fri 05/24/2019
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Monday ,December 10, 2018 to Wednesday,June 10, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PANNELL_-CLAY_____345_1

Mon 05/20/2019 to Fri 05/24/2019
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

PANNELL_-CLAY_____345_2

Mon 06/03/2019 to Fri 06/07/2019
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

MOSES___-ADIRNDCK_230_MA2

Mon 06/24/2019 to Fri 06/28/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 07/08/2019 to Fri 07/12/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

ADIRNDCK-CHASLAKE_230_13

Mon 07/08/2019 to Fri 07/12/2019
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

MARCY_____765_345_AT2

Sat 08/03/2019 to Sun 08/04/2019
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA1

Mon 08/12/2019 to Mon 08/12/2019
0700 Continuous 1459

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Monday ,December 10, 2018 to Wednesday,June 10, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT1

Tue 09/03/2019 to Tue 09/03/2019
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1750 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 3150 MW

MARCY___-N.SCTLND_345_18

Wed 09/04/2019 to Wed 09/04/2019
0500 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 11/06/2018

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2090 MW**
Impacts Total Transfer Capability 885 MW
TTC with All Lines In Service 2975 MW

MARCY___345KV_CSC

Wed 09/04/2019 to Wed 09/04/2019
0500 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 11/06/2018

FWD
(Import)
CENTRAL EAST - VC **2925 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

MOSES___-ADIRNDCK_230_MA2

Wed 09/04/2019 to Wed 09/04/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

ADIRNDCK-PORTER___230_12

Wed 09/04/2019 to Wed 09/04/2019
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

ADIRNDCK-CHASLAKE_230_13

Thu 09/05/2019 to Thu 09/05/2019
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

NIAGARA_-ROCHESTR_345_NR2

Mon 09/09/2019 to Sat 09/21/2019
0500 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Monday ,December 10, 2018 to Wednesday,June 10, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LEEDS___345KV_R395

Mon 09/09/2019 to Mon 09/09/2019
0700 Continuous 0730

Work scheduled by: NYPA

FWD
(Import)
UPNY CONED **3800 MW**
Impacts Total Transfer Capability 1900 MW
TTC with All Lines In Service 5700 MW

GILBOA_-LEEDS___345_GL3

Mon 09/09/2019 to Fri 09/27/2019
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2200 MW**
Impacts Total Transfer Capability 775 MW
TTC with All Lines In Service 2975 MW

MARCY___-N.SCTLND_345_18

Wed 09/11/2019 to Fri 09/13/2019
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2090 MW**
Impacts Total Transfer Capability 885 MW
TTC with All Lines In Service 2975 MW

MOSES___-ADIRNDCK_230_MA2

Mon 09/16/2019 to Fri 09/20/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

GOETHALS_345KV_5

Fri 09/20/2019 to Tue 09/24/2019
0001 Continuous 2359

Work scheduled by: ConEd

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

ROCHESTR-PANNELL___345_RP2

Mon 09/23/2019 to Mon 09/30/2019
0500 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

KINTIGH_-ROCHESTR_345_SRL-39

Mon 09/23/2019 to Fri 09/27/2019
0600 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Monday ,December 10, 2018 to Wednesday,June 10, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK__345KV_RNS5

Wed 09/25/2019 to Wed 09/25/2019
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

SPRNBK_-W49TH_ST_345_M51

Wed 09/25/2019 to Sat 11/02/2019
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

LEEDS__345KV_R395

Fri 09/27/2019 to Fri 09/27/2019
 1700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 1900 MW
 TTC with All Lines In Service 5700 MW

CLAY__-EDIC__345_1-16

Mon 09/30/2019 to Fri 10/04/2019
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 OSWEGO EXPORT **4850 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 5250 MW

LEEDS__-HURLYAVE_345_301

Mon 09/30/2019 to Sat 10/26/2019
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4100 MW**
 Impacts Total Transfer Capability 1600 MW
 TTC with All Lines In Service 5700 MW

CLAY__-EDIC__345_2-15

Mon 10/07/2019 to Thu 10/17/2019
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 OSWEGO EXPORT **4850 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 5250 MW

MARCY__-N.SCTLND_345_18

Wed 10/09/2019 to Fri 10/11/2019
 0500 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2090 MW**
 Impacts Total Transfer Capability 885 MW
 TTC with All Lines In Service 2975 MW

ARR: 19

NYISO TRANSFER LIMITATIONS

Monday ,December 10, 2018 to Wednesday,June 10, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Transfer ID	Start Date	End Date	Time	Duration	Work by	ARR	From Zone	To Zone	FWD (MW)	REV (MW)
CHATGUAY-MASSENA__765_7040	Sat 10/12/2019	Sat 10/26/2019	0100	Continuous	1900		MOSES SOUTH		1550 MW	
Work scheduled by: NYPA								Impacts Total Transfer Capability	1600 MW	
								TTC with All Lines In Service	3150 MW	
CHATGUAY-MASSENA__765_7040	Sat 10/12/2019	Sat 10/26/2019	0100	Continuous	1900		SCH - HQ - NY		0 MW	0 MW
Work scheduled by: NYPA								Impacts Total Transfer Capability	1500 MW	1000 MW
								TTC with All Lines In Service	1500 MW	1000 MW
MARCY__765_345_AT1	Sat 10/12/2019	Sat 10/26/2019	0100	Continuous	1900	ARR: 19	MOSES SOUTH		1750 MW	
Work scheduled by: NYPA								Impacts Total Transfer Capability	1400 MW	
								TTC with All Lines In Service	3150 MW	
MARCY__765_345_AT2	Sat 10/12/2019	Sat 10/26/2019	0100	Continuous	1900	ARR: 19	MOSES SOUTH		1700 MW	
Work scheduled by: NYPA								Impacts Total Transfer Capability	1450 MW	
								TTC with All Lines In Service	3150 MW	
MASSENA_-MARCY__765_MSU1	Sat 10/12/2019	Sat 10/26/2019	0100	Continuous	1900		CENTRAL EAST - VC		2265 MW	
Work scheduled by: NYPA								Impacts Total Transfer Capability	710 MW	
								TTC with All Lines In Service	2975 MW	
MASSENA_-MARCY__765_MSU1	Sat 10/12/2019	Sat 10/26/2019	0100	Continuous	1900		MOSES SOUTH		500 MW	
Work scheduled by: NYPA								Impacts Total Transfer Capability	2650 MW	
								TTC with All Lines In Service	3150 MW	
MASSENA_-MARCY__765_MSU1	Sat 10/12/2019	Sat 10/26/2019	0100	Continuous	1900		SCH - HQ - NY		475 MW	1000 MW
Work scheduled by: NYPA								Impacts Total Transfer Capability	1025 MW	0 MW
								TTC with All Lines In Service	1500 MW	1000 MW

NYISO TRANSFER LIMITATIONS

Monday ,December 10, 2018 to Wednesday,June 10, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040

Sat 10/12/2019 to Sat 10/26/2019
0100 1900

Work scheduled by:

FWD
(Import)
MOSES SOUTH **500 MW**
Impacts Total Transfer Capability 2650 MW
TTC with All Lines In Service 3150 MW

MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2

Sat 10/12/2019 to Sat 10/26/2019
0100 1900

Work scheduled by:

FWD REV
(Import) (Export)
SCH - HQ - NY **850 MW 0 MW**
Impacts Total Transfer Capability 650 MW 1000 MW
TTC with All Lines In Service 1500 MW 1000 MW

NIAGARA 345_230_AT4

Wed 10/23/2019 to Wed 12/18/2019
0500 Continuous 1700

Work scheduled by: NYPA

FWD REV
(Import) (Export)
SCH - OH - NY **1900 MW 1400 MW**
Impacts Total Transfer Capability 0 MW 350 MW
TTC with All Lines In Service 1900 MW 1750 MW

SPRNBRK 345KV_RNS5

Sat 11/02/2019 to Sat 11/02/2019
0130 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

HURLYAVE-ROSETON 345_303

Mon 11/04/2019 to Fri 12/06/2019
0800 Continuous 1600

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 1600 MW
TTC with All Lines In Service 5700 MW

PANNELL -CLAY 345_2

Wed 11/06/2019 to Fri 11/22/2019
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

MARCY -N.SCTLND 345_18

Thu 11/07/2019 to Fri 11/08/2019
0500 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2090 MW**
Impacts Total Transfer Capability 885 MW
TTC with All Lines In Service 2975 MW

ARR: 19

NYISO TRANSFER LIMITATIONS

Monday ,December 10, 2018 to Wednesday,June 10, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___345KV_CSC

Thu 11/07/2019 to Fri 11/08/2019
0500 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2925 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

MOSES___-ADIRNDCK_230_MA2

Tue 11/12/2019 to Fri 11/15/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 11/18/2019 to Fri 11/22/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 11/25/2019 to Wed 11/27/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 12/02/2019 to Fri 12/06/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA1

Mon 12/09/2019 to Fri 12/13/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 12/16/2019 to Mon 12/16/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Monday ,December 10, 2018 to Wednesday,June 10, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA1

Tue 12/17/2019 to Fri 12/20/2019
 0700 Continuous 1500

Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

LADENTWN-BUCHAN_S_345_Y88

Wed 01/15/2020 to Thu 02/13/2020
 0001 Continuous 2359

Work scheduled by: ORU

11/05/2018

FWD
 (Import)
 UPNY CONED **4800 MW**
 Impacts Total Transfer Capability 900 MW
 TTC with All Lines In Service 5700 MW

FRASANNX-COOPERS__345_UCC2-41

Mon 04/27/2020 to Sun 05/31/2020
 0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 CENTRAL EAST - VC **2500 MW**
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

MARCY___-FRASANNX_345_UCC2-41

Mon 04/27/2020 to Sun 05/31/2020
 0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 CENTRAL EAST - VC **2500 MW**
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW