

NYISO TRANSFER LIMITATIONS

Wednesday, February 13, 2019 to Friday, August 14, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

	FWD	REV
HUDSONP_-FARRAGUT_345_B3402		
Mon 01/15/2018 to Tue 12/31/2019		(Import) (Export)
0001 Continuous 2359		
<u>EXTENDED</u> by <u>CONED</u> <u>02/06/2019</u>		
Work scheduled by: ConEd		
SCH - PJ - NY	2600 MW	1300 MW
Impacts Total Transfer Capability	0 MW	250 MW
TTC with All Lines In Service	2600 MW	1550 MW
HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403		
Mon 01/15/2018 to Tue 12/31/2019		(Import) (Export)
0001 2359		
SCH - PJ - NY	2000 MW	1300 MW
Impacts Total Transfer Capability	600 MW	250 MW
TTC with All Lines In Service	2600 MW	1550 MW
MARION_-FARRAGUT_345_C3403		
Mon 01/15/2018 to Tue 12/31/2019		(Import) (Export)
0001 Continuous 2359		
<u>EXTENDED</u> by <u>CONED</u> <u>02/06/2019</u>		
Work scheduled by: ConEd		
SCH - PJ - NY	2600 MW	1300 MW
Impacts Total Transfer Capability	0 MW	250 MW
TTC with All Lines In Service	2600 MW	1550 MW
STLAWRNC-MOSES_230_L33P		
Mon 04/30/2018 to Fri 12/31/2021		(Import) (Export)
0456 Continuous 2359		
<u>EXT FORCE</u> by <u>IESO</u> <u>08/21/2018</u>		
Work scheduled by: IESO		
SCH - OH - NY	2250 MW	2000 MW
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	2250 MW	2000 MW
S.RIPLEY-DUNKIRK_230_68		
Tue 01/15/2019 to Mon 04/08/2019		(Import) (Export)
1128 Continuous 0759		
<u>EXT FORCE</u> by <u>PJM</u> <u>02/11/2019</u>		
Work scheduled by: PJM		
SCH - PJ - NY	2600 MW	1300 MW
Impacts Total Transfer Capability	0 MW	250 MW
TTC with All Lines In Service	2600 MW	1550 MW
DUNWODIE_345KV_6		
Wed 01/23/2019 to Fri 03/01/2019		FWD (Import)
0001 Continuous 2359		
<u>EXTENDED</u> by <u>CE</u> <u>02/07/2019</u>		
Work scheduled by: ConEd		
SPR/DUN-SOUTH	3800 MW	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	
MOSES_-ADIRNDCK_230_MA1		
Mon 02/04/2019 to Fri 02/08/2019		FWD (Import)
0700 Continuous 1530		
<u>UPDATED</u> by <u>NYPA</u> <u>01/28/2019</u>		
Work scheduled by: NYPA		
MOSES SOUTH	2300 MW	
Impacts Total Transfer Capability	850 MW	
TTC with All Lines In Service	3150 MW	

NYISO TRANSFER LIMITATIONS

Wednesday, February 13, 2019 to Friday, August 14, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO-NYISO_LIMIT_1100						FWD
Tue 02/05/2019	to	Sat 02/09/2019	<u>UPDATED</u>	<u>by IESO</u>	<u>02/08/2019</u>	(Import)
0500	Continuous	1659				1400 MW
Work scheduled by: IESO						Impacts Total Transfer Capability 850 MW
						TTC with All Lines In Service 2250 MW
SCH-NYISO-IMO_LIMIT_1200						REV
Tue 02/05/2019	to	Sat 02/09/2019	<u>UPDATED</u>	<u>by IESO</u>	<u>02/08/2019</u>	(Export)
0500	Continuous	1659				1500 MW
Work scheduled by: IESO						Impacts Total Transfer Capability 500 MW
						TTC with All Lines In Service 2000 MW
BUCHAN_N-EASTVIEW_345_W93						FWD
Thu 02/07/2019	to	Fri 02/08/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>01/30/2019</u>	(Import)
0301	Continuous	0130				4350 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 1350 MW
						TTC with All Lines In Service 5700 MW
EASTVIEW-SPRNBK__345_W79						FWD
Fri 02/08/2019	to	Fri 02/08/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>01/30/2019</u>	(Import)
0100	Continuous	0130				4350 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 1350 MW
						TTC with All Lines In Service 5700 MW
EASTVIEW-SPRNBK__345_W78						FWD
Fri 02/08/2019	to	Fri 02/08/2019	<u>UPDATED</u>	<u>by CE</u>	<u>02/09/2019</u>	(Import)
0200	Continuous	0230				4350 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 1350 MW
						TTC with All Lines In Service 5700 MW
SPRNBK__345KV_RNS3						FWD
Fri 02/08/2019	to	Fri 02/08/2019	<u>UPDATED</u>	<u>by CE</u>	<u>02/09/2019</u>	(Import)
0200	Continuous	0230				3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
MILLWOOD-EASTVIEW_345_W85						FWD
Fri 02/08/2019	to	Sat 02/09/2019	<u>UPDATED</u>	<u>by CE</u>	<u>02/09/2019</u>	(Import)
0200	Continuous	0032				4350 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 1350 MW
						TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Wednesday, February 13, 2019 to Friday, August 14, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO-NYISO_LIMIT_1900

Sat 02/09/2019 to Sun 02/10/2019
1700 Continuous 2359

Work scheduled by: IESO

UPDATED by IESO 02/09/2019

SCH - OH - NY **2200 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2250 MW

FWD
(Import)

SCH-IMO-NYISO_LIMIT_1700

Mon 02/11/2019 to Fri 12/31/2021
0001 Continuous 2359

Work scheduled by: IESO

SCH - OH - NY **2000 MW**
Impacts Total Transfer Capability 250 MW
TTC with All Lines In Service 2250 MW

FWD
(Import)

MOSES__-ADIRNDCK_230_MAL

Mon 02/11/2019 to Fri 02/15/2019
0700 Continuous 1500

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

FWD
(Import)

GOETHALS_345KV_5

Wed 02/13/2019 to Sat 02/16/2019
0400 Continuous 0130

Work scheduled by: ConEd

CANCELLED by ConEd 02/12/2019

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

W49TH_ST-E13THSTA_345_M55

Wed 02/13/2019 to Fri 02/15/2019
0652 Continuous 2359

Work scheduled by: ConEd

FORCED by CE 02/13/2019

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD
(Import)

W49TH_ST_345KV_6

Wed 02/13/2019 to Fri 02/15/2019
0652 Continuous 2359

Work scheduled by: ConEd

FORCED by CE 02/13/2019

SCH - PJM_HTP **375 MW**
Impacts Total Transfer Capability 285 MW
TTC with All Lines In Service 660 MW

FWD
(Import)

MILLWOOD-EASTVIEW_345_W99

Thu 02/14/2019 to Thu 02/14/2019
0001 Continuous 0030

Work scheduled by: ConEd

UPDATED by CONED 02/08/2019

UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1350 MW
TTC with All Lines In Service 5700 MW

FWD
(Import)

NYISO TRANSFER LIMITATIONS

Wednesday, February 13, 2019 to Friday, August 14, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK__345KV_RNS5					FWD	
Thu 02/14/2019	to	Thu 02/14/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/08/2019</u>	(Import)
0001	Continuous	0030				3200 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	1400 MW
					Impacts Total Transfer Capability	4600 MW
					TTC with All Lines In Service	4600 MW
EASTVIEW-SPRNBK__345_W64					FWD	
Thu 02/14/2019	to	Thu 02/14/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/08/2019</u>	(Import)
0001	Continuous	2230				4350 MW
Work scheduled by: ConEd					UPNY CONED	1350 MW
					Impacts Total Transfer Capability	5700 MW
					TTC with All Lines In Service	5700 MW
BECK__-NIAGARA__345_PA302					FWD	REV
Thu 02/14/2019	to	Thu 02/14/2019	<u>UPDATED</u>	<u>by IESO</u>	<u>02/11/2019</u>	(Import) (Export)
0500	Continuous	1700				1100 MW 950 MW
Work scheduled by: IESO					SCH - OH - NY	1050 MW
					Impacts Total Transfer Capability	2000 MW
					TTC with All Lines In Service	2250 MW
MILLWOOD-EASTVIEW_345_W99					FWD	
Thu 02/14/2019	to	Thu 02/14/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/08/2019</u>	(Import)
2200	Continuous	2230				4350 MW
Work scheduled by: ConEd					UPNY CONED	1350 MW
					Impacts Total Transfer Capability	5700 MW
					TTC with All Lines In Service	5700 MW
SPRNBK__345KV_RNS5					FWD	
Thu 02/14/2019	to	Thu 02/14/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/08/2019</u>	(Import)
2200	Continuous	2230				3200 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	1400 MW
					Impacts Total Transfer Capability	4600 MW
					TTC with All Lines In Service	4600 MW
SCRIBA__-VOLNEY__345_20					FWD	
Sat 02/16/2019	to	Sun 02/17/2019				(Import)
0600	Continuous	1900				5250 MW
Work scheduled by: NGrid					OSWEGO EXPORT	0 MW
					Impacts Total Transfer Capability	5250 MW
					TTC with All Lines In Service	5250 MW
MOSES__-ADIRNDCK_230_MA2					FWD	
Tue 02/19/2019	to	Fri 02/22/2019	<u>CANCELLED</u>	<u>by NYPA</u>	<u>02/12/2019</u>	(Import)
0700	Continuous	1500				2300 MW
Work scheduled by: NYPA					MOSES SOUTH	850 MW
					Impacts Total Transfer Capability	3150 MW
					TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Wednesday, February 13, 2019 to Friday, August 14, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ADIRNDCK-PORTER_230_12			FWD	
Wed 02/20/2019	to	Wed 02/20/2019	(Import)	
0700	Daily(No Weekends)	1530	MOSES SOUTH	2300 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	850 MW
			TTC with All Lines In Service	3150 MW
MOSES-ADIRNDCK_230_MA2			FWD	
Wed 02/20/2019	to	Wed 02/20/2019	(Import)	
0700	Continuous	1530	MOSES SOUTH	2300 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW
			TTC with All Lines In Service	3150 MW
FIVEMILE-STOLLERD_345_29			FWD	REV
Wed 02/20/2019	to	Fri 02/22/2019	(Import)	(Export)
0730	Continuous	1900	SCH - PJ - NY	2600 MW 1300 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	0 MW 250 MW
			TTC with All Lines In Service	2600 MW 1550 MW
CHAT_DC_GC2			FWD	
Thu 02/21/2019	to	Thu 02/21/2019	(Import)	
0500	Continuous	1800	MOSES SOUTH	2850 MW
Work scheduled by: HQ			Impacts Total Transfer Capability	300 MW
			TTC with All Lines In Service	3150 MW
CHAT_DC_GC2				REV
Thu 02/21/2019	to	Thu 02/21/2019		(Export)
0500	Continuous	1800	SCH - HQ - NY	500 MW
Work scheduled by: HQ			Impacts Total Transfer Capability	500 MW
			TTC with All Lines In Service	1000 MW
ADIRNDCK-CHASLAKE_230_13			FWD	
Thu 02/21/2019	to	Thu 02/21/2019	(Import)	
0700	Daily(No Weekends)	1530	MOSES SOUTH	2300 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	850 MW
			TTC with All Lines In Service	3150 MW
MOSES-ADIRNDCK_230_MA1			FWD	
Thu 02/21/2019	to	Thu 02/21/2019	(Import)	
0700	Continuous	1530	MOSES SOUTH	2300 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW
			TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Wednesday, February 13, 2019 to Friday, August 14, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -ADIRNDCK_230_MA1				FWD
Mon 02/25/2019	to	Fri 03/01/2019		(Import)
0700	Continuous	1500		MOSES SOUTH 2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW
SCRIBA -VOLNEY_345_21				FWD
Wed 02/27/2019	to	Thu 02/28/2019	UPDATED by NGRID 12/11/2018	(Import)
0730	Continuous	2000		OSWEGO EXPORT 5250 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 0 MW
				TTC with All Lines In Service 5250 MW
ATHENS -PLSNTVLY_345_91				FWD
Thu 02/28/2019	to	Thu 02/28/2019		(Import)
0630	Continuous	2230		UPNY CONED 3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1900 MW
				TTC with All Lines In Service 5700 MW
PLSNTVLY_345KV_RNS4				FWD
Thu 02/28/2019	to	Thu 02/28/2019		(Import)
0630	Continuous	2230		UPNY CONED 3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1900 MW
				TTC with All Lines In Service 5700 MW
PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4				FWD
Fri 03/01/2019	to	Mon 03/04/2019		(Import)
0001		0200		UPNY CONED 3800 MW
Work scheduled by:				Impacts Total Transfer Capability 1900 MW
				TTC with All Lines In Service 5700 MW
LONG_MTN-PLSNTVLY_345_398				FWD
Fri 03/01/2019	to	Sun 05/19/2019	UPDATED by ISONE 01/30/2019	(Import) (Export)
0001	Continuous	2359		SCH - NE - NY 700 MW 1250 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 700 MW 550 MW
				TTC with All Lines In Service 1400 MW 1800 MW
LONG_MTN-PLSNTVLY_345_398				FWD
Fri 03/01/2019	to	Sun 05/19/2019	UPDATED by ISONE 01/30/2019	(Import) (Export)
0001	Continuous	2359		SCH - NPX_1385 100 MW 100 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 100 MW 100 MW
				TTC with All Lines In Service 200 MW 200 MW

NYISO TRANSFER LIMITATIONS

Wednesday, February 13, 2019 to Friday, August 14, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						REV
SCH-NYISO-NE_LIMIT_700						(Export)
Fri 03/01/2019	to	Sun 05/19/2019	<u>UPDATED</u>	<u>by ISONE</u>	<u>01/30/2019</u>	
0001	Continuous	2359				900 MW
Work scheduled by: ConEd					SCH - NE - NY	900 MW
					Impacts Total Transfer Capability	900 MW
					TTC with All Lines In Service	1800 MW
<hr/>						
PLSNTVLY-EFISHKIL_345_F37						FWD
						(Import)
Mon 03/04/2019	to	Wed 03/06/2019	<u>UPDATED</u>	<u>by ISONE</u>	<u>01/30/2019</u>	
0201	Continuous	0300				4000 MW
Work scheduled by: ConEd					UPNY CONED	4000 MW
					Impacts Total Transfer Capability	1700 MW
					TTC with All Lines In Service	5700 MW
<hr/>						
SCRIBA__-VOLNEY__345_20						FWD
						(Import)
Mon 03/04/2019	to	Tue 03/05/2019				
0600	Continuous	1800				5250 MW
Work scheduled by: NGrid					OSWEGO EXPORT	5250 MW
					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	5250 MW
<hr/>						
MOSES__-ADIRNDCK_230_MA1						FWD
						(Import)
Mon 03/04/2019	to	Fri 03/08/2019				
0700	Continuous	1500				2300 MW
Work scheduled by: NYPA					MOSES SOUTH	2300 MW
					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
<hr/>						
DUNWODIE_345KV_4						FWD
						(Import)
Thu 03/07/2019	to	Thu 03/07/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/06/2019</u>	
0001	Continuous	0030				3800 MW
Work scheduled by: LI					SPR/DUN-SOUTH	3800 MW
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<hr/>						
DUNWODIE_345KV_6						FWD
						(Import)
Thu 03/07/2019	to	Thu 03/07/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/06/2019</u>	
0001	Continuous	0030				3800 MW
Work scheduled by: LI					SPR/DUN-SOUTH	3800 MW
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<hr/>						
DUNWODIE-SHORE_RD_345_Y50						FWD
						(Import)
Thu 03/07/2019	to	Fri 03/08/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/06/2019</u>	
0001	Continuous	2359				800 MW
Work scheduled by: LI					CONED - LIPA	800 MW
					Impacts Total Transfer Capability	700 MW
					TTC with All Lines In Service	1500 MW

NYISO TRANSFER LIMITATIONS

Wednesday, February 13, 2019 to Friday , August 14, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SHORE_RD_345_138_BK 1						FWD	
Thu 03/07/2019	to	Fri 03/08/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/06/2019</u>	(Import)	
0001	Continuous	2359				CONED - LIPA	1350 MW
Work scheduled by: LI						Impacts Total Transfer Capability	150 MW
						TTC with All Lines In Service	1500 MW
SHORE_RD_345_138_BK 2						FWD	
Thu 03/07/2019	to	Fri 03/08/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/06/2019</u>	(Import)	
0001	Continuous	2359				CONED - LIPA	1350 MW
Work scheduled by: LI						Impacts Total Transfer Capability	150 MW
						TTC with All Lines In Service	1500 MW
EASTVIEW-SPRNBRK_345_W64						FWD	
Thu 03/07/2019	to	Mon 03/11/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/08/2019</u>	(Import)	
0001	Continuous	0200				UPNY CONED	4350 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	1350 MW
						TTC with All Lines In Service	5700 MW
MILLWOOD-EASTVIEW_345_W99						FWD	
Thu 03/07/2019	to	Mon 03/11/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/08/2019</u>	(Import)	
0001	Continuous	0200				UPNY CONED	4350 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	1350 MW
						TTC with All Lines In Service	5700 MW
DUNWODIE_345KV_4						FWD	
Fri 03/08/2019	to	Fri 03/08/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/06/2019</u>	(Import)	
2330	Continuous	2359				SPR/DUN-SOUTH	3800 MW
Work scheduled by: LI						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_6						FWD	
Fri 03/08/2019	to	Fri 03/08/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/06/2019</u>	(Import)	
2330	Continuous	2359				SPR/DUN-SOUTH	3800 MW
Work scheduled by: LI						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
BECK____-NIAGARA_345_PA301						FWD	REV
Mon 03/11/2019	to	Fri 03/15/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>02/06/2019</u>	(Import)	(Export)
0600	Continuous	1700				SCH - OH - NY	1100 MW 950 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	1150 MW 1050 MW
						TTC with All Lines In Service	2250 MW 2000 MW

NYISO TRANSFER LIMITATIONS

Wednesday, February 13, 2019 to Friday, August 14, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>STLAWRNC-MOSES 230_L33P & STLAWRNC-MOSES 230_L34P</p> <p>Mon 03/11/2019 to Mon 03/11/2019</p> <p style="padding-left: 40px;">0700 1530</p> <p>Work scheduled by:</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>MOSES SOUTH 2700 MW</p> <p>Impacts Total Transfer Capability 450 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>STLAWRNC-MOSES 230_L34P</p> <p>Mon 03/11/2019 to Mon 03/11/2019</p> <p style="padding-left: 40px;">0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD REV</p> <p style="text-align: right;">(Import) (Export)</p> <p>SCH - OH - NY 2250 MW 2000 MW</p> <p>Impacts Total Transfer Capability 0 MW 0 MW</p> <p>TTC with All Lines In Service 2250 MW 2000 MW</p>
<p>LEEDS 345_LEEDS SVC</p> <p>Mon 03/11/2019 to Fri 03/22/2019</p> <p style="padding-left: 40px;">0800 Continuous 1600</p> <p>Work scheduled by: NGrid</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>CENTRAL EAST - VC 2950 MW</p> <p>Impacts Total Transfer Capability 25 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p>MOSES -ADIRNDCK_230_MAL</p> <p>Tue 03/12/2019 to Fri 03/15/2019</p> <p style="padding-left: 40px;">0700 Continuous 1500</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>MOSES SOUTH 2300 MW</p> <p>Impacts Total Transfer Capability 850 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>MARCY 765_345_AT1</p> <p>Mon 03/18/2019 to Fri 03/22/2019</p> <p style="padding-left: 40px;">0500 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>MOSES SOUTH 1750 MW</p> <p>Impacts Total Transfer Capability 1400 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>SCH-NYISO-HQ CEDARS_LIMIT_0</p> <p>Mon 03/18/2019 to Thu 04/04/2019</p> <p style="padding-left: 40px;">0700 Continuous 1700</p> <p>Work scheduled by: HQ</p>	<p style="text-align: right;">REV</p> <p style="text-align: right;">(Export)</p> <p>SCH - HQ_CEDARS 0 MW</p> <p>Impacts Total Transfer Capability 100 MW</p> <p>TTC with All Lines In Service 100 MW</p>
<p>MARCY 345KV_CSC</p> <p>Mon 04/01/2019 to Sun 04/07/2019</p> <p style="padding-left: 40px;">0500 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>CENTRAL EAST - VC 2925 MW</p> <p>Impacts Total Transfer Capability 50 MW</p> <p>TTC with All Lines In Service 2975 MW</p>

ARR: 19

NYISO TRANSFER LIMITATIONS

Wednesday, February 13, 2019 to Friday , August 14, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>VOLNEY__-MARCY___345_19</p> <p>Mon 04/01/2019 to Wed 04/10/2019 0500 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC 2825 MW</p> <p>Impacts Total Transfer Capability 150 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
ARR: 19	
<p>VOLNEY__-MARCY___345_19</p> <p>Mon 04/01/2019 to Wed 04/10/2019 0500 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>OSWEGO EXPORT 4900 MW</p> <p>Impacts Total Transfer Capability 350 MW</p> <p>TTC with All Lines In Service 5250 MW</p>
ARR: 19	
<p>PLSNTVLY-EFISHKIL_345_F37</p> <p>Thu 04/04/2019 to Mon 04/08/2019 0001 Continuous 0200</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>UPNY CONED 4000 MW</p> <p>Impacts Total Transfer Capability 1700 MW</p> <p>TTC with All Lines In Service 5700 MW</p>
UPDATED by ISONE 01/30/2019	
<p>NIAGARA_-ROCHESTR_345_NR2</p> <p>Fri 04/05/2019 to Fri 04/05/2019 0500 Continuous 1700</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>DYSINGER EAST 1700 MW</p> <p>Impacts Total Transfer Capability 1450 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>LINDN_CG-LNDVFT___345_V-3022</p> <p>Sun 04/07/2019 to Fri 04/12/2019 1400 Continuous 1800</p> <p>Work scheduled by: PJM</p>	<p style="text-align: right;">FWD REV (Import) (Export)</p> <p>SCH - PJM_VFT 0 MW 0 MW</p> <p>Impacts Total Transfer Capability 315 MW 315 MW</p> <p>TTC with All Lines In Service 315 MW 315 MW</p>
<p>PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4</p> <p>Mon 04/08/2019 to Sat 04/13/2019 0001 0300</p> <p>Work scheduled by:</p>	<p style="text-align: right;">FWD (Import)</p> <p>UPNY CONED 3800 MW</p> <p>Impacts Total Transfer Capability 1900 MW</p> <p>TTC with All Lines In Service 5700 MW</p>
<p>PLSNTVLE-DUNWODIE_345_W89</p> <p>Mon 04/08/2019 to Fri 05/10/2019 0001 Continuous 2359</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>UPNY CONED 4000 MW</p> <p>Impacts Total Transfer Capability 1700 MW</p> <p>TTC with All Lines In Service 5700 MW</p>

NYISO TRANSFER LIMITATIONS

Wednesday, February 13, 2019 to Friday , August 14, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEPTUNE_-DUFFYAVE_345_NEPTUNE				FWD	
Mon 04/08/2019	to	Tue 04/09/2019		(Import)	
0600	Continuous	1800	SCH - PJM_NEPTUNE	0 MW	
Work scheduled by: LI			Impacts Total Transfer Capability	660 MW	
			TTC with All Lines In Service	660 MW	
NEWBRDGE-DUFFYAVE_345_501				FWD	
Mon 04/08/2019	to	Tue 04/09/2019		(Import)	
0600	Continuous	1800	SCH - PJM_NEPTUNE	0 MW	
Work scheduled by: LI			Impacts Total Transfer Capability	660 MW	
			TTC with All Lines In Service	660 MW	
NEWBRDGE_345_138_BK_1				FWD	
Mon 04/08/2019	to	Tue 04/09/2019		(Import)	
0600	Continuous	1800	SCH - PJM_NEPTUNE	375 MW	
Work scheduled by: LI			Impacts Total Transfer Capability	285 MW	
			TTC with All Lines In Service	660 MW	
NEWBRDGE_345_138_BK_2				FWD	
Mon 04/08/2019	to	Tue 04/09/2019		(Import)	
0600	Continuous	1800	SCH - PJM_NEPTUNE	375 MW	
Work scheduled by: LI			Impacts Total Transfer Capability	285 MW	
			TTC with All Lines In Service	660 MW	
S.RIPLEY-DUNKIRK__230_68				FWD	REV
Mon 04/08/2019	to	Mon 04/15/2019	UPDATED	(Import)	(Export)
0800	Continuous	2000	by PJM		
Work scheduled by: PJM			02/11/2019	SCH - PJ - NY	2600 MW 1300 MW
				Impacts Total Transfer Capability	0 MW 250 MW
				TTC with All Lines In Service	2600 MW 1550 MW
MARCY___345KV_CSC				FWD	
Thu 04/11/2019	to	Wed 04/17/2019		(Import)	
0500	Continuous	1730	CENTRAL EAST - VC	2925 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	50 MW	
			TTC with All Lines In Service	2975 MW	
MARCY___-EDIC___345_UE1-7				FWD	
Thu 04/11/2019	to	Sat 04/20/2019		(Import)	
0500	Continuous	1730	OSWEGO EXPORT	5250 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	0 MW	
			TTC with All Lines In Service	5250 MW	

ARR: 19&16

NYISO TRANSFER LIMITATIONS

Wednesday, February 13, 2019 to Friday, August 14, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>				
SCRIBA	-VOLNEY	345	20	
Mon 04/15/2019	to	Tue 04/16/2019		FWD
0600	Continuous	1800		(Import)
Work scheduled by: NGrid				OSWEGO EXPORT 5250 MW
				Impacts Total Transfer Capability 0 MW
				TTC with All Lines In Service 5250 MW
<hr/>				
GILBOA	-N.SCTLND	345	GNS-1	
Thu 04/18/2019	to	Thu 04/18/2019		FWD
1330	Continuous	1530		(Import)
Work scheduled by: NYPA				CENTRAL EAST - VC 2520 MW
				Impacts Total Transfer Capability 455 MW
				TTC with All Lines In Service 2975 MW
<hr/>				
MARCY	765	345	AT2	
Mon 04/22/2019	to	Fri 04/26/2019		FWD
0500	Continuous	1730		(Import)
Work scheduled by: NYPA				MOSES SOUTH 1700 MW
				Impacts Total Transfer Capability 1450 MW
				TTC with All Lines In Service 3150 MW
<hr/>				
EDIC	-FRASER	345	EF24-40	
Mon 04/22/2019	to	Sun 04/28/2019		FWD
0500	Continuous	1730		(Import)
Work scheduled by: NYPA				CENTRAL EAST - VC 2500 MW
				Impacts Total Transfer Capability 475 MW
				TTC with All Lines In Service 2975 MW
<hr/>				
SPRNBRK	345KV	RNS5		
Mon 04/29/2019	to	Mon 04/29/2019		FWD
0001	Continuous	0030		(Import)
Work scheduled by: ConEd				SPR/DUN-SOUTH 3200 MW
				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW
<hr/>				
SPRNBRK	-W49TH	ST	345	M51
Mon 04/29/2019	to	Sun 05/05/2019		FWD
0001	Continuous	2200		(Import)
Work scheduled by: ConEd				SPR/DUN-SOUTH 3200 MW
				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW
<hr/>				
FRASANNX	-COOPERS	345	UCC2-41	
Mon 04/29/2019	to	Fri 05/03/2019		FWD
0500	Continuous	1730		(Import)
Work scheduled by: NYPA				CENTRAL EAST - VC 2500 MW
				Impacts Total Transfer Capability 475 MW
				TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Wednesday, February 13, 2019 to Friday, August 14, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY -FRASANNX_345_UCC2-41				FWD	
Mon 04/29/2019	to	Fri 05/03/2019	UPDATED	by NYPA	08/22/2018
0500	Continuous	1730			
Work scheduled by: NYPA				ARR: 19	
				CENTRAL EAST - VC	2500 MW
				Impacts Total Transfer Capability	475 MW
				TTC with All Lines In Service	2975 MW
MOSES -ADIRNDCK_230_MAI				FWD	
Mon 04/29/2019	to	Fri 05/03/2019			
0700	Continuous	1500			
Work scheduled by: NYPA					
				MOSES SOUTH	2300 MW
				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
EGRDNCTY_345_138_AT2				FWD	
Wed 05/01/2019	to	Wed 05/15/2019			
0001	Continuous	2359			
Work scheduled by: LI					
				CONED - LIPA	1250 MW
				Impacts Total Transfer Capability	250 MW
				TTC with All Lines In Service	1500 MW
HUDSONTP-W49TH_ST_345_Y56				FWD	
Wed 05/01/2019	to	Tue 05/07/2019			
0600	Continuous	1800			
Work scheduled by: PJM					
				SCH - PJM_HTP	0 MW
				Impacts Total Transfer Capability	660 MW
				TTC with All Lines In Service	660 MW
SPRNBK_345KV_RNS5				FWD	
Sun 05/05/2019	to	Sun 05/05/2019			
2130	Continuous	2200			
Work scheduled by: ConEd					
				SPR/DUN-SOUTH	3200 MW
				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	4600 MW
KINTIGH -ROCHESTR_345_SR1-39				FWD	
Mon 05/06/2019	to	Fri 05/10/2019	UPDATED	by NYSEG	11/08/2018
0600	Continuous	1700			
Work scheduled by: NYPA					
				DYSINGER EAST	1400 MW
				Impacts Total Transfer Capability	1750 MW
				TTC with All Lines In Service	3150 MW
SHOR_NPX-SHOREHAM_138_CSC				FWD	REV
Mon 05/06/2019	to	Fri 05/10/2019			
0700	Continuous	1800			
Work scheduled by: LI					
				SCH - NPX_CSC	0 MW 0 MW
				Impacts Total Transfer Capability	330 MW 330 MW
				TTC with All Lines In Service	330 MW 330 MW

NYISO TRANSFER LIMITATIONS

Wednesday, February 13, 2019 to Friday , August 14, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROSETON_-ROCKTVRN_345_311

Mon 05/06/2019 to Sat 06/01/2019
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4400 MW**
 Impacts Total Transfer Capability 1300 MW
 TTC with All Lines In Service 5700 MW

NIAGARA_-ROCHESTR_345_NR2

Mon 05/13/2019 to Fri 05/17/2019
 0600 Continuous 1700
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **1400 MW**
 Impacts Total Transfer Capability 1750 MW
 TTC with All Lines In Service 3150 MW

ADIRNDCK-PORTER___230_12

Mon 05/20/2019 to Fri 05/24/2019
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2100 MW**
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW

PANNELL_-CLAY_____345_1

Mon 05/20/2019 to Fri 05/24/2019
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 WEST CENTRAL **1300 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

ROSETON_-EFISHKIL_345_RFK305

Thu 05/23/2019 to Thu 05/23/2019
 0800 Daily 1600
 Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4800 MW**
 Impacts Total Transfer Capability 900 MW
 TTC with All Lines In Service 5700 MW

SCRIBA_-VOLNEY___345_20

Tue 05/28/2019 to Tue 05/28/2019
 0600 Continuous 1800
 Work scheduled by: NGrid

FWD
 (Import)
 OSWEGO EXPORT **5250 MW**
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 5250 MW

PANNELL_-CLAY_____345_2

Mon 06/03/2019 to Fri 06/07/2019
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 WEST CENTRAL **1300 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

NYISO TRANSFER LIMITATIONS

Wednesday, February 13, 2019 to Friday, August 14, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA2

Mon 06/24/2019 to Fri 06/28/2019
 0700 Continuous 1500
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2100 MW**
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 07/08/2019 to Fri 07/12/2019
 0700 Continuous 1500
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2100 MW**
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW

ADIRNDCK-CHASLAKE_230_13

Mon 07/08/2019 to Fri 07/12/2019
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2100 MW**
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW

MARCY___765_345_AT2

Sat 08/03/2019 to Sun 08/04/2019
 0500 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA1

Mon 08/12/2019 to Mon 08/12/2019 **UPDATED by NYPA 10/10/2018**
 0700 Continuous 1459
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2100 MW**
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW

MARCY___765_345_AT1

Tue 09/03/2019 to Tue 09/03/2019
 0500 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1750 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 3150 MW

MARCY___-N.SCTLND_345_18

Wed 09/04/2019 to Wed 09/04/2019 **UPDATED by NYPA 11/06/2018**
 0500 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 CENTRAL EAST - VC **2090 MW**
 Impacts Total Transfer Capability 885 MW
 TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Wednesday, February 13, 2019 to Friday, August 14, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___345KV_CSC

FWD

Wed 09/04/2019 to Wed 09/04/2019
0500 Continuous 1730

UPDATED by NYPA 11/06/2018

(Import)

Work scheduled by: NYPA

CENTRAL EAST - VC **2925 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

MOSES___-ADIRNDCK_230_MA2

FWD

Wed 09/04/2019 to Wed 09/04/2019
0700 Continuous 1500

(Import)

Work scheduled by: NYPA

MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

ADIRNDCK-PORTER___230_12

FWD

Wed 09/04/2019 to Wed 09/04/2019
0700 Continuous 1530

(Import)

Work scheduled by: NYPA

MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

ADIRNDCK-CHASLAKE_230_13

FWD

Thu 09/05/2019 to Thu 09/05/2019
0700 Continuous 1530

(Import)

Work scheduled by: NYPA

MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

NIAGARA_-ROCHESTR_345_NR2

FWD

Mon 09/09/2019 to Sat 09/21/2019
0500 Continuous 1700

(Import)

Work scheduled by: NYPA

DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

LEEDS___345KV_R395

FWD

Mon 09/09/2019 to Mon 09/09/2019
0700 Continuous 0730

(Import)

Work scheduled by: NYPA

UPNY CONED **3800 MW**
Impacts Total Transfer Capability 1900 MW
TTC with All Lines In Service 5700 MW

GILBOA_-LEEDS___345_GL3

FWD

Mon 09/09/2019 to Fri 09/27/2019
0700 Continuous 1730

(Import)

Work scheduled by: NYPA

CENTRAL EAST - VC **2200 MW**
Impacts Total Transfer Capability 775 MW
TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Wednesday, February 13, 2019 to Friday, August 14, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___-N.SCTLND_345_18

Wed 09/11/2019 to Fri 09/13/2019
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

CENTRAL EAST - VC **2090 MW**
Impacts Total Transfer Capability 885 MW
TTC with All Lines In Service 2975 MW

MOSES___-ADIRNDCK_230_MA2

Mon 09/16/2019 to Fri 09/20/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

GOETHALS_345KV_5

Fri 09/20/2019 to Tue 09/24/2019
0001 Continuous 2359

Work scheduled by: ConEd

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

ROCHESTR-PANNELL_345_RP2

Mon 09/23/2019 to Mon 09/30/2019
0500 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

KINTIGH_-ROCHESTR_345_SRL-39

Mon 09/23/2019 to Fri 09/27/2019
0600 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

LEEDS___345KV_R395

Fri 09/27/2019 to Fri 09/27/2019
1700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

UPNY CONED **3800 MW**
Impacts Total Transfer Capability 1900 MW
TTC with All Lines In Service 5700 MW

CLAY___-EDIC___345_1-16

Mon 09/30/2019 to Fri 10/04/2019
0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

OSWEGO EXPORT **4850 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 5250 MW

NYISO TRANSFER LIMITATIONS

Wednesday, February 13, 2019 to Friday, August 14, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LEEDS -HURLYAVE_345_301		FWD	
Mon 09/30/2019	to Sat 10/26/2019	(Import)	
0800	Continuous 1600	UPNY CONED	4100 MW
Work scheduled by: CHGE		Impacts Total Transfer Capability	1600 MW
		TTC with All Lines In Service	5700 MW
CLAY -EDIC_345_2-15		FWD	
Mon 10/07/2019	to Thu 10/17/2019	(Import)	
0700	Continuous 1530	OSWEGO EXPORT	4850 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	400 MW
		TTC with All Lines In Service	5250 MW
MARCY -N.SCTLND_345_18		FWD	
Wed 10/09/2019	to Fri 10/11/2019	(Import)	
0500	Continuous 1730	CENTRAL EAST - VC	2090 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	885 MW
		TTC with All Lines In Service	2975 MW
CHATGUAY-MASSENA_765_7040		FWD	
Sat 10/12/2019	to Sat 10/26/2019	(Import)	
0100	Continuous 1900	MOSES SOUTH	1550 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	1600 MW
		TTC with All Lines In Service	3150 MW
CHATGUAY-MASSENA_765_7040		FWD	REV
Sat 10/12/2019	to Sat 10/26/2019	(Import)	(Export)
0100	Continuous 1900	SCH - HQ - NY	0 MW 0 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	1500 MW 1000 MW
		TTC with All Lines In Service	1500 MW 1000 MW
MARCY_765_345_AT1		FWD	
Sat 10/12/2019	to Sat 10/26/2019	(Import)	
0100	Continuous 1900	MOSES SOUTH	1750 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	1400 MW
		TTC with All Lines In Service	3150 MW
MARCY_765_345_AT2		FWD	
Sat 10/12/2019	to Sat 10/26/2019	(Import)	
0100	Continuous 1900	MOSES SOUTH	1700 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	1450 MW
		TTC with All Lines In Service	3150 MW

ARR: 19

ARR: 19

ARR: 19

NYISO TRANSFER LIMITATIONS

Wednesday, February 13, 2019 to Friday, August 14, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>MASSENA -MARCY 765_MSU1</p> <p>Sat 10/12/2019 to Sat 10/26/2019 0100 Continuous 1900</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import)</p> <p>CENTRAL EAST - VC 2265 MW</p> <p>Impacts Total Transfer Capability 710 MW</p> <p>TTC with All Lines In Service 2975 MW</p>															
<p>MASSENA -MARCY 765_MSU1</p> <p>Sat 10/12/2019 to Sat 10/26/2019 0100 Continuous 1900</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import)</p> <p>MOSES SOUTH 500 MW</p> <p>Impacts Total Transfer Capability 2650 MW</p> <p>TTC with All Lines In Service 3150 MW</p>															
<p>MASSENA -MARCY 765_MSU1</p> <p>Sat 10/12/2019 to Sat 10/26/2019 0100 Continuous 1900</p> <p>Work scheduled by: NYPA</p>	<table border="0" style="width: 100%;"> <tr> <td style="width: 10%;"></td> <td style="width: 70%;">FWD</td> <td style="width: 20%;">REV</td> </tr> <tr> <td></td> <td>(Import)</td> <td>(Export)</td> </tr> <tr> <td>SCH - HQ - NY</td> <td>475 MW</td> <td>1000 MW</td> </tr> <tr> <td>Impacts Total Transfer Capability</td> <td>1025 MW</td> <td>0 MW</td> </tr> <tr> <td>TTC with All Lines In Service</td> <td>1500 MW</td> <td>1000 MW</td> </tr> </table>		FWD	REV		(Import)	(Export)	SCH - HQ - NY	475 MW	1000 MW	Impacts Total Transfer Capability	1025 MW	0 MW	TTC with All Lines In Service	1500 MW	1000 MW
	FWD	REV														
	(Import)	(Export)														
SCH - HQ - NY	475 MW	1000 MW														
Impacts Total Transfer Capability	1025 MW	0 MW														
TTC with All Lines In Service	1500 MW	1000 MW														
<p>MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040</p> <p>Sat 10/12/2019 to Sat 10/26/2019 0100 1900</p> <p>Work scheduled by:</p>	<p>FWD (Import)</p> <p>MOSES SOUTH 500 MW</p> <p>Impacts Total Transfer Capability 2650 MW</p> <p>TTC with All Lines In Service 3150 MW</p>															
<p>MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2</p> <p>Sat 10/12/2019 to Sat 10/26/2019 0100 1900</p> <p>Work scheduled by:</p>	<table border="0" style="width: 100%;"> <tr> <td style="width: 10%;"></td> <td style="width: 70%;">FWD</td> <td style="width: 20%;">REV</td> </tr> <tr> <td></td> <td>(Import)</td> <td>(Export)</td> </tr> <tr> <td>SCH - HQ - NY</td> <td>850 MW</td> <td>0 MW</td> </tr> <tr> <td>Impacts Total Transfer Capability</td> <td>650 MW</td> <td>1000 MW</td> </tr> <tr> <td>TTC with All Lines In Service</td> <td>1500 MW</td> <td>1000 MW</td> </tr> </table>		FWD	REV		(Import)	(Export)	SCH - HQ - NY	850 MW	0 MW	Impacts Total Transfer Capability	650 MW	1000 MW	TTC with All Lines In Service	1500 MW	1000 MW
	FWD	REV														
	(Import)	(Export)														
SCH - HQ - NY	850 MW	0 MW														
Impacts Total Transfer Capability	650 MW	1000 MW														
TTC with All Lines In Service	1500 MW	1000 MW														
<p>DUNWODIE_345KV_3</p> <p>Tue 10/22/2019 to Tue 10/22/2019 UPDATED by CONED 02/06/2019 0001 Continuous 0030</p> <p>Work scheduled by: ConEd</p>	<p>FWD (Import)</p> <p>SPR/DUN-SOUTH 3800 MW</p> <p>Impacts Total Transfer Capability 800 MW</p> <p>TTC with All Lines In Service 4600 MW</p>															
<p>DUNWODIE_345KV_5</p> <p>Tue 10/22/2019 to Tue 10/22/2019 UPDATED by CONED 02/06/2019 0001 Continuous 0030</p> <p>Work scheduled by: ConEd</p>	<p>FWD (Import)</p> <p>SPR/DUN-SOUTH 3800 MW</p> <p>Impacts Total Transfer Capability 800 MW</p> <p>TTC with All Lines In Service 4600 MW</p>															

NYISO TRANSFER LIMITATIONS

Wednesday, February 13, 2019 to Friday, August 14, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE-MOTTHAVN_345_71					FWD	
Tue 10/22/2019	to	Tue 11/26/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/06/2019</u>	(Import)
0001	Continuous	2359				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	800 MW
					Impacts Total Transfer Capability	4600 MW
					TTC with All Lines In Service	
NIAGARA_345_230_AT4					FWD	REV
Wed 10/23/2019	to	Wed 12/18/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>12/19/2018</u>	(Import) (Export)
0500	Continuous	1700				1900 MW 1400 MW
Work scheduled by: NYPA					SCH - OH - NY	0 MW 350 MW
					Impacts Total Transfer Capability	1900 MW 1750 MW
					TTC with All Lines In Service	
HURLYAVE-ROSETON_345_303					FWD	
Mon 11/04/2019	to	Fri 12/06/2019				(Import)
0800	Continuous	1600				4100 MW
Work scheduled by: CHGE					UPNY CONED	1600 MW
					Impacts Total Transfer Capability	5700 MW
					TTC with All Lines In Service	
PANNELL_-CLAY_345_2					FWD	
Wed 11/06/2019	to	Fri 11/22/2019				(Import)
0700	Continuous	1530				1300 MW
Work scheduled by: NYPA					WEST CENTRAL	950 MW
					Impacts Total Transfer Capability	2250 MW
					TTC with All Lines In Service	
MARCY_-N.SCTLND_345_18					FWD	
Thu 11/07/2019	to	Fri 11/08/2019				(Import)
0500	Continuous	1730				2090 MW
Work scheduled by: NYPA					CENTRAL EAST - VC	885 MW
					Impacts Total Transfer Capability	2975 MW
					TTC with All Lines In Service	
MARCY_345KV_CSC					FWD	
Thu 11/07/2019	to	Fri 11/08/2019				(Import)
0500	Continuous	1730				2925 MW
Work scheduled by: NYPA					CENTRAL EAST - VC	50 MW
					Impacts Total Transfer Capability	2975 MW
					TTC with All Lines In Service	
MOSES_-ADIRNDCK_230_MA2					FWD	
Tue 11/12/2019	to	Fri 11/15/2019				(Import)
0700	Continuous	1500				2300 MW
Work scheduled by: NYPA					MOSES SOUTH	850 MW
					Impacts Total Transfer Capability	3150 MW
					TTC with All Lines In Service	

NYISO TRANSFER LIMITATIONS

Wednesday, February 13, 2019 to Friday, August 14, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA2

Mon 11/18/2019 to Fri 11/22/2019
 0700 Continuous 1500
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 11/25/2019 to Wed 11/27/2019
 0700 Continuous 1500
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

DUNWODIE_345KV_3

Tue 11/26/2019 to Tue 11/26/2019 **UPDATED by CONED 02/06/2019**
 2330 Continuous 2359
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_5

Tue 11/26/2019 to Tue 11/26/2019 **UPDATED by CONED 02/06/2019**
 2330 Continuous 2359
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

MOSES___-ADIRNDCK_230_MA2

Mon 12/02/2019 to Fri 12/06/2019
 0700 Continuous 1500
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA1

Mon 12/09/2019 to Fri 12/13/2019
 0700 Continuous 1500
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 12/16/2019 to Mon 12/16/2019
 0700 Continuous 1500
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Wednesday, February 13, 2019 to Friday, August 14, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA1

Tue 12/17/2019 to Fri 12/20/2019
 0700 Continuous 1500
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

LADENTWN-BUCHAN_S_345_Y88

Wed 01/15/2020 to Thu 02/13/2020
 0001 Continuous 2359
 Work scheduled by: ORU

11/05/2018

FWD
 (Import)
 UPNY CONED **4800 MW**
 Impacts Total Transfer Capability 900 MW
 TTC with All Lines In Service 5700 MW

FRASANNX-COOPERS__345_UCC2-41

Mon 04/27/2020 to Sun 05/31/2020
 0700 Continuous 1530
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 CENTRAL EAST - VC **2500 MW**
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

MARCY___-FRASANNX_345_UCC2-41

Mon 04/27/2020 to Sun 05/31/2020
 0700 Continuous 1530
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 CENTRAL EAST - VC **2500 MW**
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW