

NYISO TRANSFER LIMITATIONS

Friday ,February 15, 2019 to Sunday ,August 16, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

	FWD	REV
HUDSONP_-FARRAGUT_345_B3402		
Mon 01/15/2018 to Tue 12/31/2019	(Import)	(Export)
0001 Continuous 2359	2600 MW	1300 MW
Work scheduled by: ConEd	Impacts Total Transfer Capability	0 MW 250 MW
	TTC with All Lines In Service	2600 MW 1550 MW
<hr/>		
HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403		
Mon 01/15/2018 to Tue 12/31/2019	(Import)	(Export)
0001 2359	2000 MW	1300 MW
Work scheduled by:	Impacts Total Transfer Capability	600 MW 250 MW
	TTC with All Lines In Service	2600 MW 1550 MW
<hr/>		
MARION_-FARRAGUT_345_C3403		
Mon 01/15/2018 to Tue 12/31/2019	(Import)	(Export)
0001 Continuous 2359	2600 MW	1300 MW
Work scheduled by: ConEd	Impacts Total Transfer Capability	0 MW 250 MW
	TTC with All Lines In Service	2600 MW 1550 MW
<hr/>		
STLAWRNC-MOSES_230_L33P		
Mon 04/30/2018 to Fri 12/31/2021	(Import)	(Export)
0456 Continuous 2359	2250 MW	2000 MW
Work scheduled by: IESO	Impacts Total Transfer Capability	0 MW 0 MW
	TTC with All Lines In Service	2250 MW 2000 MW
<hr/>		
S.RIPLEY-DUNKIRK_230_68		
Tue 01/15/2019 to Mon 04/08/2019	(Import)	(Export)
1128 Continuous 0759	2600 MW	1300 MW
Work scheduled by: PJM	Impacts Total Transfer Capability	0 MW 250 MW
	TTC with All Lines In Service	2600 MW 1550 MW
<hr/>		
DUNWODIE_345KV_6		
Wed 01/23/2019 to Fri 03/01/2019	(Import)	
0001 Continuous 2359	3800 MW	
Work scheduled by: ConEd	Impacts Total Transfer Capability	800 MW
	TTC with All Lines In Service	4600 MW
<hr/>		
SCH-IMO-NYISO_LIMIT_1900		
Sat 02/09/2019 to Sun 02/10/2019	(Import)	
1700 Continuous 2359	2200 MW	
Work scheduled by: IESO	Impacts Total Transfer Capability	50 MW
	TTC with All Lines In Service	2250 MW

NYISO TRANSFER LIMITATIONS

Friday ,February 15, 2019 to Sunday ,August 16, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO-NYISO_LIMIT_1700

Mon 02/11/2019 to Fri 12/31/2021
0001 Continuous 2359

Work scheduled by: IESO

FWD
(Import)
SCH - OH - NY **2000 MW**
Impacts Total Transfer Capability 250 MW
TTC with All Lines In Service 2250 MW

MOSES -ADIRNDCK_230_MAI

Mon 02/11/2019 to Fri 02/15/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

GOETHALS_345KV_5

Wed 02/13/2019 to Sat 02/16/2019 **CANCELLED by ConEd 02/12/2019**
0400 Continuous 0130

Work scheduled by: ConEd

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

W49TH_ST-E13THSTA_345_M55

Wed 02/13/2019 to Fri 02/22/2019 **EXT FORCE by CE 02/14/2019**
0652 Continuous 2359

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

W49TH_ST_345KV_6

Wed 02/13/2019 to Fri 02/22/2019 **EXT FORCE by CE 02/14/2019**
0652 Continuous 2359

Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **375 MW**
Impacts Total Transfer Capability 285 MW
TTC with All Lines In Service 660 MW

MILLWOOD-EASTVIEW_345_W99

Thu 02/14/2019 to Thu 02/14/2019 **UPDATED by CONED 02/08/2019**
0001 Continuous 0030

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1350 MW
TTC with All Lines In Service 5700 MW

SPRNBRK_345KV_RNS5

Thu 02/14/2019 to Thu 02/14/2019 **UPDATED by CONED 02/08/2019**
0001 Continuous 0030

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Friday ,February 15, 2019 to Sunday ,August 16, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EASTVIEW-SPRNBK__345_W64					FWD	
Thu 02/14/2019	to	Thu 02/14/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/08/2019</u>	(Import)
0001	Continuous	2230				4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1350 MW	
					TTC with All Lines In Service 5700 MW	
BECK__-NIAGARA__345_PA302					FWD	
Thu 02/14/2019	to	Thu 02/14/2019	<u>CANCELLED</u>	<u>by IESO</u>	<u>02/14/2019</u>	(Import) (Export)
0500	Continuous	1700				1100 MW 950 MW
Work scheduled by: IESO					Impacts Total Transfer Capability 1150 MW 1050 MW	
					TTC with All Lines In Service 2250 MW 2000 MW	
MILLWOOD-EASTVIEW_345_W99					FWD	
Thu 02/14/2019	to	Thu 02/14/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/08/2019</u>	(Import)
2200	Continuous	2230				4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1350 MW	
					TTC with All Lines In Service 5700 MW	
SPRNBK__345KV_RNS5					FWD	
Thu 02/14/2019	to	Thu 02/14/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/08/2019</u>	(Import)
2200	Continuous	2230				3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1400 MW	
					TTC with All Lines In Service 4600 MW	
SCRIBA__-VOLNEY__345_20					FWD	
Sat 02/16/2019	to	Sun 02/17/2019				(Import)
0600	Continuous	1900				5250 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 0 MW	
					TTC with All Lines In Service 5250 MW	
BECK__-NIAGARA__345_PA302					FWD	
Tue 02/19/2019	to	Tue 02/19/2019	<u>CANCELLED</u>	<u>by IESO</u>	<u>02/15/2019</u>	(Import) (Export)
0500	Continuous	1700				1100 MW 950 MW
Work scheduled by: IESO					Impacts Total Transfer Capability 1150 MW 1050 MW	
					TTC with All Lines In Service 2250 MW 2000 MW	
MOSES__-ADIRNDCK_230_MA2					FWD	
Tue 02/19/2019	to	Fri 02/22/2019	<u>CANCELLED</u>	<u>by NYPA</u>	<u>02/12/2019</u>	(Import)
0700	Continuous	1500				2300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 850 MW	
					TTC with All Lines In Service 3150 MW	

NYISO TRANSFER LIMITATIONS

Friday ,February 15, 2019 to Sunday ,August 16, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>ADIRNDCK-PORTER_230_12</p> <p>Wed 02/20/2019 to Wed 02/20/2019 0700 Daily(No Weekends) 1530</p> <p>Work scheduled by: NGrid</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH 2300 MW</p> <p>Impacts Total Transfer Capability 850 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>MOSES-ADIRNDCK_230_MA2</p> <p>Wed 02/20/2019 to Wed 02/20/2019 0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH 2300 MW</p> <p>Impacts Total Transfer Capability 850 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>FIVEMILE-STOLLERD_345_29</p> <p>Wed 02/20/2019 to Fri 02/22/2019 0730 Continuous 1900</p> <p>Work scheduled by: NGrid</p>	<p style="text-align: right;">FWD REV (Import) (Export)</p> <p>SCH - PJ - NY 2600 MW 1300 MW</p> <p>Impacts Total Transfer Capability 0 MW 250 MW</p> <p>TTC with All Lines In Service 2600 MW 1550 MW</p>
<p>CHAT_DC_GC2</p> <p>Thu 02/21/2019 to Thu 02/21/2019 0500 Continuous 1800</p> <p>Work scheduled by: HQ</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH 2850 MW</p> <p>Impacts Total Transfer Capability 300 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>CHAT_DC_GC2</p> <p>Thu 02/21/2019 to Thu 02/21/2019 0500 Continuous 1800</p> <p>Work scheduled by: HQ</p>	<p style="text-align: right;">REV (Export)</p> <p>SCH - HQ - NY 500 MW</p> <p>Impacts Total Transfer Capability 500 MW</p> <p>TTC with All Lines In Service 1000 MW</p>
<p>ADIRNDCK-CHASLAKE_230_13</p> <p>Thu 02/21/2019 to Thu 02/21/2019 0700 Daily(No Weekends) 1530</p> <p>Work scheduled by: NGrid</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH 2300 MW</p> <p>Impacts Total Transfer Capability 850 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>MOSES-ADIRNDCK_230_MA1</p> <p>Thu 02/21/2019 to Thu 02/21/2019 0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH 2300 MW</p> <p>Impacts Total Transfer Capability 850 MW</p> <p>TTC with All Lines In Service 3150 MW</p>

NYISO TRANSFER LIMITATIONS

Friday ,February 15, 2019 to Sunday ,August 16, 2020

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -ADIRNDCK_230_MA1				FWD		
Mon 02/25/2019	to	Fri 03/01/2019		(Import)		
0700	Continuous	1500		MOSES SOUTH	2300 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW	
				TTC with All Lines In Service	3150 MW	
SCRIBA -VOLNEY_345_21				FWD		
Wed 02/27/2019	to	Thu 02/28/2019	UPDATED by NGRID 12/11/2018	(Import)		
0730	Continuous	2000		OSWEGO EXPORT	5250 MW	
Work scheduled by: NGrid				Impacts Total Transfer Capability	0 MW	
				TTC with All Lines In Service	5250 MW	
ATHENS -PLSNTVLY_345_91				FWD		
Thu 02/28/2019	to	Thu 02/28/2019		(Import)		
0630	Continuous	2230		UPNY CONED	3800 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	1900 MW	
				TTC with All Lines In Service	5700 MW	
PLSNTVLY_345KV_RNS4				FWD		
Thu 02/28/2019	to	Thu 02/28/2019		(Import)		
0630	Continuous	2230		UPNY CONED	3800 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	1900 MW	
				TTC with All Lines In Service	5700 MW	
PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4				FWD		
Fri 03/01/2019	to	Mon 03/04/2019		(Import)		
0001		0200		UPNY CONED	3800 MW	
Work scheduled by:				Impacts Total Transfer Capability	1900 MW	
				TTC with All Lines In Service	5700 MW	
LONG_MTN-PLSNTVLY_345_398				FWD	REV	
Fri 03/01/2019	to	Sun 05/19/2019	UPDATED by ISONE 01/30/2019	(Import)	(Export)	
0001	Continuous	2359		SCH - NE - NY	700 MW	1250 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	700 MW	550 MW
				TTC with All Lines In Service	1400 MW	1800 MW
LONG_MTN-PLSNTVLY_345_398				FWD	REV	
Fri 03/01/2019	to	Sun 05/19/2019	UPDATED by ISONE 01/30/2019	(Import)	(Export)	
0001	Continuous	2359		SCH - NPX_1385	100 MW	100 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	100 MW	100 MW
				TTC with All Lines In Service	200 MW	200 MW

NYISO TRANSFER LIMITATIONS

Friday ,February 15, 2019 to Sunday ,August 16, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-NE_LIMIT_700						REV
Fri 03/01/2019	to	Sun 05/19/2019	<u>UPDATED</u>	<u>by ISONE</u>	<u>01/30/2019</u>	(Export)
0001	Continuous	2359				900 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 900 MW
						TTC with All Lines In Service 1800 MW
PLSNTVLY-EFISHKIL_345_F37						FWD
Mon 03/04/2019	to	Wed 03/06/2019	<u>UPDATED</u>	<u>by ISONE</u>	<u>01/30/2019</u>	(Import)
0201	Continuous	0300				4000 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 1700 MW
						TTC with All Lines In Service 5700 MW
SCRIBA_-VOLNEY___345_20						FWD
Mon 03/04/2019	to	Tue 03/05/2019				(Import)
0600	Continuous	1800				5250 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability 0 MW
						TTC with All Lines In Service 5250 MW
MOSES_-ADIRNDCK_230_MA1						FWD
Mon 03/04/2019	to	Fri 03/08/2019				(Import)
0700	Continuous	1500				2300 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 850 MW
						TTC with All Lines In Service 3150 MW
DUNWODIE_345KV_4						FWD
Thu 03/07/2019	to	Thu 03/07/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/06/2019</u>	(Import)
0001	Continuous	0030				3800 MW
Work scheduled by: LI						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_6						FWD
Thu 03/07/2019	to	Thu 03/07/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/06/2019</u>	(Import)
0001	Continuous	0030				3800 MW
Work scheduled by: LI						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
DUNWODIE-SHORE_RD_345_Y50						FWD
Thu 03/07/2019	to	Fri 03/08/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/06/2019</u>	(Import)
0001	Continuous	2359				800 MW
Work scheduled by: LI						Impacts Total Transfer Capability 700 MW
						TTC with All Lines In Service 1500 MW

NYISO TRANSFER LIMITATIONS

Friday ,February 15, 2019 to Sunday ,August 16, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					FWD
SHORE_RD_345_138_BK 1					(Import)
Thu 03/07/2019	to	Fri 03/08/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/06/2019</u>
0001	Continuous	2359			
Work scheduled by: LI					CONED - LIPA 1350 MW
					Impacts Total Transfer Capability 150 MW
					TTC with All Lines In Service 1500 MW
<hr/>					FWD
SHORE_RD_345_138_BK 2					(Import)
Thu 03/07/2019	to	Fri 03/08/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/06/2019</u>
0001	Continuous	2359			
Work scheduled by: LI					CONED - LIPA 1350 MW
					Impacts Total Transfer Capability 150 MW
					TTC with All Lines In Service 1500 MW
<hr/>					FWD
EASTVIEW-SPRNBRK_345_W64					(Import)
Thu 03/07/2019	to	Mon 03/11/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/08/2019</u>
0001	Continuous	0200			
Work scheduled by: ConEd					UPNY CONED 4350 MW
					Impacts Total Transfer Capability 1350 MW
					TTC with All Lines In Service 5700 MW
<hr/>					FWD
MILLWOOD-EASTVIEW_345_W99					(Import)
Thu 03/07/2019	to	Mon 03/11/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/08/2019</u>
0001	Continuous	0200			
Work scheduled by: ConEd					UPNY CONED 4350 MW
					Impacts Total Transfer Capability 1350 MW
					TTC with All Lines In Service 5700 MW
<hr/>					FWD
DUNWODIE_345KV_4					(Import)
Fri 03/08/2019	to	Fri 03/08/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/06/2019</u>
2330	Continuous	2359			
Work scheduled by: LI					SPR/DUN-SOUTH 3800 MW
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
<hr/>					FWD
DUNWODIE_345KV_6					(Import)
Fri 03/08/2019	to	Fri 03/08/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/06/2019</u>
2330	Continuous	2359			
Work scheduled by: LI					SPR/DUN-SOUTH 3800 MW
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
<hr/>					FWD
MILLWOOD_345KV_18					(Import)
Mon 03/11/2019	to	Mon 03/11/2019			
0001	Continuous	0030			
Work scheduled by: ConEd					UPNY CONED 4350 MW
					Impacts Total Transfer Capability 1350 MW
					TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Friday ,February 15, 2019 to Sunday ,August 16, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LADENTWN-BUCHAN_S_345_Y88					FWD	
Mon 03/11/2019	to	Thu 03/28/2019			(Import)	
0001	Continuous	0200		UPNY CONED	4800 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability 900 MW	
					TTC with All Lines In Service 5700 MW	
BECK__-NIAGARA_345_PA301					FWD REV	
Mon 03/11/2019	to	Fri 03/15/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>02/06/2019</u>	(Import) (Export)
0600	Continuous	1700		SCH - OH - NY	1100 MW 950 MW	
Work scheduled by: NYPA					Impacts Total Transfer Capability 1150 MW 1050 MW	
					TTC with All Lines In Service 2250 MW 2000 MW	
STLAWRNC-MOSES__230_L33P & STLAWRNC-MOSES__230_L34P					FWD	
Mon 03/11/2019	to	Mon 03/11/2019			(Import)	
0700		1530		MOSES SOUTH	2700 MW	
Work scheduled by:					Impacts Total Transfer Capability 450 MW	
					TTC with All Lines In Service 3150 MW	
STLAWRNC-MOSES__230_L34P					FWD REV	
Mon 03/11/2019	to	Mon 03/11/2019			(Import) (Export)	
0700	Continuous	1530		SCH - OH - NY	2250 MW 2000 MW	
Work scheduled by: NYPA					Impacts Total Transfer Capability 0 MW 0 MW	
					TTC with All Lines In Service 2250 MW 2000 MW	
LEEDS__345_LEEDS SVC					FWD	
Mon 03/11/2019	to	Fri 03/22/2019			(Import)	
0800	Continuous	1600		CENTRAL EAST - VC	2950 MW	
Work scheduled by: NGrid					Impacts Total Transfer Capability 25 MW	
					TTC with All Lines In Service 2975 MW	
MOSES__-ADIRNDCK_230_MA1					FWD	
Tue 03/12/2019	to	Fri 03/15/2019			(Import)	
0700	Continuous	1500		MOSES SOUTH	2300 MW	
Work scheduled by: NYPA					Impacts Total Transfer Capability 850 MW	
					TTC with All Lines In Service 3150 MW	
MILLWOOD_345KV_18					FWD	
Wed 03/13/2019	to	Thu 03/14/2019			(Import)	
0001	Continuous	0200		UPNY CONED	4350 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability 1350 MW	
					TTC with All Lines In Service 5700 MW	

NYISO TRANSFER LIMITATIONS

Friday ,February 15, 2019 to Sunday ,August 16, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT1

Mon 03/18/2019 to Fri 03/22/2019
0500 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1750 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 3150 MW

SCH-NYISO-HQ_CEDARS_LIMIT_0

Mon 03/18/2019 to Thu 04/04/2019
0700 Continuous 1700

Work scheduled by: HQ

REV
(Export)
SCH - HQ_CEDARS **0 MW**
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 100 MW

MILLWOOD_345KV_18

Thu 03/28/2019 to Thu 03/28/2019
0130 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1350 MW
TTC with All Lines In Service 5700 MW

MARCY___345KV_CSC

Mon 04/01/2019 to Sun 04/07/2019
0500 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2925 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

VOLNEY_-MARCY___345_19

Mon 04/01/2019 to Wed 04/10/2019
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2825 MW**
Impacts Total Transfer Capability 150 MW
TTC with All Lines In Service 2975 MW

VOLNEY_-MARCY___345_19

Mon 04/01/2019 to Wed 04/10/2019
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
OSWEGO EXPORT **4900 MW**
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 5250 MW

PLSNTVLY-EFISHRIL_345_F37

Thu 04/04/2019 to Mon 04/08/2019
0001 Continuous 0200

Work scheduled by: ConEd

UPDATED by ISONE 01/30/2019

FWD
(Import)
UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1700 MW
TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Friday ,February 15, 2019 to Sunday ,August 16, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-ROCHESTR_345_NR2

Fri 04/05/2019 to Fri 04/05/2019
 0500 Continuous 1700
 Work scheduled by: NYPA

FWD
 (Import)
DYSINGER EAST 1700 MW
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

LINDN_CG-LNDVFT___345_V-3022

Sun 04/07/2019 to Fri 04/12/2019
 1400 Continuous 1800
 Work scheduled by: PJM

FWD REV
 (Import) (Export)
SCH - PJM_VFT 0 MW 0 MW
 Impacts Total Transfer Capability 315 MW 315 MW
 TTC with All Lines In Service 315 MW 315 MW

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4

Mon 04/08/2019 to Sat 04/13/2019
 0001 0300
 Work scheduled by:

FWD
 (Import)
UPNY CONED 3800 MW
 Impacts Total Transfer Capability 1900 MW
 TTC with All Lines In Service 5700 MW

PLSNTVLE-DUNWODIE_345_W89

Mon 04/08/2019 to Fri 05/10/2019
 0001 Continuous 2359
 Work scheduled by: ConEd

FWD
 (Import)
UPNY CONED 4000 MW
 Impacts Total Transfer Capability 1700 MW
 TTC with All Lines In Service 5700 MW

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Mon 04/08/2019 to Tue 04/09/2019
 0600 Continuous 1800
 Work scheduled by: LI

FWD
 (Import)
SCH - PJM_NEPTUNE 0 MW
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE-DUFFYAVE_345_501

Mon 04/08/2019 to Tue 04/09/2019
 0600 Continuous 1800
 Work scheduled by: LI

FWD
 (Import)
SCH - PJM_NEPTUNE 0 MW
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_1

Mon 04/08/2019 to Tue 04/09/2019
 0600 Continuous 1800
 Work scheduled by: LI

FWD
 (Import)
SCH - PJM_NEPTUNE 375 MW
 Impacts Total Transfer Capability 285 MW
 TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Friday ,February 15, 2019 to Sunday ,August 16, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE_345_138_BK_2

Mon 04/08/2019 to Tue 04/09/2019
 0600 Continuous 1800
 Work scheduled by: LI

FWD
 (Import)
 SCH - PJM_NEPTUNE **375 MW**
 Impacts Total Transfer Capability 285 MW
 TTC with All Lines In Service 660 MW

S.RIPLEY-DUNKIRK_230_68

Mon 04/08/2019 to Mon 04/15/2019 **UPDATED by PJM 02/11/2019**
 0800 Continuous 2000
 Work scheduled by: PJM

FWD REV
 (Import) (Export)
 SCH - PJ - NY **2600 MW 1300 MW**
 Impacts Total Transfer Capability 0 MW 250 MW
 TTC with All Lines In Service 2600 MW 1550 MW

MARCY_345KV_CSC

Thu 04/11/2019 to Wed 04/17/2019
 0500 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2925 MW**
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 2975 MW

MARCY-EDIC_345_UE1-7

Thu 04/11/2019 to Sat 04/20/2019
 0500 Continuous 1730
 Work scheduled by: NYPA

ARR: 19&16

FWD
 (Import)
 OSWEGO EXPORT **5250 MW**
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 5250 MW

SCRIBA-VOLNEY_345_20

Mon 04/15/2019 to Tue 04/16/2019
 0600 Continuous 1800
 Work scheduled by: NGrid

FWD
 (Import)
 OSWEGO EXPORT **5250 MW**
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 5250 MW

GILBOA-N.SCTLND_345_GNS-1

Thu 04/18/2019 to Thu 04/18/2019 **UPDATED by NYPA 01/23/2019**
 1330 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2520 MW**
 Impacts Total Transfer Capability 455 MW
 TTC with All Lines In Service 2975 MW

MARCY_765_345_AT2

Mon 04/22/2019 to Fri 04/26/2019
 0500 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,February 15, 2019 to Sunday ,August 16, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>EDIC ___-FRASER___ 345_EF24-40</p> <p>Mon 04/22/2019 to Sun 04/28/2019</p> <p style="padding-left: 40px;">0500 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC 2500 MW</p> <p>Impacts Total Transfer Capability 475 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p>SPRNBRK ___345KV_RNS5</p> <p>Mon 04/29/2019 to Mon 04/29/2019</p> <p style="padding-left: 40px;">0001 Continuous 0030</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>SPR/DUN-SOUTH 3200 MW</p> <p>Impacts Total Transfer Capability 1400 MW</p> <p>TTC with All Lines In Service 4600 MW</p>
<p>SPRNBRK ___W49TH_ST_345_M51</p> <p>Mon 04/29/2019 to Sun 05/05/2019</p> <p style="padding-left: 40px;">0001 Continuous 2200</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>SPR/DUN-SOUTH 3200 MW</p> <p>Impacts Total Transfer Capability 1400 MW</p> <p>TTC with All Lines In Service 4600 MW</p>
<p>FRASANX-COOPERS ___345_UCC2-41</p> <p>Mon 04/29/2019 to Fri 05/03/2019</p> <p style="padding-left: 40px;">0500 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC 2500 MW</p> <p>Impacts Total Transfer Capability 475 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p>MARCY ___-FRASANX_345_UCC2-41</p> <p>Mon 04/29/2019 to Fri 05/03/2019</p> <p style="padding-left: 40px;">0500 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC 2500 MW</p> <p>Impacts Total Transfer Capability 475 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p>MOSES ___-ADIRNDCK_230_MA1</p> <p>Mon 04/29/2019 to Fri 05/03/2019</p> <p style="padding-left: 40px;">0700 Continuous 1500</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH 2300 MW</p> <p>Impacts Total Transfer Capability 850 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>EGRDNCTY 345_138_AT2</p> <p>Wed 05/01/2019 to Wed 05/15/2019</p> <p style="padding-left: 40px;">0001 Continuous 2359</p> <p>Work scheduled by: LI</p>	<p style="text-align: right;">FWD (Import)</p> <p>CONED - LIPA 1250 MW</p> <p>Impacts Total Transfer Capability 250 MW</p> <p>TTC with All Lines In Service 1500 MW</p>

NYISO TRANSFER LIMITATIONS

Friday ,February 15, 2019 to Sunday ,August 16, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
HUDSONTP-W49TH_ST_345_Y56			FWD
Wed 05/01/2019	to	Tue 05/07/2019	(Import)
0600	Continuous	1800	SCH - PJM_HTP 0 MW
Work scheduled by: PJM			
		Impacts Total Transfer Capability	660 MW
		TTC with All Lines In Service	660 MW
<hr/>			
SPRNBRK_345KV_RNS5			FWD
Sun 05/05/2019	to	Sun 05/05/2019	(Import)
2130	Continuous	2200	SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd			
		Impacts Total Transfer Capability	1400 MW
		TTC with All Lines In Service	4600 MW
<hr/>			
KINTIGH_-ROCHESTR_345_SRL-39			FWD
Mon 05/06/2019	to	Fri 05/10/2019	(Import)
0600	Continuous	1700	UPDATED by NYSEG 11/08/2018 DYSINGER EAST 1400 MW
Work scheduled by: NYPA			
		Impacts Total Transfer Capability	1750 MW
		TTC with All Lines In Service	3150 MW
<hr/>			
SHOR_NPX-SHOREHAM_138_CSC			FWD REV
Mon 05/06/2019	to	Fri 05/10/2019	(Import) (Export)
0700	Continuous	1800	SCH - NPX_CSC 0 MW 0 MW
Work scheduled by: LI			
		Impacts Total Transfer Capability	330 MW 330 MW
		TTC with All Lines In Service	330 MW 330 MW
<hr/>			
ROSETON_-ROCKTVRN_345_311			FWD
Mon 05/06/2019	to	Sat 06/01/2019	(Import)
0800	Continuous	1600	UPNY CONED 4400 MW
Work scheduled by: CHGE			
		Impacts Total Transfer Capability	1300 MW
		TTC with All Lines In Service	5700 MW
<hr/>			
NIAGARA_-ROCHESTR_345_NR2			FWD
Mon 05/13/2019	to	Fri 05/17/2019	(Import)
0600	Continuous	1700	DYSINGER EAST 1400 MW
Work scheduled by: NYPA			
		Impacts Total Transfer Capability	1750 MW
		TTC with All Lines In Service	3150 MW
<hr/>			
ADIRNDCK-PORTER_230_12			FWD
Mon 05/20/2019	to	Fri 05/24/2019	(Import)
0700	Continuous	1530	MOSES SOUTH 2100 MW
Work scheduled by: NYPA			
		Impacts Total Transfer Capability	1050 MW
		TTC with All Lines In Service	3150 MW
<hr/>			

NYISO TRANSFER LIMITATIONS

Friday ,February 15, 2019 to Sunday ,August 16, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PANNELL_-CLAY_____345_1

Mon 05/20/2019 to Fri 05/24/2019
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

ROSETON_-EFISHKIL_345_RFK305

Thu 05/23/2019 to Thu 05/23/2019
0800 Daily 1600

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4800 MW**
Impacts Total Transfer Capability 900 MW
TTC with All Lines In Service 5700 MW

SCRIBA_-VOLNEY___345_20

Tue 05/28/2019 to Tue 05/28/2019
0600 Continuous 1800

Work scheduled by: NGrid

FWD
(Import)
OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

PANNELL_-CLAY_____345_2

Mon 06/03/2019 to Fri 06/07/2019
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

MOSES___-ADIRNDCK_230_MA2

Mon 06/24/2019 to Fri 06/28/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 07/08/2019 to Fri 07/12/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

ADIRNDCK-CHASLAKE_230_13

Mon 07/08/2019 to Fri 07/12/2019
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,February 15, 2019 to Sunday ,August 16, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT2					FWD
Sat 08/03/2019	to	Sun 08/04/2019			(Import)
0500	Continuous	1730			MOSES SOUTH 1700 MW
Work scheduled by: NYPA			ARR: 19		Impacts Total Transfer Capability 1450 MW
					TTC with All Lines In Service 3150 MW
MOSES___-ADIRNDCK_230_MA1					FWD
Mon 08/12/2019	to	Mon 08/12/2019	UPDATED	by NYPA	(Import)
0700	Continuous	1459		10/10/2018	MOSES SOUTH 2100 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 1050 MW
					TTC with All Lines In Service 3150 MW
SHOR_NPX-SHOREHAM_138_CSC					FWD
Tue 09/03/2019	to	Wed 09/04/2019	UPDATED	by ISONE	REV
0300	Continuous	1600		02/15/2019	(Import) (Export)
Work scheduled by: LI					SCH - NPX_CSC 0 MW 0 MW
					Impacts Total Transfer Capability 330 MW 330 MW
					TTC with All Lines In Service 330 MW 330 MW
MARCY___765_345_AT1					FWD
Tue 09/03/2019	to	Tue 09/03/2019			(Import)
0500	Continuous	1730			MOSES SOUTH 1750 MW
Work scheduled by: NYPA			ARR: 19		Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 3150 MW
MARCY___-N.SCTLND_345_18					FWD
Wed 09/04/2019	to	Wed 09/04/2019	UPDATED	by NYPA	(Import)
0500	Continuous	1730		11/06/2018	CENTRAL EAST - VC 2090 MW
Work scheduled by: NYPA			ARR: 19		Impacts Total Transfer Capability 885 MW
					TTC with All Lines In Service 2975 MW
MARCY___345KV_CSC					FWD
Wed 09/04/2019	to	Wed 09/04/2019	UPDATED	by NYPA	(Import)
0500	Continuous	1730		11/06/2018	CENTRAL EAST - VC 2925 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 50 MW
					TTC with All Lines In Service 2975 MW
MOSES___-ADIRNDCK_230_MA2					FWD
Wed 09/04/2019	to	Wed 09/04/2019			(Import)
0700	Continuous	1500			MOSES SOUTH 2100 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 1050 MW
					TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,February 15, 2019 to Sunday ,August 16, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ADIRNDCK-PORTER___230_12

Wed 09/04/2019 to Wed 09/04/2019
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

ADIRNDCK-CHASLAKE_230_13

Thu 09/05/2019 to Thu 09/05/2019
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

NIAGARA_-ROCHESTR_345_NR2

Mon 09/09/2019 to Sat 09/21/2019
0500 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

LEEDS___345KV_R395

Mon 09/09/2019 to Mon 09/09/2019
0700 Continuous 0730

Work scheduled by: NYPA

FWD
(Import)
UPNY CONED **3800 MW**
Impacts Total Transfer Capability 1900 MW
TTC with All Lines In Service 5700 MW

GILBOA_-LEEDS___345_GL3

Mon 09/09/2019 to Fri 09/27/2019
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2200 MW**
Impacts Total Transfer Capability 775 MW
TTC with All Lines In Service 2975 MW

MARCY___-N.SCTLND_345_18

Wed 09/11/2019 to Fri 09/13/2019
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2090 MW**
Impacts Total Transfer Capability 885 MW
TTC with All Lines In Service 2975 MW

MOSES___-ADIRNDCK_230_MA2

Mon 09/16/2019 to Fri 09/20/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,February 15, 2019 to Sunday ,August 16, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

GOETHALS_345KV_5

Fri 09/20/2019 to Tue 09/24/2019
 0001 Continuous 2359
 Work scheduled by: ConEd

STATEN ISLAND
 Impacts Total Transfer Capability
 TTC with All Lines In Service

ROCHESTR-PANNELL_345_RP2

Mon 09/23/2019 to Mon 09/30/2019
 0500 Continuous 1700
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

KINTIGH_-ROCHESTR_345_SRI-39

Mon 09/23/2019 to Fri 09/27/2019
 0600 Continuous 1700
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **1400 MW**
 Impacts Total Transfer Capability 1750 MW
 TTC with All Lines In Service 3150 MW

LEEDS_345KV_R395

Fri 09/27/2019 to Fri 09/27/2019
 1700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 1900 MW
 TTC with All Lines In Service 5700 MW

CLAY_-EDIC_345_1-16

Mon 09/30/2019 to Fri 10/04/2019
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 OSWEGO EXPORT **4850 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 5250 MW

LEEDS_-HURLYAVE_345_301

Mon 09/30/2019 to Sat 10/26/2019
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4100 MW**
 Impacts Total Transfer Capability 1600 MW
 TTC with All Lines In Service 5700 MW

CLAY_-EDIC_345_2-15

Mon 10/07/2019 to Thu 10/17/2019
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 OSWEGO EXPORT **4850 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 5250 MW

NYISO TRANSFER LIMITATIONS

Friday ,February 15, 2019 to Sunday ,August 16, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___-N.SCTLND_345_18

Wed 10/09/2019 to Fri 10/11/2019
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2090 MW**
Impacts Total Transfer Capability 885 MW
TTC with All Lines In Service 2975 MW

CHATGUAY-MASSENA__765_7040

Sat 10/12/2019 to Sat 10/26/2019
0100 Continuous 1900

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **1550 MW**
Impacts Total Transfer Capability 1600 MW
TTC with All Lines In Service 3150 MW

CHATGUAY-MASSENA__765_7040

Sat 10/12/2019 to Sat 10/26/2019
0100 Continuous 1900

Work scheduled by: NYPA

FWD REV
(Import) (Export)
SCH - HQ - NY **0 MW 0 MW**
Impacts Total Transfer Capability 1500 MW 1000 MW
TTC with All Lines In Service 1500 MW 1000 MW

MARCY___765_345_AT1

Sat 10/12/2019 to Sat 10/26/2019
0100 Continuous 1900

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1750 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 3150 MW

MARCY___765_345_AT2

Sat 10/12/2019 to Sat 10/26/2019
0100 Continuous 1900

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

MASSENA_-MARCY___765_MSU1

Sat 10/12/2019 to Sat 10/26/2019
0100 Continuous 1900

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2265 MW**
Impacts Total Transfer Capability 710 MW
TTC with All Lines In Service 2975 MW

MASSENA_-MARCY___765_MSU1

Sat 10/12/2019 to Sat 10/26/2019
0100 Continuous 1900

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **500 MW**
Impacts Total Transfer Capability 2650 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,February 15, 2019 to Sunday ,August 16, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>				
MASSENA_-MARCY_765_MSU1				
Sat 10/12/2019	to	Sat 10/26/2019		FWD (Import) REV (Export)
0100	Continuous	1900		SCH - HQ - NY 475 MW 1000 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 1025 MW 0 MW
				TTC with All Lines In Service 1500 MW 1000 MW
<hr/>				
MASSENA_-MARCY_765_MSU1 & CHATGUAY-MASSENA_765_7040				FWD (Import)
Sat 10/12/2019	to	Sat 10/26/2019		MOSES SOUTH 500 MW
0100		1900		Impacts Total Transfer Capability 2650 MW
Work scheduled by:				TTC with All Lines In Service 3150 MW
<hr/>				
MOSES_-MASSENA_230_MMS1 & MOSES_-MASSENA_230_MMS2				FWD (Import) REV (Export)
Sat 10/12/2019	to	Sat 10/26/2019		SCH - HQ - NY 850 MW 0 MW
0100		1900		Impacts Total Transfer Capability 650 MW 1000 MW
Work scheduled by:				TTC with All Lines In Service 1500 MW 1000 MW
<hr/>				
DUNWODIE_345KV_3				FWD (Import)
Tue 10/22/2019	to	Tue 10/22/2019	<u>UPDATED</u> by CONED 02/06/2019	SPR/DUN-SOUTH 3800 MW
0001	Continuous	0030		Impacts Total Transfer Capability 800 MW
Work scheduled by: ConEd				TTC with All Lines In Service 4600 MW
<hr/>				
DUNWODIE_345KV_5				FWD (Import)
Tue 10/22/2019	to	Tue 10/22/2019	<u>UPDATED</u> by CONED 02/06/2019	SPR/DUN-SOUTH 3800 MW
0001	Continuous	0030		Impacts Total Transfer Capability 800 MW
Work scheduled by: ConEd				TTC with All Lines In Service 4600 MW
<hr/>				
DUNWODIE-MOTTHAVN_345_71				FWD (Import)
Tue 10/22/2019	to	Tue 11/26/2019	<u>UPDATED</u> by CONED 02/06/2019	SPR/DUN-SOUTH 3800 MW
0001	Continuous	2359		Impacts Total Transfer Capability 800 MW
Work scheduled by: ConEd				TTC with All Lines In Service 4600 MW
<hr/>				
NIAGARA_345_230_AT4				FWD (Import) REV (Export)
Wed 10/23/2019	to	Wed 12/18/2019	<u>UPDATED</u> by NYPA 12/19/2018	SCH - OH - NY 1900 MW 1400 MW
0500	Continuous	1700		Impacts Total Transfer Capability 0 MW 350 MW
Work scheduled by: NYPA				TTC with All Lines In Service 1900 MW 1750 MW

NYISO TRANSFER LIMITATIONS

Friday ,February 15, 2019 to Sunday ,August 16, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HURLYAVE-ROSETON__345_303

Mon 11/04/2019 to Fri 12/06/2019
0800 Continuous 1600

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 1600 MW
TTC with All Lines In Service 5700 MW

PANNELL_-CLAY_____345_2

Wed 11/06/2019 to Fri 11/22/2019
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

MARCY___-N.SCTLND_345_18

Thu 11/07/2019 to Fri 11/08/2019
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2090 MW**
Impacts Total Transfer Capability 885 MW
TTC with All Lines In Service 2975 MW

MARCY_____345KV_CSC

Thu 11/07/2019 to Fri 11/08/2019
0500 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2925 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

MOSES___-ADIRNDCK_230_MA2

Tue 11/12/2019 to Fri 11/15/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 11/18/2019 to Fri 11/22/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 11/25/2019 to Wed 11/27/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,February 15, 2019 to Sunday ,August 16, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_3

Tue 11/26/2019 to Tue 11/26/2019
 2330 Continuous 2359
 Work scheduled by: ConEd

UPDATED by CONED 02/06/2019

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_5

Tue 11/26/2019 to Tue 11/26/2019
 2330 Continuous 2359
 Work scheduled by: ConEd

UPDATED by CONED 02/06/2019

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

MOSES__-ADIRNDCK_230_MA2

Mon 12/02/2019 to Fri 12/06/2019
 0700 Continuous 1500
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MOSES__-ADIRNDCK_230_MA1

Mon 12/09/2019 to Fri 12/13/2019
 0700 Continuous 1500
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MOSES__-ADIRNDCK_230_MA2

Mon 12/16/2019 to Mon 12/16/2019
 0700 Continuous 1500
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MOSES__-ADIRNDCK_230_MA1

Tue 12/17/2019 to Fri 12/20/2019
 0700 Continuous 1500
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

LADENTWN-BUCHAN_S_345_Y88

Wed 01/15/2020 to Thu 02/13/2020
 0001 Continuous 2359
 Work scheduled by: ORU

11/05/2018

FWD
 (Import)
 UPNY CONED **4800 MW**
 Impacts Total Transfer Capability 900 MW
 TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Friday ,February 15, 2019 to Sunday ,August 16, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASANNX-COOPERS__345_UCC2-41

Mon 04/27/2020 to Sun 05/31/2020
 0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 CENTRAL EAST - VC **2500 MW**
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

MARCY__-FRASANNX_345_UCC2-41

Mon 04/27/2020 to Sun 05/31/2020
 0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 CENTRAL EAST - VC **2500 MW**
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW