

NYISO TRANSFER LIMITATIONS

Sunday ,February 17, 2019 to Tuesday ,August 18, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

	FWD	REV
HUDSONP_-FARRAGUT_345_B3402		
Mon 01/15/2018 to Tue 12/31/2019		(Import) (Export)
0001 Continuous 2359		
<u>EXTENDED</u> by <u>CONED</u> <u>02/06/2019</u>		
Work scheduled by: ConEd	SCH - PJ - NY	2600 MW 1300 MW
	Impacts Total Transfer Capability	0 MW 250 MW
	TTC with All Lines In Service	2600 MW 1550 MW
HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403		
Mon 01/15/2018 to Tue 12/31/2019		(Import) (Export)
0001 Continuous 2359		
<u>EXTENDED</u> by <u>CONED</u> <u>02/06/2019</u>		
Work scheduled by:	SCH - PJ - NY	2000 MW 1300 MW
	Impacts Total Transfer Capability	600 MW 250 MW
	TTC with All Lines In Service	2600 MW 1550 MW
MARION_-FARRAGUT_345_C3403		
Mon 01/15/2018 to Tue 12/31/2019		(Import) (Export)
0001 Continuous 2359		
<u>EXTENDED</u> by <u>CONED</u> <u>02/06/2019</u>		
Work scheduled by: ConEd	SCH - PJ - NY	2600 MW 1300 MW
	Impacts Total Transfer Capability	0 MW 250 MW
	TTC with All Lines In Service	2600 MW 1550 MW
STLAWRNC-MOSES_230_L33P		
Mon 04/30/2018 to Fri 12/31/2021		(Import) (Export)
0456 Continuous 2359		
<u>EXT FORCE</u> by <u>IESO</u> <u>08/21/2018</u>		
Work scheduled by: IESO	SCH - OH - NY	2250 MW 2000 MW
	Impacts Total Transfer Capability	0 MW 0 MW
	TTC with All Lines In Service	2250 MW 2000 MW
S.RIPLEY-DUNKIRK_230_68		
Tue 01/15/2019 to Mon 04/08/2019		(Import) (Export)
1128 Continuous 0759		
<u>EXT FORCE</u> by <u>PJM</u> <u>02/11/2019</u>		
Work scheduled by: PJM	SCH - PJ - NY	2600 MW 1300 MW
	Impacts Total Transfer Capability	0 MW 250 MW
	TTC with All Lines In Service	2600 MW 1550 MW
DUNWODIE_345KV_6		
Wed 01/23/2019 to Fri 03/01/2019		FWD (Import)
0001 Continuous 2359		
<u>EXTENDED</u> by <u>CE</u> <u>02/07/2019</u>		
Work scheduled by: ConEd	SPR/DUN-SOUTH	3800 MW
	Impacts Total Transfer Capability	800 MW
	TTC with All Lines In Service	4600 MW
SCH-IMO-NYISO_LIMIT_1700		
Mon 02/11/2019 to Fri 12/31/2021		FWD (Import)
0001 Continuous 2359		
<u>EXTENDED</u> by <u>CONED</u> <u>02/06/2019</u>		
Work scheduled by: IESO	SCH - OH - NY	2000 MW
	Impacts Total Transfer Capability	250 MW
	TTC with All Lines In Service	2250 MW

NYISO TRANSFER LIMITATIONS

Sunday ,February 17, 2019 to Tuesday ,August 18, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA1

FWD

Mon 02/11/2019 to Fri 02/15/2019
0700 Continuous 1500

(Import)

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

GOETHALS_345KV_5

Wed 02/13/2019 to Sat 02/16/2019
0400 Continuous 0130

CANCELLED by ConEd 02/12/2019

Work scheduled by: ConEd

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

W49TH_ST-E13THSTA_345_M55

FWD

Wed 02/13/2019 to Fri 02/22/2019
0652 Continuous 2359

EXT FORCE by CE 02/14/2019

Work scheduled by: ConEd

(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

W49TH_ST_345KV_6

FWD

Wed 02/13/2019 to Fri 02/22/2019
0652 Continuous 2359

EXT FORCE by CE 02/14/2019

Work scheduled by: ConEd

(Import)
SCH - PJM_HTP **375 MW**
Impacts Total Transfer Capability 285 MW
TTC with All Lines In Service 660 MW

MILLWOOD-EASTVIEW_345_W99

FWD

Thu 02/14/2019 to Thu 02/14/2019
0001 Continuous 0030

UPDATED by CONED 02/08/2019

Work scheduled by: ConEd

(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1350 MW
TTC with All Lines In Service 5700 MW

SPRNBK__345KV_RNS5

FWD

Thu 02/14/2019 to Thu 02/14/2019
0001 Continuous 0030

UPDATED by CONED 02/08/2019

Work scheduled by: ConEd

(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

EASTVIEW-SPRNBK__345_W64

FWD

Thu 02/14/2019 to Thu 02/14/2019
0001 Continuous 2230

UPDATED by CONED 02/08/2019

Work scheduled by: ConEd

(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1350 MW
TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Sunday ,February 17, 2019 to Tuesday ,August 18, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BECK -NIAGARA 345_PA302					FWD	REV
Thu 02/14/2019	to	Thu 02/14/2019	<u>CANCELLED</u>	<u>by IESO</u>	<u>02/14/2019</u>	(Import) (Export)
0500	Continuous	1700				
Work scheduled by: IESO					SCH - OH - NY	1100 MW 950 MW
					Impacts Total Transfer Capability	1150 MW 1050 MW
					TTC with All Lines In Service	2250 MW 2000 MW
<hr/>						
MILLWOOD-EASTVIEW 345_W99					FWD	
Thu 02/14/2019	to	Thu 02/14/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/08/2019</u>	(Import)
2200	Continuous	2230				
Work scheduled by: ConEd					UPNY CONED	4350 MW
					Impacts Total Transfer Capability	1350 MW
					TTC with All Lines In Service	5700 MW
<hr/>						
SPRNBK 345KV_RNS5					FWD	
Thu 02/14/2019	to	Thu 02/14/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/08/2019</u>	(Import)
2200	Continuous	2230				
Work scheduled by: ConEd					SPR/DUN-SOUTH	3200 MW
					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
<hr/>						
SCRIBA -VOLNEY 345_20					FWD	
Sat 02/16/2019	to	Sun 02/17/2019				(Import)
0600	Continuous	1900				
Work scheduled by: NGrid					OSWEGO EXPORT	5250 MW
					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	5250 MW
<hr/>						
BECK -NIAGARA 345_PA302					FWD	REV
Tue 02/19/2019	to	Tue 02/19/2019	<u>CANCELLED</u>	<u>by IESO</u>	<u>02/15/2019</u>	(Import) (Export)
0500	Continuous	1700				
Work scheduled by: IESO					SCH - OH - NY	1100 MW 950 MW
					Impacts Total Transfer Capability	1150 MW 1050 MW
					TTC with All Lines In Service	2250 MW 2000 MW
<hr/>						
MOSES -ADIRNDCK 230_MA2					FWD	
Tue 02/19/2019	to	Fri 02/22/2019	<u>CANCELLED</u>	<u>by NYPA</u>	<u>02/12/2019</u>	(Import)
0700	Continuous	1500				
Work scheduled by: NYPA					MOSES SOUTH	2300 MW
					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
<hr/>						
ADIRNDCK-PORTER 230_12					FWD	
Wed 02/20/2019	to	Wed 02/20/2019				(Import)
0700	Daily(No Weekends)	1530				
Work scheduled by: NGrid					MOSES SOUTH	2300 MW
					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,February 17, 2019 to Tuesday ,August 18, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA2

Wed 02/20/2019 to Wed 02/20/2019
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

FIVEMILE-STOLLERD_345_29

Wed 02/20/2019 to Fri 02/22/2019
0730 Continuous 1900

Work scheduled by: NGrid

FWD REV
(Import) (Export)
SCH - PJ - NY **2600 MW 1300 MW**
Impacts Total Transfer Capability 0 MW 250 MW
TTC with All Lines In Service 2600 MW 1550 MW

CHAT_DC_GC2

Thu 02/21/2019 to Thu 02/21/2019
0500 Continuous 1800

Work scheduled by: HQ

FWD
(Import)
MOSES SOUTH **2850 MW**
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 3150 MW

CHAT_DC_GC2

Thu 02/21/2019 to Thu 02/21/2019
0500 Continuous 1800

Work scheduled by: HQ

REV
(Export)
SCH - HQ - NY **500 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1000 MW

ADIRNDCK-CHASLAKE_230_13

Thu 02/21/2019 to Thu 02/21/2019
0700 Daily(No Weekends) 1530

Work scheduled by: NGrid

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA1

Thu 02/21/2019 to Thu 02/21/2019 **UPDATED by NYISO 02/14/2019**
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA1

Mon 02/25/2019 to Fri 03/01/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,February 17, 2019 to Tuesday ,August 18, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
SCRIBA__ -VOLNEY__ 345_21			FWD
Wed 02/27/2019	to Thu 02/28/2019	UPDATED by NGRID 12/11/2018	(Import)
0730	Continuous 2000	OSWEGO EXPORT	5250 MW
Work scheduled by: NGrid		Impacts Total Transfer Capability	0 MW
		TTC with All Lines In Service	5250 MW
<hr/>			
ATHENS__ -PLSNTVLY_345_91			FWD
Thu 02/28/2019	to Thu 02/28/2019		(Import)
0630	Continuous 2230	UPNY CONED	3800 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability	1900 MW
		TTC with All Lines In Service	5700 MW
<hr/>			
PLSNTVLY_345KV_RNS4			FWD
Thu 02/28/2019	to Thu 02/28/2019		(Import)
0630	Continuous 2230	UPNY CONED	3800 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability	1900 MW
		TTC with All Lines In Service	5700 MW
<hr/>			
PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4			FWD
Fri 03/01/2019	to Mon 03/04/2019		(Import)
0001	0200	UPNY CONED	3800 MW
Work scheduled by:		Impacts Total Transfer Capability	1900 MW
		TTC with All Lines In Service	5700 MW
<hr/>			
LONG_MTN-PLSNTVLY_345_398			FWD REV
Fri 03/01/2019	to Sun 05/19/2019	UPDATED by ISONE 01/30/2019	(Import) (Export)
0001	Continuous 2359	SCH - NE - NY	700 MW 1250 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability	700 MW 550 MW
		TTC with All Lines In Service	1400 MW 1800 MW
<hr/>			
LONG_MTN-PLSNTVLY_345_398			FWD REV
Fri 03/01/2019	to Sun 05/19/2019	UPDATED by ISONE 01/30/2019	(Import) (Export)
0001	Continuous 2359	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability	100 MW 100 MW
		TTC with All Lines In Service	200 MW 200 MW
<hr/>			
SCH-NYISO-NE_LIMIT_700			REV
Fri 03/01/2019	to Sun 05/19/2019	UPDATED by ISONE 01/30/2019	(Export)
0001	Continuous 2359	SCH - NE - NY	900 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability	900 MW
		TTC with All Lines In Service	1800 MW

NYISO TRANSFER LIMITATIONS

Sunday ,February 17, 2019 to Tuesday ,August 18, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY-EFISHKIL_345_F37

Mon 03/04/2019 to Wed 03/06/2019
 0201 Continuous 0300
 Work scheduled by: ConEd

UPDATED by ISONE 01/30/2019

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 1700 MW
 TTC with All Lines In Service 5700 MW

SCRIBA -VOLNEY_345_20

Mon 03/04/2019 to Tue 03/05/2019
 0600 Continuous 1800
 Work scheduled by: NGrid

FWD
 (Import)
 OSWEGO EXPORT **5250 MW**
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 5250 MW

MOSES -ADIRNDCK_230_MA1

Mon 03/04/2019 to Fri 03/08/2019
 0700 Continuous 1500
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

DUNWODIE_345KV_4

Thu 03/07/2019 to Thu 03/07/2019
 0001 Continuous 0030
 Work scheduled by: LI

UPDATED by CONED 02/06/2019

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_6

Thu 03/07/2019 to Thu 03/07/2019
 0001 Continuous 0030
 Work scheduled by: LI

UPDATED by CONED 02/06/2019

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE-SHORE_RD_345_Y50

Thu 03/07/2019 to Fri 03/08/2019
 0001 Continuous 2359
 Work scheduled by: LI

UPDATED by CONED 02/06/2019

FWD
 (Import)
 CONED - LIPA **800 MW**
 Impacts Total Transfer Capability 700 MW
 TTC with All Lines In Service 1500 MW

SHORE_RD_345_138_BK 1

Thu 03/07/2019 to Fri 03/08/2019
 0001 Continuous 2359
 Work scheduled by: LI

UPDATED by CONED 02/06/2019

FWD
 (Import)
 CONED - LIPA **1350 MW**
 Impacts Total Transfer Capability 150 MW
 TTC with All Lines In Service 1500 MW

NYISO TRANSFER LIMITATIONS

Sunday ,February 17, 2019 to Tuesday ,August 18, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SHORE_RD_345_138_BK 2					FWD	
Thu 03/07/2019	to	Fri 03/08/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/06/2019</u>	(Import)
0001	Continuous	2359				1350 MW
Work scheduled by: LI					CONED - LIPA	
					Impacts Total Transfer Capability	150 MW
					TTC with All Lines In Service	1500 MW
EASTVIEW-SPRNBK_345_W64					FWD	
Thu 03/07/2019	to	Mon 03/11/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/08/2019</u>	(Import)
0001	Continuous	0200				4350 MW
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	1350 MW
					TTC with All Lines In Service	5700 MW
MILLWOOD-EASTVIEW_345_W99					FWD	
Thu 03/07/2019	to	Mon 03/11/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/08/2019</u>	(Import)
0001	Continuous	0200				4350 MW
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	1350 MW
					TTC with All Lines In Service	5700 MW
DUNWODIE_345KV_4					FWD	
Fri 03/08/2019	to	Fri 03/08/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/06/2019</u>	(Import)
2330	Continuous	2359				3800 MW
Work scheduled by: LI					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_6					FWD	
Fri 03/08/2019	to	Fri 03/08/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/06/2019</u>	(Import)
2330	Continuous	2359				3800 MW
Work scheduled by: LI					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
MILLWOOD_345KV_18					FWD	
Mon 03/11/2019	to	Mon 03/11/2019				(Import)
0001	Continuous	0030				4350 MW
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	1350 MW
					TTC with All Lines In Service	5700 MW
LADENTWN-BUCHAN_S_345_Y88					FWD	
Mon 03/11/2019	to	Thu 03/28/2019				(Import)
0001	Continuous	0200				4800 MW
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	900 MW
					TTC with All Lines In Service	5700 MW

NYISO TRANSFER LIMITATIONS

Sunday ,February 17, 2019 to Tuesday ,August 18, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BECK -NIAGARA 345_PA301					FWD	REV
Mon 03/11/2019	to	Fri 03/15/2019	UPDATED	by NYPA	02/06/2019	(Import) (Export)
0600	Continuous	1700				
Work scheduled by: NYPA					SCH - OH - NY	1100 MW 950 MW
					Impacts Total Transfer Capability	1150 MW 1050 MW
					TTC with All Lines In Service	2250 MW 2000 MW
<hr/>						
STLAWRNC-MOSES 230_L33P & STLAWRNC-MOSES 230_L34P					FWD	
Mon 03/11/2019	to	Mon 03/11/2019				(Import)
0700		1530				
Work scheduled by:					MOSES SOUTH	2700 MW
					Impacts Total Transfer Capability	450 MW
					TTC with All Lines In Service	3150 MW
<hr/>						
STLAWRNC-MOSES 230_L34P					FWD	REV
Mon 03/11/2019	to	Mon 03/11/2019				(Import) (Export)
0700	Continuous	1530				
Work scheduled by: NYPA					SCH - OH - NY	2250 MW 2000 MW
					Impacts Total Transfer Capability	0 MW 0 MW
					TTC with All Lines In Service	2250 MW 2000 MW
<hr/>						
LEEDS 345_LEEDS SVC					FWD	
Mon 03/11/2019	to	Fri 03/22/2019				(Import)
0800	Continuous	1600				
Work scheduled by: NGrid					CENTRAL EAST - VC	2950 MW
					Impacts Total Transfer Capability	25 MW
					TTC with All Lines In Service	2975 MW
<hr/>						
MOSES -ADIRNDCK 230_MA1					FWD	
Tue 03/12/2019	to	Fri 03/15/2019				(Import)
0700	Continuous	1500				
Work scheduled by: NYPA					MOSES SOUTH	2300 MW
					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
<hr/>						
MILLWOOD 345KV_18					FWD	
Wed 03/13/2019	to	Thu 03/14/2019				(Import)
0001	Continuous	0200				
Work scheduled by: ConEd					UPNY CONED	4350 MW
					Impacts Total Transfer Capability	1350 MW
					TTC with All Lines In Service	5700 MW
<hr/>						
MARCY 765_345_AT1					FWD	
Mon 03/18/2019	to	Fri 03/22/2019				(Import)
0500	Continuous	1530				
Work scheduled by: NYPA					MOSES SOUTH	1750 MW
					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	3150 MW

ARR: 19

NYISO TRANSFER LIMITATIONS

Sunday ,February 17, 2019 to Tuesday ,August 18, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>				
SCH-NYISO-HQ_CEDARS_LIMIT_0				REV
Mon 03/18/2019	to	Thu 04/04/2019		(Export)
0700	Continuous	1700	SCH - HQ_CEDARS	0 MW
Work scheduled by: HQ			Impacts Total Transfer Capability	100 MW
			TTC with All Lines In Service	100 MW
<hr/>				
MILLWOOD_345KV_18				FWD
Thu 03/28/2019	to	Thu 03/28/2019		(Import)
0130	Continuous	0200	UPNY CONED	4350 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	1350 MW
			TTC with All Lines In Service	5700 MW
<hr/>				
MARCY___345KV_CSC				FWD
Mon 04/01/2019	to	Sun 04/07/2019		(Import)
0500	Continuous	1730	CENTRAL EAST - VC	2925 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	50 MW
			TTC with All Lines In Service	2975 MW
<hr/>				
VOLNEY__-MARCY___345_19				FWD
Mon 04/01/2019	to	Wed 04/10/2019		(Import)
0500	Continuous	1730	CENTRAL EAST - VC	2825 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	150 MW
			TTC with All Lines In Service	2975 MW
<hr/>				
VOLNEY__-MARCY___345_19				FWD
Mon 04/01/2019	to	Wed 04/10/2019		(Import)
0500	Continuous	1730	OSWEGO EXPORT	4900 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	350 MW
			TTC with All Lines In Service	5250 MW
<hr/>				
PLSNTVLY-EFISHKIL_345_F37				FWD
Thu 04/04/2019	to	Mon 04/08/2019	UPDATED	(Import)
0001	Continuous	0200	by ISONE 01/30/2019	
Work scheduled by: ConEd			UPNY CONED	4000 MW
			Impacts Total Transfer Capability	1700 MW
			TTC with All Lines In Service	5700 MW
<hr/>				
NIAGARA_-ROCHESTR_345_NR2				FWD
Fri 04/05/2019	to	Fri 04/05/2019		(Import)
0500	Continuous	1700	DYSINGER EAST	1700 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1450 MW
			TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,February 17, 2019 to Tuesday ,August 18, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Transfer Capability	Schedule	Work Scheduled by	SCH	FWD	REV
LINDN_CG-LNDVFT_345_V-3022	Sun 04/07/2019 to Fri 04/12/2019 1400 Continuous 1800	Work scheduled by: PJM	SCH - PJM_VFT	0 MW	0 MW
			Impacts Total Transfer Capability	315 MW	315 MW
			TTC with All Lines In Service	315 MW	315 MW
PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4	Mon 04/08/2019 to Sat 04/13/2019 0001 0300	Work scheduled by:	UPNY CONED	3800 MW	
			Impacts Total Transfer Capability	1900 MW	
			TTC with All Lines In Service	5700 MW	
PLSNTVLE-DUNWODIE_345_W89	Mon 04/08/2019 to Fri 05/10/2019 0001 Continuous 2359	Work scheduled by: ConEd	UPNY CONED	4000 MW	
			Impacts Total Transfer Capability	1700 MW	
			TTC with All Lines In Service	5700 MW	
NEPTUNE_-DUFFYAVE_345_NEPTUNE	Mon 04/08/2019 to Tue 04/09/2019 0600 Continuous 1800	Work scheduled by: LI	SCH - PJM_NEPTUNE	0 MW	
			Impacts Total Transfer Capability	660 MW	
			TTC with All Lines In Service	660 MW	
NEWBRDGE-DUFFYAVE_345_501	Mon 04/08/2019 to Tue 04/09/2019 0600 Continuous 1800	Work scheduled by: LI	SCH - PJM_NEPTUNE	0 MW	
			Impacts Total Transfer Capability	660 MW	
			TTC with All Lines In Service	660 MW	
NEWBRDGE_345_138_BK_1	Mon 04/08/2019 to Tue 04/09/2019 0600 Continuous 1800	Work scheduled by: LI	SCH - PJM_NEPTUNE	375 MW	
			Impacts Total Transfer Capability	285 MW	
			TTC with All Lines In Service	660 MW	
NEWBRDGE_345_138_BK_2	Mon 04/08/2019 to Tue 04/09/2019 0600 Continuous 1800	Work scheduled by: LI	SCH - PJM_NEPTUNE	375 MW	
			Impacts Total Transfer Capability	285 MW	
			TTC with All Lines In Service	660 MW	

NYISO TRANSFER LIMITATIONS

Sunday ,February 17, 2019 to Tuesday ,August 18, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
S. RIPLEY-DUNKIRK__230_68		FWD	REV
Mon 04/08/2019 to Mon 04/15/2019	UPDATED by PJM 02/11/2019	(Import)	(Export)
0800 Continuous 2000		2600 MW	1300 MW
Work scheduled by: PJM		Impacts Total Transfer Capability	0 MW 250 MW
		TTC with All Lines In Service	2600 MW 1550 MW
<hr/>			
MARCY__345KV_CSC		FWD	
Thu 04/11/2019 to Wed 04/17/2019		(Import)	
0500 Continuous 1730		2925 MW	
Work scheduled by: NYPA		Impacts Total Transfer Capability	50 MW
		TTC with All Lines In Service	2975 MW
<hr/>			
MARCY__-EDIC__345_UE1-7		FWD	
Thu 04/11/2019 to Sat 04/20/2019		(Import)	
0500 Continuous 1730		5250 MW	
Work scheduled by: NYPA	ARR: 19&16	Impacts Total Transfer Capability	0 MW
		TTC with All Lines In Service	5250 MW
<hr/>			
SCRIBA__-VOLNEY__345_20		FWD	
Mon 04/15/2019 to Tue 04/16/2019		(Import)	
0600 Continuous 1800		5250 MW	
Work scheduled by: NGrid		Impacts Total Transfer Capability	0 MW
		TTC with All Lines In Service	5250 MW
<hr/>			
GILBOA__-N.SCTLND_345_GNS-1		FWD	
Thu 04/18/2019 to Thu 04/18/2019	UPDATED by NYPA 01/23/2019	(Import)	
1330 Continuous 1530		2520 MW	
Work scheduled by: NYPA		Impacts Total Transfer Capability	455 MW
		TTC with All Lines In Service	2975 MW
<hr/>			
MARCY__765_345_AT2		FWD	
Mon 04/22/2019 to Fri 04/26/2019		(Import)	
0500 Continuous 1730		1700 MW	
Work scheduled by: NYPA	ARR: 19	Impacts Total Transfer Capability	1450 MW
		TTC with All Lines In Service	3150 MW
<hr/>			
EDIC__-FRASER__345_EF24-40		FWD	
Mon 04/22/2019 to Sun 04/28/2019		(Import)	
0500 Continuous 1730		2500 MW	
Work scheduled by: NYPA		Impacts Total Transfer Capability	475 MW
		TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Sunday ,February 17, 2019 to Tuesday ,August 18, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK__345KV_RNS5					FWD (Import) 3200 MW Impacts Total Transfer Capability 1400 MW TTC with All Lines In Service 4600 MW
Mon 04/29/2019	to	Mon 04/29/2019			
0001	Continuous	0030		SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1400 MW
SPRNBRK_-W49TH_ST_345_M51					FWD (Import) 3200 MW Impacts Total Transfer Capability 1400 MW TTC with All Lines In Service 4600 MW
Mon 04/29/2019	to	Sun 05/05/2019		SPR/DUN-SOUTH	3200 MW
0001	Continuous	2200		Impacts Total Transfer Capability 1400 MW	
Work scheduled by: ConEd					TTC with All Lines In Service 4600 MW
FRASANX-COOPERS__345_UCC2-41					FWD (Import) 2500 MW Impacts Total Transfer Capability 475 MW TTC with All Lines In Service 2975 MW
Mon 04/29/2019	to	Fri 05/03/2019	UPDATED	by NYPA	08/22/2018
0500	Continuous	1730		CENTRAL EAST - VC	2500 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 475 MW
					TTC with All Lines In Service 2975 MW
MARCY__-FRASANX_345_UCC2-41					FWD (Import) 2500 MW Impacts Total Transfer Capability 475 MW TTC with All Lines In Service 2975 MW
Mon 04/29/2019	to	Fri 05/03/2019	UPDATED	by NYPA	08/22/2018
0500	Continuous	1730		CENTRAL EAST - VC	2500 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 475 MW
					TTC with All Lines In Service 2975 MW
MOSES__-ADIRNDCK_230_MA1					FWD (Import) 2300 MW Impacts Total Transfer Capability 850 MW TTC with All Lines In Service 3150 MW
Mon 04/29/2019	to	Fri 05/03/2019		MOSES SOUTH	2300 MW
0700	Continuous	1500		Impacts Total Transfer Capability 850 MW	
Work scheduled by: NYPA					TTC with All Lines In Service 3150 MW
EGRDNCTY_345_138_AT2					FWD (Import) 1250 MW Impacts Total Transfer Capability 250 MW TTC with All Lines In Service 1500 MW
Wed 05/01/2019	to	Wed 05/15/2019		CONED - LIPA	1250 MW
0001	Continuous	2359		Impacts Total Transfer Capability 250 MW	
Work scheduled by: LI					TTC with All Lines In Service 1500 MW
HUDSONTP-W49TH_ST_345_Y56					FWD (Import) 0 MW Impacts Total Transfer Capability 660 MW TTC with All Lines In Service 660 MW
Wed 05/01/2019	to	Tue 05/07/2019		SCH - PJM_HTP	0 MW
0600	Continuous	1800		Impacts Total Transfer Capability 660 MW	
Work scheduled by: PJM					TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Sunday ,February 17, 2019 to Tuesday ,August 18, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK__345KV_RNS5				FWD	
Sun 05/05/2019	to	Sun 05/05/2019		(Import)	
2130	Continuous	2200	SPR/DUN-SOUTH	3200 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	1400 MW	
			TTC with All Lines In Service	4600 MW	
KINTIGH_-ROCHESTR_345_SRL-39				FWD	
Mon 05/06/2019	to	Fri 05/10/2019	UPDATED	by NYSEG	11/08/2018
0600	Continuous	1700	DYSINGER EAST	1400 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1750 MW	
			TTC with All Lines In Service	3150 MW	
SHOR_NPX-SHOREHAM_138_CSC				FWD	REV
Mon 05/06/2019	to	Fri 05/10/2019		(Import)	(Export)
0700	Continuous	1800	SCH - NPX_CSC	0 MW	0 MW
Work scheduled by: LI			Impacts Total Transfer Capability	330 MW	330 MW
			TTC with All Lines In Service	330 MW	330 MW
ROSETON_-ROCKTVRN_345_311				FWD	
Mon 05/06/2019	to	Sat 06/01/2019		(Import)	
0800	Continuous	1600	UPNY CONED	4400 MW	
Work scheduled by: CHGE			Impacts Total Transfer Capability	1300 MW	
			TTC with All Lines In Service	5700 MW	
NIAGARA_-ROCHESTR_345_NR2				FWD	
Mon 05/13/2019	to	Fri 05/17/2019		(Import)	
0600	Continuous	1700	DYSINGER EAST	1400 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1750 MW	
			TTC with All Lines In Service	3150 MW	
ADIRNDCK-PORTER__230_12				FWD	
Mon 05/20/2019	to	Fri 05/24/2019		(Import)	
0700	Continuous	1530	MOSES SOUTH	2100 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1050 MW	
			TTC with All Lines In Service	3150 MW	
PANNELL_-CLAY____345_1				FWD	
Mon 05/20/2019	to	Fri 05/24/2019		(Import)	
0700	Continuous	1530	WEST CENTRAL	1300 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	950 MW	
			TTC with All Lines In Service	2250 MW	

NYISO TRANSFER LIMITATIONS

Sunday ,February 17, 2019 to Tuesday ,August 18, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROSETON_-EFISHKIL_345_RFK305

Thu 05/23/2019 to Thu 05/23/2019
0800 Daily 1600

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4800 MW**
Impacts Total Transfer Capability 900 MW
TTC with All Lines In Service 5700 MW

SCRIBA_-VOLNEY_345_20

Tue 05/28/2019 to Tue 05/28/2019
0600 Continuous 1800

Work scheduled by: NGrid

FWD
(Import)
OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

PANNELL_-CLAY_345_2

Mon 06/03/2019 to Fri 06/07/2019
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

MOSES_-ADIRNDCK_230_MA2

Mon 06/24/2019 to Fri 06/28/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

MOSES_-ADIRNDCK_230_MA2

Mon 07/08/2019 to Fri 07/12/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

ADIRNDCK-CHASLAKE_230_13

Mon 07/08/2019 to Fri 07/12/2019
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

MARCY_765_345_AT2

Sat 08/03/2019 to Sun 08/04/2019
0500 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

ARR: 19

NYISO TRANSFER LIMITATIONS

Sunday ,February 17, 2019 to Tuesday ,August 18, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA1					FWD	
Mon 08/12/2019	to	Mon 08/12/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/10/2018</u>	(Import)
0700	Continuous	1459				2100 MW
Work scheduled by: NYPA					MOSES SOUTH	
					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	3150 MW
SHOR_NPX-SHOREHAM_138_CSC					FWD	REV
Tue 09/03/2019	to	Wed 09/04/2019	<u>UPDATED</u>	<u>by ISONE</u>	<u>02/15/2019</u>	(Import) (Export)
0300	Continuous	1600				0 MW 0 MW
Work scheduled by: LI					SCH - NPX_CSC	
					Impacts Total Transfer Capability	330 MW 330 MW
					TTC with All Lines In Service	330 MW 330 MW
MARCY___765_345_AT1					FWD	
Tue 09/03/2019	to	Tue 09/03/2019				(Import)
0500	Continuous	1730				1750 MW
Work scheduled by: NYPA					MOSES SOUTH	
					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	3150 MW
MARCY___-N.SCTLND_345_18					FWD	
Wed 09/04/2019	to	Wed 09/04/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>11/06/2018</u>	(Import)
0500	Continuous	1730				2090 MW
Work scheduled by: NYPA					CENTRAL EAST - VC	
					Impacts Total Transfer Capability	885 MW
					TTC with All Lines In Service	2975 MW
MARCY___345KV_CSC					FWD	
Wed 09/04/2019	to	Wed 09/04/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>11/06/2018</u>	(Import)
0500	Continuous	1730				2925 MW
Work scheduled by: NYPA					CENTRAL EAST - VC	
					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	2975 MW
MOSES___-ADIRNDCK_230_MA2					FWD	
Wed 09/04/2019	to	Wed 09/04/2019				(Import)
0700	Continuous	1500				2100 MW
Work scheduled by: NYPA					MOSES SOUTH	
					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	3150 MW
ADIRNDCK-PORTER___230_12					FWD	
Wed 09/04/2019	to	Wed 09/04/2019				(Import)
0700	Continuous	1530				2100 MW
Work scheduled by: NYPA					MOSES SOUTH	
					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,February 17, 2019 to Tuesday ,August 18, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ADIRNDCK-CHASLAKE_230_13

Thu 09/05/2019 to Thu 09/05/2019
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

NIAGARA -ROCHESTR_345_NR2

Mon 09/09/2019 to Sat 09/21/2019
0500 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

LEEDS___345KV_R395

Mon 09/09/2019 to Mon 09/09/2019
0700 Continuous 0730

Work scheduled by: NYPA

FWD
(Import)
UPNY CONED **3800 MW**
Impacts Total Transfer Capability 1900 MW
TTC with All Lines In Service 5700 MW

GILBOA -LEEDS___345_GL3

Mon 09/09/2019 to Fri 09/27/2019
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2200 MW**
Impacts Total Transfer Capability 775 MW
TTC with All Lines In Service 2975 MW

MARCY___-N.SCTLND_345_18

Wed 09/11/2019 to Fri 09/13/2019
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2090 MW**
Impacts Total Transfer Capability 885 MW
TTC with All Lines In Service 2975 MW

MOSES___-ADIRNDCK_230_MA2

Mon 09/16/2019 to Fri 09/20/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

GOETHALS_345KV_5

Fri 09/20/2019 to Tue 09/24/2019
0001 Continuous 2359

Work scheduled by: ConEd

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Sunday ,February 17, 2019 to Tuesday ,August 18, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROCHESTR-PANNELL__345_RP2

Mon 09/23/2019 to Mon 09/30/2019
 0500 Continuous 1700
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

KINTIGH_-ROCHESTR_345_SR1-39

Mon 09/23/2019 to Fri 09/27/2019
 0600 Continuous 1700
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **1400 MW**
 Impacts Total Transfer Capability 1750 MW
 TTC with All Lines In Service 3150 MW

LEEDS__345KV_R395

Fri 09/27/2019 to Fri 09/27/2019
 1700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 1900 MW
 TTC with All Lines In Service 5700 MW

CLAY_-EDIC__345_1-16

Mon 09/30/2019 to Fri 10/04/2019
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 OSWEGO EXPORT **4850 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 5250 MW

LEEDS_-HURLYAVE_345_301

Mon 09/30/2019 to Sat 10/26/2019
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4100 MW**
 Impacts Total Transfer Capability 1600 MW
 TTC with All Lines In Service 5700 MW

CLAY_-EDIC__345_2-15

Mon 10/07/2019 to Thu 10/17/2019
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 OSWEGO EXPORT **4850 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 5250 MW

MARCY_-N.SCTLND_345_18

Wed 10/09/2019 to Fri 10/11/2019
 0500 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2090 MW**
 Impacts Total Transfer Capability 885 MW
 TTC with All Lines In Service 2975 MW

ARR: 19

NYISO TRANSFER LIMITATIONS

Sunday ,February 17, 2019 to Tuesday ,August 18, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHATGUAY-MASSENA__765_7040

Sat 10/12/2019 to Sat 10/26/2019
 0100 Continuous 1900
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **1550 MW**
 Impacts Total Transfer Capability 1600 MW
 TTC with All Lines In Service 3150 MW

CHATGUAY-MASSENA__765_7040

Sat 10/12/2019 to Sat 10/26/2019
 0100 Continuous 1900
 Work scheduled by: NYPA

FWD REV
 (Import) (Export)
 SCH - HQ - NY **0 MW 0 MW**
 Impacts Total Transfer Capability 1500 MW 1000 MW
 TTC with All Lines In Service 1500 MW 1000 MW

MARCY__765_345_AT1

Sat 10/12/2019 to Sat 10/26/2019
 0100 Continuous 1900
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1750 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 3150 MW

MARCY__765_345_AT2

Sat 10/12/2019 to Sat 10/26/2019
 0100 Continuous 1900
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

MASSENA_-MARCY__765_MSU1

Sat 10/12/2019 to Sat 10/26/2019
 0100 Continuous 1900
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2265 MW**
 Impacts Total Transfer Capability 710 MW
 TTC with All Lines In Service 2975 MW

MASSENA_-MARCY__765_MSU1

Sat 10/12/2019 to Sat 10/26/2019
 0100 Continuous 1900
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **500 MW**
 Impacts Total Transfer Capability 2650 MW
 TTC with All Lines In Service 3150 MW

MASSENA_-MARCY__765_MSU1

Sat 10/12/2019 to Sat 10/26/2019
 0100 Continuous 1900
 Work scheduled by: NYPA

FWD REV
 (Import) (Export)
 SCH - HQ - NY **475 MW 1000 MW**
 Impacts Total Transfer Capability 1025 MW 0 MW
 TTC with All Lines In Service 1500 MW 1000 MW

NYISO TRANSFER LIMITATIONS

Sunday ,February 17, 2019 to Tuesday ,August 18, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA_-MARCY_ 765_MSU1 & CHATGUAY-MASSENA_ 765_7040

Sat 10/12/2019 to Sat 10/26/2019
0100 1900

Work scheduled by:

FWD
(Import)
MOSES SOUTH **500 MW**
Impacts Total Transfer Capability 2650 MW
TTC with All Lines In Service 3150 MW

MOSES_-MASSENA_ 230_MMS1 & MOSES_-MASSENA_ 230_MMS2

Sat 10/12/2019 to Sat 10/26/2019
0100 1900

Work scheduled by:

FWD REV
(Import) (Export)
SCH - HQ - NY **850 MW 0 MW**
Impacts Total Transfer Capability 650 MW 1000 MW
TTC with All Lines In Service 1500 MW 1000 MW

DUNWODIE_345KV_3

Tue 10/22/2019 to Tue 10/22/2019 **UPDATED by CONED 02/06/2019**
0001 Continuous 0030

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_5

Tue 10/22/2019 to Tue 10/22/2019 **UPDATED by CONED 02/06/2019**
0001 Continuous 0030

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

DUNWODIE-MOTTHAVN_345_71

Tue 10/22/2019 to Tue 11/26/2019 **UPDATED by CONED 02/06/2019**
0001 Continuous 2359

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

NIAGARA_345_230_AT4

Wed 10/23/2019 to Wed 12/18/2019 **UPDATED by NYPA 12/19/2018**
0500 Continuous 1700

Work scheduled by: NYPA

FWD REV
(Import) (Export)
SCH - OH - NY **1900 MW 1400 MW**
Impacts Total Transfer Capability 0 MW 350 MW
TTC with All Lines In Service 1900 MW 1750 MW

HURLYAVE-ROSETON_345_303

Mon 11/04/2019 to Fri 12/06/2019
0800 Continuous 1600

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 1600 MW
TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Sunday ,February 17, 2019 to Tuesday ,August 18, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PANNELL_-CLAY_____345_2

Wed 11/06/2019 to Fri 11/22/2019
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)

WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

MARCY___-N.SCTLND_345_18

Thu 11/07/2019 to Fri 11/08/2019
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)

CENTRAL EAST - VC **2090 MW**
Impacts Total Transfer Capability 885 MW
TTC with All Lines In Service 2975 MW

MARCY___345KV_CSC

Thu 11/07/2019 to Fri 11/08/2019
0500 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)

CENTRAL EAST - VC **2925 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

MOSES___-ADIRNDCK_230_MA2

Tue 11/12/2019 to Fri 11/15/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 11/18/2019 to Fri 11/22/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 11/25/2019 to Wed 11/27/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

DUNWODIE_345KV_3

Tue 11/26/2019 to Tue 11/26/2019
2330 Continuous 2359

Work scheduled by: ConEd

UPDATED by CONED 02/06/2019

FWD
(Import)

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,February 17, 2019 to Tuesday ,August 18, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_5

Tue 11/26/2019 to Tue 11/26/2019
2330 Continuous 2359

Work scheduled by: ConEd

UPDATED by CONED 02/06/2019

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD
(Import)

MOSES__-ADIRNDCK_230_MA2

Mon 12/02/2019 to Fri 12/06/2019
0700 Continuous 1500

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

FWD
(Import)

MOSES__-ADIRNDCK_230_MA1

Mon 12/09/2019 to Fri 12/13/2019
0700 Continuous 1500

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

FWD
(Import)

MOSES__-ADIRNDCK_230_MA2

Mon 12/16/2019 to Mon 12/16/2019
0700 Continuous 1500

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

FWD
(Import)

MOSES__-ADIRNDCK_230_MA1

Tue 12/17/2019 to Fri 12/20/2019
0700 Continuous 1500

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

FWD
(Import)

LADENTWN-BUCHAN_S_345_Y88

Wed 01/15/2020 to Thu 02/13/2020
0001 Continuous 2359

Work scheduled by: ORU

11/05/2018

UPNY CONED **4800 MW**
Impacts Total Transfer Capability 900 MW
TTC with All Lines In Service 5700 MW

FWD
(Import)

FRASANNX-COOPERS__345_UCC2-41

Mon 04/27/2020 to Sun 05/31/2020
0700 Continuous 1530

Work scheduled by: NYPA

CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

FWD
(Import)

ARR: 19

NYISO TRANSFER LIMITATIONS

Sunday ,February 17, 2019 to Tuesday ,August 18, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___-FRASANX_345_UCC2-41

FWD

Mon 04/27/2020 to Sun 05/31/2020
 0700 Continuous 1530

(Import)

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC 2500 MW
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW