

NYISO TRANSFER LIMITATIONS

Monday ,February 18, 2019 to Wednesday, August 19, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

	FWD	REV
HUDSONP_-FARRAGUT_345_B3402		
Mon 01/15/2018 to Tue 12/31/2019		(Import) (Export)
0001 Continuous 2359		
<u>EXTENDED</u> by <u>CONED</u> <u>02/06/2019</u>		
Work scheduled by: ConEd		
SCH - PJ - NY	2600 MW	1300 MW
Impacts Total Transfer Capability	0 MW	250 MW
TTC with All Lines In Service	2600 MW	1550 MW
HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403		
Mon 01/15/2018 to Tue 12/31/2019		(Import) (Export)
0001 Continuous 2359		
SCH - PJ - NY	2000 MW	1300 MW
Impacts Total Transfer Capability	600 MW	250 MW
TTC with All Lines In Service	2600 MW	1550 MW
MARION_-FARRAGUT_345_C3403		
Mon 01/15/2018 to Tue 12/31/2019		(Import) (Export)
0001 Continuous 2359		
<u>EXTENDED</u> by <u>CONED</u> <u>02/06/2019</u>		
Work scheduled by: ConEd		
SCH - PJ - NY	2600 MW	1300 MW
Impacts Total Transfer Capability	0 MW	250 MW
TTC with All Lines In Service	2600 MW	1550 MW
STLAWRNC-MOSES_230_L33P		
Mon 04/30/2018 to Fri 12/31/2021		(Import) (Export)
0456 Continuous 2359		
<u>EXT FORCE</u> by <u>IESO</u> <u>08/21/2018</u>		
Work scheduled by: IESO		
SCH - OH - NY	2250 MW	2000 MW
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	2250 MW	2000 MW
S.RIPLEY-DUNKIRK_230_68		
Tue 01/15/2019 to Mon 04/08/2019		(Import) (Export)
1128 Continuous 0759		
<u>EXT FORCE</u> by <u>PJM</u> <u>02/11/2019</u>		
Work scheduled by: PJM		
SCH - PJ - NY	2600 MW	1300 MW
Impacts Total Transfer Capability	0 MW	250 MW
TTC with All Lines In Service	2600 MW	1550 MW
DUNWODIE_345KV_6		
Wed 01/23/2019 to Fri 03/01/2019		(Import)
0001 Continuous 2359		
<u>EXTENDED</u> by <u>CE</u> <u>02/07/2019</u>		
Work scheduled by: ConEd		
SPR/DUN-SOUTH	3800 MW	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	
SCH-IMO-NYISO_LIMIT_1700		
Mon 02/11/2019 to Fri 12/31/2021		(Import)
0001 Continuous 2359		
SCH - OH - NY	2000 MW	
Impacts Total Transfer Capability	250 MW	
TTC with All Lines In Service	2250 MW	

NYISO TRANSFER LIMITATIONS

Monday ,February 18, 2019 to Wednesday, August 19, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -ADIRNDCK_230_MA1					FWD	
Mon 02/11/2019	to	Fri 02/15/2019			(Import)	
0700	Continuous	1500		MOSES SOUTH	2300 MW	
Work scheduled by: NYPA					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
W49TH_ST-E13THSTA_345_M55					FWD	
Wed 02/13/2019	to	Fri 02/22/2019	EXT FORCE	by CE	02/14/2019	(Import)
0652	Continuous	2359				
Work scheduled by: ConEd					SPR/DUN-SOUTH	3800 MW
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
W49TH_ST_345KV_6					FWD	
Wed 02/13/2019	to	Fri 02/22/2019	EXT FORCE	by CE	02/14/2019	(Import)
0652	Continuous	2359				
Work scheduled by: ConEd					SCH - PJM_HTP	375 MW
					Impacts Total Transfer Capability	285 MW
					TTC with All Lines In Service	660 MW
MILLWOOD-EASTVIEW_345_W99					FWD	
Thu 02/14/2019	to	Thu 02/14/2019	UPDATED	by CONED	02/08/2019	(Import)
0001	Continuous	0030				
Work scheduled by: ConEd					UPNY CONED	4350 MW
					Impacts Total Transfer Capability	1350 MW
					TTC with All Lines In Service	5700 MW
SPRNBK_345KV_RNS5					FWD	
Thu 02/14/2019	to	Thu 02/14/2019	UPDATED	by CONED	02/08/2019	(Import)
0001	Continuous	0030				
Work scheduled by: ConEd					SPR/DUN-SOUTH	3200 MW
					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
EASTVIEW-SPRNBK_345_W64					FWD	
Thu 02/14/2019	to	Thu 02/14/2019	UPDATED	by CONED	02/08/2019	(Import)
0001	Continuous	2230				
Work scheduled by: ConEd					UPNY CONED	4350 MW
					Impacts Total Transfer Capability	1350 MW
					TTC with All Lines In Service	5700 MW
BECK -NIAGARA_345_PA302					FWD	REV
Thu 02/14/2019	to	Thu 02/14/2019	CANCELLED	by IESO	02/14/2019	(Import) (Export)
0500	Continuous	1700				
Work scheduled by: IESO					SCH - OH - NY	1100 MW 950 MW
					Impacts Total Transfer Capability	1150 MW 1050 MW
					TTC with All Lines In Service	2250 MW 2000 MW

NYISO TRANSFER LIMITATIONS

Monday ,February 18, 2019 to Wednesday, August 19, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD-EASTVIEW_345_W99				FWD	
Thu 02/14/2019	to	Thu 02/14/2019	<u>UPDATED</u> <u>by CONED</u> <u>02/08/2019</u>	(Import)	
2200	Continuous	2230		UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	1350 MW
				TTC with All Lines In Service	5700 MW
SPRNBRK_345KV_RNS5				FWD	
Thu 02/14/2019	to	Thu 02/14/2019	<u>UPDATED</u> <u>by CONED</u> <u>02/08/2019</u>	(Import)	
2200	Continuous	2230		SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	4600 MW
SCRIBA_-VOLNEY_345_20				FWD	
Sat 02/16/2019	to	Sun 02/17/2019		(Import)	
0600	Continuous	1900		OSWEGO EXPORT	5250 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	0 MW
				TTC with All Lines In Service	5250 MW
BECK_-NIAGARA_345_PA302				FWD	REV
Tue 02/19/2019	to	Tue 02/19/2019	<u>CANCELLED</u> <u>by IESO</u> <u>02/15/2019</u>	(Import)	(Export)
0500	Continuous	1700		SCH - OH - NY	1100 MW 950 MW
Work scheduled by: IESO				Impacts Total Transfer Capability	1150 MW 1050 MW
				TTC with All Lines In Service	2250 MW 2000 MW
ADIRNDCK-PORTER_230_12				FWD	
Wed 02/20/2019	to	Wed 02/20/2019		(Import)	
0700	Daily(No Weekends)	1530		MOSES SOUTH	2300 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
MOSES_-ADIRNDCK_230_MA2				FWD	
Wed 02/20/2019	to	Wed 02/20/2019		(Import)	
0700	Continuous	1530		MOSES SOUTH	2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
FIVEMILE-STOLLERD_345_29				FWD	REV
Wed 02/20/2019	to	Fri 02/22/2019		(Import)	(Export)
0730	Continuous	1900		SCH - PJ - NY	2600 MW 1300 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	0 MW 250 MW
				TTC with All Lines In Service	2600 MW 1550 MW

NYISO TRANSFER LIMITATIONS

Monday ,February 18, 2019 to Wednesday, August 19, 2020

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC2

Thu 02/21/2019 to Thu 02/21/2019
 0500 Continuous 1800
 Work scheduled by: HQ

FWD
 (Import)
 MOSES SOUTH **2850 MW**
 Impacts Total Transfer Capability 300 MW
 TTC with All Lines In Service 3150 MW

CHAT_DC_GC2

Thu 02/21/2019 to Thu 02/21/2019
 0500 Continuous 1800
 Work scheduled by: HQ

REV
 (Export)
 SCH - HQ - NY **500 MW**
 Impacts Total Transfer Capability 500 MW
 TTC with All Lines In Service 1000 MW

ADIRNDCK-CHASLAKE_230_13

Thu 02/21/2019 to Thu 02/21/2019
 0700 Daily(No Weekends) 1530
 Work scheduled by: NGrid

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MOSES__-ADIRNDCK_230_MAL

Thu 02/21/2019 to Thu 02/21/2019 **UPDATED by NYISO 02/14/2019**
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MOSES__-ADIRNDCK_230_MAL

Mon 02/25/2019 to Fri 03/01/2019
 0700 Continuous 1500
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

SCRIBA__-VOLNEY__345_21

Wed 02/27/2019 to Thu 02/28/2019 **UPDATED by NGRID 12/11/2018**
 0730 Continuous 2000
 Work scheduled by: NGrid

FWD
 (Import)
 OSWEGO EXPORT **5250 MW**
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 5250 MW

ATHENS__-PLSNTVLY_345_91

Thu 02/28/2019 to Thu 02/28/2019
 0630 Continuous 2230
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 1900 MW
 TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Monday ,February 18, 2019 to Wednesday, August 19, 2020

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RNS4

Thu 02/28/2019 to Thu 02/28/2019
 0630 Continuous 2230
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 1900 MW
 TTC with All Lines In Service 5700 MW

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4

Fri 03/01/2019 to Mon 03/04/2019
 0001 0200
 Work scheduled by:

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 1900 MW
 TTC with All Lines In Service 5700 MW

LONG_MTN-PLSNTVLY_345_398

Fri 03/01/2019 to Sun 05/19/2019 **UPDATED by ISONE 01/30/2019**
 0001 Continuous 2359
 Work scheduled by: ConEd

FWD REV
 (Import) (Export)
 SCH - NE - NY **700 MW 1250 MW**
 Impacts Total Transfer Capability 700 MW 550 MW
 TTC with All Lines In Service 1400 MW 1800 MW

LONG_MTN-PLSNTVLY_345_398

Fri 03/01/2019 to Sun 05/19/2019 **UPDATED by ISONE 01/30/2019**
 0001 Continuous 2359
 Work scheduled by: ConEd

FWD REV
 (Import) (Export)
 SCH - NPX_1385 **100 MW 100 MW**
 Impacts Total Transfer Capability 100 MW 100 MW
 TTC with All Lines In Service 200 MW 200 MW

SCH-NYISO-NE_LIMIT_700

Fri 03/01/2019 to Sun 05/19/2019 **UPDATED by ISONE 01/30/2019**
 0001 Continuous 2359
 Work scheduled by: ConEd

REV
 (Export)
 SCH - NE - NY **900 MW**
 Impacts Total Transfer Capability 900 MW
 TTC with All Lines In Service 1800 MW

PLSNTVLY-EFISHKIL_345_F37

Mon 03/04/2019 to Wed 03/06/2019 **UPDATED by ISONE 01/30/2019**
 0201 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 1700 MW
 TTC with All Lines In Service 5700 MW

SCRIBA_-VOLNEY_345_20

Mon 03/04/2019 to Tue 03/05/2019
 0600 Continuous 1800
 Work scheduled by: NGrid

FWD
 (Import)
 OSWEGO EXPORT **5250 MW**
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 5250 MW

NYISO TRANSFER LIMITATIONS

Monday ,February 18, 2019 to Wednesday, August 19, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -ADIRNDCK_230_MA1

Mon 03/04/2019 to Fri 03/08/2019
 0700 Continuous 1500
 Work scheduled by: NYPA

FWD
 (Import)
MOSES SOUTH 2300 MW
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

DUNWODIE_345KV_4

Thu 03/07/2019 to Thu 03/07/2019 **UPDATED by CONED 02/06/2019**
 0001 Continuous 0030
 Work scheduled by: LI

FWD
 (Import)
SPR/DUN-SOUTH 3800 MW
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_6

Thu 03/07/2019 to Thu 03/07/2019 **UPDATED by CONED 02/06/2019**
 0001 Continuous 0030
 Work scheduled by: LI

FWD
 (Import)
SPR/DUN-SOUTH 3800 MW
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE-SHORE_RD_345_Y50

Thu 03/07/2019 to Fri 03/08/2019 **UPDATED by CONED 02/06/2019**
 0001 Continuous 2359
 Work scheduled by: LI

FWD
 (Import)
CONED - LIPA 800 MW
 Impacts Total Transfer Capability 700 MW
 TTC with All Lines In Service 1500 MW

SHORE_RD_345_138_BK 1

Thu 03/07/2019 to Fri 03/08/2019 **UPDATED by CONED 02/06/2019**
 0001 Continuous 2359
 Work scheduled by: LI

FWD
 (Import)
CONED - LIPA 1350 MW
 Impacts Total Transfer Capability 150 MW
 TTC with All Lines In Service 1500 MW

SHORE_RD_345_138_BK 2

Thu 03/07/2019 to Fri 03/08/2019 **UPDATED by CONED 02/06/2019**
 0001 Continuous 2359
 Work scheduled by: LI

FWD
 (Import)
CONED - LIPA 1350 MW
 Impacts Total Transfer Capability 150 MW
 TTC with All Lines In Service 1500 MW

EASTVIEW-SPRNBK_345_W64

Thu 03/07/2019 to Mon 03/11/2019 **UPDATED by CONED 02/08/2019**
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
UPNY CONED 4350 MW
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Monday ,February 18, 2019 to Wednesday, August 19, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD-EASTVIEW_345_W99					FWD	
Thu 03/07/2019	to	Mon 03/11/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/08/2019</u>	(Import)
0001	Continuous	0200				UPNY CONED 4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1350 MW
					TTC with All Lines In Service	5700 MW
DUNWODIE_345KV_4					FWD	
Fri 03/08/2019	to	Fri 03/08/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/06/2019</u>	(Import)
2330	Continuous	2359				SPR/DUN-SOUTH 3800 MW
Work scheduled by: LI					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_6					FWD	
Fri 03/08/2019	to	Fri 03/08/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/06/2019</u>	(Import)
2330	Continuous	2359				SPR/DUN-SOUTH 3800 MW
Work scheduled by: LI					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
MILLWOOD_345KV_18					FWD	
Mon 03/11/2019	to	Mon 03/11/2019				(Import)
0001	Continuous	0030				UPNY CONED 4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1350 MW
					TTC with All Lines In Service	5700 MW
LADENTWN-BUCHAN_S_345_Y88					FWD	
Mon 03/11/2019	to	Thu 03/28/2019				(Import)
0001	Continuous	0200				UPNY CONED 4800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	900 MW
					TTC with All Lines In Service	5700 MW
BECK -NIAGARA_345_PA301					FWD	REV
Mon 03/11/2019	to	Fri 03/15/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>02/06/2019</u>	(Import) (Export)
0600	Continuous	1700				SCH - OH - NY 1100 MW 950 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1150 MW 1050 MW
					TTC with All Lines In Service	2250 MW 2000 MW
STLAWRNC-MOSES_230_L33P & STLAWRNC-MOSES_230_L34P					FWD	
Mon 03/11/2019	to	Mon 03/11/2019				(Import)
0700		1530				MOSES SOUTH 2700 MW
Work scheduled by:					Impacts Total Transfer Capability	450 MW
					TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Monday ,February 18, 2019 to Wednesday, August 19, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STLAWRNC-MOSES ___230_L34P				
Mon 03/11/2019	to	Mon 03/11/2019		FWD
0700	Continuous	1530		(Import) (Export)
Work scheduled by: NYPA			SCH - OH - NY	2250 MW 2000 MW
			Impacts Total Transfer Capability	0 MW 0 MW
			TTC with All Lines In Service	2250 MW 2000 MW
<hr/>				
LEEDS ___345_LEEDS SVC				FWD
Mon 03/11/2019	to	Fri 03/22/2019		(Import)
0800	Continuous	1600		CENTRAL EAST - VC
Work scheduled by: NGrid				2950 MW
			Impacts Total Transfer Capability	25 MW
			TTC with All Lines In Service	2975 MW
<hr/>				
MOSES ___-ADIRNDCK_230_MA1				FWD
Tue 03/12/2019	to	Fri 03/15/2019		(Import)
0700	Continuous	1500		MOSES SOUTH
Work scheduled by: NYPA				2300 MW
			Impacts Total Transfer Capability	850 MW
			TTC with All Lines In Service	3150 MW
<hr/>				
MILLWOOD_345KV_18				FWD
Wed 03/13/2019	to	Thu 03/14/2019		(Import)
0001	Continuous	0200		UPNY CONED
Work scheduled by: ConEd				4350 MW
			Impacts Total Transfer Capability	1350 MW
			TTC with All Lines In Service	5700 MW
<hr/>				
MARCY ___765_345_AT1				FWD
Mon 03/18/2019	to	Fri 03/22/2019		(Import)
0500	Continuous	1530		MOSES SOUTH
Work scheduled by: NYPA				1750 MW
			Impacts Total Transfer Capability	1400 MW
			TTC with All Lines In Service	3150 MW
<hr/>				
SCH-NYISO-HQ_CEDARS_LIMIT_0				REV
Mon 03/18/2019	to	Thu 04/04/2019		(Export)
0700	Continuous	1700		SCH - HQ_CEDARS
Work scheduled by: HQ				0 MW
			Impacts Total Transfer Capability	100 MW
			TTC with All Lines In Service	100 MW
<hr/>				
MILLWOOD_345KV_18				FWD
Thu 03/28/2019	to	Thu 03/28/2019		(Import)
0130	Continuous	0200		UPNY CONED
Work scheduled by: ConEd				4350 MW
			Impacts Total Transfer Capability	1350 MW
			TTC with All Lines In Service	5700 MW

ARR: 19

NYISO TRANSFER LIMITATIONS

Monday ,February 18, 2019 to Wednesday, August 19, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___345KV_CSC				FWD		
Mon 04/01/2019	to	Sun 04/07/2019		(Import)		
0500	Continuous	1730	CENTRAL EAST - VC	2925 MW		
Work scheduled by: NYPA				Impacts Total Transfer Capability	50 MW	
				TTC with All Lines In Service	2975 MW	
VOLNEY_-MARCY___345_19				FWD		
Mon 04/01/2019	to	Wed 04/10/2019		(Import)		
0500	Continuous	1730	CENTRAL EAST - VC	2825 MW		
Work scheduled by: NYPA				Impacts Total Transfer Capability	150 MW	
				TTC with All Lines In Service	2975 MW	
VOLNEY_-MARCY___345_19				FWD		
Mon 04/01/2019	to	Wed 04/10/2019		(Import)		
0500	Continuous	1730	OSWEGO EXPORT	4900 MW		
Work scheduled by: NYPA				Impacts Total Transfer Capability	350 MW	
				TTC with All Lines In Service	5250 MW	
PLSNTVLY-EFISHKIL_345_F37				FWD		
Thu 04/04/2019	to	Mon 04/08/2019	UPDATED	(Import)		
0001	Continuous	0200	by ISONE 01/30/2019	UPNY CONED	4000 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	1700 MW	
				TTC with All Lines In Service	5700 MW	
NIAGARA_-ROCHESTR_345_NR2				FWD		
Fri 04/05/2019	to	Fri 04/05/2019		(Import)		
0500	Continuous	1700	DYSINGER EAST	1700 MW		
Work scheduled by: NYPA				Impacts Total Transfer Capability	1450 MW	
				TTC with All Lines In Service	3150 MW	
LINDN_CG-LNDVFT___345_V-3022				FWD	REV	
Sun 04/07/2019	to	Fri 04/12/2019		(Import)	(Export)	
1400	Continuous	1800	SCH - PJM_VFT	0 MW	0 MW	
Work scheduled by: PJM				Impacts Total Transfer Capability	315 MW	315 MW
				TTC with All Lines In Service	315 MW	315 MW
PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4				FWD		
Mon 04/08/2019	to	Sat 04/13/2019		(Import)		
0001		0300	UPNY CONED	3800 MW		
Work scheduled by:				Impacts Total Transfer Capability	1900 MW	
				TTC with All Lines In Service	5700 MW	

NYISO TRANSFER LIMITATIONS

Monday ,February 18, 2019 to Wednesday, August 19, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLE-DUNWODIE_345_W89				FWD	
Mon 04/08/2019	to	Fri 05/10/2019		(Import)	
0001	Continuous	2359	UPNY CONED	4000 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	1700 MW	
			TTC with All Lines In Service	5700 MW	
NEPTUNE_-DUFFYAVE_345_NEPTUNE				FWD	
Mon 04/08/2019	to	Tue 04/09/2019		(Import)	
0600	Continuous	1800	SCH - PJM_NEPTUNE	0 MW	
Work scheduled by: LI			Impacts Total Transfer Capability	660 MW	
			TTC with All Lines In Service	660 MW	
NEWBRDGE-DUFFYAVE_345_501				FWD	
Mon 04/08/2019	to	Tue 04/09/2019		(Import)	
0600	Continuous	1800	SCH - PJM_NEPTUNE	0 MW	
Work scheduled by: LI			Impacts Total Transfer Capability	660 MW	
			TTC with All Lines In Service	660 MW	
NEWBRDGE_345_138_BK_1				FWD	
Mon 04/08/2019	to	Tue 04/09/2019		(Import)	
0600	Continuous	1800	SCH - PJM_NEPTUNE	375 MW	
Work scheduled by: LI			Impacts Total Transfer Capability	285 MW	
			TTC with All Lines In Service	660 MW	
NEWBRDGE_345_138_BK_2				FWD	
Mon 04/08/2019	to	Tue 04/09/2019		(Import)	
0600	Continuous	1800	SCH - PJM_NEPTUNE	375 MW	
Work scheduled by: LI			Impacts Total Transfer Capability	285 MW	
			TTC with All Lines In Service	660 MW	
S.RIPLEY-DUNKIRK_230_68				FWD	REV
Mon 04/08/2019	to	Mon 04/15/2019	UPDATED	(Import)	(Export)
0800	Continuous	2000	by PJM		
Work scheduled by: PJM			02/11/2019	SCH - PJ - NY	2600 MW 1300 MW
				Impacts Total Transfer Capability	0 MW 250 MW
				TTC with All Lines In Service	2600 MW 1550 MW
MARCY_345KV_CSC				FWD	
Thu 04/11/2019	to	Wed 04/17/2019		(Import)	
0500	Continuous	1730	CENTRAL EAST - VC	2925 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	50 MW	
			TTC with All Lines In Service	2975 MW	

NYISO TRANSFER LIMITATIONS

Monday ,February 18, 2019 to Wednesday, August 19, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY -EDIC 345 UE1-7

Thu 04/11/2019 to Sat 04/20/2019
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19&16

FWD
(Import)
OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

SCRIBA -VOLNEY 345 20

Mon 04/15/2019 to Tue 04/16/2019
0600 Continuous 1800

Work scheduled by: NGrid

FWD
(Import)
OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

GILBOA -N.SCTLND 345 GNS-1

Thu 04/18/2019 to Thu 04/18/2019
1330 Continuous 1530

Work scheduled by: NYPA

UPDATED by NYPA 01/23/2019

FWD
(Import)
CENTRAL EAST - VC **2520 MW**
Impacts Total Transfer Capability 455 MW
TTC with All Lines In Service 2975 MW

MARCY 765 345 AT2

Mon 04/22/2019 to Fri 04/26/2019
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

EDIC -FRASER 345 EF24-40

Mon 04/22/2019 to Sun 04/28/2019
0500 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

SPRNBRK 345KV_RNS5

Mon 04/29/2019 to Mon 04/29/2019
0001 Continuous 0030

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

SPRNBRK -W49TH_ST 345 M51

Mon 04/29/2019 to Sun 05/05/2019
0001 Continuous 2200

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Monday ,February 18, 2019 to Wednesday, August 19, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASANX-COOPERS__345_UCC2-41

Mon 04/29/2019 to Fri 05/03/2019
0500 Continuous 1730

UPDATED by NYPA 08/22/2018

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

MARCY__-FRASANX_345_UCC2-41

Mon 04/29/2019 to Fri 05/03/2019
0500 Continuous 1730

UPDATED by NYPA 08/22/2018

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

MOSES__-ADIRNDCK_230_MA1

Mon 04/29/2019 to Fri 05/03/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

EGRDNCTY_345_138_AT2

Wed 05/01/2019 to Wed 05/15/2019
0001 Continuous 2359

Work scheduled by: LI

FWD
(Import)
CONED - LIPA **1250 MW**
Impacts Total Transfer Capability 250 MW
TTC with All Lines In Service 1500 MW

HUDSONTP-W49TH_ST_345_Y56

Wed 05/01/2019 to Tue 05/07/2019
0600 Continuous 1800

Work scheduled by: PJM

FWD
(Import)
SCH - PJM_HTP **0 MW**
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

SPRNBRK__345KV_RNS5

Sun 05/05/2019 to Sun 05/05/2019
2130 Continuous 2200

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

KINTIGH_-ROCHESTR_345_SR1-39

Mon 05/06/2019 to Fri 05/10/2019
0600 Continuous 1700

Work scheduled by: NYPA

UPDATED by NYSEG 11/08/2018

FWD
(Import)
DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Monday ,February 18, 2019 to Wednesday, August 19, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event Name	Start Date	End Date	Time	Duration	Work Scheduled by	Transfer Capability	Impact	TTC
SHOR_NPX-SHOREHAM_138_CSC	Mon 05/06/2019	Fri 05/10/2019	0700	Continuous	LI	SCH - NPX_CSC	0 MW	0 MW
						Impacts Total Transfer Capability	330 MW	330 MW
						TTC with All Lines In Service	330 MW	330 MW
ROSETON_-ROCKTVRN_345_311	Mon 05/06/2019	Sat 06/01/2019	0800	Continuous	CHGE	UPNY CONED	4400 MW	
						Impacts Total Transfer Capability	1300 MW	
						TTC with All Lines In Service	5700 MW	
NIAGARA_-ROCHESTR_345_NR2	Mon 05/13/2019	Fri 05/17/2019	0600	Continuous	NYPA	DYSINGER EAST	1400 MW	
						Impacts Total Transfer Capability	1750 MW	
						TTC with All Lines In Service	3150 MW	
ADIRNDCK-PORTER___230_12	Mon 05/20/2019	Fri 05/24/2019	0700	Continuous	NYPA	MOSES SOUTH	2100 MW	
						Impacts Total Transfer Capability	1050 MW	
						TTC with All Lines In Service	3150 MW	
PANNELL_-CLAY___345_1	Mon 05/20/2019	Fri 05/24/2019	0700	Continuous	NYPA	WEST CENTRAL	1300 MW	
						Impacts Total Transfer Capability	950 MW	
						TTC with All Lines In Service	2250 MW	
ROSETON_-EFISHKIL_345_RFK305	Thu 05/23/2019	Thu 05/23/2019	0800	Daily	CHGE	UPNY CONED	4800 MW	
						Impacts Total Transfer Capability	900 MW	
						TTC with All Lines In Service	5700 MW	
SCRIBA_-VOLNEY___345_20	Tue 05/28/2019	Tue 05/28/2019	0600	Continuous	NGrid	OSWEGO EXPORT	5250 MW	
						Impacts Total Transfer Capability	0 MW	
						TTC with All Lines In Service	5250 MW	

NYISO TRANSFER LIMITATIONS

Monday ,February 18, 2019 to Wednesday, August 19, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PANNELL_-CLAY_345_2				FWD	
Mon 06/03/2019	to	Fri 06/07/2019		(Import)	
0700	Continuous	1530	WEST CENTRAL	1300 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	950 MW	
			TTC with All Lines In Service	2250 MW	
MOSES_-ADIRNDCK_230_MA2				FWD	
Mon 06/24/2019	to	Fri 06/28/2019		(Import)	
0700	Continuous	1500	MOSES SOUTH	2100 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1050 MW	
			TTC with All Lines In Service	3150 MW	
MOSES_-ADIRNDCK_230_MA2				FWD	
Mon 07/08/2019	to	Fri 07/12/2019		(Import)	
0700	Continuous	1500	MOSES SOUTH	2100 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1050 MW	
			TTC with All Lines In Service	3150 MW	
ADIRNDCK-CHASLAKE_230_13				FWD	
Mon 07/08/2019	to	Fri 07/12/2019		(Import)	
0700	Continuous	1530	MOSES SOUTH	2100 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1050 MW	
			TTC with All Lines In Service	3150 MW	
MARCY_765_345_AT2				FWD	
Sat 08/03/2019	to	Sun 08/04/2019		(Import)	
0500	Continuous	1730	MOSES SOUTH	1700 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1450 MW	
			TTC with All Lines In Service	3150 MW	
MOSES_-ADIRNDCK_230_MA1				FWD	
Mon 08/12/2019	to	Mon 08/12/2019	UPDATED	by NYPA	10/10/2018
0700	Continuous	1459	MOSES SOUTH	2100 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1050 MW	
			TTC with All Lines In Service	3150 MW	
SHOR_NPX-SHOREHAM_138_CSC				FWD	REV
Tue 09/03/2019	to	Wed 09/04/2019	UPDATED	by ISONE	02/15/2019
0300	Continuous	1600	SCH - NPX_CSC	0 MW	0 MW
Work scheduled by: LI			Impacts Total Transfer Capability	330 MW	330 MW
			TTC with All Lines In Service	330 MW	330 MW

NYISO TRANSFER LIMITATIONS

Monday ,February 18, 2019 to Wednesday, August 19, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT1

Tue 09/03/2019 to Tue 09/03/2019
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1750 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 3150 MW

MARCY___-N.SCTLND_345_18

Wed 09/04/2019 to Wed 09/04/2019
0500 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 11/06/2018

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2090 MW**
Impacts Total Transfer Capability 885 MW
TTC with All Lines In Service 2975 MW

MARCY___345KV_CSC

Wed 09/04/2019 to Wed 09/04/2019
0500 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 11/06/2018

FWD
(Import)
CENTRAL EAST - VC **2925 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

MOSES___-ADIRNDCK_230_MA2

Wed 09/04/2019 to Wed 09/04/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

ADIRNDCK-PORTER___230_12

Wed 09/04/2019 to Wed 09/04/2019
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

ADIRNDCK-CHASLAKE_230_13

Thu 09/05/2019 to Thu 09/05/2019
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

NIAGARA_-ROCHESTR_345_NR2

Mon 09/09/2019 to Sat 09/21/2019
0500 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Monday ,February 18, 2019 to Wednesday, August 19, 2020

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LEEDS___345KV_R395

FWD

Mon 09/09/2019 to Mon 09/09/2019
0700 Continuous 0730

(Import)

Work scheduled by: NYPA

UPNY CONED **3800 MW**
Impacts Total Transfer Capability 1900 MW
TTC with All Lines In Service 5700 MW

GILBOA_-LEEDS___345_GL3

FWD

Mon 09/09/2019 to Fri 09/27/2019
0700 Continuous 1730

(Import)

Work scheduled by: NYPA

CENTRAL EAST - VC **2200 MW**
Impacts Total Transfer Capability 775 MW
TTC with All Lines In Service 2975 MW

MARCY___-N.SCTLND_345_18

FWD

Wed 09/11/2019 to Fri 09/13/2019
0500 Continuous 1730

(Import)

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC **2090 MW**
Impacts Total Transfer Capability 885 MW
TTC with All Lines In Service 2975 MW

MOSES___-ADIRNDCK_230_MA2

FWD

Mon 09/16/2019 to Fri 09/20/2019
0700 Continuous 1500

(Import)

Work scheduled by: NYPA

MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

GOETHALS_345KV_5

Fri 09/20/2019 to Tue 09/24/2019
0001 Continuous 2359

Work scheduled by: ConEd

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

ROCHESTR-PANNELL___345_RP2

FWD

Mon 09/23/2019 to Mon 09/30/2019
0500 Continuous 1700

(Import)

Work scheduled by: NYPA

DYSINGER EAST **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

KINTIGH_-ROCHESTR_345_SRL-39

FWD

Mon 09/23/2019 to Fri 09/27/2019
0600 Continuous 1700

(Import)

Work scheduled by: NYPA

DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Monday ,February 18, 2019 to Wednesday, August 19, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LEEDS___345KV_R395		FWD	
Fri 09/27/2019	to	Fri 09/27/2019	(Import)
1700	Continuous	1730	
Work scheduled by: NYPA		UPNY CONED	3800 MW
		Impacts Total Transfer Capability	1900 MW
		TTC with All Lines In Service	5700 MW
CLAY___-EDIC___345_1-16		FWD	
Mon 09/30/2019	to	Fri 10/04/2019	(Import)
0700	Continuous	1530	
Work scheduled by: NYPA		OSWEGO EXPORT	4850 MW
		Impacts Total Transfer Capability	400 MW
		TTC with All Lines In Service	5250 MW
LEEDS___-HURLYAVE_345_301		FWD	
Mon 09/30/2019	to	Sat 10/26/2019	(Import)
0800	Continuous	1600	
Work scheduled by: CHGE		UPNY CONED	4100 MW
		Impacts Total Transfer Capability	1600 MW
		TTC with All Lines In Service	5700 MW
CLAY___-EDIC___345_2-15		FWD	
Mon 10/07/2019	to	Thu 10/17/2019	(Import)
0700	Continuous	1530	
Work scheduled by: NYPA		OSWEGO EXPORT	4850 MW
		Impacts Total Transfer Capability	400 MW
		TTC with All Lines In Service	5250 MW
MARCY___-N.SCTLND_345_18		FWD	
Wed 10/09/2019	to	Fri 10/11/2019	(Import)
0500	Continuous	1730	
Work scheduled by: NYPA		CENTRAL EAST - VC	2090 MW
		Impacts Total Transfer Capability	885 MW
		TTC with All Lines In Service	2975 MW
CHATGUAY-MASSENA___765_7040		FWD	
Sat 10/12/2019	to	Sat 10/26/2019	(Import)
0100	Continuous	1900	
Work scheduled by: NYPA		MOSES SOUTH	1550 MW
		Impacts Total Transfer Capability	1600 MW
		TTC with All Lines In Service	3150 MW
CHATGUAY-MASSENA___765_7040		FWD	REV
Sat 10/12/2019	to	Sat 10/26/2019	(Import) (Export)
0100	Continuous	1900	
Work scheduled by: NYPA		SCH - HQ - NY	0 MW 0 MW
		Impacts Total Transfer Capability	1500 MW 1000 MW
		TTC with All Lines In Service	1500 MW 1000 MW

ARR: 19

NYISO TRANSFER LIMITATIONS

Monday ,February 18, 2019 to Wednesday, August 19, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>MARCY___765_345_AT1</p> <p>Sat 10/12/2019 to Sat 10/26/2019 0100 Continuous 1900</p> <p>Work scheduled by: NYPA</p>	<p>ARR: 19</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH 1750 MW</p> <p>Impacts Total Transfer Capability 1400 MW</p> <p>TTC with All Lines In Service 3150 MW</p>															
<p>MARCY___765_345_AT2</p> <p>Sat 10/12/2019 to Sat 10/26/2019 0100 Continuous 1900</p> <p>Work scheduled by: NYPA</p>	<p>ARR: 19</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH 1700 MW</p> <p>Impacts Total Transfer Capability 1450 MW</p> <p>TTC with All Lines In Service 3150 MW</p>															
<p>MASSENA_-MARCY___765_MSU1</p> <p>Sat 10/12/2019 to Sat 10/26/2019 0100 Continuous 1900</p> <p>Work scheduled by: NYPA</p>		<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC 2265 MW</p> <p>Impacts Total Transfer Capability 710 MW</p> <p>TTC with All Lines In Service 2975 MW</p>															
<p>MASSENA_-MARCY___765_MSU1</p> <p>Sat 10/12/2019 to Sat 10/26/2019 0100 Continuous 1900</p> <p>Work scheduled by: NYPA</p>		<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH 500 MW</p> <p>Impacts Total Transfer Capability 2650 MW</p> <p>TTC with All Lines In Service 3150 MW</p>															
<p>MASSENA_-MARCY___765_MSU1</p> <p>Sat 10/12/2019 to Sat 10/26/2019 0100 Continuous 1900</p> <p>Work scheduled by: NYPA</p>		<table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 60%;"></td> <td style="width: 20%; text-align: right;">FWD</td> <td style="width: 20%; text-align: right;">REV</td> </tr> <tr> <td></td> <td style="text-align: right;">(Import)</td> <td style="text-align: right;">(Export)</td> </tr> <tr> <td>SCH - HQ - NY</td> <td style="text-align: right;">475 MW</td> <td style="text-align: right;">1000 MW</td> </tr> <tr> <td>Impacts Total Transfer Capability</td> <td style="text-align: right;">1025 MW</td> <td style="text-align: right;">0 MW</td> </tr> <tr> <td>TTC with All Lines In Service</td> <td style="text-align: right;">1500 MW</td> <td style="text-align: right;">1000 MW</td> </tr> </table>		FWD	REV		(Import)	(Export)	SCH - HQ - NY	475 MW	1000 MW	Impacts Total Transfer Capability	1025 MW	0 MW	TTC with All Lines In Service	1500 MW	1000 MW
	FWD	REV															
	(Import)	(Export)															
SCH - HQ - NY	475 MW	1000 MW															
Impacts Total Transfer Capability	1025 MW	0 MW															
TTC with All Lines In Service	1500 MW	1000 MW															
<p>MASSENA_-MARCY___765_MSU1 & CHATGUAY-MASSENA_765_7040</p> <p>Sat 10/12/2019 to Sat 10/26/2019 0100 1900</p> <p>Work scheduled by:</p>		<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH 500 MW</p> <p>Impacts Total Transfer Capability 2650 MW</p> <p>TTC with All Lines In Service 3150 MW</p>															
<p>MOSES_-MASSENA_230_MMS1 & MOSES_-MASSENA_230_MMS2</p> <p>Sat 10/12/2019 to Sat 10/26/2019 0100 1900</p> <p>Work scheduled by:</p>		<table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 60%;"></td> <td style="width: 20%; text-align: right;">FWD</td> <td style="width: 20%; text-align: right;">REV</td> </tr> <tr> <td></td> <td style="text-align: right;">(Import)</td> <td style="text-align: right;">(Export)</td> </tr> <tr> <td>SCH - HQ - NY</td> <td style="text-align: right;">850 MW</td> <td style="text-align: right;">0 MW</td> </tr> <tr> <td>Impacts Total Transfer Capability</td> <td style="text-align: right;">650 MW</td> <td style="text-align: right;">1000 MW</td> </tr> <tr> <td>TTC with All Lines In Service</td> <td style="text-align: right;">1500 MW</td> <td style="text-align: right;">1000 MW</td> </tr> </table>		FWD	REV		(Import)	(Export)	SCH - HQ - NY	850 MW	0 MW	Impacts Total Transfer Capability	650 MW	1000 MW	TTC with All Lines In Service	1500 MW	1000 MW
	FWD	REV															
	(Import)	(Export)															
SCH - HQ - NY	850 MW	0 MW															
Impacts Total Transfer Capability	650 MW	1000 MW															
TTC with All Lines In Service	1500 MW	1000 MW															

NYISO TRANSFER LIMITATIONS

Monday ,February 18, 2019 to Wednesday, August 19, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_3					FWD	
Tue 10/22/2019	to	Tue 10/22/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/06/2019</u>	(Import)
0001	Continuous	0030				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_5					FWD	
Tue 10/22/2019	to	Tue 10/22/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/06/2019</u>	(Import)
0001	Continuous	0030				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
DUNWODIE-MOTTHAVN_345_71					FWD	
Tue 10/22/2019	to	Tue 11/26/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/06/2019</u>	(Import)
0001	Continuous	2359				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
NIAGARA_345_230_AT4					FWD	REV
Wed 10/23/2019	to	Wed 12/18/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>12/19/2018</u>	(Import) (Export)
0500	Continuous	1700				1900 MW 1400 MW
Work scheduled by: NYPA					SCH - OH - NY	
					Impacts Total Transfer Capability	0 MW 350 MW
					TTC with All Lines In Service	1900 MW 1750 MW
HURLYAVE-ROSETON_345_303					FWD	
Mon 11/04/2019	to	Fri 12/06/2019				(Import)
0800	Continuous	1600				4100 MW
Work scheduled by: CHGE					UPNY CONED	
					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	5700 MW
PANNELL_-CLAY_345_2					FWD	
Wed 11/06/2019	to	Fri 11/22/2019				(Import)
0700	Continuous	1530				1300 MW
Work scheduled by: NYPA					WEST CENTRAL	
					Impacts Total Transfer Capability	950 MW
					TTC with All Lines In Service	2250 MW
MARCY_-N.SCTLND_345_18					FWD	
Thu 11/07/2019	to	Fri 11/08/2019				(Import)
0500	Continuous	1730				2090 MW
Work scheduled by: NYPA					CENTRAL EAST - VC	
					Impacts Total Transfer Capability	885 MW
					TTC with All Lines In Service	2975 MW

ARR: 19

NYISO TRANSFER LIMITATIONS

Monday ,February 18, 2019 to Wednesday, August 19, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___345KV_CSC

Thu 11/07/2019 to Fri 11/08/2019
0500 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2925 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

MOSES___-ADIRNDCK_230_MA2

Tue 11/12/2019 to Fri 11/15/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 11/18/2019 to Fri 11/22/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 11/25/2019 to Wed 11/27/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

DUNWODIE_345KV_3

Tue 11/26/2019 to Tue 11/26/2019 **UPDATED by CONED 02/06/2019**
2330 Continuous 2359

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_5

Tue 11/26/2019 to Tue 11/26/2019 **UPDATED by CONED 02/06/2019**
2330 Continuous 2359

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

MOSES___-ADIRNDCK_230_MA2

Mon 12/02/2019 to Fri 12/06/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Monday ,February 18, 2019 to Wednesday, August 19, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA1

Mon 12/09/2019 to Fri 12/13/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 12/16/2019 to Mon 12/16/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA1

Tue 12/17/2019 to Fri 12/20/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

LADENTWN-BUCHAN_S_345_Y88

Wed 01/15/2020 to Thu 02/13/2020
0001 Continuous 2359

Work scheduled by: ORU

11/05/2018

FWD
(Import)
UPNY CONED **4800 MW**
Impacts Total Transfer Capability 900 MW
TTC with All Lines In Service 5700 MW

FRASANNX-COOPERS__345_UCC2-41

Mon 04/27/2020 to Sun 05/31/2020
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

MARCY___-FRASANNX_345_UCC2-41

Mon 04/27/2020 to Sun 05/31/2020
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW