

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 19, 2019 to Thursday ,August 20, 2020

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

	FWD	REV
<b>HUDSONP_-FARRAGUT_345_B3402</b>		
Mon 01/15/2018 to Tue 12/31/2019		(Import) (Export)
0001 Continuous 2359		
<u>EXTENDED</u> by <u>CONED</u> <u>02/06/2019</u>		
Work scheduled by: ConEd		
SCH - PJ - NY	<b>2600 MW</b>	<b>1300 MW</b>
Impacts Total Transfer Capability	0 MW	250 MW
TTC with All Lines In Service	2600 MW	1550 MW
<b>HUDSONP_-FARRAGUT_345_B3402 &amp; MARION_-FARRAGUT_345_C3403</b>		
Mon 01/15/2018 to Tue 12/31/2019		(Import) (Export)
0001 Continuous 2359		
SCH - PJ - NY	<b>2000 MW</b>	<b>1300 MW</b>
Impacts Total Transfer Capability	600 MW	250 MW
TTC with All Lines In Service	2600 MW	1550 MW
<b>MARION_-FARRAGUT_345_C3403</b>		
Mon 01/15/2018 to Tue 12/31/2019		(Import) (Export)
0001 Continuous 2359		
<u>EXTENDED</u> by <u>CONED</u> <u>02/06/2019</u>		
Work scheduled by: ConEd		
SCH - PJ - NY	<b>2600 MW</b>	<b>1300 MW</b>
Impacts Total Transfer Capability	0 MW	250 MW
TTC with All Lines In Service	2600 MW	1550 MW
<b>STLAWRNC-MOSES_230_L33P</b>		
Mon 04/30/2018 to Fri 12/31/2021		(Import) (Export)
0456 Continuous 2359		
<u>EXT FORCE</u> by <u>IESO</u> <u>08/21/2018</u>		
Work scheduled by: IESO		
SCH - OH - NY	<b>2250 MW</b>	<b>2000 MW</b>
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	2250 MW	2000 MW
<b>S.RIPLEY-DUNKIRK_230_68</b>		
Tue 01/15/2019 to Mon 04/08/2019		(Import) (Export)
1128 Continuous 0759		
<u>EXT FORCE</u> by <u>PJM</u> <u>02/11/2019</u>		
Work scheduled by: PJM		
SCH - PJ - NY	<b>2600 MW</b>	<b>1300 MW</b>
Impacts Total Transfer Capability	0 MW	250 MW
TTC with All Lines In Service	2600 MW	1550 MW
<b>DUNWODIE_345KV_6</b>		
Wed 01/23/2019 to Fri 03/01/2019		(Import)
0001 Continuous 2359		
<u>EXTENDED</u> by <u>CE</u> <u>02/07/2019</u>		
Work scheduled by: ConEd		
SPR/DUN-SOUTH	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	
<b>SCH-IMO-NYISO_LIMIT_1700</b>		
Mon 02/11/2019 to Fri 12/31/2021		(Import)
0001 Continuous 2359		
SCH - OH - NY	<b>2000 MW</b>	
Impacts Total Transfer Capability	250 MW	
TTC with All Lines In Service	2250 MW	

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 19, 2019 to Thursday ,August 20, 2020

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MOSES___-ADIRNDCK_230_MA1</b>					FWD
Mon 02/11/2019	to	Fri 02/15/2019			(Import)
0700	Continuous	1500		MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 850 MW
					TTC with All Lines In Service 3150 MW
<b>W49TH_ST-E13THSTA_345_M55</b>					FWD
Wed 02/13/2019	to	Fri 02/22/2019	<b><u>EXT FORCE</u></b>	<b><u>by CE</u></b>	<b><u>02/14/2019</u></b>
0652	Continuous	2359		SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
<b>W49TH_ST_345KV_6</b>					FWD
Wed 02/13/2019	to	Fri 02/22/2019	<b><u>EXT FORCE</u></b>	<b><u>by CE</u></b>	<b><u>02/14/2019</u></b>
0652	Continuous	2359		SCH - PJM_HTP	<b>375 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 285 MW
					TTC with All Lines In Service 660 MW
<b>MILLWOOD-EASTVIEW_345_W99</b>					FWD
Thu 02/14/2019	to	Thu 02/14/2019	<b><u>UPDATED</u></b>	<b><u>by CONED</u></b>	<b><u>02/08/2019</u></b>
0001	Continuous	0030		UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 1350 MW
					TTC with All Lines In Service 5700 MW
<b>SPRNBK__345KV_RNS5</b>					FWD
Thu 02/14/2019	to	Thu 02/14/2019	<b><u>UPDATED</u></b>	<b><u>by CONED</u></b>	<b><u>02/08/2019</u></b>
0001	Continuous	0030		SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW
<b>EASTVIEW-SPRNBK__345_W64</b>					FWD
Thu 02/14/2019	to	Thu 02/14/2019	<b><u>UPDATED</u></b>	<b><u>by CONED</u></b>	<b><u>02/08/2019</u></b>
0001	Continuous	2230		UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 1350 MW
					TTC with All Lines In Service 5700 MW
<b>BECK___-NIAGARA_345_PA302</b>					FWD
Thu 02/14/2019	to	Thu 02/14/2019	<b><u>CANCELLED</u></b>	<b><u>by IESO</u></b>	<b><u>02/14/2019</u></b>
0500	Continuous	1700		SCH - OH - NY	<b>1100 MW 950 MW</b>
Work scheduled by: IESO					Impacts Total Transfer Capability 1150 MW 1050 MW
					TTC with All Lines In Service 2250 MW 2000 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 19, 2019 to Thursday ,August 20, 2020

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MILLWOOD-EASTVIEW_345_W99</b>					FWD	
Thu 02/14/2019	to	Thu 02/14/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/08/2019</u>	(Import)
2200	Continuous	2230				UPNY CONED <b>4350 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 1350 MW
						TTC with All Lines In Service 5700 MW
<b>SPRNBRK_345KV_RNS5</b>					FWD	
Thu 02/14/2019	to	Thu 02/14/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/08/2019</u>	(Import)
2200	Continuous	2230				SPR/DUN-SOUTH <b>3200 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 1400 MW
						TTC with All Lines In Service 4600 MW
<b>SCRIBA_-VOLNEY_345_20</b>					FWD	
Sat 02/16/2019	to	Sun 02/17/2019				(Import)
0600	Continuous	1900				OSWEGO EXPORT <b>5250 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability 0 MW
						TTC with All Lines In Service 5250 MW
<b>BECK_-NIAGARA_345_PA302</b>					FWD	REV
Tue 02/19/2019	to	Tue 02/19/2019	<u>CANCELLED</u>	<u>by IESO</u>	<u>02/15/2019</u>	(Import) (Export)
0500	Continuous	1700				SCH - OH - NY <b>1100 MW 950 MW</b>
Work scheduled by: IESO						Impacts Total Transfer Capability 1150 MW 1050 MW
						TTC with All Lines In Service 2250 MW 2000 MW
<b>ADIRNDCK-PORTER_230_12</b>					FWD	
Wed 02/20/2019	to	Wed 02/20/2019				(Import)
0700	Daily(No Weekends)	1530				MOSES SOUTH <b>2300 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability 850 MW
						TTC with All Lines In Service 3150 MW
<b>MOSES_-ADIRNDCK_230_MA2</b>					FWD	
Wed 02/20/2019	to	Wed 02/20/2019				(Import)
0700	Continuous	1530				MOSES SOUTH <b>2300 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability 850 MW
						TTC with All Lines In Service 3150 MW
<b>FIVEMILE-STOLLERD_345_29</b>					FWD	REV
Wed 02/20/2019	to	Fri 02/22/2019				(Import) (Export)
0730	Continuous	1900				SCH - PJ - NY <b>2600 MW 1300 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability 0 MW 250 MW
						TTC with All Lines In Service 2600 MW 1550 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 19, 2019 to Thursday ,August 20, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT\_DC\_GC2

Thu 02/21/2019 to Thu 02/21/2019  
 0500 Continuous 1800  
 Work scheduled by: HQ

FWD  
 (Import)  
 MOSES SOUTH **2850 MW**  
 Impacts Total Transfer Capability 300 MW  
 TTC with All Lines In Service 3150 MW

CHAT\_DC\_GC2

Thu 02/21/2019 to Thu 02/21/2019  
 0500 Continuous 1800  
 Work scheduled by: HQ

REV  
 (Export)  
 SCH - HQ - NY **500 MW**  
 Impacts Total Transfer Capability 500 MW  
 TTC with All Lines In Service 1000 MW

ADIRNDCK-CHASLAKE\_230\_13

Thu 02/21/2019 to Thu 02/21/2019  
 0700 Daily(No Weekends) 1530  
 Work scheduled by: NGrid

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

MOSES\_\_-ADIRNDCK\_230\_MAI

Thu 02/21/2019 to Thu 02/21/2019 **UPDATED by NYISO 02/14/2019**  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

MOSES\_\_-ADIRNDCK\_230\_MAI

Mon 02/25/2019 to Fri 03/01/2019 **UPDATED by NYPA 02/19/2019**  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

SCRIBA\_\_-VOLNEY\_\_345\_21

Wed 02/27/2019 to Thu 02/28/2019 **UPDATED by NGRID 12/11/2018**  
 0730 Continuous 2000  
 Work scheduled by: NGrid

FWD  
 (Import)  
 OSWEGO EXPORT **5250 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 5250 MW

ATHENS\_\_-PLSNTVLY\_345\_91

Thu 02/28/2019 to Thu 02/28/2019  
 0630 Continuous 2230  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 1900 MW  
 TTC with All Lines In Service 5700 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 19, 2019 to Thursday ,August 20, 2020

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**PLSNTVLY\_345KV\_RNS4**

Thu 02/28/2019 to Thu 02/28/2019  
 0630 Continuous 2230  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 1900 MW  
 TTC with All Lines In Service 5700 MW

-----  
**PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4**

Fri 03/01/2019 to Mon 03/04/2019  
 0001 0200  
 Work scheduled by:

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 1900 MW  
 TTC with All Lines In Service 5700 MW

-----  
**LONG\_MTN-PLSNTVLY\_345\_398**

Fri 03/01/2019 to Sun 05/19/2019 **UPDATED by ISONE 01/30/2019**  
 0001 Continuous 2359  
 Work scheduled by: ConEd

FWD REV  
 (Import) (Export)  
 SCH - NE - NY **700 MW 1250 MW**  
 Impacts Total Transfer Capability 700 MW 550 MW  
 TTC with All Lines In Service 1400 MW 1800 MW

-----  
**LONG\_MTN-PLSNTVLY\_345\_398**

Fri 03/01/2019 to Sun 05/19/2019 **UPDATED by ISONE 01/30/2019**  
 0001 Continuous 2359  
 Work scheduled by: ConEd

FWD REV  
 (Import) (Export)  
 SCH - NPX\_1385 **100 MW 100 MW**  
 Impacts Total Transfer Capability 100 MW 100 MW  
 TTC with All Lines In Service 200 MW 200 MW

-----  
**SCH-NYISO-NE\_LIMIT\_700**

Fri 03/01/2019 to Sun 05/19/2019 **UPDATED by ISONE 01/30/2019**  
 0001 Continuous 2359  
 Work scheduled by: ConEd

REV  
 (Export)  
 SCH - NE - NY **900 MW**  
 Impacts Total Transfer Capability 900 MW  
 TTC with All Lines In Service 1800 MW

-----  
**PLSNTVLY-EFISHKIL\_345\_F37**

Mon 03/04/2019 to Wed 03/06/2019 **UPDATED by ISONE 01/30/2019**  
 0201 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

-----  
**SCRIBA\_-VOLNEY\_345\_20**

Mon 03/04/2019 to Tue 03/05/2019  
 0600 Continuous 1800  
 Work scheduled by: NGrid

FWD  
 (Import)  
 OSWEGO EXPORT **5250 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 5250 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 19, 2019 to Thursday ,August 20, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

Mon 03/04/2019 to Fri 03/08/2019  
 0700 Continuous 1500  
 Work scheduled by: NYPA

FWD  
 (Import)  
**MOSES SOUTH 2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

**DUNWODIE\_345KV\_4**

Thu 03/07/2019 to Thu 03/07/2019 **UPDATED by CONED 02/06/2019**  
 0001 Continuous 0030  
 Work scheduled by: LI

FWD  
 (Import)  
**SPR/DUN-SOUTH 3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_6**

Thu 03/07/2019 to Thu 03/07/2019 **UPDATED by CONED 02/06/2019**  
 0001 Continuous 0030  
 Work scheduled by: LI

FWD  
 (Import)  
**SPR/DUN-SOUTH 3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**DUNWODIE-SHORE\_RD\_345\_Y50**

Thu 03/07/2019 to Fri 03/08/2019 **UPDATED by CONED 02/06/2019**  
 0001 Continuous 2359  
 Work scheduled by: LI

FWD  
 (Import)  
**CONED - LIPA 800 MW**  
 Impacts Total Transfer Capability 700 MW  
 TTC with All Lines In Service 1500 MW

**SHORE\_RD\_345\_138\_BK 1**

Thu 03/07/2019 to Fri 03/08/2019 **UPDATED by CONED 02/06/2019**  
 0001 Continuous 2359  
 Work scheduled by: LI

FWD  
 (Import)  
**CONED - LIPA 1350 MW**  
 Impacts Total Transfer Capability 150 MW  
 TTC with All Lines In Service 1500 MW

**SHORE\_RD\_345\_138\_BK 2**

Thu 03/07/2019 to Fri 03/08/2019 **UPDATED by CONED 02/06/2019**  
 0001 Continuous 2359  
 Work scheduled by: LI

FWD  
 (Import)  
**CONED - LIPA 1350 MW**  
 Impacts Total Transfer Capability 150 MW  
 TTC with All Lines In Service 1500 MW

**EASTVIEW-SPRNBK\_\_345\_W64**

Thu 03/07/2019 to Mon 03/11/2019 **UPDATED by CONED 02/08/2019**  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
**UPNY CONED 4350 MW**  
 Impacts Total Transfer Capability 1350 MW  
 TTC with All Lines In Service 5700 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 19, 2019 to Thursday ,August 20, 2020

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MILLWOOD-EASTVIEW_345_W99</b>					FWD		
Thu 03/07/2019	to	Mon 03/11/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/08/2019</u>	(Import)	
0001	Continuous	0200				<b>4350 MW</b>	
Work scheduled by: ConEd					UPNY CONED		
					Impacts Total Transfer Capability	1350 MW	
					TTC with All Lines In Service	5700 MW	
<b>DUNWODIE_345KV_4</b>					FWD		
Fri 03/08/2019	to	Fri 03/08/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/06/2019</u>	(Import)	
2330	Continuous	2359				<b>3800 MW</b>	
Work scheduled by: LI					SPR/DUN-SOUTH		
					Impacts Total Transfer Capability	800 MW	
					TTC with All Lines In Service	4600 MW	
<b>DUNWODIE_345KV_6</b>					FWD		
Fri 03/08/2019	to	Fri 03/08/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/06/2019</u>	(Import)	
2330	Continuous	2359				<b>3800 MW</b>	
Work scheduled by: LI					SPR/DUN-SOUTH		
					Impacts Total Transfer Capability	800 MW	
					TTC with All Lines In Service	4600 MW	
<b>MILLWOOD_345KV_18</b>					FWD		
Mon 03/11/2019	to	Mon 03/11/2019				(Import)	
0001	Continuous	0030				<b>4350 MW</b>	
Work scheduled by: ConEd					UPNY CONED		
					Impacts Total Transfer Capability	1350 MW	
					TTC with All Lines In Service	5700 MW	
<b>LADENTWN-BUCHAN_S_345_Y88</b>					FWD		
Mon 03/11/2019	to	Thu 03/28/2019				(Import)	
0001	Continuous	0200				<b>4800 MW</b>	
Work scheduled by: ConEd					UPNY CONED		
					Impacts Total Transfer Capability	900 MW	
					TTC with All Lines In Service	5700 MW	
<b>BECK -NIAGARA_345_PA301</b>					FWD	REV	
Mon 03/11/2019	to	Fri 03/15/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>02/06/2019</u>	(Import)	(Export)
0600	Continuous	1700				<b>1100 MW</b>	<b>950 MW</b>
Work scheduled by: NYPA					SCH - OH - NY		
					Impacts Total Transfer Capability	1150 MW	1050 MW
					TTC with All Lines In Service	2250 MW	2000 MW
<b>STLAWRNC-MOSES_230_L33P &amp; STLAWRNC-MOSES_230_L34P</b>					FWD		
Mon 03/11/2019	to	Mon 03/11/2019				(Import)	
0700		1530				<b>2700 MW</b>	
Work scheduled by:					MOSES SOUTH		
					Impacts Total Transfer Capability	450 MW	
					TTC with All Lines In Service	3150 MW	

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 19, 2019 to Thursday ,August 20, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STLAWRNC-MOSES	230_L34P	FWD	REV
		(Import)	(Export)
Mon 03/11/2019	to Mon 03/11/2019		
0700	Continuous 1530	SCH - OH - NY	<b>2250 MW 2000 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability	0 MW 0 MW
		TTC with All Lines In Service	2250 MW 2000 MW
LEEDS	345_LEEDS SVC	FWD	
		(Import)	
Mon 03/11/2019	to Fri 03/22/2019		
0800	Continuous 1600	CENTRAL EAST - VC	<b>2950 MW</b>
Work scheduled by: NGrid		Impacts Total Transfer Capability	25 MW
		TTC with All Lines In Service	2975 MW
MOSES	-ADIRNDCK_230_MA1	FWD	
		(Import)	
Tue 03/12/2019	to Fri 03/15/2019		
0700	Continuous 1500	MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability	850 MW
		TTC with All Lines In Service	3150 MW
MILLWOOD_345KV_18		FWD	
		(Import)	
Wed 03/13/2019	to Thu 03/14/2019		
0001	Continuous 0200	UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd		Impacts Total Transfer Capability	1350 MW
		TTC with All Lines In Service	5700 MW
MARCY	765_345_AT1	FWD	
		(Import)	
Mon 03/18/2019	to Fri 03/22/2019		
0500	Continuous 1530	MOSES SOUTH	<b>1750 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability	1400 MW
		TTC with All Lines In Service	3150 MW
SCH-NYISO-HQ_CEDARS_LIMIT_0			REV
			(Export)
Mon 03/18/2019	to Thu 04/04/2019		
0700	Continuous 1700	SCH - HQ_CEDARS	<b>0 MW</b>
Work scheduled by: HQ		Impacts Total Transfer Capability	100 MW
		TTC with All Lines In Service	100 MW
MILLWOOD_345KV_18		FWD	
		(Import)	
Thu 03/28/2019	to Thu 03/28/2019		
0130	Continuous 0200	UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd		Impacts Total Transfer Capability	1350 MW
		TTC with All Lines In Service	5700 MW

ARR: 19

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 19, 2019 to Thursday ,August 20, 2020

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
<p><b>MARCY___345KV_CSC</b></p> <p>Mon 04/01/2019 to Sun 04/07/2019 0500 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC <b>2925 MW</b></p> <p>Impacts Total Transfer Capability 50 MW</p> <p>TTC with All Lines In Service 2975 MW</p>		
<hr/>			
<p><b>VOLNEY_-MARCY___345_19</b></p> <p>Mon 04/01/2019 to Wed 04/10/2019 0500 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC <b>2825 MW</b></p> <p>Impacts Total Transfer Capability 150 MW</p> <p>TTC with All Lines In Service 2975 MW</p>		
<hr/>			
<p><b>VOLNEY_-MARCY___345_19</b></p> <p>Mon 04/01/2019 to Wed 04/10/2019 0500 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>OSWEGO EXPORT <b>4900 MW</b></p> <p>Impacts Total Transfer Capability 350 MW</p> <p>TTC with All Lines In Service 5250 MW</p>		
<hr/>			
<p><b>PLSNTVLY-EFISHKIL_345_F37</b></p> <p>Thu 04/04/2019 to Mon 04/08/2019 0001 Continuous 0200</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>UPNY CONED <b>4000 MW</b></p> <p>Impacts Total Transfer Capability 1700 MW</p> <p>TTC with All Lines In Service 5700 MW</p>		
<hr/>			
<p><b>NIAGARA_-ROCHESTR_345_NR2</b></p> <p>Fri 04/05/2019 to Fri 04/05/2019 0500 Continuous 1700</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>DYSINGER EAST <b>1700 MW</b></p> <p>Impacts Total Transfer Capability 1450 MW</p> <p>TTC with All Lines In Service 3150 MW</p>		
<hr/>			
<p><b>LINDN_CG-LNDVFT___345_V-3022</b></p> <p>Sun 04/07/2019 to Fri 04/12/2019 1400 Continuous 1800</p> <p>Work scheduled by: PJM</p>	<p style="text-align: right;">FWD REV (Import) (Export)</p> <p>SCH - PJM_VFT <b>0 MW 0 MW</b></p> <p>Impacts Total Transfer Capability 315 MW 315 MW</p> <p>TTC with All Lines In Service 315 MW 315 MW</p>		
<hr/>			
<p><b>PLSNTVLY_345KV_RN5 &amp; PLSNTVLY_345KV_RN4</b></p> <p>Mon 04/08/2019 to Sat 04/13/2019 0001 0300</p> <p>Work scheduled by:</p>	<p style="text-align: right;">FWD (Import)</p> <p>UPNY CONED <b>3800 MW</b></p> <p>Impacts Total Transfer Capability 1900 MW</p> <p>TTC with All Lines In Service 5700 MW</p>		
<hr/>			

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 19, 2019 to Thursday ,August 20, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLE-DUNWODIE\_345\_W89

Mon 04/08/2019 to Fri 05/10/2019  
 0001 Continuous 2359  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

Mon 04/08/2019 to Tue 04/09/2019  
 0600 Continuous 1800  
 Work scheduled by: LI

FWD  
 (Import)  
 SCH - PJM\_NEPTUNE **0 MW**  
 Impacts Total Transfer Capability 660 MW  
 TTC with All Lines In Service 660 MW

NEWBRDGE-DUFFYAVE\_345\_501

Mon 04/08/2019 to Tue 04/09/2019  
 0600 Continuous 1800  
 Work scheduled by: LI

FWD  
 (Import)  
 SCH - PJM\_NEPTUNE **0 MW**  
 Impacts Total Transfer Capability 660 MW  
 TTC with All Lines In Service 660 MW

NEWBRDGE\_345\_138\_BK\_1

Mon 04/08/2019 to Tue 04/09/2019  
 0600 Continuous 1800  
 Work scheduled by: LI

FWD  
 (Import)  
 SCH - PJM\_NEPTUNE **375 MW**  
 Impacts Total Transfer Capability 285 MW  
 TTC with All Lines In Service 660 MW

NEWBRDGE\_345\_138\_BK\_2

Mon 04/08/2019 to Tue 04/09/2019  
 0600 Continuous 1800  
 Work scheduled by: LI

FWD  
 (Import)  
 SCH - PJM\_NEPTUNE **375 MW**  
 Impacts Total Transfer Capability 285 MW  
 TTC with All Lines In Service 660 MW

S.RIPLEY-DUNKIRK\_230\_68

Mon 04/08/2019 to Mon 04/15/2019 **UPDATED by PJM 02/11/2019**  
 0800 Continuous 2000  
 Work scheduled by: PJM

FWD REV  
 (Import) (Export)  
 SCH - PJ - NY **2600 MW 1300 MW**  
 Impacts Total Transfer Capability 0 MW 250 MW  
 TTC with All Lines In Service 2600 MW 1550 MW

MARCY\_345KV\_CSC

Thu 04/11/2019 to Wed 04/17/2019  
 0500 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2925 MW**  
 Impacts Total Transfer Capability 50 MW  
 TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 19, 2019 to Thursday ,August 20, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARCY -EDIC 345 UE1-7**

Thu 04/11/2019 to Sat 04/20/2019  
0500 Continuous 1730

Work scheduled by: NYPA

**ARR: 19&16**

FWD  
(Import)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

**SCRIBA -VOLNEY 345 20**

Mon 04/15/2019 to Tue 04/16/2019  
0600 Continuous 1800

Work scheduled by: NGrid

FWD  
(Import)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

**GILBOA -N.SCTLND 345 GNS-1**

Thu 04/18/2019 to Thu 04/18/2019  
1330 Continuous 1530

Work scheduled by: NYPA

**UPDATED by NYPA 01/23/2019**

FWD  
(Import)  
CENTRAL EAST - VC **2520 MW**  
Impacts Total Transfer Capability 455 MW  
TTC with All Lines In Service 2975 MW

**MARCY 765 345 AT2**

Mon 04/22/2019 to Fri 04/26/2019  
0500 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

**EDIC -FRASER 345 EF24-40**

Mon 04/22/2019 to Sun 04/28/2019  
0500 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

**SPRNBRK 345KV\_RNS5**

Mon 04/29/2019 to Mon 04/29/2019  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

**SPRNBRK -W49TH\_ST 345 M51**

Mon 04/29/2019 to Sun 05/05/2019  
0001 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 19, 2019 to Thursday ,August 20, 2020

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**FRASANX-COOPERS\_\_345\_UCC2-41**

Mon 04/29/2019 to Fri 05/03/2019  
0500 Continuous 1730

**UPDATED by NYPA 08/22/2018**

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

**MARCY\_\_-FRASANX\_345\_UCC2-41**

Mon 04/29/2019 to Fri 05/03/2019  
0500 Continuous 1730

**UPDATED by NYPA 08/22/2018**

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

**MOSES\_\_-ADIRNDCK\_230\_MA1**

Mon 04/29/2019 to Fri 05/03/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**EGRDNCTY\_345\_138\_AT2**

Wed 05/01/2019 to Wed 05/15/2019  
0001 Continuous 2359

Work scheduled by: LI

FWD  
(Import)  
CONED - LIPA **1250 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1500 MW

**HUDSONTP-W49TH\_ST\_345\_Y56**

Wed 05/01/2019 to Tue 05/07/2019  
0600 Continuous 1800

Work scheduled by: PJM

FWD  
(Import)  
SCH - PJM\_HTP **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

**SPRNBRK\_\_345KV\_RNS5**

Sun 05/05/2019 to Sun 05/05/2019  
2130 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

**KINTIGH\_-ROCHESTR\_345\_SR1-39**

Mon 05/06/2019 to Fri 05/10/2019  
0600 Continuous 1700

Work scheduled by: NYPA

**UPDATED by NYSEG 11/08/2018**

FWD  
(Import)  
DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 19, 2019 to Thursday ,August 20, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event Name	Start Date	End Date	Time	Duration	Work by	Zone	FWD (Import)	REV (Export)
<b>SHOR_NPX-SHOREHAM_138_CSC</b>	Mon 05/06/2019	Fri 05/10/2019	0700	Continuous	LI	SCH - NPX_CSC	0 MW	0 MW
							Impacts Total Transfer Capability	330 MW
							TTC with All Lines In Service	330 MW
<b>ROSETON_-ROCKTVRN_345_311</b>	Mon 05/06/2019	Sat 06/01/2019	0800	Continuous	CHGE	UPNY CONED	4400 MW	
							Impacts Total Transfer Capability	1300 MW
							TTC with All Lines In Service	5700 MW
<b>NIAGARA_-ROCHESTR_345_NR2</b>	Mon 05/13/2019	Fri 05/17/2019	0600	Continuous	NYPA	DYSINGER EAST	1400 MW	
							Impacts Total Transfer Capability	1750 MW
							TTC with All Lines In Service	3150 MW
<b>ADIRNDCK-PORTER___230_12</b>	Mon 05/20/2019	Fri 05/24/2019	0700	Continuous	NYPA	MOSES SOUTH	2100 MW	
							Impacts Total Transfer Capability	1050 MW
							TTC with All Lines In Service	3150 MW
<b>PANNELL_-CLAY___345_1</b>	Mon 05/20/2019	Fri 05/24/2019	0700	Continuous	NYPA	WEST CENTRAL	1300 MW	
							Impacts Total Transfer Capability	950 MW
							TTC with All Lines In Service	2250 MW
<b>ROSETON_-EFISHKIL_345_RFK305</b>	Thu 05/23/2019	Thu 05/23/2019	0800	Daily	CHGE	UPNY CONED	4800 MW	
							Impacts Total Transfer Capability	900 MW
							TTC with All Lines In Service	5700 MW
<b>SCRIBA_-VOLNEY___345_20</b>	Tue 05/28/2019	Tue 05/28/2019	0600	Continuous	NGrid	OSWEGO EXPORT	5250 MW	
							Impacts Total Transfer Capability	0 MW
							TTC with All Lines In Service	5250 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 19, 2019 to Thursday ,August 20, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>PANNELL_-CLAY_345_2</b>				FWD	
Mon 06/03/2019	to	Fri 06/07/2019		(Import)	
0700	Continuous	1530	WEST CENTRAL	<b>1300 MW</b>	
Work scheduled by: NYPA				Impacts Total Transfer Capability	950 MW
				TTC with All Lines In Service	2250 MW
<b>MOSES_-ADIRNDCK_230_MA2</b>				FWD	
Mon 06/24/2019	to	Fri 06/28/2019		(Import)	
0700	Continuous	1500	MOSES SOUTH	<b>2100 MW</b>	
Work scheduled by: NYPA				Impacts Total Transfer Capability	1050 MW
				TTC with All Lines In Service	3150 MW
<b>MOSES_-ADIRNDCK_230_MA2</b>				FWD	
Mon 07/08/2019	to	Fri 07/12/2019		(Import)	
0700	Continuous	1500	MOSES SOUTH	<b>2100 MW</b>	
Work scheduled by: NYPA				Impacts Total Transfer Capability	1050 MW
				TTC with All Lines In Service	3150 MW
<b>ADIRNDCK-CHASLAKE_230_13</b>				FWD	
Mon 07/08/2019	to	Fri 07/12/2019		(Import)	
0700	Continuous	1530	MOSES SOUTH	<b>2100 MW</b>	
Work scheduled by: NYPA				Impacts Total Transfer Capability	1050 MW
				TTC with All Lines In Service	3150 MW
<b>MARCY_765_345_AT2</b>				FWD	
Sat 08/03/2019	to	Sun 08/04/2019		(Import)	
0500	Continuous	1730	MOSES SOUTH	<b>1700 MW</b>	
Work scheduled by: NYPA				Impacts Total Transfer Capability	1450 MW
				TTC with All Lines In Service	3150 MW
					<b>ARR: 19</b>
<b>MOSES_-ADIRNDCK_230_MA1</b>				FWD	
Mon 08/12/2019	to	Mon 08/12/2019	<b>UPDATED</b>	<b>by NYPA</b>	<b>10/10/2018</b>
0700	Continuous	1459	MOSES SOUTH	<b>2100 MW</b>	
Work scheduled by: NYPA				Impacts Total Transfer Capability	1050 MW
				TTC with All Lines In Service	3150 MW
<b>SHOR_NPX-SHOREHAM_138_CSC</b>				FWD	REV
Tue 09/03/2019	to	Wed 09/04/2019	<b>UPDATED</b>	<b>by ISONE</b>	<b>02/15/2019</b>
0300	Continuous	1600	SCH - NPX_CSC	<b>0 MW</b>	<b>0 MW</b>
Work scheduled by: LI				Impacts Total Transfer Capability	330 MW 330 MW
				TTC with All Lines In Service	330 MW 330 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 19, 2019 to Thursday ,August 20, 2020

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARCY\_\_\_765\_345\_AT1**

Tue 09/03/2019 to Tue 09/03/2019  
0500 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
MOSES SOUTH **1750 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 3150 MW

**MARCY\_\_\_-N.SCTLND\_345\_18**

Wed 09/04/2019 to Wed 09/04/2019  
0500 Continuous 1730

Work scheduled by: NYPA

**UPDATED by NYPA 11/06/2018**

**ARR: 19**

FWD  
(Import)  
CENTRAL EAST - VC **2090 MW**  
Impacts Total Transfer Capability 885 MW  
TTC with All Lines In Service 2975 MW

**MARCY\_\_\_345KV\_CSC**

Wed 09/04/2019 to Wed 09/04/2019  
0500 Continuous 1730

Work scheduled by: NYPA

**UPDATED by NYPA 11/06/2018**

FWD  
(Import)  
CENTRAL EAST - VC **2925 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Wed 09/04/2019 to Wed 09/04/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

**ADIRNDCK-PORTER\_\_\_230\_12**

Wed 09/04/2019 to Wed 09/04/2019  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

**ADIRNDCK-CHASLAKE\_230\_13**

Thu 09/05/2019 to Thu 09/05/2019  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

**NIAGARA\_-ROCHESTR\_345\_NR2**

Mon 09/09/2019 to Sat 09/21/2019  
0500 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 19, 2019 to Thursday ,August 20, 2020

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**LEEDS\_\_\_345KV\_R395**

Mon 09/09/2019 to Mon 09/09/2019  
0700 Continuous 0730

Work scheduled by: NYPA

FWD

(Import)

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1900 MW  
TTC with All Lines In Service 5700 MW

**GILBOA\_-LEEDS\_\_\_345\_GL3**

Mon 09/09/2019 to Fri 09/27/2019  
0700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC **2200 MW**  
Impacts Total Transfer Capability 775 MW  
TTC with All Lines In Service 2975 MW

**MARCY\_\_\_-N.SCTLND\_345\_18**

Wed 09/11/2019 to Fri 09/13/2019  
0500 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

FWD

(Import)

CENTRAL EAST - VC **2090 MW**  
Impacts Total Transfer Capability 885 MW  
TTC with All Lines In Service 2975 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Mon 09/16/2019 to Fri 09/20/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

**GOETHALS\_345KV\_5**

Fri 09/20/2019 to Tue 09/24/2019  
0001 Continuous 2359

Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**ROCHESTR-PANNELL\_\_\_345\_RP2**

Mon 09/23/2019 to Mon 09/30/2019  
0500 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**KINTIGH\_-ROCHESTR\_345\_SRL-39**

Mon 09/23/2019 to Fri 09/27/2019  
0600 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 19, 2019 to Thursday ,August 20, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>LEEDS___345KV_R395</b>		FWD	
Fri 09/27/2019	to	Fri 09/27/2019	(Import)
1700	Continuous	1730	
Work scheduled by: NYPA		UPNY CONED	<b>3800 MW</b>
		Impacts Total Transfer Capability	1900 MW
		TTC with All Lines In Service	5700 MW
<b>CLAY___-EDIC___345_1-16</b>		FWD	
Mon 09/30/2019	to	Fri 10/04/2019	(Import)
0700	Continuous	1530	
Work scheduled by: NYPA		OSWEGO EXPORT	<b>4850 MW</b>
		Impacts Total Transfer Capability	400 MW
		TTC with All Lines In Service	5250 MW
<b>LEEDS___-HURLYAVE_345_301</b>		FWD	
Mon 09/30/2019	to	Sat 10/26/2019	(Import)
0800	Continuous	1600	
Work scheduled by: CHGE		UPNY CONED	<b>4100 MW</b>
		Impacts Total Transfer Capability	1600 MW
		TTC with All Lines In Service	5700 MW
<b>CLAY___-EDIC___345_2-15</b>		FWD	
Mon 10/07/2019	to	Thu 10/17/2019	(Import)
0700	Continuous	1530	
Work scheduled by: NYPA		OSWEGO EXPORT	<b>4850 MW</b>
		Impacts Total Transfer Capability	400 MW
		TTC with All Lines In Service	5250 MW
<b>MARCY___-N.SCTLND_345_18</b>		FWD	
Wed 10/09/2019	to	Fri 10/11/2019	(Import)
0500	Continuous	1730	
Work scheduled by: NYPA		CENTRAL EAST - VC	<b>2090 MW</b>
		Impacts Total Transfer Capability	885 MW
		TTC with All Lines In Service	2975 MW
<b>CHATGUAY-MASSENA_765_7040</b>		FWD	
Sat 10/12/2019	to	Sat 10/26/2019	(Import)
0100	Continuous	1900	
Work scheduled by: NYPA		MOSES SOUTH	<b>1550 MW</b>
		Impacts Total Transfer Capability	1600 MW
		TTC with All Lines In Service	3150 MW
<b>CHATGUAY-MASSENA_765_7040</b>		FWD	REV
Sat 10/12/2019	to	Sat 10/26/2019	(Import) (Export)
0100	Continuous	1900	
Work scheduled by: NYPA		SCH - HQ - NY	<b>0 MW 0 MW</b>
		Impacts Total Transfer Capability	1500 MW 1000 MW
		TTC with All Lines In Service	1500 MW 1000 MW

ARR: 19

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 19, 2019 to Thursday ,August 20, 2020

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p><b>MARCY___765_345_AT1</b></p> <p>Sat 10/12/2019 to Sat 10/26/2019 0100 Continuous 1900</p> <p>Work scheduled by: NYPA</p>	<p><b>ARR: 19</b></p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH <b>1750 MW</b></p> <p>Impacts Total Transfer Capability 1400 MW</p> <p>TTC with All Lines In Service 3150 MW</p>															
<p><b>MARCY___765_345_AT2</b></p> <p>Sat 10/12/2019 to Sat 10/26/2019 0100 Continuous 1900</p> <p>Work scheduled by: NYPA</p>	<p><b>ARR: 19</b></p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH <b>1700 MW</b></p> <p>Impacts Total Transfer Capability 1450 MW</p> <p>TTC with All Lines In Service 3150 MW</p>															
<p><b>MASSENA_-MARCY___765_MSU1</b></p> <p>Sat 10/12/2019 to Sat 10/26/2019 0100 Continuous 1900</p> <p>Work scheduled by: NYPA</p>		<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC <b>2265 MW</b></p> <p>Impacts Total Transfer Capability 710 MW</p> <p>TTC with All Lines In Service 2975 MW</p>															
<p><b>MASSENA_-MARCY___765_MSU1</b></p> <p>Sat 10/12/2019 to Sat 10/26/2019 0100 Continuous 1900</p> <p>Work scheduled by: NYPA</p>		<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH <b>500 MW</b></p> <p>Impacts Total Transfer Capability 2650 MW</p> <p>TTC with All Lines In Service 3150 MW</p>															
<p><b>MASSENA_-MARCY___765_MSU1</b></p> <p>Sat 10/12/2019 to Sat 10/26/2019 0100 Continuous 1900</p> <p>Work scheduled by: NYPA</p>		<table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 60%;"></td> <td style="width: 20%; text-align: right;">FWD</td> <td style="width: 20%; text-align: right;">REV</td> </tr> <tr> <td></td> <td style="text-align: right;">(Import)</td> <td style="text-align: right;">(Export)</td> </tr> <tr> <td>SCH - HQ - NY</td> <td style="text-align: right;"><b>475 MW</b></td> <td style="text-align: right;"><b>1000 MW</b></td> </tr> <tr> <td>Impacts Total Transfer Capability</td> <td style="text-align: right;">1025 MW</td> <td style="text-align: right;">0 MW</td> </tr> <tr> <td>TTC with All Lines In Service</td> <td style="text-align: right;">1500 MW</td> <td style="text-align: right;">1000 MW</td> </tr> </table>		FWD	REV		(Import)	(Export)	SCH - HQ - NY	<b>475 MW</b>	<b>1000 MW</b>	Impacts Total Transfer Capability	1025 MW	0 MW	TTC with All Lines In Service	1500 MW	1000 MW
	FWD	REV															
	(Import)	(Export)															
SCH - HQ - NY	<b>475 MW</b>	<b>1000 MW</b>															
Impacts Total Transfer Capability	1025 MW	0 MW															
TTC with All Lines In Service	1500 MW	1000 MW															
<p><b>MASSENA_-MARCY___765_MSU1 &amp; CHATGUAY-MASSENA_765_7040</b></p> <p>Sat 10/12/2019 to Sat 10/26/2019 0100 1900</p> <p>Work scheduled by:</p>		<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH <b>500 MW</b></p> <p>Impacts Total Transfer Capability 2650 MW</p> <p>TTC with All Lines In Service 3150 MW</p>															
<p><b>MOSES_-MASSENA_230_MMS1 &amp; MOSES_-MASSENA_230_MMS2</b></p> <p>Sat 10/12/2019 to Sat 10/26/2019 0100 1900</p> <p>Work scheduled by:</p>		<table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 60%;"></td> <td style="width: 20%; text-align: right;">FWD</td> <td style="width: 20%; text-align: right;">REV</td> </tr> <tr> <td></td> <td style="text-align: right;">(Import)</td> <td style="text-align: right;">(Export)</td> </tr> <tr> <td>SCH - HQ - NY</td> <td style="text-align: right;"><b>850 MW</b></td> <td style="text-align: right;"><b>0 MW</b></td> </tr> <tr> <td>Impacts Total Transfer Capability</td> <td style="text-align: right;">650 MW</td> <td style="text-align: right;">1000 MW</td> </tr> <tr> <td>TTC with All Lines In Service</td> <td style="text-align: right;">1500 MW</td> <td style="text-align: right;">1000 MW</td> </tr> </table>		FWD	REV		(Import)	(Export)	SCH - HQ - NY	<b>850 MW</b>	<b>0 MW</b>	Impacts Total Transfer Capability	650 MW	1000 MW	TTC with All Lines In Service	1500 MW	1000 MW
	FWD	REV															
	(Import)	(Export)															
SCH - HQ - NY	<b>850 MW</b>	<b>0 MW</b>															
Impacts Total Transfer Capability	650 MW	1000 MW															
TTC with All Lines In Service	1500 MW	1000 MW															

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 19, 2019 to Thursday ,August 20, 2020

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>DUNWODIE_345KV_3</b>					FWD	
Tue 10/22/2019	to	Tue 10/22/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/06/2019</u>	(Import)
0001	Continuous	0030				<b>3800 MW</b>
Work scheduled by: ConEd					SPR/DUN-SOUTH	<b>3800 MW</b>
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>DUNWODIE_345KV_5</b>					FWD	
Tue 10/22/2019	to	Tue 10/22/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/06/2019</u>	(Import)
0001	Continuous	0030				<b>3800 MW</b>
Work scheduled by: ConEd					SPR/DUN-SOUTH	<b>3800 MW</b>
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>DUNWODIE-MOTTHAVN_345_71</b>					FWD	
Tue 10/22/2019	to	Tue 11/26/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/06/2019</u>	(Import)
0001	Continuous	2359				<b>3800 MW</b>
Work scheduled by: ConEd					SPR/DUN-SOUTH	<b>3800 MW</b>
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>NIAGARA_345_230_AT4</b>					FWD	REV
Wed 10/23/2019	to	Wed 12/18/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>12/19/2018</u>	(Import) (Export)
0500	Continuous	1700				<b>1900 MW 1400 MW</b>
Work scheduled by: NYPA					SCH - OH - NY	<b>1900 MW 1400 MW</b>
					Impacts Total Transfer Capability	0 MW 350 MW
					TTC with All Lines In Service	1900 MW 1750 MW
<b>HURLYAVE-ROSETON_345_303</b>					FWD	
Mon 11/04/2019	to	Fri 12/06/2019				(Import)
0800	Continuous	1600				<b>4100 MW</b>
Work scheduled by: CHGE					UPNY CONED	<b>4100 MW</b>
					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	5700 MW
<b>PANNELL_-CLAY_345_2</b>					FWD	
Wed 11/06/2019	to	Fri 11/22/2019				(Import)
0700	Continuous	1530				<b>1300 MW</b>
Work scheduled by: NYPA					WEST CENTRAL	<b>1300 MW</b>
					Impacts Total Transfer Capability	950 MW
					TTC with All Lines In Service	2250 MW
<b>MARCY_-N.SCTLND_345_18</b>					FWD	
Thu 11/07/2019	to	Fri 11/08/2019				(Import)
0500	Continuous	1730				<b>2090 MW</b>
Work scheduled by: NYPA					CENTRAL EAST - VC	<b>2090 MW</b>
					Impacts Total Transfer Capability	885 MW
					TTC with All Lines In Service	2975 MW

ARR: 19

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 19, 2019 to Thursday ,August 20, 2020

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARCY\_\_\_345KV\_CSC**

Thu 11/07/2019 to Fri 11/08/2019  
0500 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2925 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Tue 11/12/2019 to Fri 11/15/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Mon 11/18/2019 to Fri 11/22/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Mon 11/25/2019 to Wed 11/27/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**DUNWODIE\_345KV\_3**

Tue 11/26/2019 to Tue 11/26/2019 **UPDATED by CONED 02/06/2019**  
2330 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_5**

Tue 11/26/2019 to Tue 11/26/2019 **UPDATED by CONED 02/06/2019**  
2330 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Mon 12/02/2019 to Fri 12/06/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 19, 2019 to Thursday ,August 20, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

Mon 12/09/2019 to Fri 12/13/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Mon 12/16/2019 to Mon 12/16/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

Tue 12/17/2019 to Fri 12/20/2019  
0700 Continuous 1500

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**LADENTWN-BUCHAN\_S\_345\_Y88**

Wed 01/15/2020 to Thu 02/13/2020  
0001 Continuous 2359

Work scheduled by: ORU

11/05/2018

FWD  
(Import)  
UPNY CONED **4800 MW**  
Impacts Total Transfer Capability 900 MW  
TTC with All Lines In Service 5700 MW

**FRASANNX-COOPERS\_\_345\_UCC2-41**

Mon 04/27/2020 to Sun 05/31/2020  
0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

**MARCY\_\_\_-FRASANNX\_345\_UCC2-41**

Mon 04/27/2020 to Sun 05/31/2020  
0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW