

NYISO TRANSFER LIMITATIONS

Friday ,February 22, 2019 to Sunday ,August 23, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

	FWD	REV
HUDSONP_-FARRAGUT_345_B3402		
Mon 01/15/2018 to Tue 12/31/2019		(Import) (Export)
0001 Continuous 2359		
<u>EXTENDED</u> <u>by CONED</u> <u>02/06/2019</u>		
Work scheduled by: ConEd	SCH - PJ - NY	2600 MW 1300 MW
	Impacts Total Transfer Capability	0 MW 250 MW
	TTC with All Lines In Service	2600 MW 1550 MW
HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403		
Mon 01/15/2018 to Tue 12/31/2019		(Import) (Export)
0001 Continuous 2359		
Work scheduled by:	SCH - PJ - NY	2000 MW 1300 MW
	Impacts Total Transfer Capability	600 MW 250 MW
	TTC with All Lines In Service	2600 MW 1550 MW
MARION_-FARRAGUT_345_C3403		
Mon 01/15/2018 to Tue 12/31/2019		(Import) (Export)
0001 Continuous 2359		
<u>EXTENDED</u> <u>by CONED</u> <u>02/06/2019</u>		
Work scheduled by: ConEd	SCH - PJ - NY	2600 MW 1300 MW
	Impacts Total Transfer Capability	0 MW 250 MW
	TTC with All Lines In Service	2600 MW 1550 MW
STLAWRNC-MOSES_230_L33P		
Mon 04/30/2018 to Fri 12/31/2021		(Import) (Export)
0456 Continuous 2359		
<u>EXT FORCE</u> <u>by IESO</u> <u>08/21/2018</u>		
Work scheduled by: IESO	SCH - OH - NY	2250 MW 2000 MW
	Impacts Total Transfer Capability	0 MW 0 MW
	TTC with All Lines In Service	2250 MW 2000 MW
S.RIPLEY-DUNKIRK_230_68		
Tue 01/15/2019 to Mon 04/08/2019		(Import) (Export)
1128 Continuous 0759		
<u>EXT FORCE</u> <u>by PJM</u> <u>02/11/2019</u>		
Work scheduled by: PJM	SCH - PJ - NY	2600 MW 1300 MW
	Impacts Total Transfer Capability	0 MW 250 MW
	TTC with All Lines In Service	2600 MW 1550 MW
DUNWODIE_345KV_6		
Wed 01/23/2019 to Fri 03/01/2019		FWD (Import)
0001 Continuous 2359		
<u>EXTENDED</u> <u>by CE</u> <u>02/07/2019</u>		
Work scheduled by: ConEd	SPR/DUN-SOUTH	3800 MW
	Impacts Total Transfer Capability	800 MW
	TTC with All Lines In Service	4600 MW
SCH-IMO-NYISO_LIMIT_1700		
Mon 02/11/2019 to Fri 12/31/2021		FWD (Import)
0001 Continuous 2359		
Work scheduled by: IESO	SCH - OH - NY	2000 MW
	Impacts Total Transfer Capability	250 MW
	TTC with All Lines In Service	2250 MW

NYISO TRANSFER LIMITATIONS

Friday ,February 22, 2019 to Sunday ,August 23, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					FWD
W49TH_ST-E13THSTA_345_M55					(Import)
Wed 02/13/2019	to	Fri 03/01/2019	EXT FORCE by CE	02/21/2019	3800 MW
0652	Continuous	2359			Impacts Total Transfer Capability 800 MW
Work scheduled by: ConEd					TTC with All Lines In Service 4600 MW
<hr/>					FWD
W49TH_ST_345KV_6					(Import)
Wed 02/13/2019	to	Fri 03/01/2019	EXT FORCE by CE	02/21/2019	375 MW
0652	Continuous	2359			Impacts Total Transfer Capability 285 MW
Work scheduled by: ConEd					TTC with All Lines In Service 660 MW
<hr/>					FWD
SCRIBA__-VOLNEY__345_20					(Import)
Sat 02/16/2019	to	Sun 02/17/2019			5250 MW
0600	Continuous	1900			Impacts Total Transfer Capability 0 MW
Work scheduled by: NGrid					TTC with All Lines In Service 5250 MW
<hr/>					FWD
ADIRNDCK-PORTER__230_12					(Import)
Wed 02/20/2019	to	Wed 02/20/2019			2300 MW
0700	Daily(No Weekends)	1530			Impacts Total Transfer Capability 850 MW
Work scheduled by: NGrid					TTC with All Lines In Service 3150 MW
<hr/>					FWD
MOSES__-ADIRNDCK_230_MA2					(Import)
Wed 02/20/2019	to	Wed 02/20/2019			2300 MW
0700	Continuous	1530			Impacts Total Transfer Capability 850 MW
Work scheduled by: NYPA					TTC with All Lines In Service 3150 MW
<hr/>					FWD REV
FIVEMILE-STOLLERD_345_29					(Import) (Export)
Wed 02/20/2019	to	Fri 02/22/2019			2600 MW 1300 MW
0730	Continuous	1900			Impacts Total Transfer Capability 0 MW 250 MW
Work scheduled by: NGrid					TTC with All Lines In Service 2600 MW 1550 MW
<hr/>					FWD
CHAT_DC_GC2					(Import)
Thu 02/21/2019	to	Thu 02/21/2019			2850 MW
0500	Continuous	1800			Impacts Total Transfer Capability 300 MW
Work scheduled by: HQ					TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,February 22, 2019 to Sunday ,August 23, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Transfer ID	Start Date	End Date	Time	Duration	Work Scheduled by	Transfer Type	Value
CHAT_DC_GC2	Thu 02/21/2019	Thu 02/21/2019	0500	Continuous	HQ	SCH - HQ - NY	500 MW
						Impacts Total Transfer Capability	500 MW
						TTC with All Lines In Service	1000 MW
ADIRNDCK-CHASLAKE_230_13	Thu 02/21/2019	Thu 02/21/2019	0700	Daily(No Weekends)	NGrid	MOSES SOUTH	2300 MW
						Impacts Total Transfer Capability	850 MW
						TTC with All Lines In Service	3150 MW
MOSES__-ADIRNDCK_230_MA1	Thu 02/21/2019	Thu 02/21/2019	0700	Continuous	NYPA	MOSES SOUTH	2300 MW
						Impacts Total Transfer Capability	850 MW
						TTC with All Lines In Service	3150 MW
MOSES__-ADIRNDCK_230_MA1	Mon 02/25/2019	Fri 03/01/2019	0700	Continuous	NYPA	MOSES SOUTH	2300 MW
						Impacts Total Transfer Capability	850 MW
						TTC with All Lines In Service	3150 MW
SCRIBA__-VOLNEY__345_21	Wed 02/27/2019	Thu 02/28/2019	0730	Continuous	NGRID	OSWEGO EXPORT	5250 MW
						Impacts Total Transfer Capability	0 MW
						TTC with All Lines In Service	5250 MW
ATHENS__-PLSNTVLY_345_91	Thu 02/28/2019	Thu 02/28/2019	0001	Continuous	ConEd	UPNY CONED	3800 MW
						Impacts Total Transfer Capability	1900 MW
						TTC with All Lines In Service	5700 MW
PLSNTVLY_345KV_RNS4	Thu 02/28/2019	Thu 02/28/2019	0001	Continuous	ConEd	UPNY CONED	3800 MW
						Impacts Total Transfer Capability	1900 MW
						TTC with All Lines In Service	5700 MW

NYISO TRANSFER LIMITATIONS

Friday ,February 22, 2019 to Sunday ,August 23, 2020

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY_SO_SERIES_COMP_I/S

Fri 03/01/2019 to Mon 03/04/2019
0001 Continuous 0200

Work scheduled by: NYISO

FWD
(Import)
CENTRAL EAST - VC **2740 MW**
Impacts Total Transfer Capability 235 MW
TTC with All Lines In Service 2975 MW

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4

Fri 03/01/2019 to Mon 03/04/2019
0001 Continuous 0200

Work scheduled by:

FWD
(Import)
UPNY CONED **3800 MW**
Impacts Total Transfer Capability 1900 MW
TTC with All Lines In Service 5700 MW

LONG_MTN-PLSNTVLY_345_398

Fri 03/01/2019 to Sun 05/19/2019 **UPDATED by ISONE 01/30/2019**
0001 Continuous 2359

Work scheduled by: ConEd

FWD REV
(Import) (Export)
SCH - NE - NY **700 MW 1250 MW**
Impacts Total Transfer Capability 700 MW 550 MW
TTC with All Lines In Service 1400 MW 1800 MW

LONG_MTN-PLSNTVLY_345_398

Fri 03/01/2019 to Sun 05/19/2019 **UPDATED by ISONE 01/30/2019**
0001 Continuous 2359

Work scheduled by: ConEd

FWD REV
(Import) (Export)
SCH - NPX_1385 **100 MW 100 MW**
Impacts Total Transfer Capability 100 MW 100 MW
TTC with All Lines In Service 200 MW 200 MW

SCH-NYISO-NE_LIMIT_700

Fri 03/01/2019 to Sun 05/19/2019 **UPDATED by ISONE 01/30/2019**
0001 Continuous 2359

Work scheduled by: ConEd

REV
(Export)
SCH - NE - NY **900 MW**
Impacts Total Transfer Capability 900 MW
TTC with All Lines In Service 1800 MW

PLSNTVLY-EFISHKIL_345_F37

Mon 03/04/2019 to Wed 03/06/2019 **UPDATED by ISONE 01/30/2019**
0201 Continuous 0300

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1700 MW
TTC with All Lines In Service 5700 MW

SCRIBA_-VOLNEY_345_20

Mon 03/04/2019 to Tue 03/05/2019
0600 Continuous 1800

Work scheduled by: NGrid

FWD
(Import)
OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

NYISO TRANSFER LIMITATIONS

Friday ,February 22, 2019 to Sunday ,August 23, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA1

Mon 03/04/2019 to Fri 03/08/2019
 0700 Continuous 1500
 Work scheduled by: NYPA

FWD
 (Import)
MOSES SOUTH 2300 MW
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

DUNWODIE_345KV_4

Thu 03/07/2019 to Thu 03/07/2019 UPDATED by CONED 02/06/2019
 0001 Continuous 0030
 Work scheduled by: LI

FWD
 (Import)
SPR/DUN-SOUTH 3800 MW
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_6

Thu 03/07/2019 to Thu 03/07/2019 UPDATED by CONED 02/06/2019
 0001 Continuous 0030
 Work scheduled by: LI

FWD
 (Import)
SPR/DUN-SOUTH 3800 MW
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE-SHORE_RD_345_Y50

Thu 03/07/2019 to Fri 03/08/2019 UPDATED by CONED 02/06/2019
 0001 Continuous 2359
 Work scheduled by: LI

FWD
 (Import)
CONED - LIPA 800 MW
 Impacts Total Transfer Capability 700 MW
 TTC with All Lines In Service 1500 MW

SHORE_RD_345_138_BK 1

Thu 03/07/2019 to Fri 03/08/2019 UPDATED by CONED 02/06/2019
 0001 Continuous 2359
 Work scheduled by: LI

FWD
 (Import)
CONED - LIPA 1350 MW
 Impacts Total Transfer Capability 150 MW
 TTC with All Lines In Service 1500 MW

SHORE_RD_345_138_BK 2

Thu 03/07/2019 to Fri 03/08/2019 UPDATED by CONED 02/06/2019
 0001 Continuous 2359
 Work scheduled by: LI

FWD
 (Import)
CONED - LIPA 1350 MW
 Impacts Total Transfer Capability 150 MW
 TTC with All Lines In Service 1500 MW

EASTVIEW-SPRNBK__345_W64

Thu 03/07/2019 to Mon 03/11/2019 UPDATED by CONED 02/08/2019
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
UPNY CONED 4350 MW
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Friday ,February 22, 2019 to Sunday ,August 23, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD-EASTVIEW_345_W99					FWD	
Thu 03/07/2019	to	Mon 03/11/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/08/2019</u>	(Import)
0001	Continuous	0200				4350 MW
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	1350 MW
					TTC with All Lines In Service	5700 MW
DUNWODIE_345KV_4					FWD	
Fri 03/08/2019	to	Fri 03/08/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/06/2019</u>	(Import)
2330	Continuous	2359				3800 MW
Work scheduled by: LI					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_6					FWD	
Fri 03/08/2019	to	Fri 03/08/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/06/2019</u>	(Import)
2330	Continuous	2359				3800 MW
Work scheduled by: LI					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
MILLWOOD_345KV_18					FWD	
Mon 03/11/2019	to	Mon 03/11/2019				(Import)
0001	Continuous	0030				4350 MW
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	1350 MW
					TTC with All Lines In Service	5700 MW
LADENTWN-BUCHAN_S_345_Y88					FWD	
Mon 03/11/2019	to	Thu 03/28/2019				(Import)
0001	Continuous	0200				4800 MW
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	900 MW
					TTC with All Lines In Service	5700 MW
BECK -NIAGARA_345_PA301					FWD	REV
Mon 03/11/2019	to	Fri 03/15/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>02/06/2019</u>	(Import) (Export)
0600	Continuous	1700				1100 MW 950 MW
Work scheduled by: NYPA					SCH - OH - NY	
					Impacts Total Transfer Capability	1150 MW 1050 MW
					TTC with All Lines In Service	2250 MW 2000 MW
STLAWRNC-MOSES_230_L33P & STLAWRNC-MOSES_230_L34P					FWD	
Mon 03/11/2019	to	Mon 03/11/2019				(Import)
0700		1530				2700 MW
Work scheduled by:					MOSES SOUTH	
					Impacts Total Transfer Capability	450 MW
					TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,February 22, 2019 to Sunday ,August 23, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STLAWRNC-MOSES _____ 230_L34P	FWD	REV
Mon 03/11/2019 to Mon 03/11/2019	(Import) (Export)	
0700 Continuous 1530	SCH - OH - NY	2250 MW 2000 MW
Work scheduled by: NYPA	Impacts Total Transfer Capability	0 MW 0 MW
	TTC with All Lines In Service	2250 MW 2000 MW
<hr/>		
LEEDS _____ 345_LEEDS SVC	FWD	
Mon 03/11/2019 to Fri 03/22/2019	(Import)	
0800 Continuous 1600	CENTRAL EAST - VC	2950 MW
Work scheduled by: NGrid	Impacts Total Transfer Capability	25 MW
	TTC with All Lines In Service	2975 MW
<hr/>		
MOSES ___- ADIRNDCK_230_MA1	FWD	
Tue 03/12/2019 to Fri 03/15/2019	(Import)	
0700 Continuous 1500	MOSES SOUTH	2300 MW
Work scheduled by: NYPA	Impacts Total Transfer Capability	850 MW
	TTC with All Lines In Service	3150 MW
<hr/>		
MILLWOOD_345KV_18	FWD	
Wed 03/13/2019 to Thu 03/14/2019	(Import)	
0001 Continuous 0200	UPNY CONED	4350 MW
Work scheduled by: ConEd	Impacts Total Transfer Capability	1350 MW
	TTC with All Lines In Service	5700 MW
<hr/>		
NINEMILE-CLAY _____ 345_8	FWD	
Mon 03/18/2019 to Mon 03/18/2019	(Import)	
0001 Daily(No Weekends) 0400	OSWEGO EXPORT	5150 MW
Work scheduled by: NGrid	Impacts Total Transfer Capability	100 MW
	TTC with All Lines In Service	5250 MW
<hr/>		
MARCY _____ 765_345_AT1	FWD	
Mon 03/18/2019 to Fri 03/22/2019	(Import)	
0500 Continuous 1530	MOSES SOUTH	1750 MW
Work scheduled by: NYPA	Impacts Total Transfer Capability	1400 MW
	TTC with All Lines In Service	3150 MW
<hr/>		
SCH-NYISO-HQ_CEDARS_LIMIT_0		REV
Mon 03/18/2019 to Thu 04/04/2019		(Export)
0700 Continuous 1700	SCH - HQ_CEDARS	0 MW
Work scheduled by: HQ	Impacts Total Transfer Capability	100 MW
	TTC with All Lines In Service	100 MW

ARR: 19

NYISO TRANSFER LIMITATIONS

Friday ,February 22, 2019 to Sunday ,August 23, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NINEMILE-CLAY_____345_8

Thu 03/21/2019 to Thu 03/21/2019
 0001 Daily(No Weekends) 0400
 Work scheduled by: NGrid

FWD
 (Import)
 OSWEGO EXPORT **5150 MW**
 Impacts Total Transfer Capability 100 MW
 TTC with All Lines In Service 5250 MW

MILLWOOD_345KV_18

Thu 03/28/2019 to Thu 03/28/2019
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

MARCY_____345KV_CSC

Mon 04/01/2019 to Sun 04/07/2019
 0500 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2925 MW**
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 2975 MW

VOLNEY_-MARCY_____345_19

Mon 04/01/2019 to Wed 04/10/2019
 0500 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 CENTRAL EAST - VC **2825 MW**
 Impacts Total Transfer Capability 150 MW
 TTC with All Lines In Service 2975 MW

VOLNEY_-MARCY_____345_19

Mon 04/01/2019 to Wed 04/10/2019
 0500 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 OSWEGO EXPORT **4900 MW**
 Impacts Total Transfer Capability 350 MW
 TTC with All Lines In Service 5250 MW

PLSNTVLY-EFISHKIL_345_F37

Thu 04/04/2019 to Mon 04/08/2019
 0001 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ISONE 01/30/2019

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 1700 MW
 TTC with All Lines In Service 5700 MW

NIAGARA_-ROCHESTR_345_NR2

Fri 04/05/2019 to Fri 04/05/2019
 0500 Continuous 1700
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,February 22, 2019 to Sunday ,August 23, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
LINDN_CG-LNDVFT___345_V-3022						
Sun 04/07/2019	to	Fri 04/12/2019				
1400	Continuous	1800			SCH - PJM_VFT	0 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	315 MW
					TTC with All Lines In Service	315 MW
PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4						
Mon 04/08/2019	to	Sat 04/13/2019				
0001		0300			UPNY CONED	3800 MW
Work scheduled by:					Impacts Total Transfer Capability	1900 MW
					TTC with All Lines In Service	5700 MW
PLSNTVLE-DUNWODIE_345_W89						
Mon 04/08/2019	to	Fri 05/10/2019				
0001	Continuous	2359			UPNY CONED	4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1700 MW
					TTC with All Lines In Service	5700 MW
NEPTUNE_-DUFFYAVE_345_NEPTUNE						
Mon 04/08/2019	to	Fri 04/12/2019	<u>EXTENDED</u>	<u>by PJM</u>	<u>02/20/2019</u>	
0600	Continuous	1800			SCH - PJM_NEPTUNE	0 MW
Work scheduled by: LI					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	660 MW
NEWBRDGE-DUFFYAVE_345_501						
Mon 04/08/2019	to	Fri 04/12/2019	<u>EXTENDED</u>	<u>by PJM</u>	<u>02/20/2019</u>	
0600	Continuous	1800			SCH - PJM_NEPTUNE	0 MW
Work scheduled by: LI					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	660 MW
NEWBRDGE_345_138_BK_1						
Mon 04/08/2019	to	Fri 04/12/2019	<u>EXTENDED</u>	<u>by PJM</u>	<u>02/20/2019</u>	
0600	Continuous	1800			SCH - PJM_NEPTUNE	375 MW
Work scheduled by: LI					Impacts Total Transfer Capability	285 MW
					TTC with All Lines In Service	660 MW
NEWBRDGE_345_138_BK_2						
Mon 04/08/2019	to	Fri 04/12/2019	<u>EXTENDED</u>	<u>by PJM</u>	<u>02/20/2019</u>	
0600	Continuous	1800			SCH - PJM_NEPTUNE	375 MW
Work scheduled by: LI					Impacts Total Transfer Capability	285 MW
					TTC with All Lines In Service	660 MW

NYISO TRANSFER LIMITATIONS

Friday ,February 22, 2019 to Sunday ,August 23, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK__345KV_RNS5					FWD
Mon 04/29/2019	to	Mon 04/29/2019			(Import)
0001	Continuous	0030		SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW
SPRNBRK_-W49TH_ST_345_M51					FWD
Mon 04/29/2019	to	Sun 05/05/2019			(Import)
0001	Continuous	2200		SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW
FRASANX-COOPERS__345_UCC2-41					FWD
Mon 04/29/2019	to	Fri 05/03/2019	UPDATED	by NYPA	08/22/2018
0500	Continuous	1730		CENTRAL EAST - VC	2500 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 475 MW
					TTC with All Lines In Service 2975 MW
MARCY__-FRASANX_345_UCC2-41					FWD
Mon 04/29/2019	to	Fri 05/03/2019	UPDATED	by NYPA	08/22/2018
0500	Continuous	1730		CENTRAL EAST - VC	2500 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 475 MW
					TTC with All Lines In Service 2975 MW
MOSES__-ADIRNDCK_230_MA1					FWD
Mon 04/29/2019	to	Fri 05/03/2019			(Import)
0700	Continuous	1500		MOSES SOUTH	2300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 850 MW
					TTC with All Lines In Service 3150 MW
EGRDNCTY_345_138_AT2					FWD
Wed 05/01/2019	to	Wed 05/15/2019			(Import)
0001	Continuous	2359		CONED - LIPA	1250 MW
Work scheduled by: LI					Impacts Total Transfer Capability 250 MW
					TTC with All Lines In Service 1500 MW
HUDSONTP-W49TH_ST_345_Y56					FWD
Wed 05/01/2019	to	Tue 05/07/2019			(Import)
0600	Continuous	1800		SCH - PJM_HTP	0 MW
Work scheduled by: PJM					Impacts Total Transfer Capability 660 MW
					TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Friday ,February 22, 2019 to Sunday ,August 23, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHATGUAY-MASSENA__765_7040			FWD	
Sat 05/04/2019	to	Sat 05/04/2019	(Import)	
0530	Continuous	1930	MOSES SOUTH	1550 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1600 MW
			TTC with All Lines In Service	3150 MW
CHATGUAY-MASSENA__765_7040			FWD	REV
Sat 05/04/2019	to	Sat 05/04/2019	(Import)	(Export)
0530	Continuous	1930	SCH - HQ - NY	0 MW 0 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1500 MW 1000 MW
			TTC with All Lines In Service	1500 MW 1000 MW
MASSENA_-MARCY___765_MSU1			FWD	
Sat 05/04/2019	to	Sat 05/04/2019	(Import)	
0530	Continuous	1930	CENTRAL EAST - VC	2265 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	710 MW
			TTC with All Lines In Service	2975 MW
MASSENA_-MARCY___765_MSU1			FWD	
Sat 05/04/2019	to	Sat 05/04/2019	(Import)	
0530	Continuous	1930	MOSES SOUTH	500 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	2650 MW
			TTC with All Lines In Service	3150 MW
MASSENA_-MARCY___765_MSU1			FWD	REV
Sat 05/04/2019	to	Sat 05/04/2019	(Import)	(Export)
0530	Continuous	1930	SCH - HQ - NY	475 MW 1000 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1025 MW 0 MW
			TTC with All Lines In Service	1500 MW 1000 MW
MASSENA_-MARCY___765_MSU1 & CHATGUAY-MASSENA__765_7040			FWD	
Sat 05/04/2019	to	Sat 05/04/2019	(Import)	
0530		1930	MOSES SOUTH	500 MW
Work scheduled by:			Impacts Total Transfer Capability	2650 MW
			TTC with All Lines In Service	3150 MW
SPRNBK__345KV_RNS5			FWD	
Sun 05/05/2019	to	Sun 05/05/2019	(Import)	
2130	Continuous	2200	SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	1400 MW
			TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Friday ,February 22, 2019 to Sunday ,August 23, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

KINTIGH_-ROCHESTR_345_SR1-39

Mon 05/06/2019 to Fri 05/10/2019
0600 Continuous 1700

Work scheduled by: NYPA

UPDATED by NYSEG 11/08/2018

DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

FWD
(Import)

SHOR_NPX-SHOREHAM_138_CSC

Mon 05/06/2019 to Fri 05/10/2019
0700 Continuous 1800

Work scheduled by: LI

SCH - NPX_CSC **0 MW 0 MW**
Impacts Total Transfer Capability 330 MW 330 MW
TTC with All Lines In Service 330 MW 330 MW

FWD REV
(Import) (Export)

ROSETON_-ROCKTVRN_345_311

Mon 05/06/2019 to Sat 06/01/2019
0800 Continuous 1600

Work scheduled by: CHGE

UPNY CONED **4400 MW**
Impacts Total Transfer Capability 1300 MW
TTC with All Lines In Service 5700 MW

FWD
(Import)

CHATGUAY-MASSENA_765_7040

Sat 05/11/2019 to Sat 05/11/2019
0530 Continuous 1930

Work scheduled by: NYPA

MOSES SOUTH **1550 MW**
Impacts Total Transfer Capability 1600 MW
TTC with All Lines In Service 3150 MW

FWD
(Import)

CHATGUAY-MASSENA_765_7040

Sat 05/11/2019 to Sat 05/11/2019
0530 Continuous 1930

Work scheduled by: NYPA

SCH - HQ - NY **0 MW 0 MW**
Impacts Total Transfer Capability 1500 MW 1000 MW
TTC with All Lines In Service 1500 MW 1000 MW

FWD REV
(Import) (Export)

MASSENA_-MARCY_765_MSU1

Sat 05/11/2019 to Sat 05/11/2019
0530 Continuous 1930

Work scheduled by: NYPA

CENTRAL EAST - VC **2265 MW**
Impacts Total Transfer Capability 710 MW
TTC with All Lines In Service 2975 MW

FWD
(Import)

MASSENA_-MARCY_765_MSU1

Sat 05/11/2019 to Sat 05/11/2019
0530 Continuous 1930

Work scheduled by: NYPA

MOSES SOUTH **500 MW**
Impacts Total Transfer Capability 2650 MW
TTC with All Lines In Service 3150 MW

FWD
(Import)

NYISO TRANSFER LIMITATIONS

Friday ,February 22, 2019 to Sunday ,August 23, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>MASSENA -MARCY 765_MSU1</p> <p>Sat 05/11/2019 to Sat 05/11/2019 0530 Continuous 1930</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD REV (Import) (Export)</p> <p>SCH - HQ - NY 475 MW 1000 MW</p> <p>Impacts Total Transfer Capability 1025 MW 0 MW</p> <p>TTC with All Lines In Service 1500 MW 1000 MW</p>
<p>MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040</p> <p>Sat 05/11/2019 to Sat 05/11/2019 0530 Continuous 1930</p> <p>Work scheduled by:</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH 500 MW</p> <p>Impacts Total Transfer Capability 2650 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>NIAGARA -ROCHESTR 345_NR2</p> <p>Mon 05/13/2019 to Fri 05/17/2019 0600 Continuous 1700</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>DYSINGER EAST 1400 MW</p> <p>Impacts Total Transfer Capability 1750 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>CHATGUAY-MASSENA 765_7040</p> <p>Sat 05/18/2019 to Sat 05/18/2019 0530 Continuous 1930</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH 1550 MW</p> <p>Impacts Total Transfer Capability 1600 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>CHATGUAY-MASSENA 765_7040</p> <p>Sat 05/18/2019 to Sat 05/18/2019 0530 Continuous 1930</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD REV (Import) (Export)</p> <p>SCH - HQ - NY 0 MW 0 MW</p> <p>Impacts Total Transfer Capability 1500 MW 1000 MW</p> <p>TTC with All Lines In Service 1500 MW 1000 MW</p>
<p>MASSENA -MARCY 765_MSU1</p> <p>Sat 05/18/2019 to Sat 05/18/2019 0530 Continuous 1930</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC 2265 MW</p> <p>Impacts Total Transfer Capability 710 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p>MASSENA -MARCY 765_MSU1</p> <p>Sat 05/18/2019 to Sat 05/18/2019 0530 Continuous 1930</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH 500 MW</p> <p>Impacts Total Transfer Capability 2650 MW</p> <p>TTC with All Lines In Service 3150 MW</p>

NYISO TRANSFER LIMITATIONS

Friday ,February 22, 2019 to Sunday ,August 23, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Work Scheduled	Work Scheduled by	Transfer Capability	TTC with All Lines In Service
MASSENA -MARCY 765_MSU1			
Sat 05/18/2019 to Sat 05/18/2019		FWD (Import)	REV (Export)
0530 Continuous 1930		SCH - HQ - NY	475 MW 1000 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	1025 MW 0 MW
		TTC with All Lines In Service	1500 MW 1000 MW
MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040			
Sat 05/18/2019 to Sat 05/18/2019		FWD (Import)	
0530 1930		MOSES SOUTH	500 MW
Work scheduled by:		Impacts Total Transfer Capability	2650 MW
		TTC with All Lines In Service	3150 MW
ADIRNDCK-PORTER 230_12			
Mon 05/20/2019 to Fri 05/24/2019		FWD (Import)	
0700 Continuous 1530		MOSES SOUTH	2100 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	1050 MW
		TTC with All Lines In Service	3150 MW
PANNELL -CLAY 345_1			
Mon 05/20/2019 to Fri 05/24/2019		FWD (Import)	
0700 Continuous 1530		WEST CENTRAL	1300 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	950 MW
		TTC with All Lines In Service	2250 MW
ROSETON -EFISHKIL 345_RFK305			
Thu 05/23/2019 to Thu 05/23/2019		FWD (Import)	
0800 Daily 1600		UPNY CONED	4800 MW
Work scheduled by: CHGE		Impacts Total Transfer Capability	900 MW
		TTC with All Lines In Service	5700 MW
SCRIBA -VOLNEY 345_20			
Tue 05/28/2019 to Tue 05/28/2019		FWD (Import)	
0600 Continuous 1800		OSWEGO EXPORT	5250 MW
Work scheduled by: NGrid		Impacts Total Transfer Capability	0 MW
		TTC with All Lines In Service	5250 MW
PANNELL -CLAY 345_2			
Mon 06/03/2019 to Fri 06/07/2019		FWD (Import)	
0700 Continuous 1530		WEST CENTRAL	1300 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	950 MW
		TTC with All Lines In Service	2250 MW

NYISO TRANSFER LIMITATIONS

Friday ,February 22, 2019 to Sunday ,August 23, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA2				FWD	
Mon 06/24/2019	to	Fri 06/28/2019		(Import)	
0700	Continuous	1500		MOSES SOUTH	2100 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1050 MW
				TTC with All Lines In Service	3150 MW
MOSES___-ADIRNDCK_230_MA2				FWD	
Mon 07/08/2019	to	Fri 07/12/2019		(Import)	
0700	Continuous	1500		MOSES SOUTH	2100 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1050 MW
				TTC with All Lines In Service	3150 MW
ADIRNDCK-CHASLAKE_230_13				FWD	
Mon 07/08/2019	to	Fri 07/12/2019		(Import)	
0700	Continuous	1530		MOSES SOUTH	2100 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1050 MW
				TTC with All Lines In Service	3150 MW
MARCY___765_345_AT2				FWD	
Sat 08/03/2019	to	Sun 08/04/2019		(Import)	
0500	Continuous	1730		MOSES SOUTH	1700 MW
Work scheduled by: NYPA			ARR: 19	Impacts Total Transfer Capability	1450 MW
				TTC with All Lines In Service	3150 MW
MOSES___-ADIRNDCK_230_MA1				FWD	
Mon 08/12/2019	to	Mon 08/12/2019	UPDATED	by NYPA	10/10/2018
0700	Continuous	1459		MOSES SOUTH	2100 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1050 MW
				TTC with All Lines In Service	3150 MW
SHOR_NPX-SHOREHAM_138_CSC				FWD	REV
Tue 09/03/2019	to	Wed 09/04/2019	UPDATED	by ISONE	02/15/2019
0300	Continuous	1600		SCH - NPX_CSC	0 MW 0 MW
Work scheduled by: LI				Impacts Total Transfer Capability	330 MW 330 MW
				TTC with All Lines In Service	330 MW 330 MW
MARCY___765_345_AT1				FWD	
Tue 09/03/2019	to	Tue 09/03/2019		(Import)	
0500	Continuous	1730		MOSES SOUTH	1750 MW
Work scheduled by: NYPA			ARR: 19	Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,February 22, 2019 to Sunday ,August 23, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						FWD
MARCY___-N.SCTLND_345_18						(Import)
Wed 09/04/2019	to	Wed 09/04/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>11/06/2018</u>	
0500	Continuous	1730				CENTRAL EAST - VC
Work scheduled by: NYPA					ARR: 19	2090 MW
						Impacts Total Transfer Capability 885 MW
						TTC with All Lines In Service 2975 MW
<hr/>						
MARCY___345KV_CSC						FWD
						(Import)
Wed 09/04/2019	to	Wed 09/04/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>11/06/2018</u>	
0500	Continuous	1730				CENTRAL EAST - VC
Work scheduled by: NYPA						2925 MW
						Impacts Total Transfer Capability 50 MW
						TTC with All Lines In Service 2975 MW
<hr/>						
MOSES___-ADIRNDCK_230_MA2						FWD
						(Import)
Wed 09/04/2019	to	Wed 09/04/2019				MOSES SOUTH
0700	Continuous	1500				2100 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 1050 MW
						TTC with All Lines In Service 3150 MW
<hr/>						
ADIRNDCK-PORTER___230_12						FWD
						(Import)
Wed 09/04/2019	to	Wed 09/04/2019				MOSES SOUTH
0700	Continuous	1530				2100 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 1050 MW
						TTC with All Lines In Service 3150 MW
<hr/>						
ADIRNDCK-CHASLAKE_230_13						FWD
						(Import)
Thu 09/05/2019	to	Thu 09/05/2019				MOSES SOUTH
0700	Continuous	1530				2100 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 1050 MW
						TTC with All Lines In Service 3150 MW
<hr/>						
NIAGARA_-ROCHESTR_345_NR2						FWD
						(Import)
Mon 09/09/2019	to	Sat 09/21/2019				DYSINGER EAST
0500	Continuous	1700				1400 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 1750 MW
						TTC with All Lines In Service 3150 MW
<hr/>						
LEEDS___345KV_R395						FWD
						(Import)
Mon 09/09/2019	to	Mon 09/09/2019				UPNY CONED
0700	Continuous	0730				3800 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 1900 MW
						TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Friday ,February 22, 2019 to Sunday ,August 23, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

GILBOA -LEEDS 345_GL3

Mon 09/09/2019 to Fri 09/27/2019
 0700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2200 MW**
 Impacts Total Transfer Capability 775 MW
 TTC with All Lines In Service 2975 MW

MARCY -N.SCTLND 345_18

Wed 09/11/2019 to Fri 09/13/2019
 0500 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 CENTRAL EAST - VC **2090 MW**
 Impacts Total Transfer Capability 885 MW
 TTC with All Lines In Service 2975 MW

MOSES -ADIRNDCK 230_MA2

Mon 09/16/2019 to Fri 09/20/2019
 0700 Continuous 1500
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2100 MW**
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW

GOETHALS 345KV_5

Fri 09/20/2019 to Tue 09/24/2019
 0001 Continuous 2359
 Work scheduled by: ConEd

STATEN ISLAND
 Impacts Total Transfer Capability
 TTC with All Lines In Service

ROCHESTR-PANNELL 345_RP2

Mon 09/23/2019 to Mon 09/30/2019
 0500 Continuous 1700
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

KINTIGH -ROCHESTR 345_SR1-39

Mon 09/23/2019 to Fri 09/27/2019
 0600 Continuous 1700
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **1400 MW**
 Impacts Total Transfer Capability 1750 MW
 TTC with All Lines In Service 3150 MW

LEEDS 345KV_R395

Fri 09/27/2019 to Fri 09/27/2019
 1700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 1900 MW
 TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Friday ,February 22, 2019 to Sunday ,August 23, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CLAY -EDIC 345_1-16		FWD	
Mon 09/30/2019	to Fri 10/04/2019	(Import)	
0700	Continuous 1530	OSWEGO EXPORT	4850 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	400 MW
		TTC with All Lines In Service	5250 MW
LEEDS -HURLYAVE 345_301		FWD	
Mon 09/30/2019	to Sat 10/26/2019	(Import)	
0800	Continuous 1600	UPNY CONED	4100 MW
Work scheduled by: CHGE		Impacts Total Transfer Capability	1600 MW
		TTC with All Lines In Service	5700 MW
CLAY -EDIC 345_2-15		FWD	
Mon 10/07/2019	to Thu 10/17/2019	(Import)	
0700	Continuous 1530	OSWEGO EXPORT	4850 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	400 MW
		TTC with All Lines In Service	5250 MW
MARCY -N.SCTLND 345_18		FWD	
Wed 10/09/2019	to Fri 10/11/2019	(Import)	
0500	Continuous 1730	CENTRAL EAST - VC	2090 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	885 MW
		TTC with All Lines In Service	2975 MW
		ARR: 19	
CHATGUAY-MASSENA 765_7040		FWD	
Sat 10/12/2019	to Sat 10/26/2019	(Import)	
0100	Continuous 1900	MOSES SOUTH	1550 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	1600 MW
		TTC with All Lines In Service	3150 MW
CHATGUAY-MASSENA 765_7040		FWD	REV
Sat 10/12/2019	to Sat 10/26/2019	(Import) (Export)	
0100	Continuous 1900	SCH - HQ - NY	0 MW 0 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	1500 MW 1000 MW
		TTC with All Lines In Service	1500 MW 1000 MW
MARCY 765_345_AT1		FWD	
Sat 10/12/2019	to Sat 10/26/2019	(Import)	
0100	Continuous 1900	MOSES SOUTH	1750 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	1400 MW
		TTC with All Lines In Service	3150 MW
		ARR: 19	

NYISO TRANSFER LIMITATIONS

Friday ,February 22, 2019 to Sunday ,August 23, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT2

Sat 10/12/2019 to Sat 10/26/2019
0100 Continuous 1900

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

MASSENA_-MARCY___765_MSU1

Sat 10/12/2019 to Sat 10/26/2019
0100 Continuous 1900

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2265 MW**
Impacts Total Transfer Capability 710 MW
TTC with All Lines In Service 2975 MW

MASSENA_-MARCY___765_MSU1

Sat 10/12/2019 to Sat 10/26/2019
0100 Continuous 1900

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **500 MW**
Impacts Total Transfer Capability 2650 MW
TTC with All Lines In Service 3150 MW

MASSENA_-MARCY___765_MSU1

Sat 10/12/2019 to Sat 10/26/2019
0100 Continuous 1900

Work scheduled by: NYPA

FWD REV
(Import) (Export)
SCH - HQ - NY **475 MW 1000 MW**
Impacts Total Transfer Capability 1025 MW 0 MW
TTC with All Lines In Service 1500 MW 1000 MW

MASSENA_-MARCY___765_MSU1 & CHATGUAY-MASSENA_765_7040

Sat 10/12/2019 to Sat 10/26/2019
0100 1900

Work scheduled by:

FWD
(Import)
MOSES SOUTH **500 MW**
Impacts Total Transfer Capability 2650 MW
TTC with All Lines In Service 3150 MW

MOSES_-MASSENA_230_MMS1 & MOSES_-MASSENA_230_MMS2

Sat 10/12/2019 to Sat 10/26/2019
0100 1900

Work scheduled by:

FWD REV
(Import) (Export)
SCH - HQ - NY **850 MW 0 MW**
Impacts Total Transfer Capability 650 MW 1000 MW
TTC with All Lines In Service 1500 MW 1000 MW

DUNWODIE_345KV_3

Tue 10/22/2019 to Tue 10/22/2019
0001 Continuous 0030

Work scheduled by: ConEd

UPDATED by CONED 02/06/2019

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Friday ,February 22, 2019 to Sunday ,August 23, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_5					FWD	
Tue 10/22/2019	to	Tue 10/22/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/06/2019</u>	(Import)
0001	Continuous	0030				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
DUNWODIE-MOTTHAVN_345_71					FWD	
Tue 10/22/2019	to	Tue 11/26/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/06/2019</u>	(Import)
0001	Continuous	2359				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
NIAGARA_345_230_AT4					FWD	REV
Wed 10/23/2019	to	Wed 12/18/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>12/19/2018</u>	(Import) (Export)
0500	Continuous	1700				1900 MW 1400 MW
Work scheduled by: NYPA					SCH - OH - NY	
					Impacts Total Transfer Capability	0 MW 350 MW
					TTC with All Lines In Service	1900 MW 1750 MW
HURLYAVE-ROSETON_345_303					FWD	
Mon 11/04/2019	to	Fri 12/06/2019				(Import)
0800	Continuous	1600				4100 MW
Work scheduled by: CHGE					UPNY CONED	
					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	5700 MW
PANNELL_-CLAY_345_2					FWD	
Wed 11/06/2019	to	Fri 11/22/2019				(Import)
0700	Continuous	1530				1300 MW
Work scheduled by: NYPA					WEST CENTRAL	
					Impacts Total Transfer Capability	950 MW
					TTC with All Lines In Service	2250 MW
MARCY_-N.SCTLND_345_18					FWD	
Thu 11/07/2019	to	Fri 11/08/2019				(Import)
0500	Continuous	1730				2090 MW
Work scheduled by: NYPA					CENTRAL EAST - VC	
					Impacts Total Transfer Capability	885 MW
					TTC with All Lines In Service	2975 MW
MARCY_345KV_CSC					FWD	
Thu 11/07/2019	to	Fri 11/08/2019				(Import)
0500	Continuous	1730				2925 MW
Work scheduled by: NYPA					CENTRAL EAST - VC	
					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	2975 MW

ARR: 19

NYISO TRANSFER LIMITATIONS

Friday ,February 22, 2019 to Sunday ,August 23, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA2

Tue 11/12/2019 to Fri 11/15/2019
 0700 Continuous 1500
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 11/18/2019 to Fri 11/22/2019
 0700 Continuous 1500
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 11/25/2019 to Wed 11/27/2019
 0700 Continuous 1500
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

DUNWODIE_345KV_3

Tue 11/26/2019 to Tue 11/26/2019 **UPDATED by CONED 02/06/2019**
 2330 Continuous 2359
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_5

Tue 11/26/2019 to Tue 11/26/2019 **UPDATED by CONED 02/06/2019**
 2330 Continuous 2359
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

MOSES___-ADIRNDCK_230_MA2

Mon 12/02/2019 to Fri 12/06/2019
 0700 Continuous 1500
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA1

Mon 12/09/2019 to Fri 12/13/2019
 0700 Continuous 1500
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,February 22, 2019 to Sunday ,August 23, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA2

Mon 12/16/2019 to Mon 12/16/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA1

Tue 12/17/2019 to Fri 12/20/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

LADENTWN-BUCHAN_S_345_Y88

Wed 01/15/2020 to Thu 02/13/2020
0001 Continuous 2359

Work scheduled by: ORU

11/05/2018

FWD
(Import)
UPNY CONED **4800 MW**
Impacts Total Transfer Capability 900 MW
TTC with All Lines In Service 5700 MW

FRASANNX-COOPERS__345_UCC2-41

Mon 04/27/2020 to Sun 05/31/2020
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

MARCY___-FRASANNX_345_UCC2-41

Mon 04/27/2020 to Sun 05/31/2020
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW