

NYISO TRANSFER LIMITATIONS

Saturday ,April 13, 2019 to Monday ,October 12, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

	FWD	REV
HUDSONP_-FARRAGUT_345_B3402		
Mon 01/15/2018 to Tue 12/31/2019		(Import) (Export)
0001 Continuous 2359		
<u>EXTENDED</u> by <u>CONED</u> <u>02/06/2019</u>		
Work scheduled by: ConEd	SCH - PJ - NY	2600 MW 1300 MW
	Impacts Total Transfer Capability	0 MW 250 MW
	TTC with All Lines In Service	2600 MW 1550 MW
HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403		
Mon 01/15/2018 to Tue 12/31/2019		(Import) (Export)
0001 Continuous 2359		
<u>EXTENDED</u> by <u>CONED</u> <u>02/06/2019</u>		
Work scheduled by:	SCH - PJ - NY	2000 MW 1300 MW
	Impacts Total Transfer Capability	600 MW 250 MW
	TTC with All Lines In Service	2600 MW 1550 MW
MARION_-FARRAGUT_345_C3403		
Mon 01/15/2018 to Tue 12/31/2019		(Import) (Export)
0001 Continuous 2359		
<u>EXTENDED</u> by <u>CONED</u> <u>02/06/2019</u>		
Work scheduled by: ConEd	SCH - PJ - NY	2600 MW 1300 MW
	Impacts Total Transfer Capability	0 MW 250 MW
	TTC with All Lines In Service	2600 MW 1550 MW
STLAWRNC-MOSES_230_L33P		
Mon 04/30/2018 to Fri 12/31/2021		(Import) (Export)
0456 Continuous 2359		
<u>EXT FORCE</u> by <u>IESO</u> <u>08/21/2018</u>		
Work scheduled by: IESO	SCH - OH - NY	2250 MW 2000 MW
	Impacts Total Transfer Capability	0 MW 0 MW
	TTC with All Lines In Service	2250 MW 2000 MW
S.RIPLEY-DUNKIRK_230_68		
Tue 01/15/2019 to Mon 04/08/2019		(Import) (Export)
1128 Continuous 0759		
<u>EXT FORCE</u> by <u>PJM</u> <u>02/11/2019</u>		
Work scheduled by: PJM	SCH - PJ - NY	2600 MW 1300 MW
	Impacts Total Transfer Capability	0 MW 250 MW
	TTC with All Lines In Service	2600 MW 1550 MW
DUNWODIE_345KV_6		
Wed 01/23/2019 to Thu 04/18/2019		FWD (Import)
0001 Continuous 0300		
<u>EXTENDED</u> by <u>CE</u> <u>03/28/2019</u>		
Work scheduled by: ConEd	SPR/DUN-SOUTH	3800 MW
	Impacts Total Transfer Capability	800 MW
	TTC with All Lines In Service	4600 MW
SCH-IMO-NYISO_LIMIT_1750		
Tue 02/26/2019 to Fri 12/31/2021		FWD (Import)
0001 Continuous 2359		
<u>UPDATED</u> by <u>IESO</u> <u>03/14/2019</u>		
Work scheduled by: IESO	SCH - OH - NY	2050 MW
	Impacts Total Transfer Capability	200 MW
	TTC with All Lines In Service	2250 MW

NYISO TRANSFER LIMITATIONS

Saturday ,April 13, 2019 to Monday ,October 12, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					FWD	REV
LONG_MTN-CRICKVLY_345_398					(Import)	(Export)
Fri 03/01/2019	to	Sun 05/19/2019	<u>UPDATED</u>	<u>by ISONE</u>	<u>03/27/2019</u>	
0001	Continuous	2359				
Work scheduled by: ConEd					SCH - NE - NY	700 MW
					Impacts Total Transfer Capability	700 MW
					TTC with All Lines In Service	1400 MW
<hr/>					FWD	REV
LONG_MTN-CRICKVLY_345_398					(Import)	(Export)
Fri 03/01/2019	to	Sun 05/19/2019	<u>UPDATED</u>	<u>by ISONE</u>	<u>03/27/2019</u>	
0001	Continuous	2359				
Work scheduled by: ConEd					SCH - NPX_1385	100 MW
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
<hr/>					FWD	REV
SCH-NE-NYISO_LIMIT_400					(Import)	(Export)
Fri 03/01/2019	to	Sun 05/19/2019	<u>UPDATED</u>	<u>by ISONE</u>	<u>03/27/2019</u>	
0001	Continuous	2359				
Work scheduled by: ConEd					SCH - NE - NY	600 MW
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	1400 MW
<hr/>					FWD	REV
SCH-NYISO-IMO_LIMIT_1600					(Export)	(Export)
Sat 03/16/2019	to	Fri 12/31/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>03/14/2019</u>	
0001	Continuous	2359				
Work scheduled by: IESO					SCH - OH - NY	1900 MW
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	2000 MW
<hr/>					FWD	REV
SCH-NYISO-HQ_CEDARS_LIMIT_0					(Export)	(Export)
Mon 03/18/2019	to	Mon 04/08/2019	<u>UPDATED</u>	<u>by HQ</u>	<u>02/25/2019</u>	
0400	Continuous	2230				
Work scheduled by: HQ					SCH - HQ_CEDARS	0 MW
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	100 MW
<hr/>					FWD	REV
SCH-NYISO-NE_LIMIT_600					(Export)	(Export)
Mon 04/01/2019	to	Sun 05/19/2019	<u>UPDATED</u>	<u>by ISONE</u>	<u>03/27/2019</u>	
0001	Continuous	2359				
Work scheduled by: ConEd					SCH - NE - NY	800 MW
					Impacts Total Transfer Capability	1000 MW
					TTC with All Lines In Service	1800 MW
<hr/>					FWD	REV
VOLNEY_-MARCY_345_19					(Import)	(Export)
Mon 04/01/2019	to	Wed 04/10/2019				
0500	Continuous	1730				
Work scheduled by: NYPA					CENTRAL EAST - VC	2825 MW
					Impacts Total Transfer Capability	150 MW
					TTC with All Lines In Service	2975 MW

ARR: 19

NYISO TRANSFER LIMITATIONS

Saturday ,April 13, 2019 to Monday ,October 12, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>								
VOLNEY__-MARCY___345_19							FWD	
Mon 04/01/2019	to	Wed 04/10/2019					(Import)	
0500	Continuous	1730			OSWEGO EXPORT		4900 MW	
Work scheduled by: NYPA							Impacts Total Transfer Capability	350 MW
					ARR: 19		TTC with All Lines In Service	5250 MW
<hr/>								
SCH-IMO-NYISO_LIMIT_1000							FWD	
Mon 04/01/2019	to	Wed 04/10/2019	<u>UPDATED</u>	<u>by NYISO 03/11/2019</u>			(Import)	
0700	Continuous	0830			SCH - OH - NY		1300 MW	
Work scheduled by: NGrid							Impacts Total Transfer Capability	950 MW
							TTC with All Lines In Service	2250 MW
<hr/>								
PLSNTVLY-EFISHKIL_345_F37							FWD	
Thu 04/04/2019	to	Mon 04/08/2019	<u>UPDATED</u>	<u>by ISONE 03/27/2019</u>			(Import)	
0001	Continuous	0200			UPNY CONED		4000 MW	
Work scheduled by: ConEd							Impacts Total Transfer Capability	1700 MW
							TTC with All Lines In Service	5700 MW
<hr/>								
LINDN_CG-LNDVFT___345_V-3022							FWD	REV
Sun 04/07/2019	to	Sat 04/13/2019	<u>EXTENDED</u>	<u>by PJM 04/11/2019</u>			(Import)	(Export)
1400	Continuous	1800			SCH - PJM_VFT		0 MW	0 MW
Work scheduled by: PJM							Impacts Total Transfer Capability	315 MW 315 MW
							TTC with All Lines In Service	315 MW 315 MW
<hr/>								
PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4							FWD	
Mon 04/08/2019	to	Sat 04/13/2019					(Import)	
0001		0300			UPNY CONED		3800 MW	
Work scheduled by:							Impacts Total Transfer Capability	1900 MW
							TTC with All Lines In Service	5700 MW
<hr/>								
SCH-IMO_NY_NIAG_CB_3122_W/BB							FWD	REV
Mon 04/08/2019	to	Fri 04/12/2019					(Import)	(Export)
0500	Continuous	1700			SCH - OH - NY		2000 MW	1750 MW
Work scheduled by: NYPA							Impacts Total Transfer Capability	250 MW 250 MW
							TTC with All Lines In Service	2250 MW 2000 MW
<hr/>								
NEPTUNE_-DUFFYAVE_345_NEPTUNE							FWD	
Mon 04/08/2019	to	Fri 04/12/2019	<u>UPDATED</u>	<u>by PJM 04/11/2019</u>			(Import)	
0600	Continuous	2359			SCH - PJM_NEPTUNE		0 MW	
Work scheduled by: LI							Impacts Total Transfer Capability	660 MW
							TTC with All Lines In Service	660 MW

NYISO TRANSFER LIMITATIONS

Saturday ,April 13, 2019 to Monday ,October 12, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE-DUFFYAVE_345_501						FWD
Mon 04/08/2019	to	Fri 04/12/2019	<u>UPDATED</u>	<u>by PJM</u>	<u>04/11/2019</u>	(Import)
0600	Continuous	2359				SCH - PJM_NEPTUNE Impacts Total Transfer Capability 660 MW TTC with All Lines In Service 660 MW
Work scheduled by: LI						0 MW
NEWBRDGE_345_138_BK_1						FWD
Mon 04/08/2019	to	Fri 04/12/2019	<u>UPDATED</u>	<u>by PJM</u>	<u>04/11/2019</u>	(Import)
0600	Continuous	2359				SCH - PJM_NEPTUNE Impacts Total Transfer Capability 285 MW TTC with All Lines In Service 660 MW
Work scheduled by: LI						375 MW
NEWBRDGE_345_138_BK_2						FWD
Mon 04/08/2019	to	Mon 04/15/2019	<u>UPDATED</u>	<u>by PJM</u>	<u>04/11/2019</u>	(Import)
0600	Continuous	1800				SCH - PJM_NEPTUNE Impacts Total Transfer Capability 285 MW TTC with All Lines In Service 660 MW
Work scheduled by: LI						375 MW
S.RIPLEY-DUNKIRK__230_68						FWD REV
Mon 04/08/2019	to	Mon 04/15/2019	<u>UPDATED</u>	<u>by PJM</u>	<u>02/11/2019</u>	(Import) (Export)
0800	Continuous	2000				SCH - PJ - NY Impacts Total Transfer Capability 0 MW 250 MW TTC with All Lines In Service 2600 MW 1550 MW
Work scheduled by: PJM						2600 MW 1300 MW
COOPERS_-MIDDLETP_345_CCRT34						FWD
Wed 04/10/2019	to	Wed 04/10/2019				(Import)
0700	Continuous	1600				CENTRAL EAST - VC Impacts Total Transfer Capability 255 MW TTC with All Lines In Service 2975 MW
Work scheduled by: ORU						2720 MW
MARCY____345KV_CSC						FWD
Thu 04/11/2019	to	Wed 04/17/2019				(Import)
0500	Continuous	1730				CENTRAL EAST - VC Impacts Total Transfer Capability 50 MW TTC with All Lines In Service 2975 MW
Work scheduled by: NYPA						2925 MW
MARCY____-EDIC____345_UE1-7						FWD
Thu 04/11/2019	to	Sat 04/20/2019				(Import)
0500	Continuous	1730				OSWEGO EXPORT Impacts Total Transfer Capability 0 MW TTC with All Lines In Service 5250 MW
Work scheduled by: NYPA						5250 MW

ARR: 19&16

NYISO TRANSFER LIMITATIONS

Saturday ,April 13, 2019 to Monday ,October 12, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					FWD
SCH-IMO-NYISO_LIMIT_300					(Import)
Sat 04/13/2019	to	Sat 04/13/2019	<u>UPDATED</u>	<u>by NYISO</u>	<u>04/05/2019</u>
0001	Continuous	2359			
Work scheduled by: NYISO					SCH - OH - NY 600 MW
					Impacts Total Transfer Capability 1650 MW
					TTC with All Lines In Service 2250 MW
<hr/>					
SCH-NYISO-IMO_LIMIT_500					REV
					(Export)
Sat 04/13/2019	to	Sat 04/13/2019	<u>UPDATED</u>	<u>by NYISO</u>	<u>04/05/2019</u>
0001	Continuous	2359			
Work scheduled by: NYISO					SCH - OH - NY 800 MW
					Impacts Total Transfer Capability 1200 MW
					TTC with All Lines In Service 2000 MW
<hr/>					
SCH-NYISO-PJM_LIMIT_200					REV
					(Export)
Sat 04/13/2019	to	Sat 04/13/2019	<u>UPDATED</u>	<u>by NYISO</u>	<u>04/05/2019</u>
0001	Continuous	2359			
Work scheduled by: NYISO					SCH - PJ - NY 500 MW
					Impacts Total Transfer Capability 1050 MW
					TTC with All Lines In Service 1550 MW
<hr/>					
DUNWODIE-SHORE_RD_345_Y50					FWD
					(Import)
Sat 04/13/2019	to	Mon 04/15/2019	<u>UPDATED</u>	<u>by CE</u>	<u>04/13/2019</u>
0301	Continuous	1830			
Work scheduled by: ConEd					CONED - LIPA 800 MW
					Impacts Total Transfer Capability 700 MW
					TTC with All Lines In Service 1500 MW
<hr/>					
DUNWODIE_345KV_4					FWD
					(Import)
Sat 04/13/2019	to	Mon 04/15/2019	<u>UPDATED</u>	<u>by CE</u>	<u>04/13/2019</u>
0301	Continuous	1830			
Work scheduled by: ConEd					SPR/DUN-SOUTH 3800 MW
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
<hr/>					
DUNWODIE_345KV_8					FWD
					(Import)
Sat 04/13/2019	to	Mon 04/15/2019	<u>UPDATED</u>	<u>by CE</u>	<u>04/13/2019</u>
0301	Continuous	1830			
Work scheduled by: ConEd					SPR/DUN-SOUTH 3800 MW
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
<hr/>					
PLSNTVLE-DUNWODIE_345_W90					FWD
					(Import)
Sat 04/13/2019	to	Mon 04/15/2019	<u>UPDATED</u>	<u>by CE</u>	<u>04/13/2019</u>
0301	Continuous	1830			
Work scheduled by: ConEd					UPNY CONED 4000 MW
					Impacts Total Transfer Capability 1700 MW
					TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Saturday ,April 13, 2019 to Monday ,October 12, 2020

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC1

Sat 04/13/2019 to Sat 04/13/2019
0700 Continuous 1700

Work scheduled by: HQ

FWD
(Import)
MOSES SOUTH **2850 MW**
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 3150 MW

CHAT_DC_GC1

Sat 04/13/2019 to Sat 04/13/2019
0700 Continuous 1700

Work scheduled by: HQ

REV
(Export)
SCH - HQ - NY **500 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1000 MW

SCH-HQ-NYISO_LIMIT_1150

Sat 04/13/2019 to Sat 04/13/2019
0700 Continuous 1700

Work scheduled by: HQ

FWD
(Import)
SCH - HQ - NY **1150 MW**
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 1500 MW

SPRNBRK__345KV_RNS5

Sun 04/14/2019 to Sun 04/14/2019
0001 Continuous 0030

Work scheduled by: ConEd

FORCED by CE 04/12/2019

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

SPRNBRK_-W49TH_ST_345_M51

Sun 04/14/2019 to Sat 04/20/2019
0001 Continuous 2200

Work scheduled by: ConEd

FORCED by CE 04/12/2019

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

NINEMILE-CLAY 345_8

Sun 04/14/2019 to Sun 04/14/2019
0200 Continuous 0230

Work scheduled by: NGrid

FWD
(Import)
OSWEGO EXPORT **5150 MW**
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 5250 MW

SPRNBRK__345KV_RNS5

Mon 04/15/2019 to Mon 04/15/2019
0001 Continuous 0030

Work scheduled by: ConEd

CANCELLED by ConEd 04/08/2019

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Saturday ,April 13, 2019 to Monday ,October 12, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EASTVIEW-SPRNBK__345_W64				FWD
Mon 04/15/2019	to	Fri 04/19/2019	CANCELLED by ConEd 04/08/2019	(Import)
0001	Continuous	0159		UPNY CONED 4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1350 MW
				TTC with All Lines In Service 5700 MW
MILLWOOD-EASTVIEW_345_W99				FWD
Mon 04/15/2019	to	Fri 04/19/2019	CANCELLED by ConEd 04/08/2019	(Import)
0001	Continuous	0159		UPNY CONED 4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1350 MW
				TTC with All Lines In Service 5700 MW
SCH-NYISO-HQ_LIMIT_800				REV
Mon 04/15/2019	to	Fri 05/24/2019		(Export)
0400	Continuous	1700		SCH - HQ - NY 800 MW
Work scheduled by: HQ				Impacts Total Transfer Capability 200 MW
				TTC with All Lines In Service 1000 MW
SCRIBA__-VOLNEY__345_20				FWD
Mon 04/15/2019	to	Tue 04/16/2019		(Import)
0600	Continuous	1800		OSWEGO EXPORT 5250 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 0 MW
				TTC with All Lines In Service 5250 MW
PORTER__-ROTTRDAM_230_30				FWD
Mon 04/15/2019	to	Mon 04/15/2019		(Import)
0700	Daily(No Weekends)	1630		CENTRAL EAST - VC 2805 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 170 MW
				TTC with All Lines In Service 2975 MW
DUNWODIE_345KV_7				FWD
Thu 04/18/2019	to	Thu 04/18/2019	CANCELLED by ConEd 04/11/2019	(Import)
0301	Continuous	0330		SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_8				FWD
Thu 04/18/2019	to	Thu 04/18/2019	CANCELLED by ConEd 04/11/2019	(Import)
0301	Continuous	0330		SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Saturday ,April 13, 2019 to Monday ,October 12, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					FWD
DUNWODIE-MOTTHAVN_345_72					(Import)
Thu 04/18/2019	to	Thu 04/25/2019	<u>CANCELLED</u>	<u>by ConEd</u>	<u>04/11/2019</u>
0301	Continuous	0300			
Work scheduled by: ConEd					SPR/DUN-SOUTH 3800 MW
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
<hr/>					FWD
SPRNBRK_345KV_RNS5					(Import)
Fri 04/19/2019	to	Fri 04/19/2019	<u>CANCELLED</u>	<u>by ConEd</u>	<u>04/08/2019</u>
0130	Continuous	0159			
Work scheduled by: ConEd					SPR/DUN-SOUTH 3200 MW
					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW
<hr/>					FWD
EASTVIEW-SPRNBRK_345_W79					(Import)
Fri 04/19/2019	to	Fri 04/19/2019			
0200	Continuous	2230			
Work scheduled by: ConEd					UPNY CONED 4350 MW
					Impacts Total Transfer Capability 1350 MW
					TTC with All Lines In Service 5700 MW
<hr/>					FWD
BUCHAN_N-EASTVIEW_345_W93					(Import)
Fri 04/19/2019	to	Mon 04/22/2019			
0200	Continuous	0300			
Work scheduled by: ConEd					UPNY CONED 4350 MW
					Impacts Total Transfer Capability 1350 MW
					TTC with All Lines In Service 5700 MW
<hr/>					FWD
SCH-IMO-NYISO_LIMIT_300					(Import)
Sat 04/20/2019	to	Sat 04/20/2019	<u>UPDATED</u>	<u>by NYISO</u>	<u>04/05/2019</u>
0001	Continuous	2359			
Work scheduled by: NYISO					SCH - OH - NY 600 MW
					Impacts Total Transfer Capability 1650 MW
					TTC with All Lines In Service 2250 MW
<hr/>					REV
SCH-NYISO-IMO_LIMIT_500					(Export)
Sat 04/20/2019	to	Sat 04/20/2019	<u>UPDATED</u>	<u>by NYISO</u>	<u>04/05/2019</u>
0001	Continuous	2359			
Work scheduled by: NYISO					SCH - OH - NY 800 MW
					Impacts Total Transfer Capability 1200 MW
					TTC with All Lines In Service 2000 MW
<hr/>					REV
SCH-NYISO-PJM_LIMIT_200					(Export)
Sat 04/20/2019	to	Sat 04/20/2019	<u>UPDATED</u>	<u>by NYISO</u>	<u>04/05/2019</u>
0001	Continuous	2359			
Work scheduled by: NYISO					SCH - PJ - NY 500 MW
					Impacts Total Transfer Capability 1050 MW
					TTC with All Lines In Service 1550 MW

NYISO TRANSFER LIMITATIONS

Saturday ,April 13, 2019 to Monday ,October 12, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK__345KV_RNS5					FWD
Sat 04/20/2019	to	Sat 04/20/2019	FORCED	by CE	(Import)
2130	Continuous	2200			3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW
EASTVIEW-SPRNBK__345_W79					FWD
Mon 04/22/2019	to	Mon 04/22/2019			(Import)
0230	Continuous	0300			4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1350 MW
					TTC with All Lines In Service 5700 MW
SCH-NYISO-IMO_NIAGARA_CB_3002					FWD REV
Mon 04/22/2019	to	Mon 04/22/2019			(Import) (Export)
0500	Continuous	1700			1550 MW 1400 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 700 MW 600 MW
					TTC with All Lines In Service 2250 MW 2000 MW
EDIC__-FRASER__345_EF24-40					FWD
Mon 04/22/2019	to	Fri 04/26/2019			(Import)
0500	Continuous	1730			2500 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 475 MW
					TTC with All Lines In Service 2975 MW
MARCY__765_345_AT2					FWD
Mon 04/22/2019	to	Fri 04/26/2019			(Import)
0500	Continuous	1730			1700 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 1450 MW
ARR: 19					TTC with All Lines In Service 3150 MW
EFISHKIL-WOOD_ST__345_F38					FWD
Thu 04/25/2019	to	Thu 04/25/2019			(Import)
0001	Continuous	0030			4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1700 MW
					TTC with All Lines In Service 5700 MW
PLSNTVLE-DUNWODIE_345_W89					FWD
Thu 04/25/2019	to	Thu 04/25/2019			(Import)
0001	Continuous	0030			4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1700 MW
					TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Saturday ,April 13, 2019 to Monday ,October 12, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

WOOD_ST_-PLSNTVLE_345_Y86

Thu 04/25/2019 to Sun 04/28/2019
 0001 Continuous 0259
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 1700 MW
 TTC with All Lines In Service 5700 MW

DUNWODIE_345KV_7

Thu 04/25/2019 to Thu 04/25/2019 **CANCELLED by ConEd 04/11/2019**
 0230 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_8

Thu 04/25/2019 to Thu 04/25/2019 **CANCELLED by ConEd 04/11/2019**
 0230 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

FRASANX-COOPERS__345_UCC2-41

Sat 04/27/2019 to Fri 05/03/2019 **UPDATED by NYPA 08/22/2018**
 0500 Continuous 1730
 Work scheduled by: NYPA **ARR: 19**

FWD
 (Import)
 CENTRAL EAST - VC **2500 MW**
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

MARCY__-FRASANX_345_UCC2-41

Sat 04/27/2019 to Fri 05/03/2019 **UPDATED by NYPA 08/22/2018**
 0500 Continuous 1730
 Work scheduled by: NYPA **ARR: 19**

FWD
 (Import)
 CENTRAL EAST - VC **2500 MW**
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

EFISHKIL-WOOD_ST__345_F38

Sun 04/28/2019 to Sun 04/28/2019
 0230 Continuous 0259
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 1700 MW
 TTC with All Lines In Service 5700 MW

PLSNTVLE-DUNWODIE_345_W89

Sun 04/28/2019 to Sun 04/28/2019
 0230 Continuous 0259
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 1700 MW
 TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Saturday ,April 13, 2019 to Monday ,October 12, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

KINTIGH_-ROCHESTR_345_SR1-39				FWD
Mon 04/29/2019	to	Thu 05/02/2019	UPDATED by NYSEG 11/08/2018	(Import)
0600	Continuous	1700	DYSINGER EAST	1700 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 1450 MW
				TTC with All Lines In Service 3150 MW
MOSES_-ADIRNDCK_230_MAI				FWD
Mon 04/29/2019	to	Fri 05/03/2019	CANCELLED by NYPA 04/12/2019	(Import)
0700	Continuous	1500	MOSES SOUTH	2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW
SCH-HQ-NYISO_LIMIT_1400				FWD
Mon 04/29/2019	to	Fri 05/03/2019		(Import)
0700	Continuous	1730	SCH - HQ - NY	1400 MW
Work scheduled by: HQ				Impacts Total Transfer Capability 100 MW
				TTC with All Lines In Service 1500 MW
CHAT_DC_GC1				FWD
Mon 04/29/2019	to	Fri 05/24/2019		(Import)
0700	Continuous	1700	MOSES SOUTH	2850 MW
Work scheduled by: HQ				Impacts Total Transfer Capability 300 MW
				TTC with All Lines In Service 3150 MW
CHAT_DC_GC1				REV
Mon 04/29/2019	to	Fri 05/24/2019		(Export)
0700	Continuous	1700	SCH - HQ - NY	500 MW
Work scheduled by: HQ				Impacts Total Transfer Capability 500 MW
				TTC with All Lines In Service 1000 MW
DUNWODIE_345KV_3				FWD
Wed 05/01/2019	to	Wed 05/01/2019		(Import)
0001	Continuous	0030	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_4				FWD
Wed 05/01/2019	to	Wed 05/01/2019		(Import)
0001	Continuous	0030	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Saturday ,April 13, 2019 to Monday ,October 12, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Work Scheduled	Work Scheduled by	Impact	TTC with All Lines In Service
PLSNTVLE-DUNWODIE_345_W89			
Wed 05/01/2019 0001 to Thu 05/02/2019 0300 Continuous	ConEd	UPNY CONED Impacts Total Transfer Capability 1700 MW	4000 MW 5700 MW
EGRDNCTY_345_138_AT2			
Wed 05/01/2019 0001 to Wed 05/15/2019 2359 Continuous	LI	CONED - LIPA Impacts Total Transfer Capability 250 MW	1250 MW 1500 MW
HUDSONTP-W49TH_ST_345_Y56			
Wed 05/01/2019 0600 to Tue 05/07/2019 1800 Continuous	PJM	SCH - PJM_HTP Impacts Total Transfer Capability 660 MW	0 MW 660 MW
DUNWODIE_345KV_3			
Thu 05/02/2019 0230 to Thu 05/02/2019 0300 Continuous	ConEd	SPR/DUN-SOUTH Impacts Total Transfer Capability 800 MW	3800 MW 4600 MW
DUNWODIE_345KV_4			
Thu 05/02/2019 0230 to Thu 05/02/2019 0300 Continuous	ConEd	SPR/DUN-SOUTH Impacts Total Transfer Capability 800 MW	3800 MW 4600 MW
STONYRDG-HILLSIDE_230_72			
Fri 05/03/2019 0800 to Fri 05/03/2019 1530 Continuous	NYSEG	DYSINGER EAST Impacts Total Transfer Capability 300 MW	2850 MW 3150 MW
CHATGUAY-MASSENA__765_7040			
Sat 05/04/2019 0530 to Sat 05/04/2019 1930 Continuous	NYPA	MOSES SOUTH Impacts Total Transfer Capability 1600 MW	1550 MW 3150 MW

NYISO TRANSFER LIMITATIONS

Saturday ,April 13, 2019 to Monday ,October 12, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHATGUAY-MASSENA__765_7040

Sat 05/04/2019 to Sat 05/04/2019
 0530 Continuous 1930

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	0 MW	0 MW
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

MASSENA_-MARCY____765_MSU1

Sat 05/04/2019 to Sat 05/04/2019
 0530 Continuous 1930

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	2265 MW
Impacts Total Transfer Capability	710 MW
TTC with All Lines In Service	2975 MW

MASSENA_-MARCY____765_MSU1

Sat 05/04/2019 to Sat 05/04/2019
 0530 Continuous 1930

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	500 MW
Impacts Total Transfer Capability	2650 MW
TTC with All Lines In Service	3150 MW

MASSENA_-MARCY____765_MSU1

Sat 05/04/2019 to Sat 05/04/2019
 0530 Continuous 1930

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	475 MW	1000 MW
Impacts Total Transfer Capability	1025 MW	0 MW
TTC with All Lines In Service	1500 MW	1000 MW

MASSENA_-MARCY____765_MSU1 & CHATGUAY-MASSENA__765_7040

Sat 05/04/2019 to Sat 05/04/2019
 0530 1930

Work scheduled by:

	FWD
	(Import)
MOSES SOUTH	500 MW
Impacts Total Transfer Capability	2650 MW
TTC with All Lines In Service	3150 MW

S.PERRY_-MEYER____230_87

Mon 05/06/2019 to Mon 05/06/2019
 0600 Continuous 1600

Work scheduled by: NYSEG

	FWD
	(Import)
DYSINGER EAST	2850 MW
Impacts Total Transfer Capability	300 MW
TTC with All Lines In Service	3150 MW

SHOR_NPX-SHOREHAM_138_CSC

Mon 05/06/2019 to Fri 05/10/2019
 0700 Continuous 1800

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_CSC	0 MW	0 MW
Impacts Total Transfer Capability	330 MW	330 MW
TTC with All Lines In Service	330 MW	330 MW

NYISO TRANSFER LIMITATIONS

Saturday ,April 13, 2019 to Monday ,October 12, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROSETON_-ROCKTVRN_345_311

FWD

Mon 05/06/2019 to Sat 06/08/2019
0800 Continuous 1600

EXTENDED by CHGE 03/26/2019

Work scheduled by: CHGE

UPNY CONED **4400 MW**
Impacts Total Transfer Capability 1300 MW
TTC with All Lines In Service 5700 MW

SPRNBRK_345KV_RNS4

FWD

Tue 05/07/2019 to Tue 05/07/2019
0001 Continuous 2359

Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

EASTVIEW-SPRNBRK_345_W65

FWD

Tue 05/07/2019 to Wed 05/08/2019
0001 Continuous 0200

Work scheduled by: ConEd

UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1350 MW
TTC with All Lines In Service 5700 MW

MILLWOOD-EASTVIEW_345_W82

FWD

Tue 05/07/2019 to Wed 05/08/2019
0001 Continuous 0200

Work scheduled by: ConEd

UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1350 MW
TTC with All Lines In Service 5700 MW

EGRDNCTY_345_138_AT1

FWD

Wed 05/08/2019 to Fri 05/10/2019
0300 Continuous 2200

Work scheduled by: ConEd

CONED - LIPA **1250 MW**
Impacts Total Transfer Capability 250 MW
TTC with All Lines In Service 1500 MW

SPRNBRK_-EGRDNCTR_345_Y49

FWD

Wed 05/08/2019 to Fri 05/10/2019
0300 Continuous 2200

Work scheduled by: ConEd

CONED - LIPA **775 MW**
Impacts Total Transfer Capability 725 MW
TTC with All Lines In Service 1500 MW

EASTVIEW-SPRNBRK_345_W64

FWD

Sat 05/11/2019 to Sat 05/11/2019
0001 Continuous 0030

Work scheduled by: ConEd

UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1350 MW
TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Saturday ,April 13, 2019 to Monday ,October 12, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Outage ID	Start Date	End Date	Time	Work by	Zone	Impact	TTC	FWD	REV
SPRNBK__345KV_RNS5	Sat 05/11/2019	Sat 05/11/2019	0001 - 0030	ConEd	SPR/DUN-SOUTH	1400 MW	4600 MW	(Import)	
Impacts Total Transfer Capability 1400 MW TTC with All Lines In Service 4600 MW									
MILLWOOD-EASTVIEW_345_W99	Sat 05/11/2019	Tue 05/14/2019	0001 - 2230	ConEd	UPNY CONED	1350 MW	5700 MW	(Import)	
Impacts Total Transfer Capability 1350 MW TTC with All Lines In Service 5700 MW									
CHATGUAY-MASSENA__765_7040	Sat 05/11/2019	Sat 05/11/2019	0530 - 1930	NYPA	MOSES SOUTH	1600 MW	3150 MW	(Import)	
Impacts Total Transfer Capability 1600 MW TTC with All Lines In Service 3150 MW									
CHATGUAY-MASSENA__765_7040	Sat 05/11/2019	Sat 05/11/2019	0530 - 1930	NYPA	SCH - HQ - NY	1500 MW	1000 MW	(Import)	(Export)
Impacts Total Transfer Capability 1500 MW TTC with All Lines In Service 1500 MW									
MASSENA_-MARCY____765_MSU1	Sat 05/11/2019	Sat 05/11/2019	0530 - 1930	NYPA	CENTRAL EAST - VC	710 MW	2975 MW	(Import)	
Impacts Total Transfer Capability 710 MW TTC with All Lines In Service 2975 MW									
MASSENA_-MARCY____765_MSU1	Sat 05/11/2019	Sat 05/11/2019	0530 - 1930	NYPA	MOSES SOUTH	2650 MW	3150 MW	(Import)	
Impacts Total Transfer Capability 2650 MW TTC with All Lines In Service 3150 MW									
MASSENA_-MARCY____765_MSU1	Sat 05/11/2019	Sat 05/11/2019	0530 - 1930	NYPA	SCH - HQ - NY	1025 MW	1000 MW	(Import)	(Export)
Impacts Total Transfer Capability 1025 MW TTC with All Lines In Service 1500 MW									

NYISO TRANSFER LIMITATIONS

Saturday ,April 13, 2019 to Monday ,October 12, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040

Sat 05/11/2019 to Sat 05/11/2019
0530 to 1930

Work scheduled by:

FWD
(Import)
MOSES SOUTH 500 MW
Impacts Total Transfer Capability 2650 MW
TTC with All Lines In Service 3150 MW

NIAGARA -ROCHESTR 345_NR2

Mon 05/13/2019 to Fri 05/17/2019
0500 Continuous 1700

Work scheduled by: NYPA

UPDATED by NYPA 04/09/2019

FWD
(Import)
DYSINGER EAST 1400 MW
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

EASTVIEW-SPRNBRK 345_W64

Tue 05/14/2019 to Tue 05/14/2019
2200 Continuous 2230

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED 4350 MW
Impacts Total Transfer Capability 1350 MW
TTC with All Lines In Service 5700 MW

SPRNBRK 345KV_RNS5

Tue 05/14/2019 to Tue 05/14/2019
2200 Continuous 2230

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH 3200 MW
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

CHATGUAY-MASSENA 765_7040

Sat 05/18/2019 to Sat 05/18/2019
0530 Continuous 1930

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH 1550 MW
Impacts Total Transfer Capability 1600 MW
TTC with All Lines In Service 3150 MW

CHATGUAY-MASSENA 765_7040

Sat 05/18/2019 to Sat 05/18/2019
0530 Continuous 1930

Work scheduled by: NYPA

FWD REV
(Import) (Export)
SCH - HQ - NY 0 MW 0 MW
Impacts Total Transfer Capability 1500 MW 1000 MW
TTC with All Lines In Service 1500 MW 1000 MW

MASSENA -MARCY 765_MSU1

Sat 05/18/2019 to Sat 05/18/2019
0530 Continuous 1930

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC 2265 MW
Impacts Total Transfer Capability 710 MW
TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Saturday ,April 13, 2019 to Monday ,October 12, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA -MARCY 765_MSU1			FWD	
Sat 05/18/2019	to	Sat 05/18/2019	(Import)	
0530	Continuous	1930	MOSES SOUTH	500 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	2650 MW
			TTC with All Lines In Service	3150 MW
MASSENA -MARCY 765_MSU1			FWD	REV
Sat 05/18/2019	to	Sat 05/18/2019	(Import)	(Export)
0530	Continuous	1930	SCH - HQ - NY	475 MW 1000 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1025 MW 0 MW
			TTC with All Lines In Service	1500 MW 1000 MW
MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040			FWD	
Sat 05/18/2019	to	Sat 05/18/2019	(Import)	
0530		1930	MOSES SOUTH	500 MW
Work scheduled by:			Impacts Total Transfer Capability	2650 MW
			TTC with All Lines In Service	3150 MW
SCH-NE-NYISO_LIMIT_500			FWD	
Mon 05/20/2019	to	Thu 05/23/2019	(Import)	
0600	Continuous	2000	SCH - NE - NY	700 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	700 MW
			TTC with All Lines In Service	1400 MW
SCH-NYISO-NE_LIMIT_1200				REV
Mon 05/20/2019	to	Thu 05/23/2019		(Export)
0600	Continuous	2000	SCH - NE - NY	1400 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	200 MW
			TTC with All Lines In Service	1600 MW
ADIRNDCK-PORTER 230_12			FWD	
Mon 05/20/2019	to	Fri 05/24/2019	(Import)	
0700	Continuous	1530	MOSES SOUTH	2100 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1050 MW
			TTC with All Lines In Service	3150 MW
PANNELL -CLAY 345_1			FWD	
Mon 05/20/2019	to	Fri 05/24/2019	(Import)	
0700	Continuous	1530	WEST CENTRAL	1300 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	950 MW
			TTC with All Lines In Service	2250 MW

NYISO TRANSFER LIMITATIONS

Saturday ,April 13, 2019 to Monday ,October 12, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROSETON_-EFISHKIL_345_RFK305

Thu 05/23/2019 to Thu 05/23/2019
0800 Daily 1600

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4800 MW**
Impacts Total Transfer Capability 900 MW
TTC with All Lines In Service 5700 MW

SCRIBA_-VOLNEY_345_20

Tue 05/28/2019 to Tue 05/28/2019
0600 Continuous 1800

Work scheduled by: NGrid

FWD
(Import)
OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

PANNELL_-CLAY_345_2

Mon 06/03/2019 to Fri 06/07/2019
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

NIAGARA_-KINTIGH_345_NS1-38

Mon 06/03/2019 to Fri 06/07/2019
0800 Continuous 1430

Work scheduled by: NYSEG

FWD
(Import)
DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

FRASER_345_FRASER SVC

Mon 06/03/2019 to Fri 06/07/2019
0800 Continuous 1700

Work scheduled by: NYSEG

FWD
(Import)
CENTRAL EAST - VC **2935 MW**
Impacts Total Transfer Capability 40 MW
TTC with All Lines In Service 2975 MW

NIAGARA_-KINTIGH_345_NS1-38

Mon 06/10/2019 to Fri 06/14/2019
0800 Continuous 1430

Work scheduled by: NYSEG

FWD
(Import)
DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

MOSES_-ADIRNDCK_230_MA2

Mon 06/24/2019 to Fri 06/28/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Saturday ,April 13, 2019 to Monday ,October 12, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA2

Mon 07/08/2019 to Fri 07/12/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

ADIRNDCK-CHASLAKE_230_13

Mon 07/08/2019 to Fri 07/12/2019
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

MARCY___765_345_AT2

Sat 08/03/2019 to Sun 08/04/2019
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

NIAGARA_345_230_AT4

Mon 08/05/2019 to Tue 08/06/2019
0500 Continuous 1700

Work scheduled by: NYPA

FWD REV
(Import) (Export)
SCH - OH - NY **1900 MW 1400 MW**
Impacts Total Transfer Capability 0 MW 350 MW
TTC with All Lines In Service 1900 MW 1750 MW

MOSES___-ADIRNDCK_230_MA1

Mon 08/12/2019 to Mon 08/12/2019 **UPDATED by NYPA 10/10/2018**
0700 Continuous 1459

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

SHOR_NPX-SHOREHAM_138_CSC

Tue 09/03/2019 to Wed 09/04/2019 **UPDATED by ISONE 02/15/2019**
0300 Continuous 1600

Work scheduled by: LI

FWD REV
(Import) (Export)
SCH - NPX_CSC **0 MW 0 MW**
Impacts Total Transfer Capability 330 MW 330 MW
TTC with All Lines In Service 330 MW 330 MW

MARCY___765_345_AT1

Tue 09/03/2019 to Tue 09/03/2019
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1750 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Saturday ,April 13, 2019 to Monday ,October 12, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___-N.SCTLND_345_18

Wed 09/04/2019 to Wed 09/04/2019
0500 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 11/06/2018

ARR: 19

FWD

(Import)

CENTRAL EAST - VC **2090 MW**
Impacts Total Transfer Capability 885 MW
TTC with All Lines In Service 2975 MW

MARCY___345KV_CSC

Wed 09/04/2019 to Wed 09/04/2019
0500 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 11/06/2018

FWD

(Import)

CENTRAL EAST - VC **2925 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

MOSES___-ADIRNDCK_230_MA2

Wed 09/04/2019 to Wed 09/04/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

ADIRNDCK-PORTER___230_12

Wed 09/04/2019 to Wed 09/04/2019
0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

ADIRNDCK-CHASLAKE_230_13

Thu 09/05/2019 to Thu 09/05/2019
0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

NIAGARA_-ROCHESTR_345_NR2

Mon 09/09/2019 to Sat 09/21/2019
0500 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

LEEDS___345KV_R395

Mon 09/09/2019 to Mon 09/09/2019
0700 Continuous 0730

Work scheduled by: NYPA

FWD

(Import)

UPNY CONED **3800 MW**
Impacts Total Transfer Capability 1900 MW
TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Saturday ,April 13, 2019 to Monday ,October 12, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

GILBOA -LEEDS 345_GL3

Mon 09/09/2019 to Fri 09/27/2019
0700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC **2200 MW**
Impacts Total Transfer Capability 775 MW
TTC with All Lines In Service 2975 MW

MARCY -N.SCTLND 345_18

Wed 09/11/2019 to Fri 09/13/2019
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

CENTRAL EAST - VC **2090 MW**
Impacts Total Transfer Capability 885 MW
TTC with All Lines In Service 2975 MW

MOSES -ADIRNDCK 230_MA2

Mon 09/16/2019 to Fri 09/20/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

GOETHALS 345KV_5

Fri 09/20/2019 to Tue 09/24/2019
0001 Continuous 2359

Work scheduled by: ConEd

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

ROCHESTR-PANNELL 345_RP2

Mon 09/23/2019 to Mon 09/30/2019
0500 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

KINTIGH -ROCHESTR 345_SR1-39

Mon 09/23/2019 to Fri 09/27/2019
0600 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

LEEDS 345KV_R395

Fri 09/27/2019 to Fri 09/27/2019
1700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

UPNY CONED **3800 MW**
Impacts Total Transfer Capability 1900 MW
TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Saturday ,April 13, 2019 to Monday ,October 12, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CLAY -EDIC 345_1-16		FWD	
Mon 09/30/2019	to Fri 10/04/2019	(Import)	
0700	Continuous 1530	OSWEGO EXPORT	4850 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	400 MW
		TTC with All Lines In Service	5250 MW
LEEDS -HURLYAVE 345_301		FWD	
Mon 09/30/2019	to Sat 10/26/2019	(Import)	
0800	Continuous 1600	UPNY CONED	4100 MW
Work scheduled by: CHGE		Impacts Total Transfer Capability	1600 MW
		TTC with All Lines In Service	5700 MW
CLAY -EDIC 345_2-15		FWD	
Mon 10/07/2019	to Thu 10/17/2019	(Import)	
0700	Continuous 1530	OSWEGO EXPORT	4850 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	400 MW
		TTC with All Lines In Service	5250 MW
MARCY -N.SCTLND 345_18		FWD	
Wed 10/09/2019	to Fri 10/11/2019	(Import)	
0500	Continuous 1730	CENTRAL EAST - VC	2090 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	885 MW
		TTC with All Lines In Service	2975 MW
		ARR: 19	
CHATGUAY-MASSENA 765_7040		FWD	
Sat 10/12/2019	to Sat 10/26/2019	(Import)	
0100	Continuous 1900	MOSES SOUTH	1550 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	1600 MW
		TTC with All Lines In Service	3150 MW
CHATGUAY-MASSENA 765_7040		FWD	REV
Sat 10/12/2019	to Sat 10/26/2019	(Import) (Export)	
0100	Continuous 1900	SCH - HQ - NY	0 MW 0 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	1500 MW 1000 MW
		TTC with All Lines In Service	1500 MW 1000 MW
MARCY 765_345_AT1		FWD	
Sat 10/12/2019	to Sat 10/26/2019	(Import)	
0100	Continuous 1900	MOSES SOUTH	1750 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	1400 MW
		TTC with All Lines In Service	3150 MW
		ARR: 19	

NYISO TRANSFER LIMITATIONS

Saturday ,April 13, 2019 to Monday ,October 12, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT2

Sat 10/12/2019 to Sat 10/26/2019
0100 Continuous 1900

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

MASSENA_-MARCY___765_MSU1

Sat 10/12/2019 to Sat 10/26/2019
0100 Continuous 1900

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2265 MW**
Impacts Total Transfer Capability 710 MW
TTC with All Lines In Service 2975 MW

MASSENA_-MARCY___765_MSU1

Sat 10/12/2019 to Sat 10/26/2019
0100 Continuous 1900

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **500 MW**
Impacts Total Transfer Capability 2650 MW
TTC with All Lines In Service 3150 MW

MASSENA_-MARCY___765_MSU1

Sat 10/12/2019 to Sat 10/26/2019
0100 Continuous 1900

Work scheduled by: NYPA

FWD REV
(Import) (Export)
SCH - HQ - NY **475 MW 1000 MW**
Impacts Total Transfer Capability 1025 MW 0 MW
TTC with All Lines In Service 1500 MW 1000 MW

MASSENA_-MARCY___765_MSU1 & CHATGUAY-MASSENA_765_7040

Sat 10/12/2019 to Sat 10/26/2019
0100 1900

Work scheduled by:

FWD
(Import)
MOSES SOUTH **500 MW**
Impacts Total Transfer Capability 2650 MW
TTC with All Lines In Service 3150 MW

MOSES_-MASSENA_230_MMS1 & MOSES_-MASSENA_230_MMS2

Sat 10/12/2019 to Sat 10/26/2019
0100 1900

Work scheduled by:

FWD REV
(Import) (Export)
SCH - HQ - NY **850 MW 0 MW**
Impacts Total Transfer Capability 650 MW 1000 MW
TTC with All Lines In Service 1500 MW 1000 MW

DUNWODIE_345KV_3

Tue 10/22/2019 to Tue 10/22/2019
0001 Continuous 0030

Work scheduled by: ConEd

UPDATED by CONED 02/06/2019

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Saturday ,April 13, 2019 to Monday ,October 12, 2020

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_5					FWD	
Tue 10/22/2019	to	Tue 10/22/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/06/2019</u>	(Import)
0001	Continuous	0030				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
DUNWODIE-MOTTHAVN_345_71					FWD	
Tue 10/22/2019	to	Tue 11/26/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>02/06/2019</u>	(Import)
0001	Continuous	2359				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
GILBOA_-N.SCTLND_345_GNS-1					FWD	
Tue 10/22/2019	to	Thu 10/24/2019				(Import)
0700	Continuous	1530				CENTRAL EAST - VC 2520 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	455 MW
					TTC with All Lines In Service	2975 MW
GILBOA_-N.SCTLND_345_GNS-1					FWD	
Fri 10/25/2019	to	Fri 10/25/2019				(Import)
1330	Continuous	1530				CENTRAL EAST - VC 2520 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	455 MW
					TTC with All Lines In Service	2975 MW
NIAGARA_345_230_AT4					FWD	REV
Mon 10/28/2019	to	Fri 12/13/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>04/10/2019</u>	(Import) (Export)
0500	Continuous	1700				SCH - OH - NY 1900 MW 1400 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	0 MW 350 MW
					TTC with All Lines In Service	1900 MW 1750 MW
LINDN_CG-LNDVFT_345_V-3022					FWD	REV
Mon 11/04/2019	to	Thu 11/07/2019				(Import) (Export)
0800	Continuous	1500				SCH - PJM_VFT 0 MW 0 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	315 MW 315 MW
					TTC with All Lines In Service	315 MW 315 MW
HURLYAVE-ROSETON_345_303					FWD	
Mon 11/04/2019	to	Fri 12/06/2019				(Import)
0800	Continuous	1600				UPNY CONED 4100 MW
Work scheduled by: CHGE					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	5700 MW

NYISO TRANSFER LIMITATIONS

Saturday ,April 13, 2019 to Monday ,October 12, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PANNELL_-CLAY_____345_2

Wed 11/06/2019 to Fri 11/22/2019
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)

WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

MARCY_-N.SCTLND_345_18

Thu 11/07/2019 to Fri 11/08/2019
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)

CENTRAL EAST - VC **2090 MW**
Impacts Total Transfer Capability 885 MW
TTC with All Lines In Service 2975 MW

MARCY_____345KV_CSC

Thu 11/07/2019 to Fri 11/08/2019
0500 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)

CENTRAL EAST - VC **2925 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

MOSES_-ADIRNDCK_230_MA2

Tue 11/12/2019 to Fri 11/15/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MOSES_-ADIRNDCK_230_MA2

Mon 11/18/2019 to Fri 11/22/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MOSES_-ADIRNDCK_230_MA2

Mon 11/25/2019 to Wed 11/27/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

DUNWODIE_345KV_3

Tue 11/26/2019 to Tue 11/26/2019
2330 Continuous 2359

Work scheduled by: ConEd

UPDATED by CONED 02/06/2019

FWD
(Import)

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Saturday ,April 13, 2019 to Monday ,October 12, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_5

Tue 11/26/2019 to Tue 11/26/2019
2330 Continuous 2359

Work scheduled by: ConEd

UPDATED by CONED 02/06/2019

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD
(Import)

MOSES__-ADIRNDCK_230_MA2

Mon 12/02/2019 to Fri 12/06/2019
0700 Continuous 1500

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

FWD
(Import)

MOSES__-ADIRNDCK_230_MA1

Mon 12/09/2019 to Fri 12/13/2019
0700 Continuous 1500

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

FWD
(Import)

MOSES__-ADIRNDCK_230_MA2

Mon 12/16/2019 to Mon 12/16/2019
0700 Continuous 1500

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

FWD
(Import)

MOSES__-ADIRNDCK_230_MA1

Tue 12/17/2019 to Fri 12/20/2019
0700 Continuous 1500

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

FWD
(Import)

LADENTWN-BUCHAN_S_345_Y88

Wed 01/15/2020 to Thu 02/13/2020
0001 Continuous 2359

Work scheduled by: ORU

11/05/2018

UPNY CONED **4800 MW**
Impacts Total Transfer Capability 900 MW
TTC with All Lines In Service 5700 MW

FWD
(Import)

DOLSONAV-ROCKTVRN_345_DART44

Mon 04/27/2020 to Sun 05/10/2020
0700 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 03/21/2019

CENTRAL EAST - VC **2720 MW**
Impacts Total Transfer Capability 255 MW
TTC with All Lines In Service 2975 MW

FWD
(Import)

NYISO TRANSFER LIMITATIONS

Saturday ,April 13, 2019 to Monday ,October 12, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

COOPERS_-DOLSONAV_345_CCDA42

Mon 05/11/2020 to Fri 05/29/2020
0700 Continuous 1730

UPDATED by NYPA 03/21/2019

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2720 MW**
Impacts Total Transfer Capability 255 MW
TTC with All Lines In Service 2975 MW

FRASANNX-COOPERS__345_UCC2-41

Mon 09/07/2020 to Fri 10/23/2020
0700 Continuous 1730

UPDATED by NYPA 03/01/2019

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

MARCY___-FRASANNX_345_UCC2-41

Mon 09/07/2020 to Fri 10/23/2020
0700 Continuous 1730

UPDATED by NYPA 03/01/2019

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

LADENTWN-BUCHAN_S_345_Y88

Tue 09/15/2020 to Wed 10/14/2020
0001 Continuous 2359

CANCELLED by ORU 04/10/2019

Work scheduled by: ORU

FWD
(Import)
UPNY CONED **4800 MW**
Impacts Total Transfer Capability 900 MW
TTC with All Lines In Service 5700 MW