

# NYISO TRANSFER LIMITATIONS

Sunday ,April 14, 2019 to Tuesday ,October 13, 2020

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

	FWD	REV
<hr/>		
<b>HUDSONP_-FARRAGUT_345_B3402</b>	(Import)	(Export)
Mon 01/15/2018 to Tue 12/31/2019 <b><u>EXTENDED</u> by CONED <u>02/06/2019</u></b>		
0001 Continuous 2359		
Work scheduled by: ConEd		
	SCH - PJ - NY	<b>2600 MW</b>
	Impacts Total Transfer Capability	0 MW
	TTC with All Lines In Service	2600 MW
		<b>1300 MW</b>
	Impacts Total Transfer Capability	0 MW
	TTC with All Lines In Service	2600 MW
		<b>250 MW</b>
<hr/>		
<b>HUDSONP_-FARRAGUT_345_B3402 &amp; MARION_-FARRAGUT_345_C3403</b>	(Import)	(Export)
Mon 01/15/2018 to Tue 12/31/2019		
0001 2359		
Work scheduled by:		
	SCH - PJ - NY	<b>2000 MW</b>
	Impacts Total Transfer Capability	600 MW
	TTC with All Lines In Service	2600 MW
		<b>1300 MW</b>
	Impacts Total Transfer Capability	0 MW
	TTC with All Lines In Service	2600 MW
		<b>250 MW</b>
<hr/>		
<b>MARION_-FARRAGUT_345_C3403</b>	(Import)	(Export)
Mon 01/15/2018 to Tue 12/31/2019 <b><u>EXTENDED</u> by CONED <u>02/06/2019</u></b>		
0001 Continuous 2359		
Work scheduled by: ConEd		
	SCH - PJ - NY	<b>2600 MW</b>
	Impacts Total Transfer Capability	0 MW
	TTC with All Lines In Service	2600 MW
		<b>1300 MW</b>
	Impacts Total Transfer Capability	0 MW
	TTC with All Lines In Service	2600 MW
		<b>250 MW</b>
<hr/>		
<b>STLAWRNC-MOSES_230_L33P</b>	(Import)	(Export)
Mon 04/30/2018 to Fri 12/31/2021 <b><u>EXT FORCE</u> by IESO <u>08/21/2018</u></b>		
0456 Continuous 2359		
Work scheduled by: IESO		
	SCH - OH - NY	<b>2250 MW</b>
	Impacts Total Transfer Capability	0 MW
	TTC with All Lines In Service	2250 MW
		<b>2000 MW</b>
	Impacts Total Transfer Capability	0 MW
	TTC with All Lines In Service	2250 MW
		<b>2000 MW</b>
<hr/>		
<b>DUNWODIE_345KV_6</b>	(Import)	
Wed 01/23/2019 to Thu 04/18/2019 <b><u>EXTENDED</u> by CE <u>03/28/2019</u></b>		
0001 Continuous 0300		
Work scheduled by: ConEd		
	SPR/DUN-SOUTH	<b>3800 MW</b>
	Impacts Total Transfer Capability	800 MW
	TTC with All Lines In Service	4600 MW
<hr/>		
<b>SCH-IMO-NYISO_LIMIT_1750</b>	(Import)	
Tue 02/26/2019 to Fri 12/31/2021 <b><u>UPDATED</u> by IESO <u>03/14/2019</u></b>		
0001 Continuous 2359		
Work scheduled by: IESO		
	SCH - OH - NY	<b>2050 MW</b>
	Impacts Total Transfer Capability	200 MW
	TTC with All Lines In Service	2250 MW
<hr/>		
<b>LONG_MTN-CRICKVLY_345_398</b>	(Import)	(Export)
Fri 03/01/2019 to Sun 05/19/2019 <b><u>UPDATED</u> by ISONE <u>03/27/2019</u></b>		
0001 Continuous 2359		
Work scheduled by: ConEd		
	SCH - NE - NY	<b>700 MW</b>
	Impacts Total Transfer Capability	700 MW
	TTC with All Lines In Service	1400 MW
		<b>1250 MW</b>
	Impacts Total Transfer Capability	700 MW
	TTC with All Lines In Service	1400 MW
		<b>550 MW</b>
	Impacts Total Transfer Capability	700 MW
	TTC with All Lines In Service	1400 MW
		<b>1800 MW</b>

# NYISO TRANSFER LIMITATIONS

Sunday ,April 14, 2019 to Tuesday ,October 13, 2020

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					FWD	REV
<b>LONG_MTN-CRICKVLY_345_398</b>					(Import)	(Export)
Fri 03/01/2019	to	Sun 05/19/2019	<u>UPDATED</u>	<u>by ISONE</u>	<u>03/27/2019</u>	
0001	Continuous	2359				
Work scheduled by: ConEd					SCH - NPX_1385	<b>100 MW</b>
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
<hr/>					FWD	
<b>SCH-NE-NYISO_LIMIT_400</b>					(Import)	
Fri 03/01/2019	to	Sun 05/19/2019	<u>UPDATED</u>	<u>by ISONE</u>	<u>03/27/2019</u>	
0001	Continuous	2359				
Work scheduled by: ConEd					SCH - NE - NY	<b>600 MW</b>
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	1400 MW
<hr/>						REV
<b>SCH-NYISO-IMO_LIMIT_1600</b>						(Export)
Sat 03/16/2019	to	Fri 12/31/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>03/14/2019</u>	
0001	Continuous	2359				
Work scheduled by: IESO					SCH - OH - NY	<b>1900 MW</b>
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	2000 MW
<hr/>						REV
<b>SCH-NYISO-NE_LIMIT_600</b>						(Export)
Mon 04/01/2019	to	Sun 05/19/2019	<u>UPDATED</u>	<u>by ISONE</u>	<u>03/27/2019</u>	
0001	Continuous	2359				
Work scheduled by: ConEd					SCH - NE - NY	<b>800 MW</b>
					Impacts Total Transfer Capability	1000 MW
					TTC with All Lines In Service	1800 MW
<hr/>						FWD
<b>VOLNEY__-MARCY___345_19</b>					(Import)	
Mon 04/01/2019	to	Wed 04/10/2019				
0500	Continuous	1730				
Work scheduled by: NYPA					CENTRAL EAST - VC	<b>2825 MW</b>
					Impacts Total Transfer Capability	150 MW
					TTC with All Lines In Service	2975 MW
<hr/>						FWD
<b>VOLNEY__-MARCY___345_19</b>					(Import)	
Mon 04/01/2019	to	Wed 04/10/2019				
0500	Continuous	1730				
Work scheduled by: NYPA					OSWEGO EXPORT	<b>4900 MW</b>
					Impacts Total Transfer Capability	350 MW
					TTC with All Lines In Service	5250 MW
<hr/>						FWD
<b>SCH-IMO-NYISO_LIMIT_1000</b>					(Import)	
Mon 04/01/2019	to	Wed 04/10/2019	<u>UPDATED</u>	<u>by NYISO</u>	<u>03/11/2019</u>	
0700	Continuous	0830				
Work scheduled by: NGrid					SCH - OH - NY	<b>1300 MW</b>
					Impacts Total Transfer Capability	950 MW
					TTC with All Lines In Service	2250 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 14, 2019 to Tuesday ,October 13, 2020

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					FWD	REV
<b>LINDN_CG-LNDVFT___345_V-3022</b>					(Import)	(Export)
Sun 04/07/2019	to	Sat 04/13/2019	<b>by PJM</b>	<b>04/14/2019</b>	<b>0 MW</b>	<b>0 MW</b>
1400	Continuous	1800			SCH - PJM_VFT	
Work scheduled by: PJM					Impacts Total Transfer Capability	315 MW
					TTC with All Lines In Service	315 MW
<hr/>					FWD	
<b>PLSNTVLY_345KV_RN5 &amp; PLSNTVLY_345KV_RN4</b>					(Import)	
Mon 04/08/2019	to	Sat 04/13/2019			UPNY CONED	<b>3800 MW</b>
0001		0300			Impacts Total Transfer Capability	1900 MW
Work scheduled by:					TTC with All Lines In Service	5700 MW
<hr/>					FWD	REV
<b>SCH-IMO_NY_NIAG_CB_3122_W/BB</b>					(Import)	(Export)
Mon 04/08/2019	to	Fri 04/12/2019			SCH - OH - NY	<b>2000 MW</b>
0500	Continuous	1700			Impacts Total Transfer Capability	250 MW
Work scheduled by: NYPA					TTC with All Lines In Service	2250 MW
<hr/>					FWD	
<b>NEPTUNE_-DUFFYAVE_345_NEPTUNE</b>					(Import)	
Mon 04/08/2019	to	Fri 04/12/2019	<b>UPDATED</b>	<b>by PJM</b>	<b>04/14/2019</b>	<b>0 MW</b>
0600	Continuous	2359			SCH - PJM_NEPTUNE	
Work scheduled by: LI					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	660 MW
<hr/>					FWD	
<b>NEWBRDGE-DUFFYAVE_345_501</b>					(Import)	
Mon 04/08/2019	to	Fri 04/12/2019	<b>UPDATED</b>	<b>by PJM</b>	<b>04/14/2019</b>	<b>0 MW</b>
0600	Continuous	2359			SCH - PJM_NEPTUNE	
Work scheduled by: LI					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	660 MW
<hr/>					FWD	
<b>NEWBRDGE_345_138_BK_1</b>					(Import)	
Mon 04/08/2019	to	Fri 04/12/2019	<b>UPDATED</b>	<b>by PJM</b>	<b>04/14/2019</b>	<b>375 MW</b>
0600	Continuous	2359			SCH - PJM_NEPTUNE	
Work scheduled by: LI					Impacts Total Transfer Capability	285 MW
					TTC with All Lines In Service	660 MW
<hr/>					FWD	
<b>NEWBRDGE_345_138_BK_2</b>					(Import)	
Mon 04/08/2019	to	Sat 04/13/2019	<b>UPDATED</b>	<b>by PJM</b>	<b>04/14/2019</b>	<b>375 MW</b>
0600	Continuous	1800			SCH - PJM_NEPTUNE	
Work scheduled by: LI					Impacts Total Transfer Capability	285 MW
					TTC with All Lines In Service	660 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 14, 2019 to Tuesday ,October 13, 2020

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>S.RIPLEY-DUNKIRK__230_68</b>					FWD	REV
Mon 04/08/2019	to	Mon 04/15/2019	<u>UPDATED</u>	<u>by PJM</u>	<u>02/11/2019</u>	(Import) (Export)
0800	Continuous	2000				<b>2600 MW 1300 MW</b>
Work scheduled by: PJM					SCH - PJ - NY	0 MW 250 MW
					Impacts Total Transfer Capability	2600 MW 1550 MW
					TTC with All Lines In Service	
<b>COOPERS_-MIDDLETP_345_CCRT34</b>					FWD	
Wed 04/10/2019	to	Wed 04/10/2019				(Import)
0700	Continuous	1600				<b>2720 MW</b>
Work scheduled by: ORU					CENTRAL EAST - VC	255 MW
					Impacts Total Transfer Capability	2975 MW
					TTC with All Lines In Service	
<b>MARCY___345KV_CSC</b>					FWD	
Thu 04/11/2019	to	Wed 04/17/2019				(Import)
0500	Continuous	1730				<b>2925 MW</b>
Work scheduled by: NYPA					CENTRAL EAST - VC	50 MW
					Impacts Total Transfer Capability	2975 MW
					TTC with All Lines In Service	
<b>MARCY_-EDIC_____345_UE1-7</b>					FWD	
Thu 04/11/2019	to	Sat 04/20/2019				(Import)
0500	Continuous	1730				<b>5250 MW</b>
Work scheduled by: NYPA					OSWEGO EXPORT	0 MW
					Impacts Total Transfer Capability	5250 MW
					TTC with All Lines In Service	
<b>SCH-IMO-NYISO_LIMIT_300</b>					FWD	
Sat 04/13/2019	to	Sat 04/13/2019	<u>UPDATED</u>	<u>by NYISO</u>	<u>04/05/2019</u>	(Import)
0001	Continuous	2359				<b>600 MW</b>
Work scheduled by: NYISO					SCH - OH - NY	1650 MW
					Impacts Total Transfer Capability	2250 MW
					TTC with All Lines In Service	
<b>SCH-NYISO-IMO_LIMIT_500</b>						REV
Sat 04/13/2019	to	Sat 04/13/2019	<u>UPDATED</u>	<u>by NYISO</u>	<u>04/05/2019</u>	(Export)
0001	Continuous	2359				<b>800 MW</b>
Work scheduled by: NYISO					SCH - OH - NY	1200 MW
					Impacts Total Transfer Capability	2000 MW
					TTC with All Lines In Service	
<b>SCH-NYISO-PJM_LIMIT_200</b>						REV
Sat 04/13/2019	to	Sat 04/13/2019	<u>UPDATED</u>	<u>by NYISO</u>	<u>04/05/2019</u>	(Export)
0001	Continuous	2359				<b>500 MW</b>
Work scheduled by: NYISO					SCH - PJ - NY	1050 MW
					Impacts Total Transfer Capability	1550 MW
					TTC with All Lines In Service	

# NYISO TRANSFER LIMITATIONS

Sunday ,April 14, 2019 to Tuesday ,October 13, 2020

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>DUNWODIE-SHORE_RD_345_Y50</b>						FWD
Sat 04/13/2019	to	Mon 04/15/2019	<u>UPDATED</u>	<u>by CE</u>	<u>04/13/2019</u>	(Import)
0301	Continuous	1830				<b>800 MW</b>
Work scheduled by: ConEd						CONED - LIPA
						Impacts Total Transfer Capability 700 MW
						TTC with All Lines In Service 1500 MW
<b>DUNWODIE_345KV_4</b>						FWD
Sat 04/13/2019	to	Mon 04/15/2019	<u>UPDATED</u>	<u>by CE</u>	<u>04/13/2019</u>	(Import)
0301	Continuous	1830				<b>3800 MW</b>
Work scheduled by: ConEd						SPR/DUN-SOUTH
						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
<b>DUNWODIE_345KV_8</b>						FWD
Sat 04/13/2019	to	Mon 04/15/2019	<u>UPDATED</u>	<u>by CE</u>	<u>04/13/2019</u>	(Import)
0301	Continuous	1830				<b>3800 MW</b>
Work scheduled by: ConEd						SPR/DUN-SOUTH
						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
<b>PLSNTVLE-DUNWODIE_345_W90</b>						FWD
Sat 04/13/2019	to	Mon 04/15/2019	<u>UPDATED</u>	<u>by CE</u>	<u>04/13/2019</u>	(Import)
0301	Continuous	1830				<b>4000 MW</b>
Work scheduled by: ConEd						UPNY CONED
						Impacts Total Transfer Capability 1700 MW
						TTC with All Lines In Service 5700 MW
<b>CHAT_DC_GC1</b>						FWD
Sat 04/13/2019	to	Sat 04/13/2019				(Import)
0700	Continuous	1700				<b>2850 MW</b>
Work scheduled by: HQ						MOSES SOUTH
						Impacts Total Transfer Capability 300 MW
						TTC with All Lines In Service 3150 MW
<b>CHAT_DC_GC1</b>						REV
Sat 04/13/2019	to	Sat 04/13/2019				(Export)
0700	Continuous	1700				<b>500 MW</b>
Work scheduled by: HQ						SCH - HQ - NY
						Impacts Total Transfer Capability 500 MW
						TTC with All Lines In Service 1000 MW
<b>SCH-HQ-NYISO_LIMIT_1150</b>						FWD
Sat 04/13/2019	to	Sat 04/13/2019				(Import)
0700	Continuous	1700				<b>1150 MW</b>
Work scheduled by: HQ						SCH - HQ - NY
						Impacts Total Transfer Capability 350 MW
						TTC with All Lines In Service 1500 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 14, 2019 to Tuesday ,October 13, 2020

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						
<b>NINEMILE-CLAY</b> _____ <b>345_8</b>					FWD	
Sun 04/14/2019	to	Sun 04/14/2019	<b><u>CANCELLED</u></b>	<b><u>by NGrid</u></b>	<b><u>04/14/2019</u></b>	(Import)
0200	Continuous	0230				OSWEGO EXPORT <b>5150 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability 100 MW
						TTC with All Lines In Service 5250 MW
<hr/>						
<b>SPRNBRK</b> _____ <b>345KV_RNS5</b>					FWD	
Sun 04/14/2019	to	Sun 04/14/2019	<b><u>FORCED</u></b>	<b><u>by CE</u></b>	<b><u>04/14/2019</u></b>	(Import)
1000	Continuous	1030				SPR/DUN-SOUTH <b>3200 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 1400 MW
						TTC with All Lines In Service 4600 MW
<hr/>						
<b>SPRNBRK</b> _____ <b>-W49TH_ST_345_M51</b>					FWD	
Sun 04/14/2019	to	Sat 04/20/2019	<b><u>FORCED</u></b>	<b><u>by CE</u></b>	<b><u>04/14/2019</u></b>	(Import)
1000	Continuous	2200				SPR/DUN-SOUTH <b>3200 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 1400 MW
						TTC with All Lines In Service 4600 MW
<hr/>						
<b>SCH-NYISO-HQ_LIMIT_800</b>						REV
Mon 04/15/2019	to	Fri 05/24/2019				(Export)
0400	Continuous	1700				SCH - HQ - NY <b>800 MW</b>
Work scheduled by: HQ						Impacts Total Transfer Capability 200 MW
						TTC with All Lines In Service 1000 MW
<hr/>						
<b>SCRIBA</b> _____ <b>-VOLNEY</b> _____ <b>345_20</b>					FWD	
Mon 04/15/2019	to	Tue 04/16/2019				(Import)
0600	Continuous	1800				OSWEGO EXPORT <b>5250 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability 0 MW
						TTC with All Lines In Service 5250 MW
<hr/>						
<b>PORTER</b> _____ <b>-ROTTRDAM_230_30</b>					FWD	
Mon 04/15/2019	to	Mon 04/15/2019				(Import)
0700	Daily(No Weekends)	1630				CENTRAL EAST - VC <b>2805 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability 170 MW
						TTC with All Lines In Service 2975 MW
<hr/>						
<b>DUNWODIE</b> _____ <b>345KV_7</b>					FWD	
Thu 04/18/2019	to	Thu 04/18/2019	<b><u>CANCELLED</u></b>	<b><u>by ConEd</u></b>	<b><u>04/11/2019</u></b>	(Import)
0301	Continuous	0330				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 14, 2019 to Tuesday ,October 13, 2020

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					FWD
DUNWODIE_345KV_8					(Import)
Thu 04/18/2019	to	Thu 04/18/2019	<b><u>CANCELLED</u></b>	<b><u>by ConEd</u></b>	<b><u>04/11/2019</u></b>
0301	Continuous	0330			
Work scheduled by: ConEd					3800 MW
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
<hr/>					FWD
DUNWODIE-MOTTHAVN_345_72					(Import)
Thu 04/18/2019	to	Thu 04/25/2019	<b><u>CANCELLED</u></b>	<b><u>by ConEd</u></b>	<b><u>04/11/2019</u></b>
0301	Continuous	0300			
Work scheduled by: ConEd					3800 MW
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
<hr/>					FWD
SPRNBK__345KV_RNS5					(Import)
Fri 04/19/2019	to	Fri 04/19/2019	<b><u>FORCED</u></b>	<b><u>by CE</u></b>	<b><u>04/14/2019</u></b>
0001	Continuous	0030			
Work scheduled by: ConEd					3200 MW
					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW
<hr/>					FWD
EASTVIEW-SPRNBK__345_W79					(Import)
Fri 04/19/2019	to	Fri 04/19/2019			
0200	Continuous	2230			
Work scheduled by: ConEd					4350 MW
					Impacts Total Transfer Capability 1350 MW
					TTC with All Lines In Service 5700 MW
<hr/>					FWD
BUCHAN_N-EASTVIEW_345_W93					(Import)
Fri 04/19/2019	to	Mon 04/22/2019			
0200	Continuous	0300			
Work scheduled by: ConEd					4350 MW
					Impacts Total Transfer Capability 1350 MW
					TTC with All Lines In Service 5700 MW
<hr/>					FWD
SPRNBK__345KV_RNS5					(Import)
Fri 04/19/2019	to	Fri 04/19/2019	<b><u>FORCED</u></b>	<b><u>by CE</u></b>	<b><u>04/14/2019</u></b>
1500	Continuous	1530			
Work scheduled by: ConEd					3200 MW
					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW
<hr/>					FWD
SCH-IMO-NYISO_LIMIT_300					(Import)
Sat 04/20/2019	to	Sat 04/20/2019	<b><u>UPDATED</u></b>	<b><u>by NYISO</u></b>	<b><u>04/05/2019</u></b>
0001	Continuous	2359			
Work scheduled by: NYISO					600 MW
					Impacts Total Transfer Capability 1650 MW
					TTC with All Lines In Service 2250 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 14, 2019 to Tuesday ,October 13, 2020

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SCH-NYISO-IMO\_LIMIT\_500**

Sat 04/20/2019 to Sat 04/20/2019  
0001 Continuous 2359

**UPDATED by NYISO 04/05/2019**

Work scheduled by: NYISO

SCH - OH - NY  
Impacts Total Transfer Capability 1200 MW  
TTC with All Lines In Service 2000 MW

REV  
(Export)

**SCH-NYISO-PJM\_LIMIT\_200**

Sat 04/20/2019 to Sat 04/20/2019  
0001 Continuous 2359

**UPDATED by NYISO 04/05/2019**

Work scheduled by: NYISO

SCH - PJ - NY  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 1550 MW

REV  
(Export)

**SPRNBK\_\_345KV\_RNS5**

Sat 04/20/2019 to Sat 04/20/2019  
2130 Continuous 2200

**FORCED by CE 04/14/2019**

Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

FWD  
(Import)

**EASTVIEW-SPRNBK\_\_345\_W79**

Mon 04/22/2019 to Mon 04/22/2019  
0230 Continuous 0300

Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability 1350 MW  
TTC with All Lines In Service 5700 MW

FWD  
(Import)

**SCH-NYISO-IMO\_NIAGARA\_CB\_3002**

Mon 04/22/2019 to Mon 04/22/2019  
0500 Continuous 1700

Work scheduled by: NYPA

SCH - OH - NY  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 2250 MW

FWD REV  
(Import) (Export)

**EDIC\_\_-FRASER\_\_345\_EF24-40**

Mon 04/22/2019 to Fri 04/26/2019  
0500 Continuous 1730

Work scheduled by: NYPA

CENTRAL EAST - VC  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

FWD  
(Import)

**MARCY\_\_765\_345\_AT2**

Mon 04/22/2019 to Fri 04/26/2019  
0500 Continuous 1730

Work scheduled by: NYPA

MOSES SOUTH  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

FWD  
(Import)

**ARR: 19**



# NYISO TRANSFER LIMITATIONS

Sunday ,April 14, 2019 to Tuesday ,October 13, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>EFISHKIL-WOOD_ST__345_F38</b>				FWD
Thu 04/25/2019	to	Thu 04/25/2019		(Import)
0001	Continuous	0030	UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 1700 MW
				TTC with All Lines In Service 5700 MW
<b>PLSNTVLE-DUNWODIE_345_W89</b>				FWD
Thu 04/25/2019	to	Thu 04/25/2019		(Import)
0001	Continuous	0030	UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 1700 MW
				TTC with All Lines In Service 5700 MW
<b>WOOD_ST_-PLSNTVLE_345_Y86</b>				FWD
Thu 04/25/2019	to	Sun 04/28/2019		(Import)
0001	Continuous	0259	UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 1700 MW
				TTC with All Lines In Service 5700 MW
<b>DUNWODIE_345KV_7</b>				FWD
Thu 04/25/2019	to	Thu 04/25/2019	<b>CANCELLED by ConEd 04/11/2019</b>	(Import)
0230	Continuous	0300	SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
<b>DUNWODIE_345KV_8</b>				FWD
Thu 04/25/2019	to	Thu 04/25/2019	<b>CANCELLED by ConEd 04/11/2019</b>	(Import)
0230	Continuous	0300	SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
<b>FRASANX-COOPERS__345_UCC2-41</b>				FWD
Sat 04/27/2019	to	Fri 05/03/2019	<b>UPDATED by NYPA 08/22/2018</b>	(Import)
0500	Continuous	1730	CENTRAL EAST - VC	<b>2500 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability 475 MW
				TTC with All Lines In Service 2975 MW
<b>MARCY__-FRASANX_345_UCC2-41</b>				FWD
Sat 04/27/2019	to	Fri 05/03/2019	<b>UPDATED by NYPA 08/22/2018</b>	(Import)
0500	Continuous	1730	CENTRAL EAST - VC	<b>2500 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability 475 MW
				TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 14, 2019 to Tuesday ,October 13, 2020

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**EFISHKIL-WOOD\_ST\_345\_F38**

Sun 04/28/2019 to Sun 04/28/2019  
 0230 Continuous 0259  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

**PLSNTVLE-DUNWODIE\_345\_W89**

Sun 04/28/2019 to Sun 04/28/2019  
 0230 Continuous 0259  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

**KINTIGH\_-ROCHESTR\_345\_SRI-39**

Mon 04/29/2019 to Thu 05/02/2019 **UPDATED by NYSEG 11/08/2018**  
 0600 Continuous 1700  
 Work scheduled by: NYPA

FWD  
 (Import)  
 DYSINGER EAST **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

**MOSES\_-ADIRNDCK\_230\_MA1**

Mon 04/29/2019 to Fri 05/03/2019 **CANCELLED by NYPA 04/12/2019**  
 0700 Continuous 1500  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

**SCH-HQ-NYISO\_LIMIT\_1400**

Mon 04/29/2019 to Fri 05/03/2019  
 0700 Continuous 1730  
 Work scheduled by: HQ

FWD  
 (Import)  
 SCH - HQ - NY **1400 MW**  
 Impacts Total Transfer Capability 100 MW  
 TTC with All Lines In Service 1500 MW

**CHAT\_DC\_GC1**

Mon 04/29/2019 to Fri 05/24/2019  
 0700 Continuous 1700  
 Work scheduled by: HQ

FWD  
 (Import)  
 MOSES SOUTH **2850 MW**  
 Impacts Total Transfer Capability 300 MW  
 TTC with All Lines In Service 3150 MW

**CHAT\_DC\_GC1**

Mon 04/29/2019 to Fri 05/24/2019  
 0700 Continuous 1700  
 Work scheduled by: HQ

REV  
 (Export)  
 SCH - HQ - NY **500 MW**  
 Impacts Total Transfer Capability 500 MW  
 TTC with All Lines In Service 1000 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 14, 2019 to Tuesday ,October 13, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>DUNWODIE_345KV_3</b>			FWD
Wed 05/01/2019	to	Wed 05/01/2019	(Import)
0001	Continuous	0030	
Work scheduled by: ConEd			
			SPR/DUN-SOUTH <b>3800 MW</b>
			Impacts Total Transfer Capability 800 MW
			TTC with All Lines In Service 4600 MW
<b>DUNWODIE_345KV_4</b>			FWD
Wed 05/01/2019	to	Wed 05/01/2019	(Import)
0001	Continuous	0030	
Work scheduled by: ConEd			
			SPR/DUN-SOUTH <b>3800 MW</b>
			Impacts Total Transfer Capability 800 MW
			TTC with All Lines In Service 4600 MW
<b>PLSNTVLE-DUNWODIE_345_W89</b>			FWD
Wed 05/01/2019	to	Thu 05/02/2019	(Import)
0001	Continuous	0300	
Work scheduled by: ConEd			
			UPNY CONED <b>4000 MW</b>
			Impacts Total Transfer Capability 1700 MW
			TTC with All Lines In Service 5700 MW
<b>EGRDNCTY_345_138_AT2</b>			FWD
Wed 05/01/2019	to	Wed 05/15/2019	(Import)
0001	Continuous	2359	
Work scheduled by: LI			
			CONED - LIPA <b>1250 MW</b>
			Impacts Total Transfer Capability 250 MW
			TTC with All Lines In Service 1500 MW
<b>HUDSONTP-W49TH_ST_345_Y56</b>			FWD
Wed 05/01/2019	to	Tue 05/07/2019	(Import)
0600	Continuous	1800	
Work scheduled by: PJM			
			SCH - PJM_HTP <b>0 MW</b>
			Impacts Total Transfer Capability 660 MW
			TTC with All Lines In Service 660 MW
<b>DUNWODIE_345KV_3</b>			FWD
Thu 05/02/2019	to	Thu 05/02/2019	(Import)
0230	Continuous	0300	
Work scheduled by: ConEd			
			SPR/DUN-SOUTH <b>3800 MW</b>
			Impacts Total Transfer Capability 800 MW
			TTC with All Lines In Service 4600 MW
<b>DUNWODIE_345KV_4</b>			FWD
Thu 05/02/2019	to	Thu 05/02/2019	(Import)
0230	Continuous	0300	
Work scheduled by: ConEd			
			SPR/DUN-SOUTH <b>3800 MW</b>
			Impacts Total Transfer Capability 800 MW
			TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 14, 2019 to Tuesday ,October 13, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**STONYRDG-HILLSIDE\_230\_72**

Fri 05/03/2019 to Fri 05/03/2019  
0800 Continuous 1530

Work scheduled by: NYSEG

FWD  
(Import)  
DYSINGER EAST **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

**CHATGUAY-MASSENA\_765\_7040**

Sat 05/04/2019 to Sat 05/04/2019  
0530 Continuous 1930

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **1550 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 3150 MW

**CHATGUAY-MASSENA\_765\_7040**

Sat 05/04/2019 to Sat 05/04/2019  
0530 Continuous 1930

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

**MASSENA -MARCY\_765\_MSU1**

Sat 05/04/2019 to Sat 05/04/2019  
0530 Continuous 1930

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2265 MW**  
Impacts Total Transfer Capability 710 MW  
TTC with All Lines In Service 2975 MW

**MASSENA -MARCY\_765\_MSU1**

Sat 05/04/2019 to Sat 05/04/2019  
0530 Continuous 1930

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **500 MW**  
Impacts Total Transfer Capability 2650 MW  
TTC with All Lines In Service 3150 MW

**MASSENA -MARCY\_765\_MSU1**

Sat 05/04/2019 to Sat 05/04/2019  
0530 Continuous 1930

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	<b>475 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	1025 MW	0 MW
TTC with All Lines In Service	1500 MW	1000 MW

**MASSENA -MARCY\_765\_MSU1 & CHATGUAY-MASSENA\_765\_7040**

Sat 05/04/2019 to Sat 05/04/2019  
0530 Continuous 1930

Work scheduled by:

FWD  
(Import)  
MOSES SOUTH **500 MW**  
Impacts Total Transfer Capability 2650 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 14, 2019 to Tuesday ,October 13, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>S. PERRY - MEYER 230_87</b>					FWD	
Mon 05/06/2019	to	Mon 05/06/2019			(Import)	
0600	Continuous	1600		DYSINGER EAST		<b>2850 MW</b>
Work scheduled by: NYSEG					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW
<b>SHOR_NPX-SHOREHAM_138_CSC</b>					FWD	REV
Mon 05/06/2019	to	Fri 05/10/2019			(Import)	(Export)
0700	Continuous	1800		SCH - NPX_CSC		<b>0 MW 0 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability	330 MW 330 MW
					TTC with All Lines In Service	330 MW 330 MW
<b>ROSETON - ROCKTVRN_345_311</b>					FWD	
Mon 05/06/2019	to	Sat 06/08/2019	<u>EXTENDED</u>	<u>by CHGE</u>	<u>03/26/2019</u>	
0800	Continuous	1600				
Work scheduled by: CHGE					UPNY CONED	<b>4400 MW</b>
					Impacts Total Transfer Capability	1300 MW
					TTC with All Lines In Service	5700 MW
<b>SPRNBRK_345KV_RNS4</b>					FWD	
Tue 05/07/2019	to	Tue 05/07/2019			(Import)	
0001	Continuous	2359		SPR/DUN-SOUTH		<b>3200 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
<b>EASTVIEW-SPRNBRK_345_W65</b>					FWD	
Tue 05/07/2019	to	Wed 05/08/2019			(Import)	
0001	Continuous	0200		UPNY CONED		<b>4350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	1350 MW
					TTC with All Lines In Service	5700 MW
<b>MILLWOOD-EASTVIEW_345_W82</b>					FWD	
Tue 05/07/2019	to	Wed 05/08/2019			(Import)	
0001	Continuous	0200		UPNY CONED		<b>4350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	1350 MW
					TTC with All Lines In Service	5700 MW
<b>EGRDNCTY_345_138_AT1</b>					FWD	
Wed 05/08/2019	to	Fri 05/10/2019			(Import)	
0300	Continuous	2200		CONED - LIPA		<b>1250 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	250 MW
					TTC with All Lines In Service	1500 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 14, 2019 to Tuesday ,October 13, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SPRNBK_-EGRDNCTR_345_Y49</b>			FWD	
Wed 05/08/2019	to	Fri 05/10/2019	(Import)	
0300	Continuous	2200	CONED - LIPA	<b>775 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	725 MW
			TTC with All Lines In Service	1500 MW
<b>EASTVIEW-SPRNBK_345_W64</b>			FWD	
Sat 05/11/2019	to	Sat 05/11/2019	(Import)	
0001	Continuous	0030	UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	1350 MW
			TTC with All Lines In Service	5700 MW
<b>SPRNBK_345KV_RNS5</b>			FWD	
Sat 05/11/2019	to	Sat 05/11/2019	(Import)	
0001	Continuous	0030	SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	1400 MW
			TTC with All Lines In Service	4600 MW
<b>MILLWOOD-EASTVIEW_345_W99</b>			FWD	
Sat 05/11/2019	to	Tue 05/14/2019	(Import)	
0001	Continuous	2230	UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	1350 MW
			TTC with All Lines In Service	5700 MW
<b>CHATGUAY-MASSENA_765_7040</b>			FWD	
Sat 05/11/2019	to	Sat 05/11/2019	(Import)	
0530	Continuous	1930	MOSES SOUTH	<b>1550 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	1600 MW
			TTC with All Lines In Service	3150 MW
<b>CHATGUAY-MASSENA_765_7040</b>			FWD	REV
Sat 05/11/2019	to	Sat 05/11/2019	(Import)	(Export)
0530	Continuous	1930	SCH - HQ - NY	<b>0 MW 0 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	1500 MW 1000 MW
			TTC with All Lines In Service	1500 MW 1000 MW
<b>MASSENA_-MARCY_765_MSU1</b>			FWD	
Sat 05/11/2019	to	Sat 05/11/2019	(Import)	
0530	Continuous	1930	CENTRAL EAST - VC	<b>2265 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	710 MW
			TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 14, 2019 to Tuesday ,October 13, 2020

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p><b>MASSENA -MARCY 765_MSU1</b></p> <p>Sat 05/11/2019 to Sat 05/11/2019 0530 Continuous 1930</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import)</p> <p>MOSES SOUTH <b>500 MW</b></p> <p>Impacts Total Transfer Capability 2650 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p><b>MASSENA -MARCY 765_MSU1</b></p> <p>Sat 05/11/2019 to Sat 05/11/2019 0530 Continuous 1930</p> <p>Work scheduled by: NYPA</p>	<p>FWD REV (Import) (Export)</p> <p>SCH - HQ - NY <b>475 MW 1000 MW</b></p> <p>Impacts Total Transfer Capability 1025 MW 0 MW</p> <p>TTC with All Lines In Service 1500 MW 1000 MW</p>
<p><b>MASSENA -MARCY 765_MSU1 &amp; CHATGUAY-MASSENA 765_7040</b></p> <p>Sat 05/11/2019 to Sat 05/11/2019 0530 1930</p> <p>Work scheduled by:</p>	<p>FWD (Import)</p> <p>MOSES SOUTH <b>500 MW</b></p> <p>Impacts Total Transfer Capability 2650 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p><b>NIAGARA -ROCHESTR 345_NR2</b></p> <p>Mon 05/13/2019 to Fri 05/17/2019 <b>UPDATED by NYPA 04/09/2019</b> 0500 Continuous 1700</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import)</p> <p>DYSINGER EAST <b>1400 MW</b></p> <p>Impacts Total Transfer Capability 1750 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p><b>EASTVIEW-SPRNBK 345_W64</b></p> <p>Tue 05/14/2019 to Tue 05/14/2019 2200 Continuous 2230</p> <p>Work scheduled by: ConEd</p>	<p>FWD (Import)</p> <p>UPNY CONED <b>4350 MW</b></p> <p>Impacts Total Transfer Capability 1350 MW</p> <p>TTC with All Lines In Service 5700 MW</p>
<p><b>SPRNBK 345KV_RNS5</b></p> <p>Tue 05/14/2019 to Tue 05/14/2019 2200 Continuous 2230</p> <p>Work scheduled by: ConEd</p>	<p>FWD (Import)</p> <p>SPR/DUN-SOUTH <b>3200 MW</b></p> <p>Impacts Total Transfer Capability 1400 MW</p> <p>TTC with All Lines In Service 4600 MW</p>
<p><b>CHATGUAY-MASSENA 765_7040</b></p> <p>Sat 05/18/2019 to Sat 05/18/2019 0530 Continuous 1930</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import)</p> <p>MOSES SOUTH <b>1550 MW</b></p> <p>Impacts Total Transfer Capability 1600 MW</p> <p>TTC with All Lines In Service 3150 MW</p>

# NYISO TRANSFER LIMITATIONS

Sunday ,April 14, 2019 to Tuesday ,October 13, 2020

Seasonal Limits

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**CHATGUAY-MASSENA\_\_765\_7040**

Sat 05/18/2019 to Sat 05/18/2019  
0530 Continuous 1930

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

**MASSENA -MARCY\_\_\_\_765\_MSU1**

Sat 05/18/2019 to Sat 05/18/2019  
0530 Continuous 1930

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	<b>2265 MW</b>
Impacts Total Transfer Capability	710 MW
TTC with All Lines In Service	2975 MW

**MASSENA -MARCY\_\_\_\_765\_MSU1**

Sat 05/18/2019 to Sat 05/18/2019  
0530 Continuous 1930

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>500 MW</b>
Impacts Total Transfer Capability	2650 MW
TTC with All Lines In Service	3150 MW

**MASSENA -MARCY\_\_\_\_765\_MSU1**

Sat 05/18/2019 to Sat 05/18/2019  
0530 Continuous 1930

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	<b>475 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	1025 MW	0 MW
TTC with All Lines In Service	1500 MW	1000 MW

**MASSENA -MARCY\_\_\_\_765\_MSU1 & CHATGUAY-MASSENA\_\_765\_7040**

Sat 05/18/2019 to Sat 05/18/2019  
0530 Continuous 1930

Work scheduled by:

	FWD
	(Import)
MOSES SOUTH	<b>500 MW</b>
Impacts Total Transfer Capability	2650 MW
TTC with All Lines In Service	3150 MW

**SCH-NE-NYISO\_LIMIT\_500**

Mon 05/20/2019 to Thu 05/23/2019  
0600 Continuous 2000

Work scheduled by: ISONE

	FWD
	(Import)
SCH - NE - NY	<b>700 MW</b>
Impacts Total Transfer Capability	700 MW
TTC with All Lines In Service	1400 MW

**SCH-NYISO-NE\_LIMIT\_1200**

Mon 05/20/2019 to Thu 05/23/2019  
0600 Continuous 2000

Work scheduled by: ISONE

		REV
		(Export)
SCH - NE - NY		<b>1400 MW</b>
Impacts Total Transfer Capability		200 MW
TTC with All Lines In Service		1600 MW



# NYISO TRANSFER LIMITATIONS

Sunday ,April 14, 2019 to Tuesday ,October 13, 2020

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**ADIRNDCK-PORTER** 230\_12

Mon 05/20/2019 to Fri 05/24/2019  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
**MOSES SOUTH** **2100 MW**  
 Impacts Total Transfer Capability 1050 MW  
 TTC with All Lines In Service 3150 MW

-----  
**PANNELL -CLAY** 345\_1

Mon 05/20/2019 to Fri 05/24/2019  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
**WEST CENTRAL** **1300 MW**  
 Impacts Total Transfer Capability 950 MW  
 TTC with All Lines In Service 2250 MW

-----  
**ROSETON -EFISHKIL** 345\_RFK305

Thu 05/23/2019 to Thu 05/23/2019  
 0800 Daily 1600  
 Work scheduled by: CHGE

FWD  
 (Import)  
**UPNY CONED** **4800 MW**  
 Impacts Total Transfer Capability 900 MW  
 TTC with All Lines In Service 5700 MW

-----  
**SCRIBA -VOLNEY** 345\_20

Tue 05/28/2019 to Tue 05/28/2019  
 0600 Continuous 1800  
 Work scheduled by: NGrid

FWD  
 (Import)  
**OSWEGO EXPORT** **5250 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 5250 MW

-----  
**PANNELL -CLAY** 345\_2

Mon 06/03/2019 to Fri 06/07/2019  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
**WEST CENTRAL** **1300 MW**  
 Impacts Total Transfer Capability 950 MW  
 TTC with All Lines In Service 2250 MW

-----  
**NIAGARA -KINTIGH** 345\_NS1-38

Mon 06/03/2019 to Fri 06/07/2019  
 0800 Continuous 1430  
 Work scheduled by: NYSEG

FWD  
 (Import)  
**DYSINGER EAST** **1400 MW**  
 Impacts Total Transfer Capability 1750 MW  
 TTC with All Lines In Service 3150 MW

-----  
**FRASER** 345\_FRASER SVC

Mon 06/03/2019 to Fri 06/07/2019  
 0800 Continuous 1700  
 Work scheduled by: NYSEG

FWD  
 (Import)  
**CENTRAL EAST - VC** **2935 MW**  
 Impacts Total Transfer Capability 40 MW  
 TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 14, 2019 to Tuesday ,October 13, 2020

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
<p><b>NIAGARA_-KINTIGH_345_NS1-38</b></p> <p>Mon 06/10/2019 to Fri 06/14/2019 0800 Continuous 1430</p> <p>Work scheduled by: NYSEG</p>	<p style="text-align: right;">FWD (Import)</p> <p>DYSINGER EAST <b>1400 MW</b></p> <p>Impacts Total Transfer Capability 1750 MW</p> <p>TTC with All Lines In Service 3150 MW</p>		
<hr/>			
<p><b>MOSES_-ADIRNDCK_230_MA2</b></p> <p>Mon 06/24/2019 to Fri 06/28/2019 0700 Continuous 1500</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH <b>2100 MW</b></p> <p>Impacts Total Transfer Capability 1050 MW</p> <p>TTC with All Lines In Service 3150 MW</p>		
<hr/>			
<p><b>MOSES_-ADIRNDCK_230_MA2</b></p> <p>Mon 07/08/2019 to Fri 07/12/2019 0700 Continuous 1500</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH <b>2100 MW</b></p> <p>Impacts Total Transfer Capability 1050 MW</p> <p>TTC with All Lines In Service 3150 MW</p>		
<hr/>			
<p><b>ADIRNDCK-CHASLAKE_230_13</b></p> <p>Mon 07/08/2019 to Fri 07/12/2019 0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH <b>2100 MW</b></p> <p>Impacts Total Transfer Capability 1050 MW</p> <p>TTC with All Lines In Service 3150 MW</p>		
<hr/>			
<p><b>MARCY_765_345_AT2</b></p> <p>Sat 08/03/2019 to Sun 08/04/2019 0500 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH <b>1700 MW</b></p> <p>Impacts Total Transfer Capability 1450 MW</p> <p>TTC with All Lines In Service 3150 MW</p>		
<hr/>			
<p><b>NIAGARA_345_230_AT4</b></p> <p>Mon 08/05/2019 to Tue 08/06/2019 0500 Continuous 1700</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD      REV (Import) (Export)</p> <p>SCH - OH - NY <b>1900 MW 1400 MW</b></p> <p>Impacts Total Transfer Capability 0 MW 350 MW</p> <p>TTC with All Lines In Service 1900 MW 1750 MW</p>		
<hr/>			
<p><b>MOSES_-ADIRNDCK_230_MA1</b></p> <p>Mon 08/12/2019 to Mon 08/12/2019 0700 Continuous 1459</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH <b>2100 MW</b></p> <p>Impacts Total Transfer Capability 1050 MW</p> <p>TTC with All Lines In Service 3150 MW</p>		

**ARR: 19**

# NYISO TRANSFER LIMITATIONS

Sunday ,April 14, 2019 to Tuesday ,October 13, 2020

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SHOR_NPX-SHOREHAM_138_CSC</b>			FWD
			REV
Tue 09/03/2019	to	Wed 09/04/2019	(Import) (Export)
0300	Continuous	1600	
Work scheduled by: LI			
<b>UPDATED by ISONE 02/15/2019</b>			
SCH - NPX_CSC			<b>0 MW 0 MW</b>
Impacts Total Transfer Capability			330 MW 330 MW
TTC with All Lines In Service			330 MW 330 MW
<b>MARCY_765_345_AT1</b>			FWD
			(Import)
Tue 09/03/2019	to	Tue 09/03/2019	
0500	Continuous	1730	
Work scheduled by: NYPA			
<b>ARR: 19</b>			
MOSES SOUTH			<b>1750 MW</b>
Impacts Total Transfer Capability			1400 MW
TTC with All Lines In Service			3150 MW
<b>MARCY-N.SCTLND_345_18</b>			FWD
			(Import)
Wed 09/04/2019	to	Wed 09/04/2019	
0500	Continuous	1730	
Work scheduled by: NYPA			
<b>UPDATED by NYPA 11/06/2018</b>			
CENTRAL EAST - VC			<b>2090 MW</b>
Impacts Total Transfer Capability			885 MW
TTC with All Lines In Service			2975 MW
<b>MARCY_345KV_CSC</b>			FWD
			(Import)
Wed 09/04/2019	to	Wed 09/04/2019	
0500	Continuous	1730	
Work scheduled by: NYPA			
<b>UPDATED by NYPA 11/06/2018</b>			
CENTRAL EAST - VC			<b>2925 MW</b>
Impacts Total Transfer Capability			50 MW
TTC with All Lines In Service			2975 MW
<b>MOSES-ADIRNDCK_230_MA2</b>			FWD
			(Import)
Wed 09/04/2019	to	Wed 09/04/2019	
0700	Continuous	1500	
Work scheduled by: NYPA			
<b>ARR: 19</b>			
MOSES SOUTH			<b>2100 MW</b>
Impacts Total Transfer Capability			1050 MW
TTC with All Lines In Service			3150 MW
<b>ADIRNDCK-PORTER_230_12</b>			FWD
			(Import)
Wed 09/04/2019	to	Wed 09/04/2019	
0700	Continuous	1530	
Work scheduled by: NYPA			
<b>ARR: 19</b>			
MOSES SOUTH			<b>2100 MW</b>
Impacts Total Transfer Capability			1050 MW
TTC with All Lines In Service			3150 MW
<b>ADIRNDCK-CHASLAKE_230_13</b>			FWD
			(Import)
Thu 09/05/2019	to	Thu 09/05/2019	
0700	Continuous	1530	
Work scheduled by: NYPA			
<b>ARR: 19</b>			
MOSES SOUTH			<b>2100 MW</b>
Impacts Total Transfer Capability			1050 MW
TTC with All Lines In Service			3150 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 14, 2019 to Tuesday ,October 13, 2020

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NIAGARA\_-ROCHESTR\_345\_NR2**

Mon 09/09/2019 to Sat 09/21/2019  
 0500 Continuous 1700  
 Work scheduled by: NYPA

FWD  
 (Import)  
 DYSINGER EAST **1400 MW**  
 Impacts Total Transfer Capability 1750 MW  
 TTC with All Lines In Service 3150 MW

**LEEDS\_\_\_345KV\_R395**

Mon 09/09/2019 to Mon 09/09/2019  
 0700 Continuous 0730  
 Work scheduled by: NYPA

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 1900 MW  
 TTC with All Lines In Service 5700 MW

**GILBOA\_-LEEDS\_\_\_345\_GL3**

Mon 09/09/2019 to Fri 09/27/2019  
 0700 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2200 MW**  
 Impacts Total Transfer Capability 775 MW  
 TTC with All Lines In Service 2975 MW

**MARCY\_-N.SCTLND\_345\_18**

Wed 09/11/2019 to Fri 09/13/2019  
 0500 Continuous 1730  
 Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
 CENTRAL EAST - VC **2090 MW**  
 Impacts Total Transfer Capability 885 MW  
 TTC with All Lines In Service 2975 MW

**MOSES\_-ADIRNDCK\_230\_MA2**

Mon 09/16/2019 to Fri 09/20/2019  
 0700 Continuous 1500  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2100 MW**  
 Impacts Total Transfer Capability 1050 MW  
 TTC with All Lines In Service 3150 MW

**GOETHALS\_345KV\_5**

Fri 09/20/2019 to Tue 09/24/2019  
 0001 Continuous 2359  
 Work scheduled by: ConEd

STATEN ISLAND  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**ROCHESTR-PANNELL\_345\_RP2**

Mon 09/23/2019 to Mon 09/30/2019  
 0500 Continuous 1700  
 Work scheduled by: NYPA

FWD  
 (Import)  
 DYSINGER EAST **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 14, 2019 to Tuesday ,October 13, 2020

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**KINTIGH\_-ROCHESTR\_345\_SR1-39**

Mon 09/23/2019 to Fri 09/27/2019  
0600 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

**LEEDS\_345KV\_R395**

Fri 09/27/2019 to Fri 09/27/2019  
1700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1900 MW  
TTC with All Lines In Service 5700 MW

**CLAY\_-EDIC\_345\_1-16**

Mon 09/30/2019 to Fri 10/04/2019  
0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

**LEEDS\_-HURLYAVE\_345\_301**

Mon 09/30/2019 to Sat 10/26/2019  
0800 Continuous 1600

Work scheduled by: CHGE

FWD

(Import)

UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 5700 MW

**CLAY\_-EDIC\_345\_2-15**

Mon 10/07/2019 to Thu 10/17/2019  
0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

**MARCY\_-N.SCTLND\_345\_18**

Wed 10/09/2019 to Fri 10/11/2019  
0500 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC **2090 MW**  
Impacts Total Transfer Capability 885 MW  
TTC with All Lines In Service 2975 MW

**ARR: 19**

**CHATGUAY-MASSENA\_765\_7040**

Sat 10/12/2019 to Sat 10/26/2019  
0100 Continuous 1900

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **1550 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 14, 2019 to Tuesday ,October 13, 2020

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**CHATGUAY-MASSENA\_\_765\_7040**

Sat 10/12/2019 to Sat 10/26/2019  
0100 Continuous 1900

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

**MARCY\_\_765\_345\_AT1**

Sat 10/12/2019 to Sat 10/26/2019  
0100 Continuous 1900

Work scheduled by: NYPA

**ARR: 19**

	FWD	
	(Import)	
MOSES SOUTH	<b>1750 MW</b>	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	3150 MW	

**MARCY\_\_765\_345\_AT2**

Sat 10/12/2019 to Sat 10/26/2019  
0100 Continuous 1900

Work scheduled by: NYPA

**ARR: 19**

	FWD	
	(Import)	
MOSES SOUTH	<b>1700 MW</b>	
Impacts Total Transfer Capability	1450 MW	
TTC with All Lines In Service	3150 MW	

**MASSENA\_-MARCY\_\_765\_MSU1**

Sat 10/12/2019 to Sat 10/26/2019  
0100 Continuous 1900

Work scheduled by: NYPA

	FWD	
	(Import)	
CENTRAL EAST - VC	<b>2265 MW</b>	
Impacts Total Transfer Capability	710 MW	
TTC with All Lines In Service	2975 MW	

**MASSENA\_-MARCY\_\_765\_MSU1**

Sat 10/12/2019 to Sat 10/26/2019  
0100 Continuous 1900

Work scheduled by: NYPA

	FWD	
	(Import)	
MOSES SOUTH	<b>500 MW</b>	
Impacts Total Transfer Capability	2650 MW	
TTC with All Lines In Service	3150 MW	

**MASSENA\_-MARCY\_\_765\_MSU1**

Sat 10/12/2019 to Sat 10/26/2019  
0100 Continuous 1900

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	<b>475 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	1025 MW	0 MW
TTC with All Lines In Service	1500 MW	1000 MW

**MASSENA\_-MARCY\_\_765\_MSU1 & CHATGUAY-MASSENA\_\_765\_7040**

Sat 10/12/2019 to Sat 10/26/2019  
0100 Continuous 1900

Work scheduled by:

	FWD	
	(Import)	
MOSES SOUTH	<b>500 MW</b>	
Impacts Total Transfer Capability	2650 MW	
TTC with All Lines In Service	3150 MW	

# NYISO TRANSFER LIMITATIONS

Sunday ,April 14, 2019 to Tuesday ,October 13, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2	FWD	REV
Sat 10/12/2019 to Sat 10/26/2019	(Import)	(Export)
0100 to 1900	SCH - HQ - NY Impacts Total Transfer Capability TTC with All Lines In Service	<b>850 MW</b> 0 MW 650 MW 1000 MW 1500 MW 1000 MW
Work scheduled by:		
DUNWODIE_345KV_3	FWD	
Tue 10/22/2019 to Tue 10/22/2019	(Import)	
0001 Continuous 0030	SPR/DUN-SOUTH Impacts Total Transfer Capability TTC with All Lines In Service	<b>3800 MW</b> 800 MW 4600 MW
Work scheduled by: ConEd		
DUNWODIE_345KV_5	FWD	
Tue 10/22/2019 to Tue 10/22/2019	(Import)	
0001 Continuous 0030	SPR/DUN-SOUTH Impacts Total Transfer Capability TTC with All Lines In Service	<b>3800 MW</b> 800 MW 4600 MW
Work scheduled by: ConEd		
DUNWODIE-MOTTHAVN_345_71	FWD	
Tue 10/22/2019 to Tue 11/26/2019	(Import)	
0001 Continuous 2359	SPR/DUN-SOUTH Impacts Total Transfer Capability TTC with All Lines In Service	<b>3800 MW</b> 800 MW 4600 MW
Work scheduled by: ConEd		
GILBOA -N.SCTLND_345_GNS-1	FWD	
Tue 10/22/2019 to Thu 10/24/2019	(Import)	
0700 Continuous 1530	CENTRAL EAST - VC Impacts Total Transfer Capability TTC with All Lines In Service	<b>2520 MW</b> 455 MW 2975 MW
Work scheduled by: NYPA		
GILBOA -N.SCTLND_345_GNS-1	FWD	
Fri 10/25/2019 to Fri 10/25/2019	(Import)	
1330 Continuous 1530	CENTRAL EAST - VC Impacts Total Transfer Capability TTC with All Lines In Service	<b>2520 MW</b> 455 MW 2975 MW
Work scheduled by: NYPA		
NIAGARA_345_230_AT4	FWD	REV
Mon 10/28/2019 to Fri 12/13/2019	(Import)	(Export)
0500 Continuous 1700	SCH - OH - NY Impacts Total Transfer Capability TTC with All Lines In Service	<b>1900 MW</b> 1400 MW 0 MW 350 MW 1900 MW 1750 MW
Work scheduled by: NYPA		

# NYISO TRANSFER LIMITATIONS

Sunday ,April 14, 2019 to Tuesday ,October 13, 2020

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

	FWD	REV
	(Import)	(Export)
<hr/>		
<b>LINDN_CG-LNDVFT___345_V-3022</b>		
Mon 11/04/2019 to Thu 11/07/2019		
0800 Continuous 1500		
Work scheduled by: PJM		
	SCH - PJM_VFT	<b>0 MW 0 MW</b>
	Impacts Total Transfer Capability	315 MW 315 MW
	TTC with All Lines In Service	315 MW 315 MW
<hr/>		
<b>HURLYAVE-ROSETON___345_303</b>		
Mon 11/04/2019 to Fri 12/06/2019		
0800 Continuous 1600		
Work scheduled by: CHGE		
	UPNY CONED	<b>4100 MW</b>
	Impacts Total Transfer Capability	1600 MW
	TTC with All Lines In Service	5700 MW
<hr/>		
<b>PANNELL_-CLAY___345_2</b>		
Wed 11/06/2019 to Fri 11/22/2019		
0700 Continuous 1530		
Work scheduled by: NYPA		
	WEST CENTRAL	<b>1300 MW</b>
	Impacts Total Transfer Capability	950 MW
	TTC with All Lines In Service	2250 MW
<hr/>		
<b>MARCY___-N.SCTLND_345_18</b>		
Thu 11/07/2019 to Fri 11/08/2019		
0500 Continuous 1730		
Work scheduled by: NYPA		
	CENTRAL EAST - VC	<b>2090 MW</b>
	Impacts Total Transfer Capability	885 MW
	TTC with All Lines In Service	2975 MW
<hr/>		
<b>MARCY___345KV_CSC</b>		
Thu 11/07/2019 to Fri 11/08/2019		
0500 Continuous 1730		
Work scheduled by: NYPA		
	CENTRAL EAST - VC	<b>2925 MW</b>
	Impacts Total Transfer Capability	50 MW
	TTC with All Lines In Service	2975 MW
<hr/>		
<b>MOSES___-ADIRNDCK_230_MA2</b>		
Tue 11/12/2019 to Fri 11/15/2019		
0700 Continuous 1500		
Work scheduled by: NYPA		
	MOSES SOUTH	<b>2300 MW</b>
	Impacts Total Transfer Capability	850 MW
	TTC with All Lines In Service	3150 MW
<hr/>		
<b>MOSES___-ADIRNDCK_230_MA2</b>		
Mon 11/18/2019 to Fri 11/22/2019		
0700 Continuous 1500		
Work scheduled by: NYPA		
	MOSES SOUTH	<b>2300 MW</b>
	Impacts Total Transfer Capability	850 MW
	TTC with All Lines In Service	3150 MW

**ARR: 19**



# NYISO TRANSFER LIMITATIONS

Sunday ,April 14, 2019 to Tuesday ,October 13, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Mon 11/25/2019 to Wed 11/27/2019  
 0700 Continuous 1500  
 Work scheduled by: NYPA

FWD  
 (Import)  
**MOSES SOUTH 2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

**DUNWODIE\_345KV\_3**

Tue 11/26/2019 to Tue 11/26/2019 **UPDATED by CONED 02/06/2019**  
 2330 Continuous 2359  
 Work scheduled by: ConEd

FWD  
 (Import)  
**SPR/DUN-SOUTH 3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_5**

Tue 11/26/2019 to Tue 11/26/2019 **UPDATED by CONED 02/06/2019**  
 2330 Continuous 2359  
 Work scheduled by: ConEd

FWD  
 (Import)  
**SPR/DUN-SOUTH 3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Mon 12/02/2019 to Fri 12/06/2019  
 0700 Continuous 1500  
 Work scheduled by: NYPA

FWD  
 (Import)  
**MOSES SOUTH 2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

Mon 12/09/2019 to Fri 12/13/2019  
 0700 Continuous 1500  
 Work scheduled by: NYPA

FWD  
 (Import)  
**MOSES SOUTH 2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Mon 12/16/2019 to Mon 12/16/2019  
 0700 Continuous 1500  
 Work scheduled by: NYPA

FWD  
 (Import)  
**MOSES SOUTH 2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

Tue 12/17/2019 to Fri 12/20/2019  
 0700 Continuous 1500  
 Work scheduled by: NYPA

FWD  
 (Import)  
**MOSES SOUTH 2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,April 14, 2019 to Tuesday ,October 13, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>LADENTWN-BUCHAN_S_345_Y88</b>					FWD
Wed 01/15/2020	to	Thu 02/13/2020	<u>11/05/2018</u>		(Import)
0001	Continuous	2359		UPNY CONED	<b>4800 MW</b>
Work scheduled by: ORU					Impacts Total Transfer Capability 900 MW
					TTC with All Lines In Service 5700 MW
<b>DOLSONAV-ROCKTVRN_345_DART44</b>					FWD
Mon 04/27/2020	to	Sun 05/10/2020	<u>03/21/2019</u>	<u>UPDATED</u> <u>by NYPA</u>	(Import)
0700	Continuous	1730		CENTRAL EAST - VC	<b>2720 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 255 MW
					TTC with All Lines In Service 2975 MW
<b>COOPERS_-DOLSONAV_345_CCDA42</b>					FWD
Mon 05/11/2020	to	Fri 05/29/2020	<u>03/21/2019</u>	<u>UPDATED</u> <u>by NYPA</u>	(Import)
0700	Continuous	1730		CENTRAL EAST - VC	<b>2720 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 255 MW
					TTC with All Lines In Service 2975 MW
<b>FRASANNX-COOPERS__345_UCC2-41</b>					FWD
Mon 09/07/2020	to	Fri 10/23/2020	<u>03/01/2019</u>	<u>UPDATED</u> <u>by NYPA</u>	(Import)
0700	Continuous	1730		CENTRAL EAST - VC	<b>2500 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 475 MW
					TTC with All Lines In Service 2975 MW
<b>MARCY__-FRASANNX_345_UCC2-41</b>					FWD
Mon 09/07/2020	to	Fri 10/23/2020	<u>03/01/2019</u>	<u>UPDATED</u> <u>by NYPA</u>	(Import)
0700	Continuous	1730		CENTRAL EAST - VC	<b>2500 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 475 MW
					TTC with All Lines In Service 2975 MW
<b>LADENTWN-BUCHAN_S_345_Y88</b>					FWD
Tue 09/15/2020	to	Wed 10/14/2020	<u>04/10/2019</u>	<u>CANCELLED</u> <u>by ORU</u>	(Import)
0001	Continuous	2359		UPNY CONED	<b>4800 MW</b>
Work scheduled by: ORU					Impacts Total Transfer Capability 900 MW
					TTC with All Lines In Service 5700 MW