

NYISO TRANSFER LIMITATIONS

Friday ,June 21, 2019 to Sunday ,December 20, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>				FWD	REV
HUDSONP_-FARRAGUT_345_B3402				(Import)	(Export)
Mon 01/15/2018	to	Tue 12/31/2019	<u>EXTENDED</u> <u>by CONED</u> <u>02/06/2019</u>		
0001	Continuous	2359		SCH - PJ - NY	1950 MW 1200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	200 MW 150 MW
				TTC with All Lines In Service	2150 MW 1350 MW
<hr/>				FWD	REV
HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403				(Import)	(Export)
Mon 01/15/2018	to	Tue 12/31/2019			
0001		2359		SCH - PJ - NY	1800 MW 1100 MW
Work scheduled by:				Impacts Total Transfer Capability	350 MW 250 MW
				TTC with All Lines In Service	2150 MW 1350 MW
<hr/>				FWD	REV
MARION_-FARRAGUT_345_C3403				(Import)	(Export)
Mon 01/15/2018	to	Tue 12/31/2019	<u>EXTENDED</u> <u>by CONED</u> <u>02/06/2019</u>		
0001	Continuous	2359		SCH - PJ - NY	1950 MW 1200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	200 MW 150 MW
				TTC with All Lines In Service	2150 MW 1350 MW
<hr/>				FWD	REV
STLAWRNC-MOSES_230_L33P				(Import)	(Export)
Mon 04/30/2018	to	Fri 12/31/2021	<u>EXT FORCE</u> <u>by IESO</u> <u>08/21/2018</u>		
0456	Continuous	2359		SCH - OH - NY	1900 MW 1700 MW
Work scheduled by: IESO				Impacts Total Transfer Capability	0 MW 0 MW
				TTC with All Lines In Service	1900 MW 1700 MW
<hr/>				FWD	
SCH-IMO-NYISO_LIMIT_1550				(Import)	
Fri 05/03/2019	to	Fri 07/19/2019		SCH - OH - NY	1850 MW
1700	Continuous	1700		Impacts Total Transfer Capability	50 MW
Work scheduled by: IESO				TTC with All Lines In Service	1900 MW
<hr/>					REV
SCH-NYISO-IMO_LIMIT_1100					(Export)
Fri 05/03/2019	to	Fri 07/19/2019		SCH - OH - NY	1400 MW
1700	Continuous	1700		Impacts Total Transfer Capability	300 MW
Work scheduled by: IESO				TTC with All Lines In Service	1700 MW
<hr/>				FWD	
SCH-IMO-NYISO_LIMIT_1400				(Import)	
Sun 05/05/2019	to	Fri 07/12/2019	<u>EXTENDED</u> <u>by IESO</u> <u>06/14/2019</u>		
0500	Continuous	1700		SCH - OH - NY	1700 MW
Work scheduled by: IESO				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	1900 MW

NYISO TRANSFER LIMITATIONS

Friday ,June 21, 2019 to Sunday ,December 20, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>									
SCH-NYISO-HQ_LIMIT_800									REV
Wed 06/05/2019	to	Fri 07/19/2019	<u>EXTENDED</u>	<u>by HQ</u>	<u>06/19/2019</u>			(Export)	
0001	Continuous	1900				SCH - HQ - NY			800 MW
Work scheduled by: HQ						Impacts Total Transfer Capability			200 MW
						TTC with All Lines In Service			1000 MW
<hr/>									
NIAGARA -KINTIGH_345_NS1-38									FWD
Mon 06/10/2019	to	Fri 06/21/2019	<u>EXTENDED</u>	<u>by NYSEG</u>	<u>06/18/2019</u>			(Import)	
0800	Continuous	1009				DYSINGER EAST			1400 MW
Work scheduled by: NYSEG						Impacts Total Transfer Capability			1750 MW
						TTC with All Lines In Service			3150 MW
<hr/>									
SCH-IMO-NYISO_LIMIT_1200									FWD
Mon 06/10/2019	to	Wed 06/19/2019	<u>EXTENDED</u>	<u>by NYSEG</u>	<u>06/18/2019</u>			(Import)	
0900	Continuous	2359				SCH - OH - NY			1500 MW
Work scheduled by: NYSEG						Impacts Total Transfer Capability			400 MW
						TTC with All Lines In Service			1900 MW
<hr/>									
RAMAPO -LADENTWN_345_W72									FWD
Wed 06/12/2019	to	Sun 06/16/2019	<u>FORCED</u>	<u>by CONED</u>	<u>06/14/2019</u>			(Import)	
2124	Continuous	2359				UPNY CONED			4400 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability			1300 MW
						TTC with All Lines In Service			5700 MW
<hr/>									
W49TH_ST_345KV_5									FWD
Sat 06/15/2019	to	Tue 06/25/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>06/13/2019</u>			(Import)	
0001	Continuous	0600				SCH - PJM_HTP			350 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability			310 MW
						TTC with All Lines In Service			660 MW
<hr/>									
W49TH_ST_345KV_7									FWD
Sat 06/15/2019	to	Tue 06/25/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>06/13/2019</u>			(Import)	
0001	Continuous	0600				SCH - PJM_HTP			350 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability			310 MW
						TTC with All Lines In Service			660 MW
<hr/>									
NRTH1385-NOR_HBR_138_601									FWD
Tue 06/18/2019	to	Tue 06/18/2019	<u>CANCELLED</u>	<u>by ISONE</u>	<u>06/18/2019</u>			(Import)	REV
0800	Continuous	1300				SCH - NPX_1385			100 MW
Work scheduled by: ISONE						Impacts Total Transfer Capability			100 MW
						TTC with All Lines In Service			200 MW

NYISO TRANSFER LIMITATIONS

Friday ,June 21, 2019 to Sunday ,December 20, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>				
NRTH1385-NOR HBR__138_602			FWD	REV
Tue 06/18/2019 to Tue 06/18/2019	CANCELLED	by ISONE	(Import) (Export)	
0800 Continuous 1300		06/18/2019	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
<hr/>				
NRTH1385-NOR HBR__138_603			FWD	REV
Tue 06/18/2019 to Tue 06/18/2019	CANCELLED	by ISONE	(Import) (Export)	
0800 Continuous 1300		06/18/2019	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
<hr/>				
NRTH1385-NRTHPORT_138_NNC			FWD	REV
Tue 06/18/2019 to Tue 06/18/2019	CANCELLED	by ISONE	(Import) (Export)	
0800 Continuous 1300		06/18/2019	SCH - NPX_1385	0 MW 0 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
<hr/>				
PIERCBRK-FIVEMILE_345_37			FWD	REV
Thu 06/20/2019 to Thu 06/20/2019	UPDATED	by NYISO	(Import) (Export)	
0700 Continuous 2230		06/19/2019	SCH - PJ - NY	2100 MW 1300 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	50 MW 50 MW
			TTC with All Lines In Service	2150 MW 1350 MW
<hr/>				
SCH-IMO-NYISO_LIMIT_500			FWD	
Thu 06/20/2019 to Thu 06/20/2019	UPDATED	by NYISO	(Import)	
0700 Continuous 2230		06/19/2019	SCH - OH - NY	800 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	1100 MW
			TTC with All Lines In Service	1900 MW
<hr/>				
BECK__-NIAGARA_345_PA302			FWD	REV
Thu 06/20/2019 to Fri 06/21/2019	CANCELLED	by NYISO	(Import) (Export)	
0830 Daily 2000		06/18/2019	SCH - OH - NY	900 MW 800 MW
Work scheduled by: IESO			Impacts Total Transfer Capability	1000 MW 900 MW
			TTC with All Lines In Service	1900 MW 1700 MW
<hr/>				
SCH-IMO-NYISO_LIMIT_500			FWD	
Fri 06/21/2019 to Fri 06/21/2019	UPDATED	by NYISO	(Import)	
0700 Continuous 1014		06/19/2019	SCH - OH - NY	800 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	1100 MW
			TTC with All Lines In Service	1900 MW

NYISO TRANSFER LIMITATIONS

Friday ,June 21, 2019 to Sunday ,December 20, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

	FWD	REV	
<hr/>			
NRTH1385-NOR HBR__138_601			(Import) (Export)
Fri 06/21/2019 to Fri 06/21/2019 UPDATED by ISONE 06/19/2019			
0800 Continuous 1300			
Work scheduled by: ISONE			
	SCH - NPX_1385	100 MW	100 MW
	Impacts Total Transfer Capability	100 MW	100 MW
	TTC with All Lines In Service	200 MW	200 MW
<hr/>			
NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_602			(Import) (Export)
Fri 06/21/2019 to Fri 06/21/2019			
0800 1300			
Work scheduled by:			
	SCH - NPX_1385	0 MW	0 MW
	Impacts Total Transfer Capability	200 MW	200 MW
	TTC with All Lines In Service	200 MW	200 MW
<hr/>			
NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_603			(Import) (Export)
Fri 06/21/2019 to Fri 06/21/2019			
0800 1300			
Work scheduled by:			
	SCH - NPX_1385	0 MW	0 MW
	Impacts Total Transfer Capability	200 MW	200 MW
	TTC with All Lines In Service	200 MW	200 MW
<hr/>			
NRTH1385-NOR HBR__138_602			(Import) (Export)
Fri 06/21/2019 to Fri 06/21/2019 UPDATED by ISONE 06/19/2019			
0800 Continuous 1300			
Work scheduled by: ISONE			
	SCH - NPX_1385	100 MW	100 MW
	Impacts Total Transfer Capability	100 MW	100 MW
	TTC with All Lines In Service	200 MW	200 MW
<hr/>			
NRTH1385-NOR HBR__138_602 & NRTH1385-NOR HBR__138_603			(Import) (Export)
Fri 06/21/2019 to Fri 06/21/2019			
0800 1300			
Work scheduled by:			
	SCH - NPX_1385	0 MW	0 MW
	Impacts Total Transfer Capability	200 MW	200 MW
	TTC with All Lines In Service	200 MW	200 MW
<hr/>			
NRTH1385-NOR HBR__138_603			(Import) (Export)
Fri 06/21/2019 to Fri 06/21/2019 UPDATED by ISONE 06/19/2019			
0800 Continuous 1300			
Work scheduled by: ISONE			
	SCH - NPX_1385	100 MW	100 MW
	Impacts Total Transfer Capability	100 MW	100 MW
	TTC with All Lines In Service	200 MW	200 MW
<hr/>			
NRTH1385-NRTHPORT_138_NNC			(Import) (Export)
Fri 06/21/2019 to Fri 06/21/2019 UPDATED by ISONE 06/19/2019			
0800 Continuous 1300			
Work scheduled by: ISONE			
	SCH - NPX_1385	0 MW	0 MW
	Impacts Total Transfer Capability	200 MW	200 MW
	TTC with All Lines In Service	200 MW	200 MW

NYISO TRANSFER LIMITATIONS

Friday ,June 21, 2019 to Sunday ,December 20, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA2

Mon 06/24/2019 to Fri 06/28/2019
0700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

LEEDS___345_LEEDS SVC

Mon 06/24/2019 to Fri 06/28/2019
0800 Continuous 1600

Work scheduled by: NGrid

FWD

(Import)

CENTRAL EAST - VC **2950 MW**
Impacts Total Transfer Capability 25 MW
TTC with All Lines In Service 2975 MW

MARCY_SO_SERIES_COMP_I/S

Fri 06/28/2019 to Thu 10/31/2019 **UPDATED by NYISO 06/21/2019**
1600 Continuous 2359

Work scheduled by: NYISO

FWD

(Import)

CENTRAL EAST - VC **2740 MW**
Impacts Total Transfer Capability 235 MW
TTC with All Lines In Service 2975 MW

SPRNBRK_-W49TH_ST_345_M52

Sun 06/30/2019 to Tue 07/02/2019
0001 Continuous 0200

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

SPRNBRK__345KV_RNS4

Sun 06/30/2019 to Tue 07/02/2019
0001 Continuous 0200

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

W49TH_ST_345KV_5

Sun 06/30/2019 to Tue 07/02/2019
0001 Continuous 0200

Work scheduled by: ConEd

FWD

(Import)

SCH - PJM_HTP **350 MW**
Impacts Total Transfer Capability 310 MW
TTC with All Lines In Service 660 MW

CHAT_DC_GC2

Sun 07/07/2019 to Sun 07/07/2019 **UPDATED by HQ 06/21/2019**
0500 Continuous 2000

Work scheduled by: HQ

FWD

(Import)

MOSES SOUTH **2850 MW**
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,June 21, 2019 to Sunday ,December 20, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC2					REV	
Sun 07/07/2019	to	Sun 07/07/2019	<u>UPDATED</u>	<u>by HQ</u>	<u>06/21/2019</u>	(Export)
0500	Continuous	2000				500 MW
Work scheduled by: HQ					SCH - HQ - NY	500 MW
					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1000 MW
MOSES -ADIRNDCK_230_MA2					FWD	
Mon 07/08/2019	to	Fri 07/12/2019				(Import)
0700	Continuous	1500				2100 MW
Work scheduled by: NYPA					MOSES SOUTH	2100 MW
					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	3150 MW
ADIRNDCK-CHASLAKE_230_13					FWD	
Mon 07/08/2019	to	Fri 07/12/2019				(Import)
0700	Continuous	1530				2100 MW
Work scheduled by: NYPA					MOSES SOUTH	2100 MW
					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	3150 MW
CHATGUAY-MASSENA_765_7040					FWD	
Sat 08/03/2019	to	Sun 08/04/2019				(Import)
0500	Continuous	1730				1550 MW
Work scheduled by: NYPA					MOSES SOUTH	1550 MW
					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	3150 MW
CHATGUAY-MASSENA_765_7040					FWD	REV
Sat 08/03/2019	to	Sun 08/04/2019				(Import) (Export)
0500	Continuous	1730				0 MW 0 MW
Work scheduled by: NYPA					SCH - HQ - NY	0 MW 0 MW
					Impacts Total Transfer Capability	1500 MW 1000 MW
					TTC with All Lines In Service	1500 MW 1000 MW
MASSENA -MARCY_765_MSU1					FWD	
Sat 08/03/2019	to	Sun 08/04/2019				(Import)
0500	Continuous	1730				2265 MW
Work scheduled by: NYPA					CENTRAL EAST - VC	2265 MW
					Impacts Total Transfer Capability	710 MW
					TTC with All Lines In Service	2975 MW
MASSENA -MARCY_765_MSU1					FWD	
Sat 08/03/2019	to	Sun 08/04/2019				(Import)
0500	Continuous	1730				500 MW
Work scheduled by: NYPA					MOSES SOUTH	500 MW
					Impacts Total Transfer Capability	2650 MW
					TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,June 21, 2019 to Sunday ,December 20, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA -MARCY 765_MSU1				FWD	REV
Sat 08/03/2019	to	Sun 08/04/2019		(Import)	(Export)
0500	Continuous	1730		SCH - HQ - NY	475 MW 1000 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1025 MW 0 MW
				TTC with All Lines In Service	1500 MW 1000 MW
MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040				FWD	
Sat 08/03/2019	to	Sun 08/04/2019		(Import)	
0500		1730		MOSES SOUTH	500 MW
Work scheduled by:				Impacts Total Transfer Capability	2650 MW
				TTC with All Lines In Service	3150 MW
MASSENA -MARCY 765_MSU1 & MARCY_SO_SERIES_COMP_I/S				FWD	
Sat 08/03/2019	to	Sun 08/04/2019		(Import)	
0500		1730		CENTRAL EAST - VC	2080 MW
Work scheduled by:				Impacts Total Transfer Capability	895 MW
				TTC with All Lines In Service	2975 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2				FWD	REV
Sat 08/03/2019	to	Sun 08/04/2019		(Import)	(Export)
0500		1730		SCH - HQ - NY	850 MW 0 MW
Work scheduled by:				Impacts Total Transfer Capability	650 MW 1000 MW
				TTC with All Lines In Service	1500 MW 1000 MW
NIAGARA 345_230_AT4				FWD	REV
Mon 08/05/2019	to	Tue 08/06/2019		(Import)	(Export)
0500	Continuous	1700		SCH - OH - NY	1900 MW 1400 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	0 MW 300 MW
				TTC with All Lines In Service	1900 MW 1700 MW
MOSES -ADIRNDCK 230_MA1				FWD	
Mon 08/12/2019	to	Mon 08/12/2019	UPDATED by NYPA 10/10/2018	(Import)	
0700	Continuous	1459		MOSES SOUTH	2100 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1050 MW
				TTC with All Lines In Service	3150 MW
WATRCURE-OAKDALE 345_31				FWD	REV
Wed 08/28/2019	to	Wed 08/28/2019	UPDATED by NYISO 06/10/2019	(Import)	(Export)
0800	Continuous	1000		SCH - PJ - NY	2100 MW 1300 MW
Work scheduled by: NYSEG				Impacts Total Transfer Capability	50 MW 50 MW
				TTC with All Lines In Service	2150 MW 1350 MW

NYISO TRANSFER LIMITATIONS

Friday ,June 21, 2019 to Sunday ,December 20, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
SHOR_NPX-SHOREHAM_138_CSC						
Tue 09/03/2019	to	Wed 09/04/2019	<u>UPDATED</u>	<u>by ISONE</u>	<u>02/15/2019</u>	
0300	Continuous	1600				
Work scheduled by: LI					SCH - NPX_CSC	0 MW
					Impacts Total Transfer Capability	330 MW
					TTC with All Lines In Service	330 MW
MARCY___765_345_AT1						
Tue 09/03/2019	to	Tue 09/03/2019				
0500	Continuous	1730				
Work scheduled by: NYPA					MOSES SOUTH	1750 MW
					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	3150 MW
MARCY___-N.SCTLND_345_18						
Wed 09/04/2019	to	Wed 09/04/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>11/06/2018</u>	
0500	Continuous	1730				
Work scheduled by: NYPA					CENTRAL EAST - VC	2090 MW
					Impacts Total Transfer Capability	885 MW
					TTC with All Lines In Service	2975 MW
MARCY___-N.SCTLND_345_18 & MARCY_SO_SERIES_COMP_I/S						
Wed 09/04/2019	to	Wed 09/04/2019				
0500		1730				
Work scheduled by:					CENTRAL EAST - VC	1855 MW
					Impacts Total Transfer Capability	1120 MW
					TTC with All Lines In Service	2975 MW
MARCY___345KV_CSC						
Wed 09/04/2019	to	Wed 09/04/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>11/06/2018</u>	
0500	Continuous	1730				
Work scheduled by: NYPA					CENTRAL EAST - VC	2925 MW
					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	2975 MW
MARCY___345KV_CSC & MARCY_SO_SERIES_COMP_I/S						
Wed 09/04/2019	to	Wed 09/04/2019				
0500		1730				
Work scheduled by:					CENTRAL EAST - VC	2690 MW
					Impacts Total Transfer Capability	285 MW
					TTC with All Lines In Service	2975 MW
MOSES___-ADIRNDCK_230_MA2						
Wed 09/04/2019	to	Wed 09/04/2019				
0700	Continuous	1500				
Work scheduled by: NYPA					MOSES SOUTH	2100 MW
					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,June 21, 2019 to Sunday ,December 20, 2020

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ADIRNDCK-PORTER___230_12

Wed 09/04/2019 to Wed 09/04/2019
 0700 Continuous 1530

Work scheduled by: NYPA

FWD
 (Import)
MOSES SOUTH 2100 MW
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW

ADIRNDCK-CHASLAKE_230_13

Thu 09/05/2019 to Thu 09/05/2019
 0700 Continuous 1530

Work scheduled by: NYPA

FWD
 (Import)
MOSES SOUTH 2100 MW
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW

NIAGARA_-ROCHESTR_345_NR2

Mon 09/09/2019 to Sat 09/21/2019
 0500 Continuous 1700

Work scheduled by: NYPA

FWD
 (Import)
DYSINGER EAST 1400 MW
 Impacts Total Transfer Capability 1750 MW
 TTC with All Lines In Service 3150 MW

LEEDS___345KV_R395

Mon 09/09/2019 to Mon 09/09/2019
 0700 Continuous 0730

Work scheduled by: NYPA

FWD
 (Import)
UPNY CONED 3800 MW
 Impacts Total Transfer Capability 1900 MW
 TTC with All Lines In Service 5700 MW

GILBOA_-LEEDS___345_GL3

Mon 09/09/2019 to Fri 09/27/2019
 0700 Continuous 1730

Work scheduled by: NYPA

FWD
 (Import)
CENTRAL EAST - VC 2200 MW
 Impacts Total Transfer Capability 775 MW
 TTC with All Lines In Service 2975 MW

MARCY_-N.SCTLND_345_18

Wed 09/11/2019 to Fri 09/13/2019
 0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
CENTRAL EAST - VC 2090 MW
 Impacts Total Transfer Capability 885 MW
 TTC with All Lines In Service 2975 MW

MARCY_-N.SCTLND_345_18 & MARCY_SO_SERIES_COMP_I/S

Wed 09/11/2019 to Fri 09/13/2019
 0500 Continuous 1730

Work scheduled by:

ARR: 19

FWD
 (Import)
CENTRAL EAST - VC 1855 MW
 Impacts Total Transfer Capability 1120 MW
 TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Friday ,June 21, 2019 to Sunday ,December 20, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

E13THSTA-FARRAGUT_345_45

Sun 09/15/2019 to Sun 09/15/2019
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

MOSES-ADIRNDCK_230_MA2

Mon 09/16/2019 to Fri 09/20/2019
 0700 Continuous 1500
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2100 MW**
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW

OAKDALE-FRASER_345_32

Mon 09/16/2019 to Fri 09/20/2019
 0700 Continuous 1800
 Work scheduled by: NYSEG

FWD
 (Import)
 CENTRAL EAST - VC **2650 MW**
 Impacts Total Transfer Capability 325 MW
 TTC with All Lines In Service 2975 MW

GOETHALS_345KV_5

Fri 09/20/2019 to Tue 09/24/2019
 0001 Continuous 2359
 Work scheduled by: ConEd

STATEN ISLAND
 Impacts Total Transfer Capability
 TTC with All Lines In Service

EASTVIEW-SPRNBK_345_W65

Fri 09/20/2019 to Sun 09/22/2019
 2000 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

MILLWOOD-EASTVIEW_345_W82

Fri 09/20/2019 to Sun 09/22/2019
 2000 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

SPRNBK_345KV_RNS4

Fri 09/20/2019 to Sun 09/22/2019
 2000 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Friday ,June 21, 2019 to Sunday ,December 20, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROCHESTR-PANNELL__345_RP2

Mon 09/23/2019 to Mon 09/30/2019
0500 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

KINTIGH_-ROCHESTR_345_SR1-39

Mon 09/23/2019 to Fri 09/27/2019
0600 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

OAKDALE_-FRASER__345_32

Mon 09/23/2019 to Fri 09/27/2019
0700 Continuous 1800

Work scheduled by: NYSEG

FWD

(Import)

CENTRAL EAST - VC **2650 MW**
Impacts Total Transfer Capability 325 MW
TTC with All Lines In Service 2975 MW

LEEDS__345KV_R395

Fri 09/27/2019 to Fri 09/27/2019
1700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

UPNY CONED **3800 MW**
Impacts Total Transfer Capability 1900 MW
TTC with All Lines In Service 5700 MW

KINTIGH_-ROCHESTR_345_SR1-39

Fri 09/27/2019 to Wed 10/02/2019
1701 Continuous 1900

Work scheduled by: RGE

FWD

(Import)

DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

EASTVIEW-SPRNBRK__345_W65

Fri 09/27/2019 to Sun 09/29/2019
2200 Continuous 0200

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1350 MW
TTC with All Lines In Service 5700 MW

MILLWOOD-EASTVIEW_345_W82

Fri 09/27/2019 to Sun 09/29/2019
2200 Continuous 0200

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1350 MW
TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Friday ,June 21, 2019 to Sunday ,December 20, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK__345KV_RNS4

Fri 09/27/2019 to Sun 09/29/2019
 2200 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

OAKDALE_-FRASER__345_32

Mon 09/30/2019 to Mon 09/30/2019
 0700 Continuous 1800
 Work scheduled by: NYSEG

FWD
 (Import)
 CENTRAL EAST - VC **2650 MW**
 Impacts Total Transfer Capability 325 MW
 TTC with All Lines In Service 2975 MW

CLAY_-EDIC__345_1-16

Mon 09/30/2019 to Fri 10/04/2019
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 OSWEGO EXPORT **4850 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 5250 MW

HURLYAVE-ROSETON__345_303

Mon 09/30/2019 to Sat 10/26/2019
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4100 MW**
 Impacts Total Transfer Capability 1600 MW
 TTC with All Lines In Service 5700 MW

SPRNBK__345KV_RS3 & SPRNBK__345KV_RS4

Tue 10/01/2019 to Thu 10/10/2019
 0001 2230
 Work scheduled by:

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

STOLLERD-HISHELDN_230_67

Mon 10/07/2019 to Tue 10/08/2019
 0700 Continuous 1400
 Work scheduled by: NYSEG

FWD
 (Import)
 DYSINGER EAST **2850 MW**
 Impacts Total Transfer Capability 300 MW
 TTC with All Lines In Service 3150 MW

CLAY_-EDIC__345_2-15

Mon 10/07/2019 to Thu 10/17/2019
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 OSWEGO EXPORT **4850 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 5250 MW

NYISO TRANSFER LIMITATIONS

Friday ,June 21, 2019 to Sunday ,December 20, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___-N.SCTLND_345_18

Wed 10/09/2019 to Fri 10/11/2019
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

CENTRAL EAST - VC **2090 MW**
Impacts Total Transfer Capability 885 MW
TTC with All Lines In Service 2975 MW

MARCY___-N.SCTLND_345_18 & MARCY_SO_SERIES_COMP_I/S

Wed 10/09/2019 to Fri 10/11/2019
0500 Continuous 1730

Work scheduled by:

ARR: 19

FWD

(Import)

CENTRAL EAST - VC **1855 MW**
Impacts Total Transfer Capability 1120 MW
TTC with All Lines In Service 2975 MW

E13THSTA-FARRAGUT_345_45

Sat 10/12/2019 to Sun 10/13/2019
0001 Continuous 0200

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

CHATGUAY-MASSENA_765_7040

Sat 10/12/2019 to Sat 10/26/2019
0100 Continuous 1900

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **1550 MW**
Impacts Total Transfer Capability 1600 MW
TTC with All Lines In Service 3150 MW

CHATGUAY-MASSENA_765_7040

Sat 10/12/2019 to Sat 10/26/2019
0100 Continuous 1900

Work scheduled by: NYPA

FWD

(Import) (Export)

SCH - HQ - NY **0 MW 0 MW**
Impacts Total Transfer Capability 1500 MW 1000 MW
TTC with All Lines In Service 1500 MW 1000 MW

MARCY___765_345_AT1

Sat 10/12/2019 to Sat 10/26/2019
0100 Continuous 1900

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

MOSES SOUTH **1750 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 3150 MW

MARCY___765_345_AT2

Sat 10/12/2019 to Sat 10/26/2019
0100 Continuous 1900

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,June 21, 2019 to Sunday ,December 20, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>MASSENA -MARCY 765_MSU1</p> <p>Sat 10/12/2019 to Sat 10/26/2019 0100 Continuous 1900</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC 2265 MW</p> <p>Impacts Total Transfer Capability 710 MW</p> <p>TTC with All Lines In Service 2975 MW</p>															
<p>MASSENA -MARCY 765_MSU1</p> <p>Sat 10/12/2019 to Sat 10/26/2019 0100 Continuous 1900</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH 500 MW</p> <p>Impacts Total Transfer Capability 2650 MW</p> <p>TTC with All Lines In Service 3150 MW</p>															
<p>MASSENA -MARCY 765_MSU1</p> <p>Sat 10/12/2019 to Sat 10/26/2019 0100 Continuous 1900</p> <p>Work scheduled by: NYPA</p>	<table style="width: 100%; border: none;"> <tr> <td style="width: 60%;"></td> <td style="width: 20%; text-align: right;">FWD</td> <td style="width: 20%; text-align: right;">REV</td> </tr> <tr> <td></td> <td style="text-align: right;">(Import)</td> <td style="text-align: right;">(Export)</td> </tr> <tr> <td>SCH - HQ - NY</td> <td style="text-align: right;">475 MW</td> <td style="text-align: right;">1000 MW</td> </tr> <tr> <td>Impacts Total Transfer Capability</td> <td style="text-align: right;">1025 MW</td> <td style="text-align: right;">0 MW</td> </tr> <tr> <td>TTC with All Lines In Service</td> <td style="text-align: right;">1500 MW</td> <td style="text-align: right;">1000 MW</td> </tr> </table>		FWD	REV		(Import)	(Export)	SCH - HQ - NY	475 MW	1000 MW	Impacts Total Transfer Capability	1025 MW	0 MW	TTC with All Lines In Service	1500 MW	1000 MW
	FWD	REV														
	(Import)	(Export)														
SCH - HQ - NY	475 MW	1000 MW														
Impacts Total Transfer Capability	1025 MW	0 MW														
TTC with All Lines In Service	1500 MW	1000 MW														
<p>MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040</p> <p>Sat 10/12/2019 to Sat 10/26/2019 0100 1900</p> <p>Work scheduled by:</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH 500 MW</p> <p>Impacts Total Transfer Capability 2650 MW</p> <p>TTC with All Lines In Service 3150 MW</p>															
<p>MASSENA -MARCY 765_MSU1 & MARCY_SO_SERIES_COMP_I/S</p> <p>Sat 10/12/2019 to Sat 10/26/2019 0100 1900</p> <p>Work scheduled by:</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC 2080 MW</p> <p>Impacts Total Transfer Capability 895 MW</p> <p>TTC with All Lines In Service 2975 MW</p>															
<p>MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2</p> <p>Sat 10/12/2019 to Sat 10/26/2019 0100 1900</p> <p>Work scheduled by:</p>	<table style="width: 100%; border: none;"> <tr> <td style="width: 60%;"></td> <td style="width: 20%; text-align: right;">FWD</td> <td style="width: 20%; text-align: right;">REV</td> </tr> <tr> <td></td> <td style="text-align: right;">(Import)</td> <td style="text-align: right;">(Export)</td> </tr> <tr> <td>SCH - HQ - NY</td> <td style="text-align: right;">850 MW</td> <td style="text-align: right;">0 MW</td> </tr> <tr> <td>Impacts Total Transfer Capability</td> <td style="text-align: right;">650 MW</td> <td style="text-align: right;">1000 MW</td> </tr> <tr> <td>TTC with All Lines In Service</td> <td style="text-align: right;">1500 MW</td> <td style="text-align: right;">1000 MW</td> </tr> </table>		FWD	REV		(Import)	(Export)	SCH - HQ - NY	850 MW	0 MW	Impacts Total Transfer Capability	650 MW	1000 MW	TTC with All Lines In Service	1500 MW	1000 MW
	FWD	REV														
	(Import)	(Export)														
SCH - HQ - NY	850 MW	0 MW														
Impacts Total Transfer Capability	650 MW	1000 MW														
TTC with All Lines In Service	1500 MW	1000 MW														
<p>NEPTUNE -DUFFYAVE 345_NEPTUNE</p> <p>Thu 10/17/2019 to Wed 10/23/2019 0001 Continuous 2359</p> <p>Work scheduled by: LI</p>	<p style="text-align: right;">FWD (Import)</p> <p>SCH - PJM_NEPTUNE 0 MW</p> <p>Impacts Total Transfer Capability 660 MW</p> <p>TTC with All Lines In Service 660 MW</p>															

NYISO TRANSFER LIMITATIONS

Friday ,June 21, 2019 to Sunday ,December 20, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE-DUFFYAVE_345_501

Thu 10/17/2019 to Wed 10/23/2019
 0001 Continuous 2359
 Work scheduled by: LI

FWD
 (Import)
 SCH - PJM_NEPTUNE **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_1

Thu 10/17/2019 to Wed 10/23/2019
 0001 Continuous 2359
 Work scheduled by: LI

FWD
 (Import)
 SCH - PJM_NEPTUNE **375 MW**
 Impacts Total Transfer Capability 285 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_2

Thu 10/17/2019 to Wed 10/23/2019
 0001 Continuous 2359
 Work scheduled by: LI

FWD
 (Import)
 SCH - PJM_NEPTUNE **375 MW**
 Impacts Total Transfer Capability 285 MW
 TTC with All Lines In Service 660 MW

DUNWODIE_345KV_3

Tue 10/22/2019 to Tue 10/22/2019 **UPDATED by CONED 02/06/2019**
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_5

Tue 10/22/2019 to Tue 10/22/2019 **UPDATED by CONED 02/06/2019**
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE-MOTTHAVN_345_71

Tue 10/22/2019 to Tue 11/26/2019 **UPDATED by CONED 02/06/2019**
 0001 Continuous 2359
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

GILBOA_-N.SCTLND_345_GNS-1

Tue 10/22/2019 to Thu 10/24/2019
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2520 MW**
 Impacts Total Transfer Capability 455 MW
 TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Friday ,June 21, 2019 to Sunday ,December 20, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA__345_230_AT4					FWD	REV
Wed 10/23/2019	to	Thu 10/24/2019			(Import)	(Export)
0500	Continuous	1900		SCH - OH - NY	1900 MW	1400 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	0 MW 300 MW
					TTC with All Lines In Service	1900 MW 1700 MW
WATRCURE-OAKDALE__345_31					FWD	REV
Fri 10/25/2019	to	Fri 10/25/2019	UPDATED	by NYISO 06/10/2019	(Import)	(Export)
1300	Continuous	1500		SCH - PJ - NY	2100 MW	1300 MW
Work scheduled by: NYSEG					Impacts Total Transfer Capability	50 MW 50 MW
					TTC with All Lines In Service	2150 MW 1350 MW
GILBOA__-N.SCTLND_345_GNS-1					FWD	
Fri 10/25/2019	to	Fri 10/25/2019			(Import)	
1330	Continuous	1530		CENTRAL EAST - VC	2520 MW	
Work scheduled by: NYPA					Impacts Total Transfer Capability	455 MW
					TTC with All Lines In Service	2975 MW
NIAGARA__345_230_AT4					FWD	REV
Mon 10/28/2019	to	Tue 12/17/2019	UPDATED	by NYPA 04/10/2019	(Import)	(Export)
0500	Continuous	1700		SCH - OH - NY	1900 MW	1400 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	0 MW 300 MW
					TTC with All Lines In Service	1900 MW 1700 MW
SCH-IMO-NYISO_LIMIT_1750					FWD	
Fri 11/01/2019	to	Thu 04/30/2020	UPDATED	by IESO 05/03/2019	(Import)	
0001	Continuous	2359		SCH - OH - NY	2050 MW	
Work scheduled by: IESO					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	2250 MW
SCH-NYISO-IMO_LIMIT_1600						REV
Fri 11/01/2019	to	Thu 04/30/2020	UPDATED	by IESO 05/03/2019		(Export)
0001	Continuous	2359		SCH - OH - NY		1900 MW
Work scheduled by: IESO					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	2000 MW
LINDN_CG-LNDVFT__345_V-3022					FWD	REV
Mon 11/04/2019	to	Thu 11/07/2019			(Import)	(Export)
0800	Continuous	1500		SCH - PJM_VFT	0 MW	0 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	315 MW 315 MW
					TTC with All Lines In Service	315 MW 315 MW

NYISO TRANSFER LIMITATIONS

Friday ,June 21, 2019 to Sunday ,December 20, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___-N.SCTLND_345_18

Thu 11/07/2019 to Fri 11/08/2019
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2090 MW**
Impacts Total Transfer Capability 885 MW
TTC with All Lines In Service 2975 MW

MARCY___345KV_CSC

Thu 11/07/2019 to Fri 11/08/2019
0500 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2925 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

LEEDS___-HURLYAVE_345_301

Mon 11/11/2019 to Fri 12/13/2019
0800 Continuous 1600

Work scheduled by: CHGE

UPDATED by CHGE 06/20/2019

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 1600 MW
TTC with All Lines In Service 5700 MW

MOSES___-ADIRNDCK_230_MA2

Tue 11/12/2019 to Fri 11/15/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 11/18/2019 to Fri 11/22/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 11/25/2019 to Wed 11/27/2019
0700 Continuous 1500

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

DUNWODIE_345KV_3

Tue 11/26/2019 to Tue 11/26/2019
2330 Continuous 2359

Work scheduled by: ConEd

UPDATED by CONED 02/06/2019

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Friday ,June 21, 2019 to Sunday ,December 20, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_5

Tue 11/26/2019 to Tue 11/26/2019
2330 Continuous 2359

Work scheduled by: ConEd

UPDATED by CONED 02/06/2019

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD
(Import)

MOSES__-ADIRNDCK_230_MA2

Mon 12/02/2019 to Fri 12/06/2019
0700 Continuous 1500

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

FWD
(Import)

MOSES__-ADIRNDCK_230_MA1

Mon 12/09/2019 to Fri 12/13/2019
0700 Continuous 1500

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

FWD
(Import)

MOSES__-ADIRNDCK_230_MA2

Mon 12/16/2019 to Mon 12/16/2019
0700 Continuous 1500

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

FWD
(Import)

MOSES__-ADIRNDCK_230_MA1

Tue 12/17/2019 to Fri 12/20/2019
0700 Continuous 1500

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

FWD
(Import)

MOSES__-ADIRNDCK_230_MA1

Thu 01/02/2020 to Fri 05/29/2020
0700 Continuous 1300

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

FWD
(Import)

LADENTWN-BUCHAN_S_345_Y88

Wed 01/15/2020 to Thu 02/13/2020
0001 Continuous 2359

Work scheduled by: ORU

11/05/2018

UPNY CONED **4800 MW**
Impacts Total Transfer Capability 900 MW
TTC with All Lines In Service 5700 MW

FWD
(Import)

NYISO TRANSFER LIMITATIONS

Friday ,June 21, 2019 to Sunday ,December 20, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						FWD
DOLSONAV-ROCKTVRN_345_DART44						(Import)
Mon 04/27/2020	to	Sun 05/10/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>03/21/2019</u>	CENTRAL EAST - VC 2720 MW
0700	Continuous	1730				Impacts Total Transfer Capability 255 MW
Work scheduled by: NYPA						TTC with All Lines In Service 2975 MW
<hr/>						FWD
SCH-IMO-NYISO_LIMIT_1600						(Import)
Fri 05/01/2020	to	Sat 10/31/2020	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	SCH - OH - NY 1900 MW
0001	Continuous	2359				Impacts Total Transfer Capability 0 MW
Work scheduled by: IESO						TTC with All Lines In Service 1900 MW
<hr/>						FWD
COOPERS_-DOLSONAV_345_CCDA42						(Import)
Mon 05/11/2020	to	Fri 05/29/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>03/21/2019</u>	CENTRAL EAST - VC 2720 MW
0700	Continuous	1730				Impacts Total Transfer Capability 255 MW
Work scheduled by: NYPA						TTC with All Lines In Service 2975 MW
<hr/>						FWD
MOSES_-ADIRNDCK_230_MA2						(Import)
Mon 06/01/2020	to	Sat 11/14/2020				MOSES SOUTH 2100 MW
0700	Continuous	1300				Impacts Total Transfer Capability 1050 MW
Work scheduled by: NYPA						TTC with All Lines In Service 3150 MW
<hr/>						FWD
FRASANNX-COOPERS_345_UCC2-41						(Import)
Mon 09/07/2020	to	Fri 10/23/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>03/01/2019</u>	CENTRAL EAST - VC 2500 MW
0700	Continuous	1730				Impacts Total Transfer Capability 475 MW
Work scheduled by: NYPA					ARR: 19	TTC with All Lines In Service 2975 MW
<hr/>						FWD
MARCY_-FRASANNX_345_UCC2-41						(Import)
Mon 09/07/2020	to	Fri 10/23/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>03/01/2019</u>	CENTRAL EAST - VC 2500 MW
0700	Continuous	1730				Impacts Total Transfer Capability 475 MW
Work scheduled by: NYPA					ARR: 19	TTC with All Lines In Service 2975 MW
<hr/>						FWD
SCH-IMO-NYISO_LIMIT_1750						(Import)
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	SCH - OH - NY 2050 MW
0001	Continuous	2359				Impacts Total Transfer Capability 200 MW
Work scheduled by: IESO						TTC with All Lines In Service 2250 MW

NYISO TRANSFER LIMITATIONS

Friday ,June 21, 2019 to Sunday ,December 20, 2020

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-IMO_LIMIT_1600

Sun 11/01/2020 to Fri 04/30/2021
 0001 Continuous 2359

Work scheduled by: IESO

UPDATED by IESO 05/03/2019

SCH - OH - NY
 Impacts Total Transfer Capability 1900 MW
 TTC with All Lines In Service 2000 MW

REV
 (Export)

MOSES -ADIRNDCK_230_MAI

Tue 12/01/2020 to Mon 05/31/2021
 0700 Continuous 1300

Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH 2300 MW
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW