

NYISO TRANSFER LIMITATIONS

Saturday ,October 12, 2019 to Monday ,April 12, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
HUDSONP_-FARRAGUT_345_B3402						
Mon 01/15/2018	to	Fri 05/01/2020	<u>EXTENDED</u>	<u>by CONED</u>	<u>10/08/2019</u>	
0001	Continuous	2359				
Work scheduled by: ConEd					SCH - PJ - NY	2100 MW
					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	2150 MW
HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403						
Mon 01/15/2018	to	Fri 05/01/2020				
0001		2359				
Work scheduled by:					SCH - PJ - NY	2050 MW
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	2150 MW
MARION_-FARRAGUT_345_C3403						
Mon 01/15/2018	to	Fri 05/01/2020	<u>EXTENDED</u>	<u>by CONED</u>	<u>10/08/2019</u>	
0001	Continuous	2359				
Work scheduled by: ConEd					SCH - PJ - NY	2100 MW
					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	2150 MW
STLAWRNC-MOSES_230_L33P						
Mon 04/30/2018	to	Fri 12/31/2021	<u>EXT FORCE</u>	<u>by IESO</u>	<u>08/21/2018</u>	
0456	Continuous	2359				
Work scheduled by: IESO					SCH - OH - NY	
					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
BECK_-NIAGARA_345_PA302						
Wed 07/31/2019	to	Tue 11/12/2019	<u>EXTENDED</u>	<u>by IESO</u>	<u>08/29/2019</u>	
0800	Continuous	1700				
Work scheduled by: IESO					SCH - OH - NY	900 MW
					Impacts Total Transfer Capability	1000 MW
					TTC with All Lines In Service	1900 MW
NIAGARA_-PACKARD_230_61						
Tue 09/03/2019	to	Fri 10/18/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>12/19/2018</u>	
0500	Continuous	1700				
Work scheduled by: NYPA					SCH - OH - NY	
					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
PLSNTVLY_345KV_RNS5						
Sat 09/14/2019	to	Sat 10/19/2019	<u>UPDATED</u>	<u>by CE</u>	<u>10/10/2019</u>	
0001	Continuous	0300				
Work scheduled by: ConEd					UPNY CONED	3800 MW
					Impacts Total Transfer Capability	1900 MW
					TTC with All Lines In Service	5700 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 12, 2019 to Monday ,April 12, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LEEDS___-HURLYAVE_345_301

Mon 09/30/2019 to Fri 10/11/2019
0800 Continuous 1600

UPDATED by CHGE 09/05/2019

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 1600 MW
TTC with All Lines In Service 5700 MW

FROST_BR-LONG_MTN_345_352

Wed 10/02/2019 to Fri 10/18/2019
0700 Continuous 1600

UPDATED by ISONE 09/30/2019

Work scheduled by: ISONE

FWD
(Import)
SCH - NE - NY **1150 MW**
Impacts Total Transfer Capability 250 MW
TTC with All Lines In Service 1400 MW

SCH-NE-NYISO_LIMIT_400

Wed 10/02/2019 to Fri 10/18/2019
0700 Continuous 1600

UPDATED by ISONE 09/30/2019

Work scheduled by: ISONE

FWD
(Import)
SCH - NE - NY **600 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 1400 MW

DUNWODIE_345KV_4

Thu 10/03/2019 to Sun 10/13/2019
0001 Continuous 0300

UPDATED by CE 09/30/2019

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

SPRNBK__345KV_RS3 & SPRNBK__345KV_RS4

Fri 10/04/2019 to Mon 10/14/2019
0201 2230

Work scheduled by:

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

SCH-NE-NYISO_LIMIT_300

Sat 10/05/2019 to Fri 10/18/2019
1601 Continuous 1600

UPDATED by ISONE 09/30/2019

Work scheduled by: ISONE

FWD
(Import)
SCH - NE - NY **500 MW**
Impacts Total Transfer Capability 900 MW
TTC with All Lines In Service 1400 MW

SCH-IMO-NYISO_LIMIT_400

Sun 10/06/2019 to Tue 10/08/2019
0500 Continuous 2100

UPDATED by NYPA 09/26/2019

Work scheduled by: NYPA

FWD
(Import)
SCH - OH - NY **700 MW**
Impacts Total Transfer Capability 1200 MW
TTC with All Lines In Service 1900 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 12, 2019 to Monday ,April 12, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC2				FWD
Mon 10/07/2019	to	Fri 10/11/2019		(Import)
0400	Continuous	2359	MOSES SOUTH	2850 MW
Work scheduled by: HQ				Impacts Total Transfer Capability 300 MW
				TTC with All Lines In Service 3150 MW
CHAT_DC_GC2				REV
Mon 10/07/2019	to	Fri 10/11/2019		(Export)
0400	Continuous	2359	SCH - HQ - NY	500 MW
Work scheduled by: HQ				Impacts Total Transfer Capability 500 MW
				TTC with All Lines In Service 1000 MW
SCH-HQ-NYISO_LIMIT_1100				FWD
Mon 10/07/2019	to	Fri 11/22/2019		(Import)
0400	Continuous	2300	SCH - HQ - NY	1100 MW
Work scheduled by: HQ				Impacts Total Transfer Capability 400 MW
				TTC with All Lines In Service 1500 MW
CLAY -EDIC 345_2-15				FWD
Mon 10/07/2019	to	Fri 10/11/2019		(Import)
0600	Continuous	1530	OSWEGO EXPORT	4850 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 400 MW
				TTC with All Lines In Service 5250 MW
STOLLERD-HISHELDN_230_67				FWD
Mon 10/07/2019	to	Tue 10/08/2019		(Import)
0700	Continuous	1400	DYSINGER EAST	2850 MW
Work scheduled by: NYSEG				Impacts Total Transfer Capability 300 MW
				TTC with All Lines In Service 3150 MW
MARCY -N.SCTLND_345_18				FWD
Wed 10/09/2019	to	Thu 10/10/2019	UPDATED by NGRID 10/01/2019	(Import)
0500	Continuous	1730		CENTRAL EAST - VC 2090 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 885 MW
				TTC with All Lines In Service 2975 MW
SHORE_RD_345_138_BK_1				FWD
Wed 10/09/2019	to	Fri 10/11/2019	FORCED by CONED 10/10/2019	(Import)
1825	Continuous	1902		CONED - LIPA 1350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 150 MW
				TTC with All Lines In Service 1500 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 12, 2019 to Monday ,April 12, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SHORE_RD_345_138_BK 2					FWD	
Wed 10/09/2019	to	Fri 10/11/2019	FORCED	by CONED	10/10/2019	(Import)
1825	Continuous	1902				CONED - LIPA 1350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	150 MW
					TTC with All Lines In Service	1500 MW
DUNWODIE-SHORE_RD_345_Y50					FWD	
Wed 10/09/2019	to	Fri 10/11/2019	FORCED	by CONED	10/10/2019	(Import)
1825	Continuous	2359				CONED - LIPA 800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	700 MW
					TTC with All Lines In Service	1500 MW
CHAT_DC_GC1					FWD	
Sat 10/12/2019	to	Sat 10/12/2019	UPDATED	by HQ	10/04/2019	(Import)
0001	Continuous	0200				MOSES SOUTH 2850 MW
Work scheduled by: HQ					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW
CHAT_DC_GC1						REV
Sat 10/12/2019	to	Sat 10/12/2019	UPDATED	by HQ	10/04/2019	(Export)
0001	Continuous	0200				SCH - HQ - NY 500 MW
Work scheduled by: HQ					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1000 MW
CHAT_DC_GC1 & CHAT_DC_GC2					FWD	
Sat 10/12/2019	to	Sat 10/12/2019				(Import)
0001		0200				MOSES SOUTH 2550 MW
Work scheduled by:					Impacts Total Transfer Capability	600 MW
					TTC with All Lines In Service	3150 MW
CHAT_DC_GC1 & CHAT_DC_GC2					FWD	REV
Sat 10/12/2019	to	Sat 10/12/2019				(Import) (Export)
0001		0200				SCH - HQ - NY 1370 MW 0 MW
Work scheduled by:					Impacts Total Transfer Capability	130 MW 1000 MW
					TTC with All Lines In Service	1500 MW 1000 MW
CHAT_DC_GC2					FWD	
Sat 10/12/2019	to	Sat 10/12/2019	UPDATED	by HQ	10/04/2019	(Import)
0001	Continuous	0200				MOSES SOUTH 2850 MW
Work scheduled by: HQ					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 12, 2019 to Monday ,April 12, 2021

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event ID	Start	End	Status	By	Date	Impact	Capacity	Notes
CHAT_DC_GC2								
Sat 10/12/2019 0001	to	Sat 10/12/2019 0200	<u>UPDATED</u>	<u>by HQ</u>	<u>10/04/2019</u>	SCH - HQ - NY	500 MW	REV (Export)
Work scheduled by: HQ						Impacts Total Transfer Capability	500 MW	
						TTC with All Lines In Service	1000 MW	
SCH-HQ-NYISO_LIMIT_600								
Sat 10/12/2019 0001	to	Sat 10/12/2019 0200	<u>UPDATED</u>	<u>by HQ</u>	<u>10/04/2019</u>	SCH - HQ - NY	600 MW	FWD (Import)
Work scheduled by: HQ						Impacts Total Transfer Capability	900 MW	
						TTC with All Lines In Service	1500 MW	
LEEDS___-PLSNTVLY_345_92								
Sat 10/12/2019 0001	to	Tue 10/15/2019 0200	<u>UPDATED</u>	<u>by CE</u>	<u>10/10/2019</u>	UPNY CONED	3800 MW	FWD (Import)
Work scheduled by: ConEd						Impacts Total Transfer Capability	1900 MW	
						TTC with All Lines In Service	5700 MW	
CHAT_DC_GC1 & CHAT_DC_GC2 & MOSES___-MASSENA_230_MMS1 & MOSES___-MASSENA_230_MMS2								
Sat 10/12/2019 0100	to	Sat 10/12/2019 0200				MOSES SOUTH	1950 MW	FWD (Import)
Work scheduled by:						Impacts Total Transfer Capability	1200 MW	
						TTC with All Lines In Service	3150 MW	
CHATGUAY-MASSENA_765_7040								
Sat 10/12/2019 0100	to	Tue 10/22/2019 2000	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/09/2019</u>	MOSES SOUTH	1550 MW	FWD (Import)
Work scheduled by: NYPA						Impacts Total Transfer Capability	1600 MW	
						TTC with All Lines In Service	3150 MW	
CHATGUAY-MASSENA_765_7040								
Sat 10/12/2019 0100	to	Tue 10/22/2019 2000	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/09/2019</u>	SCH - HQ - NY	0 MW	FWD (Import) (Export)
Work scheduled by: NYPA						Impacts Total Transfer Capability	1500 MW	1000 MW
						TTC with All Lines In Service	1500 MW	1000 MW
MARCY___765_345_AT1								
Sat 10/12/2019 0100	to	Tue 10/22/2019 2000	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/09/2019</u>	MOSES SOUTH	1750 MW	FWD (Import)
Work scheduled by: NYPA						Impacts Total Transfer Capability	1400 MW	
						TTC with All Lines In Service	3150 MW	

ARR: 19

NYISO TRANSFER LIMITATIONS

Saturday ,October 12, 2019 to Monday ,April 12, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT2						FWD		
Sat 10/12/2019	to	Tue 10/22/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/09/2019</u>	(Import)		
0100	Continuous	2000				MOSES SOUTH	1700 MW	
Work scheduled by: NYPA						Impacts Total Transfer Capability	1450 MW	
						TTC with All Lines In Service	3150 MW	
MASSENA_-MARCY___765_MSU1						FWD		
Sat 10/12/2019	to	Tue 10/22/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/09/2019</u>	(Import)		
0100	Continuous	2000				CENTRAL EAST - VC	2265 MW	
Work scheduled by: NYPA						Impacts Total Transfer Capability	710 MW	
						TTC with All Lines In Service	2975 MW	
MASSENA_-MARCY___765_MSU1						FWD		
Sat 10/12/2019	to	Tue 10/22/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/09/2019</u>	(Import)		
0100	Continuous	2000				MOSES SOUTH	500 MW	
Work scheduled by: NYPA						Impacts Total Transfer Capability	2650 MW	
						TTC with All Lines In Service	3150 MW	
MASSENA_-MARCY___765_MSU1						FWD	REV	
Sat 10/12/2019	to	Tue 10/22/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/09/2019</u>	(Import)	(Export)	
0100	Continuous	2000				SCH - HQ - NY	475 MW	1000 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	1025 MW	0 MW
						TTC with All Lines In Service	1500 MW	1000 MW
MASSENA_-MARCY___765_MSU1						FWD		
Sat 10/12/2019	to	Tue 10/22/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/09/2019</u>	(Import)		
0100	Continuous	2000				SCH - HQ_CEDARS	90 MW	
Work scheduled by: NYPA						Impacts Total Transfer Capability	100 MW	
						TTC with All Lines In Service	190 MW	
MASSENA_-MARCY___765_MSU1 & CHATGUAY-MASSENA_765_7040						FWD		
Sat 10/12/2019	to	Tue 10/22/2019				(Import)		
0100		2000				MOSES SOUTH	500 MW	
Work scheduled by:						Impacts Total Transfer Capability	2650 MW	
						TTC with All Lines In Service	3150 MW	
MOSES___-MASSENA_230_MMS1 & MOSES___-MASSENA_230_MMS2						FWD	REV	
Sat 10/12/2019	to	Tue 10/22/2019				(Import)	(Export)	
0100		2000				SCH - HQ - NY	850 MW	0 MW
Work scheduled by:						Impacts Total Transfer Capability	650 MW	1000 MW
						TTC with All Lines In Service	1500 MW	1000 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 12, 2019 to Monday ,April 12, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2

Sat 10/12/2019 to Tue 10/22/2019
 0100 2000

Work scheduled by:

FWD
 (Import)
 SCH - HQ_CEDARS **90 MW**
 Impacts Total Transfer Capability 100 MW
 TTC with All Lines In Service 190 MW

STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1

Sat 10/12/2019 to Tue 10/22/2019
 0100 2000

Work scheduled by:

FWD
 (Import)
 SCH - HQ_CEDARS **90 MW**
 Impacts Total Transfer Capability 100 MW
 TTC with All Lines In Service 190 MW

STLAWRNC-MOSES 230_L33P & MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2

Sat 10/12/2019 to Tue 10/22/2019
 0100 2000

Work scheduled by:

FWD
 (Import)
 SCH - HQ_CEDARS **90 MW**
 Impacts Total Transfer Capability 100 MW
 TTC with All Lines In Service 190 MW

CHAT_DC_GC2

Sat 10/12/2019 to Sat 10/12/2019
 0201 Continuous 1959

Work scheduled by: HQ

FWD
 (Import)
 MOSES SOUTH **2850 MW**
 Impacts Total Transfer Capability 300 MW
 TTC with All Lines In Service 3150 MW

CHAT_DC_GC2

Sat 10/12/2019 to Sat 10/12/2019
 0201 Continuous 1959

Work scheduled by: HQ

REV
 (Export)
 SCH - HQ - NY **500 MW**
 Impacts Total Transfer Capability 500 MW
 TTC with All Lines In Service 1000 MW

SCH-IMO-NYISO_LIMIT_600

Sat 10/12/2019 to Sat 10/12/2019
 0900 Continuous 1630

Work scheduled by: IESO

FWD
 (Import)
 SCH - OH - NY **900 MW**
 Impacts Total Transfer Capability 1000 MW
 TTC with All Lines In Service 1900 MW

SCH-NYISO-IMO_LIMIT_300

Sat 10/12/2019 to Sat 10/12/2019
 0900 Continuous 1630

Work scheduled by: IESO

REV
 (Export)
 SCH - OH - NY **600 MW**
 Impacts Total Transfer Capability 1100 MW
 TTC with All Lines In Service 1700 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 12, 2019 to Monday ,April 12, 2021

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Transfer Period	Transfer Type	Transfer Capacity	Impact	TTC
CHAT_DC_GC1				
Sat 10/12/2019 to Sun 10/13/2019	Continuous	2000 to 2300	FWD (Import)	
Work scheduled by: HQ			MOSES SOUTH	2850 MW
			Impacts Total Transfer Capability	300 MW
			TTC with All Lines In Service	3150 MW
<hr/>				
CHAT_DC_GC1				
Sat 10/12/2019 to Sun 10/13/2019	Continuous	2000 to 2300	REV (Export)	
Work scheduled by: HQ			SCH - HQ - NY	500 MW
			Impacts Total Transfer Capability	500 MW
			TTC with All Lines In Service	1000 MW
<hr/>				
CHAT_DC_GC1 & CHAT_DC_GC2				
Sat 10/12/2019 to Sun 10/13/2019	Continuous	2000 to 2300	FWD (Import)	
Work scheduled by:			MOSES SOUTH	2550 MW
			Impacts Total Transfer Capability	600 MW
			TTC with All Lines In Service	3150 MW
<hr/>				
CHAT_DC_GC1 & CHAT_DC_GC2				
Sat 10/12/2019 to Sun 10/13/2019	Continuous	2000 to 2300	FWD (Import) REV (Export)	
Work scheduled by:			SCH - HQ - NY	1370 MW 0 MW
			Impacts Total Transfer Capability	130 MW 1000 MW
			TTC with All Lines In Service	1500 MW 1000 MW
<hr/>				
CHAT_DC_GC1 & CHAT_DC_GC2 & MOSES -MASSENA_230_MMS1 & MOSES -MASSENA_230_MMS2				
Sat 10/12/2019 to Sun 10/13/2019	Continuous	2000 to 2300	FWD (Import)	
Work scheduled by:			MOSES SOUTH	1950 MW
			Impacts Total Transfer Capability	1200 MW
			TTC with All Lines In Service	3150 MW
<hr/>				
CHAT_DC_GC2				
Sat 10/12/2019 to Sun 10/13/2019	Continuous	2000 to 2300	FWD (Import)	
Work scheduled by: HQ			MOSES SOUTH	2850 MW
			Impacts Total Transfer Capability	300 MW
			TTC with All Lines In Service	3150 MW
<hr/>				
CHAT_DC_GC2				
Sat 10/12/2019 to Sun 10/13/2019	Continuous	2000 to 2300	REV (Export)	
Work scheduled by: HQ			SCH - HQ - NY	500 MW
			Impacts Total Transfer Capability	500 MW
			TTC with All Lines In Service	1000 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 12, 2019 to Monday ,April 12, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCHEDULED WORK				IMPACTS	
Start Date	End Date	Time	Work Scheduled by	Transfer Capability (MW)	TTC with All Lines In Service (MW)
SCH-HQ-NYISO_LIMIT_1150					
Sat 10/12/2019	to	Sun 10/13/2019			
2000	Continuous	2300	HQ	1150 MW	1500 MW
Work scheduled by: HQ				Impacts Total Transfer Capability	350 MW
				TTC with All Lines In Service	1500 MW
E13THSTA-FARRAGUT_345_45					
Sun 10/13/2019	to	Mon 10/14/2019			
0001	Continuous	0200	ConEd	3800 MW	4600 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
CHAT_DC_GC2					
Sun 10/13/2019	to	Fri 11/22/2019			
2301	Continuous	2300	HQ	2850 MW	3150 MW
Work scheduled by: HQ				Impacts Total Transfer Capability	300 MW
				TTC with All Lines In Service	3150 MW
CHAT_DC_GC2					
Sun 10/13/2019	to	Fri 11/22/2019			
2301	Continuous	2300	HQ	500 MW	1000 MW
Work scheduled by: HQ				Impacts Total Transfer Capability	500 MW
				TTC with All Lines In Service	1000 MW
SHORE_RD_345_138_BK_2					
Mon 10/14/2019	to	Mon 10/14/2019	<u>UPDATED</u> by <u>LI</u> <u>10/02/2019</u>		
0001	Continuous	2359	LI	1350 MW	1500 MW
Work scheduled by: LI				Impacts Total Transfer Capability	150 MW
				TTC with All Lines In Service	1500 MW
MOTTHAVN-RAINEY_345_Q12					
Mon 10/14/2019	to	Tue 10/15/2019			
0001	Continuous	2359	ConEd	3800 MW	4600 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
SHOR_NPX-SHOREHAM_138_CSC					
Mon 10/14/2019	to	Fri 10/18/2019	<u>UPDATED</u> by <u>ISONE</u> <u>08/09/2019</u>		
0600	Continuous	1600	LI	0 MW	330 MW
Work scheduled by: LI				Impacts Total Transfer Capability	330 MW
				TTC with All Lines In Service	330 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 12, 2019 to Monday ,April 12, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FIVEMILE-STOLLERD_345_29					FWD	
Mon 10/14/2019	to	Fri 10/18/2019	<u>UPDATED</u>	<u>by NGRID</u>	<u>10/08/2019</u>	(Import)
0700	Continuous	1400				SCH - PJ - NY 2100 MW
Work scheduled by: NYSEG					Impacts Total Transfer Capability 50 MW	TTC with All Lines In Service 2150 MW
PLSNTVLY-WOOD_ST_345_F30					FWD	
Tue 10/15/2019	to	Thu 10/17/2019	<u>UPDATED</u>	<u>by CE</u>	<u>10/10/2019</u>	(Import)
0301	Continuous	0300				UPNY CONED 4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1700 MW	TTC with All Lines In Service 5700 MW
LEEDS__-HURLYAVE_345_301					FWD	
Tue 10/15/2019	to	Fri 10/18/2019	<u>UPDATED</u>	<u>by CHGE</u>	<u>09/05/2019</u>	(Import)
0800	Continuous	1600				UPNY CONED 4100 MW
Work scheduled by: CHGE					Impacts Total Transfer Capability 1600 MW	TTC with All Lines In Service 5700 MW
NEPTUNE_-DUFFYAVE_345_NEPTUNE					FWD	
Thu 10/17/2019	to	Wed 10/23/2019				(Import)
0001	Continuous	2359				SCH - PJM_NEPTUNE 0 MW
Work scheduled by: LI					Impacts Total Transfer Capability 660 MW	TTC with All Lines In Service 660 MW
NEWBRDGE-DUFFYAVE_345_501					FWD	
Thu 10/17/2019	to	Wed 10/23/2019				(Import)
0001	Continuous	2359				SCH - PJM_NEPTUNE 0 MW
Work scheduled by: LI					Impacts Total Transfer Capability 660 MW	TTC with All Lines In Service 660 MW
NEWBRDGE_345_138_BK_1					FWD	
Thu 10/17/2019	to	Wed 10/23/2019				(Import)
0001	Continuous	2359				SCH - PJM_NEPTUNE 375 MW
Work scheduled by: LI					Impacts Total Transfer Capability 285 MW	TTC with All Lines In Service 660 MW
NEWBRDGE_345_138_BK_2					FWD	
Thu 10/17/2019	to	Wed 10/23/2019				(Import)
0001	Continuous	2359				SCH - PJM_NEPTUNE 375 MW
Work scheduled by: LI					Impacts Total Transfer Capability 285 MW	TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 12, 2019 to Monday ,April 12, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4

Thu 10/17/2019 to Thu 10/17/2019
 0900 1559

Work scheduled by:

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 1900 MW
 TTC with All Lines In Service 5700 MW

DUNWODIE_345KV_7

Fri 10/18/2019 to Fri 10/18/2019
 0001 Continuous 0030

Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_8

Fri 10/18/2019 to Fri 10/18/2019
 0001 Continuous 0030

Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE-MOTTHAVN_345_72

Fri 10/18/2019 to Sat 10/19/2019
 0001 Continuous 0300

Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4

Fri 10/18/2019 to Fri 10/18/2019
 0900 1559

Work scheduled by:

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 1900 MW
 TTC with All Lines In Service 5700 MW

DUNWODIE_345KV_7

Sat 10/19/2019 to Sat 10/19/2019
 0230 Continuous 0300

Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_8

Sat 10/19/2019 to Sat 10/19/2019
 0230 Continuous 0300

Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 12, 2019 to Monday ,April 12, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

KINTIGH_-ROCHESTR_345_SR1-39					FWD
Sat 10/19/2019	to	Sun 10/27/2019			(Import)
0700	Continuous	1900		DYSINGER EAST	1400 MW
Work scheduled by: RGE					Impacts Total Transfer Capability 1750 MW
					TTC with All Lines In Service 3150 MW
SHORE_RD_345_138_BK_2					FWD
Mon 10/21/2019	to	Mon 10/21/2019	<u>UPDATED</u>	<u>by LI</u>	<u>10/02/2019</u>
0001	Continuous	2359		CONED - LIPA	1350 MW
Work scheduled by: LI					Impacts Total Transfer Capability 150 MW
					TTC with All Lines In Service 1500 MW
HURLYAVE-ROSETON__345_303					FWD
Mon 10/21/2019	to	Thu 10/31/2019			(Import)
0800	Continuous	1600		UPNY CONED	4100 MW
Work scheduled by: CHGE					Impacts Total Transfer Capability 1600 MW
					TTC with All Lines In Service 5700 MW
GILBOA_-N.SCTLND_345_GNS-1					FWD
Tue 10/22/2019	to	Thu 10/24/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/10/2019</u>
0700	Continuous	1730		CENTRAL EAST - VC	2520 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 455 MW
					TTC with All Lines In Service 2975 MW
WATRCURE_345_230_BK_1					
Tue 10/22/2019	to	Tue 10/22/2019			
0800	Continuous	1530		SCH - PJ - NY	
Work scheduled by: NYSEG					Impacts Total Transfer Capability
					TTC with All Lines In Service
NIAGARA__345_230_AT4					REV
Wed 10/23/2019	to	Tue 12/17/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/10/2019</u>
0500	Continuous	1700		SCH - OH - NY	1400 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 300 MW
					TTC with All Lines In Service 1700 MW
DENNISON-ROSEMNTA_115_1/11					FWD REV
Wed 10/23/2019	to	Wed 10/23/2019	<u>CANCELLED</u>	<u>by NGrid</u>	<u>10/11/2019</u>
0700	Daily(No Weekends)	1200		SCH - HQ_CEDARS	95 MW 40 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 95 MW 0 MW
					TTC with All Lines In Service 190 MW 40 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 12, 2019 to Monday ,April 12, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Transfer ID	Start Date	End Date	Time	Frequency	Work Scheduled by	Update Info	Schedule	Impact	TTC
CEDARS__ -ROSEMNTA_115_1/11	Wed 10/23/2019	Wed 10/23/2019	0700	Daily	NGrid		SCH - HQ_CEDARS	95 MW	40 MW
				(No Weekends)			Impacts Total Transfer Capability	95 MW	0 MW
							TTC with All Lines In Service	190 MW	40 MW
DENNISON-ROSEMNTA_115_1/11	Wed 10/23/2019	Wed 10/23/2019	0700	Daily	NGrid		SCH - HQ_CEDARS	95 MW	40 MW
				(No Weekends)			Impacts Total Transfer Capability	95 MW	0 MW
							TTC with All Lines In Service	190 MW	40 MW
EGRDNCTY_345_138_AT1	Thu 10/24/2019	Sun 11/03/2019	0001	Continuous	LI	<u>UPDATED</u> <u>by CE</u> <u>09/12/2019</u>	CONED - LIPA	1250 MW	
							Impacts Total Transfer Capability	250 MW	
							TTC with All Lines In Service	1500 MW	
EGRDNCTY_345_138_AT2	Thu 10/24/2019	Sun 11/03/2019	0001	Continuous	LI	<u>UPDATED</u> <u>by CE</u> <u>09/12/2019</u>	CONED - LIPA	1250 MW	
							Impacts Total Transfer Capability	250 MW	
							TTC with All Lines In Service	1500 MW	
SPRNBRK_-EGRDNCTR_345_Y49	Thu 10/24/2019	Sun 11/03/2019	0001	Continuous	LI	<u>UPDATED</u> <u>by CE</u> <u>09/12/2019</u>	CONED - LIPA	775 MW	
							Impacts Total Transfer Capability	725 MW	
							TTC with All Lines In Service	1500 MW	
GILBOA_-N.SCTLND_345_GNS-1	Fri 10/25/2019	Fri 10/25/2019	1630	Continuous	NYPA	<u>UPDATED</u> <u>by NYPA</u> <u>09/19/2019</u>	CENTRAL EAST - VC	2520 MW	
							Impacts Total Transfer Capability	455 MW	
							TTC with All Lines In Service	2975 MW	
SHORE_RD_345_138_BK_1	Mon 10/28/2019	Mon 10/28/2019	0001	Continuous	LI	<u>UPDATED</u> <u>by LI</u> <u>10/02/2019</u>	CONED - LIPA	1350 MW	
							Impacts Total Transfer Capability	150 MW	
							TTC with All Lines In Service	1500 MW	

NYISO TRANSFER LIMITATIONS

Saturday ,October 12, 2019 to Monday ,April 12, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
NIAGARA_-ROCHESTR_345_NR2				(Import)	
Mon 10/28/2019	to	Wed 11/13/2019	UPDATED by NYPA 10/08/2019	DYSINGER EAST	1400 MW
0500	Continuous	1700		Impacts Total Transfer Capability	1750 MW
Work scheduled by: NYPA				TTC with All Lines In Service	3150 MW
HOPATCON-RAMAPO__500_5018				(Import)	(Export)
Fri 11/01/2019	to	Tue 11/05/2019		SCH - PJ - NY	1250 MW 1200 MW
0001	Continuous	2200		Impacts Total Transfer Capability	1350 MW 350 MW
Work scheduled by: ConEd				TTC with All Lines In Service	2600 MW 1550 MW
HOPATCON-RAMAPO__500_5018				(Import)	
Fri 11/01/2019	to	Tue 11/05/2019		UPNY CONED	5000 MW
0001	Continuous	2200		Impacts Total Transfer Capability	700 MW
Work scheduled by: ConEd				TTC with All Lines In Service	5700 MW
RAMAPO__345_345_PAR3500				(Import)	(Export)
Fri 11/01/2019	to	Tue 11/05/2019		SCH - PJ - NY	2150 MW 1250 MW
0001	Continuous	2200		Impacts Total Transfer Capability	450 MW 300 MW
Work scheduled by: ConEd				TTC with All Lines In Service	2600 MW 1550 MW
RAMAPO__345_345_PAR4500				(Import)	(Export)
Fri 11/01/2019	to	Tue 11/05/2019		SCH - PJ - NY	2150 MW 1250 MW
0001	Continuous	2200		Impacts Total Transfer Capability	450 MW 300 MW
Work scheduled by: ConEd				TTC with All Lines In Service	2600 MW 1550 MW
RAMAPO__500_345_BK 1500				(Import)	(Export)
Fri 11/01/2019	to	Tue 11/05/2019		SCH - PJ - NY	1250 MW 1200 MW
0001	Continuous	2200		Impacts Total Transfer Capability	1350 MW 350 MW
Work scheduled by: ConEd				TTC with All Lines In Service	2600 MW 1550 MW
RAMAPO__500_345_BK 1500				(Import)	
Fri 11/01/2019	to	Tue 11/05/2019		UPNY CONED	5000 MW
0001	Continuous	2200		Impacts Total Transfer Capability	700 MW
Work scheduled by: ConEd				TTC with All Lines In Service	5700 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 12, 2019 to Monday ,April 12, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO-NYISO_LIMIT_1750					FWD	
Fri 11/01/2019	to	Thu 04/30/2020	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Import)
0001	Continuous	2359				2050 MW
Work scheduled by: IESO					SCH - OH - NY	Impacts Total Transfer Capability 200 MW
					TTC with All Lines In Service	2250 MW
SCH-NYISO-IMO_LIMIT_1600					REV	
Fri 11/01/2019	to	Thu 04/30/2020	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Export)
0001	Continuous	2359				1900 MW
Work scheduled by: IESO					SCH - OH - NY	Impacts Total Transfer Capability 100 MW
					TTC with All Lines In Service	2000 MW
VOLNEY_-MARCY___345_19					FWD	
Fri 11/01/2019	to	Fri 11/01/2019				(Import)
0730	Daily(No Weekends)	1630				2825 MW
Work scheduled by: NGrid					CENTRAL EAST - VC	Impacts Total Transfer Capability 150 MW
					TTC with All Lines In Service	2975 MW
VOLNEY_-MARCY___345_19					FWD	
Fri 11/01/2019	to	Fri 11/01/2019				(Import)
0730	Daily(No Weekends)	1630				4900 MW
Work scheduled by: NGrid					OSWEGO EXPORT	Impacts Total Transfer Capability 350 MW
					TTC with All Lines In Service	5250 MW
SHORE_RD_345_138_BK_1					FWD	
Mon 11/04/2019	to	Mon 11/04/2019	<u>UPDATED</u>	<u>by LI</u>	<u>10/02/2019</u>	(Import)
0001	Continuous	2359				1350 MW
Work scheduled by: LI					CONED - LIPA	Impacts Total Transfer Capability 150 MW
					TTC with All Lines In Service	1500 MW
NRTH1385-NOR_HBR___138_601					FWD	REV
Mon 11/04/2019	to	Fri 11/15/2019				(Import) (Export)
0001	Continuous	2359				100 MW 100 MW
Work scheduled by: LI					SCH - NPX_1385	Impacts Total Transfer Capability 100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR_HBR___138_601 & NRTH1385-NOR_HBR___138_602					FWD	REV
Mon 11/04/2019	to	Fri 11/15/2019				(Import) (Export)
0001		2359				0 MW 0 MW
Work scheduled by:					SCH - NPX_1385	Impacts Total Transfer Capability 200 MW 200 MW
					TTC with All Lines In Service	200 MW 200 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 12, 2019 to Monday ,April 12, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_603					
Mon 11/04/2019	to	Fri 11/15/2019			
0001		2359	SCH - NPX_1385	0 MW	0 MW
Work scheduled by:				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR__138_602					
Mon 11/04/2019	to	Fri 11/15/2019			
0001	Continuous	2359	SCH - NPX_1385	100 MW	100 MW
Work scheduled by: LI				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR__138_602 & NRTH1385-NOR HBR__138_603					
Mon 11/04/2019	to	Fri 11/15/2019			
0001		2359	SCH - NPX_1385	0 MW	0 MW
Work scheduled by:				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR__138_603					
Mon 11/04/2019	to	Fri 11/15/2019			
0001	Continuous	2359	SCH - NPX_1385	100 MW	100 MW
Work scheduled by: LI				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	200 MW
NRTH1385-NRTHPORT_138_NNC					
Mon 11/04/2019	to	Fri 11/15/2019			
0001	Continuous	2359	SCH - NPX_1385	0 MW	0 MW
Work scheduled by: LI				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	200 MW
LINDN_CG-LNDVFT__345_V-3022					
Mon 11/04/2019	to	Thu 11/07/2019			
0800	Continuous	1500	SCH - PJM_VFT	0 MW	0 MW
Work scheduled by: PJM				Impacts Total Transfer Capability	315 MW
				TTC with All Lines In Service	315 MW
MARCY__-N.SCTLND_345_18					
Wed 11/06/2019	to	Wed 11/13/2019	UPDATED	by NYPA	09/11/2019
0500	Continuous	1730			
Work scheduled by: NYPA					
				ARR: 19	
				CENTRAL EAST - VC	2090 MW
				Impacts Total Transfer Capability	885 MW
				TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 12, 2019 to Monday ,April 12, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___345KV_CSC					FWD	
Wed 11/06/2019	to	Fri 11/22/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/11/2019</u>	(Import)
0500	Continuous	1730				CENTRAL EAST - VC 2925 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 50 MW	
					TTC with All Lines In Service 2975 MW	
MARCY___765_345_AT2					FWD	
Wed 11/06/2019	to	Fri 11/22/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/11/2019</u>	(Import)
0500	Continuous	1730				MOSES SOUTH 1700 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 1450 MW	
					TTC with All Lines In Service 3150 MW	
HURLYAVE-ROSETON__345_303					FWD	
Wed 11/06/2019	to	Fri 12/06/2019				(Import)
0800	Continuous	1600				UPNY CONED 4100 MW
Work scheduled by: CHGE					Impacts Total Transfer Capability 1600 MW	
					TTC with All Lines In Service 5700 MW	
N. SCTLND-LEEDS___345_94					FWD	
Wed 11/06/2019	to	Thu 11/07/2019				(Import)
0830	Continuous	1430				CENTRAL EAST - VC 2650 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 325 MW	
					TTC with All Lines In Service 2975 MW	
PLSNTVLE-DUNWODIE_345_W89					FWD	
Fri 11/08/2019	to	Sat 11/09/2019				(Import)
0001	Continuous	0030				UPNY CONED 4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1700 MW	
					TTC with All Lines In Service 5700 MW	
E13THSTA-FARRAGUT_345_45					FWD	
Tue 11/12/2019	to	Tue 11/12/2019				(Import)
0001	Continuous	0030				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW	
					TTC with All Lines In Service 4600 MW	
WATRCURE-OAKDALE__345_31					FWD	
Tue 11/12/2019	to	Tue 11/12/2019	<u>UPDATED</u>	<u>by NYSEG</u>	<u>09/13/2019</u>	(Import) (Export)
1300	Continuous	1500				SCH - PJ - NY 2600 MW 1300 MW
Work scheduled by: NYSEG					Impacts Total Transfer Capability 0 MW 250 MW	
					TTC with All Lines In Service 2600 MW 1550 MW	

NYISO TRANSFER LIMITATIONS

Saturday ,October 12, 2019 to Monday ,April 12, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY-WOOD_ST__345_F31

Thu 11/14/2019 to Thu 11/14/2019
 0001 Continuous 2200
 Work scheduled by: ConEd

UPDATED by NYISO 09/18/2019

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 1700 MW
 TTC with All Lines In Service 5700 MW

PLSNTVLY_345KV_RNS4

Thu 11/14/2019 to Thu 11/14/2019
 0001 Continuous 2200
 Work scheduled by: ConEd

UPDATED by NYISO 09/18/2019

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 1900 MW
 TTC with All Lines In Service 5700 MW

E13THSTA-FARRAGUT_345_45

Thu 11/14/2019 to Thu 11/14/2019
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

W49TH_ST-E13THSTA_345_M54

Thu 11/14/2019 to Thu 11/14/2019
 0201 Continuous 0500
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

BUCHAN_N-EASTVIEW_345_W93

Sun 11/17/2019 to Mon 11/18/2019
 0301 Continuous 0300
 Work scheduled by: ConEd

UPDATED by CONED 09/09/2019

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

EASTVIEW-SPRNBRK__345_W79

Sun 11/17/2019 to Mon 11/18/2019
 0301 Continuous 0300
 Work scheduled by: ConEd

UPDATED by CONED 09/09/2019

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

SCH-NE-NYISO_LIMIT_500

Sun 11/17/2019 to Sun 11/17/2019
 1100 Continuous 1600
 Work scheduled by: ISONE

FWD
 (Import)
 SCH - NE - NY **700 MW**
 Impacts Total Transfer Capability 700 MW
 TTC with All Lines In Service 1400 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 12, 2019 to Monday ,April 12, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-NE_LIMIT_1200					REV
Sun 11/17/2019	to	Sun 11/17/2019			(Export)
1100	Continuous	1600		SCH - NE - NY	1400 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability 400 MW
					TTC with All Lines In Service 1800 MW
SPRNBRK_345KV_RNS5					FWD
Mon 11/18/2019	to	Mon 11/18/2019	<u>UPDATED</u>	<u>by CONED</u> <u>09/09/2019</u>	(Import)
0301	Continuous	0330		SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW
EASTVIEW-SPRNBRK_345_W64					FWD
Mon 11/18/2019	to	Tue 11/19/2019	<u>UPDATED</u>	<u>by CONED</u> <u>09/09/2019</u>	(Import)
0301	Continuous	0200		UPNY CONED	4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1350 MW
					TTC with All Lines In Service 5700 MW
MILLWOOD-EASTVIEW_345_W99					FWD
Mon 11/18/2019	to	Tue 11/19/2019	<u>UPDATED</u>	<u>by CONED</u> <u>09/09/2019</u>	(Import)
0301	Continuous	0200		UPNY CONED	4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1350 MW
					TTC with All Lines In Service 5700 MW
BERKSHIR-ALPS_345_393					FWD REV
Mon 11/18/2019	to	Wed 11/27/2019			(Import) (Export)
0600	Continuous	1700		SCH - NE - NY	1150 MW 1300 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability 250 MW 500 MW
					TTC with All Lines In Service 1400 MW 1800 MW
BERKSHIR-ALPS_345_393					FWD REV
Mon 11/18/2019	to	Wed 11/27/2019			(Import) (Export)
0600	Continuous	1700		SCH - NPX_1385	100 MW 100 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability 100 MW 100 MW
					TTC with All Lines In Service 200 MW 200 MW
BERKSHIR-ALPS_345_393 & BERKSHIR-NORTHFLD_345_312					FWD REV
Mon 11/18/2019	to	Wed 11/27/2019			(Import) (Export)
0600		1700		SCH - NE - NY	1150 MW 1300 MW
Work scheduled by:					Impacts Total Transfer Capability 250 MW 500 MW
					TTC with All Lines In Service 1400 MW 1800 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 12, 2019 to Monday ,April 12, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-NORTHFLD_345_312				FWD	REV
Mon 11/18/2019	to	Wed 11/27/2019		(Import)	(Export)
0600	Continuous	1700		SCH - NE - NY	1400 MW 1500 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability	0 MW 300 MW
				TTC with All Lines In Service	1400 MW 1800 MW
BERKSHIR-NORTHFLD_345_312				FWD	REV
Mon 11/18/2019	to	Wed 11/27/2019		(Import)	(Export)
0600	Continuous	1700		SCH - NPX_1385	100 MW 100 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability	100 MW 100 MW
				TTC with All Lines In Service	200 MW 200 MW
SCH-NE-NYISO_LIMIT_800				FWD	
Mon 11/18/2019	to	Wed 11/27/2019		(Import)	
0600	Continuous	1700		SCH - NE - NY	1000 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability	400 MW
				TTC with All Lines In Service	1400 MW
SCH-NYISO-NE_LIMIT_500					REV
Mon 11/18/2019	to	Wed 11/27/2019			(Export)
0600	Continuous	1700		SCH - NE - NY	700 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability	1100 MW
				TTC with All Lines In Service	1800 MW
SPRNBK__345KV_RNS5				FWD	
Tue 11/19/2019	to	Tue 11/19/2019		(Import)	
0001	Continuous	0030		SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	4600 MW
SPRNBK__345KV_RNS5				FWD	
Tue 11/19/2019	to	Tue 11/19/2019	UPDATED by CONED 09/09/2019	(Import)	
0130	Continuous	0200		SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	4600 MW
EASTVIEW-SPRNBK__345_W64				FWD	
Sat 11/23/2019	to	Sat 11/23/2019		(Import)	
0130	Continuous	0200		UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	1350 MW
				TTC with All Lines In Service	5700 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 12, 2019 to Monday ,April 12, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD-EASTVIEW_345_W99

Sat 11/23/2019 to Sat 11/23/2019
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

SPRNBRK_345KV_RNS5

Sat 11/23/2019 to Sat 11/23/2019
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

RAMAPO_-LADENTWN_345_W72

Mon 11/25/2019 to Mon 11/25/2019
 0001 Continuous 2200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4400 MW**
 Impacts Total Transfer Capability 1300 MW
 TTC with All Lines In Service 5700 MW

MOSES_-ADIRNDCK_230_MA2

Mon 11/25/2019 to Wed 11/27/2019
 0700 Continuous 1500
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

SHOR_NPX-SHOREHAM_138_CSC

Mon 12/02/2019 to Mon 12/02/2019 **UPDATED by ISONE 10/04/2019**
 0700 Continuous 2300
 Work scheduled by: LI

FWD REV
 (Import) (Export)
 SCH - NPX_CSC **0 MW 0 MW**
 Impacts Total Transfer Capability 330 MW 330 MW
 TTC with All Lines In Service 330 MW 330 MW

MOSES_-ADIRNDCK_230_MA2

Mon 12/02/2019 to Fri 12/06/2019
 0700 Continuous 1500
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

N.SCTLND-ALPS_345_2

Mon 12/02/2019 to Mon 12/02/2019
 0730 Daily(No Weekends) 1630
 Work scheduled by: NGrid

FWD REV
 (Import) (Export)
 SCH - NE - NY **900 MW 1700 MW**
 Impacts Total Transfer Capability 500 MW 100 MW
 TTC with All Lines In Service 1400 MW 1800 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 12, 2019 to Monday ,April 12, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
N. SCTLND-ALPS 345_2					
Mon 12/02/2019	to	Mon 12/02/2019			
0730	Daily(No Weekends)	1630	SCH - NPX_1385	100 MW	100 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	200 MW
FRASER 345_FRASER SVC					
Mon 12/02/2019	to	Fri 12/13/2019			
0800	Continuous	1500	CENTRAL EAST - VC	2935 MW	
Work scheduled by: NYSEG				Impacts Total Transfer Capability	40 MW
				TTC with All Lines In Service	2975 MW
LEEDS 345KV_R94301					
Tue 12/03/2019	to	Fri 12/13/2019	UPDATED by NGRID 10/04/2019		
0800	Continuous	1500	UPNY CONED	3800 MW	
Work scheduled by: NGrid				Impacts Total Transfer Capability	1900 MW
				TTC with All Lines In Service	5700 MW
MOSES -ADIRNDCK_230_MA1					
Mon 12/09/2019	to	Fri 12/13/2019			
0700	Continuous	1500	MOSES SOUTH	2300 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
ROSETON -ROCKTVRN_345_311					
Mon 12/09/2019	to	Thu 12/12/2019			
0800	Continuous	1600	UPNY CONED	4400 MW	
Work scheduled by: CHGE				Impacts Total Transfer Capability	1300 MW
				TTC with All Lines In Service	5700 MW
SHOR_NPX-SHOREHAM_138_CSC					
Thu 12/12/2019	to	Fri 12/20/2019			
0800	Continuous	1500	SCH - NPX_CSC	0 MW	0 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability	330 MW
				TTC with All Lines In Service	330 MW
MOSES -ADIRNDCK_230_MA2					
Mon 12/16/2019	to	Mon 12/16/2019			
0700	Continuous	1500	MOSES SOUTH	2300 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 12, 2019 to Monday ,April 12, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -ADIRNDCK_230_MA1				FWD	
Tue 12/17/2019	to	Fri 12/20/2019		(Import)	
0700	Continuous	1500	MOSES SOUTH	2300 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
SCH-NE-NYISO_LIMIT_500				FWD	
Fri 12/20/2019	to	Fri 12/20/2019	<u>UPDATED</u> <u>by ISONE</u> <u>10/11/2019</u>	(Import)	
0600	Continuous	1600	SCH - NE - NY	700 MW	
Work scheduled by: ISONE				Impacts Total Transfer Capability	700 MW
				TTC with All Lines In Service	1400 MW
SCH-NYISO-NE_LIMIT_1200				REV	
Fri 12/20/2019	to	Fri 12/20/2019	<u>UPDATED</u> <u>by ISONE</u> <u>10/11/2019</u>	(Export)	
0600	Continuous	1600	SCH - NE - NY	1400 MW	
Work scheduled by: ISONE				Impacts Total Transfer Capability	400 MW
				TTC with All Lines In Service	1800 MW
MOSES -ADIRNDCK_230_MA2				FWD	
Thu 01/02/2020	to	Sun 03/01/2020		(Import)	
0700	Continuous	1530	MOSES SOUTH	2300 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
LADENTWN-BUCHAN_S_345_Y88				FWD	
Wed 01/15/2020	to	Thu 02/13/2020	<u>11/05/2018</u>	(Import)	
0001	Continuous	2359	UPNY CONED	4800 MW	
Work scheduled by: ORU				Impacts Total Transfer Capability	900 MW
				TTC with All Lines In Service	5700 MW
MOTTHAVN-RAINEY_345_Q11				FWD	
Sun 02/23/2020	to	Sun 03/01/2020		(Import)	
0001	Continuous	0200	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
NIAGARA -PACKARD_230_62				FWD	REV
Fri 02/28/2020	to	Fri 02/28/2020		(Import)	(Export)
0500	Continuous	1530	SCH - OH - NY	1100 MW	950 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1150 MW 1050 MW
				TTC with All Lines In Service	2250 MW 2000 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 12, 2019 to Monday ,April 12, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						
CHATGUAY-MASSENA__765_7040					FWD	
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)
0500	Continuous	1730				1550 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 1600 MW
						TTC with All Lines In Service 3150 MW
<hr/>						
CHATGUAY-MASSENA__765_7040					FWD	REV
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import) (Export)
0500	Continuous	1730				0 MW 0 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 1500 MW 1000 MW
						TTC with All Lines In Service 1500 MW 1000 MW
<hr/>						
MARCY__765_345_AT1					FWD	
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)
0500	Continuous	1730				1750 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 1400 MW
						TTC with All Lines In Service 3150 MW
<hr/>						
MARCY__765_345_AT2					FWD	
Mon 03/02/2020	to	Fri 03/06/2020				(Import)
0500	Continuous	1730				1700 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 1450 MW
						TTC with All Lines In Service 3150 MW
<hr/>						
MASSENA_-MARCY__765_MSU1					FWD	
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)
0500	Continuous	1730				2265 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 710 MW
						TTC with All Lines In Service 2975 MW
<hr/>						
MASSENA_-MARCY__765_MSU1					FWD	
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)
0500	Continuous	1730				500 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 2650 MW
						TTC with All Lines In Service 3150 MW
<hr/>						
MASSENA_-MARCY__765_MSU1					FWD	REV
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import) (Export)
0500	Continuous	1730				475 MW 1000 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 1025 MW 0 MW
						TTC with All Lines In Service 1500 MW 1000 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 12, 2019 to Monday ,April 12, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA -MARCY 765_MSU1				FWD	
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u> <u>by NYPA</u> <u>08/08/2019</u>	(Import)	
0500	Continuous	1730		SCH - HQ_CEDARS	90 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	109 MW
				TTC with All Lines In Service	199 MW
MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040				FWD	
Mon 03/02/2020	to	Fri 03/06/2020		(Import)	
0500		1730		MOSES SOUTH	500 MW
Work scheduled by:				Impacts Total Transfer Capability	2650 MW
				TTC with All Lines In Service	3150 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2				FWD	REV
Mon 03/02/2020	to	Fri 03/06/2020		(Import)	(Export)
0500		1730		SCH - HQ - NY	850 MW 0 MW
Work scheduled by:				Impacts Total Transfer Capability	650 MW 1000 MW
				TTC with All Lines In Service	1500 MW 1000 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2				FWD	
Mon 03/02/2020	to	Fri 03/06/2020		(Import)	
0500		1730		SCH - HQ_CEDARS	90 MW
Work scheduled by:				Impacts Total Transfer Capability	109 MW
				TTC with All Lines In Service	199 MW
STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1				FWD	
Mon 03/02/2020	to	Fri 03/06/2020		(Import)	
0500		1730		SCH - HQ_CEDARS	90 MW
Work scheduled by:				Impacts Total Transfer Capability	109 MW
				TTC with All Lines In Service	199 MW
STLAWRNC-MOSES 230_L33P & MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2				FWD	
Mon 03/02/2020	to	Fri 03/06/2020		(Import)	
0500		1730		SCH - HQ_CEDARS	90 MW
Work scheduled by:				Impacts Total Transfer Capability	109 MW
				TTC with All Lines In Service	199 MW
EASTVIEW-SPRNBRK 345_W78				FWD	
Fri 03/06/2020	to	Sat 03/07/2020		(Import)	
0001	Continuous	0200		UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	1350 MW
				TTC with All Lines In Service	5700 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 12, 2019 to Monday ,April 12, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD-EASTVIEW_345_W85

Fri 03/06/2020 to Sat 03/07/2020
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

SPRNBRK_345KV_RNS3

Fri 03/06/2020 to Sat 03/07/2020
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

MOSES_-ADIRNDCK_230_MA1

Sat 03/07/2020 to Fri 05/29/2020
 0700 Continuous 1300
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

VOLNEY_-MARCY_345_19

Tue 03/10/2020 to Tue 03/10/2020 **UPDATED by NYPA 09/24/2019**
 0700 Continuous 1530
 Work scheduled by: NYPA **ARR: 19**

FWD
 (Import)
 CENTRAL EAST - VC **2825 MW**
 Impacts Total Transfer Capability 150 MW
 TTC with All Lines In Service 2975 MW

VOLNEY_-MARCY_345_19

Tue 03/10/2020 to Tue 03/10/2020 **UPDATED by NYPA 09/24/2019**
 0700 Continuous 1530
 Work scheduled by: NYPA **ARR: 19**

FWD
 (Import)
 OSWEGO EXPORT **4900 MW**
 Impacts Total Transfer Capability 350 MW
 TTC with All Lines In Service 5250 MW

FRASANX-COOPERS_345_UCC2-41

Wed 03/11/2020 to Thu 03/12/2020
 0700 Continuous 1530
 Work scheduled by: NYPA **ARR: 19**

FWD
 (Import)
 CENTRAL EAST - VC **2500 MW**
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

MARCY_-FRASANX_345_UCC2-41

Wed 03/11/2020 to Thu 03/12/2020
 0700 Continuous 1530
 Work scheduled by: NYPA **ARR: 19**

FWD
 (Import)
 CENTRAL EAST - VC **2500 MW**
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 12, 2019 to Monday ,April 12, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>ROCHESTR-PANNELL__345_RP2</p> <p>Sat 03/14/2020 to Mon 03/23/2020 0500 Continuous 1700</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import)</p> <p>DYSINGER EAST 2300 MW</p> <p>Impacts Total Transfer Capability 850 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>MARCY__345KV_CSC</p> <p>Mon 03/16/2020 to Fri 03/27/2020 0500 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import)</p> <p>CENTRAL EAST - VC 2925 MW</p> <p>Impacts Total Transfer Capability 50 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p>ROSETON_-EFISHKIL_345_RFK305</p> <p>Mon 03/16/2020 to Fri 04/03/2020 0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import)</p> <p>UPNY CONED 4800 MW</p> <p>Impacts Total Transfer Capability 900 MW</p> <p>TTC with All Lines In Service 5700 MW</p>
<p>NIAGARA_-KINTIGH__345_NS1-38</p> <p>Fri 03/27/2020 to Fri 03/27/2020 0600 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import)</p> <p>DYSINGER EAST 1700 MW</p> <p>Impacts Total Transfer Capability 1450 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>BECK__-PACKARD__230_BP76</p> <p>Fri 03/27/2020 to Fri 03/27/2020 0800 Daily(No Weekends) 1600</p> <p>Work scheduled by: NGrid</p>	<p>FWD REV (Import) (Export)</p> <p>SCH - OH - NY 1700 MW 1500 MW</p> <p>Impacts Total Transfer Capability 550 MW 500 MW</p> <p>TTC with All Lines In Service 2250 MW 2000 MW</p>
<p>MARCY__-EDIC__345_UE1-7</p> <p>Tue 03/31/2020 to Tue 03/31/2020 UPDATED by NYPA 09/24/2019 0700 Continuous 1530</p> <p>Work scheduled by: NYPA ARR: 19&16</p>	<p>FWD (Import)</p> <p>OSWEGO EXPORT 5250 MW</p> <p>Impacts Total Transfer Capability 0 MW</p> <p>TTC with All Lines In Service 5250 MW</p>
<p>MARCY__-N.SCTLND_345_18</p> <p>Tue 04/07/2020 to Wed 04/08/2020 UPDATED by NYPA 09/24/2019 0700 Continuous 1530</p> <p>Work scheduled by: NYPA ARR: 19</p>	<p>FWD (Import)</p> <p>CENTRAL EAST - VC 2090 MW</p> <p>Impacts Total Transfer Capability 885 MW</p> <p>TTC with All Lines In Service 2975 MW</p>

NYISO TRANSFER LIMITATIONS

Saturday ,October 12, 2019 to Monday ,April 12, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>LINDN_CG-LNDVFT___345_V-3022</p> <p>Sun 04/12/2020 to Fri 04/17/2020 1400 Continuous 1800</p> <p>Work scheduled by: PJM</p>	<p>FWD (Import) (Export)</p> <p>SCH - PJM_VFT 0 MW 0 MW</p> <p>Impacts Total Transfer Capability 315 MW 315 MW</p> <p>TTC with All Lines In Service 315 MW 315 MW</p>
<p>FRASER_-GILBOA___345_GF5-35</p> <p>Mon 04/13/2020 to Wed 04/22/2020 0700 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import)</p> <p>CENTRAL EAST - VC 2650 MW</p> <p>Impacts Total Transfer Capability 325 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p>NIAGARA_-ROCHESTR_345_NR2</p> <p>Mon 04/20/2020 to Fri 05/01/2020 0500 Continuous 1700</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import)</p> <p>DYSINGER EAST 1700 MW</p> <p>Impacts Total Transfer Capability 1450 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>DOLSONAV-ROCKTVRN_345_DART44</p> <p>Mon 04/27/2020 to Sun 05/10/2020 0700 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import)</p> <p>CENTRAL EAST - VC 2720 MW</p> <p>Impacts Total Transfer Capability 255 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p>LEEDS_-HURLYAVE_345_301</p> <p>Mon 04/27/2020 to Fri 05/29/2020 0800 Continuous 1600</p> <p>Work scheduled by: CHGE</p>	<p>FWD (Import)</p> <p>UPNY CONED 4100 MW</p> <p>Impacts Total Transfer Capability 1600 MW</p> <p>TTC with All Lines In Service 5700 MW</p>
<p>SCH-IMO-NYISO_LIMIT_1600</p> <p>Fri 05/01/2020 to Sat 10/31/2020 0001 Continuous 2359</p> <p>Work scheduled by: IESO</p>	<p>FWD (Import)</p> <p>SCH - OH - NY 1900 MW</p> <p>Impacts Total Transfer Capability 0 MW</p> <p>TTC with All Lines In Service 1900 MW</p>
<p>PANNELL_-CLAY___345_2</p> <p>Mon 05/04/2020 to Fri 05/08/2020 0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import)</p> <p>WEST CENTRAL 1300 MW</p> <p>Impacts Total Transfer Capability 950 MW</p> <p>TTC with All Lines In Service 2250 MW</p>

NYISO TRANSFER LIMITATIONS

Saturday ,October 12, 2019 to Monday ,April 12, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Mon 05/04/2020 to Mon 05/18/2020
 0800 Continuous 1700
 Work scheduled by: PJM

FWD
 (Import)
 SCH - PJM_NEPTUNE **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE-DUFFYAVE_345_501

Mon 05/04/2020 to Mon 05/18/2020
 0800 Continuous 1700
 Work scheduled by: PJM

FWD
 (Import)
 SCH - PJM_NEPTUNE **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_1

Mon 05/04/2020 to Mon 05/18/2020
 0800 Continuous 1700
 Work scheduled by: PJM

FWD
 (Import)
 SCH - PJM_NEPTUNE **375 MW**
 Impacts Total Transfer Capability 285 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_2

Mon 05/04/2020 to Mon 05/18/2020
 0800 Continuous 1700
 Work scheduled by: PJM

FWD
 (Import)
 SCH - PJM_NEPTUNE **375 MW**
 Impacts Total Transfer Capability 285 MW
 TTC with All Lines In Service 660 MW

PANNELL_-CLAY____345_1

Mon 05/11/2020 to Fri 05/15/2020
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 WEST CENTRAL **1300 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

COOPERS_-DOLSONAV_345_CCDA42

Mon 05/11/2020 to Fri 05/29/2020 **UPDATED by NYPA 03/21/2019**
 0700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2720 MW**
 Impacts Total Transfer Capability 255 MW
 TTC with All Lines In Service 2975 MW

NIAGARA_-ROCHESTR_345_NR2

Mon 05/18/2020 to Fri 05/22/2020
 0500 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **1400 MW**
 Impacts Total Transfer Capability 1750 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 12, 2019 to Monday ,April 12, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -ADIRNDCK_230_MA2					FWD	
Mon 06/01/2020	to	Fri 07/31/2020			(Import)	
0700	Continuous	1730		MOSES SOUTH	2100 MW	
Work scheduled by: NYPA					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	3150 MW
NIAGARA_345_230_AT4						REV
Mon 06/29/2020	to	Tue 06/30/2020			(Export)	
0500	Continuous	1530		SCH - OH - NY	1400 MW	
Work scheduled by: NYPA					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	1700 MW
SCH-IMO-NYISO_NIAG_CB_3008_W/BB					FWD	REV
Mon 07/27/2020	to	Fri 08/07/2020			(Import)	(Export)
0500	Continuous	1530		SCH - OH - NY	1900 MW	1450 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	1900 MW
CHATGUAY-MASSENA_765_7040					FWD	
Sat 08/01/2020	to	Sun 08/02/2020	UPDATED	by NYPA	08/08/2019	(Import)
0500	Continuous	1730				MOSES SOUTH
Work scheduled by: NYPA					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	3150 MW
CHATGUAY-MASSENA_765_7040					FWD	REV
Sat 08/01/2020	to	Sun 08/02/2020	UPDATED	by NYPA	08/08/2019	(Import)
0500	Continuous	1730				SCH - HQ - NY
Work scheduled by: NYPA					Impacts Total Transfer Capability	1500 MW
					TTC with All Lines In Service	1500 MW
MARCY_765_345_AT1					FWD	
Sat 08/01/2020	to	Sun 08/02/2020	UPDATED	by NYPA	08/08/2019	(Import)
0500	Continuous	1730				MOSES SOUTH
Work scheduled by: NYPA					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	3150 MW
MASSENA -MARCY_765_MSU1					FWD	
Sat 08/01/2020	to	Sun 08/02/2020	UPDATED	by NYPA	08/08/2019	(Import)
0500	Continuous	1730				CENTRAL EAST - VC
Work scheduled by: NYPA					Impacts Total Transfer Capability	710 MW
					TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 12, 2019 to Monday ,April 12, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA -MARCY 765_MSU1						FWD	
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)	
0500	Continuous	1730				MOSES SOUTH	500 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	2650 MW
						TTC with All Lines In Service	3150 MW
MASSENA -MARCY 765_MSU1						FWD	REV
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)	(Export)
0500	Continuous	1730				SCH - HQ - NY	475 MW 1000 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	1025 MW 0 MW
						TTC with All Lines In Service	1500 MW 1000 MW
MASSENA -MARCY 765_MSU1						FWD	
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)	
0500	Continuous	1730				SCH - HQ_CEDARS	90 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	190 MW
MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040						FWD	
Sat 08/01/2020	to	Sun 08/02/2020				(Import)	
0500		1730				MOSES SOUTH	500 MW
Work scheduled by:						Impacts Total Transfer Capability	2650 MW
						TTC with All Lines In Service	3150 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2						FWD	REV
Sat 08/01/2020	to	Sun 08/02/2020				(Import)	(Export)
0500		1730				SCH - HQ - NY	850 MW 0 MW
Work scheduled by:						Impacts Total Transfer Capability	650 MW 1000 MW
						TTC with All Lines In Service	1500 MW 1000 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2						FWD	
Sat 08/01/2020	to	Sun 08/02/2020				(Import)	
0500		1730				SCH - HQ_CEDARS	90 MW
Work scheduled by:						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	190 MW
STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1						FWD	
Sat 08/01/2020	to	Sun 08/02/2020				(Import)	
0500		1730				SCH - HQ_CEDARS	90 MW
Work scheduled by:						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	190 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 12, 2019 to Monday ,April 12, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STLAWRNC-MOSES__ 230_L33P & MOSES__-MASSENA_ 230_MMS1 & MOSES__ -
MASSENA_ 230_MMS2

FWD
(Import)

Sat 08/01/2020 to Sun 08/02/2020
0500 1730

SCH - HQ_CEDARS **90 MW**
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 190 MW

Work scheduled by:

MOSES__-ADIRNDCK_ 230_MA2

FWD
(Import)

Mon 08/03/2020 to Sun 09/13/2020
0700 Continuous 1730

MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

FRASANNX-COOPERS__ 345_UCC2-41

FWD
(Import)

Mon 09/07/2020 to Fri 10/23/2020 UPDATED by NYPA 03/01/2019
0700 Continuous 1730

CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA **ARR: 19**

MARCY__-FRASANNX_ 345_UCC2-41

FWD
(Import)

Mon 09/07/2020 to Fri 10/23/2020 UPDATED by NYPA 03/01/2019
0700 Continuous 1730

CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA **ARR: 19**

MARCY__ 765_345_AT1

FWD
(Import)

Mon 09/14/2020 to Mon 09/14/2020
0500 Continuous 1730

MOSES SOUTH **1750 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA **ARR: 19**

NIAGARA_-KINTIGH_ 345_NS1-38

FWD
(Import)

Mon 09/14/2020 to Thu 09/17/2020
0500 Continuous 1530

DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

MOSES__-ADIRNDCK_ 230_MA2

FWD
(Import)

Tue 09/15/2020 to Sat 11/14/2020
0700 Continuous 1530

MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

NYISO TRANSFER LIMITATIONS

Saturday ,October 12, 2019 to Monday ,April 12, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-ROCHESTR_345_NR2

Fri 09/18/2020 to Sat 11/14/2020
 0500 Continuous 2330
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **1400 MW**
 Impacts Total Transfer Capability 1750 MW
 TTC with All Lines In Service 3150 MW

CLAY_-EDIC_345_1-16

Mon 09/21/2020 to Fri 09/25/2020
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 OSWEGO EXPORT **4850 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 5250 MW

ROSETON_-ROCKTVRN_345_311

Mon 09/21/2020 to Fri 10/23/2020 **UPDATED by CHGE 10/09/2019**
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4400 MW**
 Impacts Total Transfer Capability 1300 MW
 TTC with All Lines In Service 5700 MW

CLAY_-EDIC_345_2-15

Mon 09/28/2020 to Fri 10/02/2020
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 OSWEGO EXPORT **4850 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 5250 MW

DUNWODIE_345KV_3

Thu 10/01/2020 to Thu 10/01/2020 **UPDATED by CONED 09/05/2019**
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_5

Thu 10/01/2020 to Thu 10/01/2020 **UPDATED by CONED 09/05/2019**
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE-MOTTHAVN_345_71

Thu 10/01/2020 to Thu 11/05/2020 **UPDATED by CONED 09/05/2019**
 0001 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 12, 2019 to Monday ,April 12, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HURLYAVE-ROSETON__345_303						FWD
Mon 10/26/2020	to	Fri 12/04/2020	<u>UPDATED</u>	<u>by CHGE</u>	<u>10/09/2019</u>	(Import)
0800	Continuous	1600				4100 MW
Work scheduled by: CHGE						Impacts Total Transfer Capability 1600 MW
						TTC with All Lines In Service 5700 MW
SCH-IMO-NYISO_LIMIT_1750						FWD
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Import)
0001	Continuous	2359				2050 MW
Work scheduled by: IESO						Impacts Total Transfer Capability 200 MW
						TTC with All Lines In Service 2250 MW
SCH-NYISO-IMO_LIMIT_1600						REV
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Export)
0001	Continuous	2359				1900 MW
Work scheduled by: IESO						Impacts Total Transfer Capability 100 MW
						TTC with All Lines In Service 2000 MW
DUNWODIE_345KV_3						FWD
Thu 11/05/2020	to	Thu 11/05/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>09/05/2019</u>	(Import)
0230	Continuous	0300				3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_5						FWD
Thu 11/05/2020	to	Thu 11/05/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>09/05/2019</u>	(Import)
0230	Continuous	0300				3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
CHATGUAY-MASSENA__765_7040						FWD
Sun 11/15/2020	to	Mon 11/30/2020				(Import)
0100	Continuous	1900				1550 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 1600 MW
						TTC with All Lines In Service 3150 MW
CHATGUAY-MASSENA__765_7040						FWD REV
Sun 11/15/2020	to	Mon 11/30/2020				(Import) (Export)
0100	Continuous	1900				0 MW 0 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 1500 MW 1000 MW
						TTC with All Lines In Service 1500 MW 1000 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 12, 2019 to Monday ,April 12, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT1			FWD
Sun 11/15/2020	to	Mon 11/30/2020	(Import)
0100	Continuous	1900	MOSES SOUTH 1750 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 1400 MW
			TTC with All Lines In Service 3150 MW
MARCY___765_345_AT2			FWD
Sun 11/15/2020	to	Mon 11/30/2020	(Import)
0100	Continuous	1900	MOSES SOUTH 1700 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 1450 MW
			TTC with All Lines In Service 3150 MW
MASSENA_-MARCY___765_MSU1			FWD
Sun 11/15/2020	to	Mon 11/30/2020	(Import)
0100	Continuous	1900	CENTRAL EAST - VC 2265 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 710 MW
			TTC with All Lines In Service 2975 MW
MASSENA_-MARCY___765_MSU1			FWD
Sun 11/15/2020	to	Mon 11/30/2020	(Import)
0100	Continuous	1900	MOSES SOUTH 500 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 2650 MW
			TTC with All Lines In Service 3150 MW
MASSENA_-MARCY___765_MSU1			FWD
Sun 11/15/2020	to	Mon 11/30/2020	(Import) (Export)
0100	Continuous	1900	SCH - HQ - NY 475 MW 1000 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 1025 MW 0 MW
			TTC with All Lines In Service 1500 MW 1000 MW
MASSENA_-MARCY___765_MSU1			FWD
Sun 11/15/2020	to	Mon 11/30/2020	(Import)
0100	Continuous	1900	SCH - HQ_CEDARS 90 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 109 MW
			TTC with All Lines In Service 199 MW
MASSENA_-MARCY___765_MSU1 & CHATGUAY-MASSENA_765_7040			FWD
Sun 11/15/2020	to	Mon 11/30/2020	(Import)
0100		1900	MOSES SOUTH 500 MW
Work scheduled by:			Impacts Total Transfer Capability 2650 MW
			TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 12, 2019 to Monday ,April 12, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES ___-MASSENA___ 230_MMS1 & MOSES ___-MASSENA___ 230_MMS2	FWD	REV
Sun 11/15/2020 to Mon 11/30/2020	(Import)	(Export)
0100 1900	SCH - HQ - NY	850 MW 0 MW
Work scheduled by:	Impacts Total Transfer Capability	650 MW 1000 MW
	TTC with All Lines In Service	1500 MW 1000 MW
<hr/>		
MOSES ___-MASSENA___ 230_MMS1 & MOSES ___-MASSENA___ 230_MMS2	FWD	
Sun 11/15/2020 to Mon 11/30/2020	(Import)	
0100 1900	SCH - HQ_CEDARS	90 MW
Work scheduled by:	Impacts Total Transfer Capability	109 MW
	TTC with All Lines In Service	199 MW
<hr/>		
STLAWRNC-MOSES___ 230_L33P & MASSENA_-MARCY___ 765_MSU1	FWD	
Sun 11/15/2020 to Mon 11/30/2020	(Import)	
0100 1900	SCH - HQ_CEDARS	90 MW
Work scheduled by:	Impacts Total Transfer Capability	109 MW
	TTC with All Lines In Service	199 MW
<hr/>		
STLAWRNC-MOSES___ 230_L33P & MOSES ___-MASSENA___ 230_MMS1 & MOSES ___-MASSENA___ 230_MMS2	FWD	
Sun 11/15/2020 to Mon 11/30/2020	(Import)	
0100 1900	SCH - HQ_CEDARS	90 MW
Work scheduled by:	Impacts Total Transfer Capability	109 MW
	TTC with All Lines In Service	199 MW
<hr/>		
PLSNTVLE-DUNWODIE_345_W89	FWD	
Mon 11/16/2020 to Mon 11/16/2020	(Import)	
0001 Continuous 0030	UPNY CONED	4000 MW
Work scheduled by: ConEd	Impacts Total Transfer Capability	1700 MW
	TTC with All Lines In Service	5700 MW
<hr/>		
PLSNTVLE-DUNWODIE_345_W89	FWD	
Thu 11/26/2020 to Thu 11/26/2020	(Import)	
0230 Continuous 0300	UPNY CONED	4000 MW
Work scheduled by: ConEd	Impacts Total Transfer Capability	1700 MW
	TTC with All Lines In Service	5700 MW
<hr/>		
MOSES ___-ADIRNDCK___ 230_MA1	FWD	
Tue 12/01/2020 to Mon 05/31/2021	(Import)	
0700 Continuous 1300	MOSES SOUTH	2300 MW
Work scheduled by: NYPA	Impacts Total Transfer Capability	850 MW
	TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 12, 2019 to Monday ,April 12, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOTTHAVN-RAINEY ___ 345_Q11

Mon 03/01/2021 to Tue 04/06/2021
 0001 Continuous 0700

Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

CLAY ___-EDIC ___ 345_2-15

Mon 03/29/2021 to Fri 04/16/2021
 0800 Continuous 1730

Work scheduled by: NYPA

FWD
 (Import)
 OSWEGO EXPORT **4850 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 5250 MW