

# NYISO TRANSFER LIMITATIONS

Sunday ,October 13, 2019 to Tuesday ,April 13, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					FWD	REV
<b>HUDSONP_-FARRAGUT_345_B3402</b>					(Import)	(Export)
Mon 01/15/2018	to	Fri 05/01/2020	<b><u>EXTENDED</u></b>	<b><u>by CONED</u></b>	<b><u>10/08/2019</u></b>	
0001	Continuous	2359				
Work scheduled by: ConEd					SCH - PJ - NY	<b>2100 MW</b>
					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	2150 MW
<hr/>					FWD	REV
<b>HUDSONP_-FARRAGUT_345_B3402 &amp; MARION_-FARRAGUT_345_C3403</b>					(Import)	(Export)
Mon 01/15/2018	to	Fri 05/01/2020				
0001		2359				
Work scheduled by:					SCH - PJ - NY	<b>2050 MW</b>
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	2150 MW
<hr/>					FWD	REV
<b>MARION_-FARRAGUT_345_C3403</b>					(Import)	(Export)
Mon 01/15/2018	to	Fri 05/01/2020	<b><u>EXTENDED</u></b>	<b><u>by CONED</u></b>	<b><u>10/08/2019</u></b>	
0001	Continuous	2359				
Work scheduled by: ConEd					SCH - PJ - NY	<b>2100 MW</b>
					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	2150 MW
<hr/>					FWD	REV
<b>STLAWRNC-MOSES_230_L33P</b>					(Import)	(Export)
Mon 04/30/2018	to	Fri 12/31/2021	<b><u>EXT FORCE</u></b>	<b><u>by IESO</u></b>	<b><u>08/21/2018</u></b>	
0456	Continuous	2359				
Work scheduled by: IESO					SCH - OH - NY	
					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
<hr/>					FWD	REV
<b>BECK_-NIAGARA_345_PA302</b>					(Import)	(Export)
Wed 07/31/2019	to	Tue 11/12/2019	<b><u>EXTENDED</u></b>	<b><u>by IESO</u></b>	<b><u>08/29/2019</u></b>	
0800	Continuous	1700				
Work scheduled by: IESO					SCH - OH - NY	<b>900 MW</b>
					Impacts Total Transfer Capability	1000 MW
					TTC with All Lines In Service	1900 MW
<hr/>					FWD	REV
<b>NIAGARA_-PACKARD_230_61</b>					(Import)	(Export)
Tue 09/03/2019	to	Fri 10/18/2019	<b><u>UPDATED</u></b>	<b><u>by NYPA</u></b>	<b><u>12/19/2018</u></b>	
0500	Continuous	1700				
Work scheduled by: NYPA					SCH - OH - NY	
					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
<hr/>					FWD	REV
<b>PLSNTVLY_345KV_RNS5</b>					(Import)	(Export)
Sat 09/14/2019	to	Sat 10/19/2019	<b><u>UPDATED</u></b>	<b><u>by CE</u></b>	<b><u>10/10/2019</u></b>	
0001	Continuous	0300				
Work scheduled by: ConEd					UPNY CONED	<b>3800 MW</b>
					Impacts Total Transfer Capability	1900 MW
					TTC with All Lines In Service	5700 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 13, 2019 to Tuesday ,April 13, 2021

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>LEEDS___-HURLYAVE_345_301</b>					FWD	
Mon 09/30/2019	to	Fri 10/11/2019	<u>UPDATED</u>	<u>by CHGE</u>	<u>09/05/2019</u>	(Import)
0800	Continuous	1600				UPNY CONED <b>4100 MW</b>
Work scheduled by: CHGE					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	5700 MW
<b>FROST_BR-LONG_MTN_345_352</b>					FWD	
Wed 10/02/2019	to	Fri 10/18/2019	<u>UPDATED</u>	<u>by ISONE</u>	<u>09/30/2019</u>	(Import)
0700	Continuous	1600				SCH - NE - NY <b>1150 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability	250 MW
					TTC with All Lines In Service	1400 MW
<b>SCH-NE-NYISO_LIMIT_400</b>					FWD	
Wed 10/02/2019	to	Fri 10/18/2019	<u>UPDATED</u>	<u>by ISONE</u>	<u>09/30/2019</u>	(Import)
0700	Continuous	1600				SCH - NE - NY <b>600 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	1400 MW
<b>DUNWODIE_345KV_4</b>					FWD	
Thu 10/03/2019	to	Wed 10/16/2019	<u>UPDATED</u>	<u>by CE</u>	<u>09/30/2019</u>	(Import)
0001	Continuous	0300				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>SPRNBK__345KV_RS3 &amp; SPRNBK__345KV_RS4</b>					FWD	
Fri 10/04/2019	to	Mon 10/14/2019				(Import)
0201		2230				SPR/DUN-SOUTH <b>3200 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
<b>SCH-NE-NYISO_LIMIT_300</b>					FWD	
Sat 10/05/2019	to	Fri 10/18/2019	<u>UPDATED</u>	<u>by ISONE</u>	<u>09/30/2019</u>	(Import)
1601	Continuous	1600				SCH - NE - NY <b>500 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability	900 MW
					TTC with All Lines In Service	1400 MW
<b>SCH-IMO-NYISO_LIMIT_400</b>					FWD	
Sun 10/06/2019	to	Tue 10/08/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/26/2019</u>	(Import)
0500	Continuous	2100				SCH - OH - NY <b>700 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	1200 MW
					TTC with All Lines In Service	1900 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 13, 2019 to Tuesday ,April 13, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
<b>CHAT_DC_GC2</b>			FWD
Mon 10/07/2019	to	Fri 10/11/2019	(Import)
0400	Continuous	2359	
Work scheduled by: HQ			
		MOSES SOUTH	<b>2850 MW</b>
		Impacts Total Transfer Capability	300 MW
		TTC with All Lines In Service	3150 MW
<hr/>			
<b>CHAT_DC_GC2</b>			REV
Mon 10/07/2019	to	Fri 10/11/2019	(Export)
0400	Continuous	2359	
Work scheduled by: HQ			
		SCH - HQ - NY	<b>500 MW</b>
		Impacts Total Transfer Capability	500 MW
		TTC with All Lines In Service	1000 MW
<hr/>			
<b>SCH-HQ-NYISO_LIMIT_1100</b>			FWD
Mon 10/07/2019	to	Fri 11/22/2019	(Import)
0400	Continuous	2300	
Work scheduled by: HQ			
		SCH - HQ - NY	<b>1100 MW</b>
		Impacts Total Transfer Capability	400 MW
		TTC with All Lines In Service	1500 MW
<hr/>			
<b>CLAY -EDIC 345_2-15</b>			FWD
Mon 10/07/2019	to	Fri 10/11/2019	(Import)
0600	Continuous	1530	
Work scheduled by: NYPA			
		OSWEGO EXPORT	<b>4850 MW</b>
		Impacts Total Transfer Capability	400 MW
		TTC with All Lines In Service	5250 MW
<hr/>			
<b>STOLLERD-HISHELDN_230_67</b>			FWD
Mon 10/07/2019	to	Tue 10/08/2019	(Import)
0700	Continuous	1400	
Work scheduled by: NYSEG			
		DYSINGER EAST	<b>2850 MW</b>
		Impacts Total Transfer Capability	300 MW
		TTC with All Lines In Service	3150 MW
<hr/>			
<b>MARCY -N.SCTLND_345_18</b>			FWD
Wed 10/09/2019	to	Thu 10/10/2019	(Import)
0500	Continuous	1730	
Work scheduled by: NYPA			
		<b>UPDATED</b> <b>by NGRID</b> <b>10/01/2019</b>	
		<b>ARR: 19</b>	
		CENTRAL EAST - VC	<b>2090 MW</b>
		Impacts Total Transfer Capability	885 MW
		TTC with All Lines In Service	2975 MW
<hr/>			
<b>SHORE_RD_345_138_BK_1</b>			FWD
Wed 10/09/2019	to	Fri 10/11/2019	(Import)
1825	Continuous	1902	
Work scheduled by: ConEd			
		<b>FORCED</b> <b>by CONED</b> <b>10/10/2019</b>	
		CONED - LIPA	<b>1350 MW</b>
		Impacts Total Transfer Capability	150 MW
		TTC with All Lines In Service	1500 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 13, 2019 to Tuesday ,April 13, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SHORE_RD_345_138_BK 2</b>					FWD	
Wed 10/09/2019	to	Fri 10/11/2019	<b>FORCED</b>	<b>by CONED</b>	<b>10/10/2019</b>	(Import)
1825	Continuous	1902				CONED - LIPA <b>1350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 150 MW	
					TTC with All Lines In Service 1500 MW	
<b>DUNWODIE-SHORE_RD_345_Y50</b>					FWD	
Wed 10/09/2019	to	Fri 10/11/2019	<b>FORCED</b>	<b>by CONED</b>	<b>10/10/2019</b>	(Import)
1825	Continuous	2359				CONED - LIPA <b>800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 700 MW	
					TTC with All Lines In Service 1500 MW	
<b>CHAT_DC_GC1</b>					FWD	
Sat 10/12/2019	to	Sat 10/12/2019	<b>UPDATED</b>	<b>by HQ</b>	<b>10/04/2019</b>	(Import)
0001	Continuous	0200				MOSES SOUTH <b>2850 MW</b>
Work scheduled by: HQ					Impacts Total Transfer Capability 300 MW	
					TTC with All Lines In Service 3150 MW	
<b>CHAT_DC_GC1</b>					REV	
Sat 10/12/2019	to	Sat 10/12/2019	<b>UPDATED</b>	<b>by HQ</b>	<b>10/04/2019</b>	(Export)
0001	Continuous	0200				SCH - HQ - NY <b>500 MW</b>
Work scheduled by: HQ					Impacts Total Transfer Capability 500 MW	
					TTC with All Lines In Service 1000 MW	
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>					FWD	
Sat 10/12/2019	to	Sat 10/12/2019				(Import)
0001		0200				MOSES SOUTH <b>2550 MW</b>
Work scheduled by:					Impacts Total Transfer Capability 600 MW	
					TTC with All Lines In Service 3150 MW	
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>					FWD	
Sat 10/12/2019	to	Sat 10/12/2019				(Import) (Export)
0001		0200				SCH - HQ - NY <b>1370 MW 0 MW</b>
Work scheduled by:					Impacts Total Transfer Capability 130 MW 1000 MW	
					TTC with All Lines In Service 1500 MW 1000 MW	
<b>CHAT_DC_GC2</b>					FWD	
Sat 10/12/2019	to	Sat 10/12/2019	<b>UPDATED</b>	<b>by HQ</b>	<b>10/04/2019</b>	(Import)
0001	Continuous	0200				MOSES SOUTH <b>2850 MW</b>
Work scheduled by: HQ					Impacts Total Transfer Capability 300 MW	
					TTC with All Lines In Service 3150 MW	

# NYISO TRANSFER LIMITATIONS

Sunday ,October 13, 2019 to Tuesday ,April 13, 2021

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event ID	Start	End	Status	By	Date	Impact	Capacity	Notes
<b>CHAT_DC_GC2</b>								
Sat 10/12/2019 0001	to	Sat 10/12/2019 0200	<u>UPDATED</u>	<u>by HQ</u>	<u>10/04/2019</u>	SCH - HQ - NY	500 MW	REV (Export)
Work scheduled by: HQ						Impacts Total Transfer Capability	500 MW	
						TTC with All Lines In Service	1000 MW	
<b>SCH-HQ-NYISO_LIMIT_600</b>								
Sat 10/12/2019 0001	to	Sat 10/12/2019 0200	<u>UPDATED</u>	<u>by HQ</u>	<u>10/04/2019</u>	SCH - HQ - NY	600 MW	FWD (Import)
Work scheduled by: HQ						Impacts Total Transfer Capability	900 MW	
						TTC with All Lines In Service	1500 MW	
<b>LEEDS___-PLSNTVLY_345_92</b>								
Sat 10/12/2019 0001	to	Tue 10/15/2019 0200	<u>UPDATED</u>	<u>by CE</u>	<u>10/10/2019</u>	UPNY CONED	3800 MW	FWD (Import)
Work scheduled by: ConEd						Impacts Total Transfer Capability	1900 MW	
						TTC with All Lines In Service	5700 MW	
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2 &amp; MOSES___-MASSENA_230_MMS1 &amp; MOSES___-MASSENA_230_MMS2</b>								
Sat 10/12/2019 0100	to	Sat 10/12/2019 0200				MOSES SOUTH	1950 MW	FWD (Import)
Work scheduled by:						Impacts Total Transfer Capability	1200 MW	
						TTC with All Lines In Service	3150 MW	
<b>CHATGUAY-MASSENA_765_7040</b>								
Sat 10/12/2019 0100	to	Tue 10/22/2019 2000	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/13/2019</u>	MOSES SOUTH	1550 MW	FWD (Import)
Work scheduled by: NYPA						Impacts Total Transfer Capability	1600 MW	
						TTC with All Lines In Service	3150 MW	
<b>CHATGUAY-MASSENA_765_7040</b>								
Sat 10/12/2019 0100	to	Tue 10/22/2019 2000	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/13/2019</u>	SCH - HQ - NY	0 MW	FWD (Import) (Export)
Work scheduled by: NYPA						Impacts Total Transfer Capability	1500 MW	1000 MW
						TTC with All Lines In Service	1500 MW	1000 MW
<b>MARCY___765_345_AT1</b>								
Sat 10/12/2019 0100	to	Tue 10/22/2019 2000	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/13/2019</u>	MOSES SOUTH	1750 MW	FWD (Import)
Work scheduled by: NYPA						Impacts Total Transfer Capability	1400 MW	
						TTC with All Lines In Service	3150 MW	

ARR: 19

# NYISO TRANSFER LIMITATIONS

Sunday ,October 13, 2019 to Tuesday ,April 13, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MARCY___765_345_AT2</b>						FWD
Sat 10/12/2019	to	Tue 10/22/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/13/2019</u>	(Import)
0100	Continuous	2000				<b>MOSES SOUTH</b> <b>1700 MW</b>
Work scheduled by: NYPA				<b>ARR: 19</b>		Impacts Total Transfer Capability 1450 MW TTC with All Lines In Service 3150 MW
<b>MASSENA_-MARCY___765_MSU1</b>						FWD
Sat 10/12/2019	to	Tue 10/22/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/13/2019</u>	(Import)
0100	Continuous	2000				<b>CENTRAL EAST - VC</b> <b>2265 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability 710 MW TTC with All Lines In Service 2975 MW
<b>MASSENA_-MARCY___765_MSU1</b>						FWD
Sat 10/12/2019	to	Tue 10/22/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/13/2019</u>	(Import)
0100	Continuous	2000				<b>MOSES SOUTH</b> <b>500 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability 2650 MW TTC with All Lines In Service 3150 MW
<b>MASSENA_-MARCY___765_MSU1</b>						FWD      REV
Sat 10/12/2019	to	Tue 10/22/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/13/2019</u>	(Import) (Export)
0100	Continuous	2000				<b>SCH - HQ - NY</b> <b>475 MW    1000 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability 1025 MW    0 MW TTC with All Lines In Service 1500 MW    1000 MW
<b>MASSENA_-MARCY___765_MSU1</b>						FWD
Sat 10/12/2019	to	Tue 10/22/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/13/2019</u>	(Import)
0100	Continuous	2000				<b>SCH - HQ_CEDARS</b> <b>90 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability 100 MW TTC with All Lines In Service 190 MW
<b>MASSENA_-MARCY___765_MSU1 &amp; CHATGUAY-MASSENA_765_7040</b>						FWD
Sat 10/12/2019	to	Tue 10/22/2019				(Import)
0100		2000				<b>MOSES SOUTH</b> <b>500 MW</b>
Work scheduled by:						Impacts Total Transfer Capability 2650 MW TTC with All Lines In Service 3150 MW
<b>MOSES___-MASSENA_230_MMS1 &amp; MOSES___-MASSENA_230_MMS2</b>						FWD      REV
Sat 10/12/2019	to	Tue 10/22/2019				(Import) (Export)
0100		2000				<b>SCH - HQ - NY</b> <b>850 MW    0 MW</b>
Work scheduled by:						Impacts Total Transfer Capability 650 MW    1000 MW TTC with All Lines In Service 1500 MW    1000 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 13, 2019 to Tuesday ,April 13, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MOSES -MASSENA 230_MMS1 &amp; MOSES -MASSENA 230_MMS2</b>			FWD
Sat 10/12/2019	to	Tue 10/22/2019	(Import)
0100		2000	SCH - HQ_CEDARS <b>90 MW</b>
Work scheduled by:			Impacts Total Transfer Capability 100 MW
			TTC with All Lines In Service 190 MW
<b>STLAWRNC-MOSES 230_L33P &amp; MASSENA -MARCY 765_MSU1</b>			FWD
Sat 10/12/2019	to	Tue 10/22/2019	(Import)
0100		2000	SCH - HQ_CEDARS <b>90 MW</b>
Work scheduled by:			Impacts Total Transfer Capability 100 MW
			TTC with All Lines In Service 190 MW
<b>STLAWRNC-MOSES 230_L33P &amp; MOSES -MASSENA 230_MMS1 &amp; MOSES -MASSENA 230_MMS2</b>			FWD
Sat 10/12/2019	to	Tue 10/22/2019	(Import)
0100		2000	SCH - HQ_CEDARS <b>90 MW</b>
Work scheduled by:			Impacts Total Transfer Capability 100 MW
			TTC with All Lines In Service 190 MW
<b>CHAT_DC_GC2</b>			FWD
Sat 10/12/2019	to	Sat 10/12/2019	(Import)
0201	Continuous	1959	MOSES SOUTH <b>2850 MW</b>
Work scheduled by: HQ			Impacts Total Transfer Capability 300 MW
			TTC with All Lines In Service 3150 MW
<b>CHAT_DC_GC2</b>			REV
Sat 10/12/2019	to	Sat 10/12/2019	(Export)
0201	Continuous	1959	SCH - HQ - NY <b>500 MW</b>
Work scheduled by: HQ			Impacts Total Transfer Capability 500 MW
			TTC with All Lines In Service 1000 MW
<b>SCH-IMO-NYISO_LIMIT_600</b>			FWD
Sat 10/12/2019	to	Sat 10/12/2019	(Import)
0900	Continuous	1630	SCH - OH - NY <b>900 MW</b>
Work scheduled by: IESO			Impacts Total Transfer Capability 1000 MW
			TTC with All Lines In Service 1900 MW
<b>SCH-NYISO-IMO_LIMIT_300</b>			REV
Sat 10/12/2019	to	Sat 10/12/2019	(Export)
0900	Continuous	1630	SCH - OH - NY <b>600 MW</b>
Work scheduled by: IESO			Impacts Total Transfer Capability 1100 MW
			TTC with All Lines In Service 1700 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 13, 2019 to Tuesday ,April 13, 2021

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CHAT_DC_GC1</b>			FWD	
Sat 10/12/2019	to	Sun 10/13/2019	(Import)	
2000	Continuous	2300	MOSES SOUTH	<b>2850 MW</b>
Work scheduled by: HQ			Impacts Total Transfer Capability	300 MW
			TTC with All Lines In Service	3150 MW
<b>CHAT_DC_GC1</b>			REV	
Sat 10/12/2019	to	Sun 10/13/2019	(Export)	
2000	Continuous	2300	SCH - HQ - NY	<b>500 MW</b>
Work scheduled by: HQ			Impacts Total Transfer Capability	500 MW
			TTC with All Lines In Service	1000 MW
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>			FWD	
Sat 10/12/2019	to	Sun 10/13/2019	(Import)	
2000		2300	MOSES SOUTH	<b>2550 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	600 MW
			TTC with All Lines In Service	3150 MW
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>			FWD	REV
Sat 10/12/2019	to	Sun 10/13/2019	(Import)	(Export)
2000		2300	SCH - HQ - NY	<b>1370 MW 0 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	130 MW 1000 MW
			TTC with All Lines In Service	1500 MW 1000 MW
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2 &amp; MOSES__-MASSENA__230_MMS1 &amp; MOSES__-MASSENA__230_MMS2</b>			FWD	
Sat 10/12/2019	to	Sun 10/13/2019	(Import)	
2000		2300	MOSES SOUTH	<b>1950 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	1200 MW
			TTC with All Lines In Service	3150 MW
<b>CHAT_DC_GC2</b>			FWD	
Sat 10/12/2019	to	Sun 10/13/2019	(Import)	
2000	Continuous	2300	MOSES SOUTH	<b>2850 MW</b>
Work scheduled by: HQ			Impacts Total Transfer Capability	300 MW
			TTC with All Lines In Service	3150 MW
<b>CHAT_DC_GC2</b>			REV	
Sat 10/12/2019	to	Sun 10/13/2019	(Export)	
2000	Continuous	2300	SCH - HQ - NY	<b>500 MW</b>
Work scheduled by: HQ			Impacts Total Transfer Capability	500 MW
			TTC with All Lines In Service	1000 MW



# NYISO TRANSFER LIMITATIONS

Sunday ,October 13, 2019 to Tuesday ,April 13, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event ID	Start Date	End Date	Time	Duration	Work Scheduled by	Transfer Capability	Impacts	TTC
<b>SCH-HQ-NYISO_LIMIT_1150</b>	Sat 10/12/2019	Sun 10/13/2019	2000	2300	HQ	1150 MW	350 MW	1500 MW
						FWD (Import)		
<b>E13THSTA-FARRAGUT_345_45</b>	Sun 10/13/2019	Mon 10/14/2019	0001	0200	ConEd	3800 MW	800 MW	4600 MW
						FWD (Import)		
<b>CHAT_DC_GC2</b>	Sun 10/13/2019	Fri 11/22/2019	2301	2300	HQ	2850 MW	300 MW	3150 MW
						FWD (Import)		
<b>CHAT_DC_GC2</b>	Sun 10/13/2019	Fri 11/22/2019	2301	2300	HQ	500 MW	500 MW	1000 MW
						REV (Export)		
<b>SHORE_RD_345_138_BK_2</b>	Mon 10/14/2019	Mon 10/14/2019	0001	2359	LI	1350 MW	150 MW	1500 MW
						FWD (Import)		
<b>MOTTHAVN-RAINEY_345_Q12</b>	Mon 10/14/2019	Tue 10/15/2019	0001	2359	ConEd	3800 MW	800 MW	4600 MW
						FWD (Import)		
<b>SHOR_NPX-SHOREHAM_138_CSC</b>	Mon 10/14/2019	Fri 10/18/2019	0600	1600	LI	0 MW	330 MW	330 MW
						FWD (Import)	REV (Export)	

# NYISO TRANSFER LIMITATIONS

Sunday ,October 13, 2019 to Tuesday ,April 13, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>FIVEMILE-STOLLERD_345_29</b>					FWD
Mon 10/14/2019	to	Fri 10/18/2019	<u>UPDATED</u>	<u>by NGRID</u>	(Import)
0700	Continuous	1400		<u>10/08/2019</u>	<b>2100 MW</b>
Work scheduled by: NYSEG					SCH - PJ - NY
					Impacts Total Transfer Capability 50 MW
					TTC with All Lines In Service 2150 MW
<b>PLSNTVLY-WOOD_ST_345_F30</b>					FWD
Tue 10/15/2019	to	Thu 10/17/2019	<u>UPDATED</u>	<u>by CE</u>	(Import)
0301	Continuous	0300		<u>10/10/2019</u>	<b>4000 MW</b>
Work scheduled by: ConEd					UPNY CONED
					Impacts Total Transfer Capability 1700 MW
					TTC with All Lines In Service 5700 MW
<b>LEEDS__-HURLYAVE_345_301</b>					FWD
Tue 10/15/2019	to	Fri 10/18/2019	<u>UPDATED</u>	<u>by CHGE</u>	(Import)
0800	Continuous	1600		<u>09/05/2019</u>	<b>4100 MW</b>
Work scheduled by: CHGE					UPNY CONED
					Impacts Total Transfer Capability 1600 MW
					TTC with All Lines In Service 5700 MW
<b>NEPTUNE_-DUFFYAVE_345_NEPTUNE</b>					FWD
Thu 10/17/2019	to	Wed 10/23/2019			(Import)
0001	Continuous	2359			<b>0 MW</b>
Work scheduled by: LI					SCH - PJM_NEPTUNE
					Impacts Total Transfer Capability 660 MW
					TTC with All Lines In Service 660 MW
<b>NEWBRDGE-DUFFYAVE_345_501</b>					FWD
Thu 10/17/2019	to	Wed 10/23/2019			(Import)
0001	Continuous	2359			<b>0 MW</b>
Work scheduled by: LI					SCH - PJM_NEPTUNE
					Impacts Total Transfer Capability 660 MW
					TTC with All Lines In Service 660 MW
<b>NEWBRDGE_345_138_BK_1</b>					FWD
Thu 10/17/2019	to	Wed 10/23/2019			(Import)
0001	Continuous	2359			<b>375 MW</b>
Work scheduled by: LI					SCH - PJM_NEPTUNE
					Impacts Total Transfer Capability 285 MW
					TTC with All Lines In Service 660 MW
<b>NEWBRDGE_345_138_BK_2</b>					FWD
Thu 10/17/2019	to	Wed 10/23/2019			(Import)
0001	Continuous	2359			<b>375 MW</b>
Work scheduled by: LI					SCH - PJM_NEPTUNE
					Impacts Total Transfer Capability 285 MW
					TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 13, 2019 to Tuesday ,April 13, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4**

Thu 10/17/2019 to Thu 10/17/2019  
 0900 1559

Work scheduled by:

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 1900 MW  
 TTC with All Lines In Service 5700 MW

-----  
**DUNWODIE\_345KV\_7**

Fri 10/18/2019 to Fri 10/18/2019  
 0001 Continuous 0030

Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

-----  
**DUNWODIE\_345KV\_8**

Fri 10/18/2019 to Fri 10/18/2019  
 0001 Continuous 0030

Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

-----  
**DUNWODIE-MOTTHAVN\_345\_72**

Fri 10/18/2019 to Sat 10/19/2019  
 0001 Continuous 0300

Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

-----  
**PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4**

Fri 10/18/2019 to Fri 10/18/2019  
 0900 1559

Work scheduled by:

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 1900 MW  
 TTC with All Lines In Service 5700 MW

-----  
**DUNWODIE\_345KV\_7**

Sat 10/19/2019 to Sat 10/19/2019  
 0230 Continuous 0300

Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

-----  
**DUNWODIE\_345KV\_8**

Sat 10/19/2019 to Sat 10/19/2019  
 0230 Continuous 0300

Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 13, 2019 to Tuesday ,April 13, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>KINTIGH_-ROCHESTR_345_SR1-39</b>					FWD
Sat 10/19/2019	to	Sun 10/27/2019			(Import)
0700	Continuous	1900		DYSINGER EAST	<b>1400 MW</b>
Work scheduled by: RGE					Impacts Total Transfer Capability 1750 MW
					TTC with All Lines In Service 3150 MW
<b>SHORE_RD_345_138_BK_2</b>					FWD
Mon 10/21/2019	to	Mon 10/21/2019	<u>UPDATED</u>	<u>by LI</u>	<u>10/02/2019</u>
0001	Continuous	2359		CONED - LIPA	<b>1350 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability 150 MW
					TTC with All Lines In Service 1500 MW
<b>HURLYAVE-ROSETON__345_303</b>					FWD
Mon 10/21/2019	to	Thu 10/31/2019			(Import)
0800	Continuous	1600		UPNY CONED	<b>4100 MW</b>
Work scheduled by: CHGE					Impacts Total Transfer Capability 1600 MW
					TTC with All Lines In Service 5700 MW
<b>GILBOA_-N.SCTLND_345_GNS-1</b>					FWD
Tue 10/22/2019	to	Thu 10/24/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/10/2019</u>
0700	Continuous	1730		CENTRAL EAST - VC	<b>2520 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 455 MW
					TTC with All Lines In Service 2975 MW
<b>WATRCURE_345_230_BK_1</b>					
Tue 10/22/2019	to	Tue 10/22/2019			
0800	Continuous	1530		SCH - PJ - NY	
Work scheduled by: NYSEG					Impacts Total Transfer Capability
					TTC with All Lines In Service
<b>NIAGARA__345_230_AT4</b>					REV
Wed 10/23/2019	to	Tue 12/17/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/10/2019</u>
0500	Continuous	1700		SCH - OH - NY	<b>1400 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 300 MW
					TTC with All Lines In Service 1700 MW
<b>DENNISON-ROSEMNTA_115_1/11</b>					FWD REV
Wed 10/23/2019	to	Wed 10/23/2019	<u>CANCELLED</u>	<u>by NGrid</u>	<u>10/11/2019</u>
0700	Daily(No Weekends)	1200		SCH - HQ_CEDARS	<b>95 MW 40 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability 95 MW 0 MW
					TTC with All Lines In Service 190 MW 40 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 13, 2019 to Tuesday ,April 13, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Transfer Capability	Start Date	End Date	Time	Frequency	Work Scheduled by	Update Info	Schedule	Impact	TTC
CEDARS - ROSEMNTA_115_1/11	Wed 10/23/2019	Wed 10/23/2019	0700	Daily (No Weekends)	1700		SCH - HQ_CEDARS	95 MW	40 MW
							Impacts Total Transfer Capability	95 MW	0 MW
							TTC with All Lines In Service	190 MW	40 MW
DENNISON-ROSEMNTA_115_1/11	Wed 10/23/2019	Wed 10/23/2019	0700	Daily (No Weekends)	1700		SCH - HQ_CEDARS	95 MW	40 MW
							Impacts Total Transfer Capability	95 MW	0 MW
							TTC with All Lines In Service	190 MW	40 MW
EGRDNCTY_345_138_AT1	Thu 10/24/2019	Sun 11/03/2019	0001	Continuous	0300	<u>UPDATED</u> by <u>CE</u> <u>09/12/2019</u>	CONED - LIPA	1250 MW	
							Impacts Total Transfer Capability	250 MW	
							TTC with All Lines In Service	1500 MW	
EGRDNCTY_345_138_AT2	Thu 10/24/2019	Sun 11/03/2019	0001	Continuous	0300	<u>UPDATED</u> by <u>CE</u> <u>09/12/2019</u>	CONED - LIPA	1250 MW	
							Impacts Total Transfer Capability	250 MW	
							TTC with All Lines In Service	1500 MW	
SPRNBRK - EGRDNCTR_345_Y49	Thu 10/24/2019	Sun 11/03/2019	0001	Continuous	0300	<u>UPDATED</u> by <u>CE</u> <u>09/12/2019</u>	CONED - LIPA	775 MW	
							Impacts Total Transfer Capability	725 MW	
							TTC with All Lines In Service	1500 MW	
GILBOA - N.SCTLND_345_GNS-1	Fri 10/25/2019	Fri 10/25/2019	1630	Continuous	1730	<u>UPDATED</u> by <u>NYPA</u> <u>09/19/2019</u>	CENTRAL EAST - VC	2520 MW	
							Impacts Total Transfer Capability	455 MW	
							TTC with All Lines In Service	2975 MW	
SHORE_RD_345_138_BK 1	Mon 10/28/2019	Mon 10/28/2019	0001	Continuous	2359	<u>UPDATED</u> by <u>LI</u> <u>10/02/2019</u>	CONED - LIPA	1350 MW	
							Impacts Total Transfer Capability	150 MW	
							TTC with All Lines In Service	1500 MW	

# NYISO TRANSFER LIMITATIONS

Sunday ,October 13, 2019 to Tuesday ,April 13, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	
				(Import)	
<b>NIAGARA_-ROCHESTR_345_NR2</b>					
Mon 10/28/2019	to	Wed 11/13/2019	<b>UPDATED</b>	<b>by NYPA</b>	<b>10/08/2019</b>
0500	Continuous	1700			
Work scheduled by: NYPA				DYSINGER EAST	<b>1400 MW</b>
				Impacts Total Transfer Capability	1750 MW
				TTC with All Lines In Service	3150 MW
<b>HOPATCON-RAMAPO__500_5018</b>				FWD	REV
				(Import) (Export)	
Fri 11/01/2019	to	Tue 11/05/2019			
0001	Continuous	2200			
Work scheduled by: ConEd				SCH - PJ - NY	<b>1250 MW 1200 MW</b>
				Impacts Total Transfer Capability	1350 MW 350 MW
				TTC with All Lines In Service	2600 MW 1550 MW
<b>HOPATCON-RAMAPO__500_5018</b>				FWD	
				(Import)	
Fri 11/01/2019	to	Tue 11/05/2019			
0001	Continuous	2200			
Work scheduled by: ConEd				UPNY CONED	<b>5000 MW</b>
				Impacts Total Transfer Capability	700 MW
				TTC with All Lines In Service	5700 MW
<b>RAMAPO__345_345_PAR3500</b>				FWD	REV
				(Import) (Export)	
Fri 11/01/2019	to	Tue 11/05/2019			
0001	Continuous	2200			
Work scheduled by: ConEd				SCH - PJ - NY	<b>2150 MW 1250 MW</b>
				Impacts Total Transfer Capability	450 MW 300 MW
				TTC with All Lines In Service	2600 MW 1550 MW
<b>RAMAPO__345_345_PAR4500</b>				FWD	REV
				(Import) (Export)	
Fri 11/01/2019	to	Tue 11/05/2019			
0001	Continuous	2200			
Work scheduled by: ConEd				SCH - PJ - NY	<b>2150 MW 1250 MW</b>
				Impacts Total Transfer Capability	450 MW 300 MW
				TTC with All Lines In Service	2600 MW 1550 MW
<b>RAMAPO__500_345_BK 1500</b>				FWD	REV
				(Import) (Export)	
Fri 11/01/2019	to	Tue 11/05/2019			
0001	Continuous	2200			
Work scheduled by: ConEd				SCH - PJ - NY	<b>1250 MW 1200 MW</b>
				Impacts Total Transfer Capability	1350 MW 350 MW
				TTC with All Lines In Service	2600 MW 1550 MW
<b>RAMAPO__500_345_BK 1500</b>				FWD	
				(Import)	
Fri 11/01/2019	to	Tue 11/05/2019			
0001	Continuous	2200			
Work scheduled by: ConEd				UPNY CONED	<b>5000 MW</b>
				Impacts Total Transfer Capability	700 MW
				TTC with All Lines In Service	5700 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 13, 2019 to Tuesday ,April 13, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SCH-IMO-NYISO_LIMIT_1750</b>					FWD	
Fri 11/01/2019	to	Thu 04/30/2020	<b>UPDATED</b>	<b>by IESO</b>	<b>05/03/2019</b>	(Import)
0001	Continuous	2359				<b>2050 MW</b>
Work scheduled by: IESO					SCH - OH - NY	Impacts Total Transfer Capability 200 MW
					TTC with All Lines In Service	2250 MW
<b>SCH-NYISO-IMO_LIMIT_1600</b>					REV	
Fri 11/01/2019	to	Thu 04/30/2020	<b>UPDATED</b>	<b>by IESO</b>	<b>05/03/2019</b>	(Export)
0001	Continuous	2359				<b>1900 MW</b>
Work scheduled by: IESO					SCH - OH - NY	Impacts Total Transfer Capability 100 MW
					TTC with All Lines In Service	2000 MW
<b>VOLNEY_-MARCY___345_19</b>					FWD	
Fri 11/01/2019	to	Fri 11/01/2019				(Import)
0730	Daily(No Weekends)	1630				<b>2825 MW</b>
Work scheduled by: NGrid					CENTRAL EAST - VC	Impacts Total Transfer Capability 150 MW
					TTC with All Lines In Service	2975 MW
<b>VOLNEY_-MARCY___345_19</b>					FWD	
Fri 11/01/2019	to	Fri 11/01/2019				(Import)
0730	Daily(No Weekends)	1630				<b>4900 MW</b>
Work scheduled by: NGrid					OSWEGO EXPORT	Impacts Total Transfer Capability 350 MW
					TTC with All Lines In Service	5250 MW
<b>SHORE_RD_345_138_BK_1</b>					FWD	
Mon 11/04/2019	to	Mon 11/04/2019	<b>UPDATED</b>	<b>by LI</b>	<b>10/02/2019</b>	(Import)
0001	Continuous	2359				<b>1350 MW</b>
Work scheduled by: LI					CONED - LIPA	Impacts Total Transfer Capability 150 MW
					TTC with All Lines In Service	1500 MW
<b>NRTH1385-NOR HBR_138_601</b>					FWD	REV
Mon 11/04/2019	to	Fri 11/15/2019				(Import) (Export)
0001	Continuous	2359				<b>100 MW 100 MW</b>
Work scheduled by: LI					SCH - NPX_1385	Impacts Total Transfer Capability 100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW
<b>NRTH1385-NOR HBR_138_601 &amp; NRTH1385-NOR HBR_138_602</b>					FWD	REV
Mon 11/04/2019	to	Fri 11/15/2019				(Import) (Export)
0001		2359				<b>0 MW 0 MW</b>
Work scheduled by:					SCH - NPX_1385	Impacts Total Transfer Capability 200 MW 200 MW
					TTC with All Lines In Service	200 MW 200 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 13, 2019 to Tuesday ,April 13, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**NRTH1385-NOR HBR\_\_138\_601 & NRTH1385-NOR HBR\_\_138\_603**

Mon 11/04/2019 to Fri 11/15/2019  
 0001 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

-----  
**NRTH1385-NOR HBR\_\_138\_602**

Mon 11/04/2019 to Fri 11/15/2019  
 0001 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

-----  
**NRTH1385-NOR HBR\_\_138\_602 & NRTH1385-NOR HBR\_\_138\_603**

Mon 11/04/2019 to Fri 11/15/2019  
 0001 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

-----  
**NRTH1385-NOR HBR\_\_138\_603**

Mon 11/04/2019 to Fri 11/15/2019  
 0001 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

-----  
**NRTH1385-NRTHPORT\_138\_NNC**

Mon 11/04/2019 to Fri 11/15/2019  
 0001 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

-----  
**LINDN\_CG-LNDVFT\_\_345\_V-3022**

Mon 11/04/2019 to Thu 11/07/2019  
 0800 Continuous 1500

Work scheduled by: PJM

	FWD	REV
	(Import)	(Export)
SCH - PJM_VFT	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

-----  
**MARCY\_\_-N.SCTLND\_345\_18**

Wed 11/06/2019 to Wed 11/13/2019  
 0500 Continuous 1730

Work scheduled by: NYPA

**UPDATED by NYPA 09/11/2019**

**ARR: 19**

	FWD
	(Import)
CENTRAL EAST - VC	<b>2090 MW</b>
Impacts Total Transfer Capability	885 MW
TTC with All Lines In Service	2975 MW



# NYISO TRANSFER LIMITATIONS

Sunday ,October 13, 2019 to Tuesday ,April 13, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MARCY___345KV_CSC</b>					FWD	
Wed 11/06/2019	to	Fri 11/22/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/11/2019</u>	(Import)
0500	Continuous	1730				<b>CENTRAL EAST - VC</b> <b>2925 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 50 MW	
					TTC with All Lines In Service 2975 MW	
<b>MARCY___765_345_AT2</b>					FWD	
Wed 11/06/2019	to	Fri 11/22/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/11/2019</u>	(Import)
0500	Continuous	1730				<b>MOSES SOUTH</b> <b>1700 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 1450 MW	
					TTC with All Lines In Service 3150 MW	
<b>HURLYAVE-ROSETON__345_303</b>					FWD	
Wed 11/06/2019	to	Fri 12/06/2019				(Import)
0800	Continuous	1600				<b>UPNY CONED</b> <b>4100 MW</b>
Work scheduled by: CHGE					Impacts Total Transfer Capability 1600 MW	
					TTC with All Lines In Service 5700 MW	
<b>N.SCTLND-LEEDS___345_94</b>					FWD	
Wed 11/06/2019	to	Thu 11/07/2019				(Import)
0830	Continuous	1430				<b>CENTRAL EAST - VC</b> <b>2650 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability 325 MW	
					TTC with All Lines In Service 2975 MW	
<b>PLSNTVLE-DUNWODIE_345_W89</b>					FWD	
Fri 11/08/2019	to	Sat 11/09/2019				(Import)
0001	Continuous	0030				<b>UPNY CONED</b> <b>4000 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 1700 MW	
					TTC with All Lines In Service 5700 MW	
<b>E13THSTA-FARRAGUT_345_45</b>					FWD	
Tue 11/12/2019	to	Tue 11/12/2019				(Import)
0001	Continuous	0030				<b>SPR/DUN-SOUTH</b> <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW	
					TTC with All Lines In Service 4600 MW	
<b>WATRCURE-OAKDALE__345_31</b>					FWD	
Tue 11/12/2019	to	Tue 11/12/2019	<u>UPDATED</u>	<u>by NYSEG</u>	<u>09/13/2019</u>	(Import) (Export)
1300	Continuous	1500				<b>SCH - PJ - NY</b> <b>2600 MW 1300 MW</b>
Work scheduled by: NYSEG					Impacts Total Transfer Capability 0 MW 250 MW	
					TTC with All Lines In Service 2600 MW 1550 MW	

# NYISO TRANSFER LIMITATIONS

Sunday ,October 13, 2019 to Tuesday ,April 13, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**PLSNTVLY-WOOD\_ST\_\_345\_F31**

Thu 11/14/2019 to Thu 11/14/2019  
 0001 Continuous 2200  
 Work scheduled by: ConEd

**UPDATED by NYISO 09/18/2019**

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

**PLSNTVLY\_345KV\_RNS4**

Thu 11/14/2019 to Thu 11/14/2019  
 0001 Continuous 2200  
 Work scheduled by: ConEd

**UPDATED by NYISO 09/18/2019**

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 1900 MW  
 TTC with All Lines In Service 5700 MW

**E13THSTA-FARRAGUT\_345\_45**

Thu 11/14/2019 to Thu 11/14/2019  
 0130 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**W49TH\_ST-E13THSTA\_345\_M54**

Thu 11/14/2019 to Thu 11/14/2019  
 0201 Continuous 0500  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**BUCHAN\_N-EASTVIEW\_345\_W93**

Sun 11/17/2019 to Mon 11/18/2019  
 0301 Continuous 0300  
 Work scheduled by: ConEd

**UPDATED by CONED 09/09/2019**

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1350 MW  
 TTC with All Lines In Service 5700 MW

**EASTVIEW-SPRNBRK\_\_345\_W79**

Sun 11/17/2019 to Mon 11/18/2019  
 0301 Continuous 0300  
 Work scheduled by: ConEd

**UPDATED by CONED 09/09/2019**

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1350 MW  
 TTC with All Lines In Service 5700 MW

**SCH-NE-NYISO\_LIMIT\_500**

Sun 11/17/2019 to Sun 11/17/2019  
 1100 Continuous 1600  
 Work scheduled by: ISONE

FWD  
 (Import)  
 SCH - NE - NY **700 MW**  
 Impacts Total Transfer Capability 700 MW  
 TTC with All Lines In Service 1400 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 13, 2019 to Tuesday ,April 13, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SCH-NYISO-NE_LIMIT_1200</b>					REV
Sun 11/17/2019	to	Sun 11/17/2019			(Export)
1100	Continuous	1600		SCH - NE - NY	<b>1400 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability 400 MW
					TTC with All Lines In Service 1800 MW
<b>SPRNBRK_345KV_RNS5</b>					FWD
Mon 11/18/2019	to	Mon 11/18/2019	<u>UPDATED</u>	<u>by CONED</u> <u>09/09/2019</u>	(Import)
0301	Continuous	0330		SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW
<b>EASTVIEW-SPRNBRK_345_W64</b>					FWD
Mon 11/18/2019	to	Tue 11/19/2019	<u>UPDATED</u>	<u>by CONED</u> <u>09/09/2019</u>	(Import)
0301	Continuous	0200		UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 1350 MW
					TTC with All Lines In Service 5700 MW
<b>MILLWOOD-EASTVIEW_345_W99</b>					FWD
Mon 11/18/2019	to	Tue 11/19/2019	<u>UPDATED</u>	<u>by CONED</u> <u>09/09/2019</u>	(Import)
0301	Continuous	0200		UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 1350 MW
					TTC with All Lines In Service 5700 MW
<b>BERKSHIR-ALPS_345_393</b>					FWD REV
Mon 11/18/2019	to	Wed 11/27/2019			(Import) (Export)
0600	Continuous	1700		SCH - NE - NY	<b>1150 MW 1300 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability 250 MW 500 MW
					TTC with All Lines In Service 1400 MW 1800 MW
<b>BERKSHIR-ALPS_345_393</b>					FWD REV
Mon 11/18/2019	to	Wed 11/27/2019			(Import) (Export)
0600	Continuous	1700		SCH - NPX_1385	<b>100 MW 100 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability 100 MW 100 MW
					TTC with All Lines In Service 200 MW 200 MW
<b>BERKSHIR-ALPS_345_393 &amp; BERKSHIR-NORTHFLD_345_312</b>					FWD REV
Mon 11/18/2019	to	Wed 11/27/2019			(Import) (Export)
0600		1700		SCH - NE - NY	<b>1150 MW 1300 MW</b>
Work scheduled by:					Impacts Total Transfer Capability 250 MW 500 MW
					TTC with All Lines In Service 1400 MW 1800 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 13, 2019 to Tuesday ,April 13, 2021

Seasonal Limits

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BERKSHIR-NORTHFLD_345_312</b>				FWD	REV
Mon 11/18/2019	to	Wed 11/27/2019		(Import)	(Export)
0600	Continuous	1700		<b>SCH - NE - NY</b>	<b>1400 MW 1500 MW</b>
Work scheduled by: ISONE				Impacts Total Transfer Capability	0 MW 300 MW
				TTC with All Lines In Service	1400 MW 1800 MW
<b>BERKSHIR-NORTHFLD_345_312</b>				FWD	REV
Mon 11/18/2019	to	Wed 11/27/2019		(Import)	(Export)
0600	Continuous	1700		<b>SCH - NPX_1385</b>	<b>100 MW 100 MW</b>
Work scheduled by: ISONE				Impacts Total Transfer Capability	100 MW 100 MW
				TTC with All Lines In Service	200 MW 200 MW
<b>SCH-NE-NYISO_LIMIT_800</b>				FWD	
Mon 11/18/2019	to	Wed 11/27/2019		(Import)	
0600	Continuous	1700		<b>SCH - NE - NY</b>	<b>1000 MW</b>
Work scheduled by: ISONE				Impacts Total Transfer Capability	400 MW
				TTC with All Lines In Service	1400 MW
<b>SCH-NYISO-NE_LIMIT_500</b>					REV
Mon 11/18/2019	to	Wed 11/27/2019			(Export)
0600	Continuous	1700		<b>SCH - NE - NY</b>	<b>700 MW</b>
Work scheduled by: ISONE				Impacts Total Transfer Capability	1100 MW
				TTC with All Lines In Service	1800 MW
<b>SPRNBK__345KV_RNS5</b>				FWD	
Tue 11/19/2019	to	Tue 11/19/2019		(Import)	
0001	Continuous	0030		<b>SPR/DUN-SOUTH</b>	<b>3200 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	4600 MW
<b>SPRNBK__345KV_RNS5</b>				FWD	
Tue 11/19/2019	to	Tue 11/19/2019	<b>UPDATED by CONED 09/09/2019</b>	(Import)	
0130	Continuous	0200		<b>SPR/DUN-SOUTH</b>	<b>3200 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	4600 MW
<b>EASTVIEW-SPRNBK__345_W64</b>				FWD	
Sat 11/23/2019	to	Sat 11/23/2019		(Import)	
0130	Continuous	0200		<b>UPNY CONED</b>	<b>4350 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	1350 MW
				TTC with All Lines In Service	5700 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 13, 2019 to Tuesday ,April 13, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MILLWOOD-EASTVIEW_345_W99</b>				FWD	
Sat 11/23/2019	to	Sat 11/23/2019		(Import)	
0130	Continuous	0200	UPNY CONED	<b>4350 MW</b>	
Work scheduled by: ConEd			Impacts Total Transfer Capability	1350 MW	
			TTC with All Lines In Service	5700 MW	
<b>SPRNBRK_345KV_RNS5</b>				FWD	
Sat 11/23/2019	to	Sat 11/23/2019		(Import)	
0130	Continuous	0200	SPR/DUN-SOUTH	<b>3200 MW</b>	
Work scheduled by: ConEd			Impacts Total Transfer Capability	1400 MW	
			TTC with All Lines In Service	4600 MW	
<b>RAMAPO_-LADENTWN_345_W72</b>				FWD	
Mon 11/25/2019	to	Mon 11/25/2019		(Import)	
0001	Continuous	2200	UPNY CONED	<b>4400 MW</b>	
Work scheduled by: ConEd			Impacts Total Transfer Capability	1300 MW	
			TTC with All Lines In Service	5700 MW	
<b>MOSES_-ADIRNDCK_230_MA2</b>				FWD	
Mon 11/25/2019	to	Wed 11/27/2019		(Import)	
0700	Continuous	1500	MOSES SOUTH	<b>2300 MW</b>	
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW	
			TTC with All Lines In Service	3150 MW	
<b>SHOR_NPX-SHOREHAM_138_CSC</b>				FWD	REV
Mon 12/02/2019	to	Mon 12/02/2019	<b>UPDATED by ISONE 10/04/2019</b>	(Import)	(Export)
0700	Continuous	2300	SCH - NPX_CSC	<b>0 MW</b>	<b>0 MW</b>
Work scheduled by: LI			Impacts Total Transfer Capability	330 MW	330 MW
			TTC with All Lines In Service	330 MW	330 MW
<b>MOSES_-ADIRNDCK_230_MA2</b>				FWD	
Mon 12/02/2019	to	Fri 12/06/2019		(Import)	
0700	Continuous	1500	MOSES SOUTH	<b>2300 MW</b>	
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW	
			TTC with All Lines In Service	3150 MW	
<b>N.SCTLND-ALPS_345_2</b>				FWD	REV
Mon 12/02/2019	to	Mon 12/02/2019		(Import)	(Export)
0730	Daily(No Weekends)	1630	SCH - NE - NY	<b>900 MW</b>	<b>1700 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability	500 MW	100 MW
			TTC with All Lines In Service	1400 MW	1800 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 13, 2019 to Tuesday ,April 13, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
<b>N. SCTLND-ALPS_____345_2</b>					
Mon 12/02/2019	to	Mon 12/02/2019			
0730	Daily(No Weekends)	1630	SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	200 MW
<b>FRASER_____345_FRASER SVC</b>				FWD	
Mon 12/02/2019	to	Fri 12/13/2019		(Import)	
0800	Continuous	1500	CENTRAL EAST - VC	<b>2935 MW</b>	
Work scheduled by: NYSEG				Impacts Total Transfer Capability	40 MW
				TTC with All Lines In Service	2975 MW
<b>LEEDS_____345KV_R94301</b>				FWD	
Tue 12/03/2019	to	Fri 12/13/2019	<b>UPDATED by NGRID 10/04/2019</b>	(Import)	
0800	Continuous	1500	UPNY CONED	<b>3800 MW</b>	
Work scheduled by: NGrid				Impacts Total Transfer Capability	1900 MW
				TTC with All Lines In Service	5700 MW
<b>MOSES____-ADIRNDCK_230_MA1</b>				FWD	
Mon 12/09/2019	to	Fri 12/13/2019		(Import)	
0700	Continuous	1500	MOSES SOUTH	<b>2300 MW</b>	
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
<b>ROSETON_-ROCKTVRN_345_311</b>				FWD	
Mon 12/09/2019	to	Thu 12/12/2019		(Import)	
0800	Continuous	1600	UPNY CONED	<b>4400 MW</b>	
Work scheduled by: CHGE				Impacts Total Transfer Capability	1300 MW
				TTC with All Lines In Service	5700 MW
<b>SHOR_NPX-SHOREHAM_138_CSC</b>				FWD	REV
Thu 12/12/2019	to	Fri 12/20/2019		(Import)	(Export)
0800	Continuous	1500	SCH - NPX_CSC	<b>0 MW</b>	<b>0 MW</b>
Work scheduled by: ISONE				Impacts Total Transfer Capability	330 MW
				TTC with All Lines In Service	330 MW
<b>MOSES____-ADIRNDCK_230_MA2</b>				FWD	
Mon 12/16/2019	to	Mon 12/16/2019		(Import)	
0700	Continuous	1500	MOSES SOUTH	<b>2300 MW</b>	
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 13, 2019 to Tuesday ,April 13, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

Tue 12/17/2019 to Fri 12/20/2019  
 0700 Continuous 1500  
 Work scheduled by: NYPA

FWD  
 (Import)  
**MOSES SOUTH 2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

**SCH-NE-NYISO\_LIMIT\_500**

Fri 12/20/2019 to Fri 12/20/2019 **UPDATED by ISONE 10/11/2019**  
 0600 Continuous 1600  
 Work scheduled by: ISONE

FWD  
 (Import)  
**SCH - NE - NY 700 MW**  
 Impacts Total Transfer Capability 700 MW  
 TTC with All Lines In Service 1400 MW

**SCH-NYISO-NE\_LIMIT\_1200**

Fri 12/20/2019 to Fri 12/20/2019 **UPDATED by ISONE 10/11/2019**  
 0600 Continuous 1600  
 Work scheduled by: ISONE

REV  
 (Export)  
**SCH - NE - NY 1400 MW**  
 Impacts Total Transfer Capability 400 MW  
 TTC with All Lines In Service 1800 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Thu 01/02/2020 to Sun 03/01/2020  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
**MOSES SOUTH 2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

**LADENTWN-BUCHAN\_S\_345\_Y88**

Wed 01/15/2020 to Thu 02/13/2020 **11/05/2018**  
 0001 Continuous 2359  
 Work scheduled by: ORU

FWD  
 (Import)  
**UPNY CONED 4800 MW**  
 Impacts Total Transfer Capability 900 MW  
 TTC with All Lines In Service 5700 MW

**MOTTHAVN-RAINEY\_\_\_345\_Q11**

Sun 02/23/2020 to Sun 03/01/2020  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
**SPR/DUN-SOUTH 3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**NIAGARA\_-PACKARD\_230\_62**

Fri 02/28/2020 to Fri 02/28/2020  
 0500 Continuous 1530  
 Work scheduled by: NYPA

FWD REV  
 (Import) (Export)  
**SCH - OH - NY 1100 MW 950 MW**  
 Impacts Total Transfer Capability 1150 MW 1050 MW  
 TTC with All Lines In Service 2250 MW 2000 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 13, 2019 to Tuesday ,April 13, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Location	Start	End	Status	By	Effective Date	Impact	TTC
CHATGUAY-MASSENA 765_7040	Mon 03/02/2020 0500	Fri 03/06/2020 1730	UPDATED	by NYPA	08/08/2019	MOSES SOUTH	FWD (Import) 1550 MW
						Impacts Total Transfer Capability	1600 MW
						TTC with All Lines In Service	3150 MW
CHATGUAY-MASSENA 765_7040	Mon 03/02/2020 0500	Fri 03/06/2020 1730	UPDATED	by NYPA	08/08/2019	SCH - HQ - NY	FWD (Import) (Export) 0 MW 0 MW
						Impacts Total Transfer Capability	1500 MW 1000 MW
						TTC with All Lines In Service	1500 MW 1000 MW
MARCY 765_345_AT1	Mon 03/02/2020 0500	Fri 03/06/2020 1730	UPDATED	by NYPA	08/08/2019	MOSES SOUTH	FWD (Import) 1750 MW
						Impacts Total Transfer Capability	1400 MW
						TTC with All Lines In Service	3150 MW
MARCY 765_345_AT2	Mon 03/02/2020 0500	Fri 03/06/2020 1730	ARR: 19			MOSES SOUTH	FWD (Import) 1700 MW
						Impacts Total Transfer Capability	1450 MW
						TTC with All Lines In Service	3150 MW
MASSENA -MARCY 765_MSU1	Mon 03/02/2020 0500	Fri 03/06/2020 1730	UPDATED	by NYPA	08/08/2019	CENTRAL EAST - VC	FWD (Import) 2265 MW
						Impacts Total Transfer Capability	710 MW
						TTC with All Lines In Service	2975 MW
MASSENA -MARCY 765_MSU1	Mon 03/02/2020 0500	Fri 03/06/2020 1730	UPDATED	by NYPA	08/08/2019	MOSES SOUTH	FWD (Import) 500 MW
						Impacts Total Transfer Capability	2650 MW
						TTC with All Lines In Service	3150 MW
MASSENA -MARCY 765_MSU1	Mon 03/02/2020 0500	Fri 03/06/2020 1730	UPDATED	by NYPA	08/08/2019	SCH - HQ - NY	FWD (Import) (Export) 475 MW 1000 MW
						Impacts Total Transfer Capability	1025 MW 0 MW
						TTC with All Lines In Service	1500 MW 1000 MW



# NYISO TRANSFER LIMITATIONS

Sunday ,October 13, 2019 to Tuesday ,April 13, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MASSENA -MARCY 765_MSU1</b>				FWD	
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u> <u>by NYPA</u> <u>08/08/2019</u>	(Import)	
0500	Continuous	1730		SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	109 MW
				TTC with All Lines In Service	199 MW
<b>MASSENA -MARCY 765_MSU1 &amp; CHATGUAY-MASSENA 765_7040</b>				FWD	
Mon 03/02/2020	to	Fri 03/06/2020		(Import)	
0500		1730		MOSES SOUTH	<b>500 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	2650 MW
				TTC with All Lines In Service	3150 MW
<b>MOSES -MASSENA 230_MMS1 &amp; MOSES -MASSENA 230_MMS2</b>				FWD	REV
Mon 03/02/2020	to	Fri 03/06/2020		(Import)	(Export)
0500		1730		SCH - HQ - NY	<b>850 MW 0 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	650 MW 1000 MW
				TTC with All Lines In Service	1500 MW 1000 MW
<b>MOSES -MASSENA 230_MMS1 &amp; MOSES -MASSENA 230_MMS2</b>				FWD	
Mon 03/02/2020	to	Fri 03/06/2020		(Import)	
0500		1730		SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	109 MW
				TTC with All Lines In Service	199 MW
<b>STLAWRNC-MOSES 230_L33P &amp; MASSENA -MARCY 765_MSU1</b>				FWD	
Mon 03/02/2020	to	Fri 03/06/2020		(Import)	
0500		1730		SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	109 MW
				TTC with All Lines In Service	199 MW
<b>STLAWRNC-MOSES 230_L33P &amp; MOSES -MASSENA 230_MMS1 &amp; MOSES -MASSENA 230_MMS2</b>				FWD	
Mon 03/02/2020	to	Fri 03/06/2020		(Import)	
0500		1730		SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	109 MW
				TTC with All Lines In Service	199 MW
<b>EASTVIEW-SPRNBRK 345_W78</b>				FWD	
Fri 03/06/2020	to	Sat 03/07/2020		(Import)	
0001	Continuous	0200		UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	1350 MW
				TTC with All Lines In Service	5700 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 13, 2019 to Tuesday ,April 13, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MILLWOOD-EASTVIEW\_345\_W85**

Fri 03/06/2020 to Sat 03/07/2020  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1350 MW  
 TTC with All Lines In Service 5700 MW

**SPRNBRK\_345KV\_RNS3**

Fri 03/06/2020 to Sat 03/07/2020  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**MOSES-ADIRNDCK\_230\_MA1**

Sat 03/07/2020 to Fri 05/29/2020  
 0700 Continuous 1300  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

**VOLNEY-MARCY\_345\_19**

Tue 03/10/2020 to Tue 03/10/2020 **UPDATED by NYPA 09/24/2019**  
 0700 Continuous 1530  
 Work scheduled by: NYPA **ARR: 19**

FWD  
 (Import)  
 CENTRAL EAST - VC **2825 MW**  
 Impacts Total Transfer Capability 150 MW  
 TTC with All Lines In Service 2975 MW

**VOLNEY-MARCY\_345\_19**

Tue 03/10/2020 to Tue 03/10/2020 **UPDATED by NYPA 09/24/2019**  
 0700 Continuous 1530  
 Work scheduled by: NYPA **ARR: 19**

FWD  
 (Import)  
 OSWEGO EXPORT **4900 MW**  
 Impacts Total Transfer Capability 350 MW  
 TTC with All Lines In Service 5250 MW

**FRASANX-COOPERS\_345\_UCC2-41**

Wed 03/11/2020 to Thu 03/12/2020  
 0700 Continuous 1530  
 Work scheduled by: NYPA **ARR: 19**

FWD  
 (Import)  
 CENTRAL EAST - VC **2500 MW**  
 Impacts Total Transfer Capability 475 MW  
 TTC with All Lines In Service 2975 MW

**MARCY-FRASANX\_345\_UCC2-41**

Wed 03/11/2020 to Thu 03/12/2020  
 0700 Continuous 1530  
 Work scheduled by: NYPA **ARR: 19**

FWD  
 (Import)  
 CENTRAL EAST - VC **2500 MW**  
 Impacts Total Transfer Capability 475 MW  
 TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 13, 2019 to Tuesday ,April 13, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p><b>ROCHESTR-PANNELL__345_RP2</b></p> <p>Sat 03/14/2020 to Mon 03/23/2020 0500 Continuous 1700</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>DYSINGER EAST <b>2300 MW</b></p> <p>Impacts Total Transfer Capability 850 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p><b>MARCY__345KV_CSC</b></p> <p>Mon 03/16/2020 to Fri 03/27/2020 0500 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC <b>2925 MW</b></p> <p>Impacts Total Transfer Capability 50 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p><b>ROSETON_-EFISHKIL_345_RFK305</b></p> <p>Mon 03/16/2020 to Fri 04/03/2020 0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>UPNY CONED <b>4800 MW</b></p> <p>Impacts Total Transfer Capability 900 MW</p> <p>TTC with All Lines In Service 5700 MW</p>
<p><b>NIAGARA_-KINTIGH__345_NS1-38</b></p> <p>Fri 03/27/2020 to Fri 03/27/2020 0600 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>DYSINGER EAST <b>1700 MW</b></p> <p>Impacts Total Transfer Capability 1450 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p><b>BECK__-PACKARD__230_BP76</b></p> <p>Fri 03/27/2020 to Fri 03/27/2020 0800 Daily(No Weekends) 1600</p> <p>Work scheduled by: NGrid</p>	<p style="text-align: right;">FWD REV (Import) (Export)</p> <p>SCH - OH - NY <b>1700 MW 1500 MW</b></p> <p>Impacts Total Transfer Capability 550 MW 500 MW</p> <p>TTC with All Lines In Service 2250 MW 2000 MW</p>
<p><b>MARCY__-EDIC__345_UE1-7</b></p> <p>Tue 03/31/2020 to Tue 03/31/2020 0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>OSWEGO EXPORT <b>5250 MW</b></p> <p>Impacts Total Transfer Capability 0 MW</p> <p>TTC with All Lines In Service 5250 MW</p>
<p><b>MARCY__-N.SCTLND_345_18</b></p> <p>Tue 04/07/2020 to Wed 04/08/2020 0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC <b>2090 MW</b></p> <p>Impacts Total Transfer Capability 885 MW</p> <p>TTC with All Lines In Service 2975 MW</p>

# NYISO TRANSFER LIMITATIONS

Sunday ,October 13, 2019 to Tuesday ,April 13, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Line ID	Start Date	End Date	Time	Work Scheduled by	Transfer Capability	FWD	REV
LINDN_CG-LNDVFT_345_V-3022	Sun 04/12/2020	Fri 04/17/2020	1400 Continuous 1800	PJM	SCH - PJM_VFT	0 MW	0 MW
					Impacts Total Transfer Capability	315 MW	315 MW
					TTC with All Lines In Service	315 MW	315 MW
FRASER -GILBOA_345_GF5-35	Mon 04/13/2020	Wed 04/22/2020	0700 Continuous 1730	NYPA	CENTRAL EAST - VC	2650 MW	
					Impacts Total Transfer Capability	325 MW	
					TTC with All Lines In Service	2975 MW	
NIAGARA -ROCHESTR_345_NR2	Mon 04/20/2020	Fri 05/01/2020	0500 Continuous 1700	NYPA	DYSINGER EAST	1700 MW	
					Impacts Total Transfer Capability	1450 MW	
					TTC with All Lines In Service	3150 MW	
DOLSONAV-ROCKTVRN_345_DART44	Mon 04/27/2020	Sun 05/10/2020	0700 Continuous 1730	NYPA	CENTRAL EAST - VC	2720 MW	
					Impacts Total Transfer Capability	255 MW	
					TTC with All Lines In Service	2975 MW	
LEEDS -HURLYAVE_345_301	Mon 04/27/2020	Fri 05/29/2020	0800 Continuous 1600	CHGE	UPNY CONED	4100 MW	
					Impacts Total Transfer Capability	1600 MW	
					TTC with All Lines In Service	5700 MW	
SCH-IMO-NYISO_LIMIT_1600	Fri 05/01/2020	Sat 10/31/2020	0001 Continuous 2359	IESO	SCH - OH - NY	1900 MW	
					Impacts Total Transfer Capability	0 MW	
					TTC with All Lines In Service	1900 MW	
PANNELL -CLAY_345_2	Mon 05/04/2020	Fri 05/08/2020	0700 Continuous 1530	NYPA	WEST CENTRAL	1300 MW	
					Impacts Total Transfer Capability	950 MW	
					TTC with All Lines In Service	2250 MW	

# NYISO TRANSFER LIMITATIONS

Sunday ,October 13, 2019 to Tuesday ,April 13, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE**

Mon 05/04/2020 to Mon 05/18/2020  
 0800 Continuous 1700  
 Work scheduled by: PJM

FWD  
 (Import)  
 SCH - PJM\_NEPTUNE **0 MW**  
 Impacts Total Transfer Capability 660 MW  
 TTC with All Lines In Service 660 MW

**NEWBRDGE-DUFFYAVE\_345\_501**

Mon 05/04/2020 to Mon 05/18/2020  
 0800 Continuous 1700  
 Work scheduled by: PJM

FWD  
 (Import)  
 SCH - PJM\_NEPTUNE **0 MW**  
 Impacts Total Transfer Capability 660 MW  
 TTC with All Lines In Service 660 MW

**NEWBRDGE\_345\_138\_BK\_1**

Mon 05/04/2020 to Mon 05/18/2020  
 0800 Continuous 1700  
 Work scheduled by: PJM

FWD  
 (Import)  
 SCH - PJM\_NEPTUNE **375 MW**  
 Impacts Total Transfer Capability 285 MW  
 TTC with All Lines In Service 660 MW

**NEWBRDGE\_345\_138\_BK\_2**

Mon 05/04/2020 to Mon 05/18/2020  
 0800 Continuous 1700  
 Work scheduled by: PJM

FWD  
 (Import)  
 SCH - PJM\_NEPTUNE **375 MW**  
 Impacts Total Transfer Capability 285 MW  
 TTC with All Lines In Service 660 MW

**PANNELL\_-CLAY\_\_\_\_345\_1**

Mon 05/11/2020 to Fri 05/15/2020  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 WEST CENTRAL **1300 MW**  
 Impacts Total Transfer Capability 950 MW  
 TTC with All Lines In Service 2250 MW

**COOPERS\_-DOLSONAV\_345\_CCDA42**

Mon 05/11/2020 to Fri 05/29/2020 **UPDATED by NYPA 03/21/2019**  
 0700 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2720 MW**  
 Impacts Total Transfer Capability 255 MW  
 TTC with All Lines In Service 2975 MW

**NIAGARA\_-ROCHESTR\_345\_NR2**

Mon 05/18/2020 to Fri 05/22/2020  
 0500 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 DYSINGER EAST **1400 MW**  
 Impacts Total Transfer Capability 1750 MW  
 TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 13, 2019 to Tuesday ,April 13, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MOSES -ADIRNDCK_230_MA2</b>					FWD	
Mon 06/01/2020	to	Fri 07/31/2020			(Import)	
0700	Continuous	1730		MOSES SOUTH	<b>2100 MW</b>	
Work scheduled by: NYPA					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	3150 MW
<b>NIAGARA_345_230_AT4</b>						REV
Mon 06/29/2020	to	Tue 06/30/2020			(Export)	
0500	Continuous	1530		SCH - OH - NY	<b>1400 MW</b>	
Work scheduled by: NYPA					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	1700 MW
<b>SCH-IMO-NYISO_NIAG_CB_3008_W/BB</b>					FWD	REV
Mon 07/27/2020	to	Fri 08/07/2020			(Import)	(Export)
0500	Continuous	1530		SCH - OH - NY	<b>1900 MW</b>	<b>1450 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	1900 MW
<b>CHATGUAY-MASSENA_765_7040</b>					FWD	
Sat 08/01/2020	to	Sun 08/02/2020	<b>UPDATED</b>	<b>by NYPA</b>	<b>08/08/2019</b>	(Import)
0500	Continuous	1730				MOSES SOUTH
Work scheduled by: NYPA					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	3150 MW
<b>CHATGUAY-MASSENA_765_7040</b>					FWD	REV
Sat 08/01/2020	to	Sun 08/02/2020	<b>UPDATED</b>	<b>by NYPA</b>	<b>08/08/2019</b>	(Import)
0500	Continuous	1730				SCH - HQ - NY
Work scheduled by: NYPA					Impacts Total Transfer Capability	1500 MW
					TTC with All Lines In Service	1500 MW
<b>MARCY_765_345_AT1</b>					FWD	
Sat 08/01/2020	to	Sun 08/02/2020	<b>UPDATED</b>	<b>by NYPA</b>	<b>08/08/2019</b>	(Import)
0500	Continuous	1730				MOSES SOUTH
Work scheduled by: NYPA					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	3150 MW
<b>MASSENA -MARCY_765_MSU1</b>					FWD	
Sat 08/01/2020	to	Sun 08/02/2020	<b>UPDATED</b>	<b>by NYPA</b>	<b>08/08/2019</b>	(Import)
0500	Continuous	1730				CENTRAL EAST - VC
Work scheduled by: NYPA					Impacts Total Transfer Capability	710 MW
					TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 13, 2019 to Tuesday ,April 13, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MASSENA_-MARCY_765_MSU1</b>						FWD	
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)	
0500	Continuous	1730				MOSES SOUTH	<b>500 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	2650 MW
						TTC with All Lines In Service	3150 MW
<b>MASSENA_-MARCY_765_MSU1</b>						FWD	REV
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)	(Export)
0500	Continuous	1730				SCH - HQ - NY	<b>475 MW 1000 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	1025 MW 0 MW
						TTC with All Lines In Service	1500 MW 1000 MW
<b>MASSENA_-MARCY_765_MSU1</b>						FWD	
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)	
0500	Continuous	1730				SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	190 MW
<b>MASSENA_-MARCY_765_MSU1 &amp; CHATGUAY-MASSENA_765_7040</b>						FWD	
Sat 08/01/2020	to	Sun 08/02/2020				(Import)	
0500		1730				MOSES SOUTH	<b>500 MW</b>
Work scheduled by:						Impacts Total Transfer Capability	2650 MW
						TTC with All Lines In Service	3150 MW
<b>MOSES_-MASSENA_230_MMS1 &amp; MOSES_-MASSENA_230_MMS2</b>						FWD	REV
Sat 08/01/2020	to	Sun 08/02/2020				(Import)	(Export)
0500		1730				SCH - HQ - NY	<b>850 MW 0 MW</b>
Work scheduled by:						Impacts Total Transfer Capability	650 MW 1000 MW
						TTC with All Lines In Service	1500 MW 1000 MW
<b>MOSES_-MASSENA_230_MMS1 &amp; MOSES_-MASSENA_230_MMS2</b>						FWD	
Sat 08/01/2020	to	Sun 08/02/2020				(Import)	
0500		1730				SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by:						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	190 MW
<b>STLAWRNC-MOSES_230_L33P &amp; MASSENA_-MARCY_765_MSU1</b>						FWD	
Sat 08/01/2020	to	Sun 08/02/2020				(Import)	
0500		1730				SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by:						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	190 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 13, 2019 to Tuesday ,April 13, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>STLAWRNC-MOSES___230_L33P &amp; MOSES___-MASSENA_230_MMS1 &amp; MOSES___-                  MASSENA_230_MMS2</p> <p>Sat 08/01/2020 to Sun 08/02/2020                  0500 1730</p> <p>Work scheduled by:</p>	<p>FWD                  (Import)                  SCH - HQ_CEDARS <b>90 MW</b>                  Impacts Total Transfer Capability 100 MW                  TTC with All Lines In Service 190 MW</p>
<p>MOSES___-ADIRNDCK_230_MA2</p> <p>Mon 08/03/2020 to Sun 09/13/2020                  0700 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p>FWD                  (Import)                  MOSES SOUTH <b>2100 MW</b>                  Impacts Total Transfer Capability 1050 MW                  TTC with All Lines In Service 3150 MW</p>
<p>FRASANNX-COOPERS__345_UCC2-41</p> <p>Mon 09/07/2020 to Fri 10/23/2020 <b>UPDATED by NYPA 03/01/2019</b>                  0700 Continuous 1730</p> <p>Work scheduled by: NYPA <b>ARR: 19</b></p>	<p>FWD                  (Import)                  CENTRAL EAST - VC <b>2500 MW</b>                  Impacts Total Transfer Capability 475 MW                  TTC with All Lines In Service 2975 MW</p>
<p>MARCY___-FRASANNX_345_UCC2-41</p> <p>Mon 09/07/2020 to Fri 10/23/2020 <b>UPDATED by NYPA 03/01/2019</b>                  0700 Continuous 1730</p> <p>Work scheduled by: NYPA <b>ARR: 19</b></p>	<p>FWD                  (Import)                  CENTRAL EAST - VC <b>2500 MW</b>                  Impacts Total Transfer Capability 475 MW                  TTC with All Lines In Service 2975 MW</p>
<p>MARCY___765_345_AT1</p> <p>Mon 09/14/2020 to Mon 09/14/2020                  0500 Continuous 1730</p> <p>Work scheduled by: NYPA <b>ARR: 19</b></p>	<p>FWD                  (Import)                  MOSES SOUTH <b>1750 MW</b>                  Impacts Total Transfer Capability 1400 MW                  TTC with All Lines In Service 3150 MW</p>
<p>NIAGARA_-KINTIGH__345_NS1-38</p> <p>Mon 09/14/2020 to Thu 09/17/2020                  0500 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p>FWD                  (Import)                  DYSINGER EAST <b>1400 MW</b>                  Impacts Total Transfer Capability 1750 MW                  TTC with All Lines In Service 3150 MW</p>
<p>MOSES___-ADIRNDCK_230_MA2</p> <p>Tue 09/15/2020 to Sat 11/14/2020                  0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p>FWD                  (Import)                  MOSES SOUTH <b>2100 MW</b>                  Impacts Total Transfer Capability 1050 MW                  TTC with All Lines In Service 3150 MW</p>



# NYISO TRANSFER LIMITATIONS

Sunday ,October 13, 2019 to Tuesday ,April 13, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NIAGARA\_-ROCHESTR\_345\_NR2**

Fri 09/18/2020 to Sat 11/14/2020  
0500 Continuous 2330

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

**CLAY\_-EDIC\_345\_1-16**

Mon 09/21/2020 to Fri 09/25/2020  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

**ROSETON\_-ROCKTVRN\_345\_311**

Mon 09/21/2020 to Fri 10/23/2020 **UPDATED by CHGE 10/09/2019**  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4400 MW**  
Impacts Total Transfer Capability 1300 MW  
TTC with All Lines In Service 5700 MW

**CLAY\_-EDIC\_345\_2-15**

Mon 09/28/2020 to Fri 10/02/2020  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

**DUNWODIE\_345KV\_3**

Thu 10/01/2020 to Thu 10/01/2020 **UPDATED by CONED 09/05/2019**  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_5**

Thu 10/01/2020 to Thu 10/01/2020 **UPDATED by CONED 09/05/2019**  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**DUNWODIE-MOTTHAVN\_345\_71**

Thu 10/01/2020 to Thu 11/05/2020 **UPDATED by CONED 09/05/2019**  
0001 Continuous 0300

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 13, 2019 to Tuesday ,April 13, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>HURLYAVE-ROSETON__345_303</b>						FWD
Mon 10/26/2020	to	Fri 12/04/2020	<u>UPDATED</u>	<u>by CHGE</u>	<u>10/09/2019</u>	(Import)
0800	Continuous	1600				<b>4100 MW</b>
Work scheduled by: CHGE						Impacts Total Transfer Capability 1600 MW
						TTC with All Lines In Service 5700 MW
<b>SCH-IMO-NYISO_LIMIT_1750</b>						FWD
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Import)
0001	Continuous	2359				<b>2050 MW</b>
Work scheduled by: IESO						Impacts Total Transfer Capability 200 MW
						TTC with All Lines In Service 2250 MW
<b>SCH-NYISO-IMO_LIMIT_1600</b>						REV
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Export)
0001	Continuous	2359				<b>1900 MW</b>
Work scheduled by: IESO						Impacts Total Transfer Capability 100 MW
						TTC with All Lines In Service 2000 MW
<b>DUNWODIE_345KV_3</b>						FWD
Thu 11/05/2020	to	Thu 11/05/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>09/05/2019</u>	(Import)
0230	Continuous	0300				<b>3800 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
<b>DUNWODIE_345KV_5</b>						FWD
Thu 11/05/2020	to	Thu 11/05/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>09/05/2019</u>	(Import)
0230	Continuous	0300				<b>3800 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
<b>CHATGUAY-MASSENA__765_7040</b>						FWD
Sun 11/15/2020	to	Mon 11/30/2020				(Import)
0100	Continuous	1900				<b>1550 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability 1600 MW
						TTC with All Lines In Service 3150 MW
<b>CHATGUAY-MASSENA__765_7040</b>						FWD      REV
Sun 11/15/2020	to	Mon 11/30/2020				(Import) (Export)
0100	Continuous	1900				<b>0 MW      0 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability 1500 MW 1000 MW
						TTC with All Lines In Service 1500 MW 1000 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 13, 2019 to Tuesday ,April 13, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MARCY___765_345_AT1</b>		FWD
Sun 11/15/2020	to Mon 11/30/2020	(Import)
0100	Continuous 1900	MOSES SOUTH <b>1750 MW</b>
Work scheduled by: NYPA	<b>ARR: 19</b>	Impacts Total Transfer Capability 1400 MW
		TTC with All Lines In Service 3150 MW
<b>MARCY___765_345_AT2</b>		FWD
Sun 11/15/2020	to Mon 11/30/2020	(Import)
0100	Continuous 1900	MOSES SOUTH <b>1700 MW</b>
Work scheduled by: NYPA	<b>ARR: 19</b>	Impacts Total Transfer Capability 1450 MW
		TTC with All Lines In Service 3150 MW
<b>MASSENA_-MARCY___765_MSU1</b>		FWD
Sun 11/15/2020	to Mon 11/30/2020	(Import)
0100	Continuous 1900	CENTRAL EAST - VC <b>2265 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability 710 MW
		TTC with All Lines In Service 2975 MW
<b>MASSENA_-MARCY___765_MSU1</b>		FWD
Sun 11/15/2020	to Mon 11/30/2020	(Import)
0100	Continuous 1900	MOSES SOUTH <b>500 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability 2650 MW
		TTC with All Lines In Service 3150 MW
<b>MASSENA_-MARCY___765_MSU1</b>		FWD
Sun 11/15/2020	to Mon 11/30/2020	(Import) (Export)
0100	Continuous 1900	SCH - HQ - NY <b>475 MW 1000 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability 1025 MW 0 MW
		TTC with All Lines In Service 1500 MW 1000 MW
<b>MASSENA_-MARCY___765_MSU1</b>		FWD
Sun 11/15/2020	to Mon 11/30/2020	(Import)
0100	Continuous 1900	SCH - HQ_CEDARS <b>90 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability 109 MW
		TTC with All Lines In Service 199 MW
<b>MASSENA_-MARCY___765_MSU1 &amp; CHATGUAY-MASSENA_765_7040</b>		FWD
Sun 11/15/2020	to Mon 11/30/2020	(Import)
0100	Continuous 1900	MOSES SOUTH <b>500 MW</b>
Work scheduled by:		Impacts Total Transfer Capability 2650 MW
		TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 13, 2019 to Tuesday ,April 13, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**MOSES -MASSENA 230\_MMS1 & MOSES -MASSENA 230\_MMS2**

Sun 11/15/2020 to Mon 11/30/2020  
 0100 1900

Work scheduled by:

FWD (Import) (Export)  
 SCH - HQ - NY **850 MW 0 MW**  
 Impacts Total Transfer Capability 650 MW 1000 MW  
 TTC with All Lines In Service 1500 MW 1000 MW

-----  
**MOSES -MASSENA 230\_MMS1 & MOSES -MASSENA 230\_MMS2**

Sun 11/15/2020 to Mon 11/30/2020  
 0100 1900

Work scheduled by:

FWD (Import)  
 SCH - HQ\_CEDARS **90 MW**  
 Impacts Total Transfer Capability 109 MW  
 TTC with All Lines In Service 199 MW

-----  
**STLAWRNC-MOSES 230\_L33P & MASSENA -MARCY 765\_MSU1**

Sun 11/15/2020 to Mon 11/30/2020  
 0100 1900

Work scheduled by:

FWD (Import)  
 SCH - HQ\_CEDARS **90 MW**  
 Impacts Total Transfer Capability 109 MW  
 TTC with All Lines In Service 199 MW

-----  
**STLAWRNC-MOSES 230\_L33P & MOSES -MASSENA 230\_MMS1 & MOSES -MASSENA 230\_MMS2**

Sun 11/15/2020 to Mon 11/30/2020  
 0100 1900

Work scheduled by:

FWD (Import)  
 SCH - HQ\_CEDARS **90 MW**  
 Impacts Total Transfer Capability 109 MW  
 TTC with All Lines In Service 199 MW

-----  
**PLSNTVLE-DUNWODIE\_345\_W89**

Mon 11/16/2020 to Mon 11/16/2020  
 0001 Continuous 0030

Work scheduled by: ConEd

FWD (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

-----  
**PLSNTVLE-DUNWODIE\_345\_W89**

Thu 11/26/2020 to Thu 11/26/2020  
 0230 Continuous 0300

Work scheduled by: ConEd

FWD (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

-----  
**MOSES -ADIRNDCK 230\_MA1**

Tue 12/01/2020 to Mon 05/31/2021  
 0700 Continuous 1300

Work scheduled by: NYPA

FWD (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 13, 2019 to Tuesday ,April 13, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOTTHAVN-RAINEY\_\_\_345\_Q11

Mon 03/01/2021 to Tue 04/06/2021  
 0001 Continuous 0700

Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

CLAY\_\_\_-EDIC\_\_\_345\_2-15

Mon 03/29/2021 to Fri 04/16/2021  
 0800 Continuous 1730

Work scheduled by: NYPA

FWD  
 (Import)  
 OSWEGO EXPORT **4850 MW**  
 Impacts Total Transfer Capability 400 MW  
 TTC with All Lines In Service 5250 MW