

NYISO TRANSFER LIMITATIONS

Wednesday, October 16, 2019 to Friday, April 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					FWD	REV
HUDSONP_-FARRAGUT_345_B3402					(Import)	(Export)
Mon 01/15/2018	to	Fri 05/01/2020	<u>EXTENDED</u>	<u>by CONED</u>	<u>10/08/2019</u>	
0001	Continuous	2359				
Work scheduled by: ConEd					SCH - PJ - NY	2100 MW
					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	2150 MW
<hr/>					FWD	REV
HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403					(Import)	(Export)
Mon 01/15/2018	to	Fri 05/01/2020				
0001		2359				
Work scheduled by:					SCH - PJ - NY	2050 MW
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	2150 MW
<hr/>					FWD	REV
MARION_-FARRAGUT_345_C3403					(Import)	(Export)
Mon 01/15/2018	to	Fri 05/01/2020	<u>EXTENDED</u>	<u>by CONED</u>	<u>10/08/2019</u>	
0001	Continuous	2359				
Work scheduled by: ConEd					SCH - PJ - NY	2100 MW
					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	2150 MW
<hr/>					FWD	REV
STLAWRNC-MOSES_230_L33P					(Import)	(Export)
Mon 04/30/2018	to	Fri 12/31/2021	<u>EXT FORCE</u>	<u>by IESO</u>	<u>08/21/2018</u>	
0456	Continuous	2359				
Work scheduled by: IESO					SCH - OH - NY	
					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
<hr/>					FWD	REV
BECK_-NIAGARA_345_PA302					(Import)	(Export)
Wed 07/31/2019	to	Tue 11/12/2019	<u>EXTENDED</u>	<u>by IESO</u>	<u>08/29/2019</u>	
0800	Continuous	1700				
Work scheduled by: IESO					SCH - OH - NY	900 MW
					Impacts Total Transfer Capability	1000 MW
					TTC with All Lines In Service	1900 MW
<hr/>					FWD	REV
NIAGARA_-PACKARD_230_61					(Import)	(Export)
Tue 09/03/2019	to	Fri 10/18/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>12/19/2018</u>	
0500	Continuous	1700				
Work scheduled by: NYPA					SCH - OH - NY	
					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
<hr/>					FWD	REV
PLSNTVLY_345KV_RNS5					(Import)	(Export)
Sat 09/14/2019	to	Thu 10/17/2019	<u>UPDATED</u>	<u>by CE</u>	<u>10/10/2019</u>	
0001	Continuous	0800				
Work scheduled by: ConEd					UPNY CONED	3800 MW
					Impacts Total Transfer Capability	1900 MW
					TTC with All Lines In Service	5700 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 16, 2019 to Friday, April 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LEEDS___-HURLYAVE_345_301					FWD	
Mon 09/30/2019	to	Fri 10/11/2019	<u>UPDATED</u>	<u>by CHGE</u>	<u>09/05/2019</u>	(Import)
0800	Continuous	1600				4100 MW
Work scheduled by: CHGE					UPNY CONED	
					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	5700 MW
FROST_BR-LONG_MTN_345_352					FWD	
Wed 10/02/2019	to	Fri 10/18/2019	<u>UPDATED</u>	<u>by ISONE</u>	<u>09/30/2019</u>	(Import)
0700	Continuous	1600				1150 MW
Work scheduled by: ISONE					SCH - NE - NY	
					Impacts Total Transfer Capability	250 MW
					TTC with All Lines In Service	1400 MW
SCH-NE-NYISO_LIMIT_400					FWD	
Wed 10/02/2019	to	Fri 10/18/2019	<u>UPDATED</u>	<u>by ISONE</u>	<u>09/30/2019</u>	(Import)
0700	Continuous	1600				600 MW
Work scheduled by: ISONE					SCH - NE - NY	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	1400 MW
DUNWODIE_345KV_4					FWD	
Thu 10/03/2019	to	Thu 10/17/2019	<u>UPDATED</u>	<u>by CE</u>	<u>09/30/2019</u>	(Import)
0001	Continuous	2359				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
SPRNBK__345KV_RS3 & SPRNBK__345KV_RS4					FWD	
Fri 10/04/2019	to	Wed 10/16/2019				(Import)
0201		2230				3200 MW
Work scheduled by:					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
SCH-NE-NYISO_LIMIT_300					FWD	
Sat 10/05/2019	to	Fri 10/18/2019	<u>UPDATED</u>	<u>by ISONE</u>	<u>09/30/2019</u>	(Import)
1601	Continuous	1600				500 MW
Work scheduled by: ISONE					SCH - NE - NY	
					Impacts Total Transfer Capability	900 MW
					TTC with All Lines In Service	1400 MW
CHAT_DC_GC2					FWD	
Mon 10/07/2019	to	Fri 10/11/2019				(Import)
0400	Continuous	2359				2850 MW
Work scheduled by: HQ					MOSES SOUTH	
					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 16, 2019 to Friday, April 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event Name	Start Date	End Date	Time	Duration	Notes	Impact	TTC
CHAT_DC_GC2							
Mon 10/07/2019	to	Fri 10/11/2019	0400	Continuous	2359	SCH - HQ - NY	500 MW
Work scheduled by: HQ						Impacts Total Transfer Capability	500 MW
						TTC with All Lines In Service	1000 MW
SCH-HQ-NYISO_LIMIT_1100							
Mon 10/07/2019	to	Fri 11/22/2019	0400	Continuous	2300	SCH - HQ - NY	1100 MW
Work scheduled by: HQ						Impacts Total Transfer Capability	400 MW
						TTC with All Lines In Service	1500 MW
CLAY -EDIC 345_2-15							
Mon 10/07/2019	to	Fri 10/11/2019	0600	Continuous	1530	OSWEGO EXPORT	4850 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	400 MW
						TTC with All Lines In Service	5250 MW
SHORE_RD_345_138_BK 1							
Wed 10/09/2019	to	Fri 10/11/2019	1825	Continuous	1902	FORCED by CONED 10/10/2019 CONED - LIPA	1350 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	150 MW
						TTC with All Lines In Service	1500 MW
SHORE_RD_345_138_BK 2							
Wed 10/09/2019	to	Fri 10/11/2019	1825	Continuous	1902	FORCED by CONED 10/10/2019 CONED - LIPA	1350 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	150 MW
						TTC with All Lines In Service	1500 MW
DUNWODIE-SHORE_RD_345_Y50							
Wed 10/09/2019	to	Fri 10/11/2019	1825	Continuous	2359	FORCED by CONED 10/10/2019 CONED - LIPA	800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	700 MW
						TTC with All Lines In Service	1500 MW
CHAT_DC_GC1							
Sat 10/12/2019	to	Sat 10/12/2019	0001	Continuous	0200	UPDATED by HQ 10/04/2019 MOSES SOUTH	2850 MW
Work scheduled by: HQ						Impacts Total Transfer Capability	300 MW
						TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 16, 2019 to Friday, April 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC1						REV
Sat 10/12/2019	to	Sat 10/12/2019	<u>UPDATED</u>	<u>by HQ</u>	<u>10/04/2019</u>	(Export)
0001	Continuous	0200				500 MW
Work scheduled by: HQ						500 MW
						1000 MW
CHAT_DC_GC1 & CHAT_DC_GC2						FWD
Sat 10/12/2019	to	Sat 10/12/2019				(Import)
0001		0200				2550 MW
Work scheduled by:						600 MW
						3150 MW
CHAT_DC_GC1 & CHAT_DC_GC2						FWD REV
Sat 10/12/2019	to	Sat 10/12/2019				(Import) (Export)
0001		0200				1370 MW 0 MW
Work scheduled by:						130 MW 1000 MW
						1500 MW 1000 MW
CHAT_DC_GC2						FWD
Sat 10/12/2019	to	Sat 10/12/2019	<u>UPDATED</u>	<u>by HQ</u>	<u>10/04/2019</u>	(Import)
0001	Continuous	0200				2850 MW
Work scheduled by: HQ						300 MW
						3150 MW
CHAT_DC_GC2						REV
Sat 10/12/2019	to	Sat 10/12/2019	<u>UPDATED</u>	<u>by HQ</u>	<u>10/04/2019</u>	(Export)
0001	Continuous	0200				500 MW
Work scheduled by: HQ						500 MW
						1000 MW
SCH-HQ-NYISO_LIMIT_600						FWD
Sat 10/12/2019	to	Sat 10/12/2019	<u>UPDATED</u>	<u>by HQ</u>	<u>10/04/2019</u>	(Import)
0001	Continuous	0200				600 MW
Work scheduled by: HQ						900 MW
						1500 MW
LEEDS___-PLSNTVLY_345_92						FWD
Sat 10/12/2019	to	Tue 10/15/2019	<u>UPDATED</u>	<u>by CE</u>	<u>10/10/2019</u>	(Import)
0001	Continuous	0200				3800 MW
Work scheduled by: ConEd						1900 MW
						5700 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 16, 2019 to Friday, April 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC1 & CHAT_DC_GC2 & MOSES -MASSENA_230_MMS1 & MOSES -MASSENA_230_MMS2	FWD	
	(Import)	
Sat 10/12/2019 to Sat 10/12/2019	MOSES SOUTH	1950 MW
0100 to 0200	Impacts Total Transfer Capability	1200 MW
	TTC with All Lines In Service	3150 MW
Work scheduled by:		
<hr/>		
CHATGUAY-MASSENA_765_7040	FWD	
	(Import)	
Sat 10/12/2019 to Tue 10/22/2019	MOSES SOUTH	1550 MW
0100 Continuous 2000	Impacts Total Transfer Capability	1600 MW
	TTC with All Lines In Service	3150 MW
Work scheduled by: NYPA		
<hr/>		
CHATGUAY-MASSENA_765_7040	FWD	REV
	(Import)	(Export)
Sat 10/12/2019 to Tue 10/22/2019	SCH - HQ - NY	0 MW 0 MW
0100 Continuous 2000	Impacts Total Transfer Capability	1500 MW 1000 MW
	TTC with All Lines In Service	1500 MW 1000 MW
Work scheduled by: NYPA		
<hr/>		
MARCY_765_345_AT1	FWD	
	(Import)	
Sat 10/12/2019 to Tue 10/22/2019	MOSES SOUTH	1750 MW
0100 Continuous 2000	Impacts Total Transfer Capability	1400 MW
	TTC with All Lines In Service	3150 MW
Work scheduled by: NYPA		
<hr/>		
MARCY_765_345_AT2	FWD	
	(Import)	
Sat 10/12/2019 to Tue 10/22/2019	MOSES SOUTH	1700 MW
0100 Continuous 2000	Impacts Total Transfer Capability	1450 MW
	TTC with All Lines In Service	3150 MW
Work scheduled by: NYPA		
<hr/>		
MASSENA -MARCY_765_MSU1	FWD	
	(Import)	
Sat 10/12/2019 to Tue 10/22/2019	CENTRAL EAST - VC	2265 MW
0100 Continuous 2000	Impacts Total Transfer Capability	710 MW
	TTC with All Lines In Service	2975 MW
Work scheduled by: NYPA		
<hr/>		
MASSENA -MARCY_765_MSU1	FWD	
	(Import)	
Sat 10/12/2019 to Tue 10/22/2019	MOSES SOUTH	500 MW
0100 Continuous 2000	Impacts Total Transfer Capability	2650 MW
	TTC with All Lines In Service	3150 MW
Work scheduled by: NYPA		

NYISO TRANSFER LIMITATIONS

Wednesday, October 16, 2019 to Friday, April 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA -MARCY 765_MSU1	FWD	REV
Sat 10/12/2019 to Tue 10/22/2019	(Import)	(Export)
0100 Continuous 2000	475 MW	1000 MW
Work scheduled by: NYPA	SCH - HQ - NY	
	Impacts Total Transfer Capability 1025 MW 0 MW	
	TTC with All Lines In Service 1500 MW 1000 MW	
<hr/>		
MASSENA -MARCY 765_MSU1	FWD	
Sat 10/12/2019 to Tue 10/22/2019	(Import)	
0100 Continuous 2000	90 MW	
Work scheduled by: NYPA	SCH - HQ_CEDARS	
	Impacts Total Transfer Capability 100 MW	
	TTC with All Lines In Service 190 MW	
<hr/>		
MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040	FWD	
Sat 10/12/2019 to Tue 10/22/2019	(Import)	
0100 2000	500 MW	
Work scheduled by:	MOSES SOUTH	
	Impacts Total Transfer Capability 2650 MW	
	TTC with All Lines In Service 3150 MW	
<hr/>		
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2	FWD	REV
Sat 10/12/2019 to Tue 10/22/2019	(Import)	(Export)
0100 2000	850 MW	0 MW
Work scheduled by:	SCH - HQ - NY	
	Impacts Total Transfer Capability 650 MW 1000 MW	
	TTC with All Lines In Service 1500 MW 1000 MW	
<hr/>		
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2	FWD	
Sat 10/12/2019 to Tue 10/22/2019	(Import)	
0100 2000	90 MW	
Work scheduled by:	SCH - HQ_CEDARS	
	Impacts Total Transfer Capability 100 MW	
	TTC with All Lines In Service 190 MW	
<hr/>		
STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1	FWD	
Sat 10/12/2019 to Tue 10/22/2019	(Import)	
0100 2000	90 MW	
Work scheduled by:	SCH - HQ_CEDARS	
	Impacts Total Transfer Capability 100 MW	
	TTC with All Lines In Service 190 MW	
<hr/>		
STLAWRNC-MOSES 230_L33P & MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2	FWD	
Sat 10/12/2019 to Tue 10/22/2019	(Import)	
0100 2000	90 MW	
Work scheduled by:	SCH - HQ_CEDARS	
	Impacts Total Transfer Capability 100 MW	
	TTC with All Lines In Service 190 MW	

NYISO TRANSFER LIMITATIONS

Wednesday, October 16, 2019 to Friday, April 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC2			FWD
Sat 10/12/2019	to	Sat 10/12/2019	(Import)
0201	Continuous	1959	MOSES SOUTH 2850 MW
Work scheduled by: HQ			Impacts Total Transfer Capability 300 MW
			TTC with All Lines In Service 3150 MW
CHAT_DC_GC2			REV
Sat 10/12/2019	to	Sat 10/12/2019	(Export)
0201	Continuous	1959	SCH - HQ - NY 500 MW
Work scheduled by: HQ			Impacts Total Transfer Capability 500 MW
			TTC with All Lines In Service 1000 MW
SCH-IMO-NYISO_LIMIT_600			FWD
Sat 10/12/2019	to	Sat 10/12/2019	(Import)
0900	Continuous	1630	SCH - OH - NY 900 MW
Work scheduled by: IESO			Impacts Total Transfer Capability 1000 MW
			TTC with All Lines In Service 1900 MW
SCH-NYISO-IMO_LIMIT_300			REV
Sat 10/12/2019	to	Sat 10/12/2019	(Export)
0900	Continuous	1630	SCH - OH - NY 600 MW
Work scheduled by: IESO			Impacts Total Transfer Capability 1100 MW
			TTC with All Lines In Service 1700 MW
CHAT_DC_GC1			FWD
Sat 10/12/2019	to	Sun 10/13/2019	(Import)
2000	Continuous	2300	MOSES SOUTH 2850 MW
Work scheduled by: HQ			Impacts Total Transfer Capability 300 MW
			TTC with All Lines In Service 3150 MW
CHAT_DC_GC1			REV
Sat 10/12/2019	to	Sun 10/13/2019	(Export)
2000	Continuous	2300	SCH - HQ - NY 500 MW
Work scheduled by: HQ			Impacts Total Transfer Capability 500 MW
			TTC with All Lines In Service 1000 MW
CHAT_DC_GC1 & CHAT_DC_GC2			FWD
Sat 10/12/2019	to	Sun 10/13/2019	(Import)
2000		2300	MOSES SOUTH 2550 MW
Work scheduled by:			Impacts Total Transfer Capability 600 MW
			TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 16, 2019 to Friday, April 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC1 & CHAT_DC_GC2			FWD	REV
			(Import)	(Export)
Sat 10/12/2019	to	Sun 10/13/2019		
2000		2300	SCH - HQ - NY	1370 MW 0 MW
Work scheduled by:			Impacts Total Transfer Capability	130 MW 1000 MW
			TTC with All Lines In Service	1500 MW 1000 MW
CHAT_DC_GC1 & CHAT_DC_GC2 & MOSES -MASSENA_230_MMS1 & MOSES -MASSENA_230_MMS2			FWD	
			(Import)	
Sat 10/12/2019	to	Sun 10/13/2019	MOSES SOUTH	1950 MW
2000		2300	Impacts Total Transfer Capability	1200 MW
Work scheduled by:			TTC with All Lines In Service	3150 MW
CHAT_DC_GC2			FWD	
			(Import)	
Sat 10/12/2019	to	Sun 10/13/2019	MOSES SOUTH	2850 MW
2000	Continuous	2300	Impacts Total Transfer Capability	300 MW
Work scheduled by: HQ			TTC with All Lines In Service	3150 MW
CHAT_DC_GC2				REV
				(Export)
Sat 10/12/2019	to	Sun 10/13/2019	SCH - HQ - NY	500 MW
2000	Continuous	2300	Impacts Total Transfer Capability	500 MW
Work scheduled by: HQ			TTC with All Lines In Service	1000 MW
SCH-HQ-NYISO_LIMIT_1150			FWD	
			(Import)	
Sat 10/12/2019	to	Sun 10/13/2019	SCH - HQ - NY	1150 MW
2000	Continuous	2300	Impacts Total Transfer Capability	350 MW
Work scheduled by: HQ			TTC with All Lines In Service	1500 MW
E13THSTA-FARRAGUT_345_45			FWD	
			(Import)	
Sun 10/13/2019	to	Mon 10/14/2019	SPR/DUN-SOUTH	3800 MW
0001	Continuous	0200	Impacts Total Transfer Capability	800 MW
Work scheduled by: ConEd			TTC with All Lines In Service	4600 MW
CHAT_DC_GC2			FWD	
			(Import)	
Sun 10/13/2019	to	Fri 11/22/2019	MOSES SOUTH	2850 MW
2301	Continuous	2300	Impacts Total Transfer Capability	300 MW
Work scheduled by: HQ			TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 16, 2019 to Friday, April 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC2					REV	
Sun 10/13/2019	to	Fri 11/22/2019			(Export)	
2301	Continuous	2300		SCH - HQ - NY		500 MW
Work scheduled by: HQ					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1000 MW
SHORE_RD_345_138_BK_2					FWD	
Mon 10/14/2019	to	Mon 10/14/2019	<u>by LI</u>	<u>10/16/2019</u>	(Import)	
0001	Continuous	2359		CONED - LIPA		1350 MW
Work scheduled by: LI					Impacts Total Transfer Capability	150 MW
					TTC with All Lines In Service	1500 MW
SHOR_NPX-SHOREHAM_138_CSC					FWD	REV
Mon 10/14/2019	to	Fri 10/18/2019	<u>UPDATED</u>	<u>by ISONE</u>	<u>08/09/2019</u>	(Import) (Export)
0600	Continuous	1600		SCH - NPX_CSC		0 MW 0 MW
Work scheduled by: LI					Impacts Total Transfer Capability	330 MW 330 MW
					TTC with All Lines In Service	330 MW 330 MW
FIVEMILE-STOLLERD_345_29					FWD	
Mon 10/14/2019	to	Fri 10/18/2019	<u>UPDATED</u>	<u>by NGRID</u>	<u>10/08/2019</u>	(Import)
0700	Continuous	1400		SCH - PJ - NY		2100 MW
Work scheduled by: NYSEG					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	2150 MW
MOTTHAVN-RAINEY__345_Q12					FWD	
Mon 10/14/2019	to	Wed 10/16/2019			(Import)	
2359	Continuous	2359		SPR/DUN-SOUTH		3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
PLSNTVLY-WOOD_ST__345_F30					FWD	
Tue 10/15/2019	to	Thu 10/17/2019	<u>UPDATED</u>	<u>by CE</u>	<u>10/10/2019</u>	(Import)
0301	Continuous	0300		UPNY CONED		4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1700 MW
					TTC with All Lines In Service	5700 MW
LEEDS__-HURLYAVE_345_301					FWD	
Tue 10/15/2019	to	Tue 10/15/2019	<u>UPDATED</u>	<u>by CHGE</u>	<u>09/05/2019</u>	(Import)
0800	Continuous	1629		UPNY CONED		4100 MW
Work scheduled by: CHGE					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	5700 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 16, 2019 to Friday, April 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Thu 10/17/2019 to Wed 10/23/2019
 0001 Continuous 2359
 Work scheduled by: LI

FWD
 (Import)
 SCH - PJM_NEPTUNE **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE-DUFFYAVE_345_501

Thu 10/17/2019 to Wed 10/23/2019
 0001 Continuous 2359
 Work scheduled by: LI

FWD
 (Import)
 SCH - PJM_NEPTUNE **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_1

Thu 10/17/2019 to Wed 10/23/2019
 0001 Continuous 2359
 Work scheduled by: LI

FWD
 (Import)
 SCH - PJM_NEPTUNE **375 MW**
 Impacts Total Transfer Capability 285 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_2

Thu 10/17/2019 to Wed 10/23/2019
 0001 Continuous 2359
 Work scheduled by: LI

FWD
 (Import)
 SCH - PJM_NEPTUNE **375 MW**
 Impacts Total Transfer Capability 285 MW
 TTC with All Lines In Service 660 MW

DUNWODIE_345KV_7

Fri 10/18/2019 to Fri 10/18/2019
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_8

Fri 10/18/2019 to Fri 10/18/2019
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE-MOTTHAVN_345_72

Fri 10/18/2019 to Sat 10/19/2019
 0001 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 16, 2019 to Friday, April 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_7

Sat 10/19/2019 to Sat 10/19/2019
 0230 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_8

Sat 10/19/2019 to Sat 10/19/2019
 0230 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

KINTIGH_-ROCHESTR_345_SRI-39

Sat 10/19/2019 to Sun 10/27/2019
 0700 Continuous 1900
 Work scheduled by: RGE

FWD
 (Import)
 DYSINGER EAST **1400 MW**
 Impacts Total Transfer Capability 1750 MW
 TTC with All Lines In Service 3150 MW

SHORE_RD_345_138_BK 2

Mon 10/21/2019 to Mon 10/21/2019 **by LI 10/16/2019**
 0001 Continuous 2359
 Work scheduled by: LI

FWD
 (Import)
 CONED - LIPA **1350 MW**
 Impacts Total Transfer Capability 150 MW
 TTC with All Lines In Service 1500 MW

HURLYAVE-ROSETON__345_303

Mon 10/21/2019 to Thu 10/31/2019
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4100 MW**
 Impacts Total Transfer Capability 1600 MW
 TTC with All Lines In Service 5700 MW

GILBOA_-N.SCTLND_345_GNS-1

Tue 10/22/2019 to Thu 10/24/2019 **UPDATED by NYPA 10/10/2019**
 0700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2520 MW**
 Impacts Total Transfer Capability 455 MW
 TTC with All Lines In Service 2975 MW

WATRCURE_345_230_BK 1

Tue 10/22/2019 to Tue 10/22/2019
 0800 Continuous 1530
 Work scheduled by: NYSEG

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Wednesday, October 16, 2019 to Friday, April 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SHORE_RD_345_138_BK 1					FWD	
Wed 10/23/2019	to	Wed 10/23/2019	<u>by LI</u>	<u>10/16/2019</u>	(Import)	
0001	Continuous	2359			CONED - LIPA	1350 MW
Work scheduled by: LI					Impacts Total Transfer Capability	150 MW
					TTC with All Lines In Service	1500 MW
SCH-IMO-NYISO_LIMIT_500					FWD	
Wed 10/23/2019	to	Fri 11/08/2019	<u>UPDATED</u>	<u>by NYISO</u>	<u>10/15/2019</u>	(Import)
0500	Continuous	1859			SCH - OH - NY	800 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1100 MW
					TTC with All Lines In Service	1900 MW
NIAGARA_345_230_AT4						REV
Wed 10/23/2019	to	Tue 12/17/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/10/2019</u>	(Export)
0500	Continuous	1700			SCH - OH - NY	1400 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	1700 MW
DENNISON-ROSEMNTA_115_1/11					FWD	REV
Wed 10/23/2019	to	Wed 10/23/2019	<u>CANCELLED</u>	<u>by NGrid</u>	<u>10/11/2019</u>	(Import) (Export)
0700	Daily(No Weekends)	1200			SCH - HQ_CEDARS	95 MW 40 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	95 MW 0 MW
					TTC with All Lines In Service	190 MW 40 MW
CEDARS_-ROSEMNTA_115_1/11					FWD	REV
Wed 10/23/2019	to	Wed 10/23/2019			(Import) (Export)	
0700	Daily(No Weekends)	1700			SCH - HQ_CEDARS	95 MW 40 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	95 MW 0 MW
					TTC with All Lines In Service	190 MW 40 MW
DENNISON-ROSEMNTA_115_1/11					FWD	REV
Wed 10/23/2019	to	Wed 10/23/2019			(Import) (Export)	
0700	Daily(No Weekends)	1700			SCH - HQ_CEDARS	95 MW 40 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	95 MW 0 MW
					TTC with All Lines In Service	190 MW 40 MW
EGRDNCTY_345_138_AT1					FWD	
Thu 10/24/2019	to	Sun 11/03/2019	<u>UPDATED</u>	<u>by CE</u>	<u>09/12/2019</u>	(Import)
0001	Continuous	0300			CONED - LIPA	1250 MW
Work scheduled by: LI					Impacts Total Transfer Capability	250 MW
					TTC with All Lines In Service	1500 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 16, 2019 to Friday, April 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event ID	Start Date	End Date	Status	By	Effective Date	Impact	TTC with All Lines In Service
<hr/>							
EGRDNCTY_345_138_AT2						FWD	
Thu 10/24/2019	to	Sun 11/03/2019	<u>UPDATED</u>	<u>by CE</u>	<u>09/12/2019</u>	(Import)	
0001	Continuous	0300				CONED - LIPA	1250 MW
Work scheduled by: LI						Impacts Total Transfer Capability	250 MW
						TTC with All Lines In Service	1500 MW
<hr/>							
SPRNBRK_-EGRDNCTR_345_Y49						FWD	
Thu 10/24/2019	to	Sun 11/03/2019	<u>UPDATED</u>	<u>by CE</u>	<u>09/12/2019</u>	(Import)	
0001	Continuous	0300				CONED - LIPA	775 MW
Work scheduled by: LI						Impacts Total Transfer Capability	725 MW
						TTC with All Lines In Service	1500 MW
<hr/>							
GILBOA_-N.SCTLND_345_GNS-1						FWD	
Fri 10/25/2019	to	Fri 10/25/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/19/2019</u>	(Import)	
1630	Continuous	1730				CENTRAL EAST - VC	2520 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	455 MW
						TTC with All Lines In Service	2975 MW
<hr/>							
NIAGARA_-ROCHESTR_345_NR2						FWD	
Mon 10/28/2019	to	Wed 11/13/2019	<u>CANCELLED</u>	<u>by NYPA</u>	<u>10/16/2019</u>	(Import)	
0500	Continuous	1700				DYSINGER EAST	1400 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	1750 MW
						TTC with All Lines In Service	3150 MW
<hr/>							
HOPATCON-RAMAPO___500_5018						FWD	REV
Fri 11/01/2019	to	Tue 11/05/2019				(Import)	(Export)
0001	Continuous	2200				SCH - PJ - NY	1250 MW 1200 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	1350 MW 350 MW
						TTC with All Lines In Service	2600 MW 1550 MW
<hr/>							
HOPATCON-RAMAPO___500_5018						FWD	
Fri 11/01/2019	to	Tue 11/05/2019				(Import)	
0001	Continuous	2200				UPNY CONED	5000 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	700 MW
						TTC with All Lines In Service	5700 MW
<hr/>							
RAMAPO___345_345_PAR3500						FWD	REV
Fri 11/01/2019	to	Tue 11/05/2019				(Import)	(Export)
0001	Continuous	2200				SCH - PJ - NY	2150 MW 1250 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	450 MW 300 MW
						TTC with All Lines In Service	2600 MW 1550 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 16, 2019 to Friday, April 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

RAMAPO___345_345_PAR4500				FWD	REV
Fri 11/01/2019 to Tue 11/05/2019				(Import) (Export)	
0001	Continuous	2200		2150 MW	1250 MW
Work scheduled by: ConEd				SCH - PJ - NY	
				Impacts Total Transfer Capability	450 MW 300 MW
				TTC with All Lines In Service	2600 MW 1550 MW
RAMAPO___500_345_BK 1500				FWD	REV
Fri 11/01/2019 to Tue 11/05/2019				(Import) (Export)	
0001	Continuous	2200		1250 MW	1200 MW
Work scheduled by: ConEd				SCH - PJ - NY	
				Impacts Total Transfer Capability	1350 MW 350 MW
				TTC with All Lines In Service	2600 MW 1550 MW
RAMAPO___500_345_BK 1500				FWD	
Fri 11/01/2019 to Tue 11/05/2019				(Import)	
0001	Continuous	2200		5000 MW	
Work scheduled by: ConEd				UPNY CONED	
				Impacts Total Transfer Capability	700 MW
				TTC with All Lines In Service	5700 MW
SCH-IMO-NYISO_LIMIT_1750				FWD	
Fri 11/01/2019 to Thu 04/30/2020				(Import)	
0001	Continuous	2359	UPDATED by IESO 05/03/2019	2050 MW	
Work scheduled by: IESO				SCH - OH - NY	
				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	2250 MW
SCH-NYISO-IMO_LIMIT_1600					REV
Fri 11/01/2019 to Thu 04/30/2020				(Export)	
0001	Continuous	2359	UPDATED by IESO 05/03/2019	1900 MW	
Work scheduled by: IESO				SCH - OH - NY	
				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	2000 MW
VOLNEY_-MARCY___345_19				FWD	
Fri 11/01/2019 to Fri 11/01/2019				(Import)	
0730	Daily(No Weekends)	1630		2825 MW	
Work scheduled by: NGrid				CENTRAL EAST - VC	
				Impacts Total Transfer Capability	150 MW
				TTC with All Lines In Service	2975 MW
VOLNEY_-MARCY___345_19				FWD	
Fri 11/01/2019 to Fri 11/01/2019				(Import)	
0730	Daily(No Weekends)	1630		4900 MW	
Work scheduled by: NGrid				OSWEGO EXPORT	
				Impacts Total Transfer Capability	350 MW
				TTC with All Lines In Service	5250 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 16, 2019 to Friday, April 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
SHORE_RD_345_138_BK 1				(Import)	
Mon 11/04/2019	to	Mon 11/04/2019	<u>by LI</u> <u>10/16/2019</u>		
0001	Continuous	2359		CONED - LIPA	1350 MW
Work scheduled by: LI				Impacts Total Transfer Capability	150 MW
				TTC with All Lines In Service	1500 MW
NRTH1385-NOR HBR_138_601				(Import)	(Export)
Mon 11/04/2019	to	Fri 11/15/2019			
0001	Continuous	2359		SCH - NPX_1385	100 MW 100 MW
Work scheduled by: LI				Impacts Total Transfer Capability	100 MW 100 MW
				TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR_138_601 & NRTH1385-NOR HBR_138_602				(Import)	(Export)
Mon 11/04/2019	to	Fri 11/15/2019			
0001		2359		SCH - NPX_1385	0 MW 0 MW
Work scheduled by:				Impacts Total Transfer Capability	200 MW 200 MW
				TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR_138_601 & NRTH1385-NOR HBR_138_603				(Import)	(Export)
Mon 11/04/2019	to	Fri 11/15/2019			
0001		2359		SCH - NPX_1385	0 MW 0 MW
Work scheduled by:				Impacts Total Transfer Capability	200 MW 200 MW
				TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR_138_602				(Import)	(Export)
Mon 11/04/2019	to	Fri 11/15/2019			
0001	Continuous	2359		SCH - NPX_1385	100 MW 100 MW
Work scheduled by: LI				Impacts Total Transfer Capability	100 MW 100 MW
				TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR_138_602 & NRTH1385-NOR HBR_138_603				(Import)	(Export)
Mon 11/04/2019	to	Fri 11/15/2019			
0001		2359		SCH - NPX_1385	0 MW 0 MW
Work scheduled by:				Impacts Total Transfer Capability	200 MW 200 MW
				TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR_138_603				(Import)	(Export)
Mon 11/04/2019	to	Fri 11/15/2019			
0001	Continuous	2359		SCH - NPX_1385	100 MW 100 MW
Work scheduled by: LI				Impacts Total Transfer Capability	100 MW 100 MW
				TTC with All Lines In Service	200 MW 200 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 16, 2019 to Friday, April 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
NRTH1385-NRTHPORT_138_NNC						
Mon 11/04/2019	to	Fri 11/15/2019				
0001	Continuous	2359			SCH - NPX_1385	0 MW 0 MW
Work scheduled by: LI					Impacts Total Transfer Capability	200 MW 200 MW
					TTC with All Lines In Service	200 MW 200 MW
LINDN_CG-LNDVFT_345_V-3022						
Mon 11/04/2019	to	Thu 11/07/2019				
0800	Continuous	1500			SCH - PJM_VFT	0 MW 0 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	315 MW 315 MW
					TTC with All Lines In Service	315 MW 315 MW
MARCY_-N.SCTLND_345_18						
Wed 11/06/2019	to	Wed 11/13/2019	UPDATED	by NYPA	09/11/2019	
0500	Continuous	1730				FWD
Work scheduled by: NYPA						(Import)
					CENTRAL EAST - VC	2090 MW
					Impacts Total Transfer Capability	885 MW
					TTC with All Lines In Service	2975 MW
MARCY_345KV_CSC						
Wed 11/06/2019	to	Fri 11/22/2019	UPDATED	by NYPA	09/11/2019	
0500	Continuous	1730				FWD
Work scheduled by: NYPA						(Import)
					CENTRAL EAST - VC	2925 MW
					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	2975 MW
MARCY_765_345_AT2						
Wed 11/06/2019	to	Fri 11/22/2019	UPDATED	by NYPA	09/11/2019	
0500	Continuous	1730				FWD
Work scheduled by: NYPA						(Import)
					MOSES SOUTH	1700 MW
					Impacts Total Transfer Capability	1450 MW
					TTC with All Lines In Service	3150 MW
HURLYAVE-ROSETON_345_303						
Wed 11/06/2019	to	Fri 12/06/2019				
0800	Continuous	1600				FWD
Work scheduled by: CHGE						(Import)
					UPNY CONED	4100 MW
					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	5700 MW
N.SCTLND-LEEDS_345_94						
Wed 11/06/2019	to	Thu 11/07/2019				
0830	Continuous	1430				FWD
Work scheduled by: NGrid						(Import)
					CENTRAL EAST - VC	2650 MW
					Impacts Total Transfer Capability	325 MW
					TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 16, 2019 to Friday, April 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLE-DUNWODIE_345_W89				FWD	
Fri 11/08/2019	to	Sat 11/09/2019		(Import)	
0001	Continuous	0030	UPNY CONED	4000 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	1700 MW	
			TTC with All Lines In Service	5700 MW	
PLSNTVLY_345KV_RNS5				FWD	
Mon 11/11/2019	to	Mon 11/11/2019		(Import)	
0001	Continuous	0030	UPNY CONED	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	1900 MW	
			TTC with All Lines In Service	5700 MW	
PLSNTVLY-WOOD_ST_345_F30				FWD	
Mon 11/11/2019	to	Tue 11/12/2019		(Import)	
0001	Continuous	0200	UPNY CONED	4000 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	1700 MW	
			TTC with All Lines In Service	5700 MW	
E13THSTA-FARRAGUT_345_45				FWD	
Tue 11/12/2019	to	Tue 11/12/2019		(Import)	
0001	Continuous	0030	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
PLSNTVLY_345KV_RNS5				FWD	
Tue 11/12/2019	to	Tue 11/12/2019		(Import)	
0130	Continuous	0200	UPNY CONED	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	1900 MW	
			TTC with All Lines In Service	5700 MW	
WATRCURE-OAKDALE_345_31				FWD	REV
Tue 11/12/2019	to	Tue 11/12/2019	UPDATED	(Import)	(Export)
1300	Continuous	1500	by NYSEG 09/13/2019	SCH - PJ - NY	2600 MW 1300 MW
Work scheduled by: NYSEG			Impacts Total Transfer Capability	0 MW	250 MW
			TTC with All Lines In Service	2600 MW	1550 MW
PLSNTVLY-WOOD_ST_345_F31				FWD	
Thu 11/14/2019	to	Thu 11/14/2019	UPDATED	(Import)	
0001	Continuous	2200	by NYISO 09/18/2019	UPNY CONED	4000 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	1700 MW	
			TTC with All Lines In Service	5700 MW	

NYISO TRANSFER LIMITATIONS

Wednesday, October 16, 2019 to Friday, April 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RNS4

Thu 11/14/2019 to Thu 11/14/2019
 0001 Continuous 2200
 Work scheduled by: ConEd

UPDATED by NYISO 09/18/2019

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 1900 MW
 TTC with All Lines In Service 5700 MW

E13THSTA-FARRAGUT_345_45

Thu 11/14/2019 to Thu 11/14/2019
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

W49TH_ST-E13THSTA_345_M54

Thu 11/14/2019 to Thu 11/14/2019
 0201 Continuous 0500
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

BUCHAN_N-EASTVIEW_345_W93

Sun 11/17/2019 to Mon 11/18/2019
 0301 Continuous 0300
 Work scheduled by: ConEd

UPDATED by CONED 09/09/2019

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

EASTVIEW-SPRNRK__345_W79

Sun 11/17/2019 to Mon 11/18/2019
 0301 Continuous 0300
 Work scheduled by: ConEd

UPDATED by CONED 09/09/2019

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

SCH-NE-NYISO_LIMIT_500

Sun 11/17/2019 to Sun 11/17/2019
 1100 Continuous 1600
 Work scheduled by: ISONE

FWD
 (Import)
 SCH - NE - NY **700 MW**
 Impacts Total Transfer Capability 700 MW
 TTC with All Lines In Service 1400 MW

SCH-NYISO-NE_LIMIT_1200

Sun 11/17/2019 to Sun 11/17/2019
 1100 Continuous 1600
 Work scheduled by: ISONE

REV
 (Export)
 SCH - NE - NY **1400 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 1800 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 16, 2019 to Friday, April 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK__345KV_RNS5					FWD	
Mon 11/18/2019	to	Mon 11/18/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>09/09/2019</u>	(Import)
0301	Continuous	0330				3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1400 MW	
					TTC with All Lines In Service 4600 MW	
EASTVIEW-SPRNBK__345_W64					FWD	
Mon 11/18/2019	to	Tue 11/19/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>09/09/2019</u>	(Import)
0301	Continuous	0200				4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1350 MW	
					TTC with All Lines In Service 5700 MW	
MILLWOOD-EASTVIEW_345_W99					FWD	
Mon 11/18/2019	to	Tue 11/19/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>09/09/2019</u>	(Import)
0301	Continuous	0200				4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1350 MW	
					TTC with All Lines In Service 5700 MW	
BERKSHIR-ALPS____345_393					FWD	REV
Mon 11/18/2019	to	Wed 11/27/2019				(Import) (Export)
0600	Continuous	1700				1150 MW 1300 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability 250 MW 500 MW	
					TTC with All Lines In Service 1400 MW 1800 MW	
BERKSHIR-ALPS____345_393					FWD	REV
Mon 11/18/2019	to	Wed 11/27/2019				(Import) (Export)
0600	Continuous	1700				100 MW 100 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability 100 MW 100 MW	
					TTC with All Lines In Service 200 MW 200 MW	
BERKSHIR-ALPS____345_393 & BERKSHIR-NORTHFLD_345_312					FWD	REV
Mon 11/18/2019	to	Wed 11/27/2019				(Import) (Export)
0600		1700				1150 MW 1300 MW
Work scheduled by:					Impacts Total Transfer Capability 250 MW 500 MW	
					TTC with All Lines In Service 1400 MW 1800 MW	
BERKSHIR-NORTHFLD_345_312					FWD	REV
Mon 11/18/2019	to	Wed 11/27/2019				(Import) (Export)
0600	Continuous	1700				1400 MW 1500 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability 0 MW 300 MW	
					TTC with All Lines In Service 1400 MW 1800 MW	

NYISO TRANSFER LIMITATIONS

Wednesday, October 16, 2019 to Friday, April 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-NORTHFLD_345_312		FWD	REV
		(Import)	(Export)
Mon 11/18/2019	to Wed 11/27/2019		
0600	Continuous 1700	SCH - NPX_1385	100 MW
Work scheduled by: ISONE		Impacts Total Transfer Capability	100 MW
		TTC with All Lines In Service	200 MW
SCH-NE-NYISO_LIMIT_800		FWD	
		(Import)	
Mon 11/18/2019	to Wed 11/27/2019		
0600	Continuous 1700	SCH - NE - NY	1000 MW
Work scheduled by: ISONE		Impacts Total Transfer Capability	400 MW
		TTC with All Lines In Service	1400 MW
SCH-NYISO-NE_LIMIT_500			REV
			(Export)
Mon 11/18/2019	to Wed 11/27/2019		
0600	Continuous 1700	SCH - NE - NY	700 MW
Work scheduled by: ISONE		Impacts Total Transfer Capability	1100 MW
		TTC with All Lines In Service	1800 MW
SPRNBK__345KV_RNS5		FWD	
		(Import)	
Tue 11/19/2019	to Tue 11/19/2019		
0130	Continuous 0200	<u>UPDATED</u> <u>by CONED</u> <u>09/09/2019</u>	
Work scheduled by: ConEd		SPR/DUN-SOUTH	3200 MW
		Impacts Total Transfer Capability	1400 MW
		TTC with All Lines In Service	4600 MW
EASTVIEW-SPRNBK__345_W64		FWD	
		(Import)	
Sat 11/23/2019	to Sat 11/23/2019		
0130	Continuous 0200	UPNY CONED	4350 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability	1350 MW
		TTC with All Lines In Service	5700 MW
MILLWOOD-EASTVIEW_345_W99		FWD	
		(Import)	
Sat 11/23/2019	to Sat 11/23/2019		
0130	Continuous 0200	UPNY CONED	4350 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability	1350 MW
		TTC with All Lines In Service	5700 MW
SPRNBK__345KV_RNS5		FWD	
		(Import)	
Sat 11/23/2019	to Sat 11/23/2019		
0130	Continuous 0200	SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability	1400 MW
		TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 16, 2019 to Friday, April 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

RAMAPO__-LADENTWN_345_W72				FWD
Mon 11/25/2019	to	Mon 11/25/2019		(Import)
0001	Continuous	2200	UPNY CONED	4400 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1300 MW
				TTC with All Lines In Service 5700 MW
MOSES__-ADIRNDCK_230_MA2				FWD
Mon 11/25/2019	to	Wed 11/27/2019		(Import)
0700	Continuous	1500	MOSES SOUTH	2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW
SHOR_NPX-SHOREHAM_138_CSC				FWD
Mon 12/02/2019	to	Mon 12/02/2019	UPDATED by ISONE 10/04/2019	REV (Export)
0700	Continuous	2300	SCH - NPX_CSC	0 MW 0 MW
Work scheduled by: LI				Impacts Total Transfer Capability 330 MW 330 MW
				TTC with All Lines In Service 330 MW 330 MW
MOSES__-ADIRNDCK_230_MA2				FWD
Mon 12/02/2019	to	Fri 12/06/2019		(Import)
0700	Continuous	1500	MOSES SOUTH	2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW
N.SCTLND-ALPS____345_2				FWD
Mon 12/02/2019	to	Mon 12/02/2019		REV (Export)
0730	Daily(No Weekends)	1630	SCH - NE - NY	900 MW 1700 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 500 MW 100 MW
				TTC with All Lines In Service 1400 MW 1800 MW
N.SCTLND-ALPS____345_2				FWD
Mon 12/02/2019	to	Mon 12/02/2019		REV (Export)
0730	Daily(No Weekends)	1630	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 100 MW 100 MW
				TTC with All Lines In Service 200 MW 200 MW
FRASER____345_FRASER SVC				FWD
Mon 12/02/2019	to	Fri 12/13/2019		(Import)
0800	Continuous	1500	CENTRAL EAST - VC	2935 MW
Work scheduled by: NYSEG				Impacts Total Transfer Capability 40 MW
				TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 16, 2019 to Friday, April 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LEEDS___345KV_R94301				FWD	
Tue 12/03/2019	to	Fri 12/13/2019	UPDATED	by NGRID	10/04/2019
0800	Continuous	1500		UPNY CONED	3800 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	1900 MW
				TTC with All Lines In Service	5700 MW
MOSES___-ADIRNDCK_230_MA1				FWD	
Mon 12/09/2019	to	Fri 12/13/2019		MOSES SOUTH	2300 MW
0700	Continuous	1500		Impacts Total Transfer Capability	850 MW
Work scheduled by: NYPA				TTC with All Lines In Service	3150 MW
ROSETON_-ROCKTVRN_345_311				FWD	
Mon 12/09/2019	to	Thu 12/12/2019		UPNY CONED	4400 MW
0800	Continuous	1600		Impacts Total Transfer Capability	1300 MW
Work scheduled by: CHGE				TTC with All Lines In Service	5700 MW
SHOR_NPX-SHOREHAM_138_CSC				FWD	REV
Thu 12/12/2019	to	Fri 12/20/2019		SCH - NPX_CSC	0 MW 0 MW
0700	Continuous	1500		Impacts Total Transfer Capability	330 MW 330 MW
Work scheduled by: ISONE				TTC with All Lines In Service	330 MW 330 MW
MOSES___-ADIRNDCK_230_MA2				FWD	
Mon 12/16/2019	to	Mon 12/16/2019		MOSES SOUTH	2300 MW
0700	Continuous	1500		Impacts Total Transfer Capability	850 MW
Work scheduled by: NYPA				TTC with All Lines In Service	3150 MW
MOSES___-ADIRNDCK_230_MA1				FWD	
Tue 12/17/2019	to	Fri 12/20/2019		MOSES SOUTH	2300 MW
0700	Continuous	1500		Impacts Total Transfer Capability	850 MW
Work scheduled by: NYPA				TTC with All Lines In Service	3150 MW
SCH-NE-NYISO_LIMIT_500				FWD	
Fri 12/20/2019	to	Fri 12/20/2019	UPDATED	by ISONE	10/11/2019
0600	Continuous	1600		SCH - NE - NY	700 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability	700 MW
				TTC with All Lines In Service	1400 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 16, 2019 to Friday, April 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-NE_LIMIT_1200					REV	
Fri 12/20/2019	to	Fri 12/20/2019	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/11/2019</u>	(Export)
0600	Continuous	1600				1400 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability	400 MW
					TTC with All Lines In Service	1800 MW
MOSES -ADIRNDCK_230_MA2					FWD	
Thu 01/02/2020	to	Sun 03/01/2020				(Import)
0700	Continuous	1530				2300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
LADENTWN-BUCHAN_S_345_Y88					FWD	
Wed 01/15/2020	to	Thu 02/13/2020		<u>11/05/2018</u>		(Import)
0001	Continuous	2359				4800 MW
Work scheduled by: ORU					Impacts Total Transfer Capability	900 MW
					TTC with All Lines In Service	5700 MW
MOTTHAVN-RAINEY_345_Q11					FWD	
Sun 02/23/2020	to	Sun 03/01/2020				(Import)
0001	Continuous	0200				3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
NIAGARA -PACKARD_230_62					FWD	REV
Fri 02/28/2020	to	Fri 02/28/2020				(Import) (Export)
0500	Continuous	1530				1100 MW 950 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1150 MW 1050 MW
					TTC with All Lines In Service	2250 MW 2000 MW
CHATGUAY-MASSENA_765_7040					FWD	
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)
0500	Continuous	1730				1550 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	3150 MW
CHATGUAY-MASSENA_765_7040					FWD	REV
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import) (Export)
0500	Continuous	1730				0 MW 0 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1500 MW 1000 MW
					TTC with All Lines In Service	1500 MW 1000 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 16, 2019 to Friday, April 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT1						FWD
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)
0500	Continuous	1730				MOSES SOUTH 1750 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 1400 MW
						TTC with All Lines In Service 3150 MW
MARCY___765_345_AT2						FWD
Mon 03/02/2020	to	Fri 03/06/2020				(Import)
0500	Continuous	1730				MOSES SOUTH 1700 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 1450 MW
						TTC with All Lines In Service 3150 MW
MASSENA_-MARCY___765_MSU1						FWD
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)
0500	Continuous	1730				CENTRAL EAST - VC 2265 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 710 MW
						TTC with All Lines In Service 2975 MW
MASSENA_-MARCY___765_MSU1						FWD
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)
0500	Continuous	1730				MOSES SOUTH 500 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 2650 MW
						TTC with All Lines In Service 3150 MW
MASSENA_-MARCY___765_MSU1						FWD
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import) (Export)
0500	Continuous	1730				SCH - HQ - NY 475 MW 1000 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 1025 MW 0 MW
						TTC with All Lines In Service 1500 MW 1000 MW
MASSENA_-MARCY___765_MSU1						FWD
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)
0500	Continuous	1730				SCH - HQ_CEDARS 90 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 109 MW
						TTC with All Lines In Service 199 MW
MASSENA_-MARCY___765_MSU1 & CHATGUAY-MASSENA_765_7040						FWD
Mon 03/02/2020	to	Fri 03/06/2020				(Import)
0500		1730				MOSES SOUTH 500 MW
Work scheduled by:						Impacts Total Transfer Capability 2650 MW
						TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 16, 2019 to Friday, April 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2	FWD	REV
	(Import)	(Export)
Mon 03/02/2020 to Fri 03/06/2020 0500 1730	SCH - HQ - NY Impacts Total Transfer Capability 650 MW TTC with All Lines In Service 1500 MW	850 MW 0 MW 1000 MW 1000 MW
Work scheduled by:		
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2	FWD	
	(Import)	
Mon 03/02/2020 to Fri 03/06/2020 0500 1730	SCH - HQ_CEDARS Impacts Total Transfer Capability 109 MW TTC with All Lines In Service 199 MW	90 MW 109 MW 199 MW
Work scheduled by:		
STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1	FWD	
	(Import)	
Mon 03/02/2020 to Fri 03/06/2020 0500 1730	SCH - HQ_CEDARS Impacts Total Transfer Capability 109 MW TTC with All Lines In Service 199 MW	90 MW 109 MW 199 MW
Work scheduled by:		
STLAWRNC-MOSES 230_L33P & MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2	FWD	
	(Import)	
Mon 03/02/2020 to Fri 03/06/2020 0500 1730	SCH - HQ_CEDARS Impacts Total Transfer Capability 109 MW TTC with All Lines In Service 199 MW	90 MW 109 MW 199 MW
Work scheduled by:		
EASTVIEW-SPRNBK 345_W78	FWD	
	(Import)	
Fri 03/06/2020 to Sat 03/07/2020 0001 Continuous 0200	UPNY CONED Impacts Total Transfer Capability 1350 MW TTC with All Lines In Service 5700 MW	4350 MW 1350 MW 5700 MW
Work scheduled by: ConEd		
MILLWOOD-EASTVIEW 345_W85	FWD	
	(Import)	
Fri 03/06/2020 to Sat 03/07/2020 0001 Continuous 0200	UPNY CONED Impacts Total Transfer Capability 1350 MW TTC with All Lines In Service 5700 MW	4350 MW 1350 MW 5700 MW
Work scheduled by: ConEd		
SPRNBK 345KV_RNS3	FWD	
	(Import)	
Fri 03/06/2020 to Sat 03/07/2020 0001 Continuous 0200	SPR/DUN-SOUTH Impacts Total Transfer Capability 800 MW TTC with All Lines In Service 4600 MW	3800 MW 800 MW 4600 MW
Work scheduled by: ConEd		

NYISO TRANSFER LIMITATIONS

Wednesday, October 16, 2019 to Friday, April 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -ADIRNDCK_230_MA1

Sat 03/07/2020 to Fri 05/29/2020
0700 Continuous 1300

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

VOLNEY -MARCY_345_19

Tue 03/10/2020 to Tue 03/10/2020
0700 Continuous 1530

Work scheduled by: NYPA

UPDATED by NYPA 09/24/2019

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2825 MW**
Impacts Total Transfer Capability 150 MW
TTC with All Lines In Service 2975 MW

VOLNEY -MARCY_345_19

Tue 03/10/2020 to Tue 03/10/2020
0700 Continuous 1530

Work scheduled by: NYPA

UPDATED by NYPA 09/24/2019

ARR: 19

FWD
(Import)
OSWEGO EXPORT **4900 MW**
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 5250 MW

FRASANX-COOPERS_345_UCC2-41

Wed 03/11/2020 to Thu 03/12/2020
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

MARCY -FRASANX_345_UCC2-41

Wed 03/11/2020 to Thu 03/12/2020
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

ROCHESTR-PANNELL_345_RP2

Sat 03/14/2020 to Mon 03/23/2020
0500 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MARCY_345KV_CSC

Mon 03/16/2020 to Fri 03/27/2020
0500 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2925 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 16, 2019 to Friday, April 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROSETON_-EFISHKIL_345_RFK305				FWD	
Mon 03/16/2020	to	Fri 04/03/2020		(Import)	
0700	Continuous	1530	UPNY CONED	4800 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	900 MW	
			TTC with All Lines In Service	5700 MW	
NIAGARA_-KINTIGH_345_NS1-38				FWD	
Fri 03/27/2020	to	Fri 03/27/2020		(Import)	
0600	Continuous	1530	DYSINGER EAST	1700 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1450 MW	
			TTC with All Lines In Service	3150 MW	
BECK_-PACKARD_230_BP76				FWD	REV
Fri 03/27/2020	to	Fri 03/27/2020		(Import)	(Export)
0800	Daily(No Weekends)	1600	SCH - OH - NY	1700 MW	1500 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	550 MW	500 MW
			TTC with All Lines In Service	2250 MW	2000 MW
MARCY_-EDIC_345_UE1-7				FWD	
Tue 03/31/2020	to	Tue 03/31/2020	UPDATED	(Import)	
0700	Continuous	1530	by NYPA	OSWEGO EXPORT	5250 MW
Work scheduled by: NYPA			09/24/2019	Impacts Total Transfer Capability	0 MW
			ARR: 19&16	TTC with All Lines In Service	5250 MW
MARCY_-N.SCTLND_345_18				FWD	
Tue 04/07/2020	to	Wed 04/08/2020	UPDATED	(Import)	
0700	Continuous	1530	by NYPA	CENTRAL EAST - VC	2090 MW
Work scheduled by: NYPA			09/24/2019	Impacts Total Transfer Capability	885 MW
			ARR: 19	TTC with All Lines In Service	2975 MW
LINDN_CG-LNDVFT_345_V-3022				FWD	REV
Sun 04/12/2020	to	Fri 04/17/2020		(Import)	(Export)
1400	Continuous	1800	SCH - PJM_VFT	0 MW	0 MW
Work scheduled by: PJM			Impacts Total Transfer Capability	315 MW	315 MW
			TTC with All Lines In Service	315 MW	315 MW
FRASER_-GILBOA_345_GF5-35				FWD	
Mon 04/13/2020	to	Wed 04/22/2020		(Import)	
0700	Continuous	1730	CENTRAL EAST - VC	2650 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	325 MW	
			TTC with All Lines In Service	2975 MW	

NYISO TRANSFER LIMITATIONS

Wednesday, October 16, 2019 to Friday, April 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-ROCHESTR_345_NR2

Mon 04/20/2020 to Fri 05/01/2020
0500 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

DOLSONAV-ROCKTVRN_345_DART44

Mon 04/27/2020 to Sun 05/10/2020 UPDATED by NYPA 03/21/2019
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2720 MW**
Impacts Total Transfer Capability 255 MW
TTC with All Lines In Service 2975 MW

LEEDS_-HURLYAVE_345_301

Mon 04/27/2020 to Fri 05/29/2020
0800 Continuous 1600

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 1600 MW
TTC with All Lines In Service 5700 MW

SCH-IMO-NYISO_LIMIT_1600

Fri 05/01/2020 to Sat 10/31/2020 UPDATED by IESO 05/03/2019
0001 Continuous 2359

Work scheduled by: IESO

FWD
(Import)
SCH - OH - NY **1900 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 1900 MW

PANNELL_-CLAY____345_2

Mon 05/04/2020 to Fri 05/08/2020
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Mon 05/04/2020 to Mon 05/18/2020
0800 Continuous 1700

Work scheduled by: PJM

FWD
(Import)
SCH - PJM_NEPTUNE **0 MW**
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

NEWBRDGE-DUFFYAVE_345_501

Mon 05/04/2020 to Mon 05/18/2020
0800 Continuous 1700

Work scheduled by: PJM

FWD
(Import)
SCH - PJM_NEPTUNE **0 MW**
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 16, 2019 to Friday, April 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE_345_138_BK_1				FWD
Mon 05/04/2020	to	Mon 05/18/2020		(Import)
0800	Continuous	1700	SCH - PJM_NEPTUNE	375 MW
Work scheduled by: PJM				Impacts Total Transfer Capability 285 MW
				TTC with All Lines In Service 660 MW
NEWBRDGE_345_138_BK_2				FWD
Mon 05/04/2020	to	Mon 05/18/2020		(Import)
0800	Continuous	1700	SCH - PJM_NEPTUNE	375 MW
Work scheduled by: PJM				Impacts Total Transfer Capability 285 MW
				TTC with All Lines In Service 660 MW
PANNELL_-CLAY_345_1				FWD
Mon 05/11/2020	to	Fri 05/15/2020		(Import)
0700	Continuous	1530	WEST CENTRAL	1300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 950 MW
				TTC with All Lines In Service 2250 MW
COOPERS_-DOLSONAV_345_CCDA42				FWD
Mon 05/11/2020	to	Fri 05/29/2020	UPDATED by NYPA 03/21/2019	(Import)
0700	Continuous	1730	CENTRAL EAST - VC	2720 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 255 MW
				TTC with All Lines In Service 2975 MW
NIAGARA_-ROCHESTR_345_NR2				FWD
Mon 05/18/2020	to	Fri 05/22/2020		(Import)
0500	Continuous	1530	DYSINGER EAST	1400 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 1750 MW
				TTC with All Lines In Service 3150 MW
MOSES_-ADIRNDCK_230_MA2				FWD
Mon 06/01/2020	to	Fri 07/31/2020		(Import)
0700	Continuous	1730	MOSES SOUTH	2100 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 1050 MW
				TTC with All Lines In Service 3150 MW
NIAGARA_345_230_AT4				REV
Mon 06/29/2020	to	Tue 06/30/2020		(Export)
0500	Continuous	1530	SCH - OH - NY	1400 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 300 MW
				TTC with All Lines In Service 1700 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 16, 2019 to Friday, April 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO-NYISO_NIAG_CB_3008_W/BB						FWD	REV
						(Import)	(Export)
Mon 07/27/2020	to	Fri 08/07/2020					
0500	Continuous	1530			SCH - OH - NY	1900 MW	1450 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	0 MW 250 MW
						TTC with All Lines In Service	1900 MW 1700 MW
CHATGUAY-MASSENA_765_7040						FWD	
						(Import)	
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	MOSES SOUTH	1550 MW
0500	Continuous	1730				Impacts Total Transfer Capability	1600 MW
Work scheduled by: NYPA						TTC with All Lines In Service	3150 MW
CHATGUAY-MASSENA_765_7040						FWD	REV
						(Import)	(Export)
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	SCH - HQ - NY	0 MW 0 MW
0500	Continuous	1730				Impacts Total Transfer Capability	1500 MW 1000 MW
Work scheduled by: NYPA						TTC with All Lines In Service	1500 MW 1000 MW
MARCY_765_345_AT1						FWD	
						(Import)	
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	MOSES SOUTH	1750 MW
0500	Continuous	1730				Impacts Total Transfer Capability	1400 MW
Work scheduled by: NYPA						TTC with All Lines In Service	3150 MW
							ARR: 19
MASSENA_-MARCY_765_MSU1						FWD	
						(Import)	
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	CENTRAL EAST - VC	2265 MW
0500	Continuous	1730				Impacts Total Transfer Capability	710 MW
Work scheduled by: NYPA						TTC with All Lines In Service	2975 MW
MASSENA_-MARCY_765_MSU1						FWD	
						(Import)	
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	MOSES SOUTH	500 MW
0500	Continuous	1730				Impacts Total Transfer Capability	2650 MW
Work scheduled by: NYPA						TTC with All Lines In Service	3150 MW
MASSENA_-MARCY_765_MSU1						FWD	REV
						(Import)	(Export)
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	SCH - HQ - NY	475 MW 1000 MW
0500	Continuous	1730				Impacts Total Transfer Capability	1025 MW 0 MW
Work scheduled by: NYPA						TTC with All Lines In Service	1500 MW 1000 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 16, 2019 to Friday, April 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA -MARCY 765_MSU1				FWD	
Sat 08/01/2020	to	Sun 08/02/2020	UPDATED by NYPA 08/08/2019	(Import)	
0500	Continuous	1730		SCH - HQ_CEDARS	90 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	190 MW
MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040				FWD	
Sat 08/01/2020	to	Sun 08/02/2020		(Import)	
0500		1730		MOSES SOUTH	500 MW
Work scheduled by:				Impacts Total Transfer Capability	2650 MW
				TTC with All Lines In Service	3150 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2				FWD	REV
Sat 08/01/2020	to	Sun 08/02/2020		(Import)	(Export)
0500		1730		SCH - HQ - NY	850 MW 0 MW
Work scheduled by:				Impacts Total Transfer Capability	650 MW 1000 MW
				TTC with All Lines In Service	1500 MW 1000 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2				FWD	
Sat 08/01/2020	to	Sun 08/02/2020		(Import)	
0500		1730		SCH - HQ_CEDARS	90 MW
Work scheduled by:				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	190 MW
STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1				FWD	
Sat 08/01/2020	to	Sun 08/02/2020		(Import)	
0500		1730		SCH - HQ_CEDARS	90 MW
Work scheduled by:				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	190 MW
STLAWRNC-MOSES 230_L33P & MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2				FWD	
Sat 08/01/2020	to	Sun 08/02/2020		(Import)	
0500		1730		SCH - HQ_CEDARS	90 MW
Work scheduled by:				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	190 MW
MOSES -ADIRNDCK 230_MA2				FWD	
Mon 08/03/2020	to	Sun 09/13/2020		(Import)	
0700	Continuous	1730		MOSES SOUTH	2100 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1050 MW
				TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 16, 2019 to Friday, April 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASANX-COOPERS__345_UCC2-41					FWD
Mon 09/07/2020	to	Fri 10/23/2020	UPDATED	by NYPA	(Import)
0700	Continuous	1730		03/01/2019	2500 MW
Work scheduled by: NYPA					CENTRAL EAST - VC
					Impacts Total Transfer Capability 475 MW
					TTC with All Lines In Service 2975 MW
MARCY__-FRASANX_345_UCC2-41					FWD
Mon 09/07/2020	to	Fri 10/23/2020	UPDATED	by NYPA	(Import)
0700	Continuous	1730		03/01/2019	2500 MW
Work scheduled by: NYPA					CENTRAL EAST - VC
					Impacts Total Transfer Capability 475 MW
					TTC with All Lines In Service 2975 MW
MARCY__765_345_AT1					FWD
Mon 09/14/2020	to	Mon 09/14/2020			(Import)
0500	Continuous	1730			1750 MW
Work scheduled by: NYPA					MOSES SOUTH
					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 3150 MW
NIAGARA_-KINTIGH__345_NS1-38					FWD
Mon 09/14/2020	to	Thu 09/17/2020			(Import)
0500	Continuous	1530			1400 MW
Work scheduled by: NYPA					DYSINGER EAST
					Impacts Total Transfer Capability 1750 MW
					TTC with All Lines In Service 3150 MW
MOSES__-ADIRNDCK_230_MA2					FWD
Tue 09/15/2020	to	Sat 11/14/2020			(Import)
0700	Continuous	1530			2100 MW
Work scheduled by: NYPA					MOSES SOUTH
					Impacts Total Transfer Capability 1050 MW
					TTC with All Lines In Service 3150 MW
NIAGARA_-ROCHESTR_345_NR2					FWD
Fri 09/18/2020	to	Sat 11/14/2020			(Import)
0500	Continuous	2330			1400 MW
Work scheduled by: NYPA					DYSINGER EAST
					Impacts Total Transfer Capability 1750 MW
					TTC with All Lines In Service 3150 MW
CLAY__-EDIC__345_1-16					FWD
Mon 09/21/2020	to	Fri 09/25/2020			(Import)
0700	Continuous	1530			4850 MW
Work scheduled by: NYPA					OSWEGO EXPORT
					Impacts Total Transfer Capability 400 MW
					TTC with All Lines In Service 5250 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 16, 2019 to Friday, April 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROSETON_-ROCKTVRN_345_311					FWD	
Mon 09/21/2020	to	Fri 10/23/2020	<u>UPDATED</u>	<u>by CHGE</u>	<u>10/09/2019</u>	(Import)
0800	Continuous	1600				UPNY CONED 4400 MW
Work scheduled by: CHGE						Impacts Total Transfer Capability 1300 MW
						TTC with All Lines In Service 5700 MW
CLAY_-EDIC_345_2-15					FWD	
Mon 09/28/2020	to	Fri 10/02/2020				(Import)
0700	Continuous	1530				OSWEGO EXPORT 4850 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 400 MW
						TTC with All Lines In Service 5250 MW
DUNWODIE_345KV_3					FWD	
Thu 10/01/2020	to	Thu 10/01/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>09/05/2019</u>	(Import)
0001	Continuous	0030				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_5					FWD	
Thu 10/01/2020	to	Thu 10/01/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>09/05/2019</u>	(Import)
0001	Continuous	0030				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
DUNWODIE-MOTTHAVN_345_71					FWD	
Thu 10/01/2020	to	Thu 11/05/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>09/05/2019</u>	(Import)
0001	Continuous	0300				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
HURLYAVE-ROSETON_345_303					FWD	
Mon 10/26/2020	to	Fri 12/04/2020	<u>UPDATED</u>	<u>by CHGE</u>	<u>10/09/2019</u>	(Import)
0800	Continuous	1600				UPNY CONED 4100 MW
Work scheduled by: CHGE						Impacts Total Transfer Capability 1600 MW
						TTC with All Lines In Service 5700 MW
SCH-IMO-NYISO_LIMIT_1750					FWD	
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Import)
0001	Continuous	2359				SCH - OH - NY 2050 MW
Work scheduled by: IESO						Impacts Total Transfer Capability 200 MW
						TTC with All Lines In Service 2250 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 16, 2019 to Friday, April 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-IMO_LIMIT_1600						REV
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Export)
0001	Continuous	2359				1900 MW
Work scheduled by: IESO						100 MW
						2000 MW
DUNWODIE_345KV_3						FWD
Thu 11/05/2020	to	Thu 11/05/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>09/05/2019</u>	(Import)
0230	Continuous	0300				3800 MW
Work scheduled by: ConEd						800 MW
						4600 MW
DUNWODIE_345KV_5						FWD
Thu 11/05/2020	to	Thu 11/05/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>09/05/2019</u>	(Import)
0230	Continuous	0300				3800 MW
Work scheduled by: ConEd						800 MW
						4600 MW
CHATGUAY-MASSENA_765_7040						FWD
Sun 11/15/2020	to	Mon 11/30/2020				(Import)
0100	Continuous	1900				1550 MW
Work scheduled by: NYPA						1600 MW
						3150 MW
CHATGUAY-MASSENA_765_7040						FWD
Sun 11/15/2020	to	Mon 11/30/2020				(Import) (Export)
0100	Continuous	1900				0 MW 0 MW
Work scheduled by: NYPA						1500 MW 1000 MW
						1500 MW 1000 MW
MARCY_765_345_AT1						FWD
Sun 11/15/2020	to	Mon 11/30/2020				(Import)
0100	Continuous	1900				1750 MW
Work scheduled by: NYPA						1400 MW
ARR: 19						3150 MW
MARCY_765_345_AT2						FWD
Sun 11/15/2020	to	Mon 11/30/2020				(Import)
0100	Continuous	1900				1700 MW
Work scheduled by: NYPA						1450 MW
ARR: 19						3150 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 16, 2019 to Friday, April 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA -MARCY 765_MSU1			FWD	
Sun 11/15/2020	to	Mon 11/30/2020	(Import)	
0100	Continuous	1900	CENTRAL EAST - VC	2265 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	710 MW
			TTC with All Lines In Service	2975 MW
MASSENA -MARCY 765_MSU1			FWD	
Sun 11/15/2020	to	Mon 11/30/2020	(Import)	
0100	Continuous	1900	MOSES SOUTH	500 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	2650 MW
			TTC with All Lines In Service	3150 MW
MASSENA -MARCY 765_MSU1			FWD	REV
Sun 11/15/2020	to	Mon 11/30/2020	(Import)	(Export)
0100	Continuous	1900	SCH - HQ - NY	475 MW 1000 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1025 MW 0 MW
			TTC with All Lines In Service	1500 MW 1000 MW
MASSENA -MARCY 765_MSU1			FWD	
Sun 11/15/2020	to	Mon 11/30/2020	(Import)	
0100	Continuous	1900	SCH - HQ_CEDARS	90 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	109 MW
			TTC with All Lines In Service	199 MW
MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040			FWD	
Sun 11/15/2020	to	Mon 11/30/2020	(Import)	
0100		1900	MOSES SOUTH	500 MW
Work scheduled by:			Impacts Total Transfer Capability	2650 MW
			TTC with All Lines In Service	3150 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2			FWD	REV
Sun 11/15/2020	to	Mon 11/30/2020	(Import)	(Export)
0100		1900	SCH - HQ - NY	850 MW 0 MW
Work scheduled by:			Impacts Total Transfer Capability	650 MW 1000 MW
			TTC with All Lines In Service	1500 MW 1000 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2			FWD	
Sun 11/15/2020	to	Mon 11/30/2020	(Import)	
0100		1900	SCH - HQ_CEDARS	90 MW
Work scheduled by:			Impacts Total Transfer Capability	109 MW
			TTC with All Lines In Service	199 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 16, 2019 to Friday, April 16, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1		FWD
Sun 11/15/2020	to Mon 11/30/2020	(Import)
0100	1900	SCH - HQ_CEDARS 90 MW
Work scheduled by:		Impacts Total Transfer Capability 109 MW
		TTC with All Lines In Service 199 MW
STLAWRNC-MOSES 230_L33P & MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2		FWD
Sun 11/15/2020	to Mon 11/30/2020	(Import)
0100	1900	SCH - HQ_CEDARS 90 MW
Work scheduled by:		Impacts Total Transfer Capability 109 MW
		TTC with All Lines In Service 199 MW
PLSNTVLE-DUNWODIE_345_W89		FWD
Mon 11/16/2020	to Mon 11/16/2020	(Import)
0001	Continuous 0030	UPNY CONED 4000 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability 1700 MW
		TTC with All Lines In Service 5700 MW
PLSNTVLE-DUNWODIE_345_W89		FWD
Thu 11/26/2020	to Thu 11/26/2020	(Import)
0230	Continuous 0300	UPNY CONED 4000 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability 1700 MW
		TTC with All Lines In Service 5700 MW
MOSES -ADIRNDCK_230_MA1		FWD
Tue 12/01/2020	to Mon 05/31/2021	(Import)
0700	Continuous 1300	MOSES SOUTH 2300 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability 850 MW
		TTC with All Lines In Service 3150 MW
MOTTHAVN-RAINEY_345_Q11		FWD
Mon 03/01/2021	to Tue 04/06/2021	(Import)
0001	Continuous 0700	SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability 800 MW
		TTC with All Lines In Service 4600 MW
CLAY -EDIC 345_2-15		FWD
Mon 03/29/2021	to Fri 04/16/2021	(Import)
0800	Continuous 1730	OSWEGO EXPORT 4850 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability 400 MW
		TTC with All Lines In Service 5250 MW