

# NYISO TRANSFER LIMITATIONS

Thursday ,October 17, 2019 to Saturday ,April 17, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					FWD	REV
<b>HUDSONP_-FARRAGUT_345_B3402</b>					(Import)	(Export)
Mon 01/15/2018	to	Fri 05/01/2020	<b><u>EXTENDED</u></b>	<b><u>by CONED</u></b>	<b><u>10/08/2019</u></b>	
0001	Continuous	2359				
Work scheduled by: ConEd					SCH - PJ - NY	<b>2100 MW</b>
					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	2150 MW
<hr/>					FWD	REV
<b>HUDSONP_-FARRAGUT_345_B3402 &amp; MARION_-FARRAGUT_345_C3403</b>					(Import)	(Export)
Mon 01/15/2018	to	Fri 05/01/2020				
0001		2359				
Work scheduled by:					SCH - PJ - NY	<b>2050 MW</b>
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	2150 MW
<hr/>					FWD	REV
<b>MARION_-FARRAGUT_345_C3403</b>					(Import)	(Export)
Mon 01/15/2018	to	Fri 05/01/2020	<b><u>EXTENDED</u></b>	<b><u>by CONED</u></b>	<b><u>10/08/2019</u></b>	
0001	Continuous	2359				
Work scheduled by: ConEd					SCH - PJ - NY	<b>2100 MW</b>
					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	2150 MW
<hr/>					FWD	REV
<b>STLAWRNC-MOSES_230_L33P</b>					(Import)	(Export)
Mon 04/30/2018	to	Fri 12/31/2021	<b><u>EXT FORCE</u></b>	<b><u>by IESO</u></b>	<b><u>08/21/2018</u></b>	
0456	Continuous	2359				
Work scheduled by: IESO					SCH - OH - NY	
					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
<hr/>					FWD	REV
<b>BECK_-NIAGARA_345_PA302</b>					(Import)	(Export)
Wed 07/31/2019	to	Tue 11/12/2019	<b><u>EXTENDED</u></b>	<b><u>by IESO</u></b>	<b><u>08/29/2019</u></b>	
0800	Continuous	1700				
Work scheduled by: IESO					SCH - OH - NY	<b>900 MW</b>
					Impacts Total Transfer Capability	1000 MW
					TTC with All Lines In Service	1900 MW
<hr/>					FWD	REV
<b>NIAGARA_-PACKARD_230_61</b>					(Import)	(Export)
Tue 09/03/2019	to	Fri 10/18/2019	<b><u>UPDATED</u></b>	<b><u>by NYPA</u></b>	<b><u>12/19/2018</u></b>	
0500	Continuous	1700				
Work scheduled by: NYPA					SCH - OH - NY	
					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
<hr/>					FWD	REV
<b>PLSNTVLY_345KV_RNS5</b>					(Import)	(Export)
Sat 09/14/2019	to	Thu 10/17/2019	<b><u>UPDATED</u></b>	<b><u>by CE</u></b>	<b><u>10/10/2019</u></b>	
0001	Continuous	0800				
Work scheduled by: ConEd					UPNY CONED	<b>3800 MW</b>
					Impacts Total Transfer Capability	1900 MW
					TTC with All Lines In Service	5700 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,October 17, 2019 to Saturday ,April 17, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>FROST_BR-LONG_MTN_345_352</b>					FWD	
Wed 10/02/2019	to	Fri 10/18/2019	<u>UPDATED</u>	<u>by ISONE</u>	<u>09/30/2019</u>	(Import)
0700	Continuous	1600				<b>1150 MW</b>
Work scheduled by: ISONE					SCH - NE - NY	Impacts Total Transfer Capability 250 MW
					TTC with All Lines In Service	1400 MW
<b>SCH-NE-NYISO_LIMIT_400</b>					FWD	
Wed 10/02/2019	to	Fri 10/18/2019	<u>UPDATED</u>	<u>by ISONE</u>	<u>09/30/2019</u>	(Import)
0700	Continuous	1600				<b>600 MW</b>
Work scheduled by: ISONE					SCH - NE - NY	Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service	1400 MW
<b>DUNWODIE_345KV_4</b>					FWD	
Thu 10/03/2019	to	Thu 10/17/2019	<u>UPDATED</u>	<u>by CE</u>	<u>09/30/2019</u>	(Import)
0001	Continuous	2359				<b>3800 MW</b>
Work scheduled by: ConEd					SPR/DUN-SOUTH	Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service	4600 MW
<b>SPRNBRK_345KV_RS3 &amp; SPRNBRK_345KV_RS4</b>					FWD	
Fri 10/04/2019	to	Wed 10/16/2019				(Import)
0201		2230				<b>3200 MW</b>
Work scheduled by:					SPR/DUN-SOUTH	Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service	4600 MW
<b>SCH-NE-NYISO_LIMIT_300</b>					FWD	
Sat 10/05/2019	to	Fri 10/18/2019	<u>UPDATED</u>	<u>by ISONE</u>	<u>09/30/2019</u>	(Import)
1601	Continuous	1600				<b>500 MW</b>
Work scheduled by: ISONE					SCH - NE - NY	Impacts Total Transfer Capability 900 MW
					TTC with All Lines In Service	1400 MW
<b>SCH-HQ-NYISO_LIMIT_1100</b>					FWD	
Mon 10/07/2019	to	Fri 11/22/2019				(Import)
0400	Continuous	2300				<b>1100 MW</b>
Work scheduled by: HQ					SCH - HQ - NY	Impacts Total Transfer Capability 400 MW
					TTC with All Lines In Service	1500 MW
<b>CHAT_DC_GC1</b>					FWD	
Sat 10/12/2019	to	Sat 10/12/2019	<u>UPDATED</u>	<u>by HQ</u>	<u>10/04/2019</u>	(Import)
0001	Continuous	0200				<b>2850 MW</b>
Work scheduled by: HQ					MOSES SOUTH	Impacts Total Transfer Capability 300 MW
					TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,October 17, 2019 to Saturday ,April 17, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CHAT_DC_GC1</b>						REV
Sat 10/12/2019	to	Sat 10/12/2019	<u>UPDATED</u>	<u>by HQ</u>	<u>10/04/2019</u>	(Export)
0001	Continuous	0200				<b>500 MW</b>
Work scheduled by: HQ						Impacts Total Transfer Capability 500 MW
						TTC with All Lines In Service 1000 MW
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>						FWD
Sat 10/12/2019	to	Sat 10/12/2019				(Import)
0001		0200				<b>2550 MW</b>
Work scheduled by:						Impacts Total Transfer Capability 600 MW
						TTC with All Lines In Service 3150 MW
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>						FWD REV
Sat 10/12/2019	to	Sat 10/12/2019				(Import) (Export)
0001		0200				<b>1370 MW 0 MW</b>
Work scheduled by:						Impacts Total Transfer Capability 130 MW 1000 MW
						TTC with All Lines In Service 1500 MW 1000 MW
<b>CHAT_DC_GC2</b>						FWD
Sat 10/12/2019	to	Sat 10/12/2019	<u>UPDATED</u>	<u>by HQ</u>	<u>10/04/2019</u>	(Import)
0001	Continuous	0200				<b>2850 MW</b>
Work scheduled by: HQ						Impacts Total Transfer Capability 300 MW
						TTC with All Lines In Service 3150 MW
<b>CHAT_DC_GC2</b>						REV
Sat 10/12/2019	to	Sat 10/12/2019	<u>UPDATED</u>	<u>by HQ</u>	<u>10/04/2019</u>	(Export)
0001	Continuous	0200				<b>500 MW</b>
Work scheduled by: HQ						Impacts Total Transfer Capability 500 MW
						TTC with All Lines In Service 1000 MW
<b>SCH-HQ-NYISO_LIMIT_600</b>						FWD
Sat 10/12/2019	to	Sat 10/12/2019	<u>UPDATED</u>	<u>by HQ</u>	<u>10/04/2019</u>	(Import)
0001	Continuous	0200				<b>600 MW</b>
Work scheduled by: HQ						Impacts Total Transfer Capability 900 MW
						TTC with All Lines In Service 1500 MW
<b>LEEDS___-PLSNTVLY_345_92</b>						FWD
Sat 10/12/2019	to	Tue 10/15/2019	<u>UPDATED</u>	<u>by CE</u>	<u>10/10/2019</u>	(Import)
0001	Continuous	0200				<b>3800 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 1900 MW
						TTC with All Lines In Service 5700 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,October 17, 2019 to Saturday ,April 17, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2 &amp; MOSES -MASSENA_230_MMS1 &amp; MOSES -MASSENA_230_MMS2</b>						FWD	
						(Import)	
Sat 10/12/2019	to	Sat 10/12/2019				MOSES SOUTH	<b>1950 MW</b>
0100		0200				Impacts Total Transfer Capability	1200 MW
Work scheduled by:						TTC with All Lines In Service	3150 MW
<b>CHATGUAY-MASSENA_765_7040</b>						FWD	
						(Import)	
Sat 10/12/2019	to	Tue 10/22/2019	<b>UPDATED</b>	<b>by NYPA</b>	<b>10/13/2019</b>	MOSES SOUTH	<b>1550 MW</b>
0100	Continuous	2000				Impacts Total Transfer Capability	1600 MW
Work scheduled by: NYPA						TTC with All Lines In Service	3150 MW
<b>CHATGUAY-MASSENA_765_7040</b>						FWD	REV
						(Import)	(Export)
Sat 10/12/2019	to	Tue 10/22/2019	<b>UPDATED</b>	<b>by NYPA</b>	<b>10/13/2019</b>	SCH - HQ - NY	<b>0 MW</b> <b>0 MW</b>
0100	Continuous	2000				Impacts Total Transfer Capability	1500 MW 1000 MW
Work scheduled by: NYPA						TTC with All Lines In Service	1500 MW 1000 MW
<b>MARCY_765_345_AT1</b>						FWD	
						(Import)	
Sat 10/12/2019	to	Tue 10/22/2019	<b>UPDATED</b>	<b>by NYPA</b>	<b>10/13/2019</b>	MOSES SOUTH	<b>1750 MW</b>
0100	Continuous	2000				Impacts Total Transfer Capability	1400 MW
Work scheduled by: NYPA						TTC with All Lines In Service	3150 MW
						<b>ARR: 19</b>	
<b>MARCY_765_345_AT2</b>						FWD	
						(Import)	
Sat 10/12/2019	to	Tue 10/22/2019	<b>UPDATED</b>	<b>by NYPA</b>	<b>10/13/2019</b>	MOSES SOUTH	<b>1700 MW</b>
0100	Continuous	2000				Impacts Total Transfer Capability	1450 MW
Work scheduled by: NYPA						TTC with All Lines In Service	3150 MW
						<b>ARR: 19</b>	
<b>MASSENA -MARC_765_MSU1</b>						FWD	
						(Import)	
Sat 10/12/2019	to	Tue 10/22/2019	<b>UPDATED</b>	<b>by NYPA</b>	<b>10/13/2019</b>	CENTRAL EAST - VC	<b>2265 MW</b>
0100	Continuous	2000				Impacts Total Transfer Capability	710 MW
Work scheduled by: NYPA						TTC with All Lines In Service	2975 MW
<b>MASSENA -MARC_765_MSU1</b>						FWD	
						(Import)	
Sat 10/12/2019	to	Tue 10/22/2019	<b>UPDATED</b>	<b>by NYPA</b>	<b>10/13/2019</b>	MOSES SOUTH	<b>500 MW</b>
0100	Continuous	2000				Impacts Total Transfer Capability	2650 MW
Work scheduled by: NYPA						TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,October 17, 2019 to Saturday ,April 17, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
<b>MASSENA -MARCY 765_MSU1</b>							
Sat 10/12/2019	to	Tue 10/22/2019	<b>UPDATED</b>	<b>by NYPA</b>	<b>10/13/2019</b>		
0100	Continuous	2000				SCH - HQ - NY	<b>475 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	1025 MW
						TTC with All Lines In Service	1500 MW
							1000 MW
<b>MASSENA -MARCY 765_MSU1</b>						FWD	
						(Import)	
Sat 10/12/2019	to	Tue 10/22/2019	<b>UPDATED</b>	<b>by NYPA</b>	<b>10/13/2019</b>	SCH - HQ_CEDARS	<b>90 MW</b>
0100	Continuous	2000				Impacts Total Transfer Capability	100 MW
Work scheduled by: NYPA						TTC with All Lines In Service	190 MW
<b>MASSENA -MARCY 765_MSU1 &amp; CHATGUAY-MASSENA 765_7040</b>						FWD	
						(Import)	
Sat 10/12/2019	to	Tue 10/22/2019				MOSES SOUTH	<b>500 MW</b>
0100		2000				Impacts Total Transfer Capability	2650 MW
Work scheduled by:						TTC with All Lines In Service	3150 MW
<b>MOSES -MASSENA 230_MMS1 &amp; MOSES -MASSENA 230_MMS2</b>						FWD	REV
						(Import)	(Export)
Sat 10/12/2019	to	Tue 10/22/2019				SCH - HQ - NY	<b>850 MW</b>
0100		2000				Impacts Total Transfer Capability	650 MW
Work scheduled by:						TTC with All Lines In Service	1500 MW
							1000 MW
<b>MOSES -MASSENA 230_MMS1 &amp; MOSES -MASSENA 230_MMS2</b>						FWD	
						(Import)	
Sat 10/12/2019	to	Tue 10/22/2019				SCH - HQ_CEDARS	<b>90 MW</b>
0100		2000				Impacts Total Transfer Capability	100 MW
Work scheduled by:						TTC with All Lines In Service	190 MW
<b>STLAWRNC-MOSES 230_L33P &amp; MASSENA -MARCY 765_MSU1</b>						FWD	
						(Import)	
Sat 10/12/2019	to	Tue 10/22/2019				SCH - HQ_CEDARS	<b>90 MW</b>
0100		2000				Impacts Total Transfer Capability	100 MW
Work scheduled by:						TTC with All Lines In Service	190 MW
<b>STLAWRNC-MOSES 230_L33P &amp; MOSES -MASSENA 230_MMS1 &amp; MOSES -MASSENA 230_MMS2</b>						FWD	
						(Import)	
Sat 10/12/2019	to	Tue 10/22/2019				SCH - HQ_CEDARS	<b>90 MW</b>
0100		2000				Impacts Total Transfer Capability	100 MW
Work scheduled by:						TTC with All Lines In Service	190 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,October 17, 2019 to Saturday ,April 17, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**CHAT\_DC\_GC2**

Sat 10/12/2019 to Sat 10/12/2019  
0201 Continuous 1959

Work scheduled by: HQ

FWD

(Import)

MOSES SOUTH **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

**CHAT\_DC\_GC2**

Sat 10/12/2019 to Sat 10/12/2019  
0201 Continuous 1959

Work scheduled by: HQ

REV

(Export)

SCH - HQ - NY **500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

**SCH-IMO-NYISO\_LIMIT\_600**

Sat 10/12/2019 to Sat 10/12/2019  
0900 Continuous 1630

Work scheduled by: IESO

FWD

(Import)

SCH - OH - NY **900 MW**  
Impacts Total Transfer Capability 1000 MW  
TTC with All Lines In Service 1900 MW

**SCH-NYISO-IMO\_LIMIT\_300**

Sat 10/12/2019 to Sat 10/12/2019  
0900 Continuous 1630

Work scheduled by: IESO

REV

(Export)

SCH - OH - NY **600 MW**  
Impacts Total Transfer Capability 1100 MW  
TTC with All Lines In Service 1700 MW

**CHAT\_DC\_GC1**

Sat 10/12/2019 to Sun 10/13/2019  
2000 Continuous 2300

Work scheduled by: HQ

FWD

(Import)

MOSES SOUTH **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

**CHAT\_DC\_GC1**

Sat 10/12/2019 to Sun 10/13/2019  
2000 Continuous 2300

Work scheduled by: HQ

REV

(Export)

SCH - HQ - NY **500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

**CHAT\_DC\_GC1 & CHAT\_DC\_GC2**

Sat 10/12/2019 to Sun 10/13/2019  
2000 Continuous 2300

Work scheduled by:

FWD

(Import)

MOSES SOUTH **2550 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,October 17, 2019 to Saturday ,April 17, 2021

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC1 & CHAT_DC_GC2		FWD	REV
		(Import)	(Export)
Sat 10/12/2019	to Sun 10/13/2019		
2000	2300	SCH - HQ - NY	<b>1370 MW 0 MW</b>
Work scheduled by:		Impacts Total Transfer Capability	130 MW 1000 MW
		TTC with All Lines In Service	1500 MW 1000 MW
CHAT_DC_GC1 & CHAT_DC_GC2 & MOSES -MASSENA_230_MMS1 & MOSES -MASSENA_230_MMS2		FWD	
		(Import)	
Sat 10/12/2019	to Sun 10/13/2019		
2000	2300	MOSES SOUTH	<b>1950 MW</b>
Work scheduled by:		Impacts Total Transfer Capability	1200 MW
		TTC with All Lines In Service	3150 MW
CHAT_DC_GC2		FWD	
		(Import)	
Sat 10/12/2019	to Sun 10/13/2019		
2000	Continuous 2300	MOSES SOUTH	<b>2850 MW</b>
Work scheduled by: HQ		Impacts Total Transfer Capability	300 MW
		TTC with All Lines In Service	3150 MW
CHAT_DC_GC2			REV
			(Export)
Sat 10/12/2019	to Sun 10/13/2019		
2000	Continuous 2300	SCH - HQ - NY	<b>500 MW</b>
Work scheduled by: HQ		Impacts Total Transfer Capability	500 MW
		TTC with All Lines In Service	1000 MW
SCH-HQ-NYISO_LIMIT_1150		FWD	
		(Import)	
Sat 10/12/2019	to Sun 10/13/2019		
2000	Continuous 2300	SCH - HQ - NY	<b>1150 MW</b>
Work scheduled by: HQ		Impacts Total Transfer Capability	350 MW
		TTC with All Lines In Service	1500 MW
E13THSTA-FARRAGUT_345_45		FWD	
		(Import)	
Sun 10/13/2019	to Mon 10/14/2019		
0001	Continuous 0200	SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd		Impacts Total Transfer Capability	800 MW
		TTC with All Lines In Service	4600 MW
CHAT_DC_GC2		FWD	
		(Import)	
Sun 10/13/2019	to Fri 11/22/2019		
2301	Continuous 2300	MOSES SOUTH	<b>2850 MW</b>
Work scheduled by: HQ		Impacts Total Transfer Capability	300 MW
		TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,October 17, 2019 to Saturday ,April 17, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CHAT_DC_GC2</b>						REV
Sun 10/13/2019	to	Fri 11/22/2019				(Export)
2301	Continuous	2300			SCH - HQ - NY	<b>500 MW</b>
Work scheduled by: HQ						Impacts Total Transfer Capability 500 MW
						TTC with All Lines In Service 1000 MW
<b>SHORE_RD_345_138_BK_2</b>						FWD
Mon 10/14/2019	to	Mon 10/14/2019	<u>by LI</u>	<u>10/16/2019</u>		(Import)
0001	Continuous	2359			CONED - LIPA	<b>1350 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability 150 MW
						TTC with All Lines In Service 1500 MW
<b>SHOR_NPX-SHOREHAM_138_CSC</b>						FWD REV
Mon 10/14/2019	to	Fri 10/18/2019	<u>UPDATED</u>	<u>by ISONE</u>	<u>08/09/2019</u>	(Import) (Export)
0600	Continuous	1600			SCH - NPX_CSC	<b>0 MW 0 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability 330 MW 330 MW
						TTC with All Lines In Service 330 MW 330 MW
<b>FIVEMILE-STOLLERD_345_29</b>						FWD
Mon 10/14/2019	to	Fri 10/18/2019	<u>UPDATED</u>	<u>by NGRID</u>	<u>10/08/2019</u>	(Import)
0700	Continuous	1400			SCH - PJ - NY	<b>2100 MW</b>
Work scheduled by: NYSEG						Impacts Total Transfer Capability 50 MW
						TTC with All Lines In Service 2150 MW
<b>MOTTHAVN-RAINEY__345_Q12</b>						FWD
Mon 10/14/2019	to	Wed 10/16/2019				(Import)
2359	Continuous	2359			SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
<b>PLSNTVLY-WOOD_ST_345_F30</b>						FWD
Tue 10/15/2019	to	Thu 10/17/2019	<u>UPDATED</u>	<u>by CE</u>	<u>10/10/2019</u>	(Import)
0301	Continuous	0300			UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 1700 MW
						TTC with All Lines In Service 5700 MW
<b>LEEDS__-HURLYAVE_345_301</b>						FWD
Tue 10/15/2019	to	Tue 10/15/2019	<u>UPDATED</u>	<u>by CHGE</u>	<u>09/05/2019</u>	(Import)
0800	Continuous	1629			UPNY CONED	<b>4100 MW</b>
Work scheduled by: CHGE						Impacts Total Transfer Capability 1600 MW
						TTC with All Lines In Service 5700 MW



# NYISO TRANSFER LIMITATIONS

Thursday ,October 17, 2019 to Saturday ,April 17, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE**

Thu 10/17/2019 to Wed 10/23/2019  
 0001 Continuous 2359  
 Work scheduled by: LI

FWD  
 (Import)  
 SCH - PJM\_NEPTUNE **0 MW**  
 Impacts Total Transfer Capability 660 MW  
 TTC with All Lines In Service 660 MW

**NEWBRDGE-DUFFYAVE\_345\_501**

Thu 10/17/2019 to Wed 10/23/2019  
 0001 Continuous 2359  
 Work scheduled by: LI

FWD  
 (Import)  
 SCH - PJM\_NEPTUNE **0 MW**  
 Impacts Total Transfer Capability 660 MW  
 TTC with All Lines In Service 660 MW

**NEWBRDGE\_345\_138\_BK\_1**

Thu 10/17/2019 to Wed 10/23/2019  
 0001 Continuous 2359  
 Work scheduled by: LI

FWD  
 (Import)  
 SCH - PJM\_NEPTUNE **375 MW**  
 Impacts Total Transfer Capability 285 MW  
 TTC with All Lines In Service 660 MW

**NEWBRDGE\_345\_138\_BK\_2**

Thu 10/17/2019 to Wed 10/23/2019  
 0001 Continuous 2359  
 Work scheduled by: LI

FWD  
 (Import)  
 SCH - PJM\_NEPTUNE **375 MW**  
 Impacts Total Transfer Capability 285 MW  
 TTC with All Lines In Service 660 MW

**DUNWODIE\_345KV\_7**

Fri 10/18/2019 to Fri 10/18/2019  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_8**

Fri 10/18/2019 to Fri 10/18/2019  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**DUNWODIE-MOTTHAVN\_345\_72**

Fri 10/18/2019 to Sat 10/19/2019  
 0001 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,October 17, 2019 to Saturday ,April 17, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE\_345KV\_7**

Sat 10/19/2019 to Sat 10/19/2019  
 0230 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_8**

Sat 10/19/2019 to Sat 10/19/2019  
 0230 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**KINTIGH\_-ROCHESTR\_345\_SRL-39**

Sat 10/19/2019 to Tue 10/22/2019 **CANCELLED by RGE 10/17/2019**  
 0700 Continuous 1900  
 Work scheduled by: RGE

FWD  
 (Import)  
 DYSINGER EAST **1400 MW**  
 Impacts Total Transfer Capability 1750 MW  
 TTC with All Lines In Service 3150 MW

**SHORE\_RD\_345\_138\_BK 2**

Mon 10/21/2019 to Mon 10/21/2019 **by LI 10/16/2019**  
 0001 Continuous 2359  
 Work scheduled by: LI

FWD  
 (Import)  
 CONED - LIPA **1350 MW**  
 Impacts Total Transfer Capability 150 MW  
 TTC with All Lines In Service 1500 MW

**HURLYAVE-ROSETON\_\_345\_303**

Mon 10/21/2019 to Thu 10/31/2019  
 0800 Continuous 1600  
 Work scheduled by: CHGE

FWD  
 (Import)  
 UPNY CONED **4100 MW**  
 Impacts Total Transfer Capability 1600 MW  
 TTC with All Lines In Service 5700 MW

**GILBOA\_-N.SCTLND\_345\_GNS-1**

Tue 10/22/2019 to Thu 10/24/2019 **UPDATED by NYPA 10/10/2019**  
 0700 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2520 MW**  
 Impacts Total Transfer Capability 455 MW  
 TTC with All Lines In Service 2975 MW

**WATRCURE\_345\_230\_BK 1**

Tue 10/22/2019 to Tue 10/22/2019  
 0800 Continuous 1530  
 Work scheduled by: NYSEG

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

Thursday ,October 17, 2019 to Saturday ,April 17, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					FWD
<b>SHORE_RD_345_138_BK 1</b>					(Import)
Wed 10/23/2019	to	Wed 10/23/2019	<u>by LI</u>	<u>10/16/2019</u>	CONED - LIPA <b>1350 MW</b>
0001	Continuous	2359			Impacts Total Transfer Capability 150 MW
Work scheduled by: LI					TTC with All Lines In Service 1500 MW
<hr/>					FWD
<b>SCH-IMO-NYISO_LIMIT_500</b>					(Import)
Wed 10/23/2019	to	Fri 11/08/2019	<u>UPDATED</u>	<u>by NYISO</u> <u>10/15/2019</u>	SCH - OH - NY <b>800 MW</b>
0500	Continuous	1859			Impacts Total Transfer Capability 1100 MW
Work scheduled by: NYPA					TTC with All Lines In Service 1900 MW
<hr/>					REV
<b>NIAGARA_345_230_AT4</b>					(Export)
Wed 10/23/2019	to	Tue 12/17/2019	<u>UPDATED</u>	<u>by NYPA</u> <u>09/10/2019</u>	SCH - OH - NY <b>1400 MW</b>
0500	Continuous	1700			Impacts Total Transfer Capability 300 MW
Work scheduled by: NYPA					TTC with All Lines In Service 1700 MW
<hr/>					FWD REV
<b>CEDARS_-ROSEMNTA_115_1/11</b>					(Import) (Export)
Wed 10/23/2019	to	Wed 10/23/2019			SCH - HQ_CEDARS <b>95 MW 40 MW</b>
0700	Daily(No Weekends)	1700			Impacts Total Transfer Capability 95 MW 0 MW
Work scheduled by: NGrid					TTC with All Lines In Service 190 MW 40 MW
<hr/>					FWD REV
<b>DENNISON-ROSEMNTA_115_1/11</b>					(Import) (Export)
Wed 10/23/2019	to	Wed 10/23/2019			SCH - HQ_CEDARS <b>95 MW 40 MW</b>
0700	Daily(No Weekends)	1700			Impacts Total Transfer Capability 95 MW 0 MW
Work scheduled by: NGrid					TTC with All Lines In Service 190 MW 40 MW
<hr/>					FWD
<b>EGRDNCTY_345_138_AT1</b>					(Import)
Thu 10/24/2019	to	Sun 11/03/2019	<u>UPDATED</u>	<u>by CE</u> <u>09/12/2019</u>	CONED - LIPA <b>1250 MW</b>
0001	Continuous	0300			Impacts Total Transfer Capability 250 MW
Work scheduled by: LI					TTC with All Lines In Service 1500 MW
<hr/>					FWD
<b>EGRDNCTY_345_138_AT2</b>					(Import)
Thu 10/24/2019	to	Sun 11/03/2019	<u>UPDATED</u>	<u>by CE</u> <u>09/12/2019</u>	CONED - LIPA <b>1250 MW</b>
0001	Continuous	0300			Impacts Total Transfer Capability 250 MW
Work scheduled by: LI					TTC with All Lines In Service 1500 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,October 17, 2019 to Saturday ,April 17, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						FWD		
<b>SPRNBK_-EGRDNCTR_345_Y49</b>						(Import)		
Thu 10/24/2019	to	Sun 11/03/2019	<b>UPDATED</b>	<b>by CE</b>	<b>09/12/2019</b>			
0001	Continuous	0300				CONED - LIPA	<b>775 MW</b>	
Work scheduled by: LI						Impacts Total Transfer Capability	725 MW	
						TTC with All Lines In Service	1500 MW	
<hr/>						FWD		
<b>GILBOA_-N.SCTLND_345_GNS-1</b>						(Import)		
Fri 10/25/2019	to	Fri 10/25/2019	<b>UPDATED</b>	<b>by NYPA</b>	<b>09/19/2019</b>	CENTRAL EAST - VC	<b>2520 MW</b>	
1630	Continuous	1730				Impacts Total Transfer Capability	455 MW	
Work scheduled by: NYPA						TTC with All Lines In Service	2975 MW	
<hr/>						FWD		
<b>NIAGARA_-ROCHESTR_345_NR2</b>						(Import)		
Mon 10/28/2019	to	Wed 11/13/2019	<b>CANCELLED</b>	<b>by NYPA</b>	<b>10/16/2019</b>	DYSINGER EAST	<b>1400 MW</b>	
0500	Continuous	1700				Impacts Total Transfer Capability	1750 MW	
Work scheduled by: NYPA						TTC with All Lines In Service	3150 MW	
<hr/>						FWD	REV	
<b>DENNISON-ROSEMNTA_115_1/11</b>						(Import)	(Export)	
Mon 10/28/2019	to	Thu 10/31/2019				SCH - HQ_CEDARS	<b>95 MW</b>	<b>40 MW</b>
0700	Continuous	2015				Impacts Total Transfer Capability	95 MW	0 MW
Work scheduled by: NGrid						TTC with All Lines In Service	190 MW	40 MW
<hr/>						FWD	REV	
<b>HOPATCON-RAMAPO___500_5018</b>						(Import)	(Export)	
Fri 11/01/2019	to	Tue 11/05/2019				SCH - PJ - NY	<b>1250 MW</b>	<b>1200 MW</b>
0001	Continuous	2200				Impacts Total Transfer Capability	1350 MW	350 MW
Work scheduled by: ConEd						TTC with All Lines In Service	2600 MW	1550 MW
<hr/>						FWD		
<b>HOPATCON-RAMAPO___500_5018</b>						(Import)		
Fri 11/01/2019	to	Tue 11/05/2019				UPNY CONED	<b>5000 MW</b>	
0001	Continuous	2200				Impacts Total Transfer Capability	700 MW	
Work scheduled by: ConEd						TTC with All Lines In Service	5700 MW	
<hr/>						FWD	REV	
<b>RAMAPO___345_345_PAR3500</b>						(Import)	(Export)	
Fri 11/01/2019	to	Tue 11/05/2019				SCH - PJ - NY	<b>2150 MW</b>	<b>1250 MW</b>
0001	Continuous	2200				Impacts Total Transfer Capability	450 MW	300 MW
Work scheduled by: ConEd						TTC with All Lines In Service	2600 MW	1550 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,October 17, 2019 to Saturday ,April 17, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>RAMAPO___345_345_PAR4500</b>					FWD	REV
Fri 11/01/2019 to Tue 11/05/2019					(Import) (Export)	
0001	Continuous	2200			<b>2150 MW</b>	<b>1250 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	450 MW 300 MW
					TTC with All Lines In Service	2600 MW 1550 MW
<b>RAMAPO___500_345_BK 1500</b>					FWD	REV
Fri 11/01/2019 to Tue 11/05/2019					(Import) (Export)	
0001	Continuous	2200			<b>1250 MW</b>	<b>1200 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	1350 MW 350 MW
					TTC with All Lines In Service	2600 MW 1550 MW
<b>RAMAPO___500_345_BK 1500</b>					FWD	
Fri 11/01/2019 to Tue 11/05/2019					(Import)	
0001	Continuous	2200			<b>5000 MW</b>	
Work scheduled by: ConEd					Impacts Total Transfer Capability	700 MW
					TTC with All Lines In Service	5700 MW
<b>SCH-IMO-NYISO_LIMIT_1750</b>					FWD	
Fri 11/01/2019 to Thu 04/30/2020					(Import)	
0001	Continuous	2359	<b>UPDATED</b>	<b>by IESO</b>	<b>05/03/2019</b>	
Work scheduled by: IESO					SCH - OH - NY	<b>2050 MW</b>
					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	2250 MW
<b>SCH-NYISO-IMO_LIMIT_1600</b>						REV
Fri 11/01/2019 to Thu 04/30/2020					(Export)	
0001	Continuous	2359	<b>UPDATED</b>	<b>by IESO</b>	<b>05/03/2019</b>	
Work scheduled by: IESO					SCH - OH - NY	<b>1900 MW</b>
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	2000 MW
<b>VOLNEY__-MARCY___345_19</b>					FWD	
Fri 11/01/2019 to Fri 11/01/2019					(Import)	
0730	Daily(No Weekends)	1630			<b>2825 MW</b>	
Work scheduled by: NGrid					CENTRAL EAST - VC	<b>2825 MW</b>
					Impacts Total Transfer Capability	150 MW
					TTC with All Lines In Service	2975 MW
<b>VOLNEY__-MARCY___345_19</b>					FWD	
Fri 11/01/2019 to Fri 11/01/2019					(Import)	
0730	Daily(No Weekends)	1630			<b>4900 MW</b>	
Work scheduled by: NGrid					OSWEGO EXPORT	<b>4900 MW</b>
					Impacts Total Transfer Capability	350 MW
					TTC with All Lines In Service	5250 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,October 17, 2019 to Saturday ,April 17, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
<b>SHORE_RD_345_138_BK 1</b>				(Import)	
Mon 11/04/2019	to	Mon 11/04/2019	<u>by LI</u> <u>10/16/2019</u>		
0001	Continuous	2359		CONED - LIPA	<b>1350 MW</b>
Work scheduled by: LI				Impacts Total Transfer Capability	150 MW
				TTC with All Lines In Service	1500 MW
<b>NRTH1385-NOR HBR_138_601</b>				(Import)	(Export)
Mon 11/04/2019	to	Fri 11/15/2019			
0001	Continuous	2359		SCH - NPX_1385	<b>100 MW    100 MW</b>
Work scheduled by: LI				Impacts Total Transfer Capability	100 MW    100 MW
				TTC with All Lines In Service	200 MW    200 MW
<b>NRTH1385-NOR HBR_138_601 &amp; NRTH1385-NOR HBR_138_602</b>				(Import)	(Export)
Mon 11/04/2019	to	Fri 11/15/2019			
0001		2359		SCH - NPX_1385	<b>0 MW    0 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	200 MW    200 MW
				TTC with All Lines In Service	200 MW    200 MW
<b>NRTH1385-NOR HBR_138_601 &amp; NRTH1385-NOR HBR_138_603</b>				(Import)	(Export)
Mon 11/04/2019	to	Fri 11/15/2019			
0001		2359		SCH - NPX_1385	<b>0 MW    0 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	200 MW    200 MW
				TTC with All Lines In Service	200 MW    200 MW
<b>NRTH1385-NOR HBR_138_602</b>				(Import)	(Export)
Mon 11/04/2019	to	Fri 11/15/2019			
0001	Continuous	2359		SCH - NPX_1385	<b>100 MW    100 MW</b>
Work scheduled by: LI				Impacts Total Transfer Capability	100 MW    100 MW
				TTC with All Lines In Service	200 MW    200 MW
<b>NRTH1385-NOR HBR_138_602 &amp; NRTH1385-NOR HBR_138_603</b>				(Import)	(Export)
Mon 11/04/2019	to	Fri 11/15/2019			
0001		2359		SCH - NPX_1385	<b>0 MW    0 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	200 MW    200 MW
				TTC with All Lines In Service	200 MW    200 MW
<b>NRTH1385-NOR HBR_138_603</b>				(Import)	(Export)
Mon 11/04/2019	to	Fri 11/15/2019			
0001	Continuous	2359		SCH - NPX_1385	<b>100 MW    100 MW</b>
Work scheduled by: LI				Impacts Total Transfer Capability	100 MW    100 MW
				TTC with All Lines In Service	200 MW    200 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,October 17, 2019 to Saturday ,April 17, 2021

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
<b>NRTH1385-NRTHPORT_138_NNC</b>						
Mon 11/04/2019	to	Fri 11/15/2019				
0001	Continuous	2359		SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	200 MW
<b>LINDN_CG-LNDVFT_345_V-3022</b>						
Mon 11/04/2019	to	Thu 11/07/2019				
0800	Continuous	1500		SCH - PJM_VFT	<b>0 MW</b>	<b>0 MW</b>
Work scheduled by: PJM					Impacts Total Transfer Capability	315 MW
					TTC with All Lines In Service	315 MW
<b>MARCY_-N.SCTLND_345_18</b>						
Wed 11/06/2019	to	Wed 11/13/2019	<b>UPDATED</b>	<b>by NYPA</b>	<b>09/11/2019</b>	
0500	Continuous	1730				FWD
Work scheduled by: NYPA						(Import)
					CENTRAL EAST - VC	<b>2090 MW</b>
					Impacts Total Transfer Capability	885 MW
					TTC with All Lines In Service	2975 MW
<b>MARCY_345KV_CSC</b>						
Wed 11/06/2019	to	Fri 11/22/2019	<b>UPDATED</b>	<b>by NYPA</b>	<b>09/11/2019</b>	
0500	Continuous	1730				FWD
Work scheduled by: NYPA						(Import)
					CENTRAL EAST - VC	<b>2925 MW</b>
					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	2975 MW
<b>MARCY_765_345_AT2</b>						
Wed 11/06/2019	to	Fri 11/22/2019	<b>UPDATED</b>	<b>by NYPA</b>	<b>09/11/2019</b>	
0500	Continuous	1730				FWD
Work scheduled by: NYPA						(Import)
					MOSES SOUTH	<b>1700 MW</b>
					Impacts Total Transfer Capability	1450 MW
					TTC with All Lines In Service	3150 MW
<b>HURLYAVE-ROSETON_345_303</b>						
Wed 11/06/2019	to	Fri 12/06/2019				
0800	Continuous	1600				FWD
Work scheduled by: CHGE						(Import)
					UPNY CONED	<b>4100 MW</b>
					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	5700 MW
<b>N.SCTLND-LEEDS_345_94</b>						
Wed 11/06/2019	to	Thu 11/07/2019				
0830	Continuous	1430				FWD
Work scheduled by: NGrid						(Import)
					CENTRAL EAST - VC	<b>2650 MW</b>
					Impacts Total Transfer Capability	325 MW
					TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,October 17, 2019 to Saturday ,April 17, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>PLSNTVLE-DUNWODIE_345_W89</b>				FWD	
Fri 11/08/2019	to	Sat 11/09/2019		(Import)	
0001	Continuous	0030	UPNY CONED	<b>4000 MW</b>	
Work scheduled by: ConEd			Impacts Total Transfer Capability	1700 MW	
			TTC with All Lines In Service	5700 MW	
<b>PLSNTVLY_345KV_RNS5</b>				FWD	
Mon 11/11/2019	to	Mon 11/11/2019		(Import)	
0001	Continuous	0030	UPNY CONED	<b>3800 MW</b>	
Work scheduled by: ConEd			Impacts Total Transfer Capability	1900 MW	
			TTC with All Lines In Service	5700 MW	
<b>PLSNTVLY-WOOD_ST_345_F30</b>				FWD	
Mon 11/11/2019	to	Tue 11/12/2019		(Import)	
0001	Continuous	0200	UPNY CONED	<b>4000 MW</b>	
Work scheduled by: ConEd			Impacts Total Transfer Capability	1700 MW	
			TTC with All Lines In Service	5700 MW	
<b>E13THSTA-FARRAGUT_345_45</b>				FWD	
Tue 11/12/2019	to	Tue 11/12/2019		(Import)	
0001	Continuous	0030	SPR/DUN-SOUTH	<b>3800 MW</b>	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
<b>PLSNTVLY_345KV_RNS5</b>				FWD	
Tue 11/12/2019	to	Tue 11/12/2019		(Import)	
0130	Continuous	0200	UPNY CONED	<b>3800 MW</b>	
Work scheduled by: ConEd			Impacts Total Transfer Capability	1900 MW	
			TTC with All Lines In Service	5700 MW	
<b>WATRCURE-OAKDALE_345_31</b>				FWD	REV
Tue 11/12/2019	to	Tue 11/12/2019	<b>UPDATED</b>	(Import)	(Export)
1300	Continuous	1500	<b>by NYSEG 09/13/2019</b>	SCH - PJ - NY	<b>2600 MW 1300 MW</b>
Work scheduled by: NYSEG			Impacts Total Transfer Capability	0 MW	250 MW
			TTC with All Lines In Service	2600 MW	1550 MW
<b>PLSNTVLY-WOOD_ST_345_F31</b>				FWD	
Thu 11/14/2019	to	Thu 11/14/2019	<b>UPDATED</b>	(Import)	
0001	Continuous	2200	<b>by NYISO 09/18/2019</b>	UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	1700 MW	
			TTC with All Lines In Service	5700 MW	



# NYISO TRANSFER LIMITATIONS

Thursday ,October 17, 2019 to Saturday ,April 17, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**PLSNTVLY\_345KV\_RNS4**

Thu 11/14/2019 to Thu 11/14/2019  
 0001 Continuous 2200  
 Work scheduled by: ConEd

UPDATED by NYISO 09/18/2019

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 1900 MW  
 TTC with All Lines In Service 5700 MW

**E13THSTA-FARRAGUT\_345\_45**

Thu 11/14/2019 to Thu 11/14/2019  
 0130 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**W49TH\_ST-E13THSTA\_345\_M54**

Thu 11/14/2019 to Thu 11/14/2019  
 0201 Continuous 0500  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**BUCHAN\_N-EASTVIEW\_345\_W93**

Sun 11/17/2019 to Mon 11/18/2019  
 0301 Continuous 0300  
 Work scheduled by: ConEd

UPDATED by CONED 09/09/2019

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1350 MW  
 TTC with All Lines In Service 5700 MW

**EASTVIEW-SPRNBK\_\_345\_W79**

Sun 11/17/2019 to Mon 11/18/2019  
 0301 Continuous 0300  
 Work scheduled by: ConEd

UPDATED by CONED 09/09/2019

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1350 MW  
 TTC with All Lines In Service 5700 MW

**SCH-NE-NYISO\_LIMIT\_500**

Sun 11/17/2019 to Sun 11/17/2019  
 1100 Continuous 1600  
 Work scheduled by: ISONE

FWD  
 (Import)  
 SCH - NE - NY **700 MW**  
 Impacts Total Transfer Capability 700 MW  
 TTC with All Lines In Service 1400 MW

**SCH-NYISO-NE\_LIMIT\_1200**

Sun 11/17/2019 to Sun 11/17/2019  
 1100 Continuous 1600  
 Work scheduled by: ISONE

REV  
 (Export)  
 SCH - NE - NY **1400 MW**  
 Impacts Total Transfer Capability 400 MW  
 TTC with All Lines In Service 1800 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,October 17, 2019 to Saturday ,April 17, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	
<b>SPRNBK__345KV_RNS5</b>					(Import)	
Mon 11/18/2019	to	Mon 11/18/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>09/09/2019</u>	
0301	Continuous	0330				
Work scheduled by: ConEd					SPR/DUN-SOUTH	<b>3200 MW</b>
					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
<b>EASTVIEW-SPRNBK__345_W64</b>					(Import)	
Mon 11/18/2019	to	Tue 11/19/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>09/09/2019</u>	
0301	Continuous	0200				
Work scheduled by: ConEd					UPNY CONED	<b>4350 MW</b>
					Impacts Total Transfer Capability	1350 MW
					TTC with All Lines In Service	5700 MW
<b>MILLWOOD-EASTVIEW_345_W99</b>					(Import)	
Mon 11/18/2019	to	Tue 11/19/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>09/09/2019</u>	
0301	Continuous	0200				
Work scheduled by: ConEd					UPNY CONED	<b>4350 MW</b>
					Impacts Total Transfer Capability	1350 MW
					TTC with All Lines In Service	5700 MW
<b>BERKSHIR-ALPS____345_393</b>					(Import)	REV (Export)
Mon 11/18/2019	to	Wed 11/27/2019				
0600	Continuous	1700				
Work scheduled by: ISONE					SCH - NE - NY	<b>1150 MW 1300 MW</b>
					Impacts Total Transfer Capability	250 MW 500 MW
					TTC with All Lines In Service	1400 MW 1800 MW
						<b>ARR: 78</b>
<b>BERKSHIR-ALPS____345_393</b>					(Import)	REV (Export)
Mon 11/18/2019	to	Wed 11/27/2019				
0600	Continuous	1700				
Work scheduled by: ISONE					SCH - NPX_1385	<b>100 MW 100 MW</b>
					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW
						<b>ARR: 78</b>
<b>BERKSHIR-ALPS____345_393 &amp; BERKSHIR-NORTHFLD_345_312</b>					(Import)	REV (Export)
Mon 11/18/2019	to	Wed 11/27/2019				
0600		1700				
Work scheduled by:					SCH - NE - NY	<b>1150 MW 1300 MW</b>
					Impacts Total Transfer Capability	250 MW 500 MW
					TTC with All Lines In Service	1400 MW 1800 MW
						<b>ARR: 78</b>
<b>BERKSHIR-NORTHFLD_345_312</b>					(Import)	REV (Export)
Mon 11/18/2019	to	Wed 11/27/2019				
0600	Continuous	1700				
Work scheduled by: ISONE					SCH - NE - NY	<b>1400 MW 1500 MW</b>
					Impacts Total Transfer Capability	0 MW 300 MW
					TTC with All Lines In Service	1400 MW 1800 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,October 17, 2019 to Saturday ,April 17, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-NORTHFLD_345_312		FWD	REV
		(Import)	(Export)
Mon 11/18/2019	to Wed 11/27/2019		
0600	Continuous 1700	SCH - NPX_1385	<b>100 MW</b>
Work scheduled by: ISONE		Impacts Total Transfer Capability	100 MW
		TTC with All Lines In Service	200 MW
SCH-NE-NYISO_LIMIT_800		FWD	
		(Import)	
Mon 11/18/2019	to Wed 11/27/2019		
0600	Continuous 1700	SCH - NE - NY	<b>1000 MW</b>
Work scheduled by: ISONE		Impacts Total Transfer Capability	400 MW
		TTC with All Lines In Service	1400 MW
SCH-NYISO-NE_LIMIT_500			REV
			(Export)
Mon 11/18/2019	to Wed 11/27/2019		
0600	Continuous 1700	SCH - NE - NY	<b>700 MW</b>
Work scheduled by: ISONE		Impacts Total Transfer Capability	1100 MW
		TTC with All Lines In Service	1800 MW
SPRNBK__345KV_RNS5		FWD	
		(Import)	
Tue 11/19/2019	to Tue 11/19/2019		
0130	Continuous 0200	<b>UPDATED</b> <b>by CONED</b> <b>09/09/2019</b>	
Work scheduled by: ConEd		SPR/DUN-SOUTH	<b>3200 MW</b>
		Impacts Total Transfer Capability	1400 MW
		TTC with All Lines In Service	4600 MW
EASTVIEW-SPRNBK__345_W64		FWD	
		(Import)	
Sat 11/23/2019	to Sat 11/23/2019		
0130	Continuous 0200	UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd		Impacts Total Transfer Capability	1350 MW
		TTC with All Lines In Service	5700 MW
MILLWOOD-EASTVIEW_345_W99		FWD	
		(Import)	
Sat 11/23/2019	to Sat 11/23/2019		
0130	Continuous 0200	UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd		Impacts Total Transfer Capability	1350 MW
		TTC with All Lines In Service	5700 MW
SPRNBK__345KV_RNS5		FWD	
		(Import)	
Sat 11/23/2019	to Sat 11/23/2019		
0130	Continuous 0200	SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd		Impacts Total Transfer Capability	1400 MW
		TTC with All Lines In Service	4600 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,October 17, 2019 to Saturday ,April 17, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>RAMAPO__-LADENTWN_345_W72</b>				FWD
Mon 11/25/2019	to	Mon 11/25/2019		(Import)
0001	Continuous	2200	UPNY CONED	<b>4400 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 1300 MW
				TTC with All Lines In Service 5700 MW
<b>MOSES__-ADIRNDCK_230_MA2</b>				FWD
Mon 11/25/2019	to	Wed 11/27/2019		(Import)
0700	Continuous	1500	MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW
<b>SHOR_NPX-SHOREHAM_138_CSC</b>				FWD
Mon 12/02/2019	to	Mon 12/02/2019	<b>UPDATED by ISONE 10/04/2019</b>	REV (Export)
0700	Continuous	2300	SCH - NPX_CSC	<b>0 MW 0 MW</b>
Work scheduled by: LI				Impacts Total Transfer Capability 330 MW 330 MW
				TTC with All Lines In Service 330 MW 330 MW
<b>MOSES__-ADIRNDCK_230_MA2</b>				FWD
Mon 12/02/2019	to	Fri 12/06/2019		(Import)
0700	Continuous	1500	MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW
<b>N. SCTLND-ALPS____345_2</b>				FWD
Mon 12/02/2019	to	Mon 12/02/2019		REV (Export)
0730	Daily(No Weekends)	1630	SCH - NE - NY	<b>900 MW 1700 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability 500 MW 100 MW
				TTC with All Lines In Service 1400 MW 1800 MW
<b>N. SCTLND-ALPS____345_2</b>				FWD
Mon 12/02/2019	to	Mon 12/02/2019		REV (Export)
0730	Daily(No Weekends)	1630	SCH - NPX_1385	<b>100 MW 100 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability 100 MW 100 MW
				TTC with All Lines In Service 200 MW 200 MW
<b>FRASER____345_FRASER SVC</b>				FWD
Mon 12/02/2019	to	Fri 12/13/2019		(Import)
0800	Continuous	1500	CENTRAL EAST - VC	<b>2935 MW</b>
Work scheduled by: NYSEG				Impacts Total Transfer Capability 40 MW
				TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,October 17, 2019 to Saturday ,April 17, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>LEEDS</b> ___345KV_R94301			FWD
Tue 12/03/2019	to	Fri 12/13/2019	(Import)
0800	Continuous	1500	
Work scheduled by: NGrid			
		<b>UPDATED</b>	<b>by NGRID</b>
		<b>10/04/2019</b>	
		UPNY CONED	<b>3800 MW</b>
		Impacts Total Transfer Capability	1900 MW
		TTC with All Lines In Service	5700 MW
<hr/>			
<b>MOSES</b> ___-ADIRNDCK_230_MA1			FWD
Mon 12/09/2019	to	Fri 12/13/2019	(Import)
0700	Continuous	1500	
Work scheduled by: NYPA			
		MOSES SOUTH	<b>2300 MW</b>
		Impacts Total Transfer Capability	850 MW
		TTC with All Lines In Service	3150 MW
<hr/>			
<b>ROSETON</b> _-ROCKTVRN_345_311			FWD
Mon 12/09/2019	to	Thu 12/12/2019	(Import)
0800	Continuous	1600	
Work scheduled by: CHGE			
		UPNY CONED	<b>4400 MW</b>
		Impacts Total Transfer Capability	1300 MW
		TTC with All Lines In Service	5700 MW
<hr/>			
<b>SHOR_NPX-SHOREHAM_138_CSC</b>			FWD
Thu 12/12/2019	to	Fri 12/20/2019	(Import) (Export)
0700	Continuous	1500	
Work scheduled by: ISONE			
		SCH - NPX_CSC	<b>0 MW</b> <b>0 MW</b>
		Impacts Total Transfer Capability	330 MW    330 MW
		TTC with All Lines In Service	330 MW    330 MW
<hr/>			
<b>MOSES</b> ___-ADIRNDCK_230_MA2			FWD
Mon 12/16/2019	to	Mon 12/16/2019	(Import)
0700	Continuous	1500	
Work scheduled by: NYPA			
		MOSES SOUTH	<b>2300 MW</b>
		Impacts Total Transfer Capability	850 MW
		TTC with All Lines In Service	3150 MW
<hr/>			
<b>MOSES</b> ___-ADIRNDCK_230_MA1			FWD
Tue 12/17/2019	to	Fri 12/20/2019	(Import)
0700	Continuous	1500	
Work scheduled by: NYPA			
		MOSES SOUTH	<b>2300 MW</b>
		Impacts Total Transfer Capability	850 MW
		TTC with All Lines In Service	3150 MW
<hr/>			
<b>SCH-NE-NYISO_LIMIT_500</b>			FWD
Fri 12/20/2019	to	Fri 12/20/2019	(Import)
0600	Continuous	1600	
Work scheduled by: ISONE			
		<b>UPDATED</b>	<b>by ISONE</b>
		<b>10/11/2019</b>	
		SCH - NE - NY	<b>700 MW</b>
		Impacts Total Transfer Capability	700 MW
		TTC with All Lines In Service	1400 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,October 17, 2019 to Saturday ,April 17, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-NE_LIMIT_1200					REV	
Fri 12/20/2019	to	Fri 12/20/2019	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/11/2019</u>	(Export)
0600	Continuous	1600				<b>1400 MW</b>
Work scheduled by: ISONE					SCH - NE - NY	400 MW
					Impacts Total Transfer Capability	1800 MW
					TTC with All Lines In Service	
MOSES -ADIRNDCK_230_MA2					FWD	
Thu 01/02/2020	to	Sun 03/01/2020				(Import)
0700	Continuous	1530				<b>2300 MW</b>
Work scheduled by: NYPA					MOSES SOUTH	850 MW
					Impacts Total Transfer Capability	3150 MW
					TTC with All Lines In Service	
LADENTWN-BUCHAN_S_345_Y88					FWD	
Wed 01/15/2020	to	Thu 02/13/2020		<u>11/05/2018</u>		(Import)
0001	Continuous	2359				<b>4800 MW</b>
Work scheduled by: ORU					UPNY CONED	900 MW
					Impacts Total Transfer Capability	5700 MW
					TTC with All Lines In Service	
MOTTHAVN-RAINEY_345_Q11					FWD	
Sun 02/23/2020	to	Sun 03/01/2020				(Import)
0001	Continuous	0200				<b>3800 MW</b>
Work scheduled by: ConEd					SPR/DUN-SOUTH	800 MW
					Impacts Total Transfer Capability	4600 MW
					TTC with All Lines In Service	
NIAGARA -PACKARD_230_62					FWD	REV
Fri 02/28/2020	to	Fri 02/28/2020				(Import) (Export)
0500	Continuous	1530				<b>1100 MW 950 MW</b>
Work scheduled by: NYPA					SCH - OH - NY	1050 MW
					Impacts Total Transfer Capability	2000 MW
					TTC with All Lines In Service	
CHATGUAY-MASSENA_765_7040					FWD	
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)
0500	Continuous	1730				<b>1550 MW</b>
Work scheduled by: NYPA					MOSES SOUTH	1600 MW
					Impacts Total Transfer Capability	3150 MW
					TTC with All Lines In Service	
CHATGUAY-MASSENA_765_7040					FWD	REV
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import) (Export)
0500	Continuous	1730				<b>0 MW 0 MW</b>
Work scheduled by: NYPA					SCH - HQ - NY	1000 MW
					Impacts Total Transfer Capability	1000 MW
					TTC with All Lines In Service	1500 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,October 17, 2019 to Saturday ,April 17, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MARCY___765_345_AT1</b>						FWD
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)
0500	Continuous	1730				MOSES SOUTH <b>1750 MW</b>
Work scheduled by: NYPA				<b>ARR: 19</b>		Impacts Total Transfer Capability 1400 MW
						TTC with All Lines In Service 3150 MW
<b>MARCY___765_345_AT2</b>						FWD
Mon 03/02/2020	to	Fri 03/06/2020				(Import)
0500	Continuous	1730				MOSES SOUTH <b>1700 MW</b>
Work scheduled by: NYPA				<b>ARR: 19</b>		Impacts Total Transfer Capability 1450 MW
						TTC with All Lines In Service 3150 MW
<b>MASSENA_-MARCYS___765_MSU1</b>						FWD
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)
0500	Continuous	1730				CENTRAL EAST - VC <b>2265 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability 710 MW
						TTC with All Lines In Service 2975 MW
<b>MASSENA_-MARCYS___765_MSU1</b>						FWD
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)
0500	Continuous	1730				MOSES SOUTH <b>500 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability 2650 MW
						TTC with All Lines In Service 3150 MW
<b>MASSENA_-MARCYS___765_MSU1</b>						FWD
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import) (Export)
0500	Continuous	1730				SCH - HQ - NY <b>475 MW 1000 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability 1025 MW 0 MW
						TTC with All Lines In Service 1500 MW 1000 MW
<b>MASSENA_-MARCYS___765_MSU1</b>						FWD
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)
0500	Continuous	1730				SCH - HQ_CEDARS <b>90 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability 109 MW
						TTC with All Lines In Service 199 MW
<b>MASSENA_-MARCYS___765_MSU1 &amp; CHATGUAY-MASSENA_765_7040</b>						FWD
Mon 03/02/2020	to	Fri 03/06/2020				(Import)
0500		1730				MOSES SOUTH <b>500 MW</b>
Work scheduled by:						Impacts Total Transfer Capability 2650 MW
						TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,October 17, 2019 to Saturday ,April 17, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES ___-MASSENA___ 230_MMS1 & MOSES ___-MASSENA___ 230_MMS2	FWD	REV
	(Import)	(Export)
Mon 03/02/2020 to Fri 03/06/2020 0500 1730	SCH - HQ - NY Impacts Total Transfer Capability 650 MW TTC with All Lines In Service 1500 MW	<b>850 MW</b> 0 MW 1000 MW 1000 MW
Work scheduled by:		
MOSES ___-MASSENA___ 230_MMS1 & MOSES ___-MASSENA___ 230_MMS2	FWD	
	(Import)	
Mon 03/02/2020 to Fri 03/06/2020 0500 1730	SCH - HQ_CEDARS Impacts Total Transfer Capability 109 MW TTC with All Lines In Service 199 MW	<b>90 MW</b> 109 MW 199 MW
Work scheduled by:		
STLAWRNC-MOSES___ 230_L33P & MASSENA_-MARCY___ 765_MSU1	FWD	
	(Import)	
Mon 03/02/2020 to Fri 03/06/2020 0500 1730	SCH - HQ_CEDARS Impacts Total Transfer Capability 109 MW TTC with All Lines In Service 199 MW	<b>90 MW</b> 109 MW 199 MW
Work scheduled by:		
STLAWRNC-MOSES___ 230_L33P & MOSES ___-MASSENA___ 230_MMS1 & MOSES ___-MASSENA___ 230_MMS2	FWD	
	(Import)	
Mon 03/02/2020 to Fri 03/06/2020 0500 1730	SCH - HQ_CEDARS Impacts Total Transfer Capability 109 MW TTC with All Lines In Service 199 MW	<b>90 MW</b> 109 MW 199 MW
Work scheduled by:		
EASTVIEW-SPRNBK___ 345_W78	FWD	
	(Import)	
Fri 03/06/2020 to Sat 03/07/2020 0001 Continuous 0200	UPNY CONED Impacts Total Transfer Capability 1350 MW TTC with All Lines In Service 5700 MW	<b>4350 MW</b> 1350 MW 5700 MW
Work scheduled by: ConEd		
MILLWOOD-EASTVIEW_345_W85	FWD	
	(Import)	
Fri 03/06/2020 to Sat 03/07/2020 0001 Continuous 0200	UPNY CONED Impacts Total Transfer Capability 1350 MW TTC with All Lines In Service 5700 MW	<b>4350 MW</b> 1350 MW 5700 MW
Work scheduled by: ConEd		
SPRNBK___ 345KV_RNS3	FWD	
	(Import)	
Fri 03/06/2020 to Sat 03/07/2020 0001 Continuous 0200	SPR/DUN-SOUTH Impacts Total Transfer Capability 800 MW TTC with All Lines In Service 4600 MW	<b>3800 MW</b> 800 MW 4600 MW
Work scheduled by: ConEd		



# NYISO TRANSFER LIMITATIONS

Thursday ,October 17, 2019 to Saturday ,April 17, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES -ADIRNDCK\_230\_MA1**

Sat 03/07/2020 to Fri 05/29/2020  
0700 Continuous 1300

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**VOLNEY -MARCY\_345\_19**

Tue 03/10/2020 to Tue 03/10/2020  
0700 Continuous 1530

Work scheduled by: NYPA

**UPDATED by NYPA 09/24/2019**

**ARR: 19**

FWD  
(Import)  
CENTRAL EAST - VC **2825 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 2975 MW

**VOLNEY -MARCY\_345\_19**

Tue 03/10/2020 to Tue 03/10/2020  
0700 Continuous 1530

Work scheduled by: NYPA

**UPDATED by NYPA 09/24/2019**

**ARR: 19**

FWD  
(Import)  
OSWEGO EXPORT **4900 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 5250 MW

**FRASANX-COOPERS\_345\_UCC2-41**

Wed 03/11/2020 to Thu 03/12/2020  
0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

**MARCY -FRASANX\_345\_UCC2-41**

Wed 03/11/2020 to Thu 03/12/2020  
0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

**ROCHESTR-PANNELL\_345\_RP2**

Sat 03/14/2020 to Mon 03/23/2020  
0500 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**MARCY\_345KV\_CSC**

Mon 03/16/2020 to Fri 03/27/2020  
0500 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2925 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,October 17, 2019 to Saturday ,April 17, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>ROSETON_-EFISHKIL_345_RFK305</b>			FWD	
Mon 03/16/2020	to	Fri 04/03/2020	(Import)	
0700	Continuous	1530	UPNY CONED	<b>4800 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	900 MW
			TTC with All Lines In Service	5700 MW
<b>NIAGARA_-KINTIGH_345_NS1-38</b>			FWD	
Fri 03/27/2020	to	Fri 03/27/2020	(Import)	
0600	Continuous	1530	DYSINGER EAST	<b>1700 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	1450 MW
			TTC with All Lines In Service	3150 MW
<b>BECK_-PACKARD_230_BP76</b>			FWD	REV
Fri 03/27/2020	to	Fri 03/27/2020	(Import)	(Export)
0800	Daily(No Weekends)	1600	SCH - OH - NY	<b>1700 MW 1500 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability	550 MW 500 MW
			TTC with All Lines In Service	2250 MW 2000 MW
<b>MARCY_-EDIC_345_UE1-7</b>			FWD	
Tue 03/31/2020	to	Tue 03/31/2020	(Import)	
0700	Continuous	1530	OSWEGO EXPORT	<b>5250 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	0 MW
			TTC with All Lines In Service	5250 MW
<b>SPRNBRK_-W49TH_ST_345_M51</b>			FWD	
Mon 04/06/2020	to	Wed 04/08/2020	(Import)	
0001	Continuous	0200	SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	1400 MW
			TTC with All Lines In Service	4600 MW
<b>SPRNBRK_345KV_RNS5</b>			FWD	
Mon 04/06/2020	to	Wed 04/08/2020	(Import)	
0001	Continuous	0200	SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	1400 MW
			TTC with All Lines In Service	4600 MW
<b>MARCY_-N.SCTLND_345_18</b>			FWD	
Tue 04/07/2020	to	Wed 04/08/2020	(Import)	
0700	Continuous	1530	CENTRAL EAST - VC	<b>2090 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	885 MW
			TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,October 17, 2019 to Saturday ,April 17, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Transfer ID	Start Date	End Date	Time	Work Scheduled by	Transfer Type	Impact	TTC
LINDN_CG-LNDVFT_345_V-3022	Sun 04/12/2020	Fri 04/17/2020	1400 - 1800	PJM	SCH - PJM_VFT	0 MW	315 MW
						Impacts Total Transfer Capability	315 MW
						TTC with All Lines In Service	315 MW
PLSNTVLY-EFISHKIL_345_F36	Mon 04/13/2020	Tue 04/14/2020	0001 - 0200	ConEd	UPNY CONED	4000 MW	1700 MW
						Impacts Total Transfer Capability	1700 MW
						TTC with All Lines In Service	5700 MW
FRASER -GILBOA_345_GF5-35	Mon 04/13/2020	Wed 04/22/2020	0700 - 1730	NYPA	CENTRAL EAST - VC	2650 MW	325 MW
						Impacts Total Transfer Capability	325 MW
						TTC with All Lines In Service	2975 MW
NIAGARA -ROCHESTR_345_NR2	Mon 04/20/2020	Fri 05/01/2020	0500 - 1700	NYPA	DYSINGER EAST	1700 MW	1450 MW
						Impacts Total Transfer Capability	1450 MW
						TTC with All Lines In Service	3150 MW
DOLSONAV-ROCKTVRN_345_DART44	Mon 04/27/2020	Sun 05/10/2020	0700 - 1730	NYPA	CENTRAL EAST - VC	2720 MW	255 MW
						Impacts Total Transfer Capability	255 MW
						TTC with All Lines In Service	2975 MW
LEEDS -HURLYAVE_345_301	Mon 04/27/2020	Fri 05/29/2020	0800 - 1600	CHGE	UPNY CONED	4100 MW	1600 MW
						Impacts Total Transfer Capability	1600 MW
						TTC with All Lines In Service	5700 MW
SCH-IMO-NYISO_LIMIT_1600	Fri 05/01/2020	Sat 10/31/2020	0001 - 2359	IESO	SCH - OH - NY	1900 MW	0 MW
						Impacts Total Transfer Capability	0 MW
						TTC with All Lines In Service	1900 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,October 17, 2019 to Saturday ,April 17, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>PANNELL_-CLAY_____345_2</b>				FWD
Mon 05/04/2020	to	Fri 05/08/2020		(Import)
0700	Continuous	1530	WEST CENTRAL	<b>1300 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability 950 MW
				TTC with All Lines In Service 2250 MW
<b>NEPTUNE_-DUFFYAVE_345_NEPTUNE</b>				FWD
Mon 05/04/2020	to	Mon 05/18/2020		(Import)
0800	Continuous	1700	SCH - PJM_NEPTUNE	<b>0 MW</b>
Work scheduled by: PJM				Impacts Total Transfer Capability 660 MW
				TTC with All Lines In Service 660 MW
<b>NEWBRDGE-DUFFYAVE_345_501</b>				FWD
Mon 05/04/2020	to	Mon 05/18/2020		(Import)
0800	Continuous	1700	SCH - PJM_NEPTUNE	<b>0 MW</b>
Work scheduled by: PJM				Impacts Total Transfer Capability 660 MW
				TTC with All Lines In Service 660 MW
<b>NEWBRDGE_345_138_BK_1</b>				FWD
Mon 05/04/2020	to	Mon 05/18/2020		(Import)
0800	Continuous	1700	SCH - PJM_NEPTUNE	<b>375 MW</b>
Work scheduled by: PJM				Impacts Total Transfer Capability 285 MW
				TTC with All Lines In Service 660 MW
<b>NEWBRDGE_345_138_BK_2</b>				FWD
Mon 05/04/2020	to	Mon 05/18/2020		(Import)
0800	Continuous	1700	SCH - PJM_NEPTUNE	<b>375 MW</b>
Work scheduled by: PJM				Impacts Total Transfer Capability 285 MW
				TTC with All Lines In Service 660 MW
<b>PANNELL_-CLAY_____345_1</b>				FWD
Mon 05/11/2020	to	Fri 05/15/2020		(Import)
0700	Continuous	1530	WEST CENTRAL	<b>1300 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability 950 MW
				TTC with All Lines In Service 2250 MW
<b>COOPERS_-DOLSONAV_345_CCDA42</b>				FWD
Mon 05/11/2020	to	Fri 05/29/2020	<b>UPDATED by NYPA 03/21/2019</b>	(Import)
0700	Continuous	1730	CENTRAL EAST - VC	<b>2720 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability 255 MW
				TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,October 17, 2019 to Saturday ,April 17, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>NIAGARA_-ROCHESTR_345_NR2</b>					FWD
Mon 05/18/2020	to	Fri 05/22/2020			(Import)
0500	Continuous	1530			DYSINGER EAST <b>1400 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 1750 MW
					TTC with All Lines In Service 3150 MW
<b>MOSES_-ADIRNDCK_230_MA2</b>					FWD
Mon 06/01/2020	to	Fri 07/31/2020			(Import)
0700	Continuous	1730			MOSES SOUTH <b>2100 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 1050 MW
					TTC with All Lines In Service 3150 MW
<b>NIAGARA_345_230_AT4</b>					REV
Mon 06/29/2020	to	Tue 06/30/2020			(Export)
0500	Continuous	1530			SCH - OH - NY <b>1400 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 300 MW
					TTC with All Lines In Service 1700 MW
<b>SCH-IMO-NYISO_NIAG_CB_3008_W/BB</b>					FWD REV
Mon 07/27/2020	to	Fri 08/07/2020			(Import) (Export)
0500	Continuous	1530			SCH - OH - NY <b>1900 MW 1450 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 0 MW 250 MW
					TTC with All Lines In Service 1900 MW 1700 MW
<b>CHATGUAY-MASSENA_765_7040</b>					FWD
Sat 08/01/2020	to	Sun 08/02/2020	<b>UPDATED</b>	<b>by NYPA</b>	<b>08/08/2019</b>
0500	Continuous	1730			(Import)
Work scheduled by: NYPA					MOSES SOUTH <b>1550 MW</b>
					Impacts Total Transfer Capability 1600 MW
					TTC with All Lines In Service 3150 MW
<b>CHATGUAY-MASSENA_765_7040</b>					FWD REV
Sat 08/01/2020	to	Sun 08/02/2020	<b>UPDATED</b>	<b>by NYPA</b>	<b>08/08/2019</b>
0500	Continuous	1730			(Import) (Export)
Work scheduled by: NYPA					SCH - HQ - NY <b>0 MW 0 MW</b>
					Impacts Total Transfer Capability 1500 MW 1000 MW
					TTC with All Lines In Service 1500 MW 1000 MW
<b>MARCY_765_345_AT1</b>					FWD
Sat 08/01/2020	to	Sun 08/02/2020	<b>UPDATED</b>	<b>by NYPA</b>	<b>08/08/2019</b>
0500	Continuous	1730			(Import)
Work scheduled by: NYPA					MOSES SOUTH <b>1750 MW</b>
					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 3150 MW

**ARR: 19**

# NYISO TRANSFER LIMITATIONS

Thursday ,October 17, 2019 to Saturday ,April 17, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MASSENA -MARCY 765_MSU1</b>						FWD		
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)		
0500	Continuous	1730				CENTRAL EAST - VC	<b>2265 MW</b>	
Work scheduled by: NYPA						Impacts Total Transfer Capability	710 MW	
						TTC with All Lines In Service	2975 MW	
<b>MASSENA -MARCY 765_MSU1</b>						FWD		
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)		
0500	Continuous	1730				MOSES SOUTH	<b>500 MW</b>	
Work scheduled by: NYPA						Impacts Total Transfer Capability	2650 MW	
						TTC with All Lines In Service	3150 MW	
<b>MASSENA -MARCY 765_MSU1</b>						FWD	REV	
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import) (Export)		
0500	Continuous	1730				SCH - HQ - NY	<b>475 MW</b>	<b>1000 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	1025 MW	0 MW
						TTC with All Lines In Service	1500 MW	1000 MW
<b>MASSENA -MARCY 765_MSU1</b>						FWD		
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)		
0500	Continuous	1730				SCH - HQ_CEDARS	<b>90 MW</b>	
Work scheduled by: NYPA						Impacts Total Transfer Capability	100 MW	
						TTC with All Lines In Service	190 MW	
<b>MASSENA -MARCY 765_MSU1 &amp; CHATGUAY-MASSENA 765_7040</b>						FWD		
Sat 08/01/2020	to	Sun 08/02/2020				(Import)		
0500		1730				MOSES SOUTH	<b>500 MW</b>	
Work scheduled by:						Impacts Total Transfer Capability	2650 MW	
						TTC with All Lines In Service	3150 MW	
<b>MOSES -MASSENA 230_MMS1 &amp; MOSES -MASSENA 230_MMS2</b>						FWD	REV	
Sat 08/01/2020	to	Sun 08/02/2020				(Import) (Export)		
0500		1730				SCH - HQ - NY	<b>850 MW</b>	<b>0 MW</b>
Work scheduled by:						Impacts Total Transfer Capability	650 MW	1000 MW
						TTC with All Lines In Service	1500 MW	1000 MW
<b>MOSES -MASSENA 230_MMS1 &amp; MOSES -MASSENA 230_MMS2</b>						FWD		
Sat 08/01/2020	to	Sun 08/02/2020				(Import)		
0500		1730				SCH - HQ_CEDARS	<b>90 MW</b>	
Work scheduled by:						Impacts Total Transfer Capability	100 MW	
						TTC with All Lines In Service	190 MW	

# NYISO TRANSFER LIMITATIONS

Thursday ,October 17, 2019 to Saturday ,April 17, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>STLAWRNC-MOSES 230_L33P &amp; MASSENA -MARCY 765_MSU1</b>				FWD
Sat 08/01/2020	to	Sun 08/02/2020		(Import)
0500		1730	SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by:				Impacts Total Transfer Capability 100 MW
				TTC with All Lines In Service 190 MW
<b>STLAWRNC-MOSES 230_L33P &amp; MOSES -MASSENA 230_MMS1 &amp; MOSES -MASSENA 230_MMS2</b>				FWD
Sat 08/01/2020	to	Sun 08/02/2020		(Import)
0500		1730	SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by:				Impacts Total Transfer Capability 100 MW
				TTC with All Lines In Service 190 MW
<b>MOSES -ADIRNDCK 230_MA2</b>				FWD
Mon 08/03/2020	to	Sun 09/13/2020		(Import)
0700	Continuous	1730	MOSES SOUTH	<b>2100 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability 1050 MW
				TTC with All Lines In Service 3150 MW
<b>FRASANX-COOPERS 345_UCC2-41</b>				FWD
Mon 09/07/2020	to	Fri 10/23/2020	<b>UPDATED by NYPA 03/01/2019</b>	(Import)
0700	Continuous	1730		CENTRAL EAST - VC <b>2500 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability 475 MW
				TTC with All Lines In Service 2975 MW
<b>MARCY -FRASANX 345_UCC2-41</b>				FWD
Mon 09/07/2020	to	Fri 10/23/2020	<b>UPDATED by NYPA 03/01/2019</b>	(Import)
0700	Continuous	1730		CENTRAL EAST - VC <b>2500 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability 475 MW
				TTC with All Lines In Service 2975 MW
<b>MARCY 765_345_AT1</b>				FWD
Mon 09/14/2020	to	Mon 09/14/2020		(Import)
0500	Continuous	1730		MOSES SOUTH <b>1750 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 3150 MW
<b>NIAGARA -KINTIGH 345_NS1-38</b>				FWD
Mon 09/14/2020	to	Thu 09/17/2020		(Import)
0500	Continuous	1530		DYSINGER EAST <b>1400 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability 1750 MW
				TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,October 17, 2019 to Saturday ,April 17, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES -ADIRNDCK\_230\_MA2**

Tue 09/15/2020 to Sat 11/14/2020  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

**NIAGARA -ROCHESTR\_345\_NR2**

Fri 09/18/2020 to Sat 11/14/2020  
0500 Continuous 2330

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

**CLAY -EDIC 345\_1-16**

Mon 09/21/2020 to Fri 09/25/2020  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

**ROSETON -ROCKTVRN\_345\_311**

Mon 09/21/2020 to Fri 10/23/2020  
0800 Continuous 1600

Work scheduled by: CHGE

**UPDATED by CHGE 10/09/2019**

FWD  
(Import)  
UPNY CONED **4400 MW**  
Impacts Total Transfer Capability 1300 MW  
TTC with All Lines In Service 5700 MW

**CLAY -EDIC 345\_2-15**

Mon 09/28/2020 to Fri 10/02/2020  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

**DUNWODIE\_345KV\_3**

Thu 10/01/2020 to Thu 10/01/2020  
0001 Continuous 0030

Work scheduled by: ConEd

**UPDATED by CONED 09/05/2019**

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_5**

Thu 10/01/2020 to Thu 10/01/2020  
0001 Continuous 0030

Work scheduled by: ConEd

**UPDATED by CONED 09/05/2019**

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW



# NYISO TRANSFER LIMITATIONS

Thursday ,October 17, 2019 to Saturday ,April 17, 2021

Seasonal Limits

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE-MOTTHAVN\_345\_71**

Thu 10/01/2020 to Thu 11/05/2020  
0001 Continuous 0300

**UPDATED by CONED 09/05/2019**

Work scheduled by: ConEd

FWD  
(Import)  
**3800 MW**  
SPR/DUN-SOUTH  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**HURLYAVE-ROSETON\_345\_303**

Mon 10/26/2020 to Fri 12/04/2020  
0800 Continuous 1600

**UPDATED by CHGE 10/09/2019**

Work scheduled by: CHGE

FWD  
(Import)  
**4100 MW**  
UPNY CONED  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 5700 MW

**SCH-IMO-NYISO\_LIMIT\_1750**

Sun 11/01/2020 to Fri 04/30/2021  
0001 Continuous 2359

**UPDATED by IESO 05/03/2019**

Work scheduled by: IESO

FWD  
(Import)  
**2050 MW**  
SCH - OH - NY  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 2250 MW

**SCH-NYISO-IMO\_LIMIT\_1600**

Sun 11/01/2020 to Fri 04/30/2021  
0001 Continuous 2359

**UPDATED by IESO 05/03/2019**

Work scheduled by: IESO

REV  
(Export)  
**1900 MW**  
SCH - OH - NY  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 2000 MW

**DUNWODIE\_345KV\_3**

Thu 11/05/2020 to Thu 11/05/2020  
0230 Continuous 0300

**UPDATED by CONED 09/05/2019**

Work scheduled by: ConEd

FWD  
(Import)  
**3800 MW**  
SPR/DUN-SOUTH  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_5**

Thu 11/05/2020 to Thu 11/05/2020  
0230 Continuous 0300

**UPDATED by CONED 09/05/2019**

Work scheduled by: ConEd

FWD  
(Import)  
**3800 MW**  
SPR/DUN-SOUTH  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**CHATGUAY-MASSENA\_765\_7040**

Sun 11/15/2020 to Mon 11/30/2020  
0100 Continuous 1900

Work scheduled by: NYPA

FWD  
(Import)  
**1550 MW**  
MOSES SOUTH  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,October 17, 2019 to Saturday ,April 17, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
<b>CHATGUAY-MASSENA__765_7040</b>			
Sun 11/15/2020	to	Mon 11/30/2020	FWD
0100	Continuous	1900	(Import) (Export)
Work scheduled by: NYPA			SCH - HQ - NY
			<b>0 MW 0 MW</b>
			Impacts Total Transfer Capability
			1500 MW 1000 MW
			TTC with All Lines In Service
			1500 MW 1000 MW
<hr/>			
<b>MARCY__765_345_AT1</b>			FWD
Sun 11/15/2020	to	Mon 11/30/2020	(Import)
0100	Continuous	1900	MOSES SOUTH
Work scheduled by: NYPA			<b>1750 MW</b>
			Impacts Total Transfer Capability
			1400 MW
			TTC with All Lines In Service
			3150 MW
<hr/>			
<b>MARCY__765_345_AT2</b>			FWD
Sun 11/15/2020	to	Mon 11/30/2020	(Import)
0100	Continuous	1900	MOSES SOUTH
Work scheduled by: NYPA			<b>1700 MW</b>
			Impacts Total Transfer Capability
			1450 MW
			TTC with All Lines In Service
			3150 MW
<hr/>			
<b>MASSENA_-MARCY__765_MSU1</b>			FWD
Sun 11/15/2020	to	Mon 11/30/2020	(Import)
0100	Continuous	1900	CENTRAL EAST - VC
Work scheduled by: NYPA			<b>2265 MW</b>
			Impacts Total Transfer Capability
			710 MW
			TTC with All Lines In Service
			2975 MW
<hr/>			
<b>MASSENA_-MARCY__765_MSU1</b>			FWD
Sun 11/15/2020	to	Mon 11/30/2020	(Import)
0100	Continuous	1900	MOSES SOUTH
Work scheduled by: NYPA			<b>500 MW</b>
			Impacts Total Transfer Capability
			2650 MW
			TTC with All Lines In Service
			3150 MW
<hr/>			
<b>MASSENA_-MARCY__765_MSU1</b>			FWD
Sun 11/15/2020	to	Mon 11/30/2020	(Import) (Export)
0100	Continuous	1900	SCH - HQ - NY
Work scheduled by: NYPA			<b>475 MW 1000 MW</b>
			Impacts Total Transfer Capability
			1025 MW 0 MW
			TTC with All Lines In Service
			1500 MW 1000 MW
<hr/>			
<b>MASSENA_-MARCY__765_MSU1</b>			FWD
Sun 11/15/2020	to	Mon 11/30/2020	(Import)
0100	Continuous	1900	SCH - HQ_CEDARS
Work scheduled by: NYPA			<b>90 MW</b>
			Impacts Total Transfer Capability
			109 MW
			TTC with All Lines In Service
			199 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,October 17, 2019 to Saturday ,April 17, 2021

Seasonal Limits

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MASSENA -MARCY 765\_MSU1 & CHATGUAY-MASSENA 765\_7040**

Sun 11/15/2020 to Mon 11/30/2020  
0100 1900

Work scheduled by:

FWD  
(Import)  
MOSES SOUTH **500 MW**  
Impacts Total Transfer Capability 2650 MW  
TTC with All Lines In Service 3150 MW

**MOSES -MASSENA 230\_MMS1 & MOSES -MASSENA 230\_MMS2**

Sun 11/15/2020 to Mon 11/30/2020  
0100 1900

Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - HQ - NY **850 MW 0 MW**  
Impacts Total Transfer Capability 650 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

**MOSES -MASSENA 230\_MMS1 & MOSES -MASSENA 230\_MMS2**

Sun 11/15/2020 to Mon 11/30/2020  
0100 1900

Work scheduled by:

FWD  
(Import)  
SCH - HQ\_CEDARS **90 MW**  
Impacts Total Transfer Capability 109 MW  
TTC with All Lines In Service 199 MW

**STLAWRNC-MOSES 230\_L33P & MASSENA -MARCY 765\_MSU1**

Sun 11/15/2020 to Mon 11/30/2020  
0100 1900

Work scheduled by:

FWD  
(Import)  
SCH - HQ\_CEDARS **90 MW**  
Impacts Total Transfer Capability 109 MW  
TTC with All Lines In Service 199 MW

**STLAWRNC-MOSES 230\_L33P & MOSES -MASSENA 230\_MMS1 & MOSES -MASSENA 230\_MMS2**

Sun 11/15/2020 to Mon 11/30/2020  
0100 1900

Work scheduled by:

FWD  
(Import)  
SCH - HQ\_CEDARS **90 MW**  
Impacts Total Transfer Capability 109 MW  
TTC with All Lines In Service 199 MW

**PLSNTVLE-DUNWODIE\_345\_W89**

Mon 11/16/2020 to Mon 11/16/2020  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1700 MW  
TTC with All Lines In Service 5700 MW

**PLSNTVLE-DUNWODIE\_345\_W89**

Thu 11/26/2020 to Thu 11/26/2020  
0230 Continuous 0300

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1700 MW  
TTC with All Lines In Service 5700 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,October 17, 2019 to Saturday ,April 17, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**MOSES \_\_\_-ADIRNDCK\_230\_MA1**

Tue 12/01/2020 to Mon 05/31/2021  
 0700 Continuous 1300

Work scheduled by: NYPA

FWD  
 (Import)  
**MOSES SOUTH 2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

-----  
**MOTTHAVN-RAINEY \_\_\_345\_Q11**

Mon 03/01/2021 to Tue 04/06/2021  
 0001 Continuous 0700

Work scheduled by: ConEd

FWD  
 (Import)  
**SPR/DUN-SOUTH 3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

-----  
**CLAY \_\_\_-EDIC \_\_\_345\_2-15**

Mon 03/29/2021 to Fri 04/16/2021  
 0800 Continuous 1730

Work scheduled by: NYPA

FWD  
 (Import)  
**OSWEGO EXPORT 4850 MW**  
 Impacts Total Transfer Capability 400 MW  
 TTC with All Lines In Service 5250 MW