

# NYISO TRANSFER LIMITATIONS

Friday ,October 18, 2019 to Sunday ,April 18, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
<b>HUDSONP_-FARRAGUT_345_B3402</b>						
Mon 01/15/2018	to	Fri 05/01/2020	<u>EXTENDED</u>	<u>by CONED</u>	<u>10/08/2019</u>	
0001	Continuous	2359				
Work scheduled by: ConEd					SCH - PJ - NY	<b>2100 MW</b>
					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	2150 MW
						1250 MW
						100 MW
						1350 MW
<b>HUDSONP_-FARRAGUT_345_B3402 &amp; MARION_-FARRAGUT_345_C3403</b>						
Mon 01/15/2018	to	Fri 05/01/2020				
0001		2359				
Work scheduled by:					SCH - PJ - NY	<b>2050 MW</b>
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	2150 MW
						1150 MW
						200 MW
						1350 MW
<b>MARION_-FARRAGUT_345_C3403</b>						
Mon 01/15/2018	to	Fri 05/01/2020	<u>EXTENDED</u>	<u>by CONED</u>	<u>10/08/2019</u>	
0001	Continuous	2359				
Work scheduled by: ConEd					SCH - PJ - NY	<b>2100 MW</b>
					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	2150 MW
						1250 MW
						100 MW
						1350 MW
<b>STLAWRNC-MOSES_230_L33P</b>						
Mon 04/30/2018	to	Fri 12/31/2021	<u>EXT FORCE</u>	<u>by IESO</u>	<u>08/21/2018</u>	
0456	Continuous	2359				
Work scheduled by: IESO					SCH - OH - NY	
					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
<b>BECK_-NIAGARA_345_PA302</b>						
Wed 07/31/2019	to	Tue 11/12/2019	<u>EXTENDED</u>	<u>by IESO</u>	<u>08/29/2019</u>	
0800	Continuous	1700				
Work scheduled by: IESO					SCH - OH - NY	<b>900 MW</b>
					Impacts Total Transfer Capability	1000 MW
					TTC with All Lines In Service	1900 MW
						800 MW
						900 MW
						1700 MW
<b>NIAGARA_-PACKARD_230_61</b>						
Tue 09/03/2019	to	Fri 10/18/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>12/19/2018</u>	
0500	Continuous	1700				
Work scheduled by: NYPA					SCH - OH - NY	
					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
<b>PLSNTVLY_345KV_RNS5</b>						
Sat 09/14/2019	to	Thu 10/17/2019	<u>UPDATED</u>	<u>by CE</u>	<u>10/10/2019</u>	
0001	Continuous	0800				
Work scheduled by: ConEd					UPNY CONED	<b>3800 MW</b>
					Impacts Total Transfer Capability	1900 MW
					TTC with All Lines In Service	5700 MW

# NYISO TRANSFER LIMITATIONS

Friday ,October 18, 2019 to Sunday ,April 18, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>FROST_BR-LONG_MTN_345_352</b>					FWD	
Wed 10/02/2019	to	Fri 10/18/2019	<u>UPDATED</u>	<u>by ISONE</u>	<u>09/30/2019</u>	(Import)
0700	Continuous	1600				1150 MW
Work scheduled by: ISONE					SPR - NE - NY	Impacts Total Transfer Capability 250 MW
					TTC with All Lines In Service	1400 MW
<b>SCH-NE-NYISO_LIMIT_400</b>					FWD	
Wed 10/02/2019	to	Fri 10/18/2019	<u>UPDATED</u>	<u>by ISONE</u>	<u>09/30/2019</u>	(Import)
0700	Continuous	1600				600 MW
Work scheduled by: ISONE					SPR - NE - NY	Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service	1400 MW
<b>DUNWODIE_345KV_4</b>					FWD	
Thu 10/03/2019	to	Fri 10/18/2019	<u>UPDATED</u>	<u>by CE</u>	<u>10/18/2019</u>	(Import)
0001	Continuous	2359				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service	4600 MW
<b>SPRNBK__345KV_RS3 &amp; SPRNBK__345KV_RS4</b>					FWD	
Fri 10/04/2019	to	Wed 10/16/2019				(Import)
0201		2230				3200 MW
Work scheduled by:					SPR/DUN-SOUTH	Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service	4600 MW
<b>SCH-NE-NYISO_LIMIT_300</b>					FWD	
Sat 10/05/2019	to	Fri 10/18/2019	<u>UPDATED</u>	<u>by ISONE</u>	<u>09/30/2019</u>	(Import)
1601	Continuous	1600				500 MW
Work scheduled by: ISONE					SPR - NE - NY	Impacts Total Transfer Capability 900 MW
					TTC with All Lines In Service	1400 MW
<b>SCH-HQ-NYISO_LIMIT_1100</b>					FWD	
Mon 10/07/2019	to	Fri 11/22/2019	<u>EXTENDED</u>	<u>by HQ</u>	<u>10/18/2019</u>	(Import)
0400	Continuous	2300				1100 MW
Work scheduled by: HQ					SPR - HQ - NY	Impacts Total Transfer Capability 400 MW
					TTC with All Lines In Service	1500 MW
<b>LEEDS__ -PLSNTVLY_345_92</b>					FWD	
Sat 10/12/2019	to	Tue 10/15/2019	<u>UPDATED</u>	<u>by CE</u>	<u>10/10/2019</u>	(Import)
0001	Continuous	0200				3800 MW
Work scheduled by: ConEd					UPNY CONED	Impacts Total Transfer Capability 1900 MW
					TTC with All Lines In Service	5700 MW

# NYISO TRANSFER LIMITATIONS

Friday ,October 18, 2019 to Sunday ,April 18, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CHATGUAY-MASSENA__765_7040</b>						FWD	
Sat 10/12/2019	to	Tue 10/22/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/13/2019</u>	(Import)	
0100	Continuous	2000				MOSES SOUTH	<b>1550 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	1600 MW
						TTC with All Lines In Service	3150 MW
<b>CHATGUAY-MASSENA__765_7040</b>						FWD	REV
Sat 10/12/2019	to	Tue 10/22/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/13/2019</u>	(Import)	(Export)
0100	Continuous	2000				SCH - HQ - NY	<b>0 MW    0 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	1500 MW    1000 MW
						TTC with All Lines In Service	1500 MW    1000 MW
<b>MARCY__765_345_AT1</b>						FWD	
Sat 10/12/2019	to	Tue 10/22/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/13/2019</u>	(Import)	
0100	Continuous	2000				MOSES SOUTH	<b>1750 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	1400 MW
						TTC with All Lines In Service	3150 MW
<b>MARCY__765_345_AT2</b>						FWD	
Sat 10/12/2019	to	Tue 10/22/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/13/2019</u>	(Import)	
0100	Continuous	2000				MOSES SOUTH	<b>1700 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	1450 MW
						TTC with All Lines In Service	3150 MW
<b>MASSENA_-MARCY__765_MSU1</b>						FWD	
Sat 10/12/2019	to	Tue 10/22/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/13/2019</u>	(Import)	
0100	Continuous	2000				CENTRAL EAST - VC	<b>2265 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	710 MW
						TTC with All Lines In Service	2975 MW
<b>MASSENA_-MARCY__765_MSU1</b>						FWD	
Sat 10/12/2019	to	Tue 10/22/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/13/2019</u>	(Import)	
0100	Continuous	2000				MOSES SOUTH	<b>500 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	2650 MW
						TTC with All Lines In Service	3150 MW
<b>MASSENA_-MARCY__765_MSU1</b>						FWD	REV
Sat 10/12/2019	to	Tue 10/22/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/13/2019</u>	(Import)	(Export)
0100	Continuous	2000				SCH - HQ - NY	<b>475 MW    1000 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	1025 MW    0 MW
						TTC with All Lines In Service	1500 MW    1000 MW

# NYISO TRANSFER LIMITATIONS

Friday ,October 18, 2019 to Sunday ,April 18, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MASSENA -MARCY 765_MSU1</b>				FWD	
Sat 10/12/2019	to	Tue 10/22/2019	<b>UPDATED by NYPA 10/13/2019</b>	(Import)	
0100	Continuous	2000		SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	190 MW
<b>MASSENA -MARCY 765_MSU1 &amp; CHATGUAY-MASSENA 765_7040</b>				FWD	
Sat 10/12/2019	to	Tue 10/22/2019		(Import)	
0100		2000		MOSES SOUTH	<b>500 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	2650 MW
				TTC with All Lines In Service	3150 MW
<b>MOSES -MASSENA 230_MMS1 &amp; MOSES -MASSENA 230_MMS2</b>				FWD	REV
Sat 10/12/2019	to	Tue 10/22/2019		(Import)	(Export)
0100		2000		SCH - HQ - NY	<b>850 MW 0 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	650 MW 1000 MW
				TTC with All Lines In Service	1500 MW 1000 MW
<b>MOSES -MASSENA 230_MMS1 &amp; MOSES -MASSENA 230_MMS2</b>				FWD	
Sat 10/12/2019	to	Tue 10/22/2019		(Import)	
0100		2000		SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	190 MW
<b>STLAWRNC-MOSES 230_L33P &amp; MASSENA -MARCY 765_MSU1</b>				FWD	
Sat 10/12/2019	to	Tue 10/22/2019		(Import)	
0100		2000		SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	190 MW
<b>STLAWRNC-MOSES 230_L33P &amp; MOSES -MASSENA 230_MMS1 &amp; MOSES -MASSENA 230_MMS2</b>				FWD	
Sat 10/12/2019	to	Tue 10/22/2019		(Import)	
0100		2000		SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	190 MW
<b>CHAT_DC_GC1</b>				FWD	
Sat 10/12/2019	to	Sun 10/13/2019		(Import)	
2000	Continuous	2300		MOSES SOUTH	<b>2850 MW</b>
Work scheduled by: HQ				Impacts Total Transfer Capability	300 MW
				TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Friday ,October 18, 2019 to Sunday ,April 18, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CHAT_DC_GC1</b>			REV
Sat 10/12/2019	to	Sun 10/13/2019	(Export)
2000	Continuous	2300	<b>SCH - HQ - NY</b> <b>500 MW</b>
Work scheduled by: HQ			Impacts Total Transfer Capability 500 MW
			TTC with All Lines In Service 1000 MW
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>			FWD
Sat 10/12/2019	to	Sun 10/13/2019	(Import)
2000		2300	<b>MOSES SOUTH</b> <b>2550 MW</b>
Work scheduled by:			Impacts Total Transfer Capability 600 MW
			TTC with All Lines In Service 3150 MW
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>			FWD REV
Sat 10/12/2019	to	Sun 10/13/2019	(Import) (Export)
2000		2300	<b>SCH - HQ - NY</b> <b>1370 MW</b> <b>0 MW</b>
Work scheduled by:			Impacts Total Transfer Capability 130 MW 1000 MW
			TTC with All Lines In Service 1500 MW 1000 MW
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2 &amp; MOSES -MASSENA 230 MMS1 &amp; MOSES -MASSENA 230 MMS2</b>			FWD
Sat 10/12/2019	to	Sun 10/13/2019	(Import)
2000		2300	<b>MOSES SOUTH</b> <b>1950 MW</b>
Work scheduled by:			Impacts Total Transfer Capability 1200 MW
			TTC with All Lines In Service 3150 MW
<b>CHAT_DC_GC2</b>			FWD
Sat 10/12/2019	to	Sun 10/13/2019	(Import)
2000	Continuous	2300	<b>MOSES SOUTH</b> <b>2850 MW</b>
Work scheduled by: HQ			Impacts Total Transfer Capability 300 MW
			TTC with All Lines In Service 3150 MW
<b>CHAT_DC_GC2</b>			REV
Sat 10/12/2019	to	Sun 10/13/2019	(Export)
2000	Continuous	2300	<b>SCH - HQ - NY</b> <b>500 MW</b>
Work scheduled by: HQ			Impacts Total Transfer Capability 500 MW
			TTC with All Lines In Service 1000 MW
<b>SCH-HQ-NYISO_LIMIT_1150</b>			FWD
Sat 10/12/2019	to	Sun 10/13/2019	(Import)
2000	Continuous	2300	<b>SCH - HQ - NY</b> <b>1150 MW</b>
Work scheduled by: HQ			Impacts Total Transfer Capability 350 MW
			TTC with All Lines In Service 1500 MW

# NYISO TRANSFER LIMITATIONS

Friday ,October 18, 2019 to Sunday ,April 18, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>E13THSTA-FARRAGUT_345_45</b>					FWD	
Sun 10/13/2019	to	Mon 10/14/2019			(Import)	
0001	Continuous	0200		SPR/DUN-SOUTH	<b>3800 MW</b>	
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW	
					TTC with All Lines In Service 4600 MW	
<b>CHAT_DC_GC2</b>					FWD	
Sun 10/13/2019	to	Fri 11/22/2019	<b><u>EXTENDED</u></b>	<b><u>by HQ</u></b>	<b><u>10/18/2019</u></b>	(Import)
2301	Continuous	2300		MOSES SOUTH	<b>2850 MW</b>	
Work scheduled by: HQ					Impacts Total Transfer Capability 300 MW	
					TTC with All Lines In Service 3150 MW	
<b>CHAT_DC_GC2</b>					REV	
Sun 10/13/2019	to	Fri 11/22/2019	<b><u>EXTENDED</u></b>	<b><u>by HQ</u></b>	<b><u>10/18/2019</u></b>	(Export)
2301	Continuous	2300		SCH - HQ - NY	<b>500 MW</b>	
Work scheduled by: HQ					Impacts Total Transfer Capability 500 MW	
					TTC with All Lines In Service 1000 MW	
<b>SHORE_RD_345_138_BK 2</b>					FWD	
Mon 10/14/2019	to	Mon 10/14/2019		<b><u>by LI</u></b>	<b><u>10/16/2019</u></b>	(Import)
0001	Continuous	2359		CONED - LIPA	<b>1350 MW</b>	
Work scheduled by: LI					Impacts Total Transfer Capability 150 MW	
					TTC with All Lines In Service 1500 MW	
<b>SHOR_NPX-SHOREHAM_138_CSC</b>					FWD	REV
Mon 10/14/2019	to	Fri 10/18/2019	<b><u>UPDATED</u></b>	<b><u>by ISONE</u></b>	<b><u>08/09/2019</u></b>	(Import) (Export)
0600	Continuous	1600		SCH - NPX_CSC	<b>0 MW</b>	<b>0 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability 330 MW	330 MW
					TTC with All Lines In Service 330 MW	330 MW
<b>FIVEMILE-STOLLERD_345_29</b>					FWD	
Mon 10/14/2019	to	Fri 10/18/2019	<b><u>UPDATED</u></b>	<b><u>by NGRID</u></b>	<b><u>10/08/2019</u></b>	(Import)
0700	Continuous	1400		SCH - PJ - NY	<b>2100 MW</b>	
Work scheduled by: NYSEG					Impacts Total Transfer Capability 50 MW	
					TTC with All Lines In Service 2150 MW	
<b>MOTTHAVN-RAINEY_345_Q12</b>					FWD	
Mon 10/14/2019	to	Wed 10/16/2019				(Import)
2359	Continuous	2359		SPR/DUN-SOUTH	<b>3800 MW</b>	
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW	
					TTC with All Lines In Service 4600 MW	

# NYISO TRANSFER LIMITATIONS

Friday ,October 18, 2019 to Sunday ,April 18, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**PLSNTVLY-WOOD\_ST\_345\_F30**

Tue 10/15/2019 to Thu 10/17/2019  
 0301 Continuous 0300  
 Work scheduled by: ConEd

**UPDATED by CE 10/10/2019**

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

**LEEDS\_HURLYAVE\_345\_301**

Tue 10/15/2019 to Tue 10/15/2019  
 0800 Continuous 1629  
 Work scheduled by: CHGE

**UPDATED by CHGE 09/05/2019**

FWD  
 (Import)  
 UPNY CONED **4100 MW**  
 Impacts Total Transfer Capability 1600 MW  
 TTC with All Lines In Service 5700 MW

**NEPTUNE\_DUFFYAVE\_345\_NEPTUNE**

Thu 10/17/2019 to Wed 10/23/2019  
 0001 Continuous 2359  
 Work scheduled by: LI

FWD  
 (Import)  
 SCH - PJM\_NEPTUNE **0 MW**  
 Impacts Total Transfer Capability 660 MW  
 TTC with All Lines In Service 660 MW

**NEWBRDGE-DUFFYAVE\_345\_501**

Thu 10/17/2019 to Wed 10/23/2019  
 0001 Continuous 2359  
 Work scheduled by: LI

FWD  
 (Import)  
 SCH - PJM\_NEPTUNE **0 MW**  
 Impacts Total Transfer Capability 660 MW  
 TTC with All Lines In Service 660 MW

**NEWBRDGE\_345\_138\_BK\_1**

Thu 10/17/2019 to Wed 10/23/2019  
 0001 Continuous 2359  
 Work scheduled by: LI

FWD  
 (Import)  
 SCH - PJM\_NEPTUNE **375 MW**  
 Impacts Total Transfer Capability 285 MW  
 TTC with All Lines In Service 660 MW

**NEWBRDGE\_345\_138\_BK\_2**

Thu 10/17/2019 to Wed 10/23/2019  
 0001 Continuous 2359  
 Work scheduled by: LI

FWD  
 (Import)  
 SCH - PJM\_NEPTUNE **375 MW**  
 Impacts Total Transfer Capability 285 MW  
 TTC with All Lines In Service 660 MW

**DUNWODIE\_345KV\_7**

Sat 10/19/2019 to Sat 10/19/2019  
 0001 Continuous 0030  
 Work scheduled by: ConEd

**CANCELLED by ConEd 10/18/2019**

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Friday ,October 18, 2019 to Sunday ,April 18, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>DUNWODIE_345KV_8</b>					FWD	
Sat 10/19/2019	to	Sat 10/19/2019	<b>CANCELLED</b>	<b>by ConEd</b>	<b>10/18/2019</b>	(Import)
0001	Continuous	0030				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>DUNWODIE-MOTTHAVN_345_72</b>					FWD	
Sat 10/19/2019	to	Sun 10/20/2019	<b>CANCELLED</b>	<b>by ConEd</b>	<b>10/18/2019</b>	(Import)
0001	Continuous	0300				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>KINTIGH_-ROCHESTR_345_SRI-39</b>					FWD	
Sat 10/19/2019	to	Tue 10/22/2019	<b>CANCELLED</b>	<b>by RGE</b>	<b>10/17/2019</b>	(Import)
0700	Continuous	1900				DYSINGER EAST <b>1400 MW</b>
Work scheduled by: RGE					Impacts Total Transfer Capability	1750 MW
					TTC with All Lines In Service	3150 MW
<b>DUNWODIE_345KV_7</b>					FWD	
Sun 10/20/2019	to	Sun 10/20/2019	<b>CANCELLED</b>	<b>by ConEd</b>	<b>10/18/2019</b>	(Import)
0230	Continuous	0300				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>DUNWODIE_345KV_8</b>					FWD	
Sun 10/20/2019	to	Sun 10/20/2019	<b>CANCELLED</b>	<b>by ConEd</b>	<b>10/18/2019</b>	(Import)
0230	Continuous	0300				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>SHORE_RD_345_138_BK 2</b>					FWD	
Mon 10/21/2019	to	Mon 10/21/2019		<b>by LI</b>	<b>10/16/2019</b>	(Import)
0001	Continuous	2359				CONED - LIPA <b>1350 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability	150 MW
					TTC with All Lines In Service	1500 MW
<b>HURLYAVE-ROSETON__345_303</b>					FWD	
Mon 10/21/2019	to	Thu 10/31/2019				(Import)
0800	Continuous	1600				UPNY CONED <b>4100 MW</b>
Work scheduled by: CHGE					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	5700 MW



# NYISO TRANSFER LIMITATIONS

Friday ,October 18, 2019 to Sunday ,April 18, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**CRICKVLY-PLSNTVLY\_345\_F84**

Tue 10/22/2019 to Tue 10/22/2019  
 0001 Continuous 2000  
 Work scheduled by: ConEd

SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**CEDARS\_-ROSEMNTB\_115\_2/22**

Tue 10/22/2019 to Tue 10/22/2019  
 0700 Daily(No Weekends) 1700  
 Work scheduled by: NGrid

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	<b>95 MW</b>	<b>40 MW</b>
Impacts Total Transfer Capability	95 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

**DENNISON-ROSEMNTB\_115\_2/22**

Tue 10/22/2019 to Tue 10/22/2019  
 0700 Daily(No Weekends) 1700  
 Work scheduled by: NGrid

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	<b>95 MW</b>	<b>40 MW</b>
Impacts Total Transfer Capability	95 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

**GILBOA\_-N.SCTLND\_345\_GNS-1**

Tue 10/22/2019 to Thu 10/24/2019 **UPDATED by NYPA 10/10/2019**  
 0700 Continuous 1730  
 Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	<b>2520 MW</b>
Impacts Total Transfer Capability	455 MW
TTC with All Lines In Service	2975 MW

**WATRCURE\_345\_230\_BK 1**

Tue 10/22/2019 to Tue 10/22/2019  
 0800 Continuous 1530  
 Work scheduled by: NYSEG

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**SHORE\_RD\_345\_138\_BK 1**

Wed 10/23/2019 to Wed 10/23/2019 **by LI 10/16/2019**  
 0001 Continuous 2359  
 Work scheduled by: LI

	FWD
	(Import)
CONED - LIPA	<b>1350 MW</b>
Impacts Total Transfer Capability	150 MW
TTC with All Lines In Service	1500 MW

**SCH-IMO-NYISO\_LIMIT\_400**

Wed 10/23/2019 to Fri 11/08/2019 **UPDATED by NYISO 10/15/2019**  
 0500 Continuous 1859  
 Work scheduled by: NYPA

	FWD
	(Import)
SCH - OH - NY	<b>700 MW</b>
Impacts Total Transfer Capability	1200 MW
TTC with All Lines In Service	1900 MW

# NYISO TRANSFER LIMITATIONS

Friday ,October 18, 2019 to Sunday ,April 18, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SCH-NYISO-IMO_LIMIT_400</b>					REV	
Wed 10/23/2019	to	Fri 11/08/2019	<u>UPDATED</u>	<u>by NYISO</u>	<u>10/15/2019</u>	(Export)
0500	Continuous	1859				<b>700 MW</b>
Work scheduled by: NYPA					SCH - OH - NY	1000 MW
					Impacts Total Transfer Capability	1700 MW
					TTC with All Lines In Service	
<b>NIAGARA_345_230_AT4</b>					REV	
Wed 10/23/2019	to	Tue 12/17/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/10/2019</u>	(Export)
0500	Continuous	1700				<b>1400 MW</b>
Work scheduled by: NYPA					SCH - OH - NY	300 MW
					Impacts Total Transfer Capability	1700 MW
					TTC with All Lines In Service	
<b>CEDARS_-ROSEMNTA_115_1/11</b>					FWD	REV
Wed 10/23/2019	to	Wed 10/23/2019				(Import) (Export)
0700	Daily(No Weekends)	1700				<b>95 MW 40 MW</b>
Work scheduled by: NGrid					SCH - HQ_CEDARS	95 MW 0 MW
					Impacts Total Transfer Capability	190 MW 40 MW
					TTC with All Lines In Service	
<b>DENNISON-ROSEMNTA_115_1/11</b>					FWD	REV
Wed 10/23/2019	to	Wed 10/23/2019				(Import) (Export)
0700	Daily(No Weekends)	1700				<b>95 MW 40 MW</b>
Work scheduled by: NGrid					SCH - HQ_CEDARS	95 MW 0 MW
					Impacts Total Transfer Capability	190 MW 40 MW
					TTC with All Lines In Service	
<b>EGRDNCTY_345_138_AT1</b>					FWD	REV
Thu 10/24/2019	to	Sun 11/03/2019	<u>UPDATED</u>	<u>by CE</u>	<u>09/12/2019</u>	(Import)
0001	Continuous	0300				<b>1250 MW</b>
Work scheduled by: LI					CONED - LIPA	250 MW
					Impacts Total Transfer Capability	1500 MW
					TTC with All Lines In Service	
<b>EGRDNCTY_345_138_AT2</b>					FWD	REV
Thu 10/24/2019	to	Sun 11/03/2019	<u>UPDATED</u>	<u>by CE</u>	<u>09/12/2019</u>	(Import)
0001	Continuous	0300				<b>1250 MW</b>
Work scheduled by: LI					CONED - LIPA	250 MW
					Impacts Total Transfer Capability	1500 MW
					TTC with All Lines In Service	
<b>SPRNBRK_-EGRDNCTR_345_Y49</b>					FWD	REV
Thu 10/24/2019	to	Sun 11/03/2019	<u>UPDATED</u>	<u>by CE</u>	<u>09/12/2019</u>	(Import)
0001	Continuous	0300				<b>775 MW</b>
Work scheduled by: LI					CONED - LIPA	725 MW
					Impacts Total Transfer Capability	1500 MW
					TTC with All Lines In Service	

# NYISO TRANSFER LIMITATIONS

Friday ,October 18, 2019 to Sunday ,April 18, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>								
<b>GILBOA__-N.SCTLND_345_GNS-1</b>							FWD	
Fri 10/25/2019	to	Fri 10/25/2019	<b>UPDATED</b>	<b>by NYPA</b>	<b>09/19/2019</b>		(Import)	
1630	Continuous	1730				CENTRAL EAST - VC	<b>2520 MW</b>	
Work scheduled by: NYPA						Impacts Total Transfer Capability	455 MW	
						TTC with All Lines In Service	2975 MW	
<hr/>								
<b>NIAGARA_-ROCHESTR_345_NR2</b>							FWD	
Mon 10/28/2019	to	Wed 11/13/2019	<b>CANCELLED</b>	<b>by NYPA</b>	<b>10/16/2019</b>		(Import)	
0500	Continuous	1700				DYSINGER EAST	<b>1400 MW</b>	
Work scheduled by: NYPA						Impacts Total Transfer Capability	1750 MW	
						TTC with All Lines In Service	3150 MW	
<hr/>								
<b>DENNISON-ROSEMNTA_115_1/11</b>							FWD	REV
Mon 10/28/2019	to	Thu 10/31/2019					(Import)	(Export)
0700	Continuous	2015				SCH - HQ_CEDARS	<b>95 MW</b>	<b>40 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	95 MW	0 MW
						TTC with All Lines In Service	190 MW	40 MW
<hr/>								
<b>HOPATCON-RAMAPO___500_5018</b>							FWD	REV
Fri 11/01/2019	to	Tue 11/05/2019					(Import)	(Export)
0001	Continuous	2200				SCH - PJ - NY	<b>1250 MW</b>	<b>1200 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	1350 MW	350 MW
						TTC with All Lines In Service	2600 MW	1550 MW
<hr/>								
<b>HOPATCON-RAMAPO___500_5018</b>							FWD	
Fri 11/01/2019	to	Tue 11/05/2019					(Import)	
0001	Continuous	2200				UPNY CONED	<b>5000 MW</b>	
Work scheduled by: ConEd						Impacts Total Transfer Capability	700 MW	
						TTC with All Lines In Service	5700 MW	
<hr/>								
<b>RAMAPO___345_345_PAR3500</b>							FWD	REV
Fri 11/01/2019	to	Tue 11/05/2019					(Import)	(Export)
0001	Continuous	2200				SCH - PJ - NY	<b>2150 MW</b>	<b>1250 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	450 MW	300 MW
						TTC with All Lines In Service	2600 MW	1550 MW
<hr/>								
<b>RAMAPO___345_345_PAR4500</b>							FWD	REV
Fri 11/01/2019	to	Tue 11/05/2019					(Import)	(Export)
0001	Continuous	2200				SCH - PJ - NY	<b>2150 MW</b>	<b>1250 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	450 MW	300 MW
						TTC with All Lines In Service	2600 MW	1550 MW

# NYISO TRANSFER LIMITATIONS

Friday ,October 18, 2019 to Sunday ,April 18, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>RAMAPO__500_345_BK 1500</b>				FWD	REV
Fri 11/01/2019	to	Tue 11/05/2019		(Import)	(Export)
0001	Continuous	2200		<b>1250 MW</b>	<b>1200 MW</b>
Work scheduled by: ConEd				SCH - PJ - NY	
				Impacts Total Transfer Capability	1350 MW 350 MW
				TTC with All Lines In Service	2600 MW 1550 MW
<b>RAMAPO__500_345_BK 1500</b>				FWD	
Fri 11/01/2019	to	Tue 11/05/2019		(Import)	
0001	Continuous	2200		<b>5000 MW</b>	
Work scheduled by: ConEd				UPNY CONED	
				Impacts Total Transfer Capability	700 MW
				TTC with All Lines In Service	5700 MW
<b>SCH-IMO-NYISO_LIMIT_1750</b>				FWD	
Fri 11/01/2019	to	Thu 04/30/2020	<b>UPDATED by IESO 05/03/2019</b>	(Import)	
0001	Continuous	2359		<b>2050 MW</b>	
Work scheduled by: IESO				SCH - OH - NY	
				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	2250 MW
<b>SCH-NYISO-IMO_LIMIT_1600</b>					REV
Fri 11/01/2019	to	Thu 04/30/2020	<b>UPDATED by IESO 05/03/2019</b>		(Export)
0001	Continuous	2359		<b>1900 MW</b>	
Work scheduled by: IESO				SCH - OH - NY	
				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	2000 MW
<b>VOLNEY__-MARCY__345_19</b>				FWD	
Fri 11/01/2019	to	Fri 11/01/2019		(Import)	
0730	Daily(No Weekends)	1630		<b>2825 MW</b>	
Work scheduled by: NGrid				CENTRAL EAST - VC	
				Impacts Total Transfer Capability	150 MW
				TTC with All Lines In Service	2975 MW
<b>VOLNEY__-MARCY__345_19</b>				FWD	
Fri 11/01/2019	to	Fri 11/01/2019		(Import)	
0730	Daily(No Weekends)	1630		<b>4900 MW</b>	
Work scheduled by: NGrid				OSWEGO EXPORT	
				Impacts Total Transfer Capability	350 MW
				TTC with All Lines In Service	5250 MW
<b>CHAT_DC_GC1</b>				FWD	
Sat 11/02/2019	to	Sat 11/02/2019		(Import)	
0001	Continuous	0200		<b>2850 MW</b>	
Work scheduled by: HQ				MOSES SOUTH	
				Impacts Total Transfer Capability	300 MW
				TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Friday ,October 18, 2019 to Sunday ,April 18, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CHAT_DC_GC1</b>							REV
Sat 11/02/2019	to	Sat 11/02/2019					(Export)
0001	Continuous	0200		SCH - HQ - NY			<b>500 MW</b>
Work scheduled by: HQ				Impacts Total Transfer Capability			500 MW
				TTC with All Lines In Service			1000 MW
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>							FWD
Sat 11/02/2019	to	Sat 11/02/2019					(Import)
0001		0200		MOSES SOUTH			<b>2550 MW</b>
Work scheduled by:				Impacts Total Transfer Capability			600 MW
				TTC with All Lines In Service			3150 MW
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>							FWD
Sat 11/02/2019	to	Sat 11/02/2019					(Import) (Export)
0001		0200		SCH - HQ - NY			<b>1370 MW 0 MW</b>
Work scheduled by:				Impacts Total Transfer Capability			130 MW 1000 MW
				TTC with All Lines In Service			1500 MW 1000 MW
<b>SCH-HQ-NYISO_LIMIT_1150</b>							FWD
Sat 11/02/2019	to	Sat 11/02/2019					(Import)
0001	Continuous	0200		SCH - HQ - NY			<b>1150 MW</b>
Work scheduled by: HQ				Impacts Total Transfer Capability			350 MW
				TTC with All Lines In Service			1500 MW
<b>SHORE_RD_345_138_BK 1</b>							FWD
Mon 11/04/2019	to	Mon 11/04/2019	<b>by LI 10/16/2019</b>				(Import)
0001	Continuous	2359		CONED - LIPA			<b>1350 MW</b>
Work scheduled by: LI				Impacts Total Transfer Capability			150 MW
				TTC with All Lines In Service			1500 MW
<b>NRTH1385-NOR HBR_138_601</b>							FWD
Mon 11/04/2019	to	Fri 11/15/2019					(Import) (Export)
0001	Continuous	2359		SCH - NPX_1385			<b>100 MW 100 MW</b>
Work scheduled by: LI				Impacts Total Transfer Capability			100 MW 100 MW
				TTC with All Lines In Service			200 MW 200 MW
<b>NRTH1385-NOR HBR_138_601 &amp; NRTH1385-NOR HBR_138_602</b>							FWD
Mon 11/04/2019	to	Fri 11/15/2019					(Import) (Export)
0001		2359		SCH - NPX_1385			<b>0 MW 0 MW</b>
Work scheduled by:				Impacts Total Transfer Capability			200 MW 200 MW
				TTC with All Lines In Service			200 MW 200 MW

# NYISO TRANSFER LIMITATIONS

Friday ,October 18, 2019 to Sunday ,April 18, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**NRTH1385-NOR HBR\_\_138\_601 & NRTH1385-NOR HBR\_\_138\_603**

Mon 11/04/2019 to Fri 11/15/2019  
 0001 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

-----  
**NRTH1385-NOR HBR\_\_138\_602**

Mon 11/04/2019 to Fri 11/15/2019  
 0001 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

-----  
**NRTH1385-NOR HBR\_\_138\_602 & NRTH1385-NOR HBR\_\_138\_603**

Mon 11/04/2019 to Fri 11/15/2019  
 0001 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

-----  
**NRTH1385-NOR HBR\_\_138\_603**

Mon 11/04/2019 to Fri 11/15/2019  
 0001 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

-----  
**NRTH1385-NRTHPORT\_138\_NNC**

Mon 11/04/2019 to Fri 11/15/2019  
 0001 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

-----  
**LINDN\_CG-LNDVFT\_\_345\_V-3022**

Mon 11/04/2019 to Thu 11/07/2019  
 0800 Continuous 1500

Work scheduled by: PJM

	FWD	REV
	(Import)	(Export)
SCH - PJM_VFT	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

-----  
**MARCY\_\_-N.SCTLND\_345\_18**

Wed 11/06/2019 to Wed 11/13/2019  
 0500 Continuous 1730

Work scheduled by: NYPA

**UPDATED by NYPA 09/11/2019**

**ARR: 19**

	FWD
	(Import)
CENTRAL EAST - VC	<b>2090 MW</b>
Impacts Total Transfer Capability	885 MW
TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Friday ,October 18, 2019 to Sunday ,April 18, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARCY\_\_\_345KV\_CSC**

Wed 11/06/2019 to Fri 11/22/2019  
0500 Continuous 1730

**UPDATED by NYPA 09/11/2019**

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2925 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

**MARCY\_\_\_765\_345\_AT2**

Wed 11/06/2019 to Fri 11/22/2019  
0500 Continuous 1730

**UPDATED by NYPA 09/11/2019**

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

**HURLYAVE-ROSETON\_\_345\_303**

Wed 11/06/2019 to Fri 12/06/2019  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 5700 MW

**N.SCTLND-LEEDS\_\_\_345\_94**

Wed 11/06/2019 to Thu 11/07/2019  
0830 Continuous 1430

Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

**PLSNTVLE-DUNWODIE\_345\_W89**

Fri 11/08/2019 to Sat 11/09/2019  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1700 MW  
TTC with All Lines In Service 5700 MW

**PLSNTVLY\_345KV\_RNS5**

Mon 11/11/2019 to Mon 11/11/2019  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1900 MW  
TTC with All Lines In Service 5700 MW

**PLSNTVLY-WOOD\_ST\_\_345\_F30**

Mon 11/11/2019 to Tue 11/12/2019  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1700 MW  
TTC with All Lines In Service 5700 MW

# NYISO TRANSFER LIMITATIONS

Friday ,October 18, 2019 to Sunday ,April 18, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>E13THSTA-FARRAGUT_345_45</b>				FWD	
Tue 11/12/2019	to	Tue 11/12/2019		(Import)	
0001	Continuous	0030		SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
<b>PLSNTVLY_345KV_RNS5</b>				FWD	
Tue 11/12/2019	to	Tue 11/12/2019		(Import)	
0130	Continuous	0200		UPNY CONED	<b>3800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	1900 MW
				TTC with All Lines In Service	5700 MW
<b>WATRCURE-OAKDALE_345_31</b>				FWD	REV
Tue 11/12/2019	to	Tue 11/12/2019	<b>UPDATED</b>	<b>by NYSEG</b>	<b>09/13/2019</b>
1300	Continuous	1500		SCH - PJ - NY	<b>2600 MW 1300 MW</b>
Work scheduled by: NYSEG				Impacts Total Transfer Capability	0 MW 250 MW
				TTC with All Lines In Service	2600 MW 1550 MW
<b>PLSNTVLY-WOOD_ST_345_F31</b>				FWD	
Thu 11/14/2019	to	Thu 11/14/2019	<b>UPDATED</b>	<b>by NYISO</b>	<b>09/18/2019</b>
0001	Continuous	2200		UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	1700 MW
				TTC with All Lines In Service	5700 MW
<b>PLSNTVLY_345KV_RNS4</b>				FWD	
Thu 11/14/2019	to	Thu 11/14/2019	<b>UPDATED</b>	<b>by NYISO</b>	<b>09/18/2019</b>
0001	Continuous	2200		UPNY CONED	<b>3800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	1900 MW
				TTC with All Lines In Service	5700 MW
<b>E13THSTA-FARRAGUT_345_45</b>				FWD	
Thu 11/14/2019	to	Thu 11/14/2019		(Import)	
0130	Continuous	0200		SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
<b>W49TH_ST-E13THSTA_345_M54</b>				FWD	
Thu 11/14/2019	to	Thu 11/14/2019		(Import)	
0201	Continuous	0500		SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW



# NYISO TRANSFER LIMITATIONS

Friday ,October 18, 2019 to Sunday ,April 18, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BUCHAN_N-EASTVIEW_345_W93</b>					FWD	
Sun 11/17/2019	to	Mon 11/18/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>09/09/2019</u>	(Import)
0301	Continuous	0300				UPNY CONED <b>4350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 1350 MW	
					TTC with All Lines In Service 5700 MW	
<b>EASTVIEW-SPRNBK__345_W79</b>					FWD	
Sun 11/17/2019	to	Mon 11/18/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>09/09/2019</u>	(Import)
0301	Continuous	0300				UPNY CONED <b>4350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 1350 MW	
					TTC with All Lines In Service 5700 MW	
<b>SCH-NE-NYISO_LIMIT_500</b>					FWD	
Sun 11/17/2019	to	Sun 11/17/2019				(Import)
1100	Continuous	1600				SCH - NE - NY <b>700 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability 700 MW	
					TTC with All Lines In Service 1400 MW	
<b>SCH-NYISO-NE_LIMIT_1200</b>					REV	
Sun 11/17/2019	to	Sun 11/17/2019				(Export)
1100	Continuous	1600				SCH - NE - NY <b>1400 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability 400 MW	
					TTC with All Lines In Service 1800 MW	
<b>SPRNBK__345KV_RNS5</b>					FWD	
Mon 11/18/2019	to	Mon 11/18/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>09/09/2019</u>	(Import)
0301	Continuous	0330				SPR/DUN-SOUTH <b>3200 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 1400 MW	
					TTC with All Lines In Service 4600 MW	
<b>EASTVIEW-SPRNBK__345_W64</b>					FWD	
Mon 11/18/2019	to	Tue 11/19/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>09/09/2019</u>	(Import)
0301	Continuous	0200				UPNY CONED <b>4350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 1350 MW	
					TTC with All Lines In Service 5700 MW	
<b>MILLWOOD-EASTVIEW_345_W99</b>					FWD	
Mon 11/18/2019	to	Tue 11/19/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>09/09/2019</u>	(Import)
0301	Continuous	0200				UPNY CONED <b>4350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 1350 MW	
					TTC with All Lines In Service 5700 MW	

# NYISO TRANSFER LIMITATIONS

Friday ,October 18, 2019 to Sunday ,April 18, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BERKSHIR-ALPS_____345_393</b>			FWD	REV
Mon 11/18/2019	to	Wed 11/27/2019	(Import)	(Export)
0600	Continuous	1700	<b>SCH - NE - NY</b>	<b>1150 MW 1300 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	250 MW 500 MW
			TTC with All Lines In Service	1400 MW 1800 MW
<b>ARR: 78</b>				
<b>BERKSHIR-ALPS_____345_393</b>			FWD	REV
Mon 11/18/2019	to	Wed 11/27/2019	(Import)	(Export)
0600	Continuous	1700	<b>SCH - NPX_1385</b>	<b>100 MW 100 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
<b>ARR: 78</b>				
<b>BERKSHIR-ALPS_____345_393 &amp; BERKSHIR-NORTHFLD_345_312</b>			FWD	REV
Mon 11/18/2019	to	Wed 11/27/2019	(Import)	(Export)
0600		1700	<b>SCH - NE - NY</b>	<b>1150 MW 1300 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	250 MW 500 MW
			TTC with All Lines In Service	1400 MW 1800 MW
<b>ARR: 78</b>				
<b>BERKSHIR-NORTHFLD_345_312</b>			FWD	REV
Mon 11/18/2019	to	Wed 11/27/2019	(Import)	(Export)
0600	Continuous	1700	<b>SCH - NE - NY</b>	<b>1400 MW 1500 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	0 MW 300 MW
			TTC with All Lines In Service	1400 MW 1800 MW
<b>BERKSHIR-NORTHFLD_345_312</b>			FWD	REV
Mon 11/18/2019	to	Wed 11/27/2019	(Import)	(Export)
0600	Continuous	1700	<b>SCH - NPX_1385</b>	<b>100 MW 100 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
<b>SCH-NE-NYISO_LIMIT_800</b>			FWD	
Mon 11/18/2019	to	Wed 11/27/2019	(Import)	
0600	Continuous	1700	<b>SCH - NE - NY</b>	<b>1000 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	400 MW
			TTC with All Lines In Service	1400 MW
<b>SCH-NYISO-NE_LIMIT_500</b>				REV
Mon 11/18/2019	to	Wed 11/27/2019		(Export)
0600	Continuous	1700	<b>SCH - NE - NY</b>	<b>700 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	1100 MW
			TTC with All Lines In Service	1800 MW

# NYISO TRANSFER LIMITATIONS

Friday ,October 18, 2019 to Sunday ,April 18, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SPRNBK__345KV_RNS5</b>				FWD	
Tue 11/19/2019	to	Tue 11/19/2019	<u>UPDATED</u> <u>by CONED</u> <u>09/09/2019</u>	(Import)	
0130	Continuous	0200		SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	4600 MW
<b>EASTVIEW-SPRNBK__345_W64</b>				FWD	
Sat 11/23/2019	to	Sat 11/23/2019		(Import)	
0130	Continuous	0200		UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	1350 MW
				TTC with All Lines In Service	5700 MW
<b>MILLWOOD-EASTVIEW_345_W99</b>				FWD	
Sat 11/23/2019	to	Sat 11/23/2019		(Import)	
0130	Continuous	0200		UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	1350 MW
				TTC with All Lines In Service	5700 MW
<b>SPRNBK__345KV_RNS5</b>				FWD	
Sat 11/23/2019	to	Sat 11/23/2019		(Import)	
0130	Continuous	0200		SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	4600 MW
<b>RAMAPO__-LADENTWN_345_W72</b>				FWD	
Mon 11/25/2019	to	Mon 11/25/2019		(Import)	
0001	Continuous	2200		UPNY CONED	<b>4400 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	1300 MW
				TTC with All Lines In Service	5700 MW
<b>MOSES__-ADIRNDCK_230_MA2</b>				FWD	
Mon 11/25/2019	to	Wed 11/27/2019		(Import)	
0700	Continuous	1500		MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
<b>SHOR_NPX-SHOREHAM_138_CSC</b>				FWD	REV
Mon 12/02/2019	to	Mon 12/02/2019	<u>UPDATED</u> <u>by ISONE</u> <u>10/04/2019</u>	(Import)	(Export)
0700	Continuous	2300		SCH - NPX_CSC	<b>0 MW</b> <b>0 MW</b>
Work scheduled by: LI				Impacts Total Transfer Capability	330 MW 330 MW
				TTC with All Lines In Service	330 MW 330 MW

# NYISO TRANSFER LIMITATIONS

Friday ,October 18, 2019 to Sunday ,April 18, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p><b>MOSES -ADIRNDCK_230_MA2</b></p> <p>Mon 12/02/2019 to Fri 12/06/2019 0700 Continuous 1500</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH <b>2300 MW</b></p> <p>Impacts Total Transfer Capability 850 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p><b>N. SCTLND-ALPS 345_2</b></p> <p>Mon 12/02/2019 to Mon 12/02/2019 0730 Daily(No Weekends) 1630</p> <p>Work scheduled by: NGrid</p>	<p style="text-align: right;">FWD REV (Import) (Export)</p> <p>SCH - NE - NY <b>900 MW 1700 MW</b></p> <p>Impacts Total Transfer Capability 500 MW 100 MW</p> <p>TTC with All Lines In Service 1400 MW 1800 MW</p>
<p><b>N. SCTLND-ALPS 345_2</b></p> <p>Mon 12/02/2019 to Mon 12/02/2019 0730 Daily(No Weekends) 1630</p> <p>Work scheduled by: NGrid</p>	<p style="text-align: right;">FWD REV (Import) (Export)</p> <p>SCH - NPX_1385 <b>100 MW 100 MW</b></p> <p>Impacts Total Transfer Capability 100 MW 100 MW</p> <p>TTC with All Lines In Service 200 MW 200 MW</p>
<p><b>FRASER 345_FRASER SVC</b></p> <p>Mon 12/02/2019 to Fri 12/13/2019 0800 Continuous 1500</p> <p>Work scheduled by: NYSEG</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC <b>2935 MW</b></p> <p>Impacts Total Transfer Capability 40 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p><b>LEEDS 345KV_R94301</b></p> <p>Tue 12/03/2019 to Fri 12/13/2019 <b>UPDATED by NGRID 10/04/2019</b> 0800 Continuous 1500</p> <p>Work scheduled by: NGrid</p>	<p style="text-align: right;">FWD (Import)</p> <p>UPNY CONED <b>3800 MW</b></p> <p>Impacts Total Transfer Capability 1900 MW</p> <p>TTC with All Lines In Service 5700 MW</p>
<p><b>MOSES -ADIRNDCK_230_MA1</b></p> <p>Mon 12/09/2019 to Fri 12/13/2019 0700 Continuous 1500</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH <b>2300 MW</b></p> <p>Impacts Total Transfer Capability 850 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p><b>ROSETON -ROCKTVRN_345_311</b></p> <p>Mon 12/09/2019 to Thu 12/12/2019 0800 Continuous 1600</p> <p>Work scheduled by: CHGE</p>	<p style="text-align: right;">FWD (Import)</p> <p>UPNY CONED <b>4400 MW</b></p> <p>Impacts Total Transfer Capability 1300 MW</p> <p>TTC with All Lines In Service 5700 MW</p>

# NYISO TRANSFER LIMITATIONS

Friday ,October 18, 2019 to Sunday ,April 18, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
<b>SHOR_NPX-SHOREHAM_138_CSC</b>					
Thu 12/12/2019	to	Fri 12/20/2019			
0700	Continuous	1500	SCH - NPX_CSC	<b>0 MW</b>	<b>0 MW</b>
Work scheduled by: ISONE				Impacts Total Transfer Capability	330 MW
				TTC with All Lines In Service	330 MW
<b>MOSES -ADIRNDCK_230_MA2</b>				FWD	
Mon 12/16/2019	to	Mon 12/16/2019		(Import)	
0700	Continuous	1500	MOSES SOUTH	<b>2300 MW</b>	
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
<b>MOSES -ADIRNDCK_230_MA1</b>				FWD	
Tue 12/17/2019	to	Fri 12/20/2019		(Import)	
0700	Continuous	1500	MOSES SOUTH	<b>2300 MW</b>	
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
<b>SCH-NE-NYISO_LIMIT_500</b>				FWD	
Fri 12/20/2019	to	Fri 12/20/2019	<b>UPDATED by ISONE 10/11/2019</b>	(Import)	
0600	Continuous	1600	SCH - NE - NY	<b>700 MW</b>	
Work scheduled by: ISONE				Impacts Total Transfer Capability	700 MW
				TTC with All Lines In Service	1400 MW
<b>SCH-NYISO-NE_LIMIT_1200</b>					REV
Fri 12/20/2019	to	Fri 12/20/2019	<b>UPDATED by ISONE 10/11/2019</b>		(Export)
0600	Continuous	1600	SCH - NE - NY		<b>1400 MW</b>
Work scheduled by: ISONE				Impacts Total Transfer Capability	400 MW
				TTC with All Lines In Service	1800 MW
<b>MOSES -ADIRNDCK_230_MA2</b>				FWD	
Thu 01/02/2020	to	Sun 03/01/2020		(Import)	
0700	Continuous	1530	MOSES SOUTH	<b>2300 MW</b>	
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
<b>LADENTWN-BUCHAN_S_345_Y88</b>				FWD	
Wed 01/15/2020	to	Thu 02/13/2020	<b>11/05/2018</b>	(Import)	
0001	Continuous	2359	UPNY CONED	<b>4800 MW</b>	
Work scheduled by: ORU				Impacts Total Transfer Capability	900 MW
				TTC with All Lines In Service	5700 MW

# NYISO TRANSFER LIMITATIONS

Friday ,October 18, 2019 to Sunday ,April 18, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MOTTHAVN-RAINEY</b> ___ 345_Q11					FWD	
Sun 02/23/2020	to	Sun 03/01/2020			(Import)	
0001	Continuous	0200		SPR/DUN-SOUTH	<b>3800 MW</b>	
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>NIAGARA -PACKARD</b> ___ 230_62					FWD	REV
Fri 02/28/2020	to	Fri 02/28/2020			(Import)	(Export)
0500	Continuous	1530		SCH - OH - NY	<b>1100 MW</b>	<b>950 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	1150 MW 1050 MW
					TTC with All Lines In Service	2250 MW 2000 MW
<b>CHATGUAY-MASSENA</b> ___ 765_7040					FWD	
Mon 03/02/2020	to	Fri 03/06/2020	<b>UPDATED</b>	<b>by NYPA</b>	<b>08/08/2019</b>	
0500	Continuous	1730				
Work scheduled by: NYPA					MOSES SOUTH	<b>1550 MW</b>
					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	3150 MW
<b>CHATGUAY-MASSENA</b> ___ 765_7040					FWD	REV
Mon 03/02/2020	to	Fri 03/06/2020	<b>UPDATED</b>	<b>by NYPA</b>	<b>08/08/2019</b>	
0500	Continuous	1730				
Work scheduled by: NYPA					SCH - HQ - NY	<b>0 MW</b> <b>0 MW</b>
					Impacts Total Transfer Capability	1500 MW 1000 MW
					TTC with All Lines In Service	1500 MW 1000 MW
<b>MARCY</b> ___ 765_345_AT1					FWD	
Mon 03/02/2020	to	Fri 03/06/2020	<b>UPDATED</b>	<b>by NYPA</b>	<b>08/08/2019</b>	
0500	Continuous	1730				
Work scheduled by: NYPA					MOSES SOUTH	<b>1750 MW</b>
					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	3150 MW
<b>MARCY</b> ___ 765_345_AT2					FWD	
Mon 03/02/2020	to	Fri 03/06/2020			(Import)	
0500	Continuous	1730				
Work scheduled by: NYPA					MOSES SOUTH	<b>1700 MW</b>
					Impacts Total Transfer Capability	1450 MW
					TTC with All Lines In Service	3150 MW
<b>MASSENA -MARC</b> ___ 765_MSU1					FWD	
Mon 03/02/2020	to	Fri 03/06/2020	<b>UPDATED</b>	<b>by NYPA</b>	<b>08/08/2019</b>	
0500	Continuous	1730				
Work scheduled by: NYPA					CENTRAL EAST - VC	<b>2265 MW</b>
					Impacts Total Transfer Capability	710 MW
					TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Friday ,October 18, 2019 to Sunday ,April 18, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MASSENA_-MARCY_765_MSU1</b>					FWD	
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)
0500	Continuous	1730				MOSES SOUTH <b>500 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	2650 MW
					TTC with All Lines In Service	3150 MW
<b>MASSENA_-MARCY_765_MSU1</b>					FWD	REV
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import) (Export)
0500	Continuous	1730				SCH - HQ - NY <b>475 MW 1000 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	1025 MW 0 MW
					TTC with All Lines In Service	1500 MW 1000 MW
<b>MASSENA_-MARCY_765_MSU1</b>					FWD	
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)
0500	Continuous	1730				SCH - HQ_CEDARS <b>90 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	109 MW
					TTC with All Lines In Service	199 MW
<b>MASSENA_-MARCY_765_MSU1 &amp; CHATGUAY-MASSENA_765_7040</b>					FWD	
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)
0500		1730				MOSES SOUTH <b>500 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	2650 MW
					TTC with All Lines In Service	3150 MW
<b>MOSES_-MASSENA_230_MMS1 &amp; MOSES_-MASSENA_230_MMS2</b>					FWD	REV
Mon 03/02/2020	to	Fri 03/06/2020				(Import) (Export)
0500		1730				SCH - HQ - NY <b>850 MW 0 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	650 MW 1000 MW
					TTC with All Lines In Service	1500 MW 1000 MW
<b>MOSES_-MASSENA_230_MMS1 &amp; MOSES_-MASSENA_230_MMS2</b>					FWD	
Mon 03/02/2020	to	Fri 03/06/2020				(Import)
0500		1730				SCH - HQ_CEDARS <b>90 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	109 MW
					TTC with All Lines In Service	199 MW
<b>STLAWRNC-MOSES_230_L33P &amp; MASSENA_-MARCY_765_MSU1</b>					FWD	
Mon 03/02/2020	to	Fri 03/06/2020				(Import)
0500		1730				SCH - HQ_CEDARS <b>90 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	109 MW
					TTC with All Lines In Service	199 MW

# NYISO TRANSFER LIMITATIONS

Friday ,October 18, 2019 to Sunday ,April 18, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p><b>STLAWRNC-MOSES__230_L33P &amp; MOSES__-MASSENA_230_MMS1 &amp; MOSES__-MASSENA_230_MMS2</b></p> <p>Mon 03/02/2020 to Fri 03/06/2020 0500 1730</p> <p>Work scheduled by:</p>	<p style="text-align: right;">FWD (Import) <b>90 MW</b></p> <p>SCH - HQ_CEDARS Impacts Total Transfer Capability 109 MW TTC with All Lines In Service 199 MW</p>
<p><b>EASTVIEW-SPRNBK__345_W78</b></p> <p>Fri 03/06/2020 to Sat 03/07/2020 0001 Continuous 0200</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import) <b>4350 MW</b></p> <p>UPNY CONED Impacts Total Transfer Capability 1350 MW TTC with All Lines In Service 5700 MW</p>
<p><b>MILLWOOD-EASTVIEW_345_W85</b></p> <p>Fri 03/06/2020 to Sat 03/07/2020 0001 Continuous 0200</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import) <b>4350 MW</b></p> <p>UPNY CONED Impacts Total Transfer Capability 1350 MW TTC with All Lines In Service 5700 MW</p>
<p><b>SPRNBK__345KV_RNS3</b></p> <p>Fri 03/06/2020 to Sat 03/07/2020 0001 Continuous 0200</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import) <b>3800 MW</b></p> <p>SPR/DUN-SOUTH Impacts Total Transfer Capability 800 MW TTC with All Lines In Service 4600 MW</p>
<p><b>MOSES__-ADIRNDCK_230_MA1</b></p> <p>Sat 03/07/2020 to Fri 05/29/2020 0700 Continuous 1300</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import) <b>2300 MW</b></p> <p>MOSES SOUTH Impacts Total Transfer Capability 850 MW TTC with All Lines In Service 3150 MW</p>
<p><b>VOLNEY__-MARCY__345_19</b></p> <p>Tue 03/10/2020 to Tue 03/10/2020 0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import) <b>2825 MW</b></p> <p>CENTRAL EAST - VC Impacts Total Transfer Capability 150 MW TTC with All Lines In Service 2975 MW</p>
<p><b>VOLNEY__-MARCY__345_19</b></p> <p>Tue 03/10/2020 to Tue 03/10/2020 0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import) <b>4900 MW</b></p> <p>OSWEGO EXPORT Impacts Total Transfer Capability 350 MW TTC with All Lines In Service 5250 MW</p>



# NYISO TRANSFER LIMITATIONS

Friday ,October 18, 2019 to Sunday ,April 18, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>FRASANX-COOPERS__345_UCC2-41</b>			FWD
Wed 03/11/2020	to	Thu 03/12/2020	(Import)
0700	Continuous	1530	<b>CENTRAL EAST - VC</b> <b>2500 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability 475 MW
			TTC with All Lines In Service 2975 MW
<b>MARCY__-FRASANX_345_UCC2-41</b>			FWD
Wed 03/11/2020	to	Thu 03/12/2020	(Import)
0700	Continuous	1530	<b>CENTRAL EAST - VC</b> <b>2500 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability 475 MW
			TTC with All Lines In Service 2975 MW
<b>ROCHESTR-PANNELL__345_RP2</b>			FWD
Sat 03/14/2020	to	Mon 03/23/2020	(Import)
0500	Continuous	1700	<b>DYSINGER EAST</b> <b>2300 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability 850 MW
			TTC with All Lines In Service 3150 MW
<b>MARCY__345KV_CSC</b>			FWD
Mon 03/16/2020	to	Fri 03/27/2020	(Import)
0500	Continuous	1730	<b>CENTRAL EAST - VC</b> <b>2925 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability 50 MW
			TTC with All Lines In Service 2975 MW
<b>ROSETON_-EFISHKIL_345_RFK305</b>			FWD
Mon 03/16/2020	to	Fri 04/03/2020	(Import)
0700	Continuous	1530	<b>UPNY CONED</b> <b>4800 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability 900 MW
			TTC with All Lines In Service 5700 MW
<b>NIAGARA_-KINTIGH__345_NS1-38</b>			FWD
Fri 03/27/2020	to	Fri 03/27/2020	(Import)
0600	Continuous	1530	<b>DYSINGER EAST</b> <b>1700 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability 1450 MW
			TTC with All Lines In Service 3150 MW
<b>BECK__-PACKARD__230_BP76</b>			FWD
Fri 03/27/2020	to	Fri 03/27/2020	(Import) (Export)
0800	Daily(No Weekends)	1600	<b>SCH - OH - NY</b> <b>1700 MW</b> <b>1500 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability 550 MW 500 MW
			TTC with All Lines In Service 2250 MW 2000 MW

# NYISO TRANSFER LIMITATIONS

Friday ,October 18, 2019 to Sunday ,April 18, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MARCY -EDIC 345 UE1-7</b>				FWD	
Tue 03/31/2020	to	Tue 03/31/2020	<b>UPDATED by NYPA 09/24/2019</b>	(Import)	
0700	Continuous	1530		OSWEGO EXPORT	<b>5250 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	0 MW
				TTC with All Lines In Service	5250 MW
<b>ARR: 19&amp;16</b>					
<b>SPRNBRK -W49TH_ST_345 M51</b>				FWD	
Mon 04/06/2020	to	Wed 04/08/2020		(Import)	
0001	Continuous	0200		SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	4600 MW
<b>SPRNBRK 345KV_RNS5</b>				FWD	
Mon 04/06/2020	to	Wed 04/08/2020		(Import)	
0001	Continuous	0200		SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	4600 MW
<b>MARCY -N.SCTLND_345_18</b>				FWD	
Tue 04/07/2020	to	Wed 04/08/2020	<b>UPDATED by NYPA 09/24/2019</b>	(Import)	
0700	Continuous	1530		CENTRAL EAST - VC	<b>2090 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	885 MW
				TTC with All Lines In Service	2975 MW
<b>ARR: 19</b>					
<b>LINDN_CG-LNDVFT 345_V-3022</b>				FWD	REV
Sun 04/12/2020	to	Fri 04/17/2020		(Import)	(Export)
1400	Continuous	1800		SCH - PJM_VFT	<b>0 MW 0 MW</b>
Work scheduled by: PJM				Impacts Total Transfer Capability	315 MW 315 MW
				TTC with All Lines In Service	315 MW 315 MW
<b>PLSNTVLY-EFISHKIL_345_F36</b>				FWD	
Mon 04/13/2020	to	Tue 04/14/2020		(Import)	
0001	Continuous	0200		UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	1700 MW
				TTC with All Lines In Service	5700 MW
<b>FRASER -GILBOA 345_GF5-35</b>				FWD	
Mon 04/13/2020	to	Wed 04/22/2020		(Import)	
0700	Continuous	1730		CENTRAL EAST - VC	<b>2650 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	325 MW
				TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Friday ,October 18, 2019 to Sunday ,April 18, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NIAGARA\_-ROCHESTR\_345\_NR2**

Mon 04/20/2020 to Fri 05/01/2020  
 0500 Continuous 1700  
 Work scheduled by: NYPA

FWD  
 (Import)  
 DYSINGER EAST **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

**DOLSONAV-ROCKTVRN\_345\_DART44**

Mon 04/27/2020 to Sun 05/10/2020 **UPDATED by NYPA 03/21/2019**  
 0700 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2720 MW**  
 Impacts Total Transfer Capability 255 MW  
 TTC with All Lines In Service 2975 MW

**LEEDS\_-HURLYAVE\_345\_301**

Mon 04/27/2020 to Fri 05/29/2020  
 0800 Continuous 1600  
 Work scheduled by: CHGE

FWD  
 (Import)  
 UPNY CONED **4100 MW**  
 Impacts Total Transfer Capability 1600 MW  
 TTC with All Lines In Service 5700 MW

**SCH-IMO-NYISO\_LIMIT\_1600**

Fri 05/01/2020 to Sat 10/31/2020 **UPDATED by IESO 05/03/2019**  
 0001 Continuous 2359  
 Work scheduled by: IESO

FWD  
 (Import)  
 SCH - OH - NY **1900 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 1900 MW

**PANNELL\_-CLAY\_\_\_\_345\_2**

Mon 05/04/2020 to Fri 05/08/2020  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 WEST CENTRAL **1300 MW**  
 Impacts Total Transfer Capability 950 MW  
 TTC with All Lines In Service 2250 MW

**NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE**

Mon 05/04/2020 to Mon 05/18/2020  
 0800 Continuous 1700  
 Work scheduled by: PJM

FWD  
 (Import)  
 SCH - PJM\_NEPTUNE **0 MW**  
 Impacts Total Transfer Capability 660 MW  
 TTC with All Lines In Service 660 MW

**NEWBRDGE-DUFFYAVE\_345\_501**

Mon 05/04/2020 to Mon 05/18/2020  
 0800 Continuous 1700  
 Work scheduled by: PJM

FWD  
 (Import)  
 SCH - PJM\_NEPTUNE **0 MW**  
 Impacts Total Transfer Capability 660 MW  
 TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

Friday ,October 18, 2019 to Sunday ,April 18, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
<b>NEWBRDGE_345_138_BK_1</b>			FWD
Mon 05/04/2020	to	Mon 05/18/2020	(Import)
0800	Continuous	1700	
Work scheduled by: PJM			
		SCH - PJM_NEPTUNE	<b>375 MW</b>
		Impacts Total Transfer Capability	285 MW
		TTC with All Lines In Service	660 MW
<hr/>			
<b>NEWBRDGE_345_138_BK_2</b>			FWD
Mon 05/04/2020	to	Mon 05/18/2020	(Import)
0800	Continuous	1700	
Work scheduled by: PJM			
		SCH - PJM_NEPTUNE	<b>375 MW</b>
		Impacts Total Transfer Capability	285 MW
		TTC with All Lines In Service	660 MW
<hr/>			
<b>PANNELL_-CLAY____345_1</b>			FWD
Mon 05/11/2020	to	Fri 05/15/2020	(Import)
0700	Continuous	1530	
Work scheduled by: NYPA			
		WEST CENTRAL	<b>1300 MW</b>
		Impacts Total Transfer Capability	950 MW
		TTC with All Lines In Service	2250 MW
<hr/>			
<b>COOPERS_-DOLSONAV_345_CCDA42</b>			FWD
Mon 05/11/2020	to	Fri 05/29/2020	(Import)
0700	Continuous	1730	
Work scheduled by: NYPA			
		<b>UPDATED by NYPA 03/21/2019</b>	
		CENTRAL EAST - VC	<b>2720 MW</b>
		Impacts Total Transfer Capability	255 MW
		TTC with All Lines In Service	2975 MW
<hr/>			
<b>NIAGARA_-ROCHESTR_345_NR2</b>			FWD
Mon 05/18/2020	to	Fri 05/22/2020	(Import)
0500	Continuous	1530	
Work scheduled by: NYPA			
		DYSINGER EAST	<b>1400 MW</b>
		Impacts Total Transfer Capability	1750 MW
		TTC with All Lines In Service	3150 MW
<hr/>			
<b>MOSES_-ADIRNDCK_230_MA2</b>			FWD
Mon 06/01/2020	to	Fri 07/31/2020	(Import)
0700	Continuous	1730	
Work scheduled by: NYPA			
		MOSES SOUTH	<b>2100 MW</b>
		Impacts Total Transfer Capability	1050 MW
		TTC with All Lines In Service	3150 MW
<hr/>			
<b>NIAGARA_345_230_AT4</b>			REV
Mon 06/29/2020	to	Tue 06/30/2020	(Export)
0500	Continuous	1530	
Work scheduled by: NYPA			
		SCH - OH - NY	<b>1400 MW</b>
		Impacts Total Transfer Capability	300 MW
		TTC with All Lines In Service	1700 MW

# NYISO TRANSFER LIMITATIONS

Friday ,October 18, 2019 to Sunday ,April 18, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
<b>SCH-IMO-NYISO_NIAG_CB_3008_W/BB</b>							
Mon 07/27/2020	to	Fri 08/07/2020					
0500	Continuous	1530			SCH - OH - NY	<b>1900 MW</b>	<b>1450 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	0 MW 250 MW
						TTC with All Lines In Service	1900 MW 1700 MW
<b>CHATGUAY-MASSENA_765_7040</b>						FWD	
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)	
0500	Continuous	1730			MOSES SOUTH	<b>1550 MW</b>	
Work scheduled by: NYPA						Impacts Total Transfer Capability	1600 MW
						TTC with All Lines In Service	3150 MW
<b>CHATGUAY-MASSENA_765_7040</b>						FWD	REV
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)	(Export)
0500	Continuous	1730			SCH - HQ - NY	<b>0 MW</b>	<b>0 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	1500 MW 1000 MW
						TTC with All Lines In Service	1500 MW 1000 MW
<b>MARCY_765_345_AT1</b>						FWD	
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)	
0500	Continuous	1730			MOSES SOUTH	<b>1750 MW</b>	
Work scheduled by: NYPA						Impacts Total Transfer Capability	1400 MW
						TTC with All Lines In Service	3150 MW
							<b>ARR: 19</b>
<b>MASSENA_-MARCY_765_MSU1</b>						FWD	
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)	
0500	Continuous	1730			CENTRAL EAST - VC	<b>2265 MW</b>	
Work scheduled by: NYPA						Impacts Total Transfer Capability	710 MW
						TTC with All Lines In Service	2975 MW
<b>MASSENA_-MARCY_765_MSU1</b>						FWD	
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)	
0500	Continuous	1730			MOSES SOUTH	<b>500 MW</b>	
Work scheduled by: NYPA						Impacts Total Transfer Capability	2650 MW
						TTC with All Lines In Service	3150 MW
<b>MASSENA_-MARCY_765_MSU1</b>						FWD	REV
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)	(Export)
0500	Continuous	1730			SCH - HQ - NY	<b>475 MW</b>	<b>1000 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	1025 MW 0 MW
						TTC with All Lines In Service	1500 MW 1000 MW

# NYISO TRANSFER LIMITATIONS

Friday ,October 18, 2019 to Sunday ,April 18, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MASSENA -MARCY 765_MSU1</b>				FWD	
Sat 08/01/2020	to	Sun 08/02/2020	<b>UPDATED by NYPA 08/08/2019</b>	(Import)	
0500	Continuous	1730		SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	190 MW
<b>MASSENA -MARCY 765_MSU1 &amp; CHATGUAY-MASSENA 765_7040</b>				FWD	
Sat 08/01/2020	to	Sun 08/02/2020		(Import)	
0500		1730		MOSES SOUTH	<b>500 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	2650 MW
				TTC with All Lines In Service	3150 MW
<b>MOSES -MASSENA 230_MMS1 &amp; MOSES -MASSENA 230_MMS2</b>				FWD	REV
Sat 08/01/2020	to	Sun 08/02/2020		(Import)	(Export)
0500		1730		SCH - HQ - NY	<b>850 MW 0 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	650 MW 1000 MW
				TTC with All Lines In Service	1500 MW 1000 MW
<b>MOSES -MASSENA 230_MMS1 &amp; MOSES -MASSENA 230_MMS2</b>				FWD	
Sat 08/01/2020	to	Sun 08/02/2020		(Import)	
0500		1730		SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	190 MW
<b>STLAWRNC-MOSES 230_L33P &amp; MASSENA -MARCY 765_MSU1</b>				FWD	
Sat 08/01/2020	to	Sun 08/02/2020		(Import)	
0500		1730		SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	190 MW
<b>STLAWRNC-MOSES 230_L33P &amp; MOSES -MASSENA 230_MMS1 &amp; MOSES -MASSENA 230_MMS2</b>				FWD	
Sat 08/01/2020	to	Sun 08/02/2020		(Import)	
0500		1730		SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	190 MW
<b>MOSES -ADIRNDCK 230_MA2</b>				FWD	
Mon 08/03/2020	to	Sun 09/13/2020		(Import)	
0700	Continuous	1730		MOSES SOUTH	<b>2100 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	1050 MW
				TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Friday ,October 18, 2019 to Sunday ,April 18, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**FRASANX-COOPERS\_\_345\_UCC2-41**

Mon 09/07/2020 to Fri 10/23/2020  
0700 Continuous 1730

**UPDATED by NYPA 03/01/2019**

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

**MARCY\_\_-FRASANX\_345\_UCC2-41**

Mon 09/07/2020 to Fri 10/23/2020  
0700 Continuous 1730

**UPDATED by NYPA 03/01/2019**

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

**MARCY\_\_765\_345\_AT1**

Mon 09/14/2020 to Mon 09/14/2020  
0500 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
MOSES SOUTH **1750 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 3150 MW

**NIAGARA\_-KINTIGH\_\_345\_NS1-38**

Mon 09/14/2020 to Thu 09/17/2020  
0500 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

**MOSES\_\_-ADIRNDCK\_230\_MA2**

Tue 09/15/2020 to Sat 11/14/2020  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

**NIAGARA\_-ROCHESTR\_345\_NR2**

Fri 09/18/2020 to Sat 11/14/2020  
0500 Continuous 2330

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

**CLAY\_\_-EDIC\_\_345\_1-16**

Mon 09/21/2020 to Fri 09/25/2020  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

# NYISO TRANSFER LIMITATIONS

Friday ,October 18, 2019 to Sunday ,April 18, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>ROSETON_-ROCKTVRN_345_311</b>						FWD
Mon 09/21/2020	to	Fri 10/23/2020	<u>UPDATED</u>	<u>by CHGE</u>	<u>10/09/2019</u>	(Import)
0800	Continuous	1600				UPNY CONED <b>4400 MW</b>
Work scheduled by: CHGE						Impacts Total Transfer Capability 1300 MW
						TTC with All Lines In Service 5700 MW
<b>CLAY_-EDIC_345_2-15</b>						FWD
Mon 09/28/2020	to	Fri 10/02/2020				(Import)
0700	Continuous	1530				OSWEGO EXPORT <b>4850 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability 400 MW
						TTC with All Lines In Service 5250 MW
<b>DUNWODIE_345KV_3</b>						FWD
Thu 10/01/2020	to	Thu 10/01/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>09/05/2019</u>	(Import)
0001	Continuous	0030				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
<b>DUNWODIE_345KV_5</b>						FWD
Thu 10/01/2020	to	Thu 10/01/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>09/05/2019</u>	(Import)
0001	Continuous	0030				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
<b>DUNWODIE-MOTTHAVN_345_71</b>						FWD
Thu 10/01/2020	to	Thu 11/05/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>09/05/2019</u>	(Import)
0001	Continuous	0300				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
<b>HURLYAVE-ROSETON_345_303</b>						FWD
Mon 10/26/2020	to	Fri 12/04/2020	<u>UPDATED</u>	<u>by CHGE</u>	<u>10/09/2019</u>	(Import)
0800	Continuous	1600				UPNY CONED <b>4100 MW</b>
Work scheduled by: CHGE						Impacts Total Transfer Capability 1600 MW
						TTC with All Lines In Service 5700 MW
<b>SCH-IMO-NYISO_LIMIT_1750</b>						FWD
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Import)
0001	Continuous	2359				SCH - OH - NY <b>2050 MW</b>
Work scheduled by: IESO						Impacts Total Transfer Capability 200 MW
						TTC with All Lines In Service 2250 MW



# NYISO TRANSFER LIMITATIONS

Friday ,October 18, 2019 to Sunday ,April 18, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SCH-NYISO-IMO_LIMIT_1600</b>						REV
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Export)
0001	Continuous	2359				<b>1900 MW</b>
Work scheduled by: IESO						100 MW
						2000 MW
<b>DUNWODIE_345KV_3</b>						FWD
Thu 11/05/2020	to	Thu 11/05/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>09/05/2019</u>	(Import)
0230	Continuous	0300				<b>3800 MW</b>
Work scheduled by: ConEd						800 MW
						4600 MW
<b>DUNWODIE_345KV_5</b>						FWD
Thu 11/05/2020	to	Thu 11/05/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>09/05/2019</u>	(Import)
0230	Continuous	0300				<b>3800 MW</b>
Work scheduled by: ConEd						800 MW
						4600 MW
<b>CHATGUAY-MASSENA__765_7040</b>						FWD
Sun 11/15/2020	to	Mon 11/30/2020				(Import)
0100	Continuous	1900				<b>1550 MW</b>
Work scheduled by: NYPA						1600 MW
						3150 MW
<b>CHATGUAY-MASSENA__765_7040</b>						FWD
Sun 11/15/2020	to	Mon 11/30/2020				(Import) (Export)
0100	Continuous	1900				<b>0 MW</b> <b>0 MW</b>
Work scheduled by: NYPA						1500 MW
						1000 MW
						1500 MW
						1000 MW
<b>MARCY__765_345_AT1</b>						FWD
Sun 11/15/2020	to	Mon 11/30/2020				(Import)
0100	Continuous	1900				<b>1750 MW</b>
Work scheduled by: NYPA						1400 MW
						3150 MW
<b>MARCY__765_345_AT2</b>						FWD
Sun 11/15/2020	to	Mon 11/30/2020				(Import)
0100	Continuous	1900				<b>1700 MW</b>
Work scheduled by: NYPA						1450 MW
						3150 MW

**ARR: 19**

**ARR: 19**

# NYISO TRANSFER LIMITATIONS

Friday ,October 18, 2019 to Sunday ,April 18, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MASSENA -MARCY 765_MSU1</b>			FWD	
Sun 11/15/2020	to	Mon 11/30/2020	(Import)	
0100	Continuous	1900	CENTRAL EAST - VC	<b>2265 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	710 MW
			TTC with All Lines In Service	2975 MW
<b>MASSENA -MARCY 765_MSU1</b>			FWD	
Sun 11/15/2020	to	Mon 11/30/2020	(Import)	
0100	Continuous	1900	MOSES SOUTH	<b>500 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	2650 MW
			TTC with All Lines In Service	3150 MW
<b>MASSENA -MARCY 765_MSU1</b>			FWD	REV
Sun 11/15/2020	to	Mon 11/30/2020	(Import)	(Export)
0100	Continuous	1900	SCH - HQ - NY	<b>475 MW 1000 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	1025 MW 0 MW
			TTC with All Lines In Service	1500 MW 1000 MW
<b>MASSENA -MARCY 765_MSU1</b>			FWD	
Sun 11/15/2020	to	Mon 11/30/2020	(Import)	
0100	Continuous	1900	SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	109 MW
			TTC with All Lines In Service	199 MW
<b>MASSENA -MARCY 765_MSU1 &amp; CHATGUAY-MASSENA 765_7040</b>			FWD	
Sun 11/15/2020	to	Mon 11/30/2020	(Import)	
0100		1900	MOSES SOUTH	<b>500 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	2650 MW
			TTC with All Lines In Service	3150 MW
<b>MOSES -MASSENA 230_MMS1 &amp; MOSES -MASSENA 230_MMS2</b>			FWD	REV
Sun 11/15/2020	to	Mon 11/30/2020	(Import)	(Export)
0100		1900	SCH - HQ - NY	<b>850 MW 0 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	650 MW 1000 MW
			TTC with All Lines In Service	1500 MW 1000 MW
<b>MOSES -MASSENA 230_MMS1 &amp; MOSES -MASSENA 230_MMS2</b>			FWD	
Sun 11/15/2020	to	Mon 11/30/2020	(Import)	
0100		1900	SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	109 MW
			TTC with All Lines In Service	199 MW

# NYISO TRANSFER LIMITATIONS

Friday ,October 18, 2019 to Sunday ,April 18, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>STLAWRNC-MOSES___230_L33P &amp; MASSENA_-MARCY___765_MSU1</p> <p>Sun 11/15/2020 to Mon 11/30/2020</p> <p style="padding-left: 40px;">0100 1900</p> <p>Work scheduled by:</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>SCH - HQ_CEDARS <b>90 MW</b></p> <p>Impacts Total Transfer Capability 109 MW</p> <p>TTC with All Lines In Service 199 MW</p>
<p>STLAWRNC-MOSES___230_L33P &amp; MOSES___-MASSENA_230_MMS1 &amp; MOSES___-MASSENA_230_MMS2</p> <p>Sun 11/15/2020 to Mon 11/30/2020</p> <p style="padding-left: 40px;">0100 1900</p> <p>Work scheduled by:</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>SCH - HQ_CEDARS <b>90 MW</b></p> <p>Impacts Total Transfer Capability 109 MW</p> <p>TTC with All Lines In Service 199 MW</p>
<p>PLSNTVLE-DUNWODIE_345_W89</p> <p>Mon 11/16/2020 to Mon 11/16/2020</p> <p style="padding-left: 40px;">0001 Continuous 0030</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>UPNY CONED <b>4000 MW</b></p> <p>Impacts Total Transfer Capability 1700 MW</p> <p>TTC with All Lines In Service 5700 MW</p>
<p>PLSNTVLE-DUNWODIE_345_W89</p> <p>Thu 11/26/2020 to Thu 11/26/2020</p> <p style="padding-left: 40px;">0230 Continuous 0300</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>UPNY CONED <b>4000 MW</b></p> <p>Impacts Total Transfer Capability 1700 MW</p> <p>TTC with All Lines In Service 5700 MW</p>
<p>MOSES___-ADIRNDCK_230_MA1</p> <p>Tue 12/01/2020 to Mon 05/31/2021</p> <p style="padding-left: 40px;">0700 Continuous 1300</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>MOSES SOUTH <b>2300 MW</b></p> <p>Impacts Total Transfer Capability 850 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>MOTTHAVN-RAINEY___345_Q11</p> <p>Mon 03/01/2021 to Tue 04/06/2021</p> <p style="padding-left: 40px;">0001 Continuous 0700</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>SPR/DUN-SOUTH <b>3800 MW</b></p> <p>Impacts Total Transfer Capability 800 MW</p> <p>TTC with All Lines In Service 4600 MW</p>
<p>CLAY___-EDIC___345_2-15</p> <p>Mon 03/29/2021 to Fri 04/16/2021</p> <p style="padding-left: 40px;">0800 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>OSWEGO EXPORT <b>4850 MW</b></p> <p>Impacts Total Transfer Capability 400 MW</p> <p>TTC with All Lines In Service 5250 MW</p>