

NYISO TRANSFER LIMITATIONS

Monday ,December 09, 2019 to Wednesday,June 09, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Fri 05/01/2020 EXTENDED by CONED 10/08/2019
 0001 Continuous 2359
 Work scheduled by: ConEd

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Fri 05/01/2020
 0001 2359
 Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2550 MW	1600 MW
Impacts Total Transfer Capability	350 MW	250 MW
TTC with All Lines In Service	2900 MW	1850 MW

MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Fri 05/01/2020 EXTENDED by CONED 10/08/2019
 0001 Continuous 2359
 Work scheduled by: ConEd

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

STLAWRNC-MOSES_230_L33P

Mon 04/30/2018 to Fri 12/31/2021 EXT FORCE by IESO 08/21/2018
 0456 Continuous 2359
 Work scheduled by: IESO

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

NIAGARA_345_230_AT4

Wed 10/23/2019 to Tue 12/17/2019 UPDATED by NYPA 09/10/2019
 0500 Continuous 1700
 Work scheduled by: NYPA

		REV
		(Export)
SCH - OH - NY		1750 MW
Impacts Total Transfer Capability		150 MW
TTC with All Lines In Service		1900 MW

SCH-IMO-NYISO_LIMIT_1750

Fri 11/01/2019 to Thu 04/30/2020 UPDATED by IESO 05/03/2019
 0001 Continuous 2359
 Work scheduled by: IESO

	FWD
	(Import)
SCH - OH - NY	2050 MW
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	2050 MW

SCH-NYISO-IMO_LIMIT_1600

Fri 11/01/2019 to Thu 04/30/2020 UPDATED by IESO 05/03/2019
 0001 Continuous 2359
 Work scheduled by: IESO

	REV
	(Export)
SCH - OH - NY	1900 MW
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	1900 MW

NYISO TRANSFER LIMITATIONS

Monday ,December 09, 2019 to Wednesday,June 09, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-NE_LIMIT_1500						REV
Fri 11/01/2019	to	Thu 04/30/2020				(Export)
0001	Continuous	2359			SCH - NE - NY	1700 MW
Work scheduled by: NYISO						Impacts Total Transfer Capability
						TTC with All Lines In Service
						1700 MW
HURLYAVE-ROSETON_345_303						FWD
Wed 11/06/2019	to	Fri 12/06/2019	<u>UPDATED</u>	<u>by CH</u>	<u>10/21/2019</u>	(Import)
0800	Continuous	1600			UPNY CONED	4100 MW
Work scheduled by: CHGE						Impacts Total Transfer Capability
						TTC with All Lines In Service
						5700 MW
SCH-IMO-NYISO_LIMIT_1400						FWD
Tue 11/12/2019	to	Tue 12/17/2019	<u>EXTENDED</u>	<u>by IESO</u>	<u>11/27/2019</u>	(Import)
0501	Continuous	1700			SCH - OH - NY	1700 MW
Work scheduled by: IESO						Impacts Total Transfer Capability
						TTC with All Lines In Service
						2050 MW
SCH-NYISO-IMO_LIMIT_1400						REV
Tue 11/12/2019	to	Tue 12/17/2019	<u>EXTENDED</u>	<u>by IESO</u>	<u>11/27/2019</u>	(Export)
0501	Continuous	1700			SCH - OH - NY	1700 MW
Work scheduled by: IESO						Impacts Total Transfer Capability
						TTC with All Lines In Service
						1900 MW
OSWEGO_COMPLEX_AVR_O/S						FWD
Mon 11/18/2019	to	Mon 12/23/2019	<u>EXT FORCE</u>	<u>by GEN</u>	<u>12/04/2019</u>	(Import)
0221	Continuous	1200			CENTRAL EAST - VC	2870 MW
Work scheduled by: Gen						Impacts Total Transfer Capability
						TTC with All Lines In Service
						2975 MW
MOSES -ADIRNDCK_230_MA2						FWD
Mon 12/02/2019	to	Fri 12/06/2019				(Import)
0700	Continuous	1730			MOSES SOUTH	2300 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability
						TTC with All Lines In Service
						3150 MW
DUNWODIE_345KV_6						FWD
Tue 12/03/2019	to	Tue 12/31/2019	<u>FORCED</u>	<u>by CONED</u>	<u>12/03/2019</u>	(Import)
0048	Continuous	2359			SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability
						TTC with All Lines In Service
						4600 MW

NYISO TRANSFER LIMITATIONS

Monday ,December 09, 2019 to Wednesday,June 09, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_8					FWD	
Tue 12/03/2019	to	Tue 12/31/2019	FORCED	by CONED	12/03/2019	(Import)
0048	Continuous	2359				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service	4600 MW
PLSNTVLE-DUNWODIE_345_W90					FWD	
Tue 12/03/2019	to	Tue 12/31/2019	FORCED	by CONED	12/03/2019	(Import)
0107	Continuous	2359				4000 MW
Work scheduled by: ConEd					UPNY CONED	Impacts Total Transfer Capability 1700 MW
					TTC with All Lines In Service	5700 MW
SCH-NE-NYISO_LIMIT_500					FWD	
Tue 12/03/2019	to	Fri 12/20/2019	UPDATED	by ISONE	10/11/2019	(Import)
0700	Continuous	1600				700 MW
Work scheduled by: ISONE					SCH - NE - NY	Impacts Total Transfer Capability 700 MW
					TTC with All Lines In Service	1400 MW
SCH-NYISO-NE_LIMIT_1200					REV	
Tue 12/03/2019	to	Fri 12/20/2019	UPDATED	by ISONE	10/11/2019	(Export)
0700	Continuous	1600				1400 MW
Work scheduled by: ISONE					SCH - NE - NY	Impacts Total Transfer Capability 300 MW
					TTC with All Lines In Service	1700 MW
ALCOA_R8105_TIE_B					FWD	
Wed 12/04/2019	to	Wed 12/04/2019	UPDATED	by NGRID	11/25/2019	(Import)
0730	Continuous	1700				3100 MW
Work scheduled by: NGrid					MOSES SOUTH	Impacts Total Transfer Capability 50 MW
					TTC with All Lines In Service	3150 MW
W49TH_ST_345KV_6					FWD	
Wed 12/04/2019	to	Wed 12/04/2019	UPDATED	by CE	12/03/2019	(Import)
2230	Continuous	2300				330 MW
Work scheduled by: ConEd					SCH - PJM_HTP	Impacts Total Transfer Capability 330 MW
					TTC with All Lines In Service	660 MW
W49TH_ST_345KV_8					FWD	
Wed 12/04/2019	to	Wed 12/04/2019	UPDATED	by CE	12/03/2019	(Import)
2230	Continuous	2300				330 MW
Work scheduled by: ConEd					SCH - PJM_HTP	Impacts Total Transfer Capability 330 MW
					TTC with All Lines In Service	660 MW

NYISO TRANSFER LIMITATIONS

Monday ,December 09, 2019 to Wednesday,June 09, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

N. SCTLND-ALPS_____345_2					FWD	
Fri 12/06/2019	to	Fri 12/06/2019	UPDATED	by NGRID	12/04/2019	(Import)
0730	Continuous	1630				900 MW
Work scheduled by: NGrid					SCH - NE - NY	Impacts Total Transfer Capability 500 MW
					TTC with All Lines In Service	1400 MW
N. SCTLND-ALPS_____345_2					FWD	REV
Fri 12/06/2019	to	Fri 12/06/2019	UPDATED	by NGRID	12/04/2019	(Import) (Export)
0730	Continuous	1630				100 MW 100 MW
Work scheduled by: NGrid					SCH - NPX_1385	Impacts Total Transfer Capability 100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW
SCH-NE-NYISO_LIMIT_300					FWD	
Fri 12/06/2019	to	Fri 12/06/2019	UPDATED	by NGRID	12/04/2019	(Import)
0730	Continuous	1630				500 MW
Work scheduled by: NGrid					SCH - NE - NY	Impacts Total Transfer Capability 900 MW
					TTC with All Lines In Service	1400 MW
SCH-NYISO-NE_LIMIT_400						REV
Fri 12/06/2019	to	Fri 12/06/2019	UPDATED	by NGRID	12/04/2019	(Export)
0730	Continuous	1630				600 MW
Work scheduled by: NGrid					SCH - NE - NY	Impacts Total Transfer Capability 1100 MW
					TTC with All Lines In Service	1700 MW
NIAGARA_-PACKARD__230_62					FWD	REV
Fri 12/06/2019	to	Fri 12/06/2019	UPDATED	by IESO	11/27/2019	(Import) (Export)
0800	Daily(No Weekends)	1530				900 MW 1850 MW
Work scheduled by: NGrid					SCH - OH - NY	Impacts Total Transfer Capability 1150 MW 50 MW
					TTC with All Lines In Service	2050 MW 1900 MW
SCH-IMO-NYISO_LIMIT_300					FWD	
Fri 12/06/2019	to	Fri 12/06/2019	UPDATED	by IESO	11/27/2019	(Import)
0800	Daily(No Weekends)	1530				600 MW
Work scheduled by: NGrid					SCH - OH - NY	Impacts Total Transfer Capability 1450 MW
					TTC with All Lines In Service	2050 MW
SCH-HQ-NYISO_LIMIT_1150					FWD	
Sat 12/07/2019	to	Sat 12/07/2019	CANCELLED	by HQ	12/07/2019	(Import)
0001	Continuous	0200				1150 MW
Work scheduled by: HQ					SCH - HQ - NY	Impacts Total Transfer Capability 350 MW
					TTC with All Lines In Service	1500 MW

NYISO TRANSFER LIMITATIONS

Monday ,December 09, 2019 to Wednesday,June 09, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_5					FWD	
Mon 12/09/2019	to	Thu 12/12/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>12/09/2019</u>	(Import)
0001	Continuous	0300				315 MW
Work scheduled by: ConEd					SCH - PJM_HTP	Impacts Total Transfer Capability
						345 MW
					TTC with All Lines In Service	660 MW
W49TH_ST_345KV_7					FWD	
Mon 12/09/2019	to	Sat 12/14/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>12/09/2019</u>	(Import)
0001	Continuous	0200				315 MW
Work scheduled by: ConEd					SCH - PJM_HTP	Impacts Total Transfer Capability
						345 MW
					TTC with All Lines In Service	660 MW
SCH-IMO-NYISO_LIMIT_950					FWD	
Mon 12/09/2019	to	Wed 12/11/2019				(Import)
0500	Continuous	0459				1250 MW
Work scheduled by: NYPA					SCH - OH - NY	Impacts Total Transfer Capability
						800 MW
					TTC with All Lines In Service	2050 MW
MOSES__-ADIRNDCK_230_MA1					FWD	
Mon 12/09/2019	to	Fri 12/13/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>12/03/2019</u>	(Import)
0700	Continuous	1530				2300 MW
Work scheduled by: NYPA					MOSES SOUTH	Impacts Total Transfer Capability
						850 MW
					TTC with All Lines In Service	3150 MW
ROSETON_-ROCKTVRN_345_311					FWD	
Mon 12/09/2019	to	Thu 12/12/2019				(Import)
0800	Continuous	1600				4400 MW
Work scheduled by: CHGE					UPNY CONED	Impacts Total Transfer Capability
						1300 MW
					TTC with All Lines In Service	5700 MW
INDPDNCE-SCRIBA__345_25					FWD	
Tue 12/10/2019	to	Tue 12/10/2019				(Import)
0830	Continuous	1600				5250 MW
Work scheduled by: NGrid					OSWEGO EXPORT	Impacts Total Transfer Capability
						0 MW
					TTC with All Lines In Service	5250 MW
SHOR_NPX-SHOREHAM_138_CSC					FWD	REV
Thu 12/12/2019	to	Fri 12/20/2019				(Import) (Export)
0700	Continuous	1500				0 MW 0 MW
Work scheduled by: ISONE					SCH - NPX_CSC	Impacts Total Transfer Capability
						330 MW 330 MW
					TTC with All Lines In Service	330 MW 330 MW

NYISO TRANSFER LIMITATIONS

Monday ,December 09, 2019 to Wednesday,June 09, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO-NYISO_LIMIT_950					FWD		
Thu 12/12/2019	to	Fri 12/13/2019			(Import)		
2001	Continuous	1900			SCH - OH - NY	1250 MW	
Work scheduled by: NYPA					Impacts Total Transfer Capability	800 MW	
					TTC with All Lines In Service	2050 MW	
PIERCBRK-FIVEMILE_345_37					FWD		
Fri 12/13/2019	to	Fri 12/13/2019	<u>UPDATED</u>	<u>by NGRID</u> <u>12/05/2019</u>	(Import)		
0800	Daily(No Weekends)	1530			SCH - PJ - NY	2400 MW	
Work scheduled by: NGrid					Impacts Total Transfer Capability	500 MW	
					TTC with All Lines In Service	2900 MW	
SCH-IMO-NYISO_LIMIT_600					FWD		
Sat 12/14/2019	to	Sun 12/15/2019	<u>UPDATED</u>	<u>by NYPA</u> <u>12/09/2019</u>	(Import)		
0500	Continuous	1900			SCH - OH - NY	900 MW	
Work scheduled by: NYPA					Impacts Total Transfer Capability	1150 MW	
					TTC with All Lines In Service	2050 MW	
W49TH_ST-E13THSTA_345_M54					FWD		
Sun 12/15/2019	to	Wed 12/18/2019			(Import)		
0001	Continuous	0200			SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW	
					TTC with All Lines In Service	4600 MW	
WATRCURE-OAKDALE_345_31					FWD		
Sun 12/15/2019	to	Sat 12/21/2019			(Import)		
0800	Continuous	1700			SCH - PJ - NY	2750 MW	
Work scheduled by: NYSEG					Impacts Total Transfer Capability	150 MW	
					TTC with All Lines In Service	2900 MW	
NRTH1385-NOR HBR_138_601					FWD	REV	
Mon 12/16/2019	to	Mon 12/23/2019	<u>CANCELLED</u>	<u>by LI</u> <u>12/04/2019</u>	(Import)	(Export)	
0001	Continuous	2359			SCH - NPX_1385	100 MW	100 MW
Work scheduled by: LI					Impacts Total Transfer Capability	100 MW	100 MW
					TTC with All Lines In Service	200 MW	200 MW
NRTH1385-NOR HBR_138_602					FWD	REV	
Mon 12/16/2019	to	Mon 12/23/2019	<u>CANCELLED</u>	<u>by LI</u> <u>12/04/2019</u>	(Import)	(Export)	
0001	Continuous	2359			SCH - NPX_1385	100 MW	100 MW
Work scheduled by: LI					Impacts Total Transfer Capability	100 MW	100 MW
					TTC with All Lines In Service	200 MW	200 MW

NYISO TRANSFER LIMITATIONS

Monday ,December 09, 2019 to Wednesday,June 09, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV	
					(Import)	(Export)	
NRTH1385-NOR HBR__138_603							
Mon 12/16/2019	to	Mon 12/23/2019	CANCELLED	by LI	12/04/2019		
0001	Continuous	2359					SCH - NPX_1385
Work scheduled by: LI					Impacts Total Transfer Capability	100 MW	
					TTC with All Lines In Service	200 MW	
					100 MW	100 MW	
					200 MW	200 MW	
NRTH1385-NRTHPORT_138_NNC							
Mon 12/16/2019	to	Mon 12/23/2019	CANCELLED	by LI	12/04/2019		
0001	Continuous	2359					SCH - NPX_1385
Work scheduled by: LI					Impacts Total Transfer Capability	0 MW	
					TTC with All Lines In Service	200 MW	
					200 MW	200 MW	
					200 MW	200 MW	
SCH-NYISO-NE_LIMIT_800							
Mon 12/16/2019	to	Mon 12/23/2019					REV
0001	Continuous	2359					(Export)
Work scheduled by: ISONE					SCH - NE - NY	1000 MW	
					Impacts Total Transfer Capability	700 MW	
					TTC with All Lines In Service	1700 MW	
MOSES__-ADIRNDCK_230_MA2							
Mon 12/16/2019	to	Mon 12/16/2019					FWD
0700	Continuous	1500					(Import)
Work scheduled by: NYPA					MOSES SOUTH	2300 MW	
					Impacts Total Transfer Capability	850 MW	
					TTC with All Lines In Service	3150 MW	
EDIC__-FRASER__345_EF24-40							
Mon 12/16/2019	to	Tue 12/17/2019					FWD
0700	Continuous	1730					(Import)
Work scheduled by: NYPA					CENTRAL EAST - VC	2500 MW	
					Impacts Total Transfer Capability	475 MW	
					TTC with All Lines In Service	2975 MW	
S.RIPLEY-DUNKIRK__230_68							
Mon 12/16/2019	to	Fri 12/20/2019	UPDATED	by PJM	11/13/2019		
0900	Continuous	1500					SCH - PJ - NY
Work scheduled by: PJM					Impacts Total Transfer Capability		
					TTC with All Lines In Service		
MOSES__-ADIRNDCK_230_MA1							
Tue 12/17/2019	to	Fri 12/20/2019					FWD
0700	Continuous	1500					(Import)
Work scheduled by: NYPA					MOSES SOUTH	2300 MW	
					Impacts Total Transfer Capability	850 MW	
					TTC with All Lines In Service	3150 MW	

NYISO TRANSFER LIMITATIONS

Monday ,December 09, 2019 to Wednesday,June 09, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PIERCBRK-FIVEMILE_345_37

Tue 12/17/2019 to Thu 12/19/2019
 0730 Continuous 1630
 Work scheduled by: NGrid

FWD
 (Import)
 SCH - PJ - NY **2400 MW**
 Impacts Total Transfer Capability 500 MW
 TTC with All Lines In Service 2900 MW

EASTVIEW-SPRNBK__345_W65

Wed 12/18/2019 to Wed 12/18/2019 **CANCELLED by ConEd 12/08/2019**
 0201 Continuous 0230
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

SPRNBK__345KV_RNS4

Wed 12/18/2019 to Wed 12/18/2019 **CANCELLED by ConEd 12/08/2019**
 0201 Continuous 0230
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

MILLWOOD-EASTVIEW_345_W82

Wed 12/18/2019 to Wed 12/18/2019 **CANCELLED by ConEd 12/08/2019**
 0201 Continuous 1800
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

EASTVIEW-SPRNBK__345_W65

Wed 12/18/2019 to Wed 12/18/2019 **CANCELLED by ConEd 12/08/2019**
 1730 Continuous 1800
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

SPRNBK__345KV_RNS4

Wed 12/18/2019 to Wed 12/18/2019 **CANCELLED by ConEd 12/08/2019**
 1730 Continuous 1800
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

EFISHKIL-WOOD_ST__345_F38

Fri 12/20/2019 to Sat 12/21/2019 **CANCELLED by ConEd 12/04/2019**
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 1700 MW
 TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Monday ,December 09, 2019 to Wednesday,June 09, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLE-DUNWODIE_345_W89

Fri 12/20/2019 to Sat 12/21/2019
0001 Continuous 0030

CANCELLED by ConEd 12/04/2019

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1700 MW
TTC with All Lines In Service 5700 MW

WOOD_ST_-PLSNTVLE_345_Y86

Fri 12/20/2019 to Sat 12/21/2019
0001 Continuous 0030

CANCELLED by ConEd 12/04/2019

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1700 MW
TTC with All Lines In Service 5700 MW

LINDEN_-GOETHALS_230_A2253

Fri 12/27/2019 to Sun 12/29/2019
0001 Continuous 0300

EXTENDED by CONED 11/22/2019

Work scheduled by: ConEd

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

LINDEN_-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402

Fri 12/27/2019 to Sun 12/29/2019
0001 0300

Work scheduled by:

FWD REV
(Import) (Export)
SCH - PJ - NY **2550 MW 1600 MW**
Impacts Total Transfer Capability 350 MW 250 MW
TTC with All Lines In Service 2900 MW 1850 MW

LINDEN_-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403

Fri 12/27/2019 to Sun 12/29/2019
0001 0300

Work scheduled by:

FWD REV
(Import) (Export)
SCH - PJ - NY **2550 MW 1600 MW**
Impacts Total Transfer Capability 350 MW 250 MW
TTC with All Lines In Service 2900 MW 1850 MW

LINDEN_-GOETHALS_230_A2253 & MARION_-FARRAGUT_345_C3403

Fri 12/27/2019 to Sun 12/29/2019
0001 0300

Work scheduled by:

FWD REV
(Import) (Export)
SCH - PJ - NY **2550 MW 1600 MW**
Impacts Total Transfer Capability 350 MW 250 MW
TTC with All Lines In Service 2900 MW 1850 MW

S.RIPLEY-DUNKIRK_230_68

Mon 01/06/2020 to Fri 01/10/2020
0800 Continuous 1600

Work scheduled by: NGrid

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Monday ,December 09, 2019 to Wednesday,June 09, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASER__345_FRASER SVC				FWD
Mon 01/06/2020	to	Mon 01/20/2020	UPDATED by NYSEG 11/27/2019	(Import)
0800	Continuous	1500		CENTRAL EAST - VC 2935 MW
Work scheduled by: NYSEG				Impacts Total Transfer Capability 40 MW
				TTC with All Lines In Service 2975 MW
BECK__-NIAGARA__345_PA301				FWD REV
Mon 01/13/2020	to	Fri 01/17/2020		(Import) (Export)
0500	Continuous	1530		SCH - OH - NY 1100 MW 950 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 950 MW 950 MW
				TTC with All Lines In Service 2050 MW 1900 MW
RAMAPO__-BUCHAN_N_345_Y94				FWD
Mon 02/03/2020	to	Tue 02/04/2020		(Import)
0001	Continuous	0230		UPNY CONED 4800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 900 MW
				TTC with All Lines In Service 5700 MW
SPRNBRK__-TREMONT__345_X28				FWD
Mon 02/17/2020	to	Mon 02/17/2020	UPDATED by CONED 12/05/2019	(Import)
0001	Continuous	1800		SPR/DUN-SOUTH 4200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 400 MW
				TTC with All Lines In Service 4600 MW
MOTTHAVN-RAINEY__345_Q11				FWD
Sun 02/23/2020	to	Sun 03/01/2020		(Import)
0001	Continuous	0200		SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
NIAGARA__-PACKARD__230_62				FWD REV
Fri 02/28/2020	to	Fri 02/28/2020		(Import) (Export)
0500	Continuous	1530		SCH - OH - NY 900 MW 1850 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 1150 MW 50 MW
				TTC with All Lines In Service 2050 MW 1900 MW
CHATGUAY-MASSENA__765_7040				FWD
Mon 03/02/2020	to	Fri 03/06/2020	UPDATED by NYPA 08/08/2019	(Import)
0500	Continuous	1730		MOSES SOUTH 1550 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 1600 MW
				TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Monday ,December 09, 2019 to Wednesday,June 09, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						FWD	REV
CHATGUAY-MASSENA__765_7040						(Import)	(Export)
Mon 03/02/2020	to	Fri 03/06/2020	UPDATED	by NYPA	08/08/2019		
0500	Continuous	1730				SCH - HQ - NY	0 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	1500 MW
						TTC with All Lines In Service	1500 MW
<hr/>						FWD	REV
MARCY__765_345_AT1						(Import)	(Export)
Mon 03/02/2020	to	Fri 03/06/2020	UPDATED	by NYPA	08/08/2019		
0500	Continuous	1730				MOSES SOUTH	1750 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	1400 MW
						TTC with All Lines In Service	3150 MW
<hr/>						FWD	REV
MARCY__765_345_AT2						(Import)	(Export)
Mon 03/02/2020	to	Fri 03/06/2020					
0500	Continuous	1730				MOSES SOUTH	1700 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	1450 MW
						TTC with All Lines In Service	3150 MW
<hr/>						FWD	REV
MASSENA_-MARCY__765_MSU1						(Import)	(Export)
Mon 03/02/2020	to	Fri 03/06/2020	UPDATED	by NYPA	08/08/2019		
0500	Continuous	1730				CENTRAL EAST - VC	2265 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	710 MW
						TTC with All Lines In Service	2975 MW
<hr/>						FWD	REV
MASSENA_-MARCY__765_MSU1						(Import)	(Export)
Mon 03/02/2020	to	Fri 03/06/2020	UPDATED	by NYPA	08/08/2019		
0500	Continuous	1730				MOSES SOUTH	500 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	2650 MW
						TTC with All Lines In Service	3150 MW
<hr/>						FWD	REV
MASSENA_-MARCY__765_MSU1						(Import)	(Export)
Mon 03/02/2020	to	Fri 03/06/2020	UPDATED	by NYPA	08/08/2019		
0500	Continuous	1730				SCH - HQ - NY	475 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	1025 MW
						TTC with All Lines In Service	1500 MW
<hr/>						FWD	REV
MASSENA_-MARCY__765_MSU1						(Import)	(Export)
Mon 03/02/2020	to	Fri 03/06/2020	UPDATED	by NYPA	08/08/2019		
0500	Continuous	1730				SCH - HQ_CEDARS	90 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	109 MW
						TTC with All Lines In Service	199 MW

NYISO TRANSFER LIMITATIONS

Monday ,December 09, 2019 to Wednesday,June 09, 2021

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040

Mon 03/02/2020 to Fri 03/06/2020
0500 1730

Work scheduled by:

FWD
(Import)
MOSES SOUTH **500 MW**
Impacts Total Transfer Capability 2650 MW
TTC with All Lines In Service 3150 MW

MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2

Mon 03/02/2020 to Fri 03/06/2020
0500 1730

Work scheduled by:

FWD REV
(Import) (Export)
SCH - HQ - NY **850 MW 0 MW**
Impacts Total Transfer Capability 650 MW 1000 MW
TTC with All Lines In Service 1500 MW 1000 MW

MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2

Mon 03/02/2020 to Fri 03/06/2020
0500 1730

Work scheduled by:

FWD
(Import)
SCH - HQ_CEDARS **90 MW**
Impacts Total Transfer Capability 109 MW
TTC with All Lines In Service 199 MW

STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1

Mon 03/02/2020 to Fri 03/06/2020
0500 1730

Work scheduled by:

FWD
(Import)
SCH - HQ_CEDARS **90 MW**
Impacts Total Transfer Capability 109 MW
TTC with All Lines In Service 199 MW

STLAWRNC-MOSES 230_L33P & MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2

Mon 03/02/2020 to Fri 03/06/2020
0500 1730

Work scheduled by:

FWD
(Import)
SCH - HQ_CEDARS **90 MW**
Impacts Total Transfer Capability 109 MW
TTC with All Lines In Service 199 MW

SHOR_NPX-SHOREHAM_138_CSC

Mon 03/02/2020 to Tue 03/03/2020
0600 Continuous 1300

Work scheduled by: LI

FWD REV
(Import) (Export)
SCH - NPX_CSC **0 MW 0 MW**
Impacts Total Transfer Capability 330 MW 330 MW
TTC with All Lines In Service 330 MW 330 MW

ROSETON -EFISHKIL_345_RFK305

Mon 03/02/2020 to Fri 03/20/2020
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
UPNY CONED **4800 MW**
Impacts Total Transfer Capability 900 MW
TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Monday ,December 09, 2019 to Wednesday,June 09, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EASTVIEW-SPRNBK__345_W78

Fri 03/06/2020 to Sat 03/07/2020
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

MILLWOOD-EASTVIEW_345_W85

Fri 03/06/2020 to Sat 03/07/2020
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

SPRNBK__345KV_RNS3

Fri 03/06/2020 to Sat 03/07/2020
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

MOSES__-ADIRNDCK_230_MA1

Sat 03/07/2020 to Fri 05/29/2020
 0700 Continuous 1300
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

VOLNEY__-MARCY__345_19

Tue 03/10/2020 to Tue 03/10/2020 **UPDATED by NYPA 09/24/2019**
 0700 Continuous 1530
 Work scheduled by: NYPA **ARR: 19**

FWD
 (Import)
 CENTRAL EAST - VC **2825 MW**
 Impacts Total Transfer Capability 150 MW
 TTC with All Lines In Service 2975 MW

VOLNEY__-MARCY__345_19

Tue 03/10/2020 to Tue 03/10/2020 **UPDATED by NYPA 09/24/2019**
 0700 Continuous 1530
 Work scheduled by: NYPA **ARR: 19**

FWD
 (Import)
 OSWEGO EXPORT **4900 MW**
 Impacts Total Transfer Capability 350 MW
 TTC with All Lines In Service 5250 MW

ROCHESTR-PANNELL__345_RP2

Sat 03/14/2020 to Mon 03/23/2020
 0500 Continuous 1700
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Monday ,December 09, 2019 to Wednesday,June 09, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___345KV_CSC

Mon 03/16/2020 to Fri 03/27/2020
 0500 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2925 MW**
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 2975 MW

EASTVIEW-SPRNBK__345_W64

Sat 03/21/2020 to Sat 03/21/2020 UPDATED by CONED 12/05/2019
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

SPRNBK__345KV_RNS5

Sat 03/21/2020 to Sat 03/21/2020 UPDATED by CONED 12/05/2019
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

MILLWOOD-EASTVIEW_345_W99

Sat 03/21/2020 to Sun 03/22/2020 UPDATED by CONED 12/05/2019
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

EASTVIEW-SPRNBK__345_W64

Sun 03/22/2020 to Sun 03/22/2020 UPDATED by CONED 12/05/2019
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

SPRNBK__345KV_RNS5

Sun 03/22/2020 to Sun 03/22/2020 UPDATED by CONED 12/05/2019
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

NIAGARA_-KINTIGH__345_NS1-38

Fri 03/27/2020 to Fri 03/27/2020
 0600 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Monday ,December 09, 2019 to Wednesday,June 09, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
BECK - PACKARD 230 BP76		FWD	REV
Fri 03/27/2020 to Fri 03/27/2020		(Import) (Export)	
0800 Daily(No Weekends) 1600		SCH - OH - NY	1650 MW 1400 MW
Work scheduled by: NGrid		Impacts Total Transfer Capability	400 MW 500 MW
		TTC with All Lines In Service	2050 MW 1900 MW
<hr/>			
MARCY - EDIC 345 UE1-7		FWD	
Tue 03/31/2020 to Tue 03/31/2020	UPDATED	(Import)	
0700 Continuous 1530	by NYPA	OSWEGO EXPORT	5250 MW
Work scheduled by: NYPA	09/24/2019	Impacts Total Transfer Capability	0 MW
	ARR: 19&16	TTC with All Lines In Service	5250 MW
<hr/>			
RAMAPO - LADENTWN 345 W72		FWD	
Wed 04/01/2020 to Thu 04/02/2020		(Import)	
0001 Continuous 1830		UPNY CONED	4400 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability	1300 MW
		TTC with All Lines In Service	5700 MW
<hr/>			
FRASANX-COOPERS 345 UCC2-41		FWD	
Wed 04/01/2020 to Thu 04/02/2020	UPDATED	(Import)	
0700 Continuous 1530	by NYPA	CENTRAL EAST - VC	2500 MW
Work scheduled by: NYPA	11/12/2019	Impacts Total Transfer Capability	475 MW
	ARR: 19	TTC with All Lines In Service	2975 MW
<hr/>			
MARCY - FRASANX 345 UCC2-41		FWD	
Wed 04/01/2020 to Thu 04/02/2020	UPDATED	(Import)	
0700 Continuous 1530	by NYPA	CENTRAL EAST - VC	2500 MW
Work scheduled by: NYPA	11/12/2019	Impacts Total Transfer Capability	475 MW
	ARR: 19	TTC with All Lines In Service	2975 MW
<hr/>			
LINDN_CG-LNDVFT 345 V-3022		FWD	REV
Sun 04/05/2020 to Sat 04/11/2020		(Import) (Export)	
1400 Continuous 1400		SCH - PJM_VFT	0 MW 0 MW
Work scheduled by: PJM		Impacts Total Transfer Capability	315 MW 315 MW
		TTC with All Lines In Service	315 MW 315 MW
<hr/>			
SPRNBRK - W49TH_ST 345 M51		FWD	
Mon 04/06/2020 to Wed 04/08/2020	CANCELLED	(Import)	
0001 Continuous 0200	by ConEd	SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd	12/05/2019	Impacts Total Transfer Capability	1400 MW
		TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Monday ,December 09, 2019 to Wednesday,June 09, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK__345KV_RNS5

Mon 04/06/2020 to Wed 04/08/2020
 0001 Continuous 0200
 Work scheduled by: ConEd

CANCELLED by ConEd 12/05/2019

FWD
 (Import)
3200 MW
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

MARCY__-N.SCTLND_345_18

Tue 04/07/2020 to Wed 04/08/2020
 0700 Continuous 1530
 Work scheduled by: NYPA

UPDATED by NYPA 09/24/2019
ARR: 19

FWD
 (Import)
2090 MW
 Impacts Total Transfer Capability 885 MW
 TTC with All Lines In Service 2975 MW

PLSNTVLY-EFISHKIL_345_F36

Mon 04/13/2020 to Tue 04/14/2020
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
4000 MW
 Impacts Total Transfer Capability 1700 MW
 TTC with All Lines In Service 5700 MW

SAND_BAR-PLATSBRG_115_PV20

Mon 04/13/2020 to Tue 04/14/2020
 0600 Daily 1800
 Work scheduled by: ISONE

SCH - NE - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FRASER__-GILBOA__345_GF5-35

Mon 04/13/2020 to Wed 04/22/2020
 0700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
2650 MW
 Impacts Total Transfer Capability 325 MW
 TTC with All Lines In Service 2975 MW

NIAGARA_-ROCHESTR_345_NR2

Wed 04/15/2020 to Fri 05/01/2020
 0500 Continuous 1700
 Work scheduled by: NYPA

FWD
 (Import)
1700 MW
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

ROCHESTR-PANNELL__345_RP1

Mon 04/20/2020 to Fri 04/24/2020
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
2300 MW
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Monday ,December 09, 2019 to Wednesday,June 09, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DOLSONAV-ROCKTVRN_345_DART44

Mon 04/27/2020 to Sun 05/10/2020
0700 Continuous 1730

UPDATED by NYPA 03/21/2019

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2720 MW**
Impacts Total Transfer Capability 255 MW
TTC with All Lines In Service 2975 MW

HURLYAVE-ROSETON_345_303

Mon 04/27/2020 to Fri 05/29/2020
0800 Continuous 1600

UPDATED by CHGE 10/09/2019

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 1600 MW
TTC with All Lines In Service 5700 MW

SCH-IMO-NYISO_LIMIT_1600

Fri 05/01/2020 to Sat 10/31/2020
0001 Continuous 2359

UPDATED by IESO 05/03/2019

Work scheduled by: IESO

FWD
(Import)
SCH - OH - NY **1900 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 1900 MW

PANNELL -CLAY_345_2

Mon 05/04/2020 to Fri 05/08/2020
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Mon 05/04/2020 to Mon 05/18/2020
0800 Continuous 1700

Work scheduled by: PJM

FWD
(Import)
SCH - PJM_NEPTUNE **0 MW**
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

NEWBRDGE-DUFFYAVE_345_501

Mon 05/04/2020 to Mon 05/18/2020
0800 Continuous 1700

Work scheduled by: PJM

FWD
(Import)
SCH - PJM_NEPTUNE **0 MW**
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_1

Mon 05/04/2020 to Mon 05/18/2020
0800 Continuous 1700

Work scheduled by: PJM

FWD
(Import)
SCH - PJM_NEPTUNE **375 MW**
Impacts Total Transfer Capability 285 MW
TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Monday ,December 09, 2019 to Wednesday,June 09, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE_345_138_BK_2				FWD
Mon 05/04/2020	to	Mon 05/18/2020		(Import)
0800	Continuous	1700		SCH - PJM_NEPTUNE 375 MW
Work scheduled by: PJM				Impacts Total Transfer Capability 285 MW
				TTC with All Lines In Service 660 MW
PANNELL_-CLAY_345_1				FWD
Mon 05/11/2020	to	Fri 05/15/2020		(Import)
0700	Continuous	1530		WEST CENTRAL 1300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 950 MW
				TTC with All Lines In Service 2250 MW
COOPERS_-DOLSONAV_345_CCDA42				FWD
Mon 05/11/2020	to	Fri 05/29/2020	UPDATED by NYPA 03/21/2019	(Import)
0700	Continuous	1730		CENTRAL EAST - VC 2720 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 255 MW
				TTC with All Lines In Service 2975 MW
KINTIGH_-ROCHESTR_345_SR1-39				FWD
Mon 05/18/2020	to	Fri 05/22/2020		(Import)
0500	Continuous	1530		DYSINGER EAST 1400 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 1750 MW
				TTC with All Lines In Service 3150 MW
MOSES_-ADIRNDCK_230_MA2				FWD
Mon 06/01/2020	to	Fri 07/31/2020		(Import)
0700	Continuous	1730		MOSES SOUTH 2100 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 1050 MW
				TTC with All Lines In Service 3150 MW
NIAGARA_345_230_AT4				REV
Mon 06/29/2020	to	Tue 06/30/2020		(Export)
0500	Continuous	1530		SCH - OH - NY 1400 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 300 MW
				TTC with All Lines In Service 1700 MW
SCH-IMO-NYISO_NIAG_CB_3008_W/BB				FWD REV
Mon 07/27/2020	to	Fri 08/07/2020		(Import) (Export)
0500	Continuous	1530		SCH - OH - NY 1900 MW 1450 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 0 MW 250 MW
				TTC with All Lines In Service 1900 MW 1700 MW

NYISO TRANSFER LIMITATIONS

Monday ,December 09, 2019 to Wednesday,June 09, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHATGUAY-MASSENA__765_7040						FWD	
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)	
0500	Continuous	1730				MOSES SOUTH	1550 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	1600 MW
						TTC with All Lines In Service	3150 MW
CHATGUAY-MASSENA__765_7040						FWD	REV
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)	(Export)
0500	Continuous	1730				SCH - HQ - NY	0 MW 0 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	1500 MW 1000 MW
						TTC with All Lines In Service	1500 MW 1000 MW
MARCY__765_345_AT1						FWD	
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)	
0500	Continuous	1730				MOSES SOUTH	1750 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	1400 MW
						TTC with All Lines In Service	3150 MW
MASSENA_-MARCY__765_MSU1						FWD	
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)	
0500	Continuous	1730				CENTRAL EAST - VC	2265 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	710 MW
						TTC with All Lines In Service	2975 MW
MASSENA_-MARCY__765_MSU1						FWD	
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)	
0500	Continuous	1730				MOSES SOUTH	500 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	2650 MW
						TTC with All Lines In Service	3150 MW
MASSENA_-MARCY__765_MSU1						FWD	REV
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)	(Export)
0500	Continuous	1730				SCH - HQ - NY	475 MW 1000 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	1025 MW 0 MW
						TTC with All Lines In Service	1500 MW 1000 MW
MASSENA_-MARCY__765_MSU1						FWD	
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)	
0500	Continuous	1730				SCH - HQ_CEDARS	90 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	190 MW

NYISO TRANSFER LIMITATIONS

Monday ,December 09, 2019 to Wednesday,June 09, 2021

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040

Sat 08/01/2020 to Sun 08/02/2020
0500 1730

Work scheduled by:

FWD
(Import)
MOSES SOUTH **500 MW**
Impacts Total Transfer Capability 2650 MW
TTC with All Lines In Service 3150 MW

MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2

Sat 08/01/2020 to Sun 08/02/2020
0500 1730

Work scheduled by:

FWD REV
(Import) (Export)
SCH - HQ - NY **850 MW 0 MW**
Impacts Total Transfer Capability 650 MW 1000 MW
TTC with All Lines In Service 1500 MW 1000 MW

MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2

Sat 08/01/2020 to Sun 08/02/2020
0500 1730

Work scheduled by:

FWD
(Import)
SCH - HQ_CEDARS **90 MW**
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 190 MW

STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1

Sat 08/01/2020 to Sun 08/02/2020
0500 1730

Work scheduled by:

FWD
(Import)
SCH - HQ_CEDARS **90 MW**
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 190 MW

STLAWRNC-MOSES 230_L33P & MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2

Sat 08/01/2020 to Sun 08/02/2020
0500 1730

Work scheduled by:

FWD
(Import)
SCH - HQ_CEDARS **90 MW**
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 190 MW

MOSES -ADIRNDCK 230_MA2

Mon 08/03/2020 to Sun 09/13/2020
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

FRASANX-COOPERS 345_UCC2-41

Mon 09/07/2020 to Fri 10/23/2020 **UPDATED by NYPA 03/01/2019**
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

ARR: 19

NYISO TRANSFER LIMITATIONS

Monday ,December 09, 2019 to Wednesday,June 09, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___-FRASANNX_345_UCC2-41

Mon 09/07/2020 to Fri 10/23/2020
0700 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 03/01/2019

ARR: 19

CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

FWD
(Import)

MARCY___765_345_AT1

Mon 09/14/2020 to Mon 09/14/2020
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

MOSES SOUTH **1750 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 3150 MW

FWD
(Import)

NIAGARA_-KINTIGH_345_NS1-38

Mon 09/14/2020 to Thu 09/17/2020
0500 Continuous 1530

Work scheduled by: NYPA

DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

FWD
(Import)

MOSES___-ADIRNDCK_230_MA2

Tue 09/15/2020 to Sat 11/14/2020
0700 Continuous 1530

Work scheduled by: NYPA

MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

FWD
(Import)

NIAGARA_-ROCHESTR_345_NR2

Fri 09/18/2020 to Sat 11/14/2020
0500 Continuous 2330

Work scheduled by: NYPA

DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

FWD
(Import)

CLAY___-EDIC___345_1-16

Mon 09/21/2020 to Fri 09/25/2020
0700 Continuous 1530

Work scheduled by: NYPA

OSWEGO EXPORT **4850 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 5250 MW

FWD
(Import)

ROSETON_-ROCKTVRN_345_311

Mon 09/21/2020 to Fri 10/23/2020
0800 Continuous 1600

Work scheduled by: CHGE

UPDATED by CHGE 10/09/2019

UPNY CONED **4400 MW**
Impacts Total Transfer Capability 1300 MW
TTC with All Lines In Service 5700 MW

FWD
(Import)

NYISO TRANSFER LIMITATIONS

Monday ,December 09, 2019 to Wednesday,June 09, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_3					FWD	
Fri 09/25/2020	to	Fri 09/25/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>09/05/2019</u>	(Import)
0001	Continuous	0030				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_5					FWD	
Fri 09/25/2020	to	Fri 09/25/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>09/05/2019</u>	(Import)
0001	Continuous	0030				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
DUNWODIE-MOTTHAVN_345_71					FWD	
Fri 09/25/2020	to	Fri 10/30/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>09/05/2019</u>	(Import)
0001	Continuous	0300				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
CLAY -EDIC 345_2-15					FWD	
Mon 09/28/2020	to	Fri 10/02/2020				(Import)
0700	Continuous	1530				OSWEGO EXPORT 4850 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	400 MW
					TTC with All Lines In Service	5250 MW
SAND_BAR-PLATSBURG_115_PV20						
Sat 10/17/2020	to	Sat 11/14/2020				SCH - NE - NY
0600	Continuous	1800				Impacts Total Transfer Capability
Work scheduled by: ISONE					TTC with All Lines In Service	
LEEDS -HURLYAVE_345_301					FWD	
Mon 10/26/2020	to	Fri 12/04/2020				(Import)
0800	Continuous	1600				UPNY CONED 4100 MW
Work scheduled by: CHGE					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	5700 MW
DUNWODIE_345KV_3					FWD	
Fri 10/30/2020	to	Fri 10/30/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>09/05/2019</u>	(Import)
0230	Continuous	0300				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Monday ,December 09, 2019 to Wednesday,June 09, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_5					FWD		
Fri 10/30/2020	to	Fri 10/30/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>09/05/2019</u>	(Import)	
0230	Continuous	0300				3800 MW	
Work scheduled by: ConEd					SPR/DUN-SOUTH	800 MW	
					Impacts Total Transfer Capability	4600 MW	
					TTC with All Lines In Service		
SCH-IMO-NYISO_LIMIT_1750					FWD		
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Import)	
0001	Continuous	2359				2050 MW	
Work scheduled by: IESO					SCH - OH - NY	0 MW	
					Impacts Total Transfer Capability	2050 MW	
					TTC with All Lines In Service		
SCH-NYISO-IMO_LIMIT_1600					REV		
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Export)	
0001	Continuous	2359				1900 MW	
Work scheduled by: IESO					SCH - OH - NY	0 MW	
					Impacts Total Transfer Capability	1900 MW	
					TTC with All Lines In Service		
CHATGUAY-MASSENA__765_7040					FWD		
Sun 11/15/2020	to	Mon 11/30/2020				(Import)	
0100	Continuous	1900				1550 MW	
Work scheduled by: NYPA					MOSES SOUTH	1600 MW	
					Impacts Total Transfer Capability	3150 MW	
					TTC with All Lines In Service		
CHATGUAY-MASSENA__765_7040					FWD	REV	
Sun 11/15/2020	to	Mon 11/30/2020				(Import)	(Export)
0100	Continuous	1900				0 MW	0 MW
Work scheduled by: NYPA					SCH - HQ - NY	1500 MW	1000 MW
					Impacts Total Transfer Capability	1500 MW	1000 MW
					TTC with All Lines In Service		
MARCY__765_345_AT1					FWD		
Sun 11/15/2020	to	Mon 11/30/2020				(Import)	
0100	Continuous	1900				1750 MW	
Work scheduled by: NYPA					MOSES SOUTH	1400 MW	
					Impacts Total Transfer Capability	3150 MW	
					TTC with All Lines In Service		
MARCY__765_345_AT2					FWD		
Sun 11/15/2020	to	Mon 11/30/2020				(Import)	
0100	Continuous	1900				1700 MW	
Work scheduled by: NYPA					MOSES SOUTH	1450 MW	
					Impacts Total Transfer Capability	3150 MW	
					TTC with All Lines In Service		

ARR: 19

ARR: 19

NYISO TRANSFER LIMITATIONS

Monday ,December 09, 2019 to Wednesday,June 09, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>MASSENA -MARCY 765_MSU1</p> <p>Sun 11/15/2020 to Mon 11/30/2020 0100 Continuous 1900</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import)</p> <p>CENTRAL EAST - VC 2265 MW</p> <p>Impacts Total Transfer Capability 710 MW</p> <p>TTC with All Lines In Service 2975 MW</p>															
<p>MASSENA -MARCY 765_MSU1</p> <p>Sun 11/15/2020 to Mon 11/30/2020 0100 Continuous 1900</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import)</p> <p>MOSES SOUTH 500 MW</p> <p>Impacts Total Transfer Capability 2650 MW</p> <p>TTC with All Lines In Service 3150 MW</p>															
<p>MASSENA -MARCY 765_MSU1</p> <p>Sun 11/15/2020 to Mon 11/30/2020 0100 Continuous 1900</p> <p>Work scheduled by: NYPA</p>	<table border="0" style="width: 100%;"> <tr> <td style="width: 60%;">FWD</td> <td style="width: 20%;">REV</td> <td style="width: 20%;"></td> </tr> <tr> <td>(Import)</td> <td>(Export)</td> <td></td> </tr> <tr> <td>SCH - HQ - NY</td> <td>475 MW</td> <td>1000 MW</td> </tr> <tr> <td>Impacts Total Transfer Capability</td> <td>1025 MW</td> <td>0 MW</td> </tr> <tr> <td>TTC with All Lines In Service</td> <td>1500 MW</td> <td>1000 MW</td> </tr> </table>	FWD	REV		(Import)	(Export)		SCH - HQ - NY	475 MW	1000 MW	Impacts Total Transfer Capability	1025 MW	0 MW	TTC with All Lines In Service	1500 MW	1000 MW
FWD	REV															
(Import)	(Export)															
SCH - HQ - NY	475 MW	1000 MW														
Impacts Total Transfer Capability	1025 MW	0 MW														
TTC with All Lines In Service	1500 MW	1000 MW														
<p>MASSENA -MARCY 765_MSU1</p> <p>Sun 11/15/2020 to Mon 11/30/2020 0100 Continuous 1900</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import)</p> <p>SCH - HQ_CEDARS 90 MW</p> <p>Impacts Total Transfer Capability 109 MW</p> <p>TTC with All Lines In Service 199 MW</p>															
<p>MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040</p> <p>Sun 11/15/2020 to Mon 11/30/2020 0100 1900</p> <p>Work scheduled by:</p>	<p>FWD (Import)</p> <p>MOSES SOUTH 500 MW</p> <p>Impacts Total Transfer Capability 2650 MW</p> <p>TTC with All Lines In Service 3150 MW</p>															
<p>MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2</p> <p>Sun 11/15/2020 to Mon 11/30/2020 0100 1900</p> <p>Work scheduled by:</p>	<table border="0" style="width: 100%;"> <tr> <td style="width: 60%;">FWD</td> <td style="width: 20%;">REV</td> <td style="width: 20%;"></td> </tr> <tr> <td>(Import)</td> <td>(Export)</td> <td></td> </tr> <tr> <td>SCH - HQ - NY</td> <td>850 MW</td> <td>0 MW</td> </tr> <tr> <td>Impacts Total Transfer Capability</td> <td>650 MW</td> <td>1000 MW</td> </tr> <tr> <td>TTC with All Lines In Service</td> <td>1500 MW</td> <td>1000 MW</td> </tr> </table>	FWD	REV		(Import)	(Export)		SCH - HQ - NY	850 MW	0 MW	Impacts Total Transfer Capability	650 MW	1000 MW	TTC with All Lines In Service	1500 MW	1000 MW
FWD	REV															
(Import)	(Export)															
SCH - HQ - NY	850 MW	0 MW														
Impacts Total Transfer Capability	650 MW	1000 MW														
TTC with All Lines In Service	1500 MW	1000 MW														
<p>MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2</p> <p>Sun 11/15/2020 to Mon 11/30/2020 0100 1900</p> <p>Work scheduled by:</p>	<p>FWD (Import)</p> <p>SCH - HQ_CEDARS 90 MW</p> <p>Impacts Total Transfer Capability 109 MW</p> <p>TTC with All Lines In Service 199 MW</p>															

NYISO TRANSFER LIMITATIONS

Monday ,December 09, 2019 to Wednesday,June 09, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>STLAWRNC-MOSES___230_L33P & MASSENA_-MARCY___765_MSU1</p> <p>Sun 11/15/2020 to Mon 11/30/2020 0100 1900</p> <p>Work scheduled by:</p>	<p>FWD (Import)</p> <p>SCH - HQ_CEDARS 90 MW</p> <p>Impacts Total Transfer Capability 109 MW</p> <p>TTC with All Lines In Service 199 MW</p>
<p>STLAWRNC-MOSES___230_L33P & MOSES___-MASSENA_230_MMS1 & MOSES___- MASSENA_230_MMS2</p> <p>Sun 11/15/2020 to Mon 11/30/2020 0100 1900</p> <p>Work scheduled by:</p>	<p>FWD (Import)</p> <p>SCH - HQ_CEDARS 90 MW</p> <p>Impacts Total Transfer Capability 109 MW</p> <p>TTC with All Lines In Service 199 MW</p>
<p>PLSNTVLE-DUNWODIE_345_W89</p> <p>Mon 11/16/2020 to Mon 11/16/2020 0001 Continuous 0030</p> <p>Work scheduled by: ConEd</p>	<p>FWD (Import)</p> <p>UPNY CONED 4000 MW</p> <p>Impacts Total Transfer Capability 1700 MW</p> <p>TTC with All Lines In Service 5700 MW</p>
<p>PLSNTVLE-DUNWODIE_345_W89</p> <p>Thu 11/26/2020 to Thu 11/26/2020 0230 Continuous 0300</p> <p>Work scheduled by: ConEd</p>	<p>FWD (Import)</p> <p>UPNY CONED 4000 MW</p> <p>Impacts Total Transfer Capability 1700 MW</p> <p>TTC with All Lines In Service 5700 MW</p>
<p>MOSES___-ADIRNDCK_230_MA1</p> <p>Tue 12/01/2020 to Mon 05/31/2021 0700 Continuous 1300</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import)</p> <p>MOSES SOUTH 2300 MW</p> <p>Impacts Total Transfer Capability 850 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>SAND_BAR-PLATSBRG_115_PV20</p> <p>Mon 12/07/2020 to Fri 12/11/2020 0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p>SCH - NE - NY</p> <p>Impacts Total Transfer Capability</p> <p>TTC with All Lines In Service</p>
<p>SAND_BAR-PLATSBRG_115_PV20</p> <p>Mon 12/14/2020 to Fri 12/18/2020 0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p>SCH - NE - NY</p> <p>Impacts Total Transfer Capability</p> <p>TTC with All Lines In Service</p>

NYISO TRANSFER LIMITATIONS

Monday ,December 09, 2019 to Wednesday,June 09, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOTTHAVN-RAINEY___345_Q11

Mon 03/01/2021 to Tue 04/06/2021
 0001 Continuous 0700
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

CLAY___-EDIC___345_2-15

Mon 03/29/2021 to Fri 04/16/2021
 0800 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 OSWEGO EXPORT **4850 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 5250 MW

SCH-IMO-NYISO_LIMIT_1600

Sat 05/01/2021 to Sun 10/31/2021 **UPDATED by IESO 05/03/2019**
 0001 Continuous 2359
 Work scheduled by: IESO

FWD
 (Import)
 SCH - OH - NY **1900 MW**
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 1900 MW

PANNELL_-CLAY___345_2

Mon 05/03/2021 to Fri 05/28/2021
 0700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 WEST CENTRAL **1300 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

MOSES___-ADIRNDCK_230_MA2

Tue 06/01/2021 to Sun 11/14/2021
 0700 Continuous 1300
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2100 MW**
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW