

NYISO TRANSFER LIMITATIONS

Sunday ,December 15, 2019 to Tuesday ,June 15, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Fri 05/01/2020 **EXTENDED** **by CONED** **10/08/2019**
 0001 Continuous 2359
 Work scheduled by: ConEd

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Fri 05/01/2020
 0001 2359
 Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2550 MW	1600 MW
Impacts Total Transfer Capability	350 MW	250 MW
TTC with All Lines In Service	2900 MW	1850 MW

MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Fri 05/01/2020 **EXTENDED** **by CONED** **10/08/2019**
 0001 Continuous 2359
 Work scheduled by: ConEd

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

STLAWRNC-MOSES_230_L33P

Mon 04/30/2018 to Fri 12/31/2021 **EXT FORCE** **by IESO** **08/21/2018**
 0456 Continuous 2359
 Work scheduled by: IESO

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

NIAGARA_345_230_AT4

Wed 10/23/2019 to Tue 12/17/2019 **UPDATED** **by NYPA** **09/10/2019**
 0500 Continuous 1700
 Work scheduled by: NYPA

	REV
	(Export)
SCH - OH - NY	1750 MW
Impacts Total Transfer Capability	150 MW
TTC with All Lines In Service	1900 MW

SCH-IMO-NYISO_LIMIT_1750

Fri 11/01/2019 to Thu 04/30/2020 **UPDATED** **by IESO** **05/03/2019**
 0001 Continuous 2359
 Work scheduled by: IESO

	FWD
	(Import)
SCH - OH - NY	2050 MW
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	2050 MW

SCH-NYISO-IMO_LIMIT_1600

Fri 11/01/2019 to Thu 04/30/2020 **UPDATED** **by IESO** **05/03/2019**
 0001 Continuous 2359
 Work scheduled by: IESO

	REV
	(Export)
SCH - OH - NY	1900 MW
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	1900 MW

NYISO TRANSFER LIMITATIONS

Sunday ,December 15, 2019 to Tuesday ,June 15, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-NE_LIMIT_1500						REV
Fri 11/01/2019	to	Thu 04/30/2020				(Export)
0001	Continuous	2359			SCH - NE - NY	1700 MW
Work scheduled by: NYISO						Impacts Total Transfer Capability 0 MW
						TTC with All Lines In Service 1700 MW
SCH-IMO-NYISO_LIMIT_1400						FWD
Tue 11/12/2019	to	Tue 12/17/2019	<u>EXTENDED</u>	<u>by IESO</u>	<u>11/27/2019</u>	(Import)
0501	Continuous	1700			SCH - OH - NY	1700 MW
Work scheduled by: IESO						Impacts Total Transfer Capability 350 MW
						TTC with All Lines In Service 2050 MW
SCH-NYISO-IMO_LIMIT_1400						REV
Tue 11/12/2019	to	Tue 12/17/2019	<u>EXTENDED</u>	<u>by IESO</u>	<u>11/27/2019</u>	(Export)
0501	Continuous	1700			SCH - OH - NY	1700 MW
Work scheduled by: IESO						Impacts Total Transfer Capability 200 MW
						TTC with All Lines In Service 1900 MW
OSWEGO_COMPLEX_AVR_O/S						FWD
Mon 11/18/2019	to	Tue 12/31/2019	<u>EXT FORCE</u>	<u>by GEN</u>	<u>12/13/2019</u>	(Import)
0221	Continuous	2359			CENTRAL EAST - VC	2870 MW
Work scheduled by: Gen						Impacts Total Transfer Capability 105 MW
						TTC with All Lines In Service 2975 MW
DUNWODIE_345KV_6						FWD
Tue 12/03/2019	to	Tue 12/31/2019	<u>FORCED</u>	<u>by CONED</u>	<u>12/03/2019</u>	(Import)
0048	Continuous	2359			SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_8						FWD
Tue 12/03/2019	to	Tue 12/31/2019	<u>FORCED</u>	<u>by CONED</u>	<u>12/03/2019</u>	(Import)
0048	Continuous	2359			SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
PLSNTVLE-DUNWODIE_345_W90						FWD
Tue 12/03/2019	to	Tue 12/31/2019	<u>FORCED</u>	<u>by CONED</u>	<u>12/03/2019</u>	(Import)
0107	Continuous	2359			UPNY CONED	4000 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 1700 MW
						TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Sunday ,December 15, 2019 to Tuesday ,June 15, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_500					FWD	
Tue 12/03/2019	to	Fri 12/20/2019	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/11/2019</u>	(Import)
0700	Continuous	1600				700 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability 700 MW	
					TTC with All Lines In Service 1400 MW	
SCH-NYISO-NE_LIMIT_1200					REV	
Tue 12/03/2019	to	Fri 12/20/2019	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/11/2019</u>	(Export)
0700	Continuous	1600				1400 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability 300 MW	
					TTC with All Lines In Service 1700 MW	
W49TH_ST_345KV_5					FWD	
Mon 12/09/2019	to	Wed 12/11/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>12/11/2019</u>	(Import)
0001	Continuous	0300				315 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 345 MW	
					TTC with All Lines In Service 660 MW	
W49TH_ST_345KV_7					FWD	
Mon 12/09/2019	to	Sat 12/14/2019	<u>UPDATED</u>	<u>by CONED</u>	<u>12/11/2019</u>	(Import)
0001	Continuous	0200				315 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 345 MW	
					TTC with All Lines In Service 660 MW	
SCH-IMO-NYISO_LIMIT_950					FWD	
Mon 12/09/2019	to	Wed 12/11/2019				(Import)
0500	Continuous	0459				1250 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 800 MW	
					TTC with All Lines In Service 2050 MW	
MOSES -ADIRNDCK_230_MA1					FWD	
Mon 12/09/2019	to	Fri 12/13/2019	<u>UPDATED</u>	<u>by NYPA</u>	<u>12/03/2019</u>	(Import)
0700	Continuous	1530				2300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 850 MW	
					TTC with All Lines In Service 3150 MW	
ROSETON -ROCKTVRN_345_311					FWD	
Mon 12/09/2019	to	Wed 12/11/2019	<u>UPDATED</u>	<u>by CHGE</u>	<u>12/11/2019</u>	(Import)
0800	Continuous	1600				4400 MW
Work scheduled by: CHGE					Impacts Total Transfer Capability 1300 MW	
					TTC with All Lines In Service 5700 MW	

NYISO TRANSFER LIMITATIONS

Sunday ,December 15, 2019 to Tuesday ,June 15, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>INDPDNCE-SCRIBA_345_25</p> <p>Tue 12/10/2019 to Tue 12/10/2019 0830 Continuous 1600</p> <p>Work scheduled by: NGrid</p>	<p>FWD (Import) OSWEGO EXPORT 5250 MW Impacts Total Transfer Capability 0 MW TTC with All Lines In Service 5250 MW</p>
<p>SHOR_NPX-SHOREHAM_138_CSC</p> <p>Thu 12/12/2019 to Fri 12/20/2019 0700 Continuous 1500</p> <p>Work scheduled by: ISONE</p>	<p>FWD REV (Import) (Export) SCH - NPX_CSC 0 MW 0 MW Impacts Total Transfer Capability 330 MW 330 MW TTC with All Lines In Service 330 MW 330 MW</p>
<p>SCH-IMO-NYISO_LIMIT_950</p> <p>Thu 12/12/2019 to Fri 12/13/2019 2001 Continuous 1900</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import) SCH - OH - NY 1250 MW Impacts Total Transfer Capability 800 MW TTC with All Lines In Service 2050 MW</p>
<p>PIERCBRK-FIVEMILE_345_37</p> <p>Fri 12/13/2019 to Fri 12/13/2019 UPDATED by NGRID 12/05/2019 0800 Daily(No Weekends) 1530</p> <p>Work scheduled by: NGrid</p>	<p>FWD (Import) SCH - PJ - NY 2400 MW Impacts Total Transfer Capability 500 MW TTC with All Lines In Service 2900 MW</p>
<p>SCH-IMO-NYISO_LIMIT_300</p> <p>Sat 12/14/2019 to Sun 12/15/2019 UPDATED by IESO 12/10/2019 0500 Continuous 1900</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import) SCH - OH - NY 600 MW Impacts Total Transfer Capability 1450 MW TTC with All Lines In Service 2050 MW</p>
<p>DUNWODIE-MOTTHAVN_345_72</p> <p>Sat 12/14/2019 to Mon 12/16/2019 1256 Continuous 2359</p> <p>Work scheduled by: ConEd</p>	<p>FWD (Import) SPR/DUN-SOUTH 3800 MW Impacts Total Transfer Capability 800 MW TTC with All Lines In Service 4600 MW</p>
<p>WATRCURE-OAKDALE_345_31</p> <p>Sun 12/15/2019 to Sat 12/21/2019 UPDATED by NYSEG 12/11/2019 0800 Continuous 1700</p> <p>Work scheduled by: NYSEG</p>	<p>FWD (Import) SCH - PJ - NY 2750 MW Impacts Total Transfer Capability 150 MW TTC with All Lines In Service 2900 MW</p>

NYISO TRANSFER LIMITATIONS

Sunday ,December 15, 2019 to Tuesday ,June 15, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC1

Mon 12/16/2019 to Mon 12/16/2019
 0001 Continuous 0200
 Work scheduled by: HQ

FWD
 (Import)
MOSES SOUTH 2850 MW
 Impacts Total Transfer Capability 300 MW
 TTC with All Lines In Service 3150 MW

CHAT_DC_GC1

Mon 12/16/2019 to Mon 12/16/2019
 0001 Continuous 0200
 Work scheduled by: HQ

REV
 (Export)
SCH - HQ - NY 500 MW
 Impacts Total Transfer Capability 500 MW
 TTC with All Lines In Service 1000 MW

CHAT_DC_GC1 & CHAT_DC_GC2

Mon 12/16/2019 to Mon 12/16/2019
 0001 0200
 Work scheduled by:

FWD
 (Import)
MOSES SOUTH 2550 MW
 Impacts Total Transfer Capability 600 MW
 TTC with All Lines In Service 3150 MW

CHAT_DC_GC1 & CHAT_DC_GC2

Mon 12/16/2019 to Mon 12/16/2019
 0001 0200
 Work scheduled by:

FWD REV
 (Import) (Export)
SCH - HQ - NY 1370 MW 0 MW
 Impacts Total Transfer Capability 130 MW 1000 MW
 TTC with All Lines In Service 1500 MW 1000 MW

CHAT_DC_GC2

Mon 12/16/2019 to Mon 12/16/2019
 0001 Continuous 0200
 Work scheduled by: HQ

FWD
 (Import)
MOSES SOUTH 2850 MW
 Impacts Total Transfer Capability 300 MW
 TTC with All Lines In Service 3150 MW

CHAT_DC_GC2

Mon 12/16/2019 to Mon 12/16/2019
 0001 Continuous 0200
 Work scheduled by: HQ

REV
 (Export)
SCH - HQ - NY 500 MW
 Impacts Total Transfer Capability 500 MW
 TTC with All Lines In Service 1000 MW

SCH-HQ-NYISO_LIMIT_1150

Mon 12/16/2019 to Mon 12/16/2019
 0001 Continuous 0200
 Work scheduled by: HQ

FWD
 (Import)
SCH - HQ - NY 1150 MW
 Impacts Total Transfer Capability 350 MW
 TTC with All Lines In Service 1500 MW

NYISO TRANSFER LIMITATIONS

Sunday ,December 15, 2019 to Tuesday ,June 15, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					REV
SCH-NYISO-NE_LIMIT_800					(Export)
Mon 12/16/2019	to	Mon 12/23/2019	<u>CANCELLED</u>	<u>by NYISO</u>	<u>12/11/2019</u>
0001	Continuous	2359			
Work scheduled by: ISONE					1000 MW
					700 MW
					1700 MW
<hr/>					
MOSES__-ADIRNDCK_230_MA2					FWD
Mon 12/16/2019	to	Mon 12/16/2019	<u>CANCELLED</u>	<u>by NYPA</u>	<u>12/10/2019</u>
0700	Continuous	1500			
Work scheduled by: NYPA					(Import)
					2300 MW
					850 MW
					3150 MW
<hr/>					
EDIC__-FRASER__345_EF24-40					FWD
Mon 12/16/2019	to	Tue 12/17/2019			
0700	Continuous	1730			
Work scheduled by: NYPA					(Import)
					2500 MW
					475 MW
					2975 MW
<hr/>					
S.RIPLEY-DUNKIRK__230_68					
Mon 12/16/2019	to	Fri 12/20/2019	<u>UPDATED</u>	<u>by PJM</u>	<u>11/13/2019</u>
0900	Continuous	1500			
Work scheduled by: PJM					SCH - PJ - NY
					Impacts Total Transfer Capability
					TTC with All Lines In Service
<hr/>					
W49TH_ST-E13THSTA_345_M54					FWD
Tue 12/17/2019	to	Fri 12/20/2019	<u>UPDATED</u>	<u>by CE</u>	<u>12/15/2019</u>
0001	Continuous	0200			
Work scheduled by: ConEd					(Import)
					3800 MW
					800 MW
					4600 MW
<hr/>					
NEPTUNE_-DUFFYAVE_345_NEPTUNE					FWD
Tue 12/17/2019	to	Tue 12/17/2019			
0400	Continuous	0600			
Work scheduled by: LI					(Import)
					0 MW
					660 MW
					660 MW
<hr/>					
NEWBRDGE-DUFFYAVE_345_501					FWD
Tue 12/17/2019	to	Tue 12/17/2019			
0400	Continuous	0600			
Work scheduled by: LI					(Import)
					0 MW
					660 MW
					660 MW

NYISO TRANSFER LIMITATIONS

Sunday ,December 15, 2019 to Tuesday ,June 15, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
NEWBRDGE_345_138_BK_1			FWD
Tue 12/17/2019	to	Tue 12/17/2019	(Import)
0400	Continuous	0600	
Work scheduled by: LI			
		SCH - PJM_NEPTUNE	375 MW
		Impacts Total Transfer Capability	285 MW
		TTC with All Lines In Service	660 MW
<hr/>			
NEWBRDGE_345_138_BK_2			FWD
Tue 12/17/2019	to	Tue 12/17/2019	(Import)
0400	Continuous	0600	
Work scheduled by: LI			
		SCH - PJM_NEPTUNE	375 MW
		Impacts Total Transfer Capability	285 MW
		TTC with All Lines In Service	660 MW
<hr/>			
MOSES__-ADIRNDCK_230_MA1			FWD
Tue 12/17/2019	to	Fri 12/20/2019	(Import)
0700	Continuous	1500	
Work scheduled by: NYPA			
		<u>CANCELLED</u> by NYPA <u>12/10/2019</u>	
		MOSES SOUTH	2300 MW
		Impacts Total Transfer Capability	850 MW
		TTC with All Lines In Service	3150 MW
<hr/>			
PIERCBRK-FIVEMILE_345_37			FWD
Tue 12/17/2019	to	Thu 12/19/2019	(Import)
0730	Continuous	1630	
Work scheduled by: NGrid			
		SCH - PJ - NY	2400 MW
		Impacts Total Transfer Capability	500 MW
		TTC with All Lines In Service	2900 MW
<hr/>			
LINDEN__-GOETHALS_230_A2253			
Sat 12/28/2019	to	Sun 12/29/2019	
0001	Continuous	0300	
Work scheduled by: ConEd			
		<u>CANCELLED</u> by ConEd <u>12/13/2019</u>	
		SCH - PJ - NY	
		Impacts Total Transfer Capability	
		TTC with All Lines In Service	
<hr/>			
S.RIPLEY-DUNKIRK__230_68			
Mon 01/06/2020	to	Fri 01/10/2020	
0800	Continuous	1600	
Work scheduled by: NGrid			
		SCH - PJ - NY	
		Impacts Total Transfer Capability	
		TTC with All Lines In Service	
<hr/>			
FRASER__345_FRASER SVC			FWD
Mon 01/06/2020	to	Mon 01/20/2020	(Import)
0800	Continuous	1500	
Work scheduled by: NYSEG			
		<u>UPDATED</u> by NYSEG <u>11/27/2019</u>	
		CENTRAL EAST - VC	2935 MW
		Impacts Total Transfer Capability	40 MW
		TTC with All Lines In Service	2975 MW
<hr/>			

NYISO TRANSFER LIMITATIONS

Sunday ,December 15, 2019 to Tuesday ,June 15, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

OSWEGO__-VOLNEY__345_12		FWD	
Wed 01/08/2020 to Wed 01/08/2020		(Import)	
0830	Daily(No Weekends) 1130	OSWEGO EXPORT	5250 MW
Work scheduled by: NGrid		Impacts Total Transfer Capability	0 MW
		TTC with All Lines In Service	5250 MW
BECK____-NIAGARA__345_PA301		FWD	REV
Mon 01/13/2020 to Fri 01/17/2020		(Import)	(Export)
0500	Continuous 1530	SCH - OH - NY	1100 MW 950 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	950 MW 950 MW
		TTC with All Lines In Service	2050 MW 1900 MW
FROST_BR-LONG_MTN_345_352		FWD	
Mon 01/13/2020 to Sat 01/18/2020		(Import)	
0730	Continuous 1600	SCH - NE - NY	1300 MW
Work scheduled by: ISONE		Impacts Total Transfer Capability	100 MW
		TTC with All Lines In Service	1400 MW
RAMAPO__-BUCHAN_N_345_Y94		FWD	
Mon 02/03/2020 to Tue 02/04/2020		(Import)	
0001	Continuous 0230	CANCELLED by ConEd 12/10/2019	UPNY CONED
Work scheduled by: ConEd			4800 MW
		Impacts Total Transfer Capability	900 MW
		TTC with All Lines In Service	5700 MW
SPRNBRK_-TREMONT__345_X28		FWD	
Mon 02/17/2020 to Mon 02/17/2020		(Import)	
0001	Continuous 1800	UPDATED by CONED 12/05/2019	SPR/DUN-SOUTH
Work scheduled by: ConEd			4200 MW
		Impacts Total Transfer Capability	400 MW
		TTC with All Lines In Service	4600 MW
MOTTHAVN-RAINEY__345_Q11		FWD	
Sun 02/23/2020 to Sun 03/01/2020		(Import)	
0001	Continuous 0200	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability	800 MW
		TTC with All Lines In Service	4600 MW
NIAGARA_-PACKARD__230_62		FWD	REV
Fri 02/28/2020 to Fri 02/28/2020		(Import)	(Export)
0500	Continuous 1530	SCH - OH - NY	900 MW 1850 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	1150 MW 50 MW
		TTC with All Lines In Service	2050 MW 1900 MW

NYISO TRANSFER LIMITATIONS

Sunday ,December 15, 2019 to Tuesday ,June 15, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						
CHATGUAY-MASSENA__765_7040					FWD	
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)
0500	Continuous	1730				1550 MW
Work scheduled by: NYPA						MOSES SOUTH
						Impacts Total Transfer Capability 1600 MW
						TTC with All Lines In Service 3150 MW
<hr/>						
CHATGUAY-MASSENA__765_7040					FWD	REV
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import) (Export)
0500	Continuous	1730				0 MW 0 MW
Work scheduled by: NYPA						SCH - HQ - NY
						Impacts Total Transfer Capability 1500 MW 1000 MW
						TTC with All Lines In Service 1500 MW 1000 MW
<hr/>						
MARCY__765_345_AT1					FWD	
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)
0500	Continuous	1730				1750 MW
Work scheduled by: NYPA						MOSES SOUTH
						Impacts Total Transfer Capability 1400 MW
						TTC with All Lines In Service 3150 MW
<hr/>						
MARCY__765_345_AT2					FWD	
Mon 03/02/2020	to	Fri 03/06/2020				(Import)
0500	Continuous	1730				1700 MW
Work scheduled by: NYPA						MOSES SOUTH
						Impacts Total Transfer Capability 1450 MW
						TTC with All Lines In Service 3150 MW
<hr/>						
MASSENA_-MARCY__765_MSU1					FWD	
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)
0500	Continuous	1730				2265 MW
Work scheduled by: NYPA						CENTRAL EAST - VC
						Impacts Total Transfer Capability 710 MW
						TTC with All Lines In Service 2975 MW
<hr/>						
MASSENA_-MARCY__765_MSU1					FWD	
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)
0500	Continuous	1730				500 MW
Work scheduled by: NYPA						MOSES SOUTH
						Impacts Total Transfer Capability 2650 MW
						TTC with All Lines In Service 3150 MW
<hr/>						
MASSENA_-MARCY__765_MSU1					FWD	REV
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import) (Export)
0500	Continuous	1730				475 MW 1000 MW
Work scheduled by: NYPA						SCH - HQ - NY
						Impacts Total Transfer Capability 1025 MW 0 MW
						TTC with All Lines In Service 1500 MW 1000 MW
<hr/>						

NYISO TRANSFER LIMITATIONS

Sunday ,December 15, 2019 to Tuesday ,June 15, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA -MARCY 765_MSU1				FWD	
Mon 03/02/2020	to	Fri 03/06/2020	UPDATED by NYPA 08/08/2019	(Import)	
0500	Continuous	1730		SCH - HQ_CEDARS	90 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	109 MW
				TTC with All Lines In Service	199 MW
MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040				FWD	
Mon 03/02/2020	to	Fri 03/06/2020		(Import)	
0500		1730		MOSES SOUTH	500 MW
Work scheduled by:				Impacts Total Transfer Capability	2650 MW
				TTC with All Lines In Service	3150 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2				FWD	REV
Mon 03/02/2020	to	Fri 03/06/2020		(Import)	(Export)
0500		1730		SCH - HQ - NY	850 MW 0 MW
Work scheduled by:				Impacts Total Transfer Capability	650 MW 1000 MW
				TTC with All Lines In Service	1500 MW 1000 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2				FWD	
Mon 03/02/2020	to	Fri 03/06/2020		(Import)	
0500		1730		SCH - HQ_CEDARS	90 MW
Work scheduled by:				Impacts Total Transfer Capability	109 MW
				TTC with All Lines In Service	199 MW
STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1				FWD	
Mon 03/02/2020	to	Fri 03/06/2020		(Import)	
0500		1730		SCH - HQ_CEDARS	90 MW
Work scheduled by:				Impacts Total Transfer Capability	109 MW
				TTC with All Lines In Service	199 MW
STLAWRNC-MOSES 230_L33P & MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2				FWD	
Mon 03/02/2020	to	Fri 03/06/2020		(Import)	
0500		1730		SCH - HQ_CEDARS	90 MW
Work scheduled by:				Impacts Total Transfer Capability	109 MW
				TTC with All Lines In Service	199 MW
SHOR_NPX-SHOREHAM 138_CSC				FWD	REV
Mon 03/02/2020	to	Tue 03/03/2020		(Import)	(Export)
0600	Continuous	1300		SCH - NPX_CSC	0 MW 0 MW
Work scheduled by: LI				Impacts Total Transfer Capability	330 MW 330 MW
				TTC with All Lines In Service	330 MW 330 MW

NYISO TRANSFER LIMITATIONS

Sunday ,December 15, 2019 to Tuesday ,June 15, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROSETON_-EFISHKIL_345_RFK305

FWD

Mon 03/02/2020 to Fri 03/20/2020
0700 Continuous 1730

(Import)

Work scheduled by: NYPA

UPNY CONED **4800 MW**
Impacts Total Transfer Capability 900 MW
TTC with All Lines In Service 5700 MW

EASTVIEW-SPRNBK_345_W78

FWD

Fri 03/06/2020 to Sat 03/07/2020
0001 Continuous 0200

(Import)

Work scheduled by: ConEd

UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1350 MW
TTC with All Lines In Service 5700 MW

MILLWOOD-EASTVIEW_345_W85

FWD

Fri 03/06/2020 to Sat 03/07/2020
0001 Continuous 0200

(Import)

Work scheduled by: ConEd

UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1350 MW
TTC with All Lines In Service 5700 MW

SPRNBK_345KV_RNS3

FWD

Fri 03/06/2020 to Sat 03/07/2020
0001 Continuous 0200

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

MOSES_-ADIRNDCK_230_MAI

FWD

Sat 03/07/2020 to Fri 05/29/2020
0700 Continuous 1300

(Import)

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

VOLNEY_-MARCY_345_19

FWD

Tue 03/10/2020 to Tue 03/10/2020 **UPDATED by NYPA 09/24/2019**
0700 Continuous 1530

(Import)

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC **2825 MW**
Impacts Total Transfer Capability 150 MW
TTC with All Lines In Service 2975 MW

VOLNEY_-MARCY_345_19

FWD

Tue 03/10/2020 to Tue 03/10/2020 **UPDATED by NYPA 09/24/2019**
0700 Continuous 1530

(Import)

Work scheduled by: NYPA

ARR: 19

OSWEGO EXPORT **4900 MW**
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 5250 MW

NYISO TRANSFER LIMITATIONS

Sunday ,December 15, 2019 to Tuesday ,June 15, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROCHESTR-PANNELL__345_RP2

Sat 03/14/2020 to Mon 03/23/2020
 0500 Continuous 1700
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MARCY__345KV_CSC

Mon 03/16/2020 to Fri 03/27/2020
 0500 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2925 MW**
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 2975 MW

EASTVIEW-SPRNBK__345_W64

Sat 03/21/2020 to Sat 03/21/2020 **UPDATED by CONED 12/05/2019**
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

SPRNBK__345KV_RNS5

Sat 03/21/2020 to Sat 03/21/2020 **UPDATED by CONED 12/05/2019**
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

MILLWOOD-EASTVIEW_345_W99

Sat 03/21/2020 to Sun 03/22/2020 **UPDATED by CONED 12/05/2019**
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

EASTVIEW-SPRNBK__345_W64

Sun 03/22/2020 to Sun 03/22/2020 **UPDATED by CONED 12/05/2019**
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

SPRNBK__345KV_RNS5

Sun 03/22/2020 to Sun 03/22/2020 **UPDATED by CONED 12/05/2019**
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,December 15, 2019 to Tuesday ,June 15, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-KINTIGH_345_NS1-38				FWD	
Fri 03/27/2020	to	Fri 03/27/2020		(Import)	
0600	Continuous	1530		DYSINGER EAST	1700 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1450 MW
				TTC with All Lines In Service	3150 MW
BECK_-PACKARD_230_BP76				FWD	REV
Fri 03/27/2020	to	Fri 03/27/2020		(Import)	(Export)
0800	Daily(No Weekends)	1600		SCH - OH - NY	1650 MW 1400 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	400 MW 500 MW
				TTC with All Lines In Service	2050 MW 1900 MW
MARCY_-EDIC_345_UE1-7				FWD	
Tue 03/31/2020	to	Tue 03/31/2020	UPDATED by NYPA 09/24/2019	(Import)	
0700	Continuous	1530		OSWEGO EXPORT	5250 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	0 MW
				TTC with All Lines In Service	5250 MW
RAMAPO_-LADENTWN_345_W72				FWD	
Wed 04/01/2020	to	Thu 04/02/2020		(Import)	
0001	Continuous	1830		UPNY CONED	4400 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	1300 MW
				TTC with All Lines In Service	5700 MW
FRASANX-COOPERS_345_UCC2-41				FWD	
Wed 04/01/2020	to	Thu 04/02/2020	UPDATED by NYPA 11/12/2019	(Import)	
0700	Continuous	1530		CENTRAL EAST - VC	2500 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	475 MW
				TTC with All Lines In Service	2975 MW
MARCY_-FRASANX_345_UCC2-41				FWD	
Wed 04/01/2020	to	Thu 04/02/2020	UPDATED by NYPA 11/12/2019	(Import)	
0700	Continuous	1530		CENTRAL EAST - VC	2500 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	475 MW
				TTC with All Lines In Service	2975 MW
LINDN_CG-LNDVFT_345_V-3022				FWD	REV
Sun 04/05/2020	to	Sat 04/11/2020		(Import)	(Export)
1400	Continuous	1400		SCH - PJM_VFT	0 MW 0 MW
Work scheduled by: PJM				Impacts Total Transfer Capability	315 MW 315 MW
				TTC with All Lines In Service	315 MW 315 MW

NYISO TRANSFER LIMITATIONS

Sunday ,December 15, 2019 to Tuesday ,June 15, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___-N.SCTLND_345_18

Tue 04/07/2020 to Wed 04/08/2020
0700 Continuous 1530

Work scheduled by: NYPA

UPDATED by NYPA 09/24/2019

ARR: 19

FWD

(Import)

CENTRAL EAST - VC **2090 MW**
Impacts Total Transfer Capability 885 MW
TTC with All Lines In Service 2975 MW

PLSNTVLY-EFISHKIL_345_F36

Mon 04/13/2020 to Tue 04/14/2020
0001 Continuous 0200

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1700 MW
TTC with All Lines In Service 5700 MW

SAND_BAR-PLATSBRG_115_PV20

Mon 04/13/2020 to Tue 04/14/2020
0600 Daily 1800

Work scheduled by: ISONE

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FRASER_-GILBOA___345_GF5-35

Mon 04/13/2020 to Wed 04/22/2020
0700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC **2650 MW**
Impacts Total Transfer Capability 325 MW
TTC with All Lines In Service 2975 MW

NIAGARA_-ROCHESTR_345_NR2

Wed 04/15/2020 to Fri 05/01/2020
0500 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

ROCHESTR-PANNELL___345_RP1

Mon 04/20/2020 to Fri 04/24/2020
0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

DOLSONAV-ROCKTVRN_345_DART44

Mon 04/27/2020 to Sun 05/10/2020
0700 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 03/21/2019

FWD

(Import)

CENTRAL EAST - VC **2720 MW**
Impacts Total Transfer Capability 255 MW
TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Sunday ,December 15, 2019 to Tuesday ,June 15, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						FWD
HURLYAVE-ROSETON__345_303						(Import)
Mon 04/27/2020	to	Fri 05/29/2020	<u>UPDATED</u>	<u>by CHGE</u>	<u>10/09/2019</u>	
0800	Continuous	1600				UPNY CONED 4100 MW
Work scheduled by: CHGE						Impacts Total Transfer Capability 1600 MW
						TTC with All Lines In Service 5700 MW
<hr/>						FWD
SCH-IMO-NYISO_LIMIT_1600						(Import)
Fri 05/01/2020	to	Sat 10/31/2020	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	
0001	Continuous	2359				SCH - OH - NY 1900 MW
Work scheduled by: IESO						Impacts Total Transfer Capability 0 MW
						TTC with All Lines In Service 1900 MW
<hr/>						FWD
PANNELL_-CLAY_____345_2						(Import)
Mon 05/04/2020	to	Fri 05/08/2020				WEST CENTRAL 1300 MW
0700	Continuous	1530				Impacts Total Transfer Capability 950 MW
Work scheduled by: NYPA						TTC with All Lines In Service 2250 MW
<hr/>						FWD
NEPTUNE_-DUFFYAVE_345_NEPTUNE						(Import)
Mon 05/04/2020	to	Mon 05/18/2020				SCH - PJM_NEPTUNE 0 MW
0800	Continuous	1700				Impacts Total Transfer Capability 660 MW
Work scheduled by: PJM						TTC with All Lines In Service 660 MW
<hr/>						FWD
NEWBRDGE-DUFFYAVE_345_501						(Import)
Mon 05/04/2020	to	Mon 05/18/2020				SCH - PJM_NEPTUNE 0 MW
0800	Continuous	1700				Impacts Total Transfer Capability 660 MW
Work scheduled by: PJM						TTC with All Lines In Service 660 MW
<hr/>						FWD
NEWBRDGE_345_138_BK_1						(Import)
Mon 05/04/2020	to	Mon 05/18/2020				SCH - PJM_NEPTUNE 375 MW
0800	Continuous	1700				Impacts Total Transfer Capability 285 MW
Work scheduled by: PJM						TTC with All Lines In Service 660 MW
<hr/>						FWD
NEWBRDGE_345_138_BK_2						(Import)
Mon 05/04/2020	to	Mon 05/18/2020				SCH - PJM_NEPTUNE 375 MW
0800	Continuous	1700				Impacts Total Transfer Capability 285 MW
Work scheduled by: PJM						TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Sunday ,December 15, 2019 to Tuesday ,June 15, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PANNELL_-CLAY_____345_1				FWD	
Mon 05/11/2020	to	Fri 05/15/2020		(Import)	
0700	Continuous	1530	WEST CENTRAL	1300 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	950 MW	
			TTC with All Lines In Service	2250 MW	
COOPERS_-DOLSONAV_345_CCDA42				FWD	
Mon 05/11/2020	to	Fri 05/29/2020	<u>UPDATED</u> <u>by NYPA</u> <u>03/21/2019</u>	(Import)	
0700	Continuous	1730	CENTRAL EAST - VC	2720 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	255 MW	
			TTC with All Lines In Service	2975 MW	
KINTIGH_-ROCHESTR_345_SRI-39				FWD	
Mon 05/18/2020	to	Fri 05/22/2020		(Import)	
0500	Continuous	1530	DYSINGER EAST	1400 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1750 MW	
			TTC with All Lines In Service	3150 MW	
MOSES_-ADIRNDCK_230_MA2				FWD	
Mon 06/01/2020	to	Fri 07/31/2020		(Import)	
0700	Continuous	1730	MOSES SOUTH	2100 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1050 MW	
			TTC with All Lines In Service	3150 MW	
NIAGARA_345_230_AT4				REV	
Mon 06/29/2020	to	Tue 06/30/2020		(Export)	
0500	Continuous	1530	SCH - OH - NY	1400 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	300 MW	
			TTC with All Lines In Service	1700 MW	
SCH-IMO-NYISO_NIAG_CB_3008_W/BB				FWD	REV
Mon 07/27/2020	to	Fri 08/07/2020		(Import)	(Export)
0500	Continuous	1530	SCH - OH - NY	1900 MW	1450 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	0 MW	250 MW
			TTC with All Lines In Service	1900 MW	1700 MW
CHATGUAY-MASSENA_765_7040				FWD	
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u> <u>by NYPA</u> <u>08/08/2019</u>	(Import)	
0500	Continuous	1730	MOSES SOUTH	1550 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1600 MW	
			TTC with All Lines In Service	3150 MW	

NYISO TRANSFER LIMITATIONS

Sunday ,December 15, 2019 to Tuesday ,June 15, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						FWD	REV
CHATGUAY-MASSENA__765_7040						(Import)	(Export)
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>		
0500	Continuous	1730				SCH - HQ - NY	0 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	1500 MW
						TTC with All Lines In Service	1500 MW
<hr/>						FWD	REV
MARCY__765_345_AT1						(Import)	(Export)
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>		
0500	Continuous	1730				MOSES SOUTH	1750 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	1400 MW
						TTC with All Lines In Service	3150 MW
<hr/>						FWD	REV
MASSENA_-MARCY__765_MSU1						(Import)	(Export)
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>		
0500	Continuous	1730				CENTRAL EAST - VC	2265 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	710 MW
						TTC with All Lines In Service	2975 MW
<hr/>						FWD	REV
MASSENA_-MARCY__765_MSU1						(Import)	(Export)
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>		
0500	Continuous	1730				MOSES SOUTH	500 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	2650 MW
						TTC with All Lines In Service	3150 MW
<hr/>						FWD	REV
MASSENA_-MARCY__765_MSU1						(Import)	(Export)
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>		
0500	Continuous	1730				SCH - HQ - NY	475 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	1025 MW
						TTC with All Lines In Service	1500 MW
<hr/>						FWD	REV
MASSENA_-MARCY__765_MSU1						(Import)	(Export)
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>		
0500	Continuous	1730				SCH - HQ_CEDARS	90 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	190 MW
<hr/>						FWD	REV
MASSENA_-MARCY__765_MSU1 & CHATGUAY-MASSENA__765_7040						(Import)	(Export)
Sat 08/01/2020	to	Sun 08/02/2020					
0500		1730				MOSES SOUTH	500 MW
Work scheduled by:						Impacts Total Transfer Capability	2650 MW
						TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,December 15, 2019 to Tuesday ,June 15, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES ___-MASSENA___ 230_MMS1 & MOSES ___-MASSENA___ 230_MMS2	FWD	REV
Sat 08/01/2020 to Sun 08/02/2020	(Import)	(Export)
0500 1730	SCH - HQ - NY	850 MW 0 MW
Work scheduled by:	Impacts Total Transfer Capability	650 MW 1000 MW
	TTC with All Lines In Service	1500 MW 1000 MW
<hr/>		
MOSES ___-MASSENA___ 230_MMS1 & MOSES ___-MASSENA___ 230_MMS2	FWD	
Sat 08/01/2020 to Sun 08/02/2020	(Import)	
0500 1730	SCH - HQ_CEDARS	90 MW
Work scheduled by:	Impacts Total Transfer Capability	100 MW
	TTC with All Lines In Service	190 MW
<hr/>		
STLAWRNC-MOSES___ 230_L33P & MASSENA_-MARCY___ 765_MSU1	FWD	
Sat 08/01/2020 to Sun 08/02/2020	(Import)	
0500 1730	SCH - HQ_CEDARS	90 MW
Work scheduled by:	Impacts Total Transfer Capability	100 MW
	TTC with All Lines In Service	190 MW
<hr/>		
STLAWRNC-MOSES___ 230_L33P & MOSES ___-MASSENA___ 230_MMS1 & MOSES ___-MASSENA___ 230_MMS2	FWD	
Sat 08/01/2020 to Sun 08/02/2020	(Import)	
0500 1730	SCH - HQ_CEDARS	90 MW
Work scheduled by:	Impacts Total Transfer Capability	100 MW
	TTC with All Lines In Service	190 MW
<hr/>		
MOSES ___-ADIRNDCK___ 230_MA2	FWD	
Mon 08/03/2020 to Sun 09/13/2020	(Import)	
0700 Continuous 1730	MOSES SOUTH	2100 MW
Work scheduled by: NYPA	Impacts Total Transfer Capability	1050 MW
	TTC with All Lines In Service	3150 MW
<hr/>		
FRASANNX-COOPERS___ 345_UCC2-41	FWD	
Mon 09/07/2020 to Fri 10/23/2020	(Import)	
0700 Continuous 1730	CENTRAL EAST - VC	2500 MW
Work scheduled by: NYPA	Impacts Total Transfer Capability	475 MW
	TTC with All Lines In Service	2975 MW
		ARR: 19
<hr/>		
MARCY ___-FRASANNX___ 345_UCC2-41	FWD	
Mon 09/07/2020 to Fri 10/23/2020	(Import)	
0700 Continuous 1730	CENTRAL EAST - VC	2500 MW
Work scheduled by: NYPA	Impacts Total Transfer Capability	475 MW
	TTC with All Lines In Service	2975 MW
		ARR: 19

NYISO TRANSFER LIMITATIONS

Sunday ,December 15, 2019 to Tuesday ,June 15, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT1

Mon 09/14/2020 to Mon 09/14/2020
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1750 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 3150 MW

NIAGARA_-KINTIGH_345_NS1-38

Mon 09/14/2020 to Thu 09/17/2020
0500 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

MOSES_-ADIRNDCK_230_MA2

Tue 09/15/2020 to Sat 11/14/2020
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

NIAGARA_-ROCHESTR_345_NR2

Fri 09/18/2020 to Sat 11/14/2020
0500 Continuous 2330

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

CLAY_-EDIC___345_1-16

Mon 09/21/2020 to Fri 09/25/2020
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
OSWEGO EXPORT **4850 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 5250 MW

ROSETON_-ROCKTVRN_345_311

Mon 09/21/2020 to Fri 10/23/2020 **UPDATED by CHGE 10/09/2019**
0800 Continuous 1600

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4400 MW**
Impacts Total Transfer Capability 1300 MW
TTC with All Lines In Service 5700 MW

DUNWODIE_345KV_3

Fri 09/25/2020 to Fri 09/25/2020 **UPDATED by CONED 09/05/2019**
0001 Continuous 0030

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,December 15, 2019 to Tuesday ,June 15, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_5

Fri 09/25/2020 to Fri 09/25/2020
0001 Continuous 0030

Work scheduled by: ConEd

UPDATED by CONED 09/05/2019

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD
(Import)

DUNWODIE-MOTTHAVN_345_71

Fri 09/25/2020 to Fri 10/30/2020
0001 Continuous 0300

Work scheduled by: ConEd

UPDATED by CONED 09/05/2019

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD
(Import)

CLAY -EDIC 345_2-15

Mon 09/28/2020 to Fri 10/02/2020
0700 Continuous 1530

Work scheduled by: NYPA

OSWEGO EXPORT **4850 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 5250 MW

FWD
(Import)

SAND_BAR-PLATSBRG_115_PV20

Sat 10/17/2020 to Sat 11/14/2020
0600 Continuous 1800

Work scheduled by: ISONE

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

LEEDS -HURLYAVE_345_301

Mon 10/26/2020 to Fri 12/04/2020
0800 Continuous 1600

Work scheduled by: CHGE

UPNY CONED **4100 MW**
Impacts Total Transfer Capability 1600 MW
TTC with All Lines In Service 5700 MW

FWD
(Import)

DUNWODIE_345KV_3

Fri 10/30/2020 to Fri 10/30/2020
0230 Continuous 0300

Work scheduled by: ConEd

UPDATED by CONED 09/05/2019

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD
(Import)

DUNWODIE_345KV_5

Fri 10/30/2020 to Fri 10/30/2020
0230 Continuous 0300

Work scheduled by: ConEd

UPDATED by CONED 09/05/2019

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD
(Import)

NYISO TRANSFER LIMITATIONS

Sunday ,December 15, 2019 to Tuesday ,June 15, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO-NYISO_LIMIT_1750					FWD	
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Import)
0001	Continuous	2359				2050 MW
Work scheduled by: IESO					SCH - OH - NY	0 MW
					Impacts Total Transfer Capability	2050 MW
					TTC with All Lines In Service	2050 MW
SCH-NYISO-IMO_LIMIT_1600					REV	
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Export)
0001	Continuous	2359				1900 MW
Work scheduled by: IESO					SCH - OH - NY	0 MW
					Impacts Total Transfer Capability	1900 MW
					TTC with All Lines In Service	1900 MW
CHATGUAY-MASSENA__765_7040					FWD	
Sun 11/15/2020	to	Mon 11/30/2020				(Import)
0100	Continuous	1900				1550 MW
Work scheduled by: NYPA					MOSES SOUTH	1600 MW
					Impacts Total Transfer Capability	3150 MW
					TTC with All Lines In Service	3150 MW
CHATGUAY-MASSENA__765_7040					FWD	REV
Sun 11/15/2020	to	Mon 11/30/2020				(Import) (Export)
0100	Continuous	1900				0 MW 0 MW
Work scheduled by: NYPA					SCH - HQ - NY	1500 MW 1000 MW
					Impacts Total Transfer Capability	1500 MW 1000 MW
					TTC with All Lines In Service	1500 MW 1000 MW
MARCY___765_345_AT1					FWD	
Sun 11/15/2020	to	Mon 11/30/2020				(Import)
0100	Continuous	1900				1750 MW
Work scheduled by: NYPA					MOSES SOUTH	1400 MW
					Impacts Total Transfer Capability	3150 MW
					TTC with All Lines In Service	3150 MW
MARCY___765_345_AT2					FWD	
Sun 11/15/2020	to	Mon 11/30/2020				(Import)
0100	Continuous	1900				1700 MW
Work scheduled by: NYPA					MOSES SOUTH	1450 MW
					Impacts Total Transfer Capability	3150 MW
					TTC with All Lines In Service	3150 MW
MASSENA_-MARCY___765_MSU1					FWD	
Sun 11/15/2020	to	Mon 11/30/2020				(Import)
0100	Continuous	1900				2265 MW
Work scheduled by: NYPA					CENTRAL EAST - VC	710 MW
					Impacts Total Transfer Capability	2975 MW
					TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Sunday ,December 15, 2019 to Tuesday ,June 15, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Transfer Description	Start	End	Time	Day	Impact	TTC	FWD	REV
MASSENA -MARCY 765_MSU1	Sun 11/15/2020	Mon 11/30/2020	0100	Continuous	1900	MOSES SOUTH	500 MW	
Work scheduled by: NYPA								
						Impacts Total Transfer Capability	2650 MW	
						TTC with All Lines In Service	3150 MW	
MASSENA -MARCY 765_MSU1	Sun 11/15/2020	Mon 11/30/2020	0100	Continuous	1900	SCH - HQ - NY	475 MW	1000 MW
Work scheduled by: NYPA								
						Impacts Total Transfer Capability	1025 MW	0 MW
						TTC with All Lines In Service	1500 MW	1000 MW
MASSENA -MARCY 765_MSU1	Sun 11/15/2020	Mon 11/30/2020	0100	Continuous	1900	SCH - HQ_CEDARS	90 MW	
Work scheduled by: NYPA								
						Impacts Total Transfer Capability	109 MW	
						TTC with All Lines In Service	199 MW	
MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040	Sun 11/15/2020	Mon 11/30/2020	0100		1900	MOSES SOUTH	500 MW	
Work scheduled by:								
						Impacts Total Transfer Capability	2650 MW	
						TTC with All Lines In Service	3150 MW	
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2	Sun 11/15/2020	Mon 11/30/2020	0100		1900	SCH - HQ - NY	850 MW	0 MW
Work scheduled by:								
						Impacts Total Transfer Capability	650 MW	1000 MW
						TTC with All Lines In Service	1500 MW	1000 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2	Sun 11/15/2020	Mon 11/30/2020	0100		1900	SCH - HQ_CEDARS	90 MW	
Work scheduled by:								
						Impacts Total Transfer Capability	109 MW	
						TTC with All Lines In Service	199 MW	
STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1	Sun 11/15/2020	Mon 11/30/2020	0100		1900	SCH - HQ_CEDARS	90 MW	
Work scheduled by:								
						Impacts Total Transfer Capability	109 MW	
						TTC with All Lines In Service	199 MW	

NYISO TRANSFER LIMITATIONS

Sunday ,December 15, 2019 to Tuesday ,June 15, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STLAWRNC-MOSES_230_L33P & MOSES_-MASSENA_230_MMS1 & MOSES_-MASSENA_230_MMS2	FWD (Import)
Sun 11/15/2020 to Mon 11/30/2020 0100 to 1900	SCH - HQ_CEDARS 90 MW Impacts Total Transfer Capability 109 MW TTC with All Lines In Service 199 MW
Work scheduled by:	
PLSNTVLE-DUNWODIE_345_W89	FWD (Import)
Mon 11/16/2020 to Mon 11/16/2020 0001 Continuous 0030	UPNY CONED 4000 MW Impacts Total Transfer Capability 1700 MW TTC with All Lines In Service 5700 MW
Work scheduled by: ConEd	
PLSNTVLE-DUNWODIE_345_W89	FWD (Import)
Thu 11/26/2020 to Thu 11/26/2020 0230 Continuous 0300	UPNY CONED 4000 MW Impacts Total Transfer Capability 1700 MW TTC with All Lines In Service 5700 MW
Work scheduled by: ConEd	
MOSES_-ADIRNDCK_230_MA1	FWD (Import)
Tue 12/01/2020 to Mon 05/31/2021 0700 Continuous 1300	MOSES SOUTH 2300 MW Impacts Total Transfer Capability 850 MW TTC with All Lines In Service 3150 MW
Work scheduled by: NYPA	
SAND_BAR-PLATSBURG_115_PV20	
Mon 12/07/2020 to Fri 12/11/2020 0700 Continuous 1530	SCH - NE - NY Impacts Total Transfer Capability TTC with All Lines In Service
Work scheduled by: NYPA	
SAND_BAR-PLATSBURG_115_PV20	
Mon 12/14/2020 to Fri 12/18/2020 0700 Continuous 1530	SCH - NE - NY Impacts Total Transfer Capability TTC with All Lines In Service
Work scheduled by: NYPA	
MOTTHAVN-RAINEY_345_Q11	FWD (Import)
Mon 03/01/2021 to Tue 04/06/2021 0001 Continuous 0700	SPR/DUN-SOUTH 3800 MW Impacts Total Transfer Capability 800 MW TTC with All Lines In Service 4600 MW
Work scheduled by: ConEd	

NYISO TRANSFER LIMITATIONS

Sunday ,December 15, 2019 to Tuesday ,June 15, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CLAY -EDIC 345_2-15

Mon 03/29/2021 to Fri 04/16/2021
 0800 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 OSWEGO EXPORT **4850 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 5250 MW

SCH-IMO-NYISO_LIMIT_1600

Sat 05/01/2021 to Sun 10/31/2021 UPDATED by IESO 05/03/2019
 0001 Continuous 2359
 Work scheduled by: IESO

FWD
 (Import)
 SCH - OH - NY **1900 MW**
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 1900 MW

PANNELL -CLAY 345_2

Mon 05/03/2021 to Fri 05/28/2021
 0700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 WEST CENTRAL **1300 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

MOSES -ADIRNDCK_230_MA2

Tue 06/01/2021 to Sun 11/14/2021
 0700 Continuous 1300
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2100 MW**
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW