

# NYISO TRANSFER LIMITATIONS

Thursday ,January 23, 2020 to Saturday ,July 24, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**HUDSONP\_-FARRAGUT\_345\_B3402**

Mon 01/15/2018 to Fri 05/01/2020 **EXTENDED** **by CONED** **10/08/2019**  
 0001 Continuous 2359  
 Work scheduled by: ConEd

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

-----  
**HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_-FARRAGUT\_345\_C3403**

Mon 01/15/2018 to Fri 05/01/2020  
 0001 2359  
 Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2550 MW</b>	<b>1600 MW</b>
Impacts Total Transfer Capability	350 MW	250 MW
TTC with All Lines In Service	2900 MW	1850 MW

-----  
**MARION\_-FARRAGUT\_345\_C3403**

Mon 01/15/2018 to Fri 05/01/2020 **EXTENDED** **by CONED** **10/08/2019**  
 0001 Continuous 2359  
 Work scheduled by: ConEd

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

-----  
**STLAWRNC-MOSES\_230\_L33P**

Mon 04/30/2018 to Fri 12/31/2021 **EXT FORCE** **by IESO** **08/21/2018**  
 0456 Continuous 2359  
 Work scheduled by: IESO

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

-----  
**SCH-IMO-NYISO\_LIMIT\_1750**

Fri 11/01/2019 to Thu 04/30/2020 **UPDATED** **by IESO** **05/03/2019**  
 0001 Continuous 2359  
 Work scheduled by: IESO

	FWD
	(Import)
SCH - OH - NY	<b>2050 MW</b>
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	2050 MW

-----  
**SCH-NYISO-IMO\_LIMIT\_1600**

Fri 11/01/2019 to Thu 04/30/2020 **UPDATED** **by IESO** **05/03/2019**  
 0001 Continuous 2359  
 Work scheduled by: IESO

	REV
	(Export)
SCH - OH - NY	<b>1900 MW</b>
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	1900 MW

-----  
**SCH-NYISO-NE\_LIMIT\_1500**

Fri 11/01/2019 to Thu 04/30/2020  
 0001 Continuous 2359  
 Work scheduled by: NYISO

	REV
	(Export)
SCH - NE - NY	<b>1700 MW</b>
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	1700 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,January 23, 2020 to Saturday ,July 24, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>OSWEGO_COMPLEX_AVR_O/S</b>					FWD	
Mon 11/18/2019	to	Mon 03/09/2020	<b>EXT FORCE</b>	<b>by GEN</b>	<b>12/26/2019</b>	(Import)
0221	Continuous	0001				CENTRAL EAST - VC <b>2870 MW</b>
Work scheduled by: Gen					Impacts Total Transfer Capability	105 MW
					TTC with All Lines In Service	2975 MW
<b>DUNWODIE_345KV_6</b>					FWD	
Tue 12/03/2019	to	Thu 02/06/2020	<b>EXT FORCE</b>	<b>by CONED</b>	<b>12/27/2019</b>	(Import)
0048	Continuous	2359				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>DUNWODIE_345KV_8</b>					FWD	
Tue 12/03/2019	to	Thu 02/06/2020	<b>EXT FORCE</b>	<b>by CONED</b>	<b>12/27/2019</b>	(Import)
0048	Continuous	2359				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>PLSNTVLE-DUNWODIE_345_W90</b>					FWD	
Tue 12/03/2019	to	Thu 02/06/2020	<b>EXT FORCE</b>	<b>by CONED</b>	<b>12/27/2019</b>	(Import)
0107	Continuous	2359				UPNY CONED <b>4000 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	1700 MW
					TTC with All Lines In Service	5700 MW
<b>CHAT_DC_GC2</b>					FWD	
Thu 12/26/2019	to	Mon 01/20/2020	<b>EXTENDED</b>	<b>by HQ</b>	<b>01/13/2020</b>	(Import)
1827	Continuous	2359				MOSES SOUTH <b>2850 MW</b>
Work scheduled by: HQ					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW
<b>CHAT_DC_GC2</b>					REV	
Thu 12/26/2019	to	Mon 01/20/2020	<b>EXTENDED</b>	<b>by HQ</b>	<b>01/13/2020</b>	(Export)
1827	Continuous	2359				SCH - HQ - NY <b>500 MW</b>
Work scheduled by: HQ					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1000 MW
<b>SCH-HQ-NYISO_LIMIT_1200</b>					FWD	
Fri 01/03/2020	to	Mon 01/20/2020	<b>EXTENDED</b>	<b>by HQ</b>	<b>01/13/2020</b>	(Import)
1430	Continuous	2359				SCH - HQ - NY <b>1200 MW</b>
Work scheduled by: HQ					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	1500 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,January 23, 2020 to Saturday ,July 24, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>FRASER___345_FRASER SVC</b>					FWD	
Mon 01/13/2020	to	Mon 01/27/2020	<u>UPDATED</u>	<u>by NYSEG</u>	<u>12/18/2019</u>	(Import)
0800	Continuous	1500				CENTRAL EAST - VC <b>2935 MW</b>
Work scheduled by: NYSEG					Impacts Total Transfer Capability 40 MW	
					TTC with All Lines In Service 2975 MW	
<b>FROST_BR-LONG MTN_345_352</b>					FWD	
Mon 01/20/2020	to	Thu 01/23/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>01/14/2020</u>	(Import)
0100	Continuous	1600				SCH - NE - NY <b>1300 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability 100 MW	
					TTC with All Lines In Service 1400 MW	
<b>SCH-NE-NYISO_LIMIT_300</b>					FWD	
Mon 01/20/2020	to	Thu 01/23/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>01/14/2020</u>	(Import)
0100	Continuous	1600				SCH - NE - NY <b>500 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability 900 MW	
					TTC with All Lines In Service 1400 MW	
<b>SCH-NE-NYISO_LIMIT_500</b>					FWD	
Wed 01/22/2020	to	Thu 01/23/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>01/23/2020</u>	(Import)
0500	Continuous	1159				SCH - NE - NY <b>700 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability 700 MW	
					TTC with All Lines In Service 1400 MW	
<b>W49TH_ST-E13THSTA_345_M54</b>					FWD	
Fri 01/24/2020	to	Fri 01/24/2020	<u>CANCELLED</u>	<u>by ConEd</u>	<u>01/22/2020</u>	(Import)
0001	Continuous	0500				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW	
					TTC with All Lines In Service 4600 MW	
<b>SCH-IMO-NYISO_LIMIT_900</b>					FWD	
Fri 01/24/2020	to	Fri 01/24/2020				(Import)
0500	Continuous	1530				SCH - OH - NY <b>1200 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 850 MW	
					TTC with All Lines In Service 2050 MW	
<b>SCH-IMO-NYISO_LIMIT_1400</b>					FWD	
Sat 01/25/2020	to	Sat 01/25/2020				(Import)
0500	Continuous	1700				SCH - OH - NY <b>1700 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 350 MW	
					TTC with All Lines In Service 2050 MW	

# NYISO TRANSFER LIMITATIONS

Thursday ,January 23, 2020 to Saturday ,July 24, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**S.RIPLEY-DUNKIRK\_\_230\_68**

Wed 01/29/2020 to Wed 01/29/2020  
 0600 Daily(No Weekends) 1830  
 Work scheduled by: NGrid

**UPDATED by NYISO 01/23/2020**

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**BERKSHIR-ALPS\_\_\_\_\_345\_393**

Wed 01/29/2020 to Sat 02/08/2020  
 1301 Continuous 1600  
 Work scheduled by: ISONE

**ARR: 78**

	FWD	REV
	(Import)	(Export)
SCH - NE - NY	<b>1150 MW</b>	<b>1700 MW</b>
Impacts Total Transfer Capability	250 MW	0 MW
TTC with All Lines In Service	1400 MW	1700 MW

**BERKSHIR-ALPS\_\_\_\_\_345\_393**

Wed 01/29/2020 to Sat 02/08/2020  
 1301 Continuous 1600  
 Work scheduled by: ISONE

**ARR: 78**

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

**BERKSHIR-ALPS\_\_\_\_\_345\_393 & BERKSHIR-NORTHFLD\_345\_312**

Wed 01/29/2020 to Sat 02/08/2020  
 1301 1600  
 Work scheduled by:

**ARR: 78**

	FWD	REV
	(Import)	(Export)
SCH - NE - NY	<b>1150 MW</b>	<b>1700 MW</b>
Impacts Total Transfer Capability	250 MW	0 MW
TTC with All Lines In Service	1400 MW	1700 MW

**BERKSHIR-NORTHFLD\_345\_312**

Wed 01/29/2020 to Sat 02/08/2020  
 1301 Continuous 1600  
 Work scheduled by: ISONE

	FWD
	(Import)
SCH - NE - NY	<b>1400 MW</b>
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	1400 MW

**BERKSHIR-NORTHFLD\_345\_312**

Wed 01/29/2020 to Sat 02/08/2020  
 1301 Continuous 1600  
 Work scheduled by: ISONE

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

**SCH-NE-NYISO\_LIMIT\_700**

Wed 01/29/2020 to Sat 02/08/2020  
 1301 Continuous 1600  
 Work scheduled by: ISONE

	FWD
	(Import)
SCH - NE - NY	<b>900 MW</b>
Impacts Total Transfer Capability	500 MW
TTC with All Lines In Service	1400 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,January 23, 2020 to Saturday ,July 24, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-NE\_LIMIT\_500

Wed 01/29/2020 to Sat 02/08/2020  
 1301 Continuous 1600  
 Work scheduled by: ISONE

REV  
 (Export)  
**700 MW**  
 SCH - NE - NY  
 Impacts Total Transfer Capability 1000 MW  
 TTC with All Lines In Service 1700 MW

S.RIPLEY-DUNKIRK\_230\_68

Thu 01/30/2020 to Thu 01/30/2020 **UPDATED by NYISO 01/23/2020**  
 0630 Daily(No Weekends) 1830  
 Work scheduled by: NGrid

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

RAMAPO\_-BUCHAN\_N\_345\_Y94

Mon 02/03/2020 to Tue 02/04/2020  
 0001 Continuous 0230  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4800 MW**  
 Impacts Total Transfer Capability 900 MW  
 TTC with All Lines In Service 5700 MW

PLSNTVLY\_345KV\_RNS4

Mon 02/03/2020 to Tue 02/04/2020  
 0001 Continuous 2200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 1900 MW  
 TTC with All Lines In Service 5700 MW

BECK\_-NIAGARA\_230\_PA27

Mon 02/03/2020 to Thu 02/13/2020  
 0500 Continuous 1700  
 Work scheduled by: IESO

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

MOSES\_-ADIRNDCK\_230\_MA1

Mon 02/03/2020 to Fri 02/07/2020  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

EFISHKIL-WOOD\_ST\_345\_F39

Mon 02/10/2020 to Mon 02/10/2020  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,January 23, 2020 to Saturday ,July 24, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

WOOD\_ST\_-PLSNTVLE\_345\_Y87

Mon 02/10/2020 to Wed 02/12/2020  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

MOSES\_-ADIRNDCK\_230\_MAI

Mon 02/10/2020 to Fri 02/14/2020  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

HURLYAVE-ROSETON\_345\_303

Tue 02/11/2020 to Thu 02/13/2020  
 0700 Continuous 1600  
 Work scheduled by: CHGE

FWD  
 (Import)  
 UPNY CONED **4100 MW**  
 Impacts Total Transfer Capability 1600 MW  
 TTC with All Lines In Service 5700 MW

EFISHKIL-WOOD\_ST\_345\_F39

Wed 02/12/2020 to Wed 02/12/2020  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

EFISHKIL-WOOD\_ST\_345\_F38

Fri 02/14/2020 to Sat 02/15/2020 **UPDATED by CONED 01/15/2020**  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

WOOD\_ST\_-PLSNTVLE\_345\_Y86

Fri 02/14/2020 to Sat 02/15/2020 **UPDATED by CONED 01/15/2020**  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

SPRNBK\_-TREMONT\_345\_X28

Mon 02/17/2020 to Mon 02/17/2020 **UPDATED by CONED 12/05/2019**  
 0001 Continuous 1800  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **4200 MW**  
 Impacts Total Transfer Capability 400 MW  
 TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,January 23, 2020 to Saturday ,July 24, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
<b>WATRCURE-OAKDALE__345_31</b>			FWD
Mon 02/17/2020	to	Mon 02/17/2020	(Import)
1500	Continuous	1530	<b>2750 MW</b>
Work scheduled by: NYSEG			
		<u>UPDATED</u> <u>by NYSEG</u> <u>12/20/2019</u>	SCH - PJ - NY
			Impacts Total Transfer Capability 150 MW
			TTC with All Lines In Service 2900 MW
<hr/>			
<b>MOSES__-ADIRNDCK_230_MAI</b>			FWD
Tue 02/18/2020	to	Fri 02/21/2020	(Import)
0700	Continuous	1530	<b>2300 MW</b>
Work scheduled by: NYPA			
			MOSES SOUTH
			Impacts Total Transfer Capability 850 MW
			TTC with All Lines In Service 3150 MW
<hr/>			
<b>SPRNBRK__345KV_RNS5</b>			FWD
Mon 02/24/2020	to	Mon 02/24/2020	(Import)
0001	Continuous	0030	<b>3200 MW</b>
Work scheduled by: ConEd			
			SPR/DUN-SOUTH
			Impacts Total Transfer Capability 1400 MW
			TTC with All Lines In Service 4600 MW
<hr/>			
<b>SPRNBRK_-W49TH_ST_345_M51</b>			FWD
Mon 02/24/2020	to	Sun 03/01/2020	(Import)
0001	Continuous	0200	<b>3200 MW</b>
Work scheduled by: ConEd			
			SPR/DUN-SOUTH
			Impacts Total Transfer Capability 1400 MW
			TTC with All Lines In Service 4600 MW
<hr/>			
<b>SPRNBRK__345KV_RNS5</b>			FWD
Wed 02/26/2020	to	Wed 02/26/2020	(Import)
2130	Continuous	2200	<b>3200 MW</b>
Work scheduled by: ConEd			
			SPR/DUN-SOUTH
			Impacts Total Transfer Capability 1400 MW
			TTC with All Lines In Service 4600 MW
<hr/>			
<b>SPRNBRK__345KV_RNS5</b>			FWD
Thu 02/27/2020	to	Sun 03/01/2020	(Import)
2301	Continuous	0200	<b>3200 MW</b>
Work scheduled by: ConEd			
			SPR/DUN-SOUTH
			Impacts Total Transfer Capability 1400 MW
			TTC with All Lines In Service 4600 MW
<hr/>			
<b>NIAGARA_-PACKARD__230_62</b>			FWD      REV
Fri 02/28/2020	to	Fri 02/28/2020	(Import) (Export)
0500	Continuous	1530	<b>900 MW    1850 MW</b>
Work scheduled by: NYPA			
			SCH - OH - NY
			Impacts Total Transfer Capability 1150 MW    50 MW
			TTC with All Lines In Service 2050 MW    1900 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,January 23, 2020 to Saturday ,July 24, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>DUNWODIE_345KV_4</b>					FWD
Sun 03/01/2020	to	Sun 03/08/2020			(Import)
0001	Continuous	2200		SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
<b>CHATGUAY-MASSENA_765_7040</b>					FWD
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>
0500	Continuous	1730		MOSES SOUTH	<b>1550 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 1600 MW
					TTC with All Lines In Service 3150 MW
<b>CHATGUAY-MASSENA_765_7040</b>					FWD
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>
0500	Continuous	1730		SCH - HQ - NY	<b>0 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 1500 MW
					TTC with All Lines In Service 1500 MW
					REV (Export) 1000 MW
<b>MARCY_765_345_AT1</b>					FWD
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>
0500	Continuous	1730		MOSES SOUTH	<b>1750 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 3150 MW
<b>MARCY_765_345_AT2</b>					FWD
Mon 03/02/2020	to	Fri 03/06/2020			(Import)
0500	Continuous	1730		MOSES SOUTH	<b>1700 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 1450 MW
					TTC with All Lines In Service 3150 MW
<b>MASSENA -MARCY_765_MSU1</b>					FWD
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>
0500	Continuous	1730		CENTRAL EAST - VC	<b>2265 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 710 MW
					TTC with All Lines In Service 2975 MW
<b>MASSENA -MARCY_765_MSU1</b>					FWD
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>
0500	Continuous	1730		MOSES SOUTH	<b>500 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 2650 MW
					TTC with All Lines In Service 3150 MW



# NYISO TRANSFER LIMITATIONS

Thursday ,January 23, 2020 to Saturday ,July 24, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MASSENA_-MARCY_ 765_MSU1</b>		FWD		REV
Mon 03/02/2020 to Fri 03/06/2020	<b>UPDATED by NYPA 08/08/2019</b>			(Import) (Export)
0500 Continuous 1730				
Work scheduled by: NYPA		SCH - HQ - NY		<b>475 MW 1000 MW</b>
		Impacts Total Transfer Capability	1025 MW	0 MW
		TTC with All Lines In Service	1500 MW	1000 MW
<hr/>				
<b>MASSENA_-MARCY_ 765_MSU1</b>				FWD
Mon 03/02/2020 to Fri 03/06/2020	<b>UPDATED by NYPA 08/08/2019</b>			(Import)
0500 Continuous 1730				
Work scheduled by: NYPA		SCH - HQ_CEDARS		<b>90 MW</b>
		Impacts Total Transfer Capability	109 MW	
		TTC with All Lines In Service	199 MW	
<hr/>				
<b>MASSENA_-MARCY_ 765_MSU1 &amp; CHATGUAY-MASSENA_ 765_7040</b>				FWD
Mon 03/02/2020 to Fri 03/06/2020				(Import)
0500 1730				
Work scheduled by:		MOSES SOUTH		<b>500 MW</b>
		Impacts Total Transfer Capability	2650 MW	
		TTC with All Lines In Service	3150 MW	
<hr/>				
<b>MOSES_-MASSENA_ 230_MMS1 &amp; MOSES_-MASSENA_ 230_MMS2</b>				FWD
Mon 03/02/2020 to Fri 03/06/2020				(Import) (Export)
0500 1730				
Work scheduled by:		SCH - HQ - NY		<b>850 MW 0 MW</b>
		Impacts Total Transfer Capability	650 MW	1000 MW
		TTC with All Lines In Service	1500 MW	1000 MW
<hr/>				
<b>MOSES_-MASSENA_ 230_MMS1 &amp; MOSES_-MASSENA_ 230_MMS2</b>				FWD
Mon 03/02/2020 to Fri 03/06/2020				(Import)
0500 1730				
Work scheduled by:		SCH - HQ_CEDARS		<b>90 MW</b>
		Impacts Total Transfer Capability	109 MW	
		TTC with All Lines In Service	199 MW	
<hr/>				
<b>STLAWRNC-MOSES_ 230_L33P &amp; MASSENA_-MARCY_ 765_MSU1</b>				FWD
Mon 03/02/2020 to Fri 03/06/2020				(Import)
0500 1730				
Work scheduled by:		SCH - HQ_CEDARS		<b>90 MW</b>
		Impacts Total Transfer Capability	109 MW	
		TTC with All Lines In Service	199 MW	
<hr/>				
<b>STLAWRNC-MOSES_ 230_L33P &amp; MOSES_-MASSENA_ 230_MMS1 &amp; MOSES_-MASSENA_ 230_MMS2</b>				FWD
Mon 03/02/2020 to Fri 03/06/2020				(Import)
0500 1730				
Work scheduled by:		SCH - HQ_CEDARS		<b>90 MW</b>
		Impacts Total Transfer Capability	109 MW	
		TTC with All Lines In Service	199 MW	

# NYISO TRANSFER LIMITATIONS

Thursday ,January 23, 2020 to Saturday ,July 24, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Work Scheduled	Work Scheduled by	Transfer Capability	FWD	REV
			(Import)	(Export)
<b>SHOR_NPX-SHOREHAM_138_CSC</b>				
Mon 03/02/2020 to Tue 03/03/2020				
0600 Continuous 1300				
Work scheduled by: LI				
		SCH - NPX_CSC	0 MW	0 MW
		Impacts Total Transfer Capability	330 MW	330 MW
		TTC with All Lines In Service	330 MW	330 MW
<b>ROSETON_-EFISHKIL_345_RFK305</b>				
Mon 03/02/2020 to Fri 03/20/2020				
0700 Continuous 1730				
Work scheduled by: NYPA				
		UPNY CONED	4800 MW	
		Impacts Total Transfer Capability	900 MW	
		TTC with All Lines In Service	5700 MW	
<b>EASTVIEW-SPRNBRK_345_W78</b>				
Fri 03/06/2020 to Sat 03/07/2020				
0001 Continuous 0200				
Work scheduled by: ConEd				
		UPNY CONED	4350 MW	
		Impacts Total Transfer Capability	1350 MW	
		TTC with All Lines In Service	5700 MW	
<b>MILLWOOD-EASTVIEW_345_W85</b>				
Fri 03/06/2020 to Sat 03/07/2020				
0001 Continuous 0200				
Work scheduled by: ConEd				
		UPNY CONED	4350 MW	
		Impacts Total Transfer Capability	1350 MW	
		TTC with All Lines In Service	5700 MW	
<b>SPRNBRK_345KV_RNS3</b>				
Fri 03/06/2020 to Sat 03/07/2020				
0001 Continuous 0200				
Work scheduled by: ConEd				
		SPR/DUN-SOUTH	3800 MW	
		Impacts Total Transfer Capability	800 MW	
		TTC with All Lines In Service	4600 MW	
<b>MOSES_-ADIRNDCK_230_MA1</b>				
Sat 03/07/2020 to Fri 05/29/2020				
0700 Continuous 1300				
Work scheduled by: NYPA				
		MOSES SOUTH	2300 MW	
		Impacts Total Transfer Capability	850 MW	
		TTC with All Lines In Service	3150 MW	
<b>W49TH_ST_345KV_5</b>				
Mon 03/09/2020 to Mon 03/09/2020				
0001 Continuous 0030				
Work scheduled by: ConEd				
		SCH - PJM_HTP	350 MW	
		Impacts Total Transfer Capability	310 MW	
		TTC with All Lines In Service	660 MW	

# NYISO TRANSFER LIMITATIONS

Thursday ,January 23, 2020 to Saturday ,July 24, 2021

Seasonal Limits

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SPRNBRK_-W49TH_ST_345_M52</b>				FWD
Mon 03/09/2020	to	Wed 03/11/2020	<b><u>CANCELLED</u></b> <b>by ConEd</b> <b><u>01/22/2020</u></b>	(Import)
0001	Continuous	2200		<b>3200 MW</b>
Work scheduled by: ConEd				SPR/DUN-SOUTH
				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW
<b>SPRNBRK_345KV_RNS4</b>				FWD
Mon 03/09/2020	to	Wed 03/11/2020	<b><u>CANCELLED</u></b> <b>by ConEd</b> <b><u>01/22/2020</u></b>	(Import)
0001	Continuous	2200		<b>3200 MW</b>
Work scheduled by: ConEd				SPR/DUN-SOUTH
				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW
<b>VOLNEY_-MARCY_345_19</b>				FWD
Tue 03/10/2020	to	Tue 03/10/2020	<b><u>UPDATED</u></b> <b>by NYPA</b> <b><u>09/24/2019</u></b>	(Import)
0700	Continuous	1530		<b>2825 MW</b>
Work scheduled by: NYPA				CENTRAL EAST - VC
				Impacts Total Transfer Capability 150 MW
				TTC with All Lines In Service 2975 MW
<b>VOLNEY_-MARCY_345_19</b>				FWD
Tue 03/10/2020	to	Tue 03/10/2020	<b><u>UPDATED</u></b> <b>by NYPA</b> <b><u>09/24/2019</u></b>	(Import)
0700	Continuous	1530		<b>4900 MW</b>
Work scheduled by: NYPA				OSWEGO EXPORT
				Impacts Total Transfer Capability 350 MW
				TTC with All Lines In Service 5250 MW
<b>W49TH_ST_345KV_5</b>				FWD
Wed 03/11/2020	to	Wed 03/11/2020	<b><u>CANCELLED</u></b> <b>by ConEd</b> <b><u>01/22/2020</u></b>	(Import)
2130	Continuous	2200		<b>350 MW</b>
Work scheduled by: ConEd				SCH - PJM_HTP
				Impacts Total Transfer Capability 310 MW
				TTC with All Lines In Service 660 MW
<b>ROCHESTR-PANNELL_345_RP2</b>				FWD
Sat 03/14/2020	to	Mon 03/23/2020		(Import)
0500	Continuous	1700		<b>2300 MW</b>
Work scheduled by: NYPA				DYSINGER EAST
				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW
<b>BECK_-NIAGARA_230_PA27</b>				FWD
Mon 03/16/2020	to	Fri 03/20/2020		(Import)
0400	Continuous	1700		<b>350 MW</b>
Work scheduled by: IESO				SCH - OH - NY
				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,January 23, 2020 to Saturday ,July 24, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARCY\_\_\_345KV\_CSC**

Mon 03/16/2020 to Fri 03/27/2020  
0500 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC **2925 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

**CHASLAKE-PORTER\_\_\_230\_11**

Wed 03/18/2020 to Wed 03/18/2020  
0630 Daily(No Weekends) 1330

Work scheduled by: NGrid

FWD

(Import)

MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**SCH-NYISO-NE\_LIMIT\_900**

Wed 03/18/2020 to Tue 03/31/2020  
0700 Continuous 2359

Work scheduled by: ISONE

REV

(Export)

SCH - NE - NY **1100 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 1700 MW

**BUCHAN\_N-EASTVIEW\_345\_W93**

Thu 03/19/2020 to Thu 03/19/2020  
0200 Continuous 0230

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 1350 MW  
TTC with All Lines In Service 5700 MW

**EASTVIEW-SPRNBK\_\_\_345\_W79**

Thu 03/19/2020 to Fri 03/20/2020  
0200 Continuous 0200

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 1350 MW  
TTC with All Lines In Service 5700 MW

**BUCHAN\_N-EASTVIEW\_345\_W93**

Fri 03/20/2020 to Fri 03/20/2020  
0130 Continuous 0200

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 1350 MW  
TTC with All Lines In Service 5700 MW

**MILLWOOD-EASTVIEW\_345\_W85**

Sun 03/22/2020 to Sun 03/22/2020  
0201 Continuous 0231

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 1350 MW  
TTC with All Lines In Service 5700 MW

**UPDATED by CE 12/20/2019**

# NYISO TRANSFER LIMITATIONS

Thursday ,January 23, 2020 to Saturday ,July 24, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						FWD
<b>DUNWODIE-MOTTHAVN_345_72</b>						(Import)
Sun 03/22/2020	to	Tue 03/24/2020	<u>UPDATED</u>	<u>by CE</u>	<u>12/20/2019</u>	3800 MW
0201	Continuous	0200				Impacts Total Transfer Capability 800 MW
Work scheduled by: ConEd						TTC with All Lines In Service 4600 MW
<hr/>						FWD
<b>DUNWODIE_345KV_8</b>						(Import)
Sun 03/22/2020	to	Tue 03/24/2020	<u>UPDATED</u>	<u>by CE</u>	<u>12/20/2019</u>	3800 MW
0201	Continuous	0200				Impacts Total Transfer Capability 800 MW
Work scheduled by: ConEd						TTC with All Lines In Service 4600 MW
<hr/>						FWD
<b>EASTVIEW-SPRNBRK_345_W78</b>						(Import)
Sun 03/22/2020	to	Tue 03/24/2020	<u>UPDATED</u>	<u>by CE</u>	<u>12/20/2019</u>	4350 MW
0201	Continuous	0200				Impacts Total Transfer Capability 1350 MW
Work scheduled by: ConEd						TTC with All Lines In Service 5700 MW
<hr/>						FWD
<b>DUNWODIE_345KV_5</b>						(Import)
Sun 03/22/2020	to	Mon 05/11/2020	<u>UPDATED</u>	<u>by CE</u>	<u>12/20/2019</u>	3800 MW
0201	Continuous	0300				Impacts Total Transfer Capability 800 MW
Work scheduled by: ConEd						TTC with All Lines In Service 4600 MW
<hr/>						FWD
<b>DUNWODIE_345KV_7</b>						(Import)
Sun 03/22/2020	to	Mon 05/11/2020	<u>UPDATED</u>	<u>by CE</u>	<u>12/20/2019</u>	3800 MW
0201	Continuous	0300				Impacts Total Transfer Capability 800 MW
Work scheduled by: ConEd						TTC with All Lines In Service 4600 MW
<hr/>						FWD
<b>SPRNBRK_-DUNWODIE_345_W75</b>						(Import)
Sun 03/22/2020	to	Mon 05/11/2020	<u>UPDATED</u>	<u>by CE</u>	<u>12/20/2019</u>	3800 MW
0201	Continuous	0300				Impacts Total Transfer Capability 800 MW
Work scheduled by: ConEd						TTC with All Lines In Service 4600 MW
<hr/>						FWD
<b>SPRNBRK_345KV_RNS3</b>						(Import)
Sun 03/22/2020	to	Mon 05/11/2020	<u>UPDATED</u>	<u>by CE</u>	<u>12/20/2019</u>	3800 MW
0201	Continuous	0300				Impacts Total Transfer Capability 800 MW
Work scheduled by: ConEd						TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,January 23, 2020 to Saturday ,July 24, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**RAMAPO\_\_-BUCHAN\_N\_345\_Y94**

Tue 03/24/2020 to Tue 03/24/2020  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4800 MW**  
 Impacts Total Transfer Capability 900 MW  
 TTC with All Lines In Service 5700 MW

**MILLWOOD-EASTVIEW\_345\_W85**

Tue 03/24/2020 to Tue 03/24/2020 **UPDATED by CE 12/20/2019**  
 0130 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1350 MW  
 TTC with All Lines In Service 5700 MW

**DUNWODIE-MOTTHAVN\_345\_71**

Tue 03/24/2020 to Thu 03/26/2020 **UPDATED by CE 12/20/2019**  
 0201 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_3**

Tue 03/24/2020 to Thu 03/26/2020 **UPDATED by CE 12/20/2019**  
 0201 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**RAMAPO\_\_-BUCHAN\_N\_345\_Y94**

Tue 03/24/2020 to Tue 03/24/2020  
 0630 Continuous 0700  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4800 MW**  
 Impacts Total Transfer Capability 900 MW  
 TTC with All Lines In Service 5700 MW

**SPRNBK\_\_345KV\_RS3 & SPRNBK\_\_345KV\_RS4**

Thu 03/26/2020 to Sun 03/29/2020  
 0201 0200  
 Work scheduled by:

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**NIAGARA\_-KINTIGH\_\_345\_NS1-38**

Fri 03/27/2020 to Fri 03/27/2020  
 0600 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 DYSINGER EAST **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,January 23, 2020 to Saturday ,July 24, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p><b>BECK</b> -PACKARD_230_BP76</p> <p>Fri 03/27/2020 to Fri 03/27/2020 0800 Daily(No Weekends) 1600</p> <p>Work scheduled by: NGrid</p>	<p style="text-align: right;">FWD      REV (Import) (Export)</p> <p>SCH - OH - NY      <b>1650 MW 1400 MW</b></p> <p>Impacts Total Transfer Capability 400 MW 500 MW</p> <p>TTC with All Lines In Service 2050 MW 1900 MW</p>
<p><b>BECK</b> -NIAGARA_230_PA27</p> <p>Mon 03/30/2020 to Fri 05/29/2020 0400 Continuous 1700</p> <p>Work scheduled by: IESO</p>	<p>SCH - OH - NY</p> <p>Impacts Total Transfer Capability</p> <p>TTC with All Lines In Service</p>
<p><b>MARCY</b> -EDIC_345_UE1-7</p> <p>Tue 03/31/2020 to Tue 03/31/2020 0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>OSWEGO EXPORT      <b>5250 MW</b></p> <p>Impacts Total Transfer Capability 0 MW</p> <p>TTC with All Lines In Service 5250 MW</p>
<p><b>RAMAPO</b> -LADENTWN_345_W72</p> <p>Wed 04/01/2020 to Thu 04/02/2020 0001 Continuous 1830</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>UPNY CONED      <b>4400 MW</b></p> <p>Impacts Total Transfer Capability 1300 MW</p> <p>TTC with All Lines In Service 5700 MW</p>
<p><b>SCH-NYISO-NE_LIMIT_700</b></p> <p>Wed 04/01/2020 to Fri 04/03/2020 0001 Continuous 1600</p> <p>Work scheduled by: ISONE</p>	<p style="text-align: right;">REV (Export)</p> <p>SCH - NE - NY      <b>900 MW</b></p> <p>Impacts Total Transfer Capability 800 MW</p> <p>TTC with All Lines In Service 1700 MW</p>
<p><b>FRASANX-COOPERS_345_UCC2-41</b></p> <p>Wed 04/01/2020 to Thu 04/02/2020 0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC      <b>2500 MW</b></p> <p>Impacts Total Transfer Capability 475 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p><b>MARCY</b> -FRASANX_345_UCC2-41</p> <p>Wed 04/01/2020 to Thu 04/02/2020 0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC      <b>2500 MW</b></p> <p>Impacts Total Transfer Capability 475 MW</p> <p>TTC with All Lines In Service 2975 MW</p>

# NYISO TRANSFER LIMITATIONS

Thursday ,January 23, 2020 to Saturday ,July 24, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Transfer ID	Start Date	End Date	Time	Duration	Work Scheduled by	Transfer Type	Impact	TTC
LINDN_CG-LNDVFT_345_V-3022	Sun 04/05/2020	Sat 04/11/2020	1400	Continuous	PJM	SCH - PJM_VFT	0 MW	315 MW
							(Import)	(Export)
							Impacts Total Transfer Capability	315 MW
							TTC with All Lines In Service	315 MW
MARCY-N.SCTLND_345_18	Tue 04/07/2020	Wed 04/08/2020	0700	Continuous	NYPA	CENTRAL EAST - VC	2090 MW	885 MW
							Impacts Total Transfer Capability	2975 MW
							TTC with All Lines In Service	2975 MW
							ARR: 19	
PLSNTVLY-EFISHKIL_345_F36	Mon 04/13/2020	Tue 04/14/2020	0001	Continuous	ConEd	UPNY CONED	4000 MW	1700 MW
							Impacts Total Transfer Capability	5700 MW
							TTC with All Lines In Service	5700 MW
SAND_BAR-PLATSBRG_115_PV20	Mon 04/13/2020	Tue 04/14/2020	0600	Daily	ISONE	SCH - NE - NY		
							Impacts Total Transfer Capability	
							TTC with All Lines In Service	
FRASER-GILBOA_345_GF5-35	Mon 04/13/2020	Wed 04/22/2020	0700	Continuous	NYPA	CENTRAL EAST - VC	2650 MW	325 MW
							Impacts Total Transfer Capability	2975 MW
							TTC with All Lines In Service	2975 MW
NIAGARA-ROCHESTR_345_NR2	Wed 04/15/2020	Fri 05/01/2020	0500	Continuous	NYPA	DYSINGER EAST	1700 MW	1450 MW
							Impacts Total Transfer Capability	3150 MW
							TTC with All Lines In Service	3150 MW
ROCHESTR-PANNELL_345_RP1	Mon 04/20/2020	Fri 04/24/2020	0700	Continuous	NYPA	DYSINGER EAST	2300 MW	850 MW
							Impacts Total Transfer Capability	3150 MW
							TTC with All Lines In Service	3150 MW



# NYISO TRANSFER LIMITATIONS

Thursday ,January 23, 2020 to Saturday ,July 24, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DOLSONAV-ROCKTVRN\_345\_DART44**

Mon 04/27/2020 to Sun 05/10/2020  
0700 Continuous 1730

**UPDATED by NYPA 03/21/2019**

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2720 MW**  
Impacts Total Transfer Capability 255 MW  
TTC with All Lines In Service 2975 MW

**HURLYAVE-ROSETON\_345\_303**

Mon 04/27/2020 to Fri 05/29/2020  
0800 Continuous 1600

**UPDATED by CHGE 10/09/2019**

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 5700 MW

**DUNWODIE-MOTTHAVN\_345\_72**

Tue 04/28/2020 to Sat 05/02/2020  
0200 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**MILLWOOD-EASTVIEW\_345\_W85**

Wed 04/29/2020 to Wed 04/29/2020  
0201 Continuous 0230

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 1350 MW  
TTC with All Lines In Service 5700 MW

**EASTVIEW-SPRNBK\_345\_W78**

Wed 04/29/2020 to Sun 05/03/2020  
0201 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 1350 MW  
TTC with All Lines In Service 5700 MW

**SCH-IMO-NYISO\_LIMIT\_1600**

Fri 05/01/2020 to Sat 10/31/2020  
0001 Continuous 2359

**UPDATED by IESO 05/03/2019**

Work scheduled by: IESO

FWD  
(Import)  
SCH - OH - NY **1900 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 1900 MW

**DUNWODIE-MOTTHAVN\_345\_71**

Sat 05/02/2020 to Wed 05/06/2020  
0201 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,January 23, 2020 to Saturday ,July 24, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
<b>DUNWODIE_345KV_3</b>			FWD
Sat 05/02/2020	to	Wed 05/06/2020	(Import)
0201	Continuous	0200	SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability 800 MW
			TTC with All Lines In Service 4600 MW
<hr/>			
<b>MILLWOOD-EASTVIEW_345_W85</b>			FWD
Sun 05/03/2020	to	Sun 05/03/2020	(Import)
0130	Continuous	0200	UPNY CONED <b>4350 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability 1350 MW
			TTC with All Lines In Service 5700 MW
<hr/>			
<b>PANNELL_-CLAY____345_2</b>			FWD
Mon 05/04/2020	to	Fri 05/08/2020	(Import)
0700	Continuous	1530	WEST CENTRAL <b>1300 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability 950 MW
			TTC with All Lines In Service 2250 MW
<hr/>			
<b>NEPTUNE_-DUFFYAVE_345_NEPTUNE</b>			FWD
Mon 05/04/2020	to	Mon 05/18/2020	(Import)
0800	Continuous	1700	SCH - PJM_NEPTUNE <b>0 MW</b>
Work scheduled by: PJM			Impacts Total Transfer Capability 660 MW
			TTC with All Lines In Service 660 MW
<hr/>			
<b>NEWBRDGE-DUFFYAVE_345_501</b>			FWD
Mon 05/04/2020	to	Mon 05/18/2020	(Import)
0800	Continuous	1700	SCH - PJM_NEPTUNE <b>0 MW</b>
Work scheduled by: PJM			Impacts Total Transfer Capability 660 MW
			TTC with All Lines In Service 660 MW
<hr/>			
<b>NEWBRDGE_345_138_BK_1</b>			FWD
Mon 05/04/2020	to	Mon 05/18/2020	(Import)
0800	Continuous	1700	SCH - PJM_NEPTUNE <b>375 MW</b>
Work scheduled by: PJM			Impacts Total Transfer Capability 285 MW
			TTC with All Lines In Service 660 MW
<hr/>			
<b>NEWBRDGE_345_138_BK_2</b>			FWD
Mon 05/04/2020	to	Mon 05/18/2020	(Import)
0800	Continuous	1700	SCH - PJM_NEPTUNE <b>375 MW</b>
Work scheduled by: PJM			Impacts Total Transfer Capability 285 MW
			TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,January 23, 2020 to Saturday ,July 24, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SPRNBK\_\_345KV\_RS3 & SPRNBK\_\_345KV\_RS4**  
 Wed 05/06/2020 to Mon 05/11/2020  
 0201 0200  
 Work scheduled by:

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

**PANNELL\_-CLAY\_\_\_\_\_345\_1**  
 Mon 05/11/2020 to Fri 05/15/2020  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 WEST CENTRAL **1300 MW**  
 Impacts Total Transfer Capability 950 MW  
 TTC with All Lines In Service 2250 MW

**COOPERS\_-DOLSONAV\_345\_CCDA42**  
 Mon 05/11/2020 to Fri 05/29/2020 **UPDATED by NYPA 03/21/2019**  
 0700 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2720 MW**  
 Impacts Total Transfer Capability 255 MW  
 TTC with All Lines In Service 2975 MW

**KINTIGH\_-ROCHESTR\_345\_SR1-39**  
 Mon 05/18/2020 to Fri 05/22/2020  
 0500 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 DYSINGER EAST **1400 MW**  
 Impacts Total Transfer Capability 1750 MW  
 TTC with All Lines In Service 3150 MW

**SCH-NE-NYISO\_LIMIT\_700**  
 Mon 05/18/2020 to Mon 05/18/2020  
 0700 Continuous 1059  
 Work scheduled by: ISONE

FWD  
 (Import)  
 SCH - NE - NY **900 MW**  
 Impacts Total Transfer Capability 500 MW  
 TTC with All Lines In Service 1400 MW

**SCH-NYISO-NE\_LIMIT\_500**  
 Mon 05/18/2020 to Mon 05/18/2020  
 0700 Continuous 1059  
 Work scheduled by: ISONE

REV  
 (Export)  
 SCH - NE - NY **700 MW**  
 Impacts Total Transfer Capability 900 MW  
 TTC with All Lines In Service 1600 MW

**BERKSHIR-ALPS\_\_\_\_\_345\_393 & BERKSHIR-NORTHFLD\_345\_312**  
 Mon 05/18/2020 to Mon 05/18/2020  
 0700 1100  
 Work scheduled by:

FWD REV  
 (Import) (Export)  
 SCH - NE - NY **950 MW 1300 MW**  
 Impacts Total Transfer Capability 450 MW 300 MW  
 TTC with All Lines In Service 1400 MW 1600 MW

**ARR: 78**

# NYISO TRANSFER LIMITATIONS

Thursday ,January 23, 2020 to Saturday ,July 24, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

			FWD	REV
			(Import)	(Export)
<b>BERKSHIR-NORTHFLD_345_312</b>				
Mon 05/18/2020	to	Mon 05/18/2020		
0700	Continuous	1100	SCH - NE - NY	<b>900 MW 1500 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	500 MW 100 MW
			TTC with All Lines In Service	1400 MW 1600 MW
<b>BERKSHIR-NORTHFLD_345_312</b>				
Mon 05/18/2020	to	Mon 05/18/2020		
0700	Continuous	1100	SCH - NPX_1385	<b>100 MW 100 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
<b>BERKSHIR-ALPS_345_393</b>				
Mon 05/18/2020	to	Sat 05/30/2020		
0700	Continuous	1700	SCH - NE - NY	<b>950 MW 1300 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	450 MW 300 MW
			TTC with All Lines In Service	1400 MW 1600 MW
				<b>ARR: 78</b>
<b>BERKSHIR-ALPS_345_393</b>				
Mon 05/18/2020	to	Sat 05/30/2020		
0700	Continuous	1700	SCH - NPX_1385	<b>100 MW 100 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
				<b>ARR: 78</b>
<b>SCH-NE-NYISO_LIMIT_600</b>				
Mon 05/18/2020	to	Tue 05/26/2020		
1100	Continuous	0559	SCH - NE - NY	<b>800 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	600 MW
			TTC with All Lines In Service	1400 MW
<b>SCH-NYISO-NE_LIMIT_600</b>				
Mon 05/18/2020	to	Sat 05/30/2020		
1100	Continuous	1459	SCH - NE - NY	<b>800 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	1600 MW
<b>SCH-NE-NYISO_LIMIT_500</b>				
Tue 05/26/2020	to	Sat 05/30/2020		
0600	Continuous	1700	SCH - NE - NY	<b>700 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	700 MW
			TTC with All Lines In Service	1400 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,January 23, 2020 to Saturday ,July 24, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BERKSHIR-ALPS_____345_393 &amp; BERKSHIR-NORTHFLD_345_312</b>			FWD	REV
Sat 05/30/2020	to	Sat 05/30/2020	(Import)	(Export)
1500		1700	<b>SCH - NE - NY</b>	<b>950 MW 1300 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	450 MW 300 MW
<b>ARR: 78</b>			TTC with All Lines In Service	1400 MW 1600 MW
<b>BERKSHIR-NORTHFLD_345_312</b>			FWD	REV
Sat 05/30/2020	to	Sat 05/30/2020	(Import)	(Export)
1500	Continuous	1700	<b>SCH - NE - NY</b>	<b>900 MW 1500 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	500 MW 100 MW
			TTC with All Lines In Service	1400 MW 1600 MW
<b>BERKSHIR-NORTHFLD_345_312</b>			FWD	REV
Sat 05/30/2020	to	Sat 05/30/2020	(Import)	(Export)
1500	Continuous	1700	<b>SCH - NPX_1385</b>	<b>100 MW 100 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
<b>SCH-NYISO-NE_LIMIT_500</b>				REV
Sat 05/30/2020	to	Sat 05/30/2020		(Export)
1500	Continuous	1700	<b>SCH - NE - NY</b>	<b>700 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	900 MW
			TTC with All Lines In Service	1600 MW
<b>SHOR_NPX-SHOREHAM_138_CSC</b>			FWD	REV
Mon 06/01/2020	to	Tue 06/02/2020	(Import)	(Export)
0501	Continuous	1600	<b>SCH - NPX_CSC</b>	<b>0 MW 0 MW</b>
Work scheduled by: LI			Impacts Total Transfer Capability	330 MW 330 MW
			TTC with All Lines In Service	330 MW 330 MW
<b>MOSES____-ADIRNDCK_230_MA2</b>			FWD	
Mon 06/01/2020	to	Fri 07/31/2020	(Import)	
0700	Continuous	1730	<b>MOSES SOUTH</b>	<b>2100 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	1050 MW
			TTC with All Lines In Service	3150 MW
<b>NIAGARA__345_230_AT4</b>				REV
Mon 06/29/2020	to	Tue 06/30/2020		(Export)
0500	Continuous	1530	<b>SCH - OH - NY</b>	<b>1400 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	300 MW
			TTC with All Lines In Service	1700 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,January 23, 2020 to Saturday ,July 24, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
<b>SCH-IMO-NYISO_NIAG_CB_3008_W/BB</b>							
Mon 07/27/2020	to	Fri 08/07/2020					
0500	Continuous	1530			SCH - OH - NY	<b>1900 MW</b>	<b>1450 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	0 MW 250 MW
						TTC with All Lines In Service	1900 MW 1700 MW
<b>CHATGUAY-MASSENA_765_7040</b>						FWD	
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)	
0500	Continuous	1730			MOSES SOUTH	<b>1550 MW</b>	
Work scheduled by: NYPA						Impacts Total Transfer Capability	1600 MW
						TTC with All Lines In Service	3150 MW
<b>CHATGUAY-MASSENA_765_7040</b>						FWD	REV
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)	(Export)
0500	Continuous	1730			SCH - HQ - NY	<b>0 MW</b>	<b>0 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	1500 MW 1000 MW
						TTC with All Lines In Service	1500 MW 1000 MW
<b>MARCY_765_345_AT1</b>						FWD	
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)	
0500	Continuous	1730			MOSES SOUTH	<b>1750 MW</b>	
Work scheduled by: NYPA						Impacts Total Transfer Capability	1400 MW
						TTC with All Lines In Service	3150 MW
							<b>ARR: 19</b>
<b>MASSENA_-MARCY_765_MSU1</b>						FWD	
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)	
0500	Continuous	1730			CENTRAL EAST - VC	<b>2265 MW</b>	
Work scheduled by: NYPA						Impacts Total Transfer Capability	710 MW
						TTC with All Lines In Service	2975 MW
<b>MASSENA_-MARCY_765_MSU1</b>						FWD	
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)	
0500	Continuous	1730			MOSES SOUTH	<b>500 MW</b>	
Work scheduled by: NYPA						Impacts Total Transfer Capability	2650 MW
						TTC with All Lines In Service	3150 MW
<b>MASSENA_-MARCY_765_MSU1</b>						FWD	REV
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)	(Export)
0500	Continuous	1730			SCH - HQ - NY	<b>475 MW</b>	<b>1000 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	1025 MW 0 MW
						TTC with All Lines In Service	1500 MW 1000 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,January 23, 2020 to Saturday ,July 24, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MASSENA -MARCY 765_MSU1</b>				FWD	
Sat 08/01/2020	to	Sun 08/02/2020	<b>UPDATED by NYPA 08/08/2019</b>	(Import)	
0500	Continuous	1730		SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	190 MW
<b>MASSENA -MARCY 765_MSU1 &amp; CHATGUAY-MASSENA 765_7040</b>				FWD	
Sat 08/01/2020	to	Sun 08/02/2020		(Import)	
0500		1730		MOSES SOUTH	<b>500 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	2650 MW
				TTC with All Lines In Service	3150 MW
<b>MOSES -MASSENA 230_MMS1 &amp; MOSES -MASSENA 230_MMS2</b>				FWD	REV
Sat 08/01/2020	to	Sun 08/02/2020		(Import)	(Export)
0500		1730		SCH - HQ - NY	<b>850 MW 0 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	650 MW 1000 MW
				TTC with All Lines In Service	1500 MW 1000 MW
<b>MOSES -MASSENA 230_MMS1 &amp; MOSES -MASSENA 230_MMS2</b>				FWD	
Sat 08/01/2020	to	Sun 08/02/2020		(Import)	
0500		1730		SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	190 MW
<b>STLAWRNC-MOSES 230_L33P &amp; MASSENA -MARCY 765_MSU1</b>				FWD	
Sat 08/01/2020	to	Sun 08/02/2020		(Import)	
0500		1730		SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	190 MW
<b>STLAWRNC-MOSES 230_L33P &amp; MOSES -MASSENA 230_MMS1 &amp; MOSES -MASSENA 230_MMS2</b>				FWD	
Sat 08/01/2020	to	Sun 08/02/2020		(Import)	
0500		1730		SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	190 MW
<b>MOSES -ADIRNDCK 230_MA2</b>				FWD	
Mon 08/03/2020	to	Sun 09/13/2020		(Import)	
0700	Continuous	1730		MOSES SOUTH	<b>2100 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	1050 MW
				TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,January 23, 2020 to Saturday ,July 24, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**FRASANX-COOPERS\_\_345\_UCC2-41**

Mon 09/07/2020 to Fri 10/23/2020  
0700 Continuous 1730

**UPDATED by NYPA 03/01/2019**

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

**MARCY\_\_-FRASANX\_345\_UCC2-41**

Mon 09/07/2020 to Fri 10/23/2020  
0700 Continuous 1730

**UPDATED by NYPA 03/01/2019**

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

**MARCY\_\_765\_345\_AT1**

Mon 09/14/2020 to Mon 09/14/2020  
0500 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
MOSES SOUTH **1750 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 3150 MW

**NIAGARA\_-KINTIGH\_\_345\_NS1-38**

Mon 09/14/2020 to Thu 09/17/2020  
0500 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

**MOSES\_\_-ADIRNDCK\_230\_MA2**

Tue 09/15/2020 to Sat 11/14/2020  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

**NIAGARA\_-ROCHESTR\_345\_NR2**

Fri 09/18/2020 to Sat 11/14/2020  
0500 Continuous 2330

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

**CLAY\_\_-EDIC\_\_345\_1-16**

Mon 09/21/2020 to Fri 09/25/2020  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW



# NYISO TRANSFER LIMITATIONS

Thursday ,January 23, 2020 to Saturday ,July 24, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**ROSETON\_-ROCKTVRN\_345\_311**

Mon 09/21/2020 to Fri 10/23/2020  
0800 Continuous 1600

**UPDATED by CHGE 10/09/2019**

Work scheduled by: CHGE

FWD  
(Import)  
**UPNY CONED 4400 MW**  
Impacts Total Transfer Capability 1300 MW  
TTC with All Lines In Service 5700 MW

**DUNWODIE\_345KV\_3**

Fri 09/25/2020 to Fri 09/25/2020  
0001 Continuous 0030

**CANCELLED by ConEd 01/21/2020**

Work scheduled by: ConEd

FWD  
(Import)  
**SPR/DUN-SOUTH 3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_5**

Fri 09/25/2020 to Fri 09/25/2020  
0001 Continuous 0030

**CANCELLED by ConEd 01/21/2020**

Work scheduled by: ConEd

FWD  
(Import)  
**SPR/DUN-SOUTH 3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**DUNWODIE-MOTTHAVN\_345\_71**

Fri 09/25/2020 to Fri 10/30/2020  
0001 Continuous 0300

**CANCELLED by ConEd 01/21/2020**

Work scheduled by: ConEd

FWD  
(Import)  
**SPR/DUN-SOUTH 3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_3**

Mon 09/28/2020 to Sat 10/31/2020  
0001 Continuous 0100

Work scheduled by: ConEd

FWD  
(Import)  
**SPR/DUN-SOUTH 3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_4**

Mon 09/28/2020 to Sat 10/31/2020  
0001 Continuous 0100

Work scheduled by: ConEd

FWD  
(Import)  
**SPR/DUN-SOUTH 3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**PLSNTVLE-DUNWODIE\_345\_W89**

Mon 09/28/2020 to Sat 10/31/2020  
0001 Continuous 0100

Work scheduled by: ConEd

FWD  
(Import)  
**UPNY CONED 4000 MW**  
Impacts Total Transfer Capability 1700 MW  
TTC with All Lines In Service 5700 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,January 23, 2020 to Saturday ,July 24, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p><b>CLAY -EDIC 345_2-15</b></p> <p>Mon 09/28/2020 to Fri 10/02/2020</p> <p style="padding-left: 40px;">0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>OSWEGO EXPORT <b>4850 MW</b></p> <p>Impacts Total Transfer Capability 400 MW</p> <p>TTC with All Lines In Service 5250 MW</p>
<p><b>MOTTHAVN-RAINEY 345_Q11</b></p> <p>Thu 10/01/2020 to Thu 11/05/2020</p> <p style="padding-left: 40px;">0001 Continuous 0200</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>SPR/DUN-SOUTH <b>3800 MW</b></p> <p>Impacts Total Transfer Capability 800 MW</p> <p>TTC with All Lines In Service 4600 MW</p>
<p><b>SAND_BAR-PLATSBURG 115_PV20</b></p> <p>Sat 10/17/2020 to Sat 11/14/2020</p> <p style="padding-left: 40px;">0600 Continuous 1800</p> <p>Work scheduled by: ISONE</p>	<p>SCH - NE - NY</p> <p>Impacts Total Transfer Capability</p> <p>TTC with All Lines In Service</p>
<p><b>LEEDS -HURLYAVE 345_301</b></p> <p>Mon 10/26/2020 to Fri 12/04/2020</p> <p style="padding-left: 40px;">0800 Continuous 1600</p> <p>Work scheduled by: CHGE</p>	<p style="text-align: right;">FWD (Import)</p> <p>UPNY CONED <b>4100 MW</b></p> <p>Impacts Total Transfer Capability 1600 MW</p> <p>TTC with All Lines In Service 5700 MW</p>
<p><b>DUNWODIE_345KV_3</b></p> <p>Fri 10/30/2020 to Fri 10/30/2020</p> <p style="padding-left: 40px;">0230 Continuous 0300</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>SPR/DUN-SOUTH <b>3800 MW</b></p> <p>Impacts Total Transfer Capability 800 MW</p> <p>TTC with All Lines In Service 4600 MW</p>
<p><b>DUNWODIE_345KV_5</b></p> <p>Fri 10/30/2020 to Fri 10/30/2020</p> <p style="padding-left: 40px;">0230 Continuous 0300</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>SPR/DUN-SOUTH <b>3800 MW</b></p> <p>Impacts Total Transfer Capability 800 MW</p> <p>TTC with All Lines In Service 4600 MW</p>
<p><b>SCH-IMO-NYISO_LIMIT_1750</b></p> <p>Sun 11/01/2020 to Fri 04/30/2021</p> <p style="padding-left: 40px;">0001 Continuous 2359</p> <p>Work scheduled by: IESO</p>	<p style="text-align: right;">FWD (Import)</p> <p>SCH - OH - NY <b>2050 MW</b></p> <p>Impacts Total Transfer Capability 0 MW</p> <p>TTC with All Lines In Service 2050 MW</p>

# NYISO TRANSFER LIMITATIONS

Thursday ,January 23, 2020 to Saturday ,July 24, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-IMO\_LIMIT\_1600

Sun 11/01/2020 to Fri 04/30/2021  
0001 Continuous 2359

UPDATED by IESO 05/03/2019

Work scheduled by: IESO

SCH - OH - NY  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 1900 MW

REV  
(Export)

CHATGUAY-MASSENA\_765\_7040

Sun 11/15/2020 to Mon 11/30/2020  
0100 Continuous 1900

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH 1550 MW  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 3150 MW

CHATGUAY-MASSENA\_765\_7040

Sun 11/15/2020 to Mon 11/30/2020  
0100 Continuous 1900

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - HQ - NY 0 MW 0 MW  
Impacts Total Transfer Capability 1500 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

MARCY\_765\_345\_AT1

Sun 11/15/2020 to Mon 11/30/2020  
0100 Continuous 1900

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
MOSES SOUTH 1750 MW  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 3150 MW

MARCY\_765\_345\_AT2

Sun 11/15/2020 to Mon 11/30/2020  
0100 Continuous 1900

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
MOSES SOUTH 1700 MW  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

MASSENA -MARCY\_765\_MSU1

Sun 11/15/2020 to Mon 11/30/2020  
0100 Continuous 1900

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC 2265 MW  
Impacts Total Transfer Capability 710 MW  
TTC with All Lines In Service 2975 MW

MASSENA -MARCY\_765\_MSU1

Sun 11/15/2020 to Mon 11/30/2020  
0100 Continuous 1900

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH 500 MW  
Impacts Total Transfer Capability 2650 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,January 23, 2020 to Saturday ,July 24, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Zone	Start	End	Time	Day	SCH	FWD	REV	
MASSENA -MARCY 765_MSU1	Sun 11/15/2020	Mon 11/30/2020	0100	Continuous	1900	(Import)	(Export)	
Work scheduled by: NYPA						SCH - HQ - NY	475 MW	1000 MW
						Impacts Total Transfer Capability	1025 MW	0 MW
						TTC with All Lines In Service	1500 MW	1000 MW
MASSENA -MARCY 765_MSU1	Sun 11/15/2020	Mon 11/30/2020	0100	Continuous	1900	(Import)		
Work scheduled by: NYPA						SCH - HQ_CEDARS	90 MW	
						Impacts Total Transfer Capability	109 MW	
						TTC with All Lines In Service	199 MW	
MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040	Sun 11/15/2020	Mon 11/30/2020	0100		1900	(Import)		
Work scheduled by:						MOSES SOUTH	500 MW	
						Impacts Total Transfer Capability	2650 MW	
						TTC with All Lines In Service	3150 MW	
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2	Sun 11/15/2020	Mon 11/30/2020	0100		1900	(Import)	(Export)	
Work scheduled by:						SCH - HQ - NY	850 MW	0 MW
						Impacts Total Transfer Capability	650 MW	1000 MW
						TTC with All Lines In Service	1500 MW	1000 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2	Sun 11/15/2020	Mon 11/30/2020	0100		1900	(Import)		
Work scheduled by:						SCH - HQ_CEDARS	90 MW	
						Impacts Total Transfer Capability	109 MW	
						TTC with All Lines In Service	199 MW	
STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1	Sun 11/15/2020	Mon 11/30/2020	0100		1900	(Import)		
Work scheduled by:						SCH - HQ_CEDARS	90 MW	
						Impacts Total Transfer Capability	109 MW	
						TTC with All Lines In Service	199 MW	
STLAWRNC-MOSES 230_L33P & MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2	Sun 11/15/2020	Mon 11/30/2020	0100		1900	(Import)		
Work scheduled by:						SCH - HQ_CEDARS	90 MW	
						Impacts Total Transfer Capability	109 MW	
						TTC with All Lines In Service	199 MW	

# NYISO TRANSFER LIMITATIONS

Thursday ,January 23, 2020 to Saturday ,July 24, 2021

Seasonal Limits

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**PLSNTVLE-DUNWODIE\_345\_W89**

Mon 11/16/2020 to Mon 11/16/2020  
 0001 Continuous 0030

Work scheduled by: ConEd

FWD  
 (Import)  
**UPNY CONED 4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

-----  
**PLSNTVLE-DUNWODIE\_345\_W89**

Thu 11/26/2020 to Thu 11/26/2020  
 0230 Continuous 0300

Work scheduled by: ConEd

FWD  
 (Import)  
**UPNY CONED 4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

-----  
**MOSES\_\_-ADIRNDCK\_230\_MAL**

Tue 12/01/2020 to Mon 05/31/2021  
 0700 Continuous 1300

Work scheduled by: NYPA

FWD  
 (Import)  
**MOSES SOUTH 2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

-----  
**SAND\_BAR-PLATSBURG\_115\_PV20**

Mon 12/07/2020 to Fri 12/11/2020  
 0700 Continuous 1530

Work scheduled by: NYPA

SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

-----  
**SAND\_BAR-PLATSBURG\_115\_PV20**

Mon 12/14/2020 to Fri 12/18/2020  
 0700 Continuous 1530

Work scheduled by: NYPA

SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

-----  
**HOPATCON-RAMAPO\_\_500\_5018**

Mon 02/01/2021 to Wed 02/03/2021  
 0001 Continuous 2200

Work scheduled by: ConEd

FWD REV  
 (Import) (Export)  
**SCH - PJ - NY 1250 MW 1200 MW**  
 Impacts Total Transfer Capability 1650 MW 650 MW  
 TTC with All Lines In Service 2900 MW 1850 MW

-----  
**HOPATCON-RAMAPO\_\_500\_5018**

Mon 02/01/2021 to Wed 02/03/2021  
 0001 Continuous 2200

Work scheduled by: ConEd

FWD  
 (Import)  
**UPNY CONED 5000 MW**  
 Impacts Total Transfer Capability 700 MW  
 TTC with All Lines In Service 5700 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,January 23, 2020 to Saturday ,July 24, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
<b>RAMAPO__345_345_PAR3500</b>			
Mon 02/01/2021	to	Wed 02/03/2021	FWD
0001	Continuous	2200	(Import) (Export)
Work scheduled by: ConEd			SCH - PJ - NY
			<b>2150 MW 1250 MW</b>
			Impacts Total Transfer Capability 750 MW 600 MW
			TTC with All Lines In Service 2900 MW 1850 MW
<hr/>			
<b>RAMAPO__345_345_PAR4500</b>			
Mon 02/01/2021	to	Wed 02/03/2021	FWD
0001	Continuous	2200	(Import) (Export)
Work scheduled by: ConEd			SCH - PJ - NY
			<b>2150 MW 1250 MW</b>
			Impacts Total Transfer Capability 750 MW 600 MW
			TTC with All Lines In Service 2900 MW 1850 MW
<hr/>			
<b>RAMAPO__500_345_BK 1500</b>			
Mon 02/01/2021	to	Wed 02/03/2021	FWD
0001	Continuous	2200	(Import) (Export)
Work scheduled by: ConEd			SCH - PJ - NY
			<b>1250 MW 1200 MW</b>
			Impacts Total Transfer Capability 1650 MW 650 MW
			TTC with All Lines In Service 2900 MW 1850 MW
<hr/>			
<b>RAMAPO__500_345_BK 1500</b>			
Mon 02/01/2021	to	Wed 02/03/2021	FWD
0001	Continuous	2200	(Import)
Work scheduled by: ConEd			UPNY CONED
			<b>5000 MW</b>
			Impacts Total Transfer Capability 700 MW
			TTC with All Lines In Service 5700 MW
<hr/>			
<b>DUNWODIE_345KV_3</b>			
Mon 03/01/2021	to	Mon 03/01/2021	FWD
0001	Continuous	0030	(Import)
Work scheduled by: ConEd			SPR/DUN-SOUTH
			<b>3800 MW</b>
			Impacts Total Transfer Capability 800 MW
			TTC with All Lines In Service 4600 MW
<hr/>			
<b>DUNWODIE_345KV_5</b>			
Mon 03/01/2021	to	Mon 03/01/2021	FWD
0001	Continuous	0030	(Import)
Work scheduled by: ConEd			SPR/DUN-SOUTH
			<b>3800 MW</b>
			Impacts Total Transfer Capability 800 MW
			TTC with All Lines In Service 4600 MW
<hr/>			
<b>EASTVIEW-SPRNBK__345_W64</b>			
Mon 03/01/2021	to	Mon 03/01/2021	FWD
0001	Continuous	0030	(Import)
Work scheduled by: ConEd			UPNY CONED
			<b>4350 MW</b>
			Impacts Total Transfer Capability 1350 MW
			TTC with All Lines In Service 5700 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,January 23, 2020 to Saturday ,July 24, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SPRNBK__345KV_RNS5</b>					FWD	
Mon 03/01/2021	to	Mon 03/01/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>01/23/2020</u>	(Import)
0001	Continuous	0030				<b>3200 MW</b>
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
<b>MILLWOOD-EASTVIEW_345_W99</b>					FWD	
Mon 03/01/2021	to	Mon 03/22/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>01/23/2020</u>	(Import)
0001	Continuous	0200				<b>4350 MW</b>
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	1350 MW
					TTC with All Lines In Service	5700 MW
<b>DUNWODIE-MOTTHAVN_345_71</b>					FWD	
Mon 03/01/2021	to	Mon 04/05/2021				(Import)
0001	Continuous	0300				<b>3800 MW</b>
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>MOTTHAVN-RAINEY__345_Q11</b>					FWD	
Mon 03/01/2021	to	Tue 04/06/2021				(Import)
0001	Continuous	0700				<b>3800 MW</b>
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>EASTVIEW-SPRNBK__345_W64</b>					FWD	
Mon 03/22/2021	to	Mon 03/22/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>01/23/2020</u>	(Import)
0130	Continuous	0200				<b>4350 MW</b>
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	1350 MW
					TTC with All Lines In Service	5700 MW
<b>SPRNBK__345KV_RNS5</b>					FWD	
Mon 03/22/2021	to	Mon 03/22/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>01/23/2020</u>	(Import)
0130	Continuous	0200				<b>3200 MW</b>
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
<b>CLAY____-EDIC____345_2-15</b>					FWD	
Mon 03/29/2021	to	Fri 04/16/2021				(Import)
0800	Continuous	1730				<b>4850 MW</b>
Work scheduled by: NYPA					OSWEGO EXPORT	
					Impacts Total Transfer Capability	400 MW
					TTC with All Lines In Service	5250 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,January 23, 2020 to Saturday ,July 24, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE\_345KV\_3**

Mon 04/05/2021 to Mon 04/05/2021  
 0230 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_5**

Mon 04/05/2021 to Mon 04/05/2021  
 0230 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**SCH-IMO-NYISO\_LIMIT\_1600**

Sat 05/01/2021 to Sun 10/31/2021 **UPDATED by IESO 05/03/2019**  
 0001 Continuous 2359  
 Work scheduled by: IESO

FWD  
 (Import)  
 SCH - OH - NY **1900 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 1900 MW

**PANNELL\_-CLAY\_345\_2**

Mon 05/03/2021 to Fri 05/28/2021  
 0700 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
 WEST CENTRAL **1300 MW**  
 Impacts Total Transfer Capability 950 MW  
 TTC with All Lines In Service 2250 MW

**MOSES\_-ADIRNDCK\_230\_MA2**

Tue 06/01/2021 to Sun 11/14/2021  
 0700 Continuous 1300  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2100 MW**  
 Impacts Total Transfer Capability 1050 MW  
 TTC with All Lines In Service 3150 MW