

NYISO TRANSFER LIMITATIONS

Friday ,January 24, 2020 to Sunday ,July 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Fri 05/01/2020 **EXTENDED by CONED 10/08/2019**
 0001 Continuous 2359
 Work scheduled by: ConEd

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Fri 05/01/2020
 0001 2359
 Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2550 MW	1600 MW
Impacts Total Transfer Capability	350 MW	250 MW
TTC with All Lines In Service	2900 MW	1850 MW

MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Fri 05/01/2020 **EXTENDED by CONED 10/08/2019**
 0001 Continuous 2359
 Work scheduled by: ConEd

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

STLAWRNC-MOSES_230_L33P

Mon 04/30/2018 to Fri 12/31/2021 **EXT FORCE by IESO 08/21/2018**
 0456 Continuous 2359
 Work scheduled by: IESO

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

SCH-IMO-NYISO_LIMIT_1750

Fri 11/01/2019 to Thu 04/30/2020 **UPDATED by IESO 05/03/2019**
 0001 Continuous 2359
 Work scheduled by: IESO

	FWD
	(Import)
SCH - OH - NY	2050 MW
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	2050 MW

SCH-NYISO-IMO_LIMIT_1600

Fri 11/01/2019 to Thu 04/30/2020 **UPDATED by IESO 05/03/2019**
 0001 Continuous 2359
 Work scheduled by: IESO

	REV
	(Export)
SCH - OH - NY	1900 MW
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	1900 MW

SCH-NYISO-NE_LIMIT_1500

Fri 11/01/2019 to Thu 04/30/2020
 0001 Continuous 2359
 Work scheduled by: NYISO

	REV
	(Export)
SCH - NE - NY	1700 MW
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	1700 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 24, 2020 to Sunday ,July 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

OSWEGO_COMPLEX_AVR_O/S					FWD	
Mon 11/18/2019	to	Mon 03/09/2020	EXT FORCE	by GEN	12/26/2019	(Import)
0221	Continuous	0001				CENTRAL EAST - VC 2870 MW
Work scheduled by: Gen					Impacts Total Transfer Capability	105 MW
					TTC with All Lines In Service	2975 MW
DUNWODIE_345KV_6					FWD	
Tue 12/03/2019	to	Thu 02/20/2020	EXT FORCE	by CONED	01/24/2020	(Import)
0048	Continuous	2359				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_8					FWD	
Tue 12/03/2019	to	Thu 02/20/2020	EXT FORCE	by CONED	01/24/2020	(Import)
0048	Continuous	2359				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
PLSNTVLE-DUNWODIE_345_W90					FWD	
Tue 12/03/2019	to	Thu 02/20/2020	EXT FORCE	by CONED	01/24/2020	(Import)
0107	Continuous	2359				UPNY CONED 4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1700 MW
					TTC with All Lines In Service	5700 MW
CHAT_DC_GC2					FWD	
Thu 12/26/2019	to	Mon 01/20/2020	EXTENDED	by HQ	01/13/2020	(Import)
1827	Continuous	2359				MOSES SOUTH 2850 MW
Work scheduled by: HQ					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW
CHAT_DC_GC2					REV	
Thu 12/26/2019	to	Mon 01/20/2020	EXTENDED	by HQ	01/13/2020	(Export)
1827	Continuous	2359				SCH - HQ - NY 500 MW
Work scheduled by: HQ					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1000 MW
SCH-HQ-NYISO_LIMIT_1200					FWD	
Fri 01/03/2020	to	Mon 01/20/2020	EXTENDED	by HQ	01/13/2020	(Import)
1430	Continuous	2359				SCH - HQ - NY 1200 MW
Work scheduled by: HQ					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	1500 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 24, 2020 to Sunday ,July 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASER___345_FRASER SVC					FWD	
Mon 01/13/2020	to	Fri 01/24/2020	<u>UPDATED</u>	<u>by NYSEG</u>	<u>12/18/2019</u>	(Import)
0800	Continuous	1102				CENTRAL EAST - VC 2935 MW
Work scheduled by: NYSEG					Impacts Total Transfer Capability	40 MW
					TTC with All Lines In Service	2975 MW
FROST_BR-LONG_MTN_345_352					FWD	
Mon 01/20/2020	to	Thu 01/23/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>01/14/2020</u>	(Import)
0100	Continuous	1600				SCH - NE - NY 1300 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	1400 MW
SCH-NE-NYISO_LIMIT_300					FWD	
Mon 01/20/2020	to	Thu 01/23/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>01/14/2020</u>	(Import)
0100	Continuous	1600				SCH - NE - NY 500 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability	900 MW
					TTC with All Lines In Service	1400 MW
SCH-NE-NYISO_LIMIT_500					FWD	
Wed 01/22/2020	to	Thu 01/23/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>01/23/2020</u>	(Import)
0500	Continuous	1159				SCH - NE - NY 700 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability	700 MW
					TTC with All Lines In Service	1400 MW
W49TH_ST-E13THSTA_345_M54					FWD	
Fri 01/24/2020	to	Fri 01/24/2020	<u>CANCELLED</u>	<u>by ConEd</u>	<u>01/22/2020</u>	(Import)
0001	Continuous	0500				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
SCH-IMO-NYISO_LIMIT_900					FWD	
Fri 01/24/2020	to	Fri 01/24/2020				(Import)
0500	Continuous	1530				SCH - OH - NY 1200 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	2050 MW
SCH-IMO-NYISO_LIMIT_1400					FWD	
Sat 01/25/2020	to	Sat 01/25/2020				(Import)
0500	Continuous	1700				SCH - OH - NY 1700 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	350 MW
					TTC with All Lines In Service	2050 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 24, 2020 to Sunday ,July 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-IMO_NIAGARA_CB_3022				FWD	REV
Tue 01/28/2020	to	Wed 01/29/2020	UPDATED by NYISO 01/24/2020	(Import)	(Export)
0500	Continuous	1900		1550 MW	1400 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	500 MW
				TTC with All Lines In Service	2050 MW
				1900 MW	
<hr/>					
BERKSHIR-ALPS 345_393				FWD	REV
Wed 01/29/2020	to	Sat 02/08/2020		(Import)	(Export)
1301	Continuous	1600		1150 MW	1700 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability	250 MW
				TTC with All Lines In Service	1400 MW
				1700 MW	
				ARR: 78	
<hr/>					
BERKSHIR-ALPS 345_393				FWD	REV
Wed 01/29/2020	to	Sat 02/08/2020		(Import)	(Export)
1301	Continuous	1600		100 MW	100 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	200 MW
				200 MW	
				ARR: 78	
<hr/>					
BERKSHIR-ALPS 345_393 & BERKSHIR-NORTHFLD_345_312				FWD	REV
Wed 01/29/2020	to	Sat 02/08/2020		(Import)	(Export)
1301		1600		1150 MW	1700 MW
Work scheduled by:				Impacts Total Transfer Capability	250 MW
				TTC with All Lines In Service	1400 MW
				1700 MW	
				ARR: 78	
<hr/>					
BERKSHIR-NORTHFLD_345_312				FWD	
Wed 01/29/2020	to	Sat 02/08/2020		(Import)	
1301	Continuous	1600		1400 MW	
Work scheduled by: ISONE				Impacts Total Transfer Capability	0 MW
				TTC with All Lines In Service	1400 MW
				1400 MW	
<hr/>					
BERKSHIR-NORTHFLD_345_312				FWD	REV
Wed 01/29/2020	to	Sat 02/08/2020		(Import)	(Export)
1301	Continuous	1600		100 MW	100 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	200 MW
				200 MW	
<hr/>					
SCH-NE-NYISO_LIMIT_700				FWD	
Wed 01/29/2020	to	Sat 02/08/2020		(Import)	
1301	Continuous	1600		900 MW	
Work scheduled by: ISONE				Impacts Total Transfer Capability	500 MW
				TTC with All Lines In Service	1400 MW
				1400 MW	

NYISO TRANSFER LIMITATIONS

Friday ,January 24, 2020 to Sunday ,July 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-NE_LIMIT_500			REV
Wed 01/29/2020	to	Sat 02/08/2020	(Export)
1301	Continuous	1600	700 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability 1000 MW
			TTC with All Lines In Service 1700 MW
RAMAPO__-BUCHAN_N_345_Y94			FWD
Mon 02/03/2020	to	Tue 02/04/2020	(Import)
0001	Continuous	0230	4800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 900 MW
			TTC with All Lines In Service 5700 MW
PLSNTVLY_345KV_RNS4			FWD
Mon 02/03/2020	to	Tue 02/04/2020	(Import)
0001	Continuous	2200	3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 1900 MW
			TTC with All Lines In Service 5700 MW
BECK__-NIAGARA_230_PA27			
Mon 02/03/2020	to	Thu 02/13/2020	SCH - OH - NY
0500	Continuous	1700	Impacts Total Transfer Capability
Work scheduled by: IESO			TTC with All Lines In Service
MOSES__-ADIRNDCK_230_MA1			FWD
Mon 02/03/2020	to	Fri 02/07/2020	(Import)
0700	Continuous	1530	2300 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 850 MW
			TTC with All Lines In Service 3150 MW
EFISHKIL-WOOD_ST_345_F39			FWD
Mon 02/10/2020	to	Mon 02/10/2020	(Import)
0001	Continuous	0030	4000 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 1700 MW
			TTC with All Lines In Service 5700 MW
WOOD_ST_-PLSNTVLE_345_Y87			FWD
Mon 02/10/2020	to	Wed 02/12/2020	(Import)
0001	Continuous	0030	4000 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 1700 MW
			TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 24, 2020 to Sunday ,July 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA1

Mon 02/10/2020 to Fri 02/14/2020
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

HURLYAVE-ROSETON__345_303

Tue 02/11/2020 to Thu 02/13/2020
0700 Continuous 1600

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 1600 MW
TTC with All Lines In Service 5700 MW

EFISHKIL-WOOD_ST__345_F39

Wed 02/12/2020 to Wed 02/12/2020
0001 Continuous 0030

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1700 MW
TTC with All Lines In Service 5700 MW

EFISHKIL-WOOD_ST__345_F38

Fri 02/14/2020 to Sat 02/15/2020
0001 Continuous 0030

Work scheduled by: ConEd

UPDATED by CONED 01/15/2020

FWD
(Import)
UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1700 MW
TTC with All Lines In Service 5700 MW

WOOD_ST_-PLSNTVLE_345_Y86

Fri 02/14/2020 to Sat 02/15/2020
0001 Continuous 0030

Work scheduled by: ConEd

UPDATED by CONED 01/15/2020

FWD
(Import)
UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1700 MW
TTC with All Lines In Service 5700 MW

SPRNBK_-TREMONT__345_X28

Mon 02/17/2020 to Mon 02/17/2020
0001 Continuous 1800

Work scheduled by: ConEd

CANCELLED by ConEd 01/24/2020

FWD
(Import)
SPR/DUN-SOUTH **4200 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 4600 MW

WATRCURE-OAKDALE__345_31

Mon 02/17/2020 to Mon 02/17/2020
1500 Continuous 1530

Work scheduled by: NYSEG

UPDATED by NYSEG 12/20/2019

FWD
(Import)
SCH - PJ - NY **2750 MW**
Impacts Total Transfer Capability 150 MW
TTC with All Lines In Service 2900 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 24, 2020 to Sunday ,July 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -ADIRNDCK_230_MA1				FWD
Tue 02/18/2020	to	Fri 02/21/2020		(Import)
0700	Continuous	1530		MOSES SOUTH 2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW
SPRNBRK_345KV_RNS5				FWD
Mon 02/24/2020	to	Mon 02/24/2020	<u>CANCELLED by ConEd 01/24/2020</u>	(Import)
0001	Continuous	0030		SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW
SPRNBRK -W49TH_ST_345_M51				FWD
Mon 02/24/2020	to	Sun 03/01/2020	<u>CANCELLED by ConEd 01/24/2020</u>	(Import)
0001	Continuous	0200		SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW
SPRNBRK_345KV_RNS5				FWD
Wed 02/26/2020	to	Wed 02/26/2020	<u>CANCELLED by ConEd 01/24/2020</u>	(Import)
2130	Continuous	2200		SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW
SPRNBRK_345KV_RNS5				FWD
Thu 02/27/2020	to	Sun 03/01/2020	<u>CANCELLED by ConEd 01/24/2020</u>	(Import)
2301	Continuous	0200		SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW
NIAGARA -PACKARD_230_62				FWD
Fri 02/28/2020	to	Fri 02/28/2020		(Import) (Export)
0500	Continuous	1530		SCH - OH - NY 900 MW 1850 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 1150 MW 50 MW
				TTC with All Lines In Service 2050 MW 1900 MW
DUNWODIE_345KV_4				FWD
Sun 03/01/2020	to	Sun 03/08/2020		(Import)
0001	Continuous	2200		SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 24, 2020 to Sunday ,July 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						FWD
CHATGUAY-MASSENA__765_7040						(Import)
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	MOSES SOUTH 1550 MW
0500	Continuous	1730				Impacts Total Transfer Capability 1600 MW
Work scheduled by: NYPA						TTC with All Lines In Service 3150 MW
<hr/>						FWD
CHATGUAY-MASSENA__765_7040						(Import) (Export)
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	SCH - HQ - NY 0 MW 0 MW
0500	Continuous	1730				Impacts Total Transfer Capability 1500 MW 1000 MW
Work scheduled by: NYPA						TTC with All Lines In Service 1500 MW 1000 MW
<hr/>						FWD
MARCY__765_345_AT1						(Import)
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	MOSES SOUTH 1750 MW
0500	Continuous	1730				Impacts Total Transfer Capability 1400 MW
Work scheduled by: NYPA						TTC with All Lines In Service 3150 MW
<hr/>						FWD
MARCY__765_345_AT2						(Import)
Mon 03/02/2020	to	Fri 03/06/2020				MOSES SOUTH 1700 MW
0500	Continuous	1730				Impacts Total Transfer Capability 1450 MW
Work scheduled by: NYPA						TTC with All Lines In Service 3150 MW
<hr/>						FWD
MASSENA_-MARCY__765_MSU1						(Import)
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	CENTRAL EAST - VC 2265 MW
0500	Continuous	1730				Impacts Total Transfer Capability 710 MW
Work scheduled by: NYPA						TTC with All Lines In Service 2975 MW
<hr/>						FWD
MASSENA_-MARCY__765_MSU1						(Import)
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	MOSES SOUTH 500 MW
0500	Continuous	1730				Impacts Total Transfer Capability 2650 MW
Work scheduled by: NYPA						TTC with All Lines In Service 3150 MW
<hr/>						FWD
MASSENA_-MARCY__765_MSU1						(Import) (Export)
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	SCH - HQ - NY 475 MW 1000 MW
0500	Continuous	1730				Impacts Total Transfer Capability 1025 MW 0 MW
Work scheduled by: NYPA						TTC with All Lines In Service 1500 MW 1000 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 24, 2020 to Sunday ,July 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA -MARCY 765_MSU1				FWD	
Mon 03/02/2020	to	Fri 03/06/2020	UPDATED by NYPA 08/08/2019	(Import)	
0500	Continuous	1730		SCH - HQ_CEDARS	90 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	109 MW
				TTC with All Lines In Service	199 MW
MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040				FWD	
Mon 03/02/2020	to	Fri 03/06/2020		(Import)	
0500		1730		MOSES SOUTH	500 MW
Work scheduled by:				Impacts Total Transfer Capability	2650 MW
				TTC with All Lines In Service	3150 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2				FWD	REV
Mon 03/02/2020	to	Fri 03/06/2020		(Import)	(Export)
0500		1730		SCH - HQ - NY	850 MW 0 MW
Work scheduled by:				Impacts Total Transfer Capability	650 MW 1000 MW
				TTC with All Lines In Service	1500 MW 1000 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2				FWD	
Mon 03/02/2020	to	Fri 03/06/2020		(Import)	
0500		1730		SCH - HQ_CEDARS	90 MW
Work scheduled by:				Impacts Total Transfer Capability	109 MW
				TTC with All Lines In Service	199 MW
STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1				FWD	
Mon 03/02/2020	to	Fri 03/06/2020		(Import)	
0500		1730		SCH - HQ_CEDARS	90 MW
Work scheduled by:				Impacts Total Transfer Capability	109 MW
				TTC with All Lines In Service	199 MW
STLAWRNC-MOSES 230_L33P & MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2				FWD	
Mon 03/02/2020	to	Fri 03/06/2020		(Import)	
0500		1730		SCH - HQ_CEDARS	90 MW
Work scheduled by:				Impacts Total Transfer Capability	109 MW
				TTC with All Lines In Service	199 MW
SHOR_NPX-SHOREHAM 138_CSC				FWD	REV
Mon 03/02/2020	to	Tue 03/03/2020		(Import)	(Export)
0600	Continuous	1300		SCH - NPX_CSC	0 MW 0 MW
Work scheduled by: LI				Impacts Total Transfer Capability	330 MW 330 MW
				TTC with All Lines In Service	330 MW 330 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 24, 2020 to Sunday ,July 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROSETON_-EFISHKIL_345_RFK305

Mon 03/02/2020 to Fri 03/20/2020
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
UPNY CONED **4800 MW**
Impacts Total Transfer Capability 900 MW
TTC with All Lines In Service 5700 MW

EASTVIEW-SPRNBK_345_W78

Fri 03/06/2020 to Sat 03/07/2020
0001 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1350 MW
TTC with All Lines In Service 5700 MW

MILLWOOD-EASTVIEW_345_W85

Fri 03/06/2020 to Sat 03/07/2020
0001 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1350 MW
TTC with All Lines In Service 5700 MW

SPRNBK_345KV_RNS3

Fri 03/06/2020 to Sat 03/07/2020
0001 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

MOSES_-ADIRNDCK_230_MA1

Sat 03/07/2020 to Fri 05/29/2020
0700 Continuous 1300

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

W49TH_ST_345KV_5

Mon 03/09/2020 to Mon 03/09/2020 **CANCELLED by ConEd 01/22/2020**
0001 Continuous 0030

Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **350 MW**
Impacts Total Transfer Capability 310 MW
TTC with All Lines In Service 660 MW

SPRNBK_-W49TH_ST_345_M52

Mon 03/09/2020 to Wed 03/11/2020 **CANCELLED by ConEd 01/22/2020**
0001 Continuous 2200

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 24, 2020 to Sunday ,July 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK__345KV_RNS4

Mon 03/09/2020 to Wed 03/11/2020
 0001 Continuous 2200
 Work scheduled by: ConEd

CANCELLED by ConEd 01/22/2020

FWD
 (Import)
3200 MW
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

VOLNEY__-MARCY__345_19

Tue 03/10/2020 to Tue 03/10/2020
 0700 Continuous 1530
 Work scheduled by: NYPA

UPDATED by NYPA 09/24/2019

ARR: 19

FWD
 (Import)
2825 MW
 Impacts Total Transfer Capability 150 MW
 TTC with All Lines In Service 2975 MW

VOLNEY__-MARCY__345_19

Tue 03/10/2020 to Tue 03/10/2020
 0700 Continuous 1530
 Work scheduled by: NYPA

UPDATED by NYPA 09/24/2019

ARR: 19

FWD
 (Import)
4900 MW
 Impacts Total Transfer Capability 350 MW
 TTC with All Lines In Service 5250 MW

W49TH_ST_345KV_5

Wed 03/11/2020 to Wed 03/11/2020
 2130 Continuous 2200
 Work scheduled by: ConEd

CANCELLED by ConEd 01/22/2020

FWD
 (Import)
350 MW
 Impacts Total Transfer Capability 310 MW
 TTC with All Lines In Service 660 MW

ROCHESTR-PANNELL__345_RP2

Sat 03/14/2020 to Mon 03/23/2020
 0500 Continuous 1700
 Work scheduled by: NYPA

FWD
 (Import)
2300 MW
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

BECK__-NIAGARA__230_PA27

Mon 03/16/2020 to Fri 03/20/2020
 0400 Continuous 1700
 Work scheduled by: IESO

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

MARCY__345KV_CSC

Mon 03/16/2020 to Fri 03/27/2020
 0500 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
2925 MW
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 24, 2020 to Sunday ,July 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHASLAKE-PORTER__230_11				FWD
Wed 03/18/2020	to	Wed 03/18/2020		(Import)
0630	Daily(No Weekends)	1330	MOSES SOUTH	2300 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW
SCH-NYISO-NE_LIMIT_900				REV
Wed 03/18/2020	to	Tue 03/31/2020		(Export)
0700	Continuous	2359	SCH - NE - NY	1100 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability 600 MW
				TTC with All Lines In Service 1700 MW
BUCHAN_N-EASTVIEW_345_W93				FWD
Thu 03/19/2020	to	Thu 03/19/2020		(Import)
0200	Continuous	0230	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1350 MW
				TTC with All Lines In Service 5700 MW
EASTVIEW-SPRNBRK__345_W79				FWD
Thu 03/19/2020	to	Fri 03/20/2020		(Import)
0200	Continuous	0200	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1350 MW
				TTC with All Lines In Service 5700 MW
BUCHAN_N-EASTVIEW_345_W93				FWD
Fri 03/20/2020	to	Fri 03/20/2020		(Import)
0130	Continuous	0200	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1350 MW
				TTC with All Lines In Service 5700 MW
MILLWOOD-EASTVIEW_345_W85				FWD
Sun 03/22/2020	to	Sun 03/22/2020	UPDATED by CE 12/20/2019	(Import)
0201	Continuous	0231	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1350 MW
				TTC with All Lines In Service 5700 MW
DUNWODIE-MOTTHAVN_345_72				FWD
Sun 03/22/2020	to	Tue 03/24/2020	UPDATED by CE 12/20/2019	(Import)
0201	Continuous	0200	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 24, 2020 to Sunday ,July 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_8						FWD
Sun 03/22/2020	to	Tue 03/24/2020	<u>UPDATED</u>	<u>by CE</u>	<u>12/20/2019</u>	(Import)
0201	Continuous	0200				3800 MW
Work scheduled by: ConEd						SPR/DUN-SOUTH
						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
EASTVIEW-SPRNBK_345_W78						FWD
Sun 03/22/2020	to	Tue 03/24/2020	<u>UPDATED</u>	<u>by CE</u>	<u>12/20/2019</u>	(Import)
0201	Continuous	0200				4350 MW
Work scheduled by: ConEd						UPNY CONED
						Impacts Total Transfer Capability 1350 MW
						TTC with All Lines In Service 5700 MW
DUNWODIE_345KV_5						FWD
Sun 03/22/2020	to	Mon 05/11/2020	<u>UPDATED</u>	<u>by CE</u>	<u>12/20/2019</u>	(Import)
0201	Continuous	0300				3800 MW
Work scheduled by: ConEd						SPR/DUN-SOUTH
						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_7						FWD
Sun 03/22/2020	to	Mon 05/11/2020	<u>UPDATED</u>	<u>by CE</u>	<u>12/20/2019</u>	(Import)
0201	Continuous	0300				3800 MW
Work scheduled by: ConEd						SPR/DUN-SOUTH
						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
SPRNBK_-DUNWODIE_345_W75						FWD
Sun 03/22/2020	to	Mon 05/11/2020	<u>UPDATED</u>	<u>by CE</u>	<u>12/20/2019</u>	(Import)
0201	Continuous	0300				3800 MW
Work scheduled by: ConEd						SPR/DUN-SOUTH
						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
SPRNBK_345KV_RNS3						FWD
Sun 03/22/2020	to	Mon 05/11/2020	<u>UPDATED</u>	<u>by CE</u>	<u>12/20/2019</u>	(Import)
0201	Continuous	0300				3800 MW
Work scheduled by: ConEd						SPR/DUN-SOUTH
						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
RAMAPO_-BUCHAN_N_345_Y94						FWD
Tue 03/24/2020	to	Tue 03/24/2020				(Import)
0001	Continuous	0030				4800 MW
Work scheduled by: ConEd						UPNY CONED
						Impacts Total Transfer Capability 900 MW
						TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 24, 2020 to Sunday ,July 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD-EASTVIEW_345_W85					FWD
Tue 03/24/2020	to	Tue 03/24/2020	<u>UPDATED</u>	<u>by CE</u>	(Import)
0130	Continuous	0200		<u>12/20/2019</u>	4350 MW
Work scheduled by: ConEd					UPNY CONED
					Impacts Total Transfer Capability 1350 MW
					TTC with All Lines In Service 5700 MW
DUNWODIE-MOTTHAVN_345_71					FWD
Tue 03/24/2020	to	Thu 03/26/2020	<u>UPDATED</u>	<u>by CE</u>	(Import)
0201	Continuous	0200		<u>12/20/2019</u>	3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_3					FWD
Tue 03/24/2020	to	Thu 03/26/2020	<u>UPDATED</u>	<u>by CE</u>	(Import)
0201	Continuous	0200		<u>12/20/2019</u>	3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
RAMAPO__-BUCHAN_N_345_Y94					FWD
Tue 03/24/2020	to	Tue 03/24/2020			(Import)
0630	Continuous	0700			4800 MW
Work scheduled by: ConEd					UPNY CONED
					Impacts Total Transfer Capability 900 MW
					TTC with All Lines In Service 5700 MW
SPRNBK__345KV_RS3 & SPRNBK__345KV_RS4					FWD
Thu 03/26/2020	to	Sun 03/29/2020			(Import)
0201		0200			3800 MW
Work scheduled by:					SPR/DUN-SOUTH
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
NIAGARA_-KINTIGH__345_NS1-38					FWD
Fri 03/27/2020	to	Fri 03/27/2020			(Import)
0600	Continuous	1530			1700 MW
Work scheduled by: NYPA					DYSINGER EAST
					Impacts Total Transfer Capability 1450 MW
					TTC with All Lines In Service 3150 MW
BECK____-PACKARD__230_BP76					FWD
Fri 03/27/2020	to	Fri 03/27/2020			(Import) (Export)
0800	Daily(No Weekends)	1600			1650 MW 1400 MW
Work scheduled by: NGrid					SCH - OH - NY
					Impacts Total Transfer Capability 400 MW 500 MW
					TTC with All Lines In Service 2050 MW 1900 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 24, 2020 to Sunday ,July 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BECK -NIAGARA 230_PA27

Mon 03/30/2020 to Fri 05/29/2020
 0400 Continuous 1700
 Work scheduled by: IESO

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

MARCY -EDIC 345_UE1-7

Tue 03/31/2020 to Tue 03/31/2020 **UPDATED by NYPA 09/24/2019**
 0700 Continuous 1530
 Work scheduled by: NYPA **ARR: 19&16**

FWD
 (Import)
 OSWEGO EXPORT **5250 MW**
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 5250 MW

RAMAPO -LADENTWN 345_W72

Wed 04/01/2020 to Thu 04/02/2020
 0001 Continuous 1830
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4400 MW**
 Impacts Total Transfer Capability 1300 MW
 TTC with All Lines In Service 5700 MW

SCH-NYISO-NE LIMIT_700

Wed 04/01/2020 to Fri 04/03/2020
 0001 Continuous 1600
 Work scheduled by: ISONE

REV
 (Export)
 SCH - NE - NY **900 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 1700 MW

FRASANNX-COOPERS 345_UCC2-41

Wed 04/01/2020 to Thu 04/02/2020 **UPDATED by NYPA 11/12/2019**
 0700 Continuous 1530
 Work scheduled by: NYPA **ARR: 19**

FWD
 (Import)
 CENTRAL EAST - VC **2500 MW**
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

MARCY -FRASANNX 345_UCC2-41

Wed 04/01/2020 to Thu 04/02/2020 **UPDATED by NYPA 11/12/2019**
 0700 Continuous 1530
 Work scheduled by: NYPA **ARR: 19**

FWD
 (Import)
 CENTRAL EAST - VC **2500 MW**
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

LINDN_CG-LNDVFT 345_V-3022

Sun 04/05/2020 to Sat 04/11/2020
 1400 Continuous 1400
 Work scheduled by: PJM

FWD REV
 (Import) (Export)
 SCH - PJM_VFT **0 MW 0 MW**
 Impacts Total Transfer Capability 315 MW 315 MW
 TTC with All Lines In Service 315 MW 315 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 24, 2020 to Sunday ,July 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___-N.SCTLND_345_18

Tue 04/07/2020 to Wed 04/08/2020
0700 Continuous 1530

Work scheduled by: NYPA

UPDATED by NYPA 09/24/2019

ARR: 19

FWD

(Import)

CENTRAL EAST - VC **2090 MW**
Impacts Total Transfer Capability 885 MW
TTC with All Lines In Service 2975 MW

PLSNTVLY-EFISHKIL_345_F36

Mon 04/13/2020 to Tue 04/14/2020
0001 Continuous 0200

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1700 MW
TTC with All Lines In Service 5700 MW

SAND_BAR-PLATSBRG_115_PV20

Mon 04/13/2020 to Tue 04/14/2020
0600 Daily 1800

Work scheduled by: ISONE

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FRASER_-GILBOA___345_GF5-35

Mon 04/13/2020 to Wed 04/22/2020
0700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC **2650 MW**
Impacts Total Transfer Capability 325 MW
TTC with All Lines In Service 2975 MW

NIAGARA_-ROCHESTR_345_NR2

Wed 04/15/2020 to Fri 05/01/2020
0500 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

ROCHESTR-PANNELL___345_RP1

Mon 04/20/2020 to Fri 04/24/2020
0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

DOLSONAV-ROCKTVRN_345_DART44

Mon 04/27/2020 to Sun 05/10/2020
0700 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 03/21/2019

FWD

(Import)

CENTRAL EAST - VC **2720 MW**
Impacts Total Transfer Capability 255 MW
TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 24, 2020 to Sunday ,July 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HURLYAVE-ROSETON__345_303

Mon 04/27/2020 to Fri 05/29/2020
0800 Continuous 1600

Work scheduled by: CHGE

UPDATED by CHGE 10/09/2019

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 1600 MW
TTC with All Lines In Service 5700 MW

DUNWODIE-MOTTHAVN_345_72

Tue 04/28/2020 to Sat 05/02/2020
0200 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

MILLWOOD-EASTVIEW_345_W85

Wed 04/29/2020 to Wed 04/29/2020
0201 Continuous 0230

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1350 MW
TTC with All Lines In Service 5700 MW

EASTVIEW-SPRNBK__345_W78

Wed 04/29/2020 to Sun 05/03/2020
0201 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1350 MW
TTC with All Lines In Service 5700 MW

SCH-IMO-NYISO_LIMIT_1600

Fri 05/01/2020 to Sat 10/31/2020
0001 Continuous 2359

Work scheduled by: IESO

UPDATED by IESO 05/03/2019

FWD
(Import)
SCH - OH - NY **1900 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 1900 MW

DUNWODIE-MOTTHAVN_345_71

Sat 05/02/2020 to Wed 05/06/2020
0201 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_3

Sat 05/02/2020 to Wed 05/06/2020
0201 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 24, 2020 to Sunday ,July 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD-EASTVIEW_345_W85

Sun 05/03/2020 to Sun 05/03/2020
0130 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED 4350 MW
Impacts Total Transfer Capability 1350 MW
TTC with All Lines In Service 5700 MW

PANNELL -CLAY_345_2

Mon 05/04/2020 to Fri 05/08/2020
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL 1300 MW
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

NEPTUNE -DUFFYAVE_345_NEPTUNE

Mon 05/04/2020 to Mon 05/18/2020
0800 Continuous 1700

Work scheduled by: PJM

FWD
(Import)
SCH - PJM_NEPTUNE 0 MW
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

NEWBRDGE-DUFFYAVE_345_501

Mon 05/04/2020 to Mon 05/18/2020
0800 Continuous 1700

Work scheduled by: PJM

FWD
(Import)
SCH - PJM_NEPTUNE 0 MW
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_1

Mon 05/04/2020 to Mon 05/18/2020
0800 Continuous 1700

Work scheduled by: PJM

FWD
(Import)
SCH - PJM_NEPTUNE 375 MW
Impacts Total Transfer Capability 285 MW
TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_2

Mon 05/04/2020 to Mon 05/18/2020
0800 Continuous 1700

Work scheduled by: PJM

FWD
(Import)
SCH - PJM_NEPTUNE 375 MW
Impacts Total Transfer Capability 285 MW
TTC with All Lines In Service 660 MW

SPRNBK_345KV_RS3 & SPRNBK_345KV_RS4

Wed 05/06/2020 to Mon 05/11/2020
0201 0200

Work scheduled by:

FWD
(Import)
SPR/DUN-SOUTH 3200 MW
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 24, 2020 to Sunday ,July 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PANNELL_-CLAY_____345_1				FWD	
Mon 05/11/2020	to	Fri 05/15/2020		(Import)	
0700	Continuous	1530	WEST CENTRAL	1300 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	950 MW	
			TTC with All Lines In Service	2250 MW	
COOPERS_-DOLSONAV_345_CCDA42				FWD	
Mon 05/11/2020	to	Fri 05/29/2020	<u>UPDATED</u> <u>by NYPA</u> <u>03/21/2019</u>	(Import)	
0700	Continuous	1730	CENTRAL EAST - VC	2720 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	255 MW	
			TTC with All Lines In Service	2975 MW	
KINTIGH_-ROCHESTR_345_SRI-39				FWD	
Mon 05/18/2020	to	Fri 05/22/2020		(Import)	
0500	Continuous	1530	DYSINGER EAST	1400 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1750 MW	
			TTC with All Lines In Service	3150 MW	
SCH-NE-NYISO_LIMIT_700				FWD	
Mon 05/18/2020	to	Mon 05/18/2020		(Import)	
0700	Continuous	1059	SCH - NE - NY	900 MW	
Work scheduled by: ISONE			Impacts Total Transfer Capability	500 MW	
			TTC with All Lines In Service	1400 MW	
SCH-NYISO-NE_LIMIT_500					REV
Mon 05/18/2020	to	Mon 05/18/2020		(Export)	
0700	Continuous	1059	SCH - NE - NY	700 MW	
Work scheduled by: ISONE			Impacts Total Transfer Capability	900 MW	
			TTC with All Lines In Service	1600 MW	
BERKSHIR-ALPS_____345_393 & BERKSHIR-NORTHFLD_345_312				FWD	REV
Mon 05/18/2020	to	Mon 05/18/2020		(Import)	(Export)
0700		1100	SCH - NE - NY	950 MW	1300 MW
Work scheduled by:			Impacts Total Transfer Capability	450 MW	300 MW
			TTC with All Lines In Service	1400 MW	1600 MW
BERKSHIR-NORTHFLD_345_312				FWD	REV
Mon 05/18/2020	to	Mon 05/18/2020		(Import)	(Export)
0700	Continuous	1100	SCH - NE - NY	900 MW	1500 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	500 MW	100 MW
			TTC with All Lines In Service	1400 MW	1600 MW

ARR: 78

NYISO TRANSFER LIMITATIONS

Friday ,January 24, 2020 to Sunday ,July 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

			FWD	REV
			(Import)	(Export)
BERKSHIR-NORTHFLD_345_312				
Mon 05/18/2020	to	Mon 05/18/2020		
0700	Continuous	1100	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
BERKSHIR-ALPS_____345_393				
Mon 05/18/2020	to	Sat 05/30/2020		
0700	Continuous	1700	SCH - NE - NY	950 MW 1300 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	450 MW 300 MW
			TTC with All Lines In Service	1400 MW 1600 MW
			ARR: 78	
BERKSHIR-ALPS_____345_393				
Mon 05/18/2020	to	Sat 05/30/2020		
0700	Continuous	1700	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
			ARR: 78	
SCH-NE-NYISO_LIMIT_600				
Mon 05/18/2020	to	Tue 05/26/2020		
1100	Continuous	0559	SCH - NE - NY	800 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	600 MW
			TTC with All Lines In Service	1400 MW
SCH-NYISO-NE_LIMIT_600				
Mon 05/18/2020	to	Sat 05/30/2020		REV
1100	Continuous	1459	SCH - NE - NY	800 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	1600 MW
SCH-NE-NYISO_LIMIT_500				
Tue 05/26/2020	to	Sat 05/30/2020		FWD
0600	Continuous	1700	SCH - NE - NY	700 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	700 MW
			TTC with All Lines In Service	1400 MW
BERKSHIR-ALPS_____345_393 & BERKSHIR-NORTHFLD_345_312				
Sat 05/30/2020	to	Sat 05/30/2020		FWD
1500		1700	SCH - NE - NY	950 MW 1300 MW
Work scheduled by:			Impacts Total Transfer Capability	450 MW 300 MW
			TTC with All Lines In Service	1400 MW 1600 MW
			ARR: 78	

NYISO TRANSFER LIMITATIONS

Friday ,January 24, 2020 to Sunday ,July 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

	FWD	REV
BERKSHIR-NORTHFLD_345_312		
Sat 05/30/2020 to Sat 05/30/2020	(Import)	(Export)
1500 Continuous 1700	SCH - NE - NY	900 MW 1500 MW
Work scheduled by: ISONE	Impacts Total Transfer Capability	500 MW 100 MW
	TTC with All Lines In Service	1400 MW 1600 MW
BERKSHIR-NORTHFLD_345_312		
Sat 05/30/2020 to Sat 05/30/2020	(Import)	(Export)
1500 Continuous 1700	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: ISONE	Impacts Total Transfer Capability	100 MW 100 MW
	TTC with All Lines In Service	200 MW 200 MW
SCH-NYISO-NE_LIMIT_500		
Sat 05/30/2020 to Sat 05/30/2020		REV
1500 Continuous 1700	SCH - NE - NY	700 MW
Work scheduled by: ISONE	Impacts Total Transfer Capability	900 MW
	TTC with All Lines In Service	1600 MW
SHOR_NPX-SHOREHAM_138_CSC		
Mon 06/01/2020 to Tue 06/02/2020	(Import)	(Export)
0501 Continuous 1600	SCH - NPX_CSC	0 MW 0 MW
Work scheduled by: LI	Impacts Total Transfer Capability	330 MW 330 MW
	TTC with All Lines In Service	330 MW 330 MW
MOSES__-ADIRNDCK_230_MA2		
Mon 06/01/2020 to Fri 07/31/2020	(Import)	
0700 Continuous 1730	MOSES SOUTH	2100 MW
Work scheduled by: NYPA	Impacts Total Transfer Capability	1050 MW
	TTC with All Lines In Service	3150 MW
NIAGARA_345_230_AT4		
Mon 06/29/2020 to Tue 06/30/2020		REV
0500 Continuous 1530	SCH - OH - NY	1400 MW
Work scheduled by: NYPA	Impacts Total Transfer Capability	300 MW
	TTC with All Lines In Service	1700 MW
SCH-IMO-NYISO_NIAG_CB_3008_W/BB		
Mon 07/27/2020 to Fri 08/07/2020	(Import)	(Export)
0500 Continuous 1530	SCH - OH - NY	1900 MW 1450 MW
Work scheduled by: NYPA	Impacts Total Transfer Capability	0 MW 250 MW
	TTC with All Lines In Service	1900 MW 1700 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 24, 2020 to Sunday ,July 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						FWD	
CHATGUAY-MASSENA__765_7040						(Import)	
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	MOSES SOUTH	1550 MW
0500	Continuous	1730				Impacts Total Transfer Capability	1600 MW
Work scheduled by: NYPA						TTC with All Lines In Service	3150 MW
<hr/>						FWD	REV
CHATGUAY-MASSENA__765_7040						(Import)	(Export)
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	SCH - HQ - NY	0 MW 0 MW
0500	Continuous	1730				Impacts Total Transfer Capability	1500 MW 1000 MW
Work scheduled by: NYPA						TTC with All Lines In Service	1500 MW 1000 MW
<hr/>						FWD	
MARCY__765_345_AT1						(Import)	
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	MOSES SOUTH	1750 MW
0500	Continuous	1730				Impacts Total Transfer Capability	1400 MW
Work scheduled by: NYPA						TTC with All Lines In Service	3150 MW
<hr/>						FWD	
MASSENA_-MARCY__765_MSU1						(Import)	
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	CENTRAL EAST - VC	2265 MW
0500	Continuous	1730				Impacts Total Transfer Capability	710 MW
Work scheduled by: NYPA						TTC with All Lines In Service	2975 MW
<hr/>						FWD	
MASSENA_-MARCY__765_MSU1						(Import)	
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	MOSES SOUTH	500 MW
0500	Continuous	1730				Impacts Total Transfer Capability	2650 MW
Work scheduled by: NYPA						TTC with All Lines In Service	3150 MW
<hr/>						FWD	REV
MASSENA_-MARCY__765_MSU1						(Import)	(Export)
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	SCH - HQ - NY	475 MW 1000 MW
0500	Continuous	1730				Impacts Total Transfer Capability	1025 MW 0 MW
Work scheduled by: NYPA						TTC with All Lines In Service	1500 MW 1000 MW
<hr/>						FWD	
MASSENA_-MARCY__765_MSU1						(Import)	
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	SCH - HQ_CEDARS	90 MW
0500	Continuous	1730				Impacts Total Transfer Capability	100 MW
Work scheduled by: NYPA						TTC with All Lines In Service	190 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 24, 2020 to Sunday ,July 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040		FWD	
Sat 08/01/2020	to Sun 08/02/2020	(Import)	
0500	1730	MOSES SOUTH	500 MW
Work scheduled by:		Impacts Total Transfer Capability	2650 MW
		TTC with All Lines In Service	3150 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2		FWD	REV
Sat 08/01/2020	to Sun 08/02/2020	(Import)	(Export)
0500	1730	SCH - HQ - NY	850 MW 0 MW
Work scheduled by:		Impacts Total Transfer Capability	650 MW 1000 MW
		TTC with All Lines In Service	1500 MW 1000 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2		FWD	
Sat 08/01/2020	to Sun 08/02/2020	(Import)	
0500	1730	SCH - HQ_CEDARS	90 MW
Work scheduled by:		Impacts Total Transfer Capability	100 MW
		TTC with All Lines In Service	190 MW
STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1		FWD	
Sat 08/01/2020	to Sun 08/02/2020	(Import)	
0500	1730	SCH - HQ_CEDARS	90 MW
Work scheduled by:		Impacts Total Transfer Capability	100 MW
		TTC with All Lines In Service	190 MW
STLAWRNC-MOSES 230_L33P & MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2		FWD	
Sat 08/01/2020	to Sun 08/02/2020	(Import)	
0500	1730	SCH - HQ_CEDARS	90 MW
Work scheduled by:		Impacts Total Transfer Capability	100 MW
		TTC with All Lines In Service	190 MW
MOSES -ADIRNDCK 230_MA2		FWD	
Mon 08/03/2020	to Sun 09/13/2020	(Import)	
0700	Continuous 1730	MOSES SOUTH	2100 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	1050 MW
		TTC with All Lines In Service	3150 MW
FRASANNX-COOPERS 345_UCC2-41		FWD	
Mon 09/07/2020	to Fri 10/23/2020	(Import)	
0700	Continuous 1730	CENTRAL EAST - VC	2500 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	475 MW
		TTC with All Lines In Service	2975 MW

ARR: 19

NYISO TRANSFER LIMITATIONS

Friday ,January 24, 2020 to Sunday ,July 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY ___ -FRASANNX_345_UCC2-41 FWD
 Mon 09/07/2020 to Fri 10/23/2020 **UPDATED** **by NYPA** **03/01/2019** (Import)
 0700 Continuous 1730 **CENTRAL EAST - VC** **2500 MW**
 Work scheduled by: NYPA **Impacts Total Transfer Capability** 475 MW
TTC with All Lines In Service 2975 MW

MARCY ___ 765_345_AT1 FWD
 Mon 09/14/2020 to Mon 09/14/2020 (Import)
 0500 Continuous 1730 **MOSES SOUTH** **1750 MW**
 Work scheduled by: NYPA **Impacts Total Transfer Capability** 1400 MW
TTC with All Lines In Service 3150 MW

NIAGARA _-KINTIGH_345_NS1-38 FWD
 Mon 09/14/2020 to Thu 09/17/2020 (Import)
 0500 Continuous 1530 **DYSINGER EAST** **1400 MW**
 Work scheduled by: NYPA **Impacts Total Transfer Capability** 1750 MW
TTC with All Lines In Service 3150 MW

MOSES ___ -ADIRNDCK_230_MA2 FWD
 Tue 09/15/2020 to Sat 11/14/2020 (Import)
 0700 Continuous 1530 **MOSES SOUTH** **2100 MW**
 Work scheduled by: NYPA **Impacts Total Transfer Capability** 1050 MW
TTC with All Lines In Service 3150 MW

NIAGARA _-ROCHESTR_345_NR2 FWD
 Fri 09/18/2020 to Sat 11/14/2020 (Import)
 0500 Continuous 2330 **DYSINGER EAST** **1400 MW**
 Work scheduled by: NYPA **Impacts Total Transfer Capability** 1750 MW
TTC with All Lines In Service 3150 MW

CLAY ___ -EDIC_345_1-16 FWD
 Mon 09/21/2020 to Fri 09/25/2020 (Import)
 0700 Continuous 1530 **OSWEGO EXPORT** **4850 MW**
 Work scheduled by: NYPA **Impacts Total Transfer Capability** 400 MW
TTC with All Lines In Service 5250 MW

ROSETON _-ROCKTVRN_345_311 FWD
 Mon 09/21/2020 to Fri 10/23/2020 **UPDATED** **by CHGE** **10/09/2019** (Import)
 0800 Continuous 1600 **UPNY CONED** **4400 MW**
 Work scheduled by: CHGE **Impacts Total Transfer Capability** 1300 MW
TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 24, 2020 to Sunday ,July 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_3				FWD
Fri 09/25/2020	to	Fri 09/25/2020	CANCELLED by ConEd 01/21/2020	(Import)
0001	Continuous	0030		
Work scheduled by: ConEd				
				SPR/DUN-SOUTH 3800 MW
				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_5				FWD
Fri 09/25/2020	to	Fri 09/25/2020	CANCELLED by ConEd 01/21/2020	(Import)
0001	Continuous	0030		
Work scheduled by: ConEd				
				SPR/DUN-SOUTH 3800 MW
				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
DUNWODIE-MOTTHAVN_345_71				FWD
Fri 09/25/2020	to	Fri 10/30/2020	CANCELLED by ConEd 01/21/2020	(Import)
0001	Continuous	0300		
Work scheduled by: ConEd				
				SPR/DUN-SOUTH 3800 MW
				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_3				FWD
Mon 09/28/2020	to	Sat 10/31/2020		(Import)
0001	Continuous	0100		
Work scheduled by: ConEd				
				SPR/DUN-SOUTH 3800 MW
				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_4				FWD
Mon 09/28/2020	to	Sat 10/31/2020		(Import)
0001	Continuous	0100		
Work scheduled by: ConEd				
				SPR/DUN-SOUTH 3800 MW
				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
PLSNTVLE-DUNWODIE_345_W89				FWD
Mon 09/28/2020	to	Sat 10/31/2020		(Import)
0001	Continuous	0100		
Work scheduled by: ConEd				
				UPNY CONED 4000 MW
				Impacts Total Transfer Capability 1700 MW
				TTC with All Lines In Service 5700 MW
CLAY -EDIC 345_2-15				FWD
Mon 09/28/2020	to	Fri 10/02/2020		(Import)
0700	Continuous	1530		
Work scheduled by: NYPA				
				OSWEGO EXPORT 4850 MW
				Impacts Total Transfer Capability 400 MW
				TTC with All Lines In Service 5250 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 24, 2020 to Sunday ,July 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOTTHAVN-RAINEY___345_Q11					FWD	
Thu 10/01/2020	to	Thu 11/05/2020	UPDATED	by CONED	12/17/2019	(Import)
0001	Continuous	0200				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<hr/>						
SAND_BAR-PLATSBRG_115_PV20						
Sat 10/17/2020	to	Sat 11/14/2020				
0600	Continuous	1800				
Work scheduled by: ISONE					SCH - NE - NY	
					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
<hr/>						
LEEDS___-HURLYAVE_345_301					FWD	
Mon 10/26/2020	to	Fri 12/04/2020				(Import)
0800	Continuous	1600				4100 MW
Work scheduled by: CHGE					UPNY CONED	
					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	5700 MW
<hr/>						
DUNWODIE_345KV_3					FWD	
Fri 10/30/2020	to	Fri 10/30/2020	CANCELLED	by ConEd	01/21/2020	(Import)
0230	Continuous	0300				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<hr/>						
DUNWODIE_345KV_5					FWD	
Fri 10/30/2020	to	Fri 10/30/2020	CANCELLED	by ConEd	01/21/2020	(Import)
0230	Continuous	0300				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<hr/>						
SCH-IMO-NYISO_LIMIT_1750					FWD	
Sun 11/01/2020	to	Fri 04/30/2021	UPDATED	by IESO	05/03/2019	(Import)
0001	Continuous	2359				2050 MW
Work scheduled by: IESO					SCH - OH - NY	
					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	2050 MW
<hr/>						
SCH-NYISO-IMO_LIMIT_1600					REV	
Sun 11/01/2020	to	Fri 04/30/2021	UPDATED	by IESO	05/03/2019	(Export)
0001	Continuous	2359				1900 MW
Work scheduled by: IESO					SCH - OH - NY	
					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	1900 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 24, 2020 to Sunday ,July 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHATGUAY-MASSENA__765_7040				FWD	
Sun 11/15/2020	to	Mon 11/30/2020		(Import)	
0100	Continuous	1900	MOSES SOUTH	1550 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1600 MW	
			TTC with All Lines In Service	3150 MW	
CHATGUAY-MASSENA__765_7040				FWD	REV
Sun 11/15/2020	to	Mon 11/30/2020		(Import)	(Export)
0100	Continuous	1900	SCH - HQ - NY	0 MW	0 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1500 MW	1000 MW
			TTC with All Lines In Service	1500 MW	1000 MW
MARCY__765_345_AT1				FWD	
Sun 11/15/2020	to	Mon 11/30/2020		(Import)	
0100	Continuous	1900	MOSES SOUTH	1750 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1400 MW	
			TTC with All Lines In Service	3150 MW	
			ARR: 19		
MARCY__765_345_AT2				FWD	
Sun 11/15/2020	to	Mon 11/30/2020		(Import)	
0100	Continuous	1900	MOSES SOUTH	1700 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1450 MW	
			TTC with All Lines In Service	3150 MW	
			ARR: 19		
MASSENA_-MARCY__765_MSU1				FWD	
Sun 11/15/2020	to	Mon 11/30/2020		(Import)	
0100	Continuous	1900	CENTRAL EAST - VC	2265 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	710 MW	
			TTC with All Lines In Service	2975 MW	
MASSENA_-MARCY__765_MSU1				FWD	
Sun 11/15/2020	to	Mon 11/30/2020		(Import)	
0100	Continuous	1900	MOSES SOUTH	500 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	2650 MW	
			TTC with All Lines In Service	3150 MW	
MASSENA_-MARCY__765_MSU1				FWD	REV
Sun 11/15/2020	to	Mon 11/30/2020		(Import)	(Export)
0100	Continuous	1900	SCH - HQ - NY	475 MW	1000 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1025 MW	0 MW
			TTC with All Lines In Service	1500 MW	1000 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 24, 2020 to Sunday ,July 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA -MARCY 765_MSU1		FWD	
Sun 11/15/2020	to Mon 11/30/2020	(Import)	
0100	Continuous 1900	SCH - HQ_CEDARS	90 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	109 MW
		TTC with All Lines In Service	199 MW
MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040		FWD	
Sun 11/15/2020	to Mon 11/30/2020	(Import)	
0100	1900	MOSES SOUTH	500 MW
Work scheduled by:		Impacts Total Transfer Capability	2650 MW
		TTC with All Lines In Service	3150 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2		FWD	REV
Sun 11/15/2020	to Mon 11/30/2020	(Import)	(Export)
0100	1900	SCH - HQ - NY	850 MW 0 MW
Work scheduled by:		Impacts Total Transfer Capability	650 MW 1000 MW
		TTC with All Lines In Service	1500 MW 1000 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2		FWD	
Sun 11/15/2020	to Mon 11/30/2020	(Import)	
0100	1900	SCH - HQ_CEDARS	90 MW
Work scheduled by:		Impacts Total Transfer Capability	109 MW
		TTC with All Lines In Service	199 MW
STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1		FWD	
Sun 11/15/2020	to Mon 11/30/2020	(Import)	
0100	1900	SCH - HQ_CEDARS	90 MW
Work scheduled by:		Impacts Total Transfer Capability	109 MW
		TTC with All Lines In Service	199 MW
STLAWRNC-MOSES 230_L33P & MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2		FWD	
Sun 11/15/2020	to Mon 11/30/2020	(Import)	
0100	1900	SCH - HQ_CEDARS	90 MW
Work scheduled by:		Impacts Total Transfer Capability	109 MW
		TTC with All Lines In Service	199 MW
PLSNTVLE-DUNWODIE 345_W89		FWD	
Mon 11/16/2020	to Mon 11/16/2020	(Import)	
0001	Continuous 0030	UPNY CONED	4000 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability	1700 MW
		TTC with All Lines In Service	5700 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 24, 2020 to Sunday ,July 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLE-DUNWODIE_345_W89

Thu 11/26/2020 to Thu 11/26/2020
 0230 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
UPNY CONED 4000 MW
 Impacts Total Transfer Capability 1700 MW
 TTC with All Lines In Service 5700 MW

MOSES -ADIRNDCK_230_MAI

Tue 12/01/2020 to Mon 05/31/2021
 0700 Continuous 1300
 Work scheduled by: NYPA

FWD
 (Import)
MOSES SOUTH 2300 MW
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

SAND_BAR-PLATSBRG_115_PV20

Mon 12/07/2020 to Fri 12/11/2020
 0700 Continuous 1530
 Work scheduled by: NYPA

SCH - NE - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

SAND_BAR-PLATSBRG_115_PV20

Mon 12/14/2020 to Fri 12/18/2020
 0700 Continuous 1530
 Work scheduled by: NYPA

SCH - NE - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

HOPATCON-RAMAPO_500_5018

Mon 02/01/2021 to Wed 02/03/2021
 0001 Continuous 2200
 Work scheduled by: ConEd

FWD REV
 (Import) (Export)
SCH - PJ - NY 1250 MW 1200 MW
 Impacts Total Transfer Capability 1650 MW 650 MW
 TTC with All Lines In Service 2900 MW 1850 MW

HOPATCON-RAMAPO_500_5018

Mon 02/01/2021 to Wed 02/03/2021
 0001 Continuous 2200
 Work scheduled by: ConEd

FWD
 (Import)
UPNY CONED 5000 MW
 Impacts Total Transfer Capability 700 MW
 TTC with All Lines In Service 5700 MW

RAMAPO_345_345_PAR3500

Mon 02/01/2021 to Wed 02/03/2021
 0001 Continuous 2200
 Work scheduled by: ConEd

FWD REV
 (Import) (Export)
SCH - PJ - NY 2150 MW 1250 MW
 Impacts Total Transfer Capability 750 MW 600 MW
 TTC with All Lines In Service 2900 MW 1850 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 24, 2020 to Sunday ,July 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

RAMAPO__345_345_PAR4500				FWD	REV
Mon 02/01/2021	to	Wed 02/03/2021		(Import)	(Export)
0001	Continuous	2200		SCH - PJ - NY	2150 MW 1250 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	750 MW 600 MW
				TTC with All Lines In Service	2900 MW 1850 MW
RAMAPO__500_345_BK 1500				FWD	REV
Mon 02/01/2021	to	Wed 02/03/2021		(Import)	(Export)
0001	Continuous	2200		SCH - PJ - NY	1250 MW 1200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	1650 MW 650 MW
				TTC with All Lines In Service	2900 MW 1850 MW
RAMAPO__500_345_BK 1500				FWD	
Mon 02/01/2021	to	Wed 02/03/2021		(Import)	
0001	Continuous	2200		UPNY CONED	5000 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	700 MW
				TTC with All Lines In Service	5700 MW
DUNWODIE_345KV_3				FWD	
Mon 03/01/2021	to	Mon 03/01/2021		(Import)	
0001	Continuous	0030		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_5				FWD	
Mon 03/01/2021	to	Mon 03/01/2021		(Import)	
0001	Continuous	0030		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
EASTVIEW-SPRNBK__345_W64				FWD	
Mon 03/01/2021	to	Mon 03/01/2021	UPDATED by CONED 01/23/2020	(Import)	
0001	Continuous	0030		UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	1350 MW
				TTC with All Lines In Service	5700 MW
SPRNBK__345KV_RNS5				FWD	
Mon 03/01/2021	to	Mon 03/01/2021	UPDATED by CONED 01/23/2020	(Import)	
0001	Continuous	0030		SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 24, 2020 to Sunday ,July 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD-EASTVIEW_345_W99

Mon 03/01/2021 to Mon 03/22/2021
0001 Continuous 0200

Work scheduled by: ConEd

UPDATED by CONED 01/23/2020

UPNY CONED

FWD
(Import)

Impacts Total Transfer Capability **4350 MW**
TTC with All Lines In Service 1350 MW
5700 MW

DUNWODIE-MOTTHAVN_345_71

Mon 03/01/2021 to Mon 04/05/2021
0001 Continuous 0300

Work scheduled by: ConEd

SPR/DUN-SOUTH

FWD
(Import)

Impacts Total Transfer Capability **3800 MW**
TTC with All Lines In Service 800 MW
4600 MW

MOTTHAVN-RAINEY__345_Q11

Mon 03/01/2021 to Tue 04/06/2021
0001 Continuous 0700

Work scheduled by: ConEd

SPR/DUN-SOUTH

FWD
(Import)

Impacts Total Transfer Capability **3800 MW**
TTC with All Lines In Service 800 MW
4600 MW

EASTVIEW-SPRNBK__345_W64

Mon 03/22/2021 to Mon 03/22/2021
0130 Continuous 0200

Work scheduled by: ConEd

UPDATED by CONED 01/23/2020

UPNY CONED

FWD
(Import)

Impacts Total Transfer Capability **4350 MW**
TTC with All Lines In Service 1350 MW
5700 MW

SPRNBK__345KV_RNS5

Mon 03/22/2021 to Mon 03/22/2021
0130 Continuous 0200

Work scheduled by: ConEd

UPDATED by CONED 01/23/2020

SPR/DUN-SOUTH

FWD
(Import)

Impacts Total Transfer Capability **3200 MW**
TTC with All Lines In Service 1400 MW
4600 MW

CLAY__-EDIC__345_2-15

Mon 03/29/2021 to Fri 04/16/2021
0800 Continuous 1730

Work scheduled by: NYPA

OSWEGO EXPORT

FWD
(Import)

Impacts Total Transfer Capability **4850 MW**
TTC with All Lines In Service 400 MW
5250 MW

DUNWODIE_345KV_3

Mon 04/05/2021 to Mon 04/05/2021
0230 Continuous 0300

Work scheduled by: ConEd

SPR/DUN-SOUTH

FWD
(Import)

Impacts Total Transfer Capability **3800 MW**
TTC with All Lines In Service 800 MW
4600 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 24, 2020 to Sunday ,July 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_5

Mon 04/05/2021 to Mon 04/05/2021
0230 Continuous 0300

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

SCH-IMO-NYISO_LIMIT_1600

Sat 05/01/2021 to Sun 10/31/2021 UPDATED by IESO 05/03/2019
0001 Continuous 2359

Work scheduled by: IESO

FWD
(Import)
SCH - OH - NY **1900 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 1900 MW

PANNELL_-CLAY_345_2

Mon 05/03/2021 to Fri 05/28/2021
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

MOSES_-ADIRNDCK_230_MA2

Tue 06/01/2021 to Sun 11/14/2021
0700 Continuous 1300

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW