

NYISO TRANSFER LIMITATIONS

Sunday ,January 26, 2020 to Tuesday ,July 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Fri 05/01/2020 **EXTENDED by CONED 10/08/2019**
 0001 Continuous 2359
 Work scheduled by: ConEd

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Fri 05/01/2020
 0001 2359
 Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2550 MW	1600 MW
Impacts Total Transfer Capability	350 MW	250 MW
TTC with All Lines In Service	2900 MW	1850 MW

MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Fri 05/01/2020 **EXTENDED by CONED 10/08/2019**
 0001 Continuous 2359
 Work scheduled by: ConEd

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

STLAWRNC-MOSES_230_L33P

Mon 04/30/2018 to Fri 12/31/2021 **EXT FORCE by IESO 08/21/2018**
 0456 Continuous 2359
 Work scheduled by: IESO

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

SCH-IMO-NYISO_LIMIT_1750

Fri 11/01/2019 to Thu 04/30/2020 **UPDATED by IESO 05/03/2019**
 0001 Continuous 2359
 Work scheduled by: IESO

	FWD
	(Import)
SCH - OH - NY	2050 MW
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	2050 MW

SCH-NYISO-IMO_LIMIT_1600

Fri 11/01/2019 to Thu 04/30/2020 **UPDATED by IESO 05/03/2019**
 0001 Continuous 2359
 Work scheduled by: IESO

	REV
	(Export)
SCH - OH - NY	1900 MW
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	1900 MW

SCH-NYISO-NE_LIMIT_1500

Fri 11/01/2019 to Thu 04/30/2020
 0001 Continuous 2359
 Work scheduled by: NYISO

	REV
	(Export)
SCH - NE - NY	1700 MW
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	1700 MW

NYISO TRANSFER LIMITATIONS

Sunday ,January 26, 2020 to Tuesday ,July 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

OSWEGO_COMPLEX_AVR_O/S					FWD	
Mon 11/18/2019	to	Mon 03/09/2020	<u>EXT FORCE</u>	<u>by GEN</u>	<u>12/26/2019</u>	(Import)
0221	Continuous	0001				CENTRAL EAST - VC 2870 MW
Work scheduled by: Gen					Impacts Total Transfer Capability	105 MW
					TTC with All Lines In Service	2975 MW
DUNWODIE_345KV_6					FWD	
Tue 12/03/2019	to	Thu 02/20/2020	<u>EXT FORCE</u>	<u>by CONED</u>	<u>01/24/2020</u>	(Import)
0048	Continuous	2359				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_8					FWD	
Tue 12/03/2019	to	Thu 02/20/2020	<u>EXT FORCE</u>	<u>by CONED</u>	<u>01/24/2020</u>	(Import)
0048	Continuous	2359				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
PLSNTVLE-DUNWODIE_345_W90					FWD	
Tue 12/03/2019	to	Thu 02/20/2020	<u>EXT FORCE</u>	<u>by CONED</u>	<u>01/24/2020</u>	(Import)
0107	Continuous	2359				UPNY CONED 4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1700 MW
					TTC with All Lines In Service	5700 MW
FRASER__345_FRASER SVC					FWD	
Mon 01/13/2020	to	Fri 01/24/2020	<u>UPDATED</u>	<u>by NYSEG</u>	<u>12/18/2019</u>	(Import)
0800	Continuous	1102				CENTRAL EAST - VC 2935 MW
Work scheduled by: NYSEG					Impacts Total Transfer Capability	40 MW
					TTC with All Lines In Service	2975 MW
FROST_BR-LONG_MTN_345_352					FWD	
Mon 01/20/2020	to	Thu 01/23/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>01/14/2020</u>	(Import)
0100	Continuous	1600				SCH - NE - NY 1300 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	1400 MW
SCH-NE-NYISO_LIMIT_300					FWD	
Mon 01/20/2020	to	Thu 01/23/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>01/14/2020</u>	(Import)
0100	Continuous	1600				SCH - NE - NY 500 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability	900 MW
					TTC with All Lines In Service	1400 MW

NYISO TRANSFER LIMITATIONS

Sunday ,January 26, 2020 to Tuesday ,July 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_500					FWD		
Wed 01/22/2020	to	Thu 01/23/2020	UPDATED	by ISONE	<u>01/23/2020</u>	(Import)	
0500	Continuous	1159				700 MW	
Work scheduled by: ISONE					SCH - NE - NY	700 MW	
					Impacts Total Transfer Capability	700 MW	
					TTC with All Lines In Service	1400 MW	
W49TH_ST-E13THSTA_345_M54					FWD		
Fri 01/24/2020	to	Fri 01/24/2020	CANCELLED	by ConEd	<u>01/22/2020</u>	(Import)	
0001	Continuous	0500				3800 MW	
Work scheduled by: ConEd					SPR/DUN-SOUTH	3800 MW	
					Impacts Total Transfer Capability	800 MW	
					TTC with All Lines In Service	4600 MW	
SCH-IMO-NYISO_LIMIT_900					FWD		
Fri 01/24/2020	to	Fri 01/24/2020				(Import)	
0500	Continuous	1530				1200 MW	
Work scheduled by: NYPA					SCH - OH - NY	1200 MW	
					Impacts Total Transfer Capability	850 MW	
					TTC with All Lines In Service	2050 MW	
SCH-IMO-NYISO_LIMIT_1400					FWD		
Sat 01/25/2020	to	Sat 01/25/2020				(Import)	
0500	Continuous	1700				1700 MW	
Work scheduled by: NYPA					SCH - OH - NY	1700 MW	
					Impacts Total Transfer Capability	350 MW	
					TTC with All Lines In Service	2050 MW	
PLSNTVLE-DUNWODIE_345_W89					FWD		
Sat 01/25/2020	to	Sun 01/26/2020	FORCED	by CE	<u>01/26/2020</u>	(Import)	
1513	Continuous	2359				4000 MW	
Work scheduled by: ConEd					UPNY CONED	4000 MW	
					Impacts Total Transfer Capability	1700 MW	
					TTC with All Lines In Service	5700 MW	
SCH-NYISO-IMO_NIAGARA_CB_3022					FWD	REV	
Tue 01/28/2020	to	Wed 01/29/2020	UPDATED	by NYISO	<u>01/24/2020</u>	(Import)	(Export)
0500	Continuous	1900				1550 MW	1400 MW
Work scheduled by: NYPA					SCH - OH - NY	1550 MW	1400 MW
					Impacts Total Transfer Capability	500 MW	500 MW
					TTC with All Lines In Service	2050 MW	1900 MW
BERKSHIR-ALPS_____345_393					FWD	REV	
Wed 01/29/2020	to	Sat 02/08/2020				(Import)	(Export)
1301	Continuous	1600				1150 MW	1700 MW
Work scheduled by: ISONE					SCH - NE - NY	1150 MW	1700 MW
					Impacts Total Transfer Capability	250 MW	0 MW
					TTC with All Lines In Service	1400 MW	1700 MW

ARR: 78

NYISO TRANSFER LIMITATIONS

Sunday ,January 26, 2020 to Tuesday ,July 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-ALPS _____ 345_393		FWD		REV
Wed 01/29/2020	to	Sat 02/08/2020		(Import) (Export)
1301	Continuous	1600	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
			ARR: 78	
<hr/>				
BERKSHIR-ALPS _____ 345_393 & BERKSHIR-NORTHFLD 345_312				FWD REV
Wed 01/29/2020	to	Sat 02/08/2020		(Import) (Export)
1301		1600	SCH - NE - NY	1150 MW 1700 MW
Work scheduled by:			Impacts Total Transfer Capability	250 MW 0 MW
			TTC with All Lines In Service	1400 MW 1700 MW
			ARR: 78	
<hr/>				
BERKSHIR-NORTHFLD 345_312				FWD
Wed 01/29/2020	to	Sat 02/08/2020		(Import)
1301	Continuous	1600	SCH - NE - NY	1400 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	0 MW
			TTC with All Lines In Service	1400 MW
<hr/>				
BERKSHIR-NORTHFLD 345_312				FWD REV
Wed 01/29/2020	to	Sat 02/08/2020		(Import) (Export)
1301	Continuous	1600	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
<hr/>				
SCH-NE-NYISO_LIMIT 700				FWD
Wed 01/29/2020	to	Sat 02/08/2020		(Import)
1301	Continuous	1600	SCH - NE - NY	900 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	500 MW
			TTC with All Lines In Service	1400 MW
<hr/>				
SCH-NYISO-NE_LIMIT 500				REV
Wed 01/29/2020	to	Sat 02/08/2020		(Export)
1301	Continuous	1600	SCH - NE - NY	700 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	1000 MW
			TTC with All Lines In Service	1700 MW
<hr/>				
RAMAPO __- BUCHAN_N 345_Y94				FWD
Mon 02/03/2020	to	Tue 02/04/2020		(Import)
0001	Continuous	0230	UPNY CONED	4800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	900 MW
			TTC with All Lines In Service	5700 MW

NYISO TRANSFER LIMITATIONS

Sunday ,January 26, 2020 to Tuesday ,July 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RNS4

FWD

Mon 02/03/2020 to Tue 02/04/2020
0001 Continuous 2200

(Import)

Work scheduled by: ConEd

UPNY CONED **3800 MW**
Impacts Total Transfer Capability 1900 MW
TTC with All Lines In Service 5700 MW

BECK__-NIAGARA_230_PA27

Mon 02/03/2020 to Thu 02/13/2020
0500 Continuous 1700

Work scheduled by: IESO

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

MOSES__-ADIRNDCK_230_MA1

FWD

Mon 02/03/2020 to Fri 02/07/2020
0700 Continuous 1530

(Import)

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

EFISHKIL-WOOD_ST_345_F39

FWD

Mon 02/10/2020 to Mon 02/10/2020
0001 Continuous 0030

(Import)

Work scheduled by: ConEd

UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1700 MW
TTC with All Lines In Service 5700 MW

WOOD_ST_-PLSNTVLE_345_Y87

FWD

Mon 02/10/2020 to Wed 02/12/2020
0001 Continuous 0030

(Import)

Work scheduled by: ConEd

UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1700 MW
TTC with All Lines In Service 5700 MW

MOSES__-ADIRNDCK_230_MA1

FWD

Mon 02/10/2020 to Fri 02/14/2020
0700 Continuous 1530

(Import)

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

HURLYAVE-ROSETON_345_303

FWD

Tue 02/11/2020 to Thu 02/13/2020
0700 Continuous 1600

(Import)

Work scheduled by: CHGE

UPNY CONED **4100 MW**
Impacts Total Transfer Capability 1600 MW
TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Sunday ,January 26, 2020 to Tuesday ,July 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EFISHKIL-WOOD_ST__345_F39					FWD
Wed 02/12/2020	to	Wed 02/12/2020			(Import)
0001	Continuous	0030		UPNY CONED	4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1700 MW
					TTC with All Lines In Service 5700 MW
EFISHKIL-WOOD_ST__345_F38					FWD
Fri 02/14/2020	to	Sat 02/15/2020	UPDATED	by CONED 01/15/2020	(Import)
0001	Continuous	0030		UPNY CONED	4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1700 MW
					TTC with All Lines In Service 5700 MW
WOOD_ST_-PLSNTVLE_345_Y86					FWD
Fri 02/14/2020	to	Sat 02/15/2020	UPDATED	by CONED 01/15/2020	(Import)
0001	Continuous	0030		UPNY CONED	4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1700 MW
					TTC with All Lines In Service 5700 MW
SPRNBRK_-TREMONT__345_X28					FWD
Mon 02/17/2020	to	Mon 02/17/2020	CANCELLED	by ConEd 01/24/2020	(Import)
0001	Continuous	1800		SPR/DUN-SOUTH	4200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 400 MW
					TTC with All Lines In Service 4600 MW
WATRCURE-OAKDALE__345_31					FWD
Mon 02/17/2020	to	Mon 02/17/2020	UPDATED	by NYSEG 12/20/2019	(Import)
1500	Continuous	1530		SCH - PJ - NY	2750 MW
Work scheduled by: NYSEG					Impacts Total Transfer Capability 150 MW
					TTC with All Lines In Service 2900 MW
MOSES__-ADIRNDCK_230_MA1					FWD
Tue 02/18/2020	to	Fri 02/21/2020			(Import)
0700	Continuous	1530		MOSES SOUTH	2300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 850 MW
					TTC with All Lines In Service 3150 MW
SPRNBRK__345KV_RNS5					FWD
Mon 02/24/2020	to	Mon 02/24/2020	CANCELLED	by ConEd 01/24/2020	(Import)
0001	Continuous	0030		SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,January 26, 2020 to Tuesday ,July 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					FWD	
SPRNBRK_-W49TH_ST_345_M51					(Import)	
Mon 02/24/2020	to	Sun 03/01/2020	<u>CANCELLED</u>	<u>by ConEd</u>	<u>01/24/2020</u>	
0001	Continuous	0200				SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
<hr/>					FWD	
SPRNBRK__345KV_RNS5					(Import)	
Wed 02/26/2020	to	Wed 02/26/2020	<u>CANCELLED</u>	<u>by ConEd</u>	<u>01/24/2020</u>	
2130	Continuous	2200				SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
<hr/>					FWD	
SPRNBRK__345KV_RNS5					(Import)	
Thu 02/27/2020	to	Sun 03/01/2020	<u>CANCELLED</u>	<u>by ConEd</u>	<u>01/24/2020</u>	
2301	Continuous	0200				SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
<hr/>					FWD	
NIAGARA_-PACKARD__230_62					(Import)	REV
Fri 02/28/2020	to	Fri 02/28/2020				(Import) (Export)
0500	Continuous	1530				SCH - OH - NY 900 MW 1850 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1150 MW 50 MW
					TTC with All Lines In Service	2050 MW 1900 MW
<hr/>					FWD	
DUNWODIE_345KV_4					(Import)	
Sun 03/01/2020	to	Sun 03/08/2020				SPR/DUN-SOUTH 3800 MW
0001	Continuous	2200				Impacts Total Transfer Capability 800 MW
Work scheduled by: ConEd					TTC with All Lines In Service	4600 MW
<hr/>					FWD	
CHATGUAY-MASSENA__765_7040					(Import)	
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	
0500	Continuous	1730				MOSES SOUTH 1550 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	3150 MW
<hr/>					FWD	
CHATGUAY-MASSENA__765_7040					(Import)	REV
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import) (Export)
0500	Continuous	1730				SCH - HQ - NY 0 MW 0 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1500 MW 1000 MW
					TTC with All Lines In Service	1500 MW 1000 MW

NYISO TRANSFER LIMITATIONS

Sunday ,January 26, 2020 to Tuesday ,July 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT1						FWD
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)
0500	Continuous	1730				MOSES SOUTH 1750 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 1400 MW
						TTC with All Lines In Service 3150 MW
MARCY___765_345_AT2						FWD
Mon 03/02/2020	to	Fri 03/06/2020				(Import)
0500	Continuous	1730				MOSES SOUTH 1700 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 1450 MW
						TTC with All Lines In Service 3150 MW
MASSENA_-MARCY___765_MSU1						FWD
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)
0500	Continuous	1730				CENTRAL EAST - VC 2265 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 710 MW
						TTC with All Lines In Service 2975 MW
MASSENA_-MARCY___765_MSU1						FWD
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)
0500	Continuous	1730				MOSES SOUTH 500 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 2650 MW
						TTC with All Lines In Service 3150 MW
MASSENA_-MARCY___765_MSU1						FWD
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import) (Export)
0500	Continuous	1730				SCH - HQ - NY 475 MW 1000 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 1025 MW 0 MW
						TTC with All Lines In Service 1500 MW 1000 MW
MASSENA_-MARCY___765_MSU1						FWD
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)
0500	Continuous	1730				SCH - HQ_CEDARS 90 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 109 MW
						TTC with All Lines In Service 199 MW
MASSENA_-MARCY___765_MSU1 & CHATGUAY-MASSENA_765_7040						FWD
Mon 03/02/2020	to	Fri 03/06/2020				(Import)
0500		1730				MOSES SOUTH 500 MW
Work scheduled by:						Impacts Total Transfer Capability 2650 MW
						TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,January 26, 2020 to Tuesday ,July 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2	FWD	REV
	(Import)	(Export)
Mon 03/02/2020 to Fri 03/06/2020 0500 1730	SCH - HQ - NY 850 MW	0 MW
Work scheduled by:	Impacts Total Transfer Capability	1000 MW
	TTC with All Lines In Service	1500 MW
<hr/>		
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2	FWD	
	(Import)	
Mon 03/02/2020 to Fri 03/06/2020 0500 1730	SCH - HQ_CEDARS 90 MW	
Work scheduled by:	Impacts Total Transfer Capability	109 MW
	TTC with All Lines In Service	199 MW
<hr/>		
STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1	FWD	
	(Import)	
Mon 03/02/2020 to Fri 03/06/2020 0500 1730	SCH - HQ_CEDARS 90 MW	
Work scheduled by:	Impacts Total Transfer Capability	109 MW
	TTC with All Lines In Service	199 MW
<hr/>		
STLAWRNC-MOSES 230_L33P & MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2	FWD	
	(Import)	
Mon 03/02/2020 to Fri 03/06/2020 0500 1730	SCH - HQ_CEDARS 90 MW	
Work scheduled by:	Impacts Total Transfer Capability	109 MW
	TTC with All Lines In Service	199 MW
<hr/>		
SHOR_NPX-SHOREHAM_138_CSC	FWD	REV
	(Import)	(Export)
Mon 03/02/2020 to Tue 03/03/2020 0600 Continuous 1300	SCH - NPX_CSC 0 MW	0 MW
Work scheduled by: LI	Impacts Total Transfer Capability	330 MW
	TTC with All Lines In Service	330 MW
<hr/>		
ROSETON -EFISHKIL_345_RFK305	FWD	
	(Import)	
Mon 03/02/2020 to Fri 03/20/2020 0700 Continuous 1730	UPNY CONED 4800 MW	
Work scheduled by: NYPA	Impacts Total Transfer Capability	900 MW
	TTC with All Lines In Service	5700 MW
<hr/>		
EASTVIEW-SPRNBRK_345_W78	FWD	
	(Import)	
Fri 03/06/2020 to Sat 03/07/2020 0001 Continuous 0200	UPNY CONED 4350 MW	
Work scheduled by: ConEd	Impacts Total Transfer Capability	1350 MW
	TTC with All Lines In Service	5700 MW

NYISO TRANSFER LIMITATIONS

Sunday ,January 26, 2020 to Tuesday ,July 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD-EASTVIEW_345_W85

Fri 03/06/2020 to Sat 03/07/2020
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

SPRNBRK_345KV_RNS3

Fri 03/06/2020 to Sat 03/07/2020
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

MOSES_-ADIRNDCK_230_MA1

Sat 03/07/2020 to Fri 05/29/2020
 0700 Continuous 1300
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

W49TH_ST_345KV_5

Mon 03/09/2020 to Mon 03/09/2020 **CANCELLED by ConEd 01/22/2020**
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **350 MW**
 Impacts Total Transfer Capability 310 MW
 TTC with All Lines In Service 660 MW

SPRNBRK_-W49TH_ST_345_M52

Mon 03/09/2020 to Wed 03/11/2020 **CANCELLED by ConEd 01/22/2020**
 0001 Continuous 2200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

SPRNBRK_345KV_RNS4

Mon 03/09/2020 to Wed 03/11/2020 **CANCELLED by ConEd 01/22/2020**
 0001 Continuous 2200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

VOLNEY_-MARCY_345_19

Tue 03/10/2020 to Tue 03/10/2020 **UPDATED by NYPA 09/24/2019**
 0700 Continuous 1530
 Work scheduled by: NYPA **ARR: 19**

FWD
 (Import)
 CENTRAL EAST - VC **2825 MW**
 Impacts Total Transfer Capability 150 MW
 TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Sunday ,January 26, 2020 to Tuesday ,July 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
VOLNEY -MARCY 345_19			FWD
Tue 03/10/2020	to	Tue 03/10/2020	(Import)
0700	Continuous	1530	
Work scheduled by: NYPA		UPDATED by NYPA 09/24/2019	
		ARR: 19	
		OSWEGO EXPORT	4900 MW
		Impacts Total Transfer Capability	350 MW
		TTC with All Lines In Service	5250 MW
<hr/>			
W49TH_ST_345KV_5			FWD
Wed 03/11/2020	to	Wed 03/11/2020	(Import)
2130	Continuous	2200	
Work scheduled by: ConEd		CANCELLED by ConEd 01/22/2020	
		SCH - PJM_HTP	350 MW
		Impacts Total Transfer Capability	310 MW
		TTC with All Lines In Service	660 MW
<hr/>			
ROCHESTR-PANNELL 345_RP2			FWD
Sat 03/14/2020	to	Mon 03/23/2020	(Import)
0500	Continuous	1700	
Work scheduled by: NYPA			
		DYSINGER EAST	2300 MW
		Impacts Total Transfer Capability	850 MW
		TTC with All Lines In Service	3150 MW
<hr/>			
BECK -NIAGARA 230_PA27			
Mon 03/16/2020	to	Fri 03/20/2020	
0400	Continuous	1700	
Work scheduled by: IESO			
		SCH - OH - NY	
		Impacts Total Transfer Capability	
		TTC with All Lines In Service	
<hr/>			
MARCY 345KV_CSC			FWD
Mon 03/16/2020	to	Fri 03/27/2020	(Import)
0500	Continuous	1730	
Work scheduled by: NYPA			
		CENTRAL EAST - VC	2925 MW
		Impacts Total Transfer Capability	50 MW
		TTC with All Lines In Service	2975 MW
<hr/>			
CHASLAKE-PORTER 230_11			FWD
Wed 03/18/2020	to	Wed 03/18/2020	(Import)
0630	Daily(No Weekends)	1330	
Work scheduled by: NGrid			
		MOSES SOUTH	2300 MW
		Impacts Total Transfer Capability	850 MW
		TTC with All Lines In Service	3150 MW
<hr/>			
SCH-NYISO-NE_LIMIT_900			REV
Wed 03/18/2020	to	Tue 03/31/2020	(Export)
0700	Continuous	2359	
Work scheduled by: ISONE			
		SCH - NE - NY	1100 MW
		Impacts Total Transfer Capability	600 MW
		TTC with All Lines In Service	1700 MW

NYISO TRANSFER LIMITATIONS

Sunday ,January 26, 2020 to Tuesday ,July 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BUCHAN_N-EASTVIEW_345_W93

Thu 03/19/2020 to Thu 03/19/2020
 0200 Continuous 0230
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

EASTVIEW-SPRNBK_345_W79

Thu 03/19/2020 to Fri 03/20/2020
 0200 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

BUCHAN_N-EASTVIEW_345_W93

Fri 03/20/2020 to Fri 03/20/2020
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

MILLWOOD-EASTVIEW_345_W85

Sun 03/22/2020 to Sun 03/22/2020 **UPDATED by CE 12/20/2019**
 0201 Continuous 0231
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

DUNWODIE-MOTTHAVN_345_72

Sun 03/22/2020 to Tue 03/24/2020 **UPDATED by CE 12/20/2019**
 0201 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_8

Sun 03/22/2020 to Tue 03/24/2020 **UPDATED by CE 12/20/2019**
 0201 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

EASTVIEW-SPRNBK_345_W78

Sun 03/22/2020 to Tue 03/24/2020 **UPDATED by CE 12/20/2019**
 0201 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Sunday ,January 26, 2020 to Tuesday ,July 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_5					FWD	
Sun 03/22/2020	to	Mon 05/11/2020	<u>UPDATED</u>	<u>by CE</u>	<u>12/20/2019</u>	(Import)
0201	Continuous	0300				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	3800 MW
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<hr/>						
DUNWODIE_345KV_7					FWD	
Sun 03/22/2020	to	Mon 05/11/2020	<u>UPDATED</u>	<u>by CE</u>	<u>12/20/2019</u>	(Import)
0201	Continuous	0300				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	3800 MW
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<hr/>						
SPRNBRK_-DUNWODIE_345_W75					FWD	
Sun 03/22/2020	to	Mon 05/11/2020	<u>UPDATED</u>	<u>by CE</u>	<u>12/20/2019</u>	(Import)
0201	Continuous	0300				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	3800 MW
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<hr/>						
SPRNBRK__345KV_RNS3					FWD	
Sun 03/22/2020	to	Mon 05/11/2020	<u>UPDATED</u>	<u>by CE</u>	<u>12/20/2019</u>	(Import)
0201	Continuous	0300				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	3800 MW
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<hr/>						
RAMAPO__-BUCHAN_N_345_Y94					FWD	
Tue 03/24/2020	to	Tue 03/24/2020				(Import)
0001	Continuous	0030				4800 MW
Work scheduled by: ConEd					UPNY CONED	4800 MW
					Impacts Total Transfer Capability	900 MW
					TTC with All Lines In Service	5700 MW
<hr/>						
MILLWOOD-EASTVIEW_345_W85					FWD	
Tue 03/24/2020	to	Tue 03/24/2020	<u>UPDATED</u>	<u>by CE</u>	<u>12/20/2019</u>	(Import)
0130	Continuous	0200				4350 MW
Work scheduled by: ConEd					UPNY CONED	4350 MW
					Impacts Total Transfer Capability	1350 MW
					TTC with All Lines In Service	5700 MW
<hr/>						
DUNWODIE-MOTTHAVN_345_71					FWD	
Tue 03/24/2020	to	Thu 03/26/2020	<u>UPDATED</u>	<u>by CE</u>	<u>12/20/2019</u>	(Import)
0201	Continuous	0200				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	3800 MW
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,January 26, 2020 to Tuesday ,July 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_3

Tue 03/24/2020 to Thu 03/26/2020
0201 Continuous 0200

Work scheduled by: ConEd

UPDATED by CE 12/20/2019

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD
(Import)

RAMAPO_-BUCHAN_N_345_Y94

Tue 03/24/2020 to Tue 03/24/2020
0630 Continuous 0700

Work scheduled by: ConEd

UPNY CONED **4800 MW**
Impacts Total Transfer Capability 900 MW
TTC with All Lines In Service 5700 MW

FWD
(Import)

SPRNBK_345KV_RS3 & SPRNBK_345KV_RS4

Thu 03/26/2020 to Sun 03/29/2020
0201 0200

Work scheduled by:

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD
(Import)

NIAGARA_-KINTIGH_345_NS1-38

Fri 03/27/2020 to Fri 03/27/2020
0600 Continuous 1530

Work scheduled by: NYPA

DYSINGER EAST **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

FWD
(Import)

BECK_-PACKARD_230_BP76

Fri 03/27/2020 to Fri 03/27/2020
0800 Daily(No Weekends) 1600

Work scheduled by: NGrid

SCH - OH - NY **1650 MW 1400 MW**
Impacts Total Transfer Capability 400 MW 500 MW
TTC with All Lines In Service 2050 MW 1900 MW

FWD REV
(Import) (Export)

BECK_-NIAGARA_230_PA27

Mon 03/30/2020 to Fri 05/29/2020
0400 Continuous 1700

Work scheduled by: IESO

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD

MARCY_-EDIC_345_UE1-7

Tue 03/31/2020 to Tue 03/31/2020
0700 Continuous 1530

Work scheduled by: NYPA

UPDATED by NYPA 09/24/2019

ARR: 19&16

OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

FWD
(Import)

NYISO TRANSFER LIMITATIONS

Sunday ,January 26, 2020 to Tuesday ,July 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

RAMAPO__-LADENTWN_345_W72

Wed 04/01/2020 to Thu 04/02/2020
 0001 Continuous 1830
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4400 MW**
 Impacts Total Transfer Capability 1300 MW
 TTC with All Lines In Service 5700 MW

SCH-NYISO-NE_LIMIT_700

Wed 04/01/2020 to Fri 04/03/2020
 0001 Continuous 1600
 Work scheduled by: ISONE

REV
 (Export)
 SCH - NE - NY **900 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 1700 MW

FRASANNX-COOPERS__345_UCC2-41

Wed 04/01/2020 to Thu 04/02/2020 **UPDATED by NYPA 11/12/2019**
 0700 Continuous 1530
 Work scheduled by: NYPA **ARR: 19**

FWD
 (Import)
 CENTRAL EAST - VC **2500 MW**
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

MARCY__-FRASANNX_345_UCC2-41

Wed 04/01/2020 to Thu 04/02/2020 **UPDATED by NYPA 11/12/2019**
 0700 Continuous 1530
 Work scheduled by: NYPA **ARR: 19**

FWD
 (Import)
 CENTRAL EAST - VC **2500 MW**
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

LINDN_CG-LNDVFT__345_V-3022

Sun 04/05/2020 to Sat 04/11/2020
 1400 Continuous 1400
 Work scheduled by: PJM

FWD REV
 (Import) (Export)
 SCH - PJM_VFT **0 MW 0 MW**
 Impacts Total Transfer Capability 315 MW 315 MW
 TTC with All Lines In Service 315 MW 315 MW

MARCY__-N.SCTLND_345_18

Tue 04/07/2020 to Wed 04/08/2020 **UPDATED by NYPA 09/24/2019**
 0700 Continuous 1530
 Work scheduled by: NYPA **ARR: 19**

FWD
 (Import)
 CENTRAL EAST - VC **2090 MW**
 Impacts Total Transfer Capability 885 MW
 TTC with All Lines In Service 2975 MW

PLSNTVLY-EFISHRIL_345_F36

Mon 04/13/2020 to Tue 04/14/2020
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 1700 MW
 TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Sunday ,January 26, 2020 to Tuesday ,July 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SAND_BAR-PLATSBRG_115_PV20

Mon 04/13/2020 to Tue 04/14/2020
 0600 Daily 1800
 Work scheduled by: ISONE

SCH - NE - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FRASER_-GILBOA_345_GF5-35

Mon 04/13/2020 to Wed 04/22/2020
 0700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2650 MW**
 Impacts Total Transfer Capability 325 MW
 TTC with All Lines In Service 2975 MW

NIAGARA_-ROCHESTR_345_NR2

Wed 04/15/2020 to Fri 05/01/2020
 0500 Continuous 1700
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

ROCHESTR-PANNELL_345_RP1

Mon 04/20/2020 to Fri 04/24/2020
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

DOLSONAV-ROCKTVRN_345_DART44

Mon 04/27/2020 to Sun 05/10/2020 **UPDATED by NYPA 03/21/2019**
 0700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2720 MW**
 Impacts Total Transfer Capability 255 MW
 TTC with All Lines In Service 2975 MW

HURLYAVE-ROSETON_345_303

Mon 04/27/2020 to Fri 05/29/2020 **UPDATED by CHGE 10/09/2019**
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4100 MW**
 Impacts Total Transfer Capability 1600 MW
 TTC with All Lines In Service 5700 MW

DUNWODIE-MOTTHAVN_345_72

Tue 04/28/2020 to Sat 05/02/2020
 0200 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,January 26, 2020 to Tuesday ,July 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD-EASTVIEW_345_W85

Wed 04/29/2020 to Wed 04/29/2020
 0201 Continuous 0230
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

EASTVIEW-SPRNBK_345_W78

Wed 04/29/2020 to Sun 05/03/2020
 0201 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

SCH-IMO-NYISO_LIMIT_1600

Fri 05/01/2020 to Sat 10/31/2020 **UPDATED by IESO 05/03/2019**
 0001 Continuous 2359
 Work scheduled by: IESO

FWD
 (Import)
 SCH - OH - NY **1900 MW**
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 1900 MW

DUNWODIE-MOTTHAVN_345_71

Sat 05/02/2020 to Wed 05/06/2020
 0201 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_3

Sat 05/02/2020 to Wed 05/06/2020
 0201 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

MILLWOOD-EASTVIEW_345_W85

Sun 05/03/2020 to Sun 05/03/2020
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

PANNELL_-CLAY_345_2

Mon 05/04/2020 to Fri 05/08/2020
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 WEST CENTRAL **1300 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

NYISO TRANSFER LIMITATIONS

Sunday ,January 26, 2020 to Tuesday ,July 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Mon 05/04/2020 to Mon 05/18/2020
 0800 Continuous 1700
 Work scheduled by: PJM

FWD
 (Import)
 SCH - PJM_NEPTUNE **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE-DUFFYAVE_345_501

Mon 05/04/2020 to Mon 05/18/2020
 0800 Continuous 1700
 Work scheduled by: PJM

FWD
 (Import)
 SCH - PJM_NEPTUNE **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_1

Mon 05/04/2020 to Mon 05/18/2020
 0800 Continuous 1700
 Work scheduled by: PJM

FWD
 (Import)
 SCH - PJM_NEPTUNE **375 MW**
 Impacts Total Transfer Capability 285 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_2

Mon 05/04/2020 to Mon 05/18/2020
 0800 Continuous 1700
 Work scheduled by: PJM

FWD
 (Import)
 SCH - PJM_NEPTUNE **375 MW**
 Impacts Total Transfer Capability 285 MW
 TTC with All Lines In Service 660 MW

SPRNBK__345KV_RS3 & SPRNBK__345KV_RS4

Wed 05/06/2020 to Mon 05/11/2020
 0201 0200
 Work scheduled by:

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

PANNELL_-CLAY_____345_1

Mon 05/11/2020 to Fri 05/15/2020
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 WEST CENTRAL **1300 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

COOPERS_-DOLSONAV_345_CCDA42

Mon 05/11/2020 to Fri 05/29/2020 **UPDATED by NYPA 03/21/2019**
 0700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2720 MW**
 Impacts Total Transfer Capability 255 MW
 TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Sunday ,January 26, 2020 to Tuesday ,July 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

KINTIGH_-ROCHESTR_345_SR1-39			FWD	
Mon 05/18/2020	to	Fri 05/22/2020	(Import)	
0500	Continuous	1530	DYSINGER EAST	1400 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1750 MW
			TTC with All Lines In Service	3150 MW
SCH-NE-NYISO_LIMIT_700			FWD	
Mon 05/18/2020	to	Mon 05/18/2020	(Import)	
0700	Continuous	1059	SCH - NE - NY	900 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	500 MW
			TTC with All Lines In Service	1400 MW
SCH-NYISO-NE_LIMIT_500			REV	
Mon 05/18/2020	to	Mon 05/18/2020	(Export)	
0700	Continuous	1059	SCH - NE - NY	700 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	900 MW
			TTC with All Lines In Service	1600 MW
BERKSHIR-ALPS_____345_393 & BERKSHIR-NORTHFLD_345_312			FWD	REV
Mon 05/18/2020	to	Mon 05/18/2020	(Import)	(Export)
0700		1100	SCH - NE - NY	950 MW 1300 MW
Work scheduled by: ARR: 78			Impacts Total Transfer Capability	450 MW 300 MW
			TTC with All Lines In Service	1400 MW 1600 MW
BERKSHIR-NORTHFLD_345_312			FWD	REV
Mon 05/18/2020	to	Mon 05/18/2020	(Import)	(Export)
0700	Continuous	1100	SCH - NE - NY	900 MW 1500 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	500 MW 100 MW
			TTC with All Lines In Service	1400 MW 1600 MW
BERKSHIR-NORTHFLD_345_312			FWD	REV
Mon 05/18/2020	to	Mon 05/18/2020	(Import)	(Export)
0700	Continuous	1100	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
BERKSHIR-ALPS_____345_393			FWD	REV
Mon 05/18/2020	to	Sat 05/30/2020	(Import)	(Export)
0700	Continuous	1700	SCH - NE - NY	950 MW 1300 MW
Work scheduled by: ISONE ARR: 78			Impacts Total Transfer Capability	450 MW 300 MW
			TTC with All Lines In Service	1400 MW 1600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,January 26, 2020 to Tuesday ,July 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-ALPS _____ 345_393		FWD	REV
		(Import)	(Export)
Mon 05/18/2020	to Sat 05/30/2020		
0700	Continuous 1700	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: ISONE		Impacts Total Transfer Capability	100 MW 100 MW
ARR: 78		TTC with All Lines In Service	200 MW 200 MW
SCH-NE-NYISO_LIMIT_600		FWD	
		(Import)	
Mon 05/18/2020	to Tue 05/26/2020		
1100	Continuous 0559	SCH - NE - NY	800 MW
Work scheduled by: ISONE		Impacts Total Transfer Capability	600 MW
		TTC with All Lines In Service	1400 MW
SCH-NYISO-NE_LIMIT_600			REV
			(Export)
Mon 05/18/2020	to Sat 05/30/2020		
1100	Continuous 1459	SCH - NE - NY	800 MW
Work scheduled by: ISONE		Impacts Total Transfer Capability	800 MW
		TTC with All Lines In Service	1600 MW
SCH-NE-NYISO_LIMIT_500		FWD	
		(Import)	
Tue 05/26/2020	to Sat 05/30/2020		
0600	Continuous 1700	SCH - NE - NY	700 MW
Work scheduled by: ISONE		Impacts Total Transfer Capability	700 MW
		TTC with All Lines In Service	1400 MW
BERKSHIR-ALPS _____ 345_393 & BERKSHIR-NORTHFLD_345_312		FWD	REV
		(Import)	(Export)
Sat 05/30/2020	to Sat 05/30/2020		
1500	1700	SCH - NE - NY	950 MW 1300 MW
Work scheduled by:		Impacts Total Transfer Capability	450 MW 300 MW
ARR: 78		TTC with All Lines In Service	1400 MW 1600 MW
BERKSHIR-NORTHFLD_345_312		FWD	REV
		(Import)	(Export)
Sat 05/30/2020	to Sat 05/30/2020		
1500	Continuous 1700	SCH - NE - NY	900 MW 1500 MW
Work scheduled by: ISONE		Impacts Total Transfer Capability	500 MW 100 MW
		TTC with All Lines In Service	1400 MW 1600 MW
BERKSHIR-NORTHFLD_345_312		FWD	REV
		(Import)	(Export)
Sat 05/30/2020	to Sat 05/30/2020		
1500	Continuous 1700	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: ISONE		Impacts Total Transfer Capability	100 MW 100 MW
		TTC with All Lines In Service	200 MW 200 MW

NYISO TRANSFER LIMITATIONS

Sunday ,January 26, 2020 to Tuesday ,July 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
SCH-NYISO-NE_LIMIT_500					
Sat 05/30/2020	to	Sat 05/30/2020			
1500	Continuous	1700			
Work scheduled by: ISONE				SCH - NE - NY	700 MW
				Impacts Total Transfer Capability	900 MW
				TTC with All Lines In Service	1600 MW
SHOR_NPX-SHOREHAM_138_CSC					
Mon 06/01/2020	to	Tue 06/02/2020			
0501	Continuous	1600			
Work scheduled by: LI				SCH - NPX_CSC	0 MW
				Impacts Total Transfer Capability	330 MW
				TTC with All Lines In Service	330 MW
MOSES__-ADIRNDCK_230_MA2					
Mon 06/01/2020	to	Fri 07/31/2020			
0700	Continuous	1730			
Work scheduled by: NYPA				MOSES SOUTH	2100 MW
				Impacts Total Transfer Capability	1050 MW
				TTC with All Lines In Service	3150 MW
NIAGARA__345_230_AT4					
Mon 06/29/2020	to	Tue 06/30/2020			
0500	Continuous	1530			
Work scheduled by: NYPA				SCH - OH - NY	1400 MW
				Impacts Total Transfer Capability	300 MW
				TTC with All Lines In Service	1700 MW
SCH-IMO-NYISO_NIAG_CB_3008_W/BB					
Mon 07/27/2020	to	Fri 08/07/2020			
0500	Continuous	1530			
Work scheduled by: NYPA				SCH - OH - NY	1900 MW
				Impacts Total Transfer Capability	0 MW
				TTC with All Lines In Service	1900 MW
CHATGUAY-MASSENA__765_7040					
Sat 08/01/2020	to	Sun 08/02/2020	UPDATED	by NYPA	08/08/2019
0500	Continuous	1730			
Work scheduled by: NYPA				MOSES SOUTH	1550 MW
				Impacts Total Transfer Capability	1600 MW
				TTC with All Lines In Service	3150 MW
CHATGUAY-MASSENA__765_7040					
Sat 08/01/2020	to	Sun 08/02/2020	UPDATED	by NYPA	08/08/2019
0500	Continuous	1730			
Work scheduled by: NYPA				SCH - HQ - NY	0 MW
				Impacts Total Transfer Capability	1500 MW
				TTC with All Lines In Service	1500 MW

NYISO TRANSFER LIMITATIONS

Sunday ,January 26, 2020 to Tuesday ,July 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						FWD
MARCY___765_345_AT1						(Import)
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	MOSES SOUTH 1750 MW
0500	Continuous	1730				Impacts Total Transfer Capability 1400 MW
Work scheduled by: NYPA				ARR: 19		TTC with All Lines In Service 3150 MW
<hr/>						FWD
MASSENA_-MARCY___765_MSU1						(Import)
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	CENTRAL EAST - VC 2265 MW
0500	Continuous	1730				Impacts Total Transfer Capability 710 MW
Work scheduled by: NYPA						TTC with All Lines In Service 2975 MW
<hr/>						FWD
MASSENA_-MARCY___765_MSU1						(Import)
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	MOSES SOUTH 500 MW
0500	Continuous	1730				Impacts Total Transfer Capability 2650 MW
Work scheduled by: NYPA						TTC with All Lines In Service 3150 MW
<hr/>						FWD
MASSENA_-MARCY___765_MSU1						(Import) (Export)
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	SCH - HQ - NY 475 MW 1000 MW
0500	Continuous	1730				Impacts Total Transfer Capability 1025 MW 0 MW
Work scheduled by: NYPA						TTC with All Lines In Service 1500 MW 1000 MW
<hr/>						FWD
MASSENA_-MARCY___765_MSU1						(Import)
Sat 08/01/2020	to	Sun 08/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	SCH - HQ_CEDARS 90 MW
0500	Continuous	1730				Impacts Total Transfer Capability 100 MW
Work scheduled by: NYPA						TTC with All Lines In Service 190 MW
<hr/>						FWD
MASSENA_-MARCY___765_MSU1 & CHATGUAY-MASSENA_765_7040						(Import)
Sat 08/01/2020	to	Sun 08/02/2020				MOSES SOUTH 500 MW
0500		1730				Impacts Total Transfer Capability 2650 MW
Work scheduled by:						TTC with All Lines In Service 3150 MW
<hr/>						FWD
MOSES___-MASSENA_230_MMS1 & MOSES___-MASSENA_230_MMS2						(Import) (Export)
Sat 08/01/2020	to	Sun 08/02/2020				SCH - HQ - NY 850 MW 0 MW
0500		1730				Impacts Total Transfer Capability 650 MW 1000 MW
Work scheduled by:						TTC with All Lines In Service 1500 MW 1000 MW

NYISO TRANSFER LIMITATIONS

Sunday ,January 26, 2020 to Tuesday ,July 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2	FWD
Sat 08/01/2020 to Sun 08/02/2020	(Import)
0500 1730	SCH - HQ_CEDARS 90 MW
Work scheduled by:	Impacts Total Transfer Capability 100 MW
	TTC with All Lines In Service 190 MW
<hr/>	
STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1	FWD
Sat 08/01/2020 to Sun 08/02/2020	(Import)
0500 1730	SCH - HQ_CEDARS 90 MW
Work scheduled by:	Impacts Total Transfer Capability 100 MW
	TTC with All Lines In Service 190 MW
<hr/>	
STLAWRNC-MOSES 230_L33P & MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2	FWD
Sat 08/01/2020 to Sun 08/02/2020	(Import)
0500 1730	SCH - HQ_CEDARS 90 MW
Work scheduled by:	Impacts Total Transfer Capability 100 MW
	TTC with All Lines In Service 190 MW
<hr/>	
MOSES -ADIRNDCK 230_MA2	FWD
Mon 08/03/2020 to Sun 09/13/2020	(Import)
0700 Continuous 1730	MOSES SOUTH 2100 MW
Work scheduled by: NYPA	Impacts Total Transfer Capability 1050 MW
	TTC with All Lines In Service 3150 MW
<hr/>	
FRASANNX-COOPERS 345_UCC2-41	FWD
Mon 09/07/2020 to Fri 10/23/2020	(Import)
0700 Continuous 1730	CENTRAL EAST - VC 2500 MW
Work scheduled by: NYPA	Impacts Total Transfer Capability 475 MW
	TTC with All Lines In Service 2975 MW
<hr/>	
MARCY -FRASANNX 345_UCC2-41	FWD
Mon 09/07/2020 to Fri 10/23/2020	(Import)
0700 Continuous 1730	CENTRAL EAST - VC 2500 MW
Work scheduled by: NYPA	Impacts Total Transfer Capability 475 MW
	TTC with All Lines In Service 2975 MW
<hr/>	
MARCY 765_345_AT1	FWD
Mon 09/14/2020 to Mon 09/14/2020	(Import)
0500 Continuous 1730	MOSES SOUTH 1750 MW
Work scheduled by: NYPA	Impacts Total Transfer Capability 1400 MW
	TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,January 26, 2020 to Tuesday ,July 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-KINTIGH__345_NS1-38

Mon 09/14/2020 to Thu 09/17/2020
 0500 Continuous 1530

Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **1400 MW**
 Impacts Total Transfer Capability 1750 MW
 TTC with All Lines In Service 3150 MW

MOSES_-ADIRNDCK_230_MA2

Tue 09/15/2020 to Sat 11/14/2020
 0700 Continuous 1530

Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2100 MW**
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW

NIAGARA_-ROCHESTR_345_NR2

Fri 09/18/2020 to Sat 11/14/2020
 0500 Continuous 2330

Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **1400 MW**
 Impacts Total Transfer Capability 1750 MW
 TTC with All Lines In Service 3150 MW

CLAY_-EDIC__345_1-16

Mon 09/21/2020 to Fri 09/25/2020
 0700 Continuous 1530

Work scheduled by: NYPA

FWD
 (Import)
 OSWEGO EXPORT **4850 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 5250 MW

ROSETON_-ROCKTVRN_345_311

Mon 09/21/2020 to Fri 10/23/2020 **UPDATED by CHGE 10/09/2019**
 0800 Continuous 1600

Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4400 MW**
 Impacts Total Transfer Capability 1300 MW
 TTC with All Lines In Service 5700 MW

DUNWODIE_345KV_3

Fri 09/25/2020 to Fri 09/25/2020 **CANCELLED by ConEd 01/21/2020**
 0001 Continuous 0030

Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_5

Fri 09/25/2020 to Fri 09/25/2020 **CANCELLED by ConEd 01/21/2020**
 0001 Continuous 0030

Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,January 26, 2020 to Tuesday ,July 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE-MOTTHAVN_345_71

Fri 09/25/2020 to Fri 10/30/2020
0001 Continuous 0300

Work scheduled by: ConEd

CANCELLED by ConEd 01/21/2020

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD
(Import)

DUNWODIE_345KV_3

Mon 09/28/2020 to Sat 10/31/2020
0001 Continuous 0100

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD
(Import)

DUNWODIE_345KV_4

Mon 09/28/2020 to Sat 10/31/2020
0001 Continuous 0100

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD
(Import)

PLSNTVLE-DUNWODIE_345_W89

Mon 09/28/2020 to Sat 10/31/2020
0001 Continuous 0100

Work scheduled by: ConEd

UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1700 MW
TTC with All Lines In Service 5700 MW

FWD
(Import)

CLAY -EDIC 345_2-15

Mon 09/28/2020 to Fri 10/02/2020
0700 Continuous 1530

Work scheduled by: NYPA

OSWEGO EXPORT **4850 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 5250 MW

FWD
(Import)

MOTTHAVN-RAINEY 345_Q11

Thu 10/01/2020 to Thu 11/05/2020
0001 Continuous 0200

Work scheduled by: ConEd

UPDATED by CONED 12/17/2019

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD
(Import)

SAND_BAR-PLATSBRG_115_PV20

Sat 10/17/2020 to Sat 11/14/2020
0600 Continuous 1800

Work scheduled by: ISONE

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Sunday ,January 26, 2020 to Tuesday ,July 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LEEDS___-HURLYAVE_345_301				FWD
Mon 10/26/2020	to	Fri 12/04/2020		(Import)
0800	Continuous	1600	UPNY CONED	4100 MW
Work scheduled by: CHGE				Impacts Total Transfer Capability 1600 MW
				TTC with All Lines In Service 5700 MW
DUNWODIE_345KV_3				FWD
Fri 10/30/2020	to	Fri 10/30/2020	CANCELLED by ConEd 01/21/2020	(Import)
0230	Continuous	0300	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_5				FWD
Fri 10/30/2020	to	Fri 10/30/2020	CANCELLED by ConEd 01/21/2020	(Import)
0230	Continuous	0300	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
SCH-IMO-NYISO_LIMIT_1750				FWD
Sun 11/01/2020	to	Fri 04/30/2021	UPDATED by IESO 05/03/2019	(Import)
0001	Continuous	2359	SCH - OH - NY	2050 MW
Work scheduled by: IESO				Impacts Total Transfer Capability 0 MW
				TTC with All Lines In Service 2050 MW
SCH-NYISO-IMO_LIMIT_1600				REV
Sun 11/01/2020	to	Fri 04/30/2021	UPDATED by IESO 05/03/2019	(Export)
0001	Continuous	2359	SCH - OH - NY	1900 MW
Work scheduled by: IESO				Impacts Total Transfer Capability 0 MW
				TTC with All Lines In Service 1900 MW
CHATGUAY-MASSENA_765_7040				FWD
Sun 11/15/2020	to	Mon 11/30/2020		(Import)
0100	Continuous	1900	MOSES SOUTH	1550 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 1600 MW
				TTC with All Lines In Service 3150 MW
CHATGUAY-MASSENA_765_7040				FWD REV
Sun 11/15/2020	to	Mon 11/30/2020		(Import) (Export)
0100	Continuous	1900	SCH - HQ - NY	0 MW 0 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 1500 MW 1000 MW
				TTC with All Lines In Service 1500 MW 1000 MW

NYISO TRANSFER LIMITATIONS

Sunday ,January 26, 2020 to Tuesday ,July 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT1			FWD
Sun 11/15/2020	to	Mon 11/30/2020	(Import)
0100	Continuous	1900	MOSES SOUTH 1750 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 1400 MW
			TTC with All Lines In Service 3150 MW
MARCY___765_345_AT2			FWD
Sun 11/15/2020	to	Mon 11/30/2020	(Import)
0100	Continuous	1900	MOSES SOUTH 1700 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 1450 MW
			TTC with All Lines In Service 3150 MW
MASSENA_-MARCY___765_MSU1			FWD
Sun 11/15/2020	to	Mon 11/30/2020	(Import)
0100	Continuous	1900	CENTRAL EAST - VC 2265 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 710 MW
			TTC with All Lines In Service 2975 MW
MASSENA_-MARCY___765_MSU1			FWD
Sun 11/15/2020	to	Mon 11/30/2020	(Import)
0100	Continuous	1900	MOSES SOUTH 500 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 2650 MW
			TTC with All Lines In Service 3150 MW
MASSENA_-MARCY___765_MSU1			FWD
Sun 11/15/2020	to	Mon 11/30/2020	(Import) (Export)
0100	Continuous	1900	SCH - HQ - NY 475 MW 1000 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 1025 MW 0 MW
			TTC with All Lines In Service 1500 MW 1000 MW
MASSENA_-MARCY___765_MSU1			FWD
Sun 11/15/2020	to	Mon 11/30/2020	(Import)
0100	Continuous	1900	SCH - HQ_CEDARS 90 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 109 MW
			TTC with All Lines In Service 199 MW
MASSENA_-MARCY___765_MSU1 & CHATGUAY-MASSENA_765_7040			FWD
Sun 11/15/2020	to	Mon 11/30/2020	(Import)
0100		1900	MOSES SOUTH 500 MW
Work scheduled by:			Impacts Total Transfer Capability 2650 MW
			TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,January 26, 2020 to Tuesday ,July 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2

Sun 11/15/2020 to Mon 11/30/2020
 0100 1900

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	850 MW	0 MW
Impacts Total Transfer Capability	650 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2

Sun 11/15/2020 to Mon 11/30/2020
 0100 1900

Work scheduled by:

	FWD	
	(Import)	
SCH - HQ_CEDARS	90 MW	
Impacts Total Transfer Capability	109 MW	
TTC with All Lines In Service	199 MW	

STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1

Sun 11/15/2020 to Mon 11/30/2020
 0100 1900

Work scheduled by:

	FWD	
	(Import)	
SCH - HQ_CEDARS	90 MW	
Impacts Total Transfer Capability	109 MW	
TTC with All Lines In Service	199 MW	

STLAWRNC-MOSES 230_L33P & MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2

Sun 11/15/2020 to Mon 11/30/2020
 0100 1900

Work scheduled by:

	FWD	
	(Import)	
SCH - HQ_CEDARS	90 MW	
Impacts Total Transfer Capability	109 MW	
TTC with All Lines In Service	199 MW	

PLSNTVLE-DUNWODIE_345_W89

Mon 11/16/2020 to Mon 11/16/2020
 0001 Continuous 0030

Work scheduled by: ConEd

	FWD	
	(Import)	
UPNY CONED	4000 MW	
Impacts Total Transfer Capability	1700 MW	
TTC with All Lines In Service	5700 MW	

PLSNTVLE-DUNWODIE_345_W89

Thu 11/26/2020 to Thu 11/26/2020
 0230 Continuous 0300

Work scheduled by: ConEd

	FWD	
	(Import)	
UPNY CONED	4000 MW	
Impacts Total Transfer Capability	1700 MW	
TTC with All Lines In Service	5700 MW	

MOSES -ADIRNDCK 230_MA1

Tue 12/01/2020 to Mon 05/31/2021
 0700 Continuous 1300

Work scheduled by: NYPA

	FWD	
	(Import)	
MOSES SOUTH	2300 MW	
Impacts Total Transfer Capability	850 MW	
TTC with All Lines In Service	3150 MW	

NYISO TRANSFER LIMITATIONS

Sunday ,January 26, 2020 to Tuesday ,July 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SAND_BAR-PLATSBURG_115_PV20

Mon 12/07/2020 to Fri 12/11/2020
 0700 Continuous 1530
 Work scheduled by: NYPA

SCH - NE - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

SAND_BAR-PLATSBURG_115_PV20

Mon 12/14/2020 to Fri 12/18/2020
 0700 Continuous 1530
 Work scheduled by: NYPA

SCH - NE - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

HOPATCON-RAMAPO__500_5018

Mon 02/01/2021 to Wed 02/03/2021
 0001 Continuous 2200
 Work scheduled by: ConEd

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	1250 MW	1200 MW
Impacts Total Transfer Capability	1650 MW	650 MW
TTC with All Lines In Service	2900 MW	1850 MW

HOPATCON-RAMAPO__500_5018

Mon 02/01/2021 to Wed 02/03/2021
 0001 Continuous 2200
 Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	5000 MW
Impacts Total Transfer Capability	700 MW
TTC with All Lines In Service	5700 MW

RAMAPO__345_345_PAR3500

Mon 02/01/2021 to Wed 02/03/2021
 0001 Continuous 2200
 Work scheduled by: ConEd

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2150 MW	1250 MW
Impacts Total Transfer Capability	750 MW	600 MW
TTC with All Lines In Service	2900 MW	1850 MW

RAMAPO__345_345_PAR4500

Mon 02/01/2021 to Wed 02/03/2021
 0001 Continuous 2200
 Work scheduled by: ConEd

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2150 MW	1250 MW
Impacts Total Transfer Capability	750 MW	600 MW
TTC with All Lines In Service	2900 MW	1850 MW

RAMAPO__500_345_BK 1500

Mon 02/01/2021 to Wed 02/03/2021
 0001 Continuous 2200
 Work scheduled by: ConEd

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	1250 MW	1200 MW
Impacts Total Transfer Capability	1650 MW	650 MW
TTC with All Lines In Service	2900 MW	1850 MW

NYISO TRANSFER LIMITATIONS

Sunday ,January 26, 2020 to Tuesday ,July 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

RAMAPO__500_345_BK 1500

Mon 02/01/2021 to Wed 02/03/2021
 0001 Continuous 2200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **5000 MW**
 Impacts Total Transfer Capability 700 MW
 TTC with All Lines In Service 5700 MW

DUNWODIE_345KV_3

Mon 03/01/2021 to Mon 03/01/2021
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_5

Mon 03/01/2021 to Mon 03/01/2021
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

EASTVIEW-SPRNBK__345_W64

Mon 03/01/2021 to Mon 03/01/2021 **UPDATED by CONED 01/23/2020**
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

SPRNBK__345KV_RNS5

Mon 03/01/2021 to Mon 03/01/2021 **UPDATED by CONED 01/23/2020**
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

MILLWOOD-EASTVIEW_345_W99

Mon 03/01/2021 to Mon 03/22/2021 **UPDATED by CONED 01/23/2020**
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

DUNWODIE-MOTTHAVN_345_71

Mon 03/01/2021 to Mon 04/05/2021
 0001 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,January 26, 2020 to Tuesday ,July 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOTTHAVN-RAINEY___345_Q11

Mon 03/01/2021 to Tue 04/06/2021
 0001 Continuous 0700
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

EASTVIEW-SPRNBK___345_W64

Mon 03/22/2021 to Mon 03/22/2021 **UPDATED by CONED 01/23/2020**
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

SPRNBK___345KV_RNS5

Mon 03/22/2021 to Mon 03/22/2021 **UPDATED by CONED 01/23/2020**
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

CLAY___-EDIC___345_2-15

Mon 03/29/2021 to Fri 04/16/2021
 0800 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 OSWEGO EXPORT **4850 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 5250 MW

DUNWODIE_345KV_3

Mon 04/05/2021 to Mon 04/05/2021
 0230 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_5

Mon 04/05/2021 to Mon 04/05/2021
 0230 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

SCH-IMO-NYISO_LIMIT_1600

Sat 05/01/2021 to Sun 10/31/2021 **UPDATED by IESO 05/03/2019**
 0001 Continuous 2359
 Work scheduled by: IESO

FWD
 (Import)
 SCH - OH - NY **1900 MW**
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 1900 MW

NYISO TRANSFER LIMITATIONS

Sunday ,January 26, 2020 to Tuesday ,July 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PANNELL_-CLAY_____345_2

FWD

Mon 05/03/2021 to Fri 05/28/2021
 0700 Continuous 1730

(Import)

Work scheduled by: NYPA

WEST CENTRAL **1300 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

MOSES_-ADIRNDCK_230_MA2

FWD

Tue 06/01/2021 to Sun 11/14/2021
 0700 Continuous 1300

(Import)

Work scheduled by: NYPA

MOSES SOUTH **2100 MW**
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW