

NYISO TRANSFER LIMITATIONS

Monday ,January 27, 2020 to Wednesday, July 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Fri 05/01/2020 **EXTENDED** **by CONED** **10/08/2019**
 0001 Continuous 2359
 Work scheduled by: ConEd

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Fri 05/01/2020
 0001 2359
 Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2550 MW	1600 MW
Impacts Total Transfer Capability	350 MW	250 MW
TTC with All Lines In Service	2900 MW	1850 MW

MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Fri 05/01/2020 **EXTENDED** **by CONED** **10/08/2019**
 0001 Continuous 2359
 Work scheduled by: ConEd

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

STLAWRNC-MOSES_230_L33P

Mon 04/30/2018 to Fri 12/31/2021 **EXT FORCE** **by IESO** **08/21/2018**
 0456 Continuous 2359
 Work scheduled by: IESO

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

SCH-IMO-NYISO_LIMIT_1750

Fri 11/01/2019 to Thu 04/30/2020 **UPDATED** **by IESO** **05/03/2019**
 0001 Continuous 2359
 Work scheduled by: IESO

	FWD
	(Import)
SCH - OH - NY	2050 MW
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	2050 MW

SCH-NYISO-IMO_LIMIT_1600

Fri 11/01/2019 to Thu 04/30/2020 **UPDATED** **by IESO** **05/03/2019**
 0001 Continuous 2359
 Work scheduled by: IESO

	REV
	(Export)
SCH - OH - NY	1900 MW
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	1900 MW

SCH-NYISO-NE_LIMIT_1500

Fri 11/01/2019 to Thu 04/30/2020
 0001 Continuous 2359
 Work scheduled by: NYISO

	REV
	(Export)
SCH - NE - NY	1700 MW
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	1700 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 27, 2020 to Wednesday,July 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

OSWEGO_COMPLEX_AVR_O/S					FWD	
Mon 11/18/2019	to	Mon 03/09/2020	<u>EXT FORCE</u>	<u>by GEN</u>	<u>12/26/2019</u>	(Import)
0221	Continuous	0001				CENTRAL EAST - VC 2870 MW
Work scheduled by: Gen					Impacts Total Transfer Capability	105 MW
					TTC with All Lines In Service	2975 MW
DUNWODIE_345KV_6					FWD	
Tue 12/03/2019	to	Thu 02/20/2020	<u>EXT FORCE</u>	<u>by CONED</u>	<u>01/24/2020</u>	(Import)
0048	Continuous	2359				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_8					FWD	
Tue 12/03/2019	to	Thu 02/20/2020	<u>EXT FORCE</u>	<u>by CONED</u>	<u>01/24/2020</u>	(Import)
0048	Continuous	2359				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
PLSNTVLE-DUNWODIE_345_W90					FWD	
Tue 12/03/2019	to	Thu 02/20/2020	<u>EXT FORCE</u>	<u>by CONED</u>	<u>01/24/2020</u>	(Import)
0107	Continuous	2359				UPNY CONED 4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1700 MW
					TTC with All Lines In Service	5700 MW
FRASER__345_FRASER SVC					FWD	
Mon 01/13/2020	to	Fri 01/24/2020	<u>UPDATED</u>	<u>by NYSEG</u>	<u>12/18/2019</u>	(Import)
0800	Continuous	1102				CENTRAL EAST - VC 2935 MW
Work scheduled by: NYSEG					Impacts Total Transfer Capability	40 MW
					TTC with All Lines In Service	2975 MW
FROST_BR-LONG_MTN_345_352					FWD	
Mon 01/20/2020	to	Thu 01/23/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>01/14/2020</u>	(Import)
0100	Continuous	1600				SCH - NE - NY 1300 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	1400 MW
SCH-NE-NYISO_LIMIT_300					FWD	
Mon 01/20/2020	to	Thu 01/23/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>01/14/2020</u>	(Import)
0100	Continuous	1600				SCH - NE - NY 500 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability	900 MW
					TTC with All Lines In Service	1400 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 27, 2020 to Wednesday, July 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_500

Wed 01/22/2020 to Thu 01/23/2020
0500 Continuous 1159

UPDATED by ISONE 01/23/2020

Work scheduled by: ISONE

FWD
(Import)
700 MW
SCH - NE - NY
Impacts Total Transfer Capability 700 MW
TTC with All Lines In Service 1400 MW

W49TH_ST-E13THSTA_345_M54

Fri 01/24/2020 to Fri 01/24/2020
0001 Continuous 0500

CANCELLED by ConEd 01/22/2020

Work scheduled by: ConEd

FWD
(Import)
3800 MW
SPR/DUN-SOUTH
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

SCH-IMO-NYISO_LIMIT_900

Fri 01/24/2020 to Fri 01/24/2020
0500 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
1200 MW
SCH - OH - NY
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 2050 MW

SCH-IMO-NYISO_LIMIT_1400

Sat 01/25/2020 to Sat 01/25/2020
0500 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
1700 MW
SCH - OH - NY
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 2050 MW

PLSNTVLE-DUNWODIE_345_W89

Sat 01/25/2020 to Sun 01/26/2020
1513 Continuous 2359

FORCED by CE 01/26/2020

Work scheduled by: ConEd

FWD
(Import)
4000 MW
UPNY CONED
Impacts Total Transfer Capability 1700 MW
TTC with All Lines In Service 5700 MW

SCH-NYISO-IMO_NIAGARA_CB_3022

Tue 01/28/2020 to Wed 01/29/2020
0500 Continuous 1900

UPDATED by NYISO 01/24/2020

Work scheduled by: NYPA

FWD REV
(Import) (Export)
1550 MW 1400 MW
SCH - OH - NY
Impacts Total Transfer Capability 500 MW 500 MW
TTC with All Lines In Service 2050 MW 1900 MW

BERKSHIR-ALPS_345_393

Wed 01/29/2020 to Sat 02/08/2020
1301 Continuous 1600

ARR: 78

FWD REV
(Import) (Export)
1150 MW 1700 MW
SCH - NE - NY
Impacts Total Transfer Capability 250 MW 0 MW
TTC with All Lines In Service 1400 MW 1700 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 27, 2020 to Wednesday, July 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-ALPS _____ 345_393			FWD	REV
			(Import)	(Export)
Wed 01/29/2020	to	Sat 02/08/2020		
1301	Continuous	1600	SCH - NPX_1385	100 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW
			TTC with All Lines In Service	200 MW
ARR: 78				
BERKSHIR-ALPS _____ 345_393 & BERKSHIR-NORTHFLD_345_312			FWD	REV
			(Import)	(Export)
Wed 01/29/2020	to	Sat 02/08/2020		
1301		1600	SCH - NE - NY	1150 MW
Work scheduled by:			Impacts Total Transfer Capability	250 MW
			TTC with All Lines In Service	1400 MW
ARR: 78				
BERKSHIR-NORTHFLD_345_312			FWD	
			(Import)	
Wed 01/29/2020	to	Sat 02/08/2020		
1301	Continuous	1600	SCH - NE - NY	1400 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	0 MW
			TTC with All Lines In Service	1400 MW
BERKSHIR-NORTHFLD_345_312			FWD	REV
			(Import)	(Export)
Wed 01/29/2020	to	Sat 02/08/2020		
1301	Continuous	1600	SCH - NPX_1385	100 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW
			TTC with All Lines In Service	200 MW
SCH-NE-NYISO_LIMIT_700			FWD	
			(Import)	
Wed 01/29/2020	to	Sat 02/08/2020		
1301	Continuous	1600	SCH - NE - NY	900 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	500 MW
			TTC with All Lines In Service	1400 MW
SCH-NYISO-NE_LIMIT_500				REV
				(Export)
Wed 01/29/2020	to	Sat 02/08/2020		
1301	Continuous	1600	SCH - NE - NY	700 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	1000 MW
			TTC with All Lines In Service	1700 MW
NEPTUNE_-DUFFYAVE_345_NEPTUNE			FWD	
			(Import)	
Fri 01/31/2020	to	Fri 01/31/2020		
0900	Continuous	1530	SCH - PJM_NEPTUNE	0 MW
Work scheduled by: LI			Impacts Total Transfer Capability	660 MW
			TTC with All Lines In Service	660 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 27, 2020 to Wednesday,July 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE-DUFFYAVE_345_501

Fri 01/31/2020 to Fri 01/31/2020
0900 Continuous 1530

Work scheduled by: LI

FWD
(Import)
SCH - PJM_NEPTUNE **0 MW**
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_1

Fri 01/31/2020 to Fri 01/31/2020
0900 Continuous 1530

Work scheduled by: LI

FWD
(Import)
SCH - PJM_NEPTUNE **375 MW**
Impacts Total Transfer Capability 285 MW
TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_2

Fri 01/31/2020 to Fri 01/31/2020
0900 Continuous 1530

Work scheduled by: LI

FWD
(Import)
SCH - PJM_NEPTUNE **375 MW**
Impacts Total Transfer Capability 285 MW
TTC with All Lines In Service 660 MW

RAMAPO__-BUCHAN_N_345_Y94

Mon 02/03/2020 to Tue 02/04/2020
0001 Continuous 0230

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4800 MW**
Impacts Total Transfer Capability 900 MW
TTC with All Lines In Service 5700 MW

PLSNTVLY_345KV_RNS4

Mon 02/03/2020 to Tue 02/04/2020
0001 Continuous 2200

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **3800 MW**
Impacts Total Transfer Capability 1900 MW
TTC with All Lines In Service 5700 MW

BECK__-NIAGARA_230_PA27

Mon 02/03/2020 to Thu 02/13/2020
0500 Continuous 1700

Work scheduled by: IESO

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

MOSES__-ADIRNDCK_230_MAL

Mon 02/03/2020 to Fri 02/07/2020
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 27, 2020 to Wednesday,July 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EFISHKIL-WOOD_ST__345_F39

Mon 02/10/2020 to Mon 02/10/2020
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 1700 MW
 TTC with All Lines In Service 5700 MW

WOOD_ST_-PLSNTVLE_345_Y87

Mon 02/10/2020 to Wed 02/12/2020
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 1700 MW
 TTC with All Lines In Service 5700 MW

MOSES__-ADIRNDCK_230_MA1

Mon 02/10/2020 to Fri 02/14/2020
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

HURLYAVE-ROSETON__345_303

Tue 02/11/2020 to Thu 02/13/2020
 0700 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4100 MW**
 Impacts Total Transfer Capability 1600 MW
 TTC with All Lines In Service 5700 MW

EFISHKIL-WOOD_ST__345_F39

Wed 02/12/2020 to Wed 02/12/2020
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 1700 MW
 TTC with All Lines In Service 5700 MW

EFISHKIL-WOOD_ST__345_F38

Fri 02/14/2020 to Sat 02/15/2020 **CANCELLED by ConEd 01/27/2020**
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 1700 MW
 TTC with All Lines In Service 5700 MW

WOOD_ST_-PLSNTVLE_345_Y86

Fri 02/14/2020 to Sat 02/15/2020 **CANCELLED by ConEd 01/27/2020**
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 1700 MW
 TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 27, 2020 to Wednesday,July 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
SPRNBK_-TREMONT_345_X28			FWD
Mon 02/17/2020	to	Mon 02/17/2020	(Import)
0001	Continuous	1800	4200 MW
Work scheduled by: ConEd			
		SPR/DUN-SOUTH	4200 MW
		Impacts Total Transfer Capability	400 MW
		TTC with All Lines In Service	4600 MW
<hr/>			
WATRCURE-OAKDALE_345_31			FWD
Mon 02/17/2020	to	Mon 02/17/2020	(Import)
1500	Continuous	1530	2750 MW
Work scheduled by: NYSEG			
		SCH - PJ - NY	2750 MW
		Impacts Total Transfer Capability	150 MW
		TTC with All Lines In Service	2900 MW
<hr/>			
MOSES_-ADIRNDCK_230_MA1			FWD
Tue 02/18/2020	to	Fri 02/21/2020	(Import)
0700	Continuous	1530	2300 MW
Work scheduled by: NYPA			
		MOSES SOUTH	2300 MW
		Impacts Total Transfer Capability	850 MW
		TTC with All Lines In Service	3150 MW
<hr/>			
SPRNBK_345KV_RNS5			FWD
Mon 02/24/2020	to	Mon 02/24/2020	(Import)
0001	Continuous	0030	3200 MW
Work scheduled by: ConEd			
		SPR/DUN-SOUTH	3200 MW
		Impacts Total Transfer Capability	1400 MW
		TTC with All Lines In Service	4600 MW
<hr/>			
SPRNBK_-W49TH_ST_345_M51			FWD
Mon 02/24/2020	to	Sun 03/01/2020	(Import)
0001	Continuous	0200	3200 MW
Work scheduled by: ConEd			
		SPR/DUN-SOUTH	3200 MW
		Impacts Total Transfer Capability	1400 MW
		TTC with All Lines In Service	4600 MW
<hr/>			
SPRNBK_345KV_RNS5			FWD
Wed 02/26/2020	to	Wed 02/26/2020	(Import)
2130	Continuous	2200	3200 MW
Work scheduled by: ConEd			
		SPR/DUN-SOUTH	3200 MW
		Impacts Total Transfer Capability	1400 MW
		TTC with All Lines In Service	4600 MW
<hr/>			
SPRNBK_345KV_RNS5			FWD
Thu 02/27/2020	to	Sun 03/01/2020	(Import)
2301	Continuous	0200	3200 MW
Work scheduled by: ConEd			
		SPR/DUN-SOUTH	3200 MW
		Impacts Total Transfer Capability	1400 MW
		TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 27, 2020 to Wednesday,July 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-PACKARD__230_62					FWD	REV
					(Import)	(Export)
Fri 02/28/2020	to	Fri 02/28/2020			SCH - OH - NY	900 MW 1850 MW
0500	Continuous	1530			Impacts Total Transfer Capability	1150 MW 50 MW
Work scheduled by: NYPA					TTC with All Lines In Service	2050 MW 1900 MW
DUNWODIE_345KV_4					FWD	
					(Import)	
Sun 03/01/2020	to	Sun 03/08/2020			SPR/DUN-SOUTH	3800 MW
0001	Continuous	2200			Impacts Total Transfer Capability	800 MW
Work scheduled by: ConEd					TTC with All Lines In Service	4600 MW
CHATGUAY-MASSENA__765_7040					FWD	
					(Import)	
Mon 03/02/2020	to	Fri 03/06/2020	UPDATED	by NYPA	08/08/2019	
0500	Continuous	1730			MOSES SOUTH	1550 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	3150 MW
CHATGUAY-MASSENA__765_7040					FWD	REV
					(Import)	(Export)
Mon 03/02/2020	to	Fri 03/06/2020	UPDATED	by NYPA	08/08/2019	
0500	Continuous	1730			SCH - HQ - NY	0 MW 0 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1500 MW 1000 MW
					TTC with All Lines In Service	1500 MW 1000 MW
MARCY___765_345_AT1					FWD	
					(Import)	
Mon 03/02/2020	to	Fri 03/06/2020	UPDATED	by NYPA	08/08/2019	
0500	Continuous	1730			MOSES SOUTH	1750 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	3150 MW
MARCY___765_345_AT2					FWD	
					(Import)	
Mon 03/02/2020	to	Fri 03/06/2020			MOSES SOUTH	1700 MW
0500	Continuous	1730			Impacts Total Transfer Capability	1450 MW
Work scheduled by: NYPA					TTC with All Lines In Service	3150 MW
MASSENA_-MARCY___765_MSU1					FWD	
					(Import)	
Mon 03/02/2020	to	Fri 03/06/2020	UPDATED	by NYPA	08/08/2019	
0500	Continuous	1730			CENTRAL EAST - VC	2265 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	710 MW
					TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 27, 2020 to Wednesday, July 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA -MARCY 765_MSU1					FWD	
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)
0500	Continuous	1730				MOSES SOUTH 500 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	2650 MW
					TTC with All Lines In Service	3150 MW
MASSENA -MARCY 765_MSU1					FWD	REV
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import) (Export)
0500	Continuous	1730				SCH - HQ - NY 475 MW 1000 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1025 MW 0 MW
					TTC with All Lines In Service	1500 MW 1000 MW
MASSENA -MARCY 765_MSU1					FWD	
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)
0500	Continuous	1730				SCH - HQ_CEDARS 90 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	109 MW
					TTC with All Lines In Service	199 MW
MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040					FWD	
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)
0500		1730				MOSES SOUTH 500 MW
Work scheduled by:					Impacts Total Transfer Capability	2650 MW
					TTC with All Lines In Service	3150 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2					FWD	REV
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import) (Export)
0500		1730				SCH - HQ - NY 850 MW 0 MW
Work scheduled by:					Impacts Total Transfer Capability	650 MW 1000 MW
					TTC with All Lines In Service	1500 MW 1000 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2					FWD	
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)
0500		1730				SCH - HQ_CEDARS 90 MW
Work scheduled by:					Impacts Total Transfer Capability	109 MW
					TTC with All Lines In Service	199 MW
STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1					FWD	
Mon 03/02/2020	to	Fri 03/06/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/08/2019</u>	(Import)
0500		1730				SCH - HQ_CEDARS 90 MW
Work scheduled by:					Impacts Total Transfer Capability	109 MW
					TTC with All Lines In Service	199 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 27, 2020 to Wednesday,July 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>STLAWRNC-MOSES__230_L33P & MOSES__-MASSENA__230_MMS1 & MOSES__-MASSENA__230_MMS2</p> <p>Mon 03/02/2020 to Fri 03/06/2020 0500 1730</p> <p>Work scheduled by:</p>	<p>FWD (Import) 90 MW Impacts Total Transfer Capability 109 MW TTC with All Lines In Service 199 MW</p>
<p>SHOR_NPX-SHOREHAM_138_CSC</p> <p>Mon 03/02/2020 to Tue 03/03/2020 0600 Continuous 1300</p> <p>Work scheduled by: LI</p>	<p>FWD REV (Import) (Export) 0 MW 0 MW Impacts Total Transfer Capability 330 MW 330 MW TTC with All Lines In Service 330 MW 330 MW</p>
<p>ROSETON_-EFISHKIL_345_RFK305</p> <p>Mon 03/02/2020 to Fri 03/20/2020 0700 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import) 4800 MW Impacts Total Transfer Capability 900 MW TTC with All Lines In Service 5700 MW</p>
<p>EASTVIEW-SPRNBRK__345_W78</p> <p>Fri 03/06/2020 to Sat 03/07/2020 0001 Continuous 0200</p> <p>Work scheduled by: ConEd</p>	<p>FWD (Import) 4350 MW Impacts Total Transfer Capability 1350 MW TTC with All Lines In Service 5700 MW</p>
<p>MILLWOOD-EASTVIEW_345_W85</p> <p>Fri 03/06/2020 to Sat 03/07/2020 0001 Continuous 0200</p> <p>Work scheduled by: ConEd</p>	<p>FWD (Import) 4350 MW Impacts Total Transfer Capability 1350 MW TTC with All Lines In Service 5700 MW</p>
<p>SPRNBRK__345KV_RNS3</p> <p>Fri 03/06/2020 to Sat 03/07/2020 0001 Continuous 0200</p> <p>Work scheduled by: ConEd</p>	<p>FWD (Import) 3800 MW Impacts Total Transfer Capability 800 MW TTC with All Lines In Service 4600 MW</p>
<p>MOSES__-ADIRNDCK_230_MA1</p> <p>Sat 03/07/2020 to Fri 05/29/2020 0700 Continuous 1300</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import) 2300 MW Impacts Total Transfer Capability 850 MW TTC with All Lines In Service 3150 MW</p>

NYISO TRANSFER LIMITATIONS

Monday ,January 27, 2020 to Wednesday, July 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_5

Mon 03/09/2020 to Mon 03/09/2020
 0001 Continuous 0030
 Work scheduled by: ConEd

CANCELLED by ConEd 01/22/2020

FWD
 (Import)
 SCH - PJM_HTP **350 MW**
 Impacts Total Transfer Capability 310 MW
 TTC with All Lines In Service 660 MW

SPRNBRK_-W49TH_ST_345_M52

Mon 03/09/2020 to Wed 03/11/2020
 0001 Continuous 2200
 Work scheduled by: ConEd

CANCELLED by ConEd 01/22/2020

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

SPRNBRK__345KV_RNS4

Mon 03/09/2020 to Wed 03/11/2020
 0001 Continuous 2200
 Work scheduled by: ConEd

CANCELLED by ConEd 01/22/2020

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

VOLNEY_-MARCY__345_19

Tue 03/10/2020 to Tue 03/10/2020
 0700 Continuous 1530
 Work scheduled by: NYPA

UPDATED by NYPA 09/24/2019

ARR: 19

FWD
 (Import)
 CENTRAL EAST - VC **2825 MW**
 Impacts Total Transfer Capability 150 MW
 TTC with All Lines In Service 2975 MW

VOLNEY_-MARCY__345_19

Tue 03/10/2020 to Tue 03/10/2020
 0700 Continuous 1530
 Work scheduled by: NYPA

UPDATED by NYPA 09/24/2019

ARR: 19

FWD
 (Import)
 OSWEGO EXPORT **4900 MW**
 Impacts Total Transfer Capability 350 MW
 TTC with All Lines In Service 5250 MW

W49TH_ST_345KV_5

Wed 03/11/2020 to Wed 03/11/2020
 2130 Continuous 2200
 Work scheduled by: ConEd

CANCELLED by ConEd 01/22/2020

FWD
 (Import)
 SCH - PJM_HTP **350 MW**
 Impacts Total Transfer Capability 310 MW
 TTC with All Lines In Service 660 MW

ROCHESTR-PANNELL__345_RP2

Sat 03/14/2020 to Mon 03/23/2020
 0500 Continuous 1700
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 27, 2020 to Wednesday,July 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BECK -NIAGARA 230_PA27

Mon 03/16/2020 to Fri 03/20/2020
 0400 Continuous 1700
 Work scheduled by: IESO

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

MARCY 345KV_CSC

Mon 03/16/2020 to Fri 03/20/2020 **EXTENDED by NYISO 01/27/2020**
 0500 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2925 MW**
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 2975 MW

CHASLAKE-PORTER 230_11

Wed 03/18/2020 to Wed 03/18/2020
 0630 Daily(No Weekends) 1330
 Work scheduled by: NGrid

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

SCH-NYISO-NE LIMIT_900

Wed 03/18/2020 to Tue 03/31/2020
 0700 Continuous 2359
 Work scheduled by: ISONE

REV
 (Export)
 SCH - NE - NY **1100 MW**
 Impacts Total Transfer Capability 600 MW
 TTC with All Lines In Service 1700 MW

BUCHAN_N-EASTVIEW_345_W93

Thu 03/19/2020 to Thu 03/19/2020
 0200 Continuous 0230
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

EASTVIEW-SPRNBRK 345_W79

Thu 03/19/2020 to Fri 03/20/2020
 0200 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

BUCHAN_N-EASTVIEW_345_W93

Fri 03/20/2020 to Fri 03/20/2020
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 27, 2020 to Wednesday,July 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD-EASTVIEW_345_W85

Sun 03/22/2020 to Sun 03/22/2020
0201 Continuous 0231

UPDATED by CE 12/20/2019

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1350 MW
TTC with All Lines In Service 5700 MW

DUNWODIE-MOTTHAVN_345_72

Sun 03/22/2020 to Tue 03/24/2020
0201 Continuous 0200

UPDATED by CE 12/20/2019

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_8

Sun 03/22/2020 to Tue 03/24/2020
0201 Continuous 0200

UPDATED by CE 12/20/2019

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

EASTVIEW-SPRNBK_345_W78

Sun 03/22/2020 to Tue 03/24/2020
0201 Continuous 0200

UPDATED by CE 12/20/2019

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1350 MW
TTC with All Lines In Service 5700 MW

DUNWODIE_345KV_5

Sun 03/22/2020 to Mon 05/11/2020
0201 Continuous 0300

UPDATED by CE 12/20/2019

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_7

Sun 03/22/2020 to Mon 05/11/2020
0201 Continuous 0300

UPDATED by CE 12/20/2019

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

SPRNBK_-DUNWODIE_345_W75

Sun 03/22/2020 to Mon 05/11/2020
0201 Continuous 0300

UPDATED by CE 12/20/2019

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 27, 2020 to Wednesday,July 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK__345KV_RNS3

Sun 03/22/2020 to Mon 05/11/2020
0201 Continuous 0300

Work scheduled by: ConEd

UPDATED by CE 12/20/2019

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD
(Import)

RAMAPO__-BUCHAN_N_345_Y94

Tue 03/24/2020 to Tue 03/24/2020
0001 Continuous 0030

Work scheduled by: ConEd

UPNY CONED **4800 MW**
Impacts Total Transfer Capability 900 MW
TTC with All Lines In Service 5700 MW

FWD
(Import)

MILLWOOD-EASTVIEW_345_W85

Tue 03/24/2020 to Tue 03/24/2020
0130 Continuous 0200

Work scheduled by: ConEd

UPDATED by CE 12/20/2019

UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1350 MW
TTC with All Lines In Service 5700 MW

FWD
(Import)

DUNWODIE-MOTTHAVN_345_71

Tue 03/24/2020 to Thu 03/26/2020
0201 Continuous 0200

Work scheduled by: ConEd

UPDATED by CE 12/20/2019

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD
(Import)

DUNWODIE_345KV_3

Tue 03/24/2020 to Thu 03/26/2020
0201 Continuous 0200

Work scheduled by: ConEd

UPDATED by CE 12/20/2019

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD
(Import)

RAMAPO__-BUCHAN_N_345_Y94

Tue 03/24/2020 to Tue 03/24/2020
0630 Continuous 0700

Work scheduled by: ConEd

UPNY CONED **4800 MW**
Impacts Total Transfer Capability 900 MW
TTC with All Lines In Service 5700 MW

FWD
(Import)

SPRNBK__345KV_RS3 & SPRNBK__345KV_RS4

Thu 03/26/2020 to Sun 03/29/2020
0201 0200

Work scheduled by:

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD
(Import)

NYISO TRANSFER LIMITATIONS

Monday ,January 27, 2020 to Wednesday, July 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>NIAGARA_-KINTIGH_345_NS1-38</p> <p>Fri 03/27/2020 to Fri 03/27/2020 0600 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>DYSINGER EAST 1700 MW</p> <p>Impacts Total Transfer Capability 1450 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>BECK_-PACKARD_230_BP76</p> <p>Fri 03/27/2020 to Fri 03/27/2020 0800 Daily(No Weekends) 1600</p> <p>Work scheduled by: NGrid</p>	<p style="text-align: right;">FWD REV (Import) (Export)</p> <p>SCH - OH - NY 1650 MW 1400 MW</p> <p>Impacts Total Transfer Capability 400 MW 500 MW</p> <p>TTC with All Lines In Service 2050 MW 1900 MW</p>
<p>BECK_-NIAGARA_230_PA27</p> <p>Mon 03/30/2020 to Fri 05/29/2020 0400 Continuous 1700</p> <p>Work scheduled by: IESO</p>	<p style="text-align: right;">SCH - OH - NY</p> <p>Impacts Total Transfer Capability</p> <p>TTC with All Lines In Service</p>
<p>MARCY_-EDIC_345_UE1-7</p> <p>Tue 03/31/2020 to Tue 03/31/2020 0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>OSWEGO EXPORT 5250 MW</p> <p>Impacts Total Transfer Capability 0 MW</p> <p>TTC with All Lines In Service 5250 MW</p>
<p>RAMAPO_-LADENTWN_345_W72</p> <p>Wed 04/01/2020 to Thu 04/02/2020 0001 Continuous 1830</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>UPNY CONED 4400 MW</p> <p>Impacts Total Transfer Capability 1300 MW</p> <p>TTC with All Lines In Service 5700 MW</p>
<p>SCH-NYISO-NE_LIMIT_700</p> <p>Wed 04/01/2020 to Fri 04/03/2020 0001 Continuous 1600</p> <p>Work scheduled by: ISONE</p>	<p style="text-align: right;">REV (Export)</p> <p>SCH - NE - NY 900 MW</p> <p>Impacts Total Transfer Capability 800 MW</p> <p>TTC with All Lines In Service 1700 MW</p>
<p>FRASANNX-COOPERS_345_UCC2-41</p> <p>Wed 04/01/2020 to Thu 04/02/2020 0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC 2500 MW</p> <p>Impacts Total Transfer Capability 475 MW</p> <p>TTC with All Lines In Service 2975 MW</p>

NYISO TRANSFER LIMITATIONS

Monday ,January 27, 2020 to Wednesday, July 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___-FRASANNX_345_UCC2-41					FWD	
Wed 04/01/2020	to	Thu 04/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>11/12/2019</u>	(Import)
0700	Continuous	1530				CENTRAL EAST - VC 2500 MW
Work scheduled by: NYPA					ARR: 19	Impacts Total Transfer Capability 475 MW
						TTC with All Lines In Service 2975 MW
LINDN_CG-LNDVFT___345_V-3022					FWD	
Sun 04/05/2020	to	Sat 04/11/2020				(Import) (Export)
1400	Continuous	1400				SCH - PJM_VFT 0 MW 0 MW
Work scheduled by: PJM						Impacts Total Transfer Capability 315 MW 315 MW
						TTC with All Lines In Service 315 MW 315 MW
MARCY___-N.SCTLND_345_18					FWD	
Tue 04/07/2020	to	Wed 04/08/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/24/2019</u>	(Import)
0700	Continuous	1530				CENTRAL EAST - VC 2090 MW
Work scheduled by: NYPA					ARR: 19	Impacts Total Transfer Capability 885 MW
						TTC with All Lines In Service 2975 MW
PLSNTVLY-EFISHKIL_345_F36					FWD	
Mon 04/13/2020	to	Tue 04/14/2020				(Import)
0001	Continuous	0200				UPNY CONED 4000 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 1700 MW
						TTC with All Lines In Service 5700 MW
SAND_BAR-PLATSBRG_115_PV20					FWD	
Mon 04/13/2020	to	Tue 04/14/2020				(Import)
0600	Daily	1800				SCH - NE - NY
Work scheduled by: ISONE						Impacts Total Transfer Capability
						TTC with All Lines In Service
FRASER___-GILBOA___345_GF5-35					FWD	
Mon 04/13/2020	to	Wed 04/22/2020				(Import)
0700	Continuous	1730				CENTRAL EAST - VC 2650 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 325 MW
						TTC with All Lines In Service 2975 MW
NIAGARA_-ROCHESTR_345_NR2					FWD	
Wed 04/15/2020	to	Fri 05/01/2020				(Import)
0500	Continuous	1700				DYSINGER EAST 1700 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 1450 MW
						TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 27, 2020 to Wednesday, July 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROCHESTR-PANNELL__345_RP1

Mon 04/20/2020 to Fri 04/24/2020
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

DOLSONAV-ROCKTVRN_345_DART44

Mon 04/27/2020 to Sun 05/10/2020 **UPDATED by NYPA 03/21/2019**
 0700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2720 MW**
 Impacts Total Transfer Capability 255 MW
 TTC with All Lines In Service 2975 MW

HURLYAVE-ROSETON__345_303

Mon 04/27/2020 to Fri 05/29/2020 **UPDATED by CHGE 10/09/2019**
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4100 MW**
 Impacts Total Transfer Capability 1600 MW
 TTC with All Lines In Service 5700 MW

DUNWODIE-MOTTHAVN_345_72

Tue 04/28/2020 to Sat 05/02/2020
 0200 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

MILLWOOD-EASTVIEW_345_W85

Wed 04/29/2020 to Wed 04/29/2020
 0201 Continuous 0230
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

EASTVIEW-SPRNBRK__345_W78

Wed 04/29/2020 to Sun 05/03/2020
 0201 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

SCH-IMO-NYISO_LIMIT_1600

Fri 05/01/2020 to Sat 10/31/2020 **UPDATED by IESO 05/03/2019**
 0001 Continuous 2359
 Work scheduled by: IESO

FWD
 (Import)
 SCH - OH - NY **1900 MW**
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 1900 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 27, 2020 to Wednesday,July 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE-MOTTHAVN_345_71

Sat 05/02/2020 to Wed 05/06/2020
 0201 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_3

Sat 05/02/2020 to Wed 05/06/2020
 0201 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

MILLWOOD-EASTVIEW_345_W85

Sun 05/03/2020 to Sun 05/03/2020
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

PANNELL -CLAY_345_2

Mon 05/04/2020 to Fri 05/08/2020
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 WEST CENTRAL **1300 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

NEPTUNE -DUFFYAVE_345_NEPTUNE

Mon 05/04/2020 to Mon 05/18/2020
 0800 Continuous 1700
 Work scheduled by: PJM

FWD
 (Import)
 SCH - PJM_NEPTUNE **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE-DUFFYAVE_345_501

Mon 05/04/2020 to Mon 05/18/2020
 0800 Continuous 1700
 Work scheduled by: PJM

FWD
 (Import)
 SCH - PJM_NEPTUNE **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_1

Mon 05/04/2020 to Mon 05/18/2020
 0800 Continuous 1700
 Work scheduled by: PJM

FWD
 (Import)
 SCH - PJM_NEPTUNE **375 MW**
 Impacts Total Transfer Capability 285 MW
 TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 27, 2020 to Wednesday, July 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE_345_138_BK_2

Mon 05/04/2020 to Mon 05/18/2020
0800 Continuous 1700

Work scheduled by: PJM

FWD
(Import)
SCH - PJM_NEPTUNE **375 MW**
Impacts Total Transfer Capability 285 MW
TTC with All Lines In Service 660 MW

SPRNBRK_345KV_RS3 & SPRNBRK_345KV_RS4

Wed 05/06/2020 to Mon 05/11/2020
0201 0200

Work scheduled by:

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

PANNELL_-CLAY_345_1

Mon 05/11/2020 to Fri 05/15/2020
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

COOPERS_-DOLSONAV_345_CCDA42

Mon 05/11/2020 to Fri 05/29/2020
0700 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 03/21/2019

FWD
(Import)
CENTRAL EAST - VC **2720 MW**
Impacts Total Transfer Capability 255 MW
TTC with All Lines In Service 2975 MW

KINTIGH_-ROCHESTR_345_SRL-39

Mon 05/18/2020 to Fri 05/22/2020
0500 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

SCH-NE-NYISO_LIMIT_700

Mon 05/18/2020 to Mon 05/18/2020
0700 Continuous 1059

Work scheduled by: ISONE

FWD
(Import)
SCH - NE - NY **900 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1400 MW

SCH-NYISO-NE_LIMIT_500

Mon 05/18/2020 to Mon 05/18/2020
0700 Continuous 1059

Work scheduled by: ISONE

REV
(Export)
SCH - NE - NY **700 MW**
Impacts Total Transfer Capability 900 MW
TTC with All Lines In Service 1600 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 27, 2020 to Wednesday,July 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-ALPS _____ 345_393 & BERKSHIR-NORTHFLD_345_312			FWD	REV
Mon 05/18/2020	to	Mon 05/18/2020	(Import)	(Export)
0700		1100	SCH - NE - NY	950 MW 1300 MW
Work scheduled by:			Impacts Total Transfer Capability	450 MW 300 MW
ARR: 78			TTC with All Lines In Service	1400 MW 1600 MW
<hr/>				
BERKSHIR-NORTHFLD_345_312			FWD	REV
Mon 05/18/2020	to	Mon 05/18/2020	(Import)	(Export)
0700	Continuous	1100	SCH - NE - NY	900 MW 1500 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	500 MW 100 MW
			TTC with All Lines In Service	1400 MW 1600 MW
<hr/>				
BERKSHIR-NORTHFLD_345_312			FWD	REV
Mon 05/18/2020	to	Mon 05/18/2020	(Import)	(Export)
0700	Continuous	1100	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
<hr/>				
BERKSHIR-ALPS _____ 345_393			FWD	REV
Mon 05/18/2020	to	Sat 05/30/2020	(Import)	(Export)
0700	Continuous	1700	SCH - NE - NY	950 MW 1300 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	450 MW 300 MW
ARR: 78			TTC with All Lines In Service	1400 MW 1600 MW
<hr/>				
BERKSHIR-ALPS _____ 345_393			FWD	REV
Mon 05/18/2020	to	Sat 05/30/2020	(Import)	(Export)
0700	Continuous	1700	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
<hr/>				
SCH-NE-NYISO_LIMIT_600			FWD	
Mon 05/18/2020	to	Tue 05/26/2020	(Import)	
1100	Continuous	0559	SCH - NE - NY	800 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	600 MW
			TTC with All Lines In Service	1400 MW
<hr/>				
SCH-NYISO-NE_LIMIT_600				REV
Mon 05/18/2020	to	Sat 05/30/2020		(Export)
1100	Continuous	1459	SCH - NE - NY	800 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	1600 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 27, 2020 to Wednesday, July 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCHEDULE			FWD	REV
SCH-NE-NYISO_LIMIT_500				
Tue 05/26/2020	to	Sat 05/30/2020	(Import)	
0600	Continuous	1700	SCH - NE - NY	700 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	700 MW
			TTC with All Lines In Service	1400 MW
BERKSHIR-ALPS_345_393 & BERKSHIR-NORTHFLD_345_312				
Sat 05/30/2020	to	Sat 05/30/2020	(Import) (Export)	
1500		1700	SCH - NE - NY	950 MW 1300 MW
Work scheduled by: ARR: 78			Impacts Total Transfer Capability	450 MW 300 MW
			TTC with All Lines In Service	1400 MW 1600 MW
BERKSHIR-NORTHFLD_345_312				
Sat 05/30/2020	to	Sat 05/30/2020	(Import) (Export)	
1500	Continuous	1700	SCH - NE - NY	900 MW 1500 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	500 MW 100 MW
			TTC with All Lines In Service	1400 MW 1600 MW
BERKSHIR-NORTHFLD_345_312				
Sat 05/30/2020	to	Sat 05/30/2020	(Import) (Export)	
1500	Continuous	1700	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
SCH-NYISO-NE_LIMIT_500				
Sat 05/30/2020	to	Sat 05/30/2020	(Export)	
1500	Continuous	1700	SCH - NE - NY	700 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	900 MW
			TTC with All Lines In Service	1600 MW
SHOR_NPX-SHOREHAM_138_CSC				
Mon 06/01/2020	to	Tue 06/02/2020	(Import) (Export)	
0501	Continuous	1600	SCH - NPX_CSC	0 MW 0 MW
Work scheduled by: LI			Impacts Total Transfer Capability	330 MW 330 MW
			TTC with All Lines In Service	330 MW 330 MW
MOSES_-ADIRNDCK_230_MA2				
Mon 06/01/2020	to	Fri 07/31/2020	(Import)	
0700	Continuous	1730	MOSES SOUTH	2100 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1050 MW
			TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 27, 2020 to Wednesday,July 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA__345_230_AT4

Mon 06/29/2020 to Tue 06/30/2020
 0500 Continuous 1530
 Work scheduled by: NYPA

REV
 (Export)
 SCH - OH - NY **1400 MW**
 Impacts Total Transfer Capability 300 MW
 TTC with All Lines In Service 1700 MW

SCH-IMO-NYISO_NIAG_CB_3008_W/BB

Mon 07/27/2020 to Fri 08/07/2020
 0500 Continuous 1530
 Work scheduled by: NYPA

FWD REV
 (Import) (Export)
 SCH - OH - NY **1900 MW 1450 MW**
 Impacts Total Transfer Capability 0 MW 250 MW
 TTC with All Lines In Service 1900 MW 1700 MW

CHATGUAY-MASSENA__765_7040

Sat 08/01/2020 to Sun 08/02/2020 **UPDATED by NYPA 08/08/2019**
 0500 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **1550 MW**
 Impacts Total Transfer Capability 1600 MW
 TTC with All Lines In Service 3150 MW

CHATGUAY-MASSENA__765_7040

Sat 08/01/2020 to Sun 08/02/2020 **UPDATED by NYPA 08/08/2019**
 0500 Continuous 1730
 Work scheduled by: NYPA

FWD REV
 (Import) (Export)
 SCH - HQ - NY **0 MW 0 MW**
 Impacts Total Transfer Capability 1500 MW 1000 MW
 TTC with All Lines In Service 1500 MW 1000 MW

MARCY___765_345_AT1

Sat 08/01/2020 to Sun 08/02/2020 **UPDATED by NYPA 08/08/2019**
 0500 Continuous 1730
 Work scheduled by: NYPA **ARR: 19**

FWD
 (Import)
 MOSES SOUTH **1750 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 3150 MW

MASSENA_-MARCY___765_MSU1

Sat 08/01/2020 to Sun 08/02/2020 **UPDATED by NYPA 08/08/2019**
 0500 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2265 MW**
 Impacts Total Transfer Capability 710 MW
 TTC with All Lines In Service 2975 MW

MASSENA_-MARCY___765_MSU1

Sat 08/01/2020 to Sun 08/02/2020 **UPDATED by NYPA 08/08/2019**
 0500 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **500 MW**
 Impacts Total Transfer Capability 2650 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 27, 2020 to Wednesday, July 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Zone	Start	End	Status	By	Date	Schedule	Impact	FWD	REV
MASSENA -MARCY 765_MSU1	Sat 08/01/2020	Sun 08/02/2020	UPDATED	NYPA	08/08/2019	0500 Continuous 1730	SCH - HQ - NY Impacts Total Transfer Capability TTC with All Lines In Service	(Import) 475 MW 1025 MW 1500 MW	(Export) 1000 MW 0 MW 1000 MW
MASSENA -MARCY 765_MSU1	Sat 08/01/2020	Sun 08/02/2020	UPDATED	NYPA	08/08/2019	0500 Continuous 1730	SCH - HQ_CEDARS Impacts Total Transfer Capability TTC with All Lines In Service	(Import) 90 MW 100 MW 190 MW	
MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040	Sat 08/01/2020	Sun 08/02/2020				0500 1730	MOSES SOUTH Impacts Total Transfer Capability TTC with All Lines In Service	(Import) 500 MW 2650 MW 3150 MW	
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2	Sat 08/01/2020	Sun 08/02/2020				0500 1730	SCH - HQ - NY Impacts Total Transfer Capability TTC with All Lines In Service	(Import) 850 MW 650 MW 1500 MW	(Export) 0 MW 1000 MW 1000 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2	Sat 08/01/2020	Sun 08/02/2020				0500 1730	SCH - HQ_CEDARS Impacts Total Transfer Capability TTC with All Lines In Service	(Import) 90 MW 100 MW 190 MW	
STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1	Sat 08/01/2020	Sun 08/02/2020				0500 1730	SCH - HQ_CEDARS Impacts Total Transfer Capability TTC with All Lines In Service	(Import) 90 MW 100 MW 190 MW	
STLAWRNC-MOSES 230_L33P & MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2	Sat 08/01/2020	Sun 08/02/2020				0500 1730	SCH - HQ_CEDARS Impacts Total Transfer Capability TTC with All Lines In Service	(Import) 90 MW 100 MW 190 MW	

NYISO TRANSFER LIMITATIONS

Monday ,January 27, 2020 to Wednesday, July 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -ADIRNDCK_230_MA2

Mon 08/03/2020 to Sun 09/13/2020
0700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

FRASANX-COOPERS_345_UCC2-41

Mon 09/07/2020 to Fri 10/23/2020
0700 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 03/01/2019

ARR: 19

FWD

(Import)

CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

MARCY -FRASANX_345_UCC2-41

Mon 09/07/2020 to Fri 10/23/2020
0700 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 03/01/2019

ARR: 19

FWD

(Import)

CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

MARCY_765_345_AT1

Mon 09/14/2020 to Mon 09/14/2020
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

MOSES SOUTH **1750 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 3150 MW

NIAGARA -KINTIGH_345_NS1-38

Mon 09/14/2020 to Thu 09/17/2020
0500 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

MOSES -ADIRNDCK_230_MA2

Tue 09/15/2020 to Sat 11/14/2020
0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

NIAGARA -ROCHESTR_345_NR2

Fri 09/18/2020 to Sat 11/14/2020
0500 Continuous 2330

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 27, 2020 to Wednesday,July 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CLAY -EDIC 345_1-16

Mon 09/21/2020 to Fri 09/25/2020
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
OSWEGO EXPORT **4850 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 5250 MW

ROSETON -ROCKTVRN 345_311

Mon 09/21/2020 to Fri 10/23/2020 UPDATED by CHGE 10/09/2019
0800 Continuous 1600

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4400 MW**
Impacts Total Transfer Capability 1300 MW
TTC with All Lines In Service 5700 MW

DUNWODIE_345KV_3

Mon 09/28/2020 to Sat 10/31/2020
0001 Continuous 0100

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_4

Mon 09/28/2020 to Sat 10/31/2020
0001 Continuous 0100

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

PLSNTVLE-DUNWODIE_345_W89

Mon 09/28/2020 to Sat 10/31/2020
0001 Continuous 0100

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1700 MW
TTC with All Lines In Service 5700 MW

CLAY -EDIC 345_2-15

Mon 09/28/2020 to Fri 10/02/2020
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
OSWEGO EXPORT **4850 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 5250 MW

MOTTHAVN-RAINEY 345_Q11

Thu 10/01/2020 to Thu 11/05/2020 UPDATED by CONED 12/17/2019
0001 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 27, 2020 to Wednesday, July 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SAND_BAR-PLATSBURG_115_PV20

Sat 10/17/2020 to Sat 11/14/2020
 0600 Continuous 1800
 Work scheduled by: ISONE

SCH - NE - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

LEEDS__-HURLYAVE_345_301

Mon 10/26/2020 to Fri 12/04/2020
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4100 MW**
 Impacts Total Transfer Capability 1600 MW
 TTC with All Lines In Service 5700 MW

SCH-IMO-NYISO_LIMIT_1750

Sun 11/01/2020 to Fri 04/30/2021 **UPDATED by IESO 05/03/2019**
 0001 Continuous 2359
 Work scheduled by: IESO

FWD
 (Import)
 SCH - OH - NY **2050 MW**
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 2050 MW

SCH-NYISO-IMO_LIMIT_1600

Sun 11/01/2020 to Fri 04/30/2021 **UPDATED by IESO 05/03/2019**
 0001 Continuous 2359
 Work scheduled by: IESO

REV
 (Export)
 SCH - OH - NY **1900 MW**
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 1900 MW

CHATGUAY-MASSENA__765_7040

Sun 11/15/2020 to Mon 11/30/2020
 0100 Continuous 1900
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **1550 MW**
 Impacts Total Transfer Capability 1600 MW
 TTC with All Lines In Service 3150 MW

CHATGUAY-MASSENA__765_7040

Sun 11/15/2020 to Mon 11/30/2020
 0100 Continuous 1900
 Work scheduled by: NYPA

FWD REV
 (Import) (Export)
 SCH - HQ - NY **0 MW 0 MW**
 Impacts Total Transfer Capability 1500 MW 1000 MW
 TTC with All Lines In Service 1500 MW 1000 MW

MARCY__765_345_AT1

Sun 11/15/2020 to Mon 11/30/2020
 0100 Continuous 1900
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **1750 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 3150 MW

ARR: 19

NYISO TRANSFER LIMITATIONS

Monday ,January 27, 2020 to Wednesday,July 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT2

Sun 11/15/2020 to Mon 11/30/2020
0100 Continuous 1900

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

MASSENA_-MARCY___765_MSU1

Sun 11/15/2020 to Mon 11/30/2020
0100 Continuous 1900

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2265 MW**
Impacts Total Transfer Capability 710 MW
TTC with All Lines In Service 2975 MW

MASSENA_-MARCY___765_MSU1

Sun 11/15/2020 to Mon 11/30/2020
0100 Continuous 1900

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **500 MW**
Impacts Total Transfer Capability 2650 MW
TTC with All Lines In Service 3150 MW

MASSENA_-MARCY___765_MSU1

Sun 11/15/2020 to Mon 11/30/2020
0100 Continuous 1900

Work scheduled by: NYPA

FWD REV
(Import) (Export)
SCH - HQ - NY **475 MW 1000 MW**
Impacts Total Transfer Capability 1025 MW 0 MW
TTC with All Lines In Service 1500 MW 1000 MW

MASSENA_-MARCY___765_MSU1

Sun 11/15/2020 to Mon 11/30/2020
0100 Continuous 1900

Work scheduled by: NYPA

FWD
(Import)
SCH - HQ_CEDARS **90 MW**
Impacts Total Transfer Capability 109 MW
TTC with All Lines In Service 199 MW

MASSENA_-MARCY___765_MSU1 & CHATGUAY-MASSENA_765_7040

Sun 11/15/2020 to Mon 11/30/2020
0100 1900

Work scheduled by:

FWD
(Import)
MOSES SOUTH **500 MW**
Impacts Total Transfer Capability 2650 MW
TTC with All Lines In Service 3150 MW

MOSES___-MASSENA_230_MMS1 & MOSES___-MASSENA_230_MMS2

Sun 11/15/2020 to Mon 11/30/2020
0100 1900

Work scheduled by:

FWD REV
(Import) (Export)
SCH - HQ - NY **850 MW 0 MW**
Impacts Total Transfer Capability 650 MW 1000 MW
TTC with All Lines In Service 1500 MW 1000 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 27, 2020 to Wednesday,July 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2

Sun 11/15/2020 to Mon 11/30/2020
 0100 1900

Work scheduled by:

FWD
 (Import)
 SCH - HQ_CEDARS **90 MW**
 Impacts Total Transfer Capability 109 MW
 TTC with All Lines In Service 199 MW

STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1

Sun 11/15/2020 to Mon 11/30/2020
 0100 1900

Work scheduled by:

FWD
 (Import)
 SCH - HQ_CEDARS **90 MW**
 Impacts Total Transfer Capability 109 MW
 TTC with All Lines In Service 199 MW

STLAWRNC-MOSES 230_L33P & MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2

Sun 11/15/2020 to Mon 11/30/2020
 0100 1900

Work scheduled by:

FWD
 (Import)
 SCH - HQ_CEDARS **90 MW**
 Impacts Total Transfer Capability 109 MW
 TTC with All Lines In Service 199 MW

PLSNTVLE-DUNWODIE_345_W89

Mon 11/16/2020 to Mon 11/16/2020
 0001 Continuous 0030

Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 1700 MW
 TTC with All Lines In Service 5700 MW

PLSNTVLE-DUNWODIE_345_W89

Thu 11/26/2020 to Thu 11/26/2020
 0230 Continuous 0300

Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 1700 MW
 TTC with All Lines In Service 5700 MW

MOSES -ADIRNDCK_230_MA1

Tue 12/01/2020 to Mon 05/31/2021
 0700 Continuous 1300

Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

SAND_BAR-PLATSBRG_115_PV20

Mon 12/07/2020 to Fri 12/11/2020
 0700 Continuous 1530

Work scheduled by: NYPA

SCH - NE - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Monday ,January 27, 2020 to Wednesday,July 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SAND_BAR-PLATSBURG_115_PV20

Mon 12/14/2020 to Fri 12/18/2020
 0700 Continuous 1530
 Work scheduled by: NYPA

SCH - NE - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

HOPATCON-RAMAPO__500_5018

Mon 02/01/2021 to Wed 02/03/2021
 0001 Continuous 2200
 Work scheduled by: ConEd

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	1250 MW	1200 MW
Impacts Total Transfer Capability	1650 MW	650 MW
TTC with All Lines In Service	2900 MW	1850 MW

HOPATCON-RAMAPO__500_5018

Mon 02/01/2021 to Wed 02/03/2021
 0001 Continuous 2200
 Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	5000 MW
Impacts Total Transfer Capability	700 MW
TTC with All Lines In Service	5700 MW

RAMAPO__345_345_PAR3500

Mon 02/01/2021 to Wed 02/03/2021
 0001 Continuous 2200
 Work scheduled by: ConEd

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2150 MW	1250 MW
Impacts Total Transfer Capability	750 MW	600 MW
TTC with All Lines In Service	2900 MW	1850 MW

RAMAPO__345_345_PAR4500

Mon 02/01/2021 to Wed 02/03/2021
 0001 Continuous 2200
 Work scheduled by: ConEd

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2150 MW	1250 MW
Impacts Total Transfer Capability	750 MW	600 MW
TTC with All Lines In Service	2900 MW	1850 MW

RAMAPO__500_345_BK 1500

Mon 02/01/2021 to Wed 02/03/2021
 0001 Continuous 2200
 Work scheduled by: ConEd

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	1250 MW	1200 MW
Impacts Total Transfer Capability	1650 MW	650 MW
TTC with All Lines In Service	2900 MW	1850 MW

RAMAPO__500_345_BK 1500

Mon 02/01/2021 to Wed 02/03/2021
 0001 Continuous 2200
 Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	5000 MW
Impacts Total Transfer Capability	700 MW
TTC with All Lines In Service	5700 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 27, 2020 to Wednesday,July 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_3

Mon 03/01/2021 to Mon 03/01/2021
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_5

Mon 03/01/2021 to Mon 03/01/2021
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

EASTVIEW-SPRNBK__345_W64

Mon 03/01/2021 to Mon 03/01/2021 **UPDATED by CONED 01/23/2020**
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

SPRNBK__345KV_RNS5

Mon 03/01/2021 to Mon 03/01/2021 **UPDATED by CONED 01/23/2020**
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

MILLWOOD-EASTVIEW_345_W99

Mon 03/01/2021 to Mon 03/22/2021 **UPDATED by CONED 01/23/2020**
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

DUNWODIE-MOTTHAVN_345_71

Mon 03/01/2021 to Mon 04/05/2021
 0001 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

MOTTHAVN-RAINEY__345_Q11

Mon 03/01/2021 to Tue 04/06/2021
 0001 Continuous 0700
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 27, 2020 to Wednesday,July 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EASTVIEW-SPRNBK__345_W64					FWD	
Mon 03/22/2021	to	Mon 03/22/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>01/23/2020</u>	(Import)
0130	Continuous	0200				UPNY CONED 4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1350 MW
					TTC with All Lines In Service	5700 MW
SPRNBK__345KV_RNS5					FWD	
Mon 03/22/2021	to	Mon 03/22/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>01/23/2020</u>	(Import)
0130	Continuous	0200				SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
CLAY__-EDIC__345_2-15					FWD	
Mon 03/29/2021	to	Fri 04/16/2021				(Import)
0800	Continuous	1730				OSWEGO EXPORT 4850 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	400 MW
					TTC with All Lines In Service	5250 MW
DUNWODIE_345KV_3					FWD	
Mon 04/05/2021	to	Mon 04/05/2021				(Import)
0230	Continuous	0300				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_5					FWD	
Mon 04/05/2021	to	Mon 04/05/2021				(Import)
0230	Continuous	0300				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
SCH-IMO-NYISO_LIMIT_1600					FWD	
Sat 05/01/2021	to	Sun 10/31/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Import)
0001	Continuous	2359				SCH - OH - NY 1900 MW
Work scheduled by: IESO					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	1900 MW
PANNELL_-CLAY__345_2					FWD	
Mon 05/03/2021	to	Fri 05/28/2021				(Import)
0700	Continuous	1730				WEST CENTRAL 1300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	950 MW
					TTC with All Lines In Service	2250 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 27, 2020 to Wednesday,July 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA2

FWD

Tue 06/01/2021 to Sun 11/14/2021
 0700 Continuous 1300

(Import)

Work scheduled by: NYPA

MOSES SOUTH **2100 MW**
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW