

# NYISO TRANSFER LIMITATIONS

Monday ,May 25, 2020 to Wednesday,November 24, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					FWD	REV
<b>HUDSONP_-FARRAGUT_345_B3402</b>					(Import)	(Export)
Mon 01/15/2018	to	Thu 10/01/2020	<u><b>EXTENDED</b></u>	<u><b>by CONED</b></u>	<u><b>05/03/2020</b></u>	
0001	Continuous	2359				
Work scheduled by: ConEd					SCH - PJ - NY	<b>2100 MW</b>
					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	2150 MW
<hr/>					FWD	REV
<b>HUDSONP_-FARRAGUT_345_B3402 &amp; MARION_-FARRAGUT_345_C3403</b>					(Import)	(Export)
Mon 01/15/2018	to	Thu 10/01/2020				
0001		2359				
Work scheduled by:					SCH - PJ - NY	<b>2050 MW</b>
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	2150 MW
<hr/>					FWD	REV
<b>MARION_-FARRAGUT_345_C3403</b>					(Import)	(Export)
Mon 01/15/2018	to	Thu 10/01/2020	<u><b>EXTENDED</b></u>	<u><b>by CONED</b></u>	<u><b>05/03/2020</b></u>	
0001	Continuous	2359				
Work scheduled by: ConEd					SCH - PJ - NY	<b>2100 MW</b>
					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	2150 MW
<hr/>					FWD	REV
<b>STLAWRNC-MOSES_230_L33P</b>					(Import)	(Export)
Mon 04/30/2018	to	Fri 12/31/2021	<u><b>EXT FORCE</b></u>	<u><b>by IESO</b></u>	<u><b>08/21/2018</b></u>	
0456	Continuous	2359				
Work scheduled by: IESO					SCH - OH - NY	
					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
<hr/>					FWD	REV
<b>HURLYAVE-ROSETON_345_303</b>					(Import)	REV
Mon 04/27/2020	to	Thu 05/21/2020	<u><b>UPDATED</b></u>	<u><b>by CHGE</b></u>	<u><b>10/09/2019</b></u>	
0800	Continuous	1545				
Work scheduled by: CHGE					UPNY CONED	<b>4100 MW</b>
					Impacts Total Transfer Capability	2120 MW
					TTC with All Lines In Service	6220 MW
<hr/>					FWD	REV
<b>SCH-IMO-NYISO_LIMIT_1600</b>					(Import)	REV
Fri 05/01/2020	to	Sat 10/31/2020	<u><b>UPDATED</b></u>	<u><b>by IESO</b></u>	<u><b>05/03/2019</b></u>	
0001	Continuous	2359				
Work scheduled by: IESO					SCH - OH - NY	<b>1900 MW</b>
					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	1900 MW
<hr/>					FWD	REV
<b>MOSES_-ADIRNDCK_230_MA2</b>					(Import)	REV
Mon 05/04/2020	to	Sun 09/13/2020	<u><b>UPDATED</b></u>	<u><b>by NYPA</b></u>	<u><b>04/20/2020</b></u>	
0700	Continuous	1730				
Work scheduled by: NYPA					MOSES SOUTH	<b>2100 MW</b>
					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Monday ,May 25, 2020 to Wednesday, November 24, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>E13THSTA-FARRAGUT_345_45</b>					FWD	
Sun 05/10/2020	to	Fri 05/29/2020	<u>EXTENDED</u>	<u>by CONED</u>	<u>05/20/2020</u>	(Import)
0001	Continuous	2359				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>W49TH_ST-E13THSTA_345_M54</b>					FWD	
Mon 05/11/2020	to	Fri 05/29/2020	<u>EXTENDED</u>	<u>by CONED</u>	<u>05/20/2020</u>	(Import)
0842	Continuous	2359				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>EGRDNCTY_345_138_AT1</b>					FWD	
Mon 05/18/2020	to	Sat 05/23/2020				(Import)
0001	Continuous	0200				CONED - LIPA <b>1250 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability	250 MW
					TTC with All Lines In Service	1500 MW
<b>EGRDNCTY_345_138_AT2</b>					FWD	
Mon 05/18/2020	to	Sat 05/23/2020				(Import)
0001	Continuous	0200				CONED - LIPA <b>1250 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability	250 MW
					TTC with All Lines In Service	1500 MW
<b>SPRNBK_-EGRDNCTR_345_Y49</b>					FWD	
Mon 05/18/2020	to	Sat 05/23/2020				(Import)
0001	Continuous	0200				CONED - LIPA <b>775 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability	725 MW
					TTC with All Lines In Service	1500 MW
<b>SCH-NE-NYISO_LIMIT_500</b>					FWD	
Mon 05/18/2020	to	Fri 05/29/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>05/14/2020</u>	(Import)
0700	Daily	2259				SCH - NE - NY <b>700 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability	700 MW
					TTC with All Lines In Service	1400 MW
<b>SCH-NYISO-NE_LIMIT_700</b>					FWD	
Mon 05/18/2020	to	Fri 05/29/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>05/14/2020</u>	REV (Export)
0700	Daily	2259				SCH - NE - NY <b>900 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability	700 MW
					TTC with All Lines In Service	1600 MW

# NYISO TRANSFER LIMITATIONS

Monday ,May 25, 2020 to Wednesday, November 24, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
<b>BERKSHIR-ALPS</b>	<b>345_393</b>						
Mon 05/18/2020	to	Sat 05/30/2020	<b>UPDATED</b>	<b>by ISONE</b>	<b>05/14/2020</b>		
0700	Continuous	1700				SCH - NE - NY	<b>950 MW</b>
Work scheduled by: ISONE						Impacts Total Transfer Capability	450 MW
						TTC with All Lines In Service	1400 MW
							1600 MW
<b>BERKSHIR-ALPS</b>	<b>345_393</b>						
Mon 05/18/2020	to	Sat 05/30/2020	<b>UPDATED</b>	<b>by ISONE</b>	<b>05/14/2020</b>		
0700	Continuous	1700				SCH - NPX_1385	<b>100 MW</b>
Work scheduled by: ISONE						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
							200 MW
<b>FRASER - COOPERS</b>	<b>345_33</b>						
Mon 05/18/2020	to	Wed 05/20/2020	<b>UPDATED</b>	<b>by NYSEG</b>	<b>05/13/2020</b>		
0730	Continuous	1500				CENTRAL EAST - VC	<b>2395 MW</b>
Work scheduled by: NYSEG						Impacts Total Transfer Capability	580 MW
						TTC with All Lines In Service	2975 MW
<b>HOPATCON-RAMAPO</b>	<b>500_5018</b>						
Mon 05/18/2020	to	Fri 05/22/2020	<b>FORCED</b>	<b>by CONED</b>	<b>05/18/2020</b>		
1531	Continuous	2359				SCH - PJ - NY	<b>1150 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	1000 MW
						TTC with All Lines In Service	2150 MW
							1350 MW
<b>HOPATCON-RAMAPO</b>	<b>500_5018</b>						
Mon 05/18/2020	to	Fri 05/22/2020	<b>FORCED</b>	<b>by CONED</b>	<b>05/18/2020</b>		
1531	Continuous	2359				UPNY CONED	<b>6025 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	195 MW
						TTC with All Lines In Service	6220 MW
<b>RAMAPO</b>	<b>500_345_BK 1500</b>						
Mon 05/18/2020	to	Fri 05/22/2020	<b>FORCED</b>	<b>by CONED</b>	<b>05/18/2020</b>		
1531	Continuous	2359				SCH - PJ - NY	<b>1150 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	1000 MW
						TTC with All Lines In Service	2150 MW
							1350 MW
<b>RAMAPO</b>	<b>500_345_BK 1500</b>						
Mon 05/18/2020	to	Fri 05/22/2020	<b>FORCED</b>	<b>by CONED</b>	<b>05/18/2020</b>		
1531	Continuous	2359				UPNY CONED	<b>6025 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	195 MW
						TTC with All Lines In Service	6220 MW

# NYISO TRANSFER LIMITATIONS

Monday ,May 25, 2020 to Wednesday, November 24, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>RAMAPO___345_345_PAR3500</b>					FWD	REV
Mon 05/18/2020	to	Fri 05/22/2020	<b><u>FORCED</u></b>	<b><u>by CONED</u></b>	<b><u>05/18/2020</u></b>	(Import) (Export)
1606	Continuous	2359				<b>1800 MW 1250 MW</b>
Work scheduled by: ConEd					SCH - PJ - NY	
					Impacts Total Transfer Capability	350 MW 100 MW
					TTC with All Lines In Service	2150 MW 1350 MW
<b>RAMAPO___345_345_PAR4500</b>					FWD	REV
Mon 05/18/2020	to	Fri 05/22/2020	<b><u>FORCED</u></b>	<b><u>by CONED</u></b>	<b><u>05/18/2020</u></b>	(Import) (Export)
1606	Continuous	2359				<b>1800 MW 1250 MW</b>
Work scheduled by: ConEd					SCH - PJ - NY	
					Impacts Total Transfer Capability	350 MW 100 MW
					TTC with All Lines In Service	2150 MW 1350 MW
<b>SCH-NYISO-NE_LIMIT_500</b>						REV
Mon 05/18/2020	to	Sat 05/30/2020	<b><u>UPDATED</u></b>	<b><u>by ISONE</u></b>	<b><u>05/14/2020</u></b>	(Export)
2300	Daily	0659				<b>700 MW</b>
Work scheduled by: ISONE					SCH - NE - NY	
					Impacts Total Transfer Capability	900 MW
					TTC with All Lines In Service	1600 MW
<b>MARCY___345KV_CSC</b>					FWD	
Sat 05/23/2020	to	Sat 05/23/2020				(Import)
0600	Continuous	1830				<b>2925 MW</b>
Work scheduled by: NYPA					CENTRAL EAST - VC	
					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	2975 MW
<b>SPRNBK_-TREMONT__345_X28</b>					FWD	
Sun 05/24/2020	to	Sun 05/24/2020	<b><u>UPDATED</u></b>	<b><u>by CONED</u></b>	<b><u>05/11/2020</u></b>	(Import)
0001	Continuous	1800				<b>4200 MW</b>
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	400 MW
					TTC with All Lines In Service	4600 MW
<b>LINDN_CG-LNDVFT__345_V-3022</b>					FWD	REV
Sun 05/24/2020	to	Sat 05/30/2020	<b><u>UPDATED</u></b>	<b><u>by PJM</u></b>	<b><u>02/28/2020</u></b>	(Import) (Export)
1400	Continuous	1400				<b>0 MW 0 MW</b>
Work scheduled by: PJM					SCH - PJM_VFT	
					Impacts Total Transfer Capability	315 MW 315 MW
					TTC with All Lines In Service	315 MW 315 MW
<b>MILLWOOD_345KV_18</b>					FWD	
Thu 05/28/2020	to	Thu 05/28/2020	<b><u>UPDATED</u></b>	<b><u>by CONED</u></b>	<b><u>04/09/2020</u></b>	(Import)
0400	Continuous	0430				<b>4350 MW</b>
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	1870 MW
					TTC with All Lines In Service	6220 MW

# NYISO TRANSFER LIMITATIONS

Monday ,May 25, 2020 to Wednesday,November 24, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**LEEDS\_\_\_345KV\_R395**

Thu 05/28/2020 to Thu 06/11/2020  
 0700 Continuous 1800  
 Work scheduled by: NGrid

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 2420 MW  
 TTC with All Lines In Service 6220 MW

**INDDNCE-SCRIBA\_\_\_345\_25**

Thu 05/28/2020 to Thu 05/28/2020  
 0800 Daily(No Weekends) 1630  
 Work scheduled by: NGrid

FWD  
 (Import)  
 OSWEGO EXPORT **5250 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 5250 MW

**SCH-NE-NYISO\_LIMIT\_500**

Sat 05/30/2020 to Sat 05/30/2020 **UPDATED by ISONE 05/14/2020**  
 0700 Daily 1700  
 Work scheduled by: ISONE

FWD  
 (Import)  
 SCH - NE - NY **700 MW**  
 Impacts Total Transfer Capability 700 MW  
 TTC with All Lines In Service 1400 MW

**SCH-NYISO-NE\_LIMIT\_700**

Sat 05/30/2020 to Sat 05/30/2020 **UPDATED by ISONE 05/14/2020**  
 0700 Daily 1700  
 Work scheduled by: ISONE

REV  
 (Export)  
 SCH - NE - NY **900 MW**  
 Impacts Total Transfer Capability 700 MW  
 TTC with All Lines In Service 1600 MW

**BERKSHIR-ALPS\_\_\_345\_393 & BERKSHIR-NORTHFLD\_345\_312**

Sat 05/30/2020 to Sat 05/30/2020  
 1500 1700  
 Work scheduled by: **ARR: 78**

FWD REV  
 (Import) (Export)  
 SCH - NE - NY **950 MW 1300 MW**  
 Impacts Total Transfer Capability 450 MW 300 MW  
 TTC with All Lines In Service 1400 MW 1600 MW

**BERKSHIR-NORTHFLD\_345\_312**

Sat 05/30/2020 to Sat 05/30/2020 **UPDATED by ISONE 05/14/2020**  
 1500 Continuous 1700  
 Work scheduled by: ISONE

FWD REV  
 (Import) (Export)  
 SCH - NE - NY **900 MW 1500 MW**  
 Impacts Total Transfer Capability 500 MW 100 MW  
 TTC with All Lines In Service 1400 MW 1600 MW

**BERKSHIR-NORTHFLD\_345\_312**

Sat 05/30/2020 to Sat 05/30/2020 **UPDATED by ISONE 05/14/2020**  
 1500 Continuous 1700  
 Work scheduled by: ISONE

FWD REV  
 (Import) (Export)  
 SCH - NPX\_1385 **100 MW 100 MW**  
 Impacts Total Transfer Capability 100 MW 100 MW  
 TTC with All Lines In Service 200 MW 200 MW

# NYISO TRANSFER LIMITATIONS

Monday ,May 25, 2020 to Wednesday,November 24, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						FWD	REV
<b>SCH-NYISO-IMO_NIAGARA_CB_3002</b>						(Import)	(Export)
Mon 06/01/2020	to	Tue 06/02/2020	<b>UPDATED</b>	<b>by NYPA</b>	<b>05/20/2020</b>		
0500	Continuous	1700				<b>SCH - OH - NY</b>	<b>1300 MW 1150 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	600 MW 550 MW
						TTC with All Lines In Service	1900 MW 1700 MW
<hr/>						FWD	REV
<b>SHOR_NPX-SHOREHAM_138_CSC</b>						(Import)	(Export)
Mon 06/01/2020	to	Tue 06/02/2020	<b>UPDATED</b>	<b>by ISONE</b>	<b>03/04/2020</b>		
0501	Continuous	2330				<b>SCH - NPX_CSC</b>	<b>0 MW 0 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability	330 MW 330 MW
						TTC with All Lines In Service	330 MW 330 MW
<hr/>						FWD	
<b>STONYRDG-HILLSIDE_230_72</b>						(Import)	
Mon 06/01/2020	to	Mon 06/01/2020				<b>DYSINGER EAST</b>	<b>2850 MW</b>
0800	Continuous	1530				Impacts Total Transfer Capability	300 MW
Work scheduled by: NYSEG						TTC with All Lines In Service	3150 MW
<hr/>						FWD	
<b>S.RIPLEY-DUNKIRK__230_68</b>						(Import)	
Mon 06/01/2020	to	Sat 06/06/2020				<b>SCH - PJ - NY</b>	<b>2000 MW</b>
1700	Continuous	1700				Impacts Total Transfer Capability	150 MW
Work scheduled by: PJM						TTC with All Lines In Service	2150 MW
<hr/>						FWD	REV
<b>SCH-IMO_NY_NIAG_CB_3122_W/BB</b>						(Import)	(Export)
Wed 06/03/2020	to	Thu 06/04/2020				<b>SCH - OH - NY</b>	<b>1700 MW 1400 MW</b>
0500	Continuous	1700				Impacts Total Transfer Capability	200 MW 300 MW
Work scheduled by: NYPA						TTC with All Lines In Service	1900 MW 1700 MW
<hr/>						FWD	
<b>ROCHESTR-PANNELL__345_RP1</b>						(Import)	
Wed 06/03/2020	to	Fri 06/05/2020				<b>DYSINGER EAST</b>	<b>2300 MW</b>
0800	Continuous	1500				Impacts Total Transfer Capability	850 MW
Work scheduled by: RGE						TTC with All Lines In Service	3150 MW
<hr/>						FWD	REV
<b>SCH-NYISO-IMO_NIAGARA_CB_3108</b>							(Export)
Fri 06/05/2020	to	Fri 06/05/2020				<b>SCH - OH - NY</b>	<b>1500 MW</b>
0500	Continuous	1530				Impacts Total Transfer Capability	200 MW
Work scheduled by: NYPA						TTC with All Lines In Service	1700 MW

# NYISO TRANSFER LIMITATIONS

Monday ,May 25, 2020 to Wednesday, November 24, 2021

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p><b>OSWEGO_COMPLEX_AVR_O/S</b></p> <p>Sun 06/07/2020 to Sun 06/07/2020</p> <p style="padding-left: 40px;">0900 Continuous 0930</p> <p>Work scheduled by: Gen</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>CENTRAL EAST - VC <b>2870 MW</b></p> <p>Impacts Total Transfer Capability 105 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p><b>FROST_BR-LONG_MTN_345_352</b></p> <p>Mon 06/08/2020 to Fri 06/26/2020</p> <p style="padding-left: 40px;">0700 Continuous 1600</p> <p>Work scheduled by: ISONE</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>SCH - NE - NY <b>1150 MW</b></p> <p>Impacts Total Transfer Capability 250 MW</p> <p>TTC with All Lines In Service 1400 MW</p>
<p><b>SCH-NE-NYISO_LIMIT_300</b></p> <p>Mon 06/08/2020 to Fri 06/26/2020</p> <p style="padding-left: 40px;">0700 Continuous 1600</p> <p>Work scheduled by: ISONE</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>SCH - NE - NY <b>500 MW</b></p> <p>Impacts Total Transfer Capability 900 MW</p> <p>TTC with All Lines In Service 1400 MW</p>
<p><b>ROCHESTR-PANNELL_345_RP2</b></p> <p>Mon 06/08/2020 to Wed 06/10/2020</p> <p style="padding-left: 40px;">0800 Continuous 1500</p> <p>Work scheduled by: RGE</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>DYSINGER EAST <b>2300 MW</b></p> <p>Impacts Total Transfer Capability 850 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p><b>HOPATCON-RAMAPO_500_5018</b></p> <p>Fri 06/12/2020 to Fri 06/12/2020 <b>UPDATED by CONED 04/17/2020</b></p> <p style="padding-left: 40px;">0001 Continuous 2200</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD REV</p> <p style="text-align: right;">(Import) (Export)</p> <p>SCH - PJ - NY <b>1150 MW 1000 MW</b></p> <p>Impacts Total Transfer Capability 1000 MW 350 MW</p> <p>TTC with All Lines In Service 2150 MW 1350 MW</p>
<p><b>HOPATCON-RAMAPO_500_5018</b></p> <p>Fri 06/12/2020 to Fri 06/12/2020 <b>UPDATED by CONED 04/17/2020</b></p> <p style="padding-left: 40px;">0001 Continuous 2200</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>UPNY CONED <b>6025 MW</b></p> <p>Impacts Total Transfer Capability 195 MW</p> <p>TTC with All Lines In Service 6220 MW</p>
<p><b>RAMAPO_345_345_PAR3500</b></p> <p>Fri 06/12/2020 to Fri 06/12/2020 <b>UPDATED by CONED 04/17/2020</b></p> <p style="padding-left: 40px;">0001 Continuous 2200</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD REV</p> <p style="text-align: right;">(Import) (Export)</p> <p>SCH - PJ - NY <b>1800 MW 1250 MW</b></p> <p>Impacts Total Transfer Capability 350 MW 100 MW</p> <p>TTC with All Lines In Service 2150 MW 1350 MW</p>

# NYISO TRANSFER LIMITATIONS

Monday ,May 25, 2020 to Wednesday,November 24, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Transfer ID	Start Date	End Date	Time	Work Scheduled by	Update Info	SCH	FWD (Import)	REV (Export)	
<b>RAMAPO__345_345_PAR4500</b>	Fri 06/12/2020	Fri 06/12/2020	0001 Continuous 2200	ConEd	<u>UPDATED</u> <u>by CONED</u> <u>04/17/2020</u>	SCH - PJ - NY	1800 MW	1250 MW	
							Impacts Total Transfer Capability	350 MW	100 MW
							TTC with All Lines In Service	2150 MW	1350 MW
<b>RAMAPO__500_345_BK 1500</b>	Fri 06/12/2020	Fri 06/12/2020	0001 Continuous 2200	ConEd	<u>UPDATED</u> <u>by CONED</u> <u>04/17/2020</u>	SCH - PJ - NY	1150 MW	1000 MW	
							Impacts Total Transfer Capability	1000 MW	350 MW
							TTC with All Lines In Service	2150 MW	1350 MW
<b>RAMAPO__500_345_BK 1500</b>	Fri 06/12/2020	Fri 06/12/2020	0001 Continuous 2200	ConEd	<u>UPDATED</u> <u>by CONED</u> <u>04/17/2020</u>	UPNY CONED	6025 MW		
							Impacts Total Transfer Capability	195 MW	
							TTC with All Lines In Service	6220 MW	
<b>W49TH_ST-E13THSTA_345_M55</b>	Sat 06/13/2020	Sun 06/14/2020	0001 Continuous 0200	ConEd		SPR/DUN-SOUTH	3800 MW		
							Impacts Total Transfer Capability	800 MW	
							TTC with All Lines In Service	4600 MW	
<b>W49TH_ST_345KV_6</b>	Sat 06/13/2020	Sun 06/14/2020	0001 Continuous 0200	ConEd		SCH - PJM_HTP	300 MW		
							Impacts Total Transfer Capability	360 MW	
							TTC with All Lines In Service	660 MW	
<b>BUCHAN_N-EASTVIEW_345_W93</b>	Sun 06/14/2020	Sun 06/14/2020	0001 Continuous 0030	ConEd	<u>UPDATED</u> <u>by CONED</u> <u>04/28/2020</u>	UPNY CONED	4350 MW		
							Impacts Total Transfer Capability	1870 MW	
							TTC with All Lines In Service	6220 MW	
<b>RAMAPO__-BUCHAN_N_345_Y94</b>	Sun 06/14/2020	Sun 06/14/2020	0001 Continuous 0030	ConEd	<u>UPDATED</u> <u>by CONED</u> <u>04/28/2020</u>	UPNY CONED	5765 MW		
							Impacts Total Transfer Capability	455 MW	
							TTC with All Lines In Service	6220 MW	



# NYISO TRANSFER LIMITATIONS

Monday ,May 25, 2020 to Wednesday, November 24, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Transfer ID	Start Date	End Date	Time	Work by	Zone	Direction	Capacity (MW)	TTC (MW)
CHAT_DC_GC1	Sun 06/14/2020	Sun 06/14/2020	0001 - 0200	HQ	MOSES SOUTH	FWD (Import)	2850 MW	3150 MW
							Impacts Total Transfer Capability	300 MW
							TTC with All Lines In Service	3150 MW
CHAT_DC_GC1	Sun 06/14/2020	Sun 06/14/2020	0001 - 0200	HQ	SCH - HQ - NY	REV (Export)	500 MW	1000 MW
							Impacts Total Transfer Capability	500 MW
							TTC with All Lines In Service	1000 MW
CHAT_DC_GC1 & CHAT_DC_GC2	Sun 06/14/2020	Sun 06/14/2020	0001 - 0200		MOSES SOUTH	FWD (Import)	2550 MW	3150 MW
							Impacts Total Transfer Capability	600 MW
							TTC with All Lines In Service	3150 MW
CHAT_DC_GC1 & CHAT_DC_GC2	Sun 06/14/2020	Sun 06/14/2020	0001 - 0200		SCH - HQ - NY	FWD (Import) / REV (Export)	1370 MW / 0 MW	1000 MW
							Impacts Total Transfer Capability	130 MW / 1000 MW
							TTC with All Lines In Service	1500 MW / 1000 MW
CHAT_DC_GC2	Sun 06/14/2020	Sun 06/14/2020	0001 - 0200	HQ	MOSES SOUTH	FWD (Import)	2850 MW	3150 MW
							Impacts Total Transfer Capability	300 MW
							TTC with All Lines In Service	3150 MW
CHAT_DC_GC2	Sun 06/14/2020	Sun 06/14/2020	0001 - 0200	HQ	SCH - HQ - NY	REV (Export)	500 MW	1000 MW
							Impacts Total Transfer Capability	500 MW
							TTC with All Lines In Service	1000 MW
SCH-HQ-NYISO_LIMIT_1150	Sun 06/14/2020	Sun 06/14/2020	0001 - 0200	HQ	SCH - HQ - NY	FWD (Import)	1150 MW	1500 MW
							Impacts Total Transfer Capability	350 MW
							TTC with All Lines In Service	1500 MW

# NYISO TRANSFER LIMITATIONS

Monday ,May 25, 2020 to Wednesday, November 24, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BUCHAN_N-EASTVIEW_345_W93</b>				FWD
Sun 06/14/2020	to	Sun 06/14/2020	<u>UPDATED</u> <u>by CONED</u> <u>04/28/2020</u>	(Import)
1030	Continuous	1100	UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 1870 MW
				TTC with All Lines In Service 6220 MW
<b>RAMAPO_-BUCHAN_N_345_Y94</b>				FWD
Sun 06/14/2020	to	Sun 06/14/2020	<u>UPDATED</u> <u>by CONED</u> <u>04/28/2020</u>	(Import)
1030	Continuous	1100	UPNY CONED	<b>5765 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 455 MW
				TTC with All Lines In Service 6220 MW
<b>ROSETON_-EFISHKIL_345_RFK305</b>				FWD
Mon 06/15/2020	to	Mon 06/15/2020		(Import)
0700	Daily	1600	UPNY CONED	<b>5990 MW</b>
Work scheduled by: CHGE				Impacts Total Transfer Capability 230 MW
				TTC with All Lines In Service 6220 MW
<b>SPRNBRK_-W49TH_ST_345_M51</b>				FWD
Sat 06/27/2020	to	Mon 06/29/2020		(Import)
0001	Continuous	0300	SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW
<b>SPRNBRK__345KV_RNS5</b>				FWD
Sat 06/27/2020	to	Mon 06/29/2020		(Import)
0001	Continuous	0300	SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW
<b>CHAT_DC_GC1</b>				FWD
Sun 06/28/2020	to	Sun 06/28/2020		(Import)
0001	Continuous	0200	MOSES SOUTH	<b>2850 MW</b>
Work scheduled by: HQ				Impacts Total Transfer Capability 300 MW
				TTC with All Lines In Service 3150 MW
<b>CHAT_DC_GC1</b>				REV
Sun 06/28/2020	to	Sun 06/28/2020		(Export)
0001	Continuous	0200	SCH - HQ - NY	<b>500 MW</b>
Work scheduled by: HQ				Impacts Total Transfer Capability 500 MW
				TTC with All Lines In Service 1000 MW

# NYISO TRANSFER LIMITATIONS

Monday ,May 25, 2020 to Wednesday, November 24, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Transfer Capability	Start Date	End Date	Time	Work Scheduled by	Zone	FWD (Import)	REV (Export)
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>							
Sun 06/28/2020	to	Sun 06/28/2020	0001 to 0200	Work scheduled by:	MOSES SOUTH	2550 MW	
Impacts Total Transfer Capability						600 MW	
TTC with All Lines In Service						3150 MW	
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>							
Sun 06/28/2020	to	Sun 06/28/2020	0001 to 0200	Work scheduled by:	SCH - HQ - NY	1370 MW	0 MW
Impacts Total Transfer Capability						130 MW	1000 MW
TTC with All Lines In Service						1500 MW	1000 MW
<b>CHAT_DC_GC2</b>							
Sun 06/28/2020	to	Sun 06/28/2020	0001 Continuous to 0200	Work scheduled by: HQ	MOSES SOUTH	2850 MW	
Impacts Total Transfer Capability						300 MW	
TTC with All Lines In Service						3150 MW	
<b>CHAT_DC_GC2</b>							
Sun 06/28/2020	to	Sun 06/28/2020	0001 Continuous to 0200	Work scheduled by: HQ	SCH - HQ - NY		500 MW
Impacts Total Transfer Capability							500 MW
TTC with All Lines In Service							1000 MW
<b>SCH-HQ-NYISO_LIMIT_1150</b>							
Sun 06/28/2020	to	Sun 06/28/2020	0001 Continuous to 0200	Work scheduled by: HQ	SCH - HQ - NY	1150 MW	
Impacts Total Transfer Capability						350 MW	
TTC with All Lines In Service						1500 MW	
<b>NIAGARA_345_230_AT4</b>							
Mon 06/29/2020	to	Tue 06/30/2020	0500 Continuous to 1530	Work scheduled by: NYPA	SCH - OH - NY		1400 MW
Impacts Total Transfer Capability							300 MW
TTC with All Lines In Service							1700 MW
<b>PORTER_-ROTTDAM_230_31</b>							
Tue 07/07/2020	to	Tue 07/07/2020	0830 Daily(No Weekends) to 1130	Work scheduled by: NGrid	CENTRAL EAST - VC	2805 MW	
Impacts Total Transfer Capability						170 MW	
TTC with All Lines In Service						2975 MW	

# NYISO TRANSFER LIMITATIONS

Monday ,May 25, 2020 to Wednesday,November 24, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO-NYISO_NIAG_CB_3008_W/BB				FWD	REV
				(Import)	(Export)
Mon 07/27/2020	to	Fri 08/07/2020			
0500	Continuous	1530			
Work scheduled by: NYPA					
				SCH - OH - NY	<b>1900 MW</b>
				Impacts Total Transfer Capability	0 MW
				TTC with All Lines In Service	1900 MW
					1700 MW
SAND_BAR-PLATSBURG_115_PV20					
Sun 08/09/2020	to	Sun 08/16/2020			
0800	Daily	1600			
Work scheduled by: ISONE					
				SCH - NE - NY	
				Impacts Total Transfer Capability	
				TTC with All Lines In Service	
SAND_BAR-PLATSBURG_115_PV20					
Sat 08/22/2020	to	Sat 08/29/2020			
0800	Daily	1600			
Work scheduled by: ISONE					
				SCH - NE - NY	
				Impacts Total Transfer Capability	
				TTC with All Lines In Service	
MEYER___-CANANDGA_230_60				FWD	
				(Import)	
Thu 09/10/2020	to	Thu 09/10/2020			
0730	Continuous	1630			
Work scheduled by: NYSEG					
				DYSINGER EAST	<b>2850 MW</b>
				Impacts Total Transfer Capability	300 MW
				TTC with All Lines In Service	3150 MW
MARCY___765_345_AT1				FWD	
				(Import)	
Mon 09/14/2020	to	Mon 09/14/2020	<b>UPDATED</b>	<b>by NYPA</b>	<b>03/31/2020</b>
0500	Continuous	1730			
Work scheduled by: NYPA					
				MOSES SOUTH	<b>1750 MW</b>
				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	3150 MW
NIAGARA_-KINTIGH_345_NS1-38				FWD	
				(Import)	
Mon 09/14/2020	to	Thu 09/17/2020			
0500	Continuous	1530			
Work scheduled by: NYPA					
				DYSINGER EAST	<b>1400 MW</b>
				Impacts Total Transfer Capability	1750 MW
				TTC with All Lines In Service	3150 MW
BRANCHBG-HOPATCON_500_5060				FWD	
				(Import)	
Tue 09/15/2020	to	Wed 09/16/2020	<b>UPDATED</b>	<b>by PJM</b>	<b>04/20/2020</b>
0200	Continuous	2300			
Work scheduled by: PJM					
				UPNY CONED	<b>6025 MW</b>
				Impacts Total Transfer Capability	195 MW
				TTC with All Lines In Service	6220 MW

# NYISO TRANSFER LIMITATIONS

Monday ,May 25, 2020 to Wednesday,November 24, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES -ADIRNDCK\_230\_MA2**

Tue 09/15/2020 to Sat 11/14/2020  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
**MOSES SOUTH 2100 MW**  
 Impacts Total Transfer Capability 1050 MW  
 TTC with All Lines In Service 3150 MW

**NIAGARA -ROCHESTR\_345\_NR2**

Fri 09/18/2020 to Sat 11/14/2020  
 0500 Continuous 2330  
 Work scheduled by: NYPA

FWD  
 (Import)  
**DYSINGER EAST 1400 MW**  
 Impacts Total Transfer Capability 1750 MW  
 TTC with All Lines In Service 3150 MW

**EASTVIEW-SPRNBRK\_345\_W65**

Sat 09/19/2020 to Sat 09/19/2020  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
**UPNY CONED 4350 MW**  
 Impacts Total Transfer Capability 1870 MW  
 TTC with All Lines In Service 6220 MW

**MILLWOOD-EASTVIEW\_345\_W82**

Sat 09/19/2020 to Sat 09/19/2020  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
**UPNY CONED 5985 MW**  
 Impacts Total Transfer Capability 235 MW  
 TTC with All Lines In Service 6220 MW

**SPRNBRK\_345KV\_RNS4**

Sat 09/19/2020 to Sat 09/19/2020  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
**SPR/DUN-SOUTH 3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

**EASTVIEW-SPRNBRK\_345\_W65**

Sat 09/19/2020 to Sat 09/19/2020  
 0330 Continuous 0400  
 Work scheduled by: ConEd

FWD  
 (Import)  
**UPNY CONED 4350 MW**  
 Impacts Total Transfer Capability 1870 MW  
 TTC with All Lines In Service 6220 MW

**MILLWOOD-EASTVIEW\_345\_W82**

Sat 09/19/2020 to Sat 09/19/2020  
 0330 Continuous 0400  
 Work scheduled by: ConEd

FWD  
 (Import)  
**UPNY CONED 5985 MW**  
 Impacts Total Transfer Capability 235 MW  
 TTC with All Lines In Service 6220 MW

# NYISO TRANSFER LIMITATIONS

Monday ,May 25, 2020 to Wednesday,November 24, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Work Details	Transfer Capabilities
<b>SPRNBK_345KV_RNS4</b>	
Sat 09/19/2020 to Sat 09/19/2020	FWD
0330 Continuous 0400	(Import)
Work scheduled by: ConEd	SPR/DUN-SOUTH <b>3200 MW</b>
	Impacts Total Transfer Capability 1400 MW
	TTC with All Lines In Service 4600 MW
<b>MILLWOOD_345KV_18</b>	
Sun 09/20/2020 to Sun 09/20/2020	FWD
0001 Continuous 0030	(Import)
Work scheduled by: ConEd	UPNY CONED <b>4350 MW</b>
	Impacts Total Transfer Capability 1870 MW
	TTC with All Lines In Service 6220 MW
<b>BUCHAN_S-MILLWOOD_345_W98</b>	
Sun 09/20/2020 to Fri 09/25/2020	FWD
0001 Continuous 0200	(Import)
Work scheduled by: ConEd	UPNY CONED <b>6135 MW</b>
	Impacts Total Transfer Capability 85 MW
	TTC with All Lines In Service 6220 MW
<b>CLAY-EDIC_345_1-16</b>	
Mon 09/21/2020 to Fri 09/25/2020	FWD
0700 Continuous 1530	(Import)
Work scheduled by: NYPA	OSWEGO EXPORT <b>4850 MW</b>
	Impacts Total Transfer Capability 400 MW
	TTC with All Lines In Service 5250 MW
<b>FRASANNX-COOPERS_345_UCC2-41</b>	
Mon 09/21/2020 to Sun 09/27/2020	FWD
0700 Continuous 1730	(Import)
Work scheduled by: NYPA	CENTRAL EAST - VC <b>2500 MW</b>
	Impacts Total Transfer Capability 475 MW
	TTC with All Lines In Service 2975 MW
	ARR: 19
<b>MARCY-FRASANNX_345_UCC2-41</b>	
Mon 09/21/2020 to Sun 09/27/2020	FWD
0700 Continuous 1730	(Import)
Work scheduled by: NYPA	CENTRAL EAST - VC <b>2500 MW</b>
	Impacts Total Transfer Capability 475 MW
	TTC with All Lines In Service 2975 MW
	ARR: 19
<b>ROSETON-ROCKTVRN_345_311</b>	
Mon 09/21/2020 to Fri 10/23/2020	FWD
0800 Continuous 1600	(Import)
Work scheduled by: CHGE	UPNY CONED <b>4400 MW</b>
	Impacts Total Transfer Capability 1820 MW
	TTC with All Lines In Service 6220 MW

# NYISO TRANSFER LIMITATIONS

Monday ,May 25, 2020 to Wednesday,November 24, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MILLWOOD\_345KV\_18**

Fri 09/25/2020 to Fri 09/25/2020  
 0130 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1870 MW  
 TTC with All Lines In Service 6220 MW

**EASTVIEW-SPRNBRK\_\_345\_W78**

Sat 09/26/2020 to Sun 09/27/2020  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1870 MW  
 TTC with All Lines In Service 6220 MW

**MILLWOOD-EASTVIEW\_345\_W85**

Sat 09/26/2020 to Sun 09/27/2020  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **5985 MW**  
 Impacts Total Transfer Capability 235 MW  
 TTC with All Lines In Service 6220 MW

**SPRNBRK\_\_345KV\_RNS3**

Sat 09/26/2020 to Sun 09/27/2020  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_3**

Mon 09/28/2020 to Sat 10/31/2020  
 0001 Continuous 0100  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_4**

Mon 09/28/2020 to Sat 10/31/2020  
 0001 Continuous 0100  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**PLSNTVLE-DUNWODIE\_345\_W89**

Mon 09/28/2020 to Sat 10/31/2020  
 0001 Continuous 0100  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 2220 MW  
 TTC with All Lines In Service 6220 MW

# NYISO TRANSFER LIMITATIONS

Monday ,May 25, 2020 to Wednesday,November 24, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**CLAY -EDIC 345\_2-15**

Mon 09/28/2020 to Fri 10/02/2020  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 OSWEGO EXPORT **4850 MW**  
 Impacts Total Transfer Capability 400 MW  
 TTC with All Lines In Service 5250 MW

**MOTTHAVN-RAINEY 345\_Q11**

Thu 10/01/2020 to Thu 11/05/2020 **UPDATED by CONED 12/17/2019**  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**HUDSONTP-W49TH\_ST\_345\_Y56**

Fri 10/02/2020 to Thu 10/08/2020  
 0001 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SCH - PJM\_HTP **0 MW**  
 Impacts Total Transfer Capability 660 MW  
 TTC with All Lines In Service 660 MW

**W49TH\_ST\_345KV\_7**

Fri 10/02/2020 to Thu 10/08/2020  
 0001 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SCH - PJM\_HTP **365 MW**  
 Impacts Total Transfer Capability 295 MW  
 TTC with All Lines In Service 660 MW

**W49TH\_ST\_345KV\_8**

Fri 10/02/2020 to Thu 10/08/2020  
 0001 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SCH - PJM\_HTP **450 MW**  
 Impacts Total Transfer Capability 210 MW  
 TTC with All Lines In Service 660 MW

**PANNELL -CLAY 345\_1**

Mon 10/05/2020 to Fri 10/09/2020 **UPDATED by NYPA 05/07/2020**  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 WEST CENTRAL **1300 MW**  
 Impacts Total Transfer Capability 950 MW  
 TTC with All Lines In Service 2250 MW

**SAND\_BAR-PLATSBRG\_115\_PV20**

Sat 10/17/2020 to Sat 11/14/2020  
 0600 Continuous 1800  
 Work scheduled by: ISONE

SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service



# NYISO TRANSFER LIMITATIONS

Monday ,May 25, 2020 to Wednesday,November 24, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Zone	Start	End	Status	By	Effective Date	Impact	FWD	REV
ROCHESTR-PANNELL_345_RP1	Mon 10/19/2020 0500	Fri 10/23/2020 1700	UPDATED	by NYPA	03/10/2020	DYSINGER EAST	FWD (Import) 2300 MW	
Work scheduled by: NYPA						Impacts Total Transfer Capability	850 MW	
						TTC with All Lines In Service	3150 MW	
SHOR_NPX-SHOREHAM_138_CSC	Mon 10/19/2020 0700	Fri 10/23/2020 1500	UPDATED	by LI	03/02/2020	SCH - NPX_CSC	FWD (Import) 0 MW	REV (Export) 0 MW
Work scheduled by: LI						Impacts Total Transfer Capability	330 MW	330 MW
						TTC with All Lines In Service	330 MW	330 MW
PANNELL -CLAY_345_2	Mon 10/19/2020 0700	Fri 10/23/2020 1530	UPDATED	by NYPA	05/07/2020	WEST CENTRAL	FWD (Import) 1300 MW	
Work scheduled by: NYPA						Impacts Total Transfer Capability	950 MW	
						TTC with All Lines In Service	2250 MW	
BERKSHIR-ALPS_345_393	Mon 10/19/2020 0730	Tue 11/10/2020 1330	UPDATED	by ISONE	04/01/2020	SCH - NE - NY	FWD (Import) 950 MW	REV (Export) 1300 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability	450 MW	300 MW
						TTC with All Lines In Service	1400 MW	1600 MW
								ARR: 78
BERKSHIR-ALPS_345_393	Mon 10/19/2020 0730	Tue 11/10/2020 1330	UPDATED	by ISONE	04/01/2020	SCH - NPX_1385	FWD (Import) 100 MW	REV (Export) 100 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability	100 MW	100 MW
						TTC with All Lines In Service	200 MW	200 MW
								ARR: 78
BERKSHIR-ALPS_345_393 & BERKSHIR-NORTHFLD_345_312	Mon 10/19/2020 0730	Tue 11/10/2020 1330				SCH - NE - NY	FWD (Import) 950 MW	REV (Export) 1300 MW
Work scheduled by:						Impacts Total Transfer Capability	450 MW	300 MW
						TTC with All Lines In Service	1400 MW	1600 MW
								ARR: 78
BERKSHIR-NORTHFLD_345_312	Mon 10/19/2020 0730	Tue 11/10/2020 1330	UPDATED	by ISONE	04/01/2020	SCH - NE - NY	FWD (Import) 900 MW	REV (Export) 1500 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability	500 MW	100 MW
						TTC with All Lines In Service	1400 MW	1600 MW

# NYISO TRANSFER LIMITATIONS

Monday ,May 25, 2020 to Wednesday, November 24, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event ID	Start Date	End Date	Time	Duration	Work Scheduled by	Update Info	SCH	FWD	REV
BERKSHIR-NORTHFLD_345_312	Mon 10/19/2020	Tue 11/10/2020	0730	Continuous	1330	<u>UPDATED</u> by <u>ISONE</u> <u>04/01/2020</u>	SCH - NPX_1385	(Import)	(Export)
							Impacts Total Transfer Capability	100 MW	100 MW
							TTC with All Lines In Service	200 MW	200 MW
LEEDS_345_LEEDS SVC	Mon 10/26/2020	Fri 10/30/2020	0800	Continuous	1600		CENTRAL EAST - VC	(Import)	
							Impacts Total Transfer Capability	2950 MW	
							TTC with All Lines In Service	25 MW	
LEEDS_HURLYAVE_345_301	Mon 10/26/2020	Fri 12/04/2020	0800	Continuous	1600		UPNY CONED	(Import)	
							Impacts Total Transfer Capability	4100 MW	
							TTC with All Lines In Service	2120 MW	
SCH-IMO-NYISO_LIMIT_1750	Sun 11/01/2020	Fri 04/30/2021	0001	Continuous	2359	<u>UPDATED</u> by <u>IESO</u> <u>05/03/2019</u>	SCH - OH - NY	(Import)	
							Impacts Total Transfer Capability	2050 MW	
							TTC with All Lines In Service	0 MW	
SCH-NYISO-IMO_LIMIT_1600	Sun 11/01/2020	Fri 04/30/2021	0001	Continuous	2359	<u>UPDATED</u> by <u>IESO</u> <u>05/03/2019</u>	SCH - OH - NY	(Export)	
							Impacts Total Transfer Capability	1900 MW	
							TTC with All Lines In Service	0 MW	1900 MW
SPRNBRK_W49TH_ST_345_M51	Thu 11/12/2020	Mon 11/16/2020	0001	Continuous	0300		SPR/DUN-SOUTH	(Import)	
							Impacts Total Transfer Capability	3200 MW	
							TTC with All Lines In Service	1400 MW	4600 MW
SPRNBRK_345KV_RNS5	Thu 11/12/2020	Mon 11/16/2020	0001	Continuous	0300		SPR/DUN-SOUTH	(Import)	
							Impacts Total Transfer Capability	3200 MW	
							TTC with All Lines In Service	1400 MW	4600 MW

# NYISO TRANSFER LIMITATIONS

Monday ,May 25, 2020 to Wednesday,November 24, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CHATGUAY-MASSENA__765_7040</b>			FWD	
Sun 11/15/2020	to	Mon 11/30/2020	(Import)	
0100	Continuous	1900	MOSES SOUTH	<b>1550 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	1600 MW
			TTC with All Lines In Service	3150 MW
<b>CHATGUAY-MASSENA__765_7040</b>			FWD	REV
Sun 11/15/2020	to	Mon 11/30/2020	(Import)	(Export)
0100	Continuous	1900	SCH - HQ - NY	<b>0 MW 0 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	1500 MW 1000 MW
			TTC with All Lines In Service	1500 MW 1000 MW
<b>MARCY__765_345_AT1</b>			FWD	
Sun 11/15/2020	to	Mon 11/30/2020	(Import)	
0100	Continuous	1900	MOSES SOUTH	<b>1750 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	1400 MW
			TTC with All Lines In Service	3150 MW
				<b>ARR: 19</b>
<b>MARCY__765_345_AT2</b>			FWD	
Sun 11/15/2020	to	Mon 11/30/2020	(Import)	
0100	Continuous	1900	MOSES SOUTH	<b>1700 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	1450 MW
			TTC with All Lines In Service	3150 MW
				<b>ARR: 19</b>
<b>MASSENA_-MARCY__765_MSU1</b>			FWD	
Sun 11/15/2020	to	Mon 11/30/2020	(Import)	
0100	Continuous	1900	CENTRAL EAST - VC	<b>2265 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	710 MW
			TTC with All Lines In Service	2975 MW
<b>MASSENA_-MARCY__765_MSU1</b>			FWD	
Sun 11/15/2020	to	Mon 11/30/2020	(Import)	
0100	Continuous	1900	MOSES SOUTH	<b>500 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	2650 MW
			TTC with All Lines In Service	3150 MW
<b>MASSENA_-MARCY__765_MSU1</b>			FWD	REV
Sun 11/15/2020	to	Mon 11/30/2020	(Import)	(Export)
0100	Continuous	1900	SCH - HQ - NY	<b>475 MW 1000 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	1025 MW 0 MW
			TTC with All Lines In Service	1500 MW 1000 MW

# NYISO TRANSFER LIMITATIONS

Monday ,May 25, 2020 to Wednesday,November 24, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MASSENA -MARCY 765_MSU1</b>		FWD	
Sun 11/15/2020	to Mon 11/30/2020	(Import)	
0100	Continuous 1900	SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability	109 MW
		TTC with All Lines In Service	199 MW
<b>MASSENA -MARCY 765_MSU1 &amp; CHATGUAY-MASSENA 765_7040</b>		FWD	
Sun 11/15/2020	to Mon 11/30/2020	(Import)	
0100	1900	MOSES SOUTH	<b>500 MW</b>
Work scheduled by:		Impacts Total Transfer Capability	2650 MW
		TTC with All Lines In Service	3150 MW
<b>MOSES -MASSENA 230_MMS1 &amp; MOSES -MASSENA 230_MMS2</b>		FWD	REV
Sun 11/15/2020	to Mon 11/30/2020	(Import)	(Export)
0100	1900	SCH - HQ - NY	<b>850 MW 0 MW</b>
Work scheduled by:		Impacts Total Transfer Capability	650 MW 1000 MW
		TTC with All Lines In Service	1500 MW 1000 MW
<b>MOSES -MASSENA 230_MMS1 &amp; MOSES -MASSENA 230_MMS2</b>		FWD	
Sun 11/15/2020	to Mon 11/30/2020	(Import)	
0100	1900	SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by:		Impacts Total Transfer Capability	109 MW
		TTC with All Lines In Service	199 MW
<b>STLAWRNC-MOSES 230_L33P &amp; MASSENA -MARCY 765_MSU1</b>		FWD	
Sun 11/15/2020	to Mon 11/30/2020	(Import)	
0100	1900	SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by:		Impacts Total Transfer Capability	109 MW
		TTC with All Lines In Service	199 MW
<b>STLAWRNC-MOSES 230_L33P &amp; MOSES -MASSENA 230_MMS1 &amp; MOSES -MASSENA 230_MMS2</b>		FWD	
Sun 11/15/2020	to Mon 11/30/2020	(Import)	
0100	1900	SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by:		Impacts Total Transfer Capability	109 MW
		TTC with All Lines In Service	199 MW
<b>PLSNTVLE-DUNWODIE 345_W89</b>		FWD	
Mon 11/16/2020	to Mon 11/16/2020	(Import)	
0001	Continuous 0030	UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd		Impacts Total Transfer Capability	2220 MW
		TTC with All Lines In Service	6220 MW

# NYISO TRANSFER LIMITATIONS

Monday ,May 25, 2020 to Wednesday,November 24, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**PLSNTVLE-DUNWODIE\_345\_W89**

Thu 11/26/2020 to Thu 11/26/2020  
 0230 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 2220 MW  
 TTC with All Lines In Service 6220 MW

**LADENTWN-BUCHAN\_S\_345\_Y88**

Mon 11/30/2020 to Thu 01/14/2021 **UPDATED by CONED 01/30/2020**  
 0001 Continuous 2359  
 Work scheduled by: ORU

FWD  
 (Import)  
 UPNY CONED **5930 MW**  
 Impacts Total Transfer Capability 290 MW  
 TTC with All Lines In Service 6220 MW

**NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE**

Mon 11/30/2020 to Sun 12/20/2020 **UPDATED by LI 04/29/2020**  
 0600 Continuous 1600  
 Work scheduled by: PJM

FWD  
 (Import)  
 SCH - PJM\_NEPTUNE **0 MW**  
 Impacts Total Transfer Capability 660 MW  
 TTC with All Lines In Service 660 MW

**NEWBRDGE-DUFFYAVE\_345\_501**

Mon 11/30/2020 to Sun 12/20/2020 **UPDATED by LI 04/29/2020**  
 0600 Continuous 1600  
 Work scheduled by: PJM

FWD  
 (Import)  
 SCH - PJM\_NEPTUNE **0 MW**  
 Impacts Total Transfer Capability 660 MW  
 TTC with All Lines In Service 660 MW

**MARCY\_\_\_345KV\_CSC**

Tue 12/01/2020 to Fri 12/11/2020  
 0700 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2925 MW**  
 Impacts Total Transfer Capability 50 MW  
 TTC with All Lines In Service 2975 MW

**MOSES\_-ADIRNDCK\_230\_MA1**

Tue 12/01/2020 to Mon 05/31/2021  
 0700 Continuous 1300  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

**SAND\_BAR-PLATSBRG\_115\_PV20**

Mon 12/07/2020 to Fri 12/11/2020  
 0700 Continuous 1530  
 Work scheduled by: NYPA

SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

Monday ,May 25, 2020 to Wednesday, November 24, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LONG_MTN-CRICKVLY_345_398			FWD	REV
			(Import)	(Export)
Tue 12/08/2020	to	Thu 12/10/2020		
0700	Continuous	1600	SCH - NE - NY	<b>700 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	700 MW
			TTC with All Lines In Service	1400 MW
LONG_MTN-CRICKVLY_345_398			FWD	REV
			(Import)	(Export)
Tue 12/08/2020	to	Thu 12/10/2020		
0700	Continuous	1600	SCH - NPX_1385	<b>100 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW
			TTC with All Lines In Service	200 MW
SCH-NE-NYISO_LIMIT_400			FWD	
			(Import)	
Tue 12/08/2020	to	Thu 12/10/2020		
0700	Continuous	1600	SCH - NE - NY	<b>600 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	1400 MW
SCH-NYISO-NE_LIMIT_1000				REV
				(Export)
Tue 12/08/2020	to	Thu 12/10/2020		
0700	Continuous	1600	SCH - NE - NY	<b>1200 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	500 MW
			TTC with All Lines In Service	1700 MW
MARCY__-EDIC____345_UE1-7			FWD	
			(Import)	
Mon 12/14/2020	to	Mon 12/14/2020		
0700	Continuous	1730	OSWEGO EXPORT	<b>5250 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	0 MW
			TTC with All Lines In Service	5250 MW
SAND_BAR-PLATSBRG_115_PV20				
Mon 12/14/2020	to	Fri 12/18/2020		
0700	Continuous	1530	SCH - NE - NY	
Work scheduled by: NYPA			Impacts Total Transfer Capability	
			TTC with All Lines In Service	
FRASANX-COOPERS__345_UCC2-41			FWD	
			(Import)	
Tue 12/15/2020	to	Wed 12/16/2020		
0700	Continuous	1530	CENTRAL EAST - VC	<b>2500 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	475 MW
			TTC with All Lines In Service	2975 MW

ARR: 19&16

ARR: 19

# NYISO TRANSFER LIMITATIONS

Monday ,May 25, 2020 to Wednesday, November 24, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARCY\_\_\_-FRASANNX\_345\_UCC2-41**

Tue 12/15/2020 to Wed 12/16/2020  
0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

**HOPATCON-RAMAPO\_\_\_500\_5018**

Mon 02/01/2021 to Wed 02/03/2021  
0001 Continuous 2200

Work scheduled by: ConEd

FWD REV  
(Import) (Export)  
SCH - PJ - NY **1250 MW 1200 MW**  
Impacts Total Transfer Capability 1650 MW 650 MW  
TTC with All Lines In Service 2900 MW 1850 MW

**HOPATCON-RAMAPO\_\_\_500\_5018**

Mon 02/01/2021 to Wed 02/03/2021  
0001 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **6025 MW**  
Impacts Total Transfer Capability 195 MW  
TTC with All Lines In Service 6220 MW

**RAMAPO\_\_\_345\_345\_PAR3500**

Mon 02/01/2021 to Wed 02/03/2021  
0001 Continuous 2200

Work scheduled by: ConEd

FWD REV  
(Import) (Export)  
SCH - PJ - NY **2150 MW 1250 MW**  
Impacts Total Transfer Capability 750 MW 600 MW  
TTC with All Lines In Service 2900 MW 1850 MW

**RAMAPO\_\_\_345\_345\_PAR4500**

Mon 02/01/2021 to Wed 02/03/2021  
0001 Continuous 2200

Work scheduled by: ConEd

FWD REV  
(Import) (Export)  
SCH - PJ - NY **2150 MW 1250 MW**  
Impacts Total Transfer Capability 750 MW 600 MW  
TTC with All Lines In Service 2900 MW 1850 MW

**RAMAPO\_\_\_500\_345\_BK 1500**

Mon 02/01/2021 to Wed 02/03/2021  
0001 Continuous 2200

Work scheduled by: ConEd

FWD REV  
(Import) (Export)  
SCH - PJ - NY **1250 MW 1200 MW**  
Impacts Total Transfer Capability 1650 MW 650 MW  
TTC with All Lines In Service 2900 MW 1850 MW

**RAMAPO\_\_\_500\_345\_BK 1500**

Mon 02/01/2021 to Wed 02/03/2021  
0001 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **6025 MW**  
Impacts Total Transfer Capability 195 MW  
TTC with All Lines In Service 6220 MW

# NYISO TRANSFER LIMITATIONS

Monday ,May 25, 2020 to Wednesday,November 24, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY-WOOD\_ST\_\_345\_F30

Mon 02/15/2021 to Tue 02/16/2021  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 2220 MW  
 TTC with All Lines In Service 6220 MW

PLSNTVLY\_345KV\_RNS5

Mon 02/15/2021 to Tue 02/16/2021  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 2420 MW  
 TTC with All Lines In Service 6220 MW

EFISHKIL-WOOD\_ST\_\_345\_F39

Thu 02/18/2021 to Sat 02/20/2021 **UPDATED by CE 04/01/2020**  
 2100 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 2220 MW  
 TTC with All Lines In Service 6220 MW

WOOD\_ST\_-PLSNTVLE\_345\_Y87

Thu 02/18/2021 to Sat 02/20/2021 **UPDATED by CE 04/01/2020**  
 2100 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **5905 MW**  
 Impacts Total Transfer Capability 315 MW  
 TTC with All Lines In Service 6220 MW

DUNWODIE\_345KV\_3

Mon 03/01/2021 to Mon 03/01/2021  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

DUNWODIE\_345KV\_5

Mon 03/01/2021 to Mon 03/01/2021  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

EASTVIEW-SPRNBK\_\_345\_W64

Mon 03/01/2021 to Mon 03/01/2021 **UPDATED by CONED 01/23/2020**  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1870 MW  
 TTC with All Lines In Service 6220 MW



# NYISO TRANSFER LIMITATIONS

Monday ,May 25, 2020 to Wednesday,November 24, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SPRNBK__345KV_RNS5</b>					FWD	
Mon 03/01/2021	to	Mon 03/01/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>01/23/2020</u>	(Import)
0001	Continuous	0030				SPR/DUN-SOUTH <b>3200 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
<b>MILLWOOD-EASTVIEW_345_W99</b>					FWD	
Mon 03/01/2021	to	Mon 03/22/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>01/23/2020</u>	(Import)
0001	Continuous	0200				UPNY CONED <b>5985 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	235 MW
					TTC with All Lines In Service	6220 MW
<b>DUNWODIE-MOTTHAVN_345_71</b>					FWD	
Mon 03/01/2021	to	Mon 04/05/2021				(Import)
0001	Continuous	0300				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>MOTTHAVN-RAINEY__345_Q11</b>					FWD	
Mon 03/01/2021	to	Tue 04/06/2021				(Import)
0001	Continuous	0700				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>EASTVIEW-SPRNBK__345_W64</b>					FWD	
Mon 03/22/2021	to	Mon 03/22/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>01/23/2020</u>	(Import)
0130	Continuous	0200				UPNY CONED <b>4350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	1870 MW
					TTC with All Lines In Service	6220 MW
<b>SPRNBK__345KV_RNS5</b>					FWD	
Mon 03/22/2021	to	Mon 03/22/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>01/23/2020</u>	(Import)
0130	Continuous	0200				SPR/DUN-SOUTH <b>3200 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
<b>CLAY____-EDIC____345_2-15</b>					FWD	
Mon 03/29/2021	to	Fri 04/16/2021				(Import)
0800	Continuous	1730				OSWEGO EXPORT <b>4850 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	400 MW
					TTC with All Lines In Service	5250 MW

# NYISO TRANSFER LIMITATIONS

Monday ,May 25, 2020 to Wednesday,November 24, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE\_345KV\_3**

Mon 04/05/2021 to Mon 04/05/2021  
 0230 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_5**

Mon 04/05/2021 to Mon 04/05/2021  
 0230 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**SPRNBK\_-TREMONT\_345\_X28**

Mon 04/19/2021 to Tue 04/20/2021  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **4200 MW**  
 Impacts Total Transfer Capability 400 MW  
 TTC with All Lines In Service 4600 MW

**SCH-IMO-NYISO\_LIMIT\_1600**

Sat 05/01/2021 to Sun 10/31/2021 **UPDATED by IESO 05/03/2019**  
 0001 Continuous 2359  
 Work scheduled by: IESO

FWD  
 (Import)  
 SCH - OH - NY **1900 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 1900 MW

**PANNELL\_-CLAY\_345\_2**

Mon 05/03/2021 to Fri 05/28/2021  
 0700 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
 WEST CENTRAL **1300 MW**  
 Impacts Total Transfer Capability 950 MW  
 TTC with All Lines In Service 2250 MW

**MOSES\_-ADIRNDCK\_230\_MA2**

Tue 06/01/2021 to Sun 11/14/2021  
 0700 Continuous 1300  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2100 MW**  
 Impacts Total Transfer Capability 1050 MW  
 TTC with All Lines In Service 3150 MW

**SPRNBK\_-W49TH\_ST\_345\_M51**

Fri 10/01/2021 to Sun 10/17/2021  
 0001 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Monday ,May 25, 2020 to Wednesday,November 24, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**SPRNBK\_\_345KV\_RNS5**

FWD

Fri 10/01/2021 to Sun 10/17/2021

(Import)

0001 Continuous 0300

SPR/DUN-SOUTH

**3200 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

-----  
**SCH-IMO-NYISO\_LIMIT\_1750**

FWD

Mon 11/01/2021 to Fri 12/31/2021

(Import)

0001 Continuous 2359

**UPDATED by IESO 05/03/2019**

SCH - OH - NY

**2050 MW**

Work scheduled by: IESO

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 2050 MW

-----  
**SCH-NYISO-IMO\_LIMIT\_1600**

REV

Mon 11/01/2021 to Fri 12/31/2021

(Export)

0001 Continuous 2359

**UPDATED by IESO 05/03/2019**

SCH - OH - NY

**1900 MW**

Work scheduled by: IESO

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 1900 MW