

# NYISO TRANSFER LIMITATIONS

Tuesday ,May 26, 2020 to Thursday ,November 25, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					FWD	REV
<b>HUDSONP_-FARRAGUT_345_B3402</b>					(Import)	(Export)
Mon 01/15/2018	to	Thu 10/01/2020	<u><b>EXTENDED</b></u>	<u><b>by CONED</b></u>	<u><b>05/03/2020</b></u>	
0001	Continuous	2359				
Work scheduled by: ConEd					SCH - PJ - NY	<b>2100 MW</b>
					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	2150 MW
						1250 MW
						100 MW
						1350 MW
<hr/>						
<b>HUDSONP_-FARRAGUT_345_B3402 &amp; MARION_-FARRAGUT_345_C3403</b>					FWD	REV
					(Import)	(Export)
Mon 01/15/2018	to	Thu 10/01/2020				
0001		2359				
Work scheduled by:					SCH - PJ - NY	<b>2050 MW</b>
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	2150 MW
						1150 MW
						200 MW
						1350 MW
<hr/>						
<b>MARION_-FARRAGUT_345_C3403</b>					FWD	REV
					(Import)	(Export)
Mon 01/15/2018	to	Thu 10/01/2020	<u><b>EXTENDED</b></u>	<u><b>by CONED</b></u>	<u><b>05/03/2020</b></u>	
0001	Continuous	2359				
Work scheduled by: ConEd					SCH - PJ - NY	<b>2100 MW</b>
					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	2150 MW
						1250 MW
						100 MW
						1350 MW
<hr/>						
<b>STLAWRNC-MOSES_230_L33P</b>						
Mon 04/30/2018	to	Fri 12/31/2021	<u><b>EXT FORCE</b></u>	<u><b>by IESO</b></u>	<u><b>08/21/2018</b></u>	
0456	Continuous	2359				
Work scheduled by: IESO					SCH - OH - NY	
					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
<hr/>						
<b>HURLYAVE-ROSETON_345_303</b>					FWD	
					(Import)	
Mon 04/27/2020	to	Thu 05/21/2020	<u><b>UPDATED</b></u>	<u><b>by CHGE</b></u>	<u><b>10/09/2019</b></u>	
0800	Continuous	1545				
Work scheduled by: CHGE					UPNY CONED	<b>4100 MW</b>
					Impacts Total Transfer Capability	2120 MW
					TTC with All Lines In Service	6220 MW
<hr/>						
<b>SCH-IMO-NYISO_LIMIT_1600</b>					FWD	
					(Import)	
Fri 05/01/2020	to	Sat 10/31/2020	<u><b>UPDATED</b></u>	<u><b>by IESO</b></u>	<u><b>05/03/2019</b></u>	
0001	Continuous	2359				
Work scheduled by: IESO					SCH - OH - NY	<b>1900 MW</b>
					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	1900 MW
<hr/>						
<b>MOSES_-ADIRNDCK_230_MA2</b>					FWD	
					(Import)	
Mon 05/04/2020	to	Sun 09/13/2020	<u><b>UPDATED</b></u>	<u><b>by NYPA</b></u>	<u><b>04/20/2020</b></u>	
0700	Continuous	1730				
Work scheduled by: NYPA					MOSES SOUTH	<b>2100 MW</b>
					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,May 26, 2020 to Thursday ,November 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>E13THSTA-FARRAGUT_345_45</b>					FWD	
Sun 05/10/2020	to	Fri 05/29/2020	<b>EXTENDED</b>	<b>by CONED</b>	<b>05/20/2020</b>	(Import)
0001	Continuous	2359				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>W49TH_ST-E13THSTA_345_M54</b>					FWD	
Mon 05/11/2020	to	Fri 05/29/2020	<b>EXTENDED</b>	<b>by CONED</b>	<b>05/20/2020</b>	(Import)
0842	Continuous	2359				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>EGRDNCTY_345_138_AT1</b>					FWD	
Mon 05/18/2020	to	Sat 05/23/2020				(Import)
0001	Continuous	0200				CONED - LIPA <b>1250 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability	250 MW
					TTC with All Lines In Service	1500 MW
<b>EGRDNCTY_345_138_AT2</b>					FWD	
Mon 05/18/2020	to	Sat 05/23/2020				(Import)
0001	Continuous	0200				CONED - LIPA <b>1250 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability	250 MW
					TTC with All Lines In Service	1500 MW
<b>SPRNBK_-EGRDNCTR_345_Y49</b>					FWD	
Mon 05/18/2020	to	Sat 05/23/2020				(Import)
0001	Continuous	0200				CONED - LIPA <b>775 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability	725 MW
					TTC with All Lines In Service	1500 MW
<b>SCH-NE-NYISO_LIMIT_500</b>					FWD	
Mon 05/18/2020	to	Fri 05/29/2020	<b>UPDATED</b>	<b>by ISONE</b>	<b>05/14/2020</b>	(Import)
0700	Daily	2259				SCH - NE - NY <b>700 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability	700 MW
					TTC with All Lines In Service	1400 MW
<b>SCH-NYISO-NE_LIMIT_700</b>					FWD	
Mon 05/18/2020	to	Fri 05/29/2020	<b>UPDATED</b>	<b>by ISONE</b>	<b>05/14/2020</b>	REV (Export)
0700	Daily	2259				SCH - NE - NY <b>900 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability	700 MW
					TTC with All Lines In Service	1600 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,May 26, 2020 to Thursday ,November 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
<b>BERKSHIR-ALPS</b>	<b>345_393</b>						
Mon 05/18/2020	to	Sat 05/30/2020	<b>UPDATED</b>	<b>by ISONE</b>	<b>05/14/2020</b>		
0700	Continuous	1700				SCH - NE - NY	<b>950 MW</b>
Work scheduled by: ISONE						Impacts Total Transfer Capability	450 MW
						TTC with All Lines In Service	1400 MW
							1600 MW
<b>BERKSHIR-ALPS</b>	<b>345_393</b>						
Mon 05/18/2020	to	Sat 05/30/2020	<b>UPDATED</b>	<b>by ISONE</b>	<b>05/14/2020</b>		
0700	Continuous	1700				SCH - NPX_1385	<b>100 MW</b>
Work scheduled by: ISONE						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
							200 MW
<b>HOPATCON-RAMAPO</b>	<b>500_5018</b>						
Mon 05/18/2020	to	Fri 05/22/2020	<b>FORCED</b>	<b>by CONED</b>	<b>05/18/2020</b>		
1531	Continuous	2359				SCH - PJ - NY	<b>1150 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	1000 MW
						TTC with All Lines In Service	2150 MW
							1350 MW
<b>HOPATCON-RAMAPO</b>	<b>500_5018</b>						
Mon 05/18/2020	to	Fri 05/22/2020	<b>FORCED</b>	<b>by CONED</b>	<b>05/18/2020</b>		
1531	Continuous	2359				UPNY CONED	<b>6025 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	195 MW
						TTC with All Lines In Service	6220 MW
<b>RAMAPO</b>	<b>500_345_BK 1500</b>						
Mon 05/18/2020	to	Fri 05/22/2020	<b>FORCED</b>	<b>by CONED</b>	<b>05/18/2020</b>		
1531	Continuous	2359				SCH - PJ - NY	<b>1150 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	1000 MW
						TTC with All Lines In Service	2150 MW
							1350 MW
<b>RAMAPO</b>	<b>500_345_BK 1500</b>						
Mon 05/18/2020	to	Fri 05/22/2020	<b>FORCED</b>	<b>by CONED</b>	<b>05/18/2020</b>		
1531	Continuous	2359				UPNY CONED	<b>6025 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	195 MW
						TTC with All Lines In Service	6220 MW
<b>RAMAPO</b>	<b>345_345_PAR3500</b>						
Mon 05/18/2020	to	Fri 05/22/2020	<b>FORCED</b>	<b>by CONED</b>	<b>05/18/2020</b>		
1606	Continuous	2359				SCH - PJ - NY	<b>1800 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	350 MW
						TTC with All Lines In Service	2150 MW
							1350 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,May 26, 2020 to Thursday ,November 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Location	Start	End	Day	Time	Duration	Work by	Update	By	Effective Date	SCH	FWD	REV
<b>RAMAPO___345_345_PAR4500</b>	Mon 05/18/2020	Fri 05/22/2020	Continuous	1606	2359	ConEd	<b>FORCED</b>	<b>by CONED</b>	<b>05/18/2020</b>	SCH - PJ - NY	(Import)	(Export)
											<b>1800 MW</b>	<b>1250 MW</b>
										Impacts Total Transfer Capability	350 MW	100 MW
										TTC with All Lines In Service	2150 MW	1350 MW
<b>SCH-NYISO-NE_LIMIT_500</b>	Mon 05/18/2020	Sat 05/30/2020	Daily	2300	0659	ISONNE	<b>UPDATED</b>	<b>by ISONNE</b>	<b>05/14/2020</b>	SCH - NE - NY		REV (Export)
												<b>700 MW</b>
										Impacts Total Transfer Capability		900 MW
										TTC with All Lines In Service		1600 MW
<b>MARCY___345KV_CSC</b>	Sat 05/23/2020	Sat 05/23/2020	Continuous	0600	1830	NYPA					FWD (Import)	
										CENTRAL EAST - VC		<b>2925 MW</b>
										Impacts Total Transfer Capability	50 MW	
										TTC with All Lines In Service	2975 MW	
<b>SPRNBK_-TREMONT__345_X28</b>	Sun 05/24/2020	Sun 05/24/2020	Continuous	0001	1800	ConEd	<b>UPDATED</b>	<b>by CONED</b>	<b>05/11/2020</b>	SPR/DUN-SOUTH	FWD (Import)	
												<b>4200 MW</b>
										Impacts Total Transfer Capability	400 MW	
										TTC with All Lines In Service	4600 MW	
<b>LINDN_CG-LNDVFT__345_V-3022</b>	Sun 05/24/2020	Sat 05/30/2020	Continuous	1400	1400	PJM	<b>UPDATED</b>	<b>by PJM</b>	<b>02/28/2020</b>	SCH - PJM_VFT	FWD (Import)	REV (Export)
											<b>0 MW</b>	<b>0 MW</b>
										Impacts Total Transfer Capability	315 MW	315 MW
										TTC with All Lines In Service	315 MW	315 MW
<b>MILLWOOD_345KV_18</b>	Thu 05/28/2020	Thu 05/28/2020	Continuous	0400	0430	ConEd	<b>UPDATED</b>	<b>by CONED</b>	<b>04/09/2020</b>	UPNY CONED	FWD (Import)	
												<b>4350 MW</b>
										Impacts Total Transfer Capability	1870 MW	
										TTC with All Lines In Service	6220 MW	
<b>LEEDS___345KV_R395</b>	Thu 05/28/2020	Thu 06/11/2020	Continuous	0700	1800	NGrid				UPNY CONED	FWD (Import)	
												<b>3800 MW</b>
										Impacts Total Transfer Capability	2420 MW	
										TTC with All Lines In Service	6220 MW	

# NYISO TRANSFER LIMITATIONS

Tuesday ,May 26, 2020 to Thursday ,November 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>INDPDNCE-SCRIBA_345_25</b>				FWD	
Thu 05/28/2020	to	Thu 05/28/2020		(Import)	
0800	Daily(No Weekends)	1630			
Work scheduled by: NGrid				OSWEGO EXPORT	5250 MW
				Impacts Total Transfer Capability	0 MW
				TTC with All Lines In Service	5250 MW
<b>SCH-NE-NYISO_LIMIT_500</b>				FWD	
Sat 05/30/2020	to	Sat 05/30/2020	<u>UPDATED</u> <u>by ISONE</u> <u>05/14/2020</u>	(Import)	
0700	Daily	1700			
Work scheduled by: ISONE				SCH - NE - NY	700 MW
				Impacts Total Transfer Capability	700 MW
				TTC with All Lines In Service	1400 MW
<b>SCH-NYISO-NE_LIMIT_700</b>					REV
Sat 05/30/2020	to	Sat 05/30/2020	<u>UPDATED</u> <u>by ISONE</u> <u>05/14/2020</u>		(Export)
0700	Daily	1700			
Work scheduled by: ISONE				SCH - NE - NY	900 MW
				Impacts Total Transfer Capability	700 MW
				TTC with All Lines In Service	1600 MW
<b>BERKSHIR-ALPS_345_393 &amp; BERKSHIR-NORTHFLD_345_312</b>				FWD	REV
Sat 05/30/2020	to	Sat 05/30/2020		(Import)	(Export)
1500		1700			
Work scheduled by: <b>ARR: 78</b>				SCH - NE - NY	950 MW 1300 MW
				Impacts Total Transfer Capability	450 MW 300 MW
				TTC with All Lines In Service	1400 MW 1600 MW
<b>BERKSHIR-NORTHFLD_345_312</b>				FWD	REV
Sat 05/30/2020	to	Sat 05/30/2020	<u>UPDATED</u> <u>by ISONE</u> <u>05/14/2020</u>	(Import)	(Export)
1500	Continuous	1700			
Work scheduled by: ISONE				SCH - NE - NY	900 MW 1500 MW
				Impacts Total Transfer Capability	500 MW 100 MW
				TTC with All Lines In Service	1400 MW 1600 MW
<b>BERKSHIR-NORTHFLD_345_312</b>				FWD	REV
Sat 05/30/2020	to	Sat 05/30/2020	<u>UPDATED</u> <u>by ISONE</u> <u>05/14/2020</u>	(Import)	(Export)
1500	Continuous	1700			
Work scheduled by: ISONE				SCH - NPX_1385	100 MW 100 MW
				Impacts Total Transfer Capability	100 MW 100 MW
				TTC with All Lines In Service	200 MW 200 MW
<b>SCH-NYISO-IMO_NIAGARA_CB_3002</b>				FWD	REV
Mon 06/01/2020	to	Tue 06/02/2020	<u>UPDATED</u> <u>by NYPA</u> <u>05/20/2020</u>	(Import)	(Export)
0500	Continuous	1700			
Work scheduled by: NYPA				SCH - OH - NY	1300 MW 1150 MW
				Impacts Total Transfer Capability	600 MW 550 MW
				TTC with All Lines In Service	1900 MW 1700 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,May 26, 2020 to Thursday ,November 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
<b>SHOR_NPX-SHOREHAM_138_CSC</b>					
Mon 06/01/2020	to	Tue 06/02/2020	<u>UPDATED</u> <u>by ISONE</u> <u>03/04/2020</u>		
0501	Continuous	2330		SCH - NPX_CSC	<b>0 MW</b> <b>0 MW</b>
Work scheduled by: LI				Impacts Total Transfer Capability	330 MW 330 MW
				TTC with All Lines In Service	330 MW 330 MW
<b>STONYRDG-HILLSIDE_230_72</b>					
Mon 06/01/2020	to	Mon 06/01/2020			
0800	Continuous	1530		DYSINGER EAST	<b>2850 MW</b>
Work scheduled by: NYSEG				Impacts Total Transfer Capability	300 MW
				TTC with All Lines In Service	3150 MW
<b>S.RIPLEY-DUNKIRK__230_68</b>					
Mon 06/01/2020	to	Sat 06/06/2020			
1700	Continuous	1700		SCH - PJ - NY	<b>2000 MW</b>
Work scheduled by: PJM				Impacts Total Transfer Capability	150 MW
				TTC with All Lines In Service	2150 MW
<b>SCH-IMO_NY_NIAG_CB_3122_W/BB</b>					
Wed 06/03/2020	to	Thu 06/04/2020			
0500	Continuous	1700		SCH - OH - NY	<b>1700 MW</b> <b>1400 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	200 MW 300 MW
				TTC with All Lines In Service	1900 MW 1700 MW
<b>ROCHESTR-PANNELL__345_RP1</b>					
Wed 06/03/2020	to	Fri 06/05/2020			
0800	Continuous	1500		DYSINGER EAST	<b>2300 MW</b>
Work scheduled by: RGE				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
<b>SCH-NYISO-IMO_NIAGARA_CB_3108</b>					
Fri 06/05/2020	to	Fri 06/05/2020	<u>UPDATED</u> <u>by NYPA</u> <u>05/26/2020</u>		
0500	Continuous	1700		SCH - OH - NY	<b>1500 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	1700 MW
<b>OSWEGO_COMPLEX_AVR_O/S</b>					
Sun 06/07/2020	to	Sun 06/07/2020			
0900	Continuous	0930		CENTRAL EAST - VC	<b>2870 MW</b>
Work scheduled by: Gen				Impacts Total Transfer Capability	105 MW
				TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,May 26, 2020 to Thursday ,November 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event Name	Start	End	Time	Duration	Work by	SCH	Impacts	TTC	FWD	REV	
<b>FROST_BR-LONG_MTN_345_352</b>	Mon 06/08/2020	Fri 06/26/2020	0700	Continuous	1600	ISONE	SCH - NE - NY	1150 MW	250 MW	1400 MW	
							Impacts Total Transfer Capability				
							TTC with All Lines In Service				
<b>SCH-NE-NYISO_LIMIT_300</b>	Mon 06/08/2020	Fri 06/26/2020	0700	Continuous	1600	ISONE	SCH - NE - NY	500 MW	900 MW	1400 MW	
							Impacts Total Transfer Capability				
							TTC with All Lines In Service				
<b>ROCHESTR-PANNELL_345_RP2</b>	Mon 06/08/2020	Wed 06/10/2020	0800	Continuous	1500	RGE	DYSINGER EAST	2300 MW	850 MW	3150 MW	
							Impacts Total Transfer Capability				
							TTC with All Lines In Service				
<b>HOPATCON-RAMAPO_500_5018</b>	Fri 06/12/2020	Fri 06/12/2020	0001	Continuous	2200	ConEd	SCH - PJ - NY	1150 MW	1000 MW	350 MW	1350 MW
							Impacts Total Transfer Capability				
							TTC with All Lines In Service				
<b>HOPATCON-RAMAPO_500_5018</b>	Fri 06/12/2020	Fri 06/12/2020	0001	Continuous	2200	ConEd	UPNY CONED	6025 MW	195 MW	6220 MW	
							Impacts Total Transfer Capability				
							TTC with All Lines In Service				
<b>RAMAPO_345_345_PAR3500</b>	Fri 06/12/2020	Fri 06/12/2020	0001	Continuous	2200	ConEd	SCH - PJ - NY	1800 MW	350 MW	100 MW	1350 MW
							Impacts Total Transfer Capability				
							TTC with All Lines In Service				
<b>RAMAPO_345_345_PAR4500</b>	Fri 06/12/2020	Fri 06/12/2020	0001	Continuous	2200	ConEd	SCH - PJ - NY	1800 MW	350 MW	100 MW	1350 MW
							Impacts Total Transfer Capability				
							TTC with All Lines In Service				

# NYISO TRANSFER LIMITATIONS

Tuesday ,May 26, 2020 to Thursday ,November 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Outage ID	Start Date	End Date	Time	Work Scheduled by	Update Info	Transfer Capability	FWD (Import)	REV (Export)
<b>RAMAPO__500_345_BK_1500</b>	Fri 06/12/2020	Fri 06/12/2020	0001 Continuous	ConEd	<u>UPDATED</u> <u>by CONED</u> <u>04/17/2020</u>	SPR/DUN-SOUTH	1150 MW	1000 MW
						Impacts Total Transfer Capability	1000 MW	350 MW
						TTC with All Lines In Service	2150 MW	1350 MW
<b>RAMAPO__500_345_BK_1500</b>	Fri 06/12/2020	Fri 06/12/2020	0001 Continuous	ConEd	<u>UPDATED</u> <u>by CONED</u> <u>04/17/2020</u>	UPNY CONED	6025 MW	
						Impacts Total Transfer Capability	195 MW	
						TTC with All Lines In Service	6220 MW	
<b>W49TH_ST-E13THSTA_345_M55</b>	Sat 06/13/2020	Sun 06/14/2020	0001 Continuous	ConEd		SPR/DUN-SOUTH	3800 MW	
						Impacts Total Transfer Capability	800 MW	
						TTC with All Lines In Service	4600 MW	
<b>W49TH_ST_345KV_6</b>	Sat 06/13/2020	Sun 06/14/2020	0001 Continuous	ConEd		SCH - PJM_HTP	300 MW	
						Impacts Total Transfer Capability	360 MW	
						TTC with All Lines In Service	660 MW	
<b>BUCHAN_N-EASTVIEW_345_W93</b>	Sun 06/14/2020	Sun 06/14/2020	0001 Continuous	ConEd	<u>UPDATED</u> <u>by CONED</u> <u>04/28/2020</u>	UPNY CONED	4350 MW	
						Impacts Total Transfer Capability	1870 MW	
						TTC with All Lines In Service	6220 MW	
<b>RAMAPO__-BUCHAN_N_345_Y94</b>	Sun 06/14/2020	Sun 06/14/2020	0001 Continuous	ConEd	<u>UPDATED</u> <u>by CONED</u> <u>04/28/2020</u>	UPNY CONED	5765 MW	
						Impacts Total Transfer Capability	455 MW	
						TTC with All Lines In Service	6220 MW	
<b>CHAT_DC_GC1</b>	Sun 06/14/2020	Sun 06/14/2020	0001 Continuous	HQ		MOSES SOUTH	2850 MW	
						Impacts Total Transfer Capability	300 MW	
						TTC with All Lines In Service	3150 MW	



# NYISO TRANSFER LIMITATIONS

Tuesday ,May 26, 2020 to Thursday ,November 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
<p><b>CHAT_DC_GC1</b></p> <p>Sun 06/14/2020 to Sun 06/14/2020 0001 Continuous 0200</p> <p>Work scheduled by: HQ</p>	<p>SCH - HQ - NY</p> <p>Impacts Total Transfer Capability</p> <p>TTC with All Lines In Service</p>		<p>REV (Export) <b>500 MW</b> 500 MW 1000 MW</p>
<hr/>			
<p><b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b></p> <p>Sun 06/14/2020 to Sun 06/14/2020 0001 0200</p> <p>Work scheduled by:</p>	<p>MOSES SOUTH</p> <p>Impacts Total Transfer Capability</p> <p>TTC with All Lines In Service</p>		<p>FWD (Import) <b>2550 MW</b> 600 MW 3150 MW</p>
<hr/>			
<p><b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b></p> <p>Sun 06/14/2020 to Sun 06/14/2020 0001 0200</p> <p>Work scheduled by:</p>	<p>SCH - HQ - NY</p> <p>Impacts Total Transfer Capability</p> <p>TTC with All Lines In Service</p>		<p>FWD REV (Import) (Export) <b>1370 MW 0 MW</b> 130 MW 1000 MW 1500 MW 1000 MW</p>
<hr/>			
<p><b>CHAT_DC_GC2</b></p> <p>Sun 06/14/2020 to Sun 06/14/2020 0001 Continuous 0200</p> <p>Work scheduled by: HQ</p>	<p>MOSES SOUTH</p> <p>Impacts Total Transfer Capability</p> <p>TTC with All Lines In Service</p>		<p>FWD (Import) <b>2850 MW</b> 300 MW 3150 MW</p>
<hr/>			
<p><b>CHAT_DC_GC2</b></p> <p>Sun 06/14/2020 to Sun 06/14/2020 0001 Continuous 0200</p> <p>Work scheduled by: HQ</p>	<p>SCH - HQ - NY</p> <p>Impacts Total Transfer Capability</p> <p>TTC with All Lines In Service</p>		<p>REV (Export) <b>500 MW</b> 500 MW 1000 MW</p>
<hr/>			
<p><b>SCH-HQ-NYISO_LIMIT_1150</b></p> <p>Sun 06/14/2020 to Sun 06/14/2020 0001 Continuous 0200</p> <p>Work scheduled by: HQ</p>	<p>SCH - HQ - NY</p> <p>Impacts Total Transfer Capability</p> <p>TTC with All Lines In Service</p>		<p>FWD (Import) <b>1150 MW</b> 350 MW 1500 MW</p>
<hr/>			
<p><b>BUCHAN_N-EASTVIEW_345_W93</b></p> <p>Sun 06/14/2020 to Sun 06/14/2020 1030 Continuous 1100</p> <p>Work scheduled by: ConEd</p>	<p><b>UPDATED by CONED 04/28/2020</b></p> <p>UPNY CONED</p> <p>Impacts Total Transfer Capability</p> <p>TTC with All Lines In Service</p>		<p>FWD (Import) <b>4350 MW</b> 1870 MW 6220 MW</p>

# NYISO TRANSFER LIMITATIONS

Tuesday ,May 26, 2020 to Thursday ,November 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>RAMAPO__-BUCHAN_N_345_Y94</b>				FWD
Sun 06/14/2020	to	Sun 06/14/2020	<b>UPDATED</b> <b>by CONED</b> <b>04/28/2020</b>	(Import)
1030	Continuous	1100	UPNY CONED	<b>5765 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 455 MW
				TTC with All Lines In Service 6220 MW
<b>ROSETON_-EFISHKIL_345_RFK305</b>				FWD
Mon 06/15/2020	to	Mon 06/15/2020		(Import)
0700	Daily	1600	UPNY CONED	<b>5990 MW</b>
Work scheduled by: CHGE				Impacts Total Transfer Capability 230 MW
				TTC with All Lines In Service 6220 MW
<b>SPRNBRK_-W49TH_ST_345_M51</b>				FWD
Sat 06/27/2020	to	Mon 06/29/2020		(Import)
0001	Continuous	0300	SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW
<b>SPRNBRK__345KV_RNS5</b>				FWD
Sat 06/27/2020	to	Mon 06/29/2020		(Import)
0001	Continuous	0300	SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW
<b>CHAT_DC_GC1</b>				FWD
Sun 06/28/2020	to	Sun 06/28/2020		(Import)
0001	Continuous	0200	MOSES SOUTH	<b>2850 MW</b>
Work scheduled by: HQ				Impacts Total Transfer Capability 300 MW
				TTC with All Lines In Service 3150 MW
<b>CHAT_DC_GC1</b>				REV
Sun 06/28/2020	to	Sun 06/28/2020		(Export)
0001	Continuous	0200	SCH - HQ - NY	<b>500 MW</b>
Work scheduled by: HQ				Impacts Total Transfer Capability 500 MW
				TTC with All Lines In Service 1000 MW
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>				FWD
Sun 06/28/2020	to	Sun 06/28/2020		(Import)
0001		0200	MOSES SOUTH	<b>2550 MW</b>
Work scheduled by:				Impacts Total Transfer Capability 600 MW
				TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,May 26, 2020 to Thursday ,November 25, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

	FWD	REV
	(Import)	(Export)
<hr/>		
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>		
Sun 06/28/2020 to Sun 06/28/2020		
0001 0200		
Work scheduled by:		
	SCH - HQ - NY	<b>1370 MW 0 MW</b>
	Impacts Total Transfer Capability	130 MW 1000 MW
	TTC with All Lines In Service	1500 MW 1000 MW
<hr/>		
<b>CHAT_DC_GC2</b>		
Sun 06/28/2020 to Sun 06/28/2020		
0001 Continuous 0200		
Work scheduled by: HQ		
	MOSES SOUTH	<b>2850 MW</b>
	Impacts Total Transfer Capability	300 MW
	TTC with All Lines In Service	3150 MW
<hr/>		
<b>CHAT_DC_GC2</b>		
Sun 06/28/2020 to Sun 06/28/2020		
0001 Continuous 0200		
Work scheduled by: HQ		
	SCH - HQ - NY	<b>500 MW</b>
	Impacts Total Transfer Capability	500 MW
	TTC with All Lines In Service	1000 MW
<hr/>		
<b>SCH-HQ-NYISO_LIMIT_1150</b>		
Sun 06/28/2020 to Sun 06/28/2020		
0001 Continuous 0200		
Work scheduled by: HQ		
	SCH - HQ - NY	<b>1150 MW</b>
	Impacts Total Transfer Capability	350 MW
	TTC with All Lines In Service	1500 MW
<hr/>		
<b>NIAGARA_345_230_AT4</b>		
Mon 06/29/2020 to Tue 06/30/2020		
0500 Continuous 1530		
Work scheduled by: NYPA		
	SCH - OH - NY	<b>1400 MW</b>
	Impacts Total Transfer Capability	300 MW
	TTC with All Lines In Service	1700 MW
<hr/>		
<b>PORTER_-ROTTRDAM_230_31</b>		
Tue 07/07/2020 to Tue 07/07/2020		
0830 Daily(No Weekends) 1130		
Work scheduled by: NGrid		
	CENTRAL EAST - VC	<b>2805 MW</b>
	Impacts Total Transfer Capability	170 MW
	TTC with All Lines In Service	2975 MW
<hr/>		
<b>SCH-IMO-NYISO_NIAG_CB_3008_W/BB</b>		
Mon 07/27/2020 to Fri 08/07/2020		
0500 Continuous 1530		
Work scheduled by: NYPA		
	SCH - OH - NY	<b>1900 MW 1450 MW</b>
	Impacts Total Transfer Capability	0 MW 250 MW
	TTC with All Lines In Service	1900 MW 1700 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,May 26, 2020 to Thursday ,November 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SAND\_BAR-PLATSBURG\_115\_PV20

Sun 08/09/2020 to Sun 08/16/2020  
 0800 Daily 1600  
 Work scheduled by: ISONE

SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

SAND\_BAR-PLATSBURG\_115\_PV20

Sat 08/22/2020 to Sat 08/29/2020  
 0800 Daily 1600  
 Work scheduled by: ISONE

SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

MEYER\_\_-CANANDGA\_230\_60

Thu 09/10/2020 to Thu 09/10/2020  
 0730 Continuous 1630  
 Work scheduled by: NYSEG

FWD  
 (Import)  
 DYSINGER EAST **2850 MW**  
 Impacts Total Transfer Capability 300 MW  
 TTC with All Lines In Service 3150 MW

MARCY\_\_765\_345\_AT1

Mon 09/14/2020 to Mon 09/14/2020 **UPDATED by NYPA 03/31/2020**  
 0500 Continuous 1730  
 Work scheduled by: NYPA **ARR: 19**

FWD  
 (Import)  
 MOSES SOUTH **1750 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 3150 MW

NIAGARA\_-KINTIGH\_345\_NS1-38

Mon 09/14/2020 to Thu 09/17/2020  
 0500 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 DYSINGER EAST **1400 MW**  
 Impacts Total Transfer Capability 1750 MW  
 TTC with All Lines In Service 3150 MW

BRANCHBG-HOPATCON\_500\_5060

Tue 09/15/2020 to Wed 09/16/2020 **UPDATED by PJM 04/20/2020**  
 0200 Continuous 2300  
 Work scheduled by: PJM

FWD  
 (Import)  
 UPNY CONED **6025 MW**  
 Impacts Total Transfer Capability 195 MW  
 TTC with All Lines In Service 6220 MW

MOSES\_\_-ADIRNDCK\_230\_MA2

Tue 09/15/2020 to Sat 11/14/2020  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2100 MW**  
 Impacts Total Transfer Capability 1050 MW  
 TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,May 26, 2020 to Thursday ,November 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NIAGARA\_-ROCHESTR\_345\_NR2**

Fri 09/18/2020 to Sat 11/14/2020  
 0500 Continuous 2330  
 Work scheduled by: NYPA

FWD  
 (Import)  
 DYSINGER EAST **1400 MW**  
 Impacts Total Transfer Capability 1750 MW  
 TTC with All Lines In Service 3150 MW

**EASTVIEW-SPRNBK\_\_345\_W65**

Sat 09/19/2020 to Sat 09/19/2020  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1870 MW  
 TTC with All Lines In Service 6220 MW

**MILLWOOD-EASTVIEW\_345\_W82**

Sat 09/19/2020 to Sat 09/19/2020  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **5985 MW**  
 Impacts Total Transfer Capability 235 MW  
 TTC with All Lines In Service 6220 MW

**SPRNBK\_\_345KV\_RNS4**

Sat 09/19/2020 to Sat 09/19/2020  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

**EASTVIEW-SPRNBK\_\_345\_W65**

Sat 09/19/2020 to Sat 09/19/2020  
 0330 Continuous 0400  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1870 MW  
 TTC with All Lines In Service 6220 MW

**MILLWOOD-EASTVIEW\_345\_W82**

Sat 09/19/2020 to Sat 09/19/2020  
 0330 Continuous 0400  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **5985 MW**  
 Impacts Total Transfer Capability 235 MW  
 TTC with All Lines In Service 6220 MW

**SPRNBK\_\_345KV\_RNS4**

Sat 09/19/2020 to Sat 09/19/2020  
 0330 Continuous 0400  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,May 26, 2020 to Thursday ,November 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MILLWOOD\_345KV\_18**

Sun 09/20/2020 to Sun 09/20/2020  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1870 MW  
 TTC with All Lines In Service 6220 MW

**BUCHAN\_S-MILLWOOD\_345\_W98**

Sun 09/20/2020 to Fri 09/25/2020  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **6135 MW**  
 Impacts Total Transfer Capability 85 MW  
 TTC with All Lines In Service 6220 MW

**CLAY\_\_-EDIC\_\_345\_1-16**

Mon 09/21/2020 to Fri 09/25/2020  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 OSWEGO EXPORT **4850 MW**  
 Impacts Total Transfer Capability 400 MW  
 TTC with All Lines In Service 5250 MW

**FRASANX-COOPERS\_\_345\_UCC2-41**

Mon 09/21/2020 to Sun 09/27/2020 **UPDATED by NYPA 04/15/2020**  
 0700 Continuous 1730  
 Work scheduled by: NYPA **ARR: 19**

FWD  
 (Import)  
 CENTRAL EAST - VC **2500 MW**  
 Impacts Total Transfer Capability 475 MW  
 TTC with All Lines In Service 2975 MW

**MARCY\_\_-FRASANX\_345\_UCC2-41**

Mon 09/21/2020 to Sun 09/27/2020 **UPDATED by NYPA 04/15/2020**  
 0700 Continuous 1730  
 Work scheduled by: NYPA **ARR: 19**

FWD  
 (Import)  
 CENTRAL EAST - VC **2500 MW**  
 Impacts Total Transfer Capability 475 MW  
 TTC with All Lines In Service 2975 MW

**ROSETON\_-ROCKTVRN\_345\_311**

Mon 09/21/2020 to Fri 10/23/2020 **UPDATED by CHGE 10/09/2019**  
 0800 Continuous 1600  
 Work scheduled by: CHGE

FWD  
 (Import)  
 UPNY CONED **4400 MW**  
 Impacts Total Transfer Capability 1820 MW  
 TTC with All Lines In Service 6220 MW

**MILLWOOD\_345KV\_18**

Fri 09/25/2020 to Fri 09/25/2020  
 0130 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1870 MW  
 TTC with All Lines In Service 6220 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,May 26, 2020 to Thursday ,November 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**EASTVIEW-SPRNBK\_\_345\_W78**

Sat 09/26/2020 to Sun 09/27/2020  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 1870 MW  
TTC with All Lines In Service 6220 MW

**MILLWOOD-EASTVIEW\_345\_W85**

Sat 09/26/2020 to Sun 09/27/2020  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **5985 MW**  
Impacts Total Transfer Capability 235 MW  
TTC with All Lines In Service 6220 MW

**SPRNBK\_\_345KV\_RNS3**

Sat 09/26/2020 to Sun 09/27/2020  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_3**

Mon 09/28/2020 to Sat 10/31/2020  
0001 Continuous 0100

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_4**

Mon 09/28/2020 to Sat 10/31/2020  
0001 Continuous 0100

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**PLSNTVLE-DUNWODIE\_345\_W89**

Mon 09/28/2020 to Sat 10/31/2020  
0001 Continuous 0100

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 2220 MW  
TTC with All Lines In Service 6220 MW

**CLAY\_\_-EDIC\_\_345\_2-15**

Mon 09/28/2020 to Fri 10/02/2020  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,May 26, 2020 to Thursday ,November 25, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MOTTHAVN-RAINEY___345_Q11</b>					FWD	
Thu 10/01/2020	to	Thu 11/05/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>12/17/2019</u>	(Import)
0001	Continuous	0200				<b>3800 MW</b>
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>HUDSONTP-W49TH_ST_345_Y56</b>					FWD	
Fri 10/02/2020	to	Thu 10/08/2020				(Import)
0001	Continuous	0300				<b>0 MW</b>
Work scheduled by: ConEd					SCH - PJM_HTP	
					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	660 MW
<b>W49TH_ST_345KV_7</b>					FWD	
Fri 10/02/2020	to	Thu 10/08/2020				(Import)
0001	Continuous	0300				<b>365 MW</b>
Work scheduled by: ConEd					SCH - PJM_HTP	
					Impacts Total Transfer Capability	295 MW
					TTC with All Lines In Service	660 MW
<b>W49TH_ST_345KV_8</b>					FWD	
Fri 10/02/2020	to	Thu 10/08/2020				(Import)
0001	Continuous	0300				<b>450 MW</b>
Work scheduled by: ConEd					SCH - PJM_HTP	
					Impacts Total Transfer Capability	210 MW
					TTC with All Lines In Service	660 MW
<b>PANNELL_-CLAY___345_1</b>					FWD	
Mon 10/05/2020	to	Fri 10/09/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/07/2020</u>	(Import)
0700	Continuous	1530				<b>1300 MW</b>
Work scheduled by: NYPA					WEST CENTRAL	
					Impacts Total Transfer Capability	950 MW
					TTC with All Lines In Service	2250 MW
<b>SAND_BAR-PLATSBRG_115_PV20</b>					FWD	
Sat 10/17/2020	to	Sat 11/14/2020				(Import)
0600	Continuous	1800				<b>2300 MW</b>
Work scheduled by: ISONE					DYSINGER EAST	
					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
<b>ROCHESTR-PANNELL___345_RP1</b>					FWD	
Mon 10/19/2020	to	Fri 10/23/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>03/10/2020</u>	(Import)
0500	Continuous	1700				<b>2300 MW</b>
Work scheduled by: NYPA					DYSINGER EAST	
					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW



# NYISO TRANSFER LIMITATIONS

Tuesday ,May 26, 2020 to Thursday ,November 25, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SHOR_NPX-SHOREHAM_138_CSC</b>						FWD	REV
Mon 10/19/2020	to	Fri 10/23/2020	<u>UPDATED</u>	<u>by LI</u>	<u>03/02/2020</u>	(Import)	(Export)
0700	Continuous	1500					
Work scheduled by: LI						SCH - NPX_CSC	<b>0 MW 0 MW</b>
						Impacts Total Transfer Capability	330 MW 330 MW
						TTC with All Lines In Service	330 MW 330 MW
<b>PANNELL -CLAY_345_2</b>						FWD	
Mon 10/19/2020	to	Fri 10/23/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/07/2020</u>	(Import)	
0700	Continuous	1530					
Work scheduled by: NYPA						WEST CENTRAL	<b>1300 MW</b>
						Impacts Total Transfer Capability	950 MW
						TTC with All Lines In Service	2250 MW
<b>BERKSHIR-ALPS_345_393</b>						FWD	REV
Mon 10/19/2020	to	Tue 11/10/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>04/01/2020</u>	(Import)	(Export)
0730	Continuous	1330					
Work scheduled by: NGrid						SCH - NE - NY	<b>950 MW 1300 MW</b>
						Impacts Total Transfer Capability	450 MW 300 MW
						TTC with All Lines In Service	1400 MW 1600 MW
							<b>ARR: 78</b>
<b>BERKSHIR-ALPS_345_393</b>						FWD	REV
Mon 10/19/2020	to	Tue 11/10/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>04/01/2020</u>	(Import)	(Export)
0730	Continuous	1330					
Work scheduled by: NGrid						SCH - NPX_1385	<b>100 MW 100 MW</b>
						Impacts Total Transfer Capability	100 MW 100 MW
						TTC with All Lines In Service	200 MW 200 MW
<b>BERKSHIR-ALPS_345_393 &amp; BERKSHIR-NORTHFLD_345_312</b>						FWD	REV
Mon 10/19/2020	to	Tue 11/10/2020				(Import)	(Export)
0730		1330					
Work scheduled by:						SCH - NE - NY	<b>950 MW 1300 MW</b>
						Impacts Total Transfer Capability	450 MW 300 MW
						TTC with All Lines In Service	1400 MW 1600 MW
							<b>ARR: 78</b>
<b>BERKSHIR-NORTHFLD_345_312</b>						FWD	REV
Mon 10/19/2020	to	Tue 11/10/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>04/01/2020</u>	(Import)	(Export)
0730	Continuous	1330					
Work scheduled by: NGrid						SCH - NE - NY	<b>900 MW 1500 MW</b>
						Impacts Total Transfer Capability	500 MW 100 MW
						TTC with All Lines In Service	1400 MW 1600 MW
<b>BERKSHIR-NORTHFLD_345_312</b>						FWD	REV
Mon 10/19/2020	to	Tue 11/10/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>04/01/2020</u>	(Import)	(Export)
0730	Continuous	1330					
Work scheduled by: NGrid						SCH - NPX_1385	<b>100 MW 100 MW</b>
						Impacts Total Transfer Capability	100 MW 100 MW
						TTC with All Lines In Service	200 MW 200 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,May 26, 2020 to Thursday ,November 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LEEDS\_\_\_345\_LEEDS SVC

Mon 10/26/2020 to Fri 10/30/2020  
 0800 Continuous 1600  
 Work scheduled by: NGrid

FWD  
 (Import)  
 CENTRAL EAST - VC **2950 MW**  
 Impacts Total Transfer Capability 25 MW  
 TTC with All Lines In Service 2975 MW

LEEDS\_\_\_-HURLYAVE\_345\_301

Mon 10/26/2020 to Fri 12/04/2020  
 0800 Continuous 1600  
 Work scheduled by: CHGE

FWD  
 (Import)  
 UPNY CONED **4100 MW**  
 Impacts Total Transfer Capability 2120 MW  
 TTC with All Lines In Service 6220 MW

SCH-IMO-NYISO\_LIMIT\_1750

Sun 11/01/2020 to Fri 04/30/2021 **UPDATED by IESO 05/03/2019**  
 0001 Continuous 2359  
 Work scheduled by: IESO

FWD  
 (Import)  
 SCH - OH - NY **2050 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 2050 MW

SCH-NYISO-IMO\_LIMIT\_1600

Sun 11/01/2020 to Fri 04/30/2021 **UPDATED by IESO 05/03/2019**  
 0001 Continuous 2359  
 Work scheduled by: IESO

REV  
 (Export)  
 SCH - OH - NY **1900 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 1900 MW

SPRNBRK\_-W49TH\_ST\_345\_M51

Thu 11/12/2020 to Mon 11/16/2020  
 0001 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

SPRNBRK\_\_345KV\_RNS5

Thu 11/12/2020 to Mon 11/16/2020  
 0001 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

CHATGUAY-MASSENA\_\_765\_7040

Sun 11/15/2020 to Mon 11/30/2020  
 0100 Continuous 1900  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **1550 MW**  
 Impacts Total Transfer Capability 1600 MW  
 TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,May 26, 2020 to Thursday ,November 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**CHATGUAY-MASSENA\_\_765\_7040**

Sun 11/15/2020 to Mon 11/30/2020  
 0100 Continuous 1900

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

-----  
**MARCY\_\_765\_345\_AT1**

Sun 11/15/2020 to Mon 11/30/2020  
 0100 Continuous 1900

Work scheduled by: NYPA

**ARR: 19**

	FWD
	(Import)
MOSES SOUTH	<b>1750 MW</b>
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	3150 MW

-----  
**MARCY\_\_765\_345\_AT2**

Sun 11/15/2020 to Mon 11/30/2020  
 0100 Continuous 1900

Work scheduled by: NYPA

**ARR: 19**

	FWD
	(Import)
MOSES SOUTH	<b>1700 MW</b>
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

-----  
**MASSENA\_-MARCY\_\_765\_MSU1**

Sun 11/15/2020 to Mon 11/30/2020  
 0100 Continuous 1900

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	<b>2265 MW</b>
Impacts Total Transfer Capability	710 MW
TTC with All Lines In Service	2975 MW

-----  
**MASSENA\_-MARCY\_\_765\_MSU1**

Sun 11/15/2020 to Mon 11/30/2020  
 0100 Continuous 1900

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>500 MW</b>
Impacts Total Transfer Capability	2650 MW
TTC with All Lines In Service	3150 MW

-----  
**MASSENA\_-MARCY\_\_765\_MSU1**

Sun 11/15/2020 to Mon 11/30/2020  
 0100 Continuous 1900

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	<b>475 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	1025 MW	0 MW
TTC with All Lines In Service	1500 MW	1000 MW

-----  
**MASSENA\_-MARCY\_\_765\_MSU1**

Sun 11/15/2020 to Mon 11/30/2020  
 0100 Continuous 1900

Work scheduled by: NYPA

	FWD
	(Import)
SCH - HQ_CEDARS	<b>90 MW</b>
Impacts Total Transfer Capability	109 MW
TTC with All Lines In Service	199 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,May 26, 2020 to Thursday ,November 25, 2021

Seasonal Limits

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA\_-MARCY\_\_\_765\_MSU1 & CHATGUAY-MASSENA\_\_\_765\_7040

Sun 11/15/2020 to Mon 11/30/2020  
0100 1900

Work scheduled by:

FWD  
(Import)  
MOSES SOUTH **500 MW**  
Impacts Total Transfer Capability 2650 MW  
TTC with All Lines In Service 3150 MW

MOSES\_\_\_-MASSENA\_\_\_230\_MMS1 & MOSES\_\_\_-MASSENA\_\_\_230\_MMS2

Sun 11/15/2020 to Mon 11/30/2020  
0100 1900

Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - HQ - NY **850 MW 0 MW**  
Impacts Total Transfer Capability 650 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

MOSES\_\_\_-MASSENA\_\_\_230\_MMS1 & MOSES\_\_\_-MASSENA\_\_\_230\_MMS2

Sun 11/15/2020 to Mon 11/30/2020  
0100 1900

Work scheduled by:

FWD  
(Import)  
SCH - HQ\_CEDARS **90 MW**  
Impacts Total Transfer Capability 109 MW  
TTC with All Lines In Service 199 MW

STLAWRNC-MOSES\_\_\_230\_L33P & MASSENA\_-MARCY\_\_\_765\_MSU1

Sun 11/15/2020 to Mon 11/30/2020  
0100 1900

Work scheduled by:

FWD  
(Import)  
SCH - HQ\_CEDARS **90 MW**  
Impacts Total Transfer Capability 109 MW  
TTC with All Lines In Service 199 MW

STLAWRNC-MOSES\_\_\_230\_L33P & MOSES\_\_\_-MASSENA\_\_\_230\_MMS1 & MOSES\_\_\_-  
MASSENA\_\_\_230\_MMS2

Sun 11/15/2020 to Mon 11/30/2020  
0100 1900

Work scheduled by:

FWD  
(Import)  
SCH - HQ\_CEDARS **90 MW**  
Impacts Total Transfer Capability 109 MW  
TTC with All Lines In Service 199 MW

PLSNTVLE-DUNWODIE\_345\_W89

Mon 11/16/2020 to Mon 11/16/2020  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 2220 MW  
TTC with All Lines In Service 6220 MW

PLSNTVLE-DUNWODIE\_345\_W89

Thu 11/26/2020 to Thu 11/26/2020  
0230 Continuous 0300

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 2220 MW  
TTC with All Lines In Service 6220 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,May 26, 2020 to Thursday ,November 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Line ID	Start Date	End Date	Time	Duration	Work by	Impact	TTC
LADENTWN-BUCHAN_S_345_Y88	Mon 11/30/2020	Thu 01/14/2021	0001	Continuous	2359	ORU	5930 MW
							(Import)
							290 MW
							6220 MW
NEPTUNE_-DUFFYAVE_345_NEPTUNE	Mon 11/30/2020	Sun 12/20/2020	0600	Continuous	1600	PJM	0 MW
							(Import)
							660 MW
							660 MW
NEWBRDGE-DUFFYAVE_345_501	Mon 11/30/2020	Sun 12/20/2020	0600	Continuous	1600	PJM	0 MW
							(Import)
							660 MW
							660 MW
MARCY___345KV_CSC	Tue 12/01/2020	Fri 12/11/2020	0700	Continuous	1730	NYPA	2925 MW
							(Import)
							50 MW
							2975 MW
MOSES__-ADIRNDCK_230_MAI	Tue 12/01/2020	Mon 05/31/2021	0700	Continuous	1300	NYPA	2300 MW
							(Import)
							850 MW
							3150 MW
SAND_BAR-PLATSBRG_115_PV20	Mon 12/07/2020	Fri 12/11/2020	0700	Continuous	1530	NYPA	
							(Import)
							700 MW
							400 MW
LONG_MTN-CRICKVLY_345_398	Tue 12/08/2020	Thu 12/10/2020	0700	Continuous	1600	ISONE	700 MW
							(Import)
							400 MW
							1700 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,May 26, 2020 to Thursday ,November 25, 2021

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**LONG\_MTN-CRICKVLY\_345\_398**

Tue 12/08/2020 to Thu 12/10/2020  
0700 Continuous 1600

Work scheduled by: ISONE

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

**SCH-NE-NYISO\_LIMIT\_400**

Tue 12/08/2020 to Thu 12/10/2020  
0700 Continuous 1600

Work scheduled by: ISONE

	FWD
	(Import)
SCH - NE - NY	<b>600 MW</b>
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	1400 MW

**SCH-NYISO-NE\_LIMIT\_1000**

Tue 12/08/2020 to Thu 12/10/2020  
0700 Continuous 1600

Work scheduled by: ISONE

		REV
		(Export)
SCH - NE - NY		<b>1200 MW</b>
Impacts Total Transfer Capability		500 MW
TTC with All Lines In Service		1700 MW

**MARCY -EDIC 345\_UE1-7**

Mon 12/14/2020 to Mon 12/14/2020  
0700 Continuous 1730

Work scheduled by: NYPA

**ARR: 19&16**

	FWD
	(Import)
OSWEGO EXPORT	<b>5250 MW</b>
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	5250 MW

**SAND\_BAR-PLATSBURG\_115\_PV20**

Mon 12/14/2020 to Fri 12/18/2020  
0700 Continuous 1530

Work scheduled by: NYPA

SCH - NE - NY	
Impacts Total Transfer Capability	
TTC with All Lines In Service	

**FRASANNX-COOPERS 345\_UCC2-41**

Tue 12/15/2020 to Wed 12/16/2020  
0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 19**

	FWD
	(Import)
CENTRAL EAST - VC	<b>2500 MW</b>
Impacts Total Transfer Capability	475 MW
TTC with All Lines In Service	2975 MW

**MARCY -FRASANNX\_345\_UCC2-41**

Tue 12/15/2020 to Wed 12/16/2020  
0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 19**

	FWD
	(Import)
CENTRAL EAST - VC	<b>2500 MW</b>
Impacts Total Transfer Capability	475 MW
TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,May 26, 2020 to Thursday ,November 25, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>HOPATCON-RAMAPO__500_5018</b>			FWD	REV
Mon 02/01/2021	to	Wed 02/03/2021	(Import) (Export)	
0001	Continuous	2200	SCH - PJ - NY	<b>1250 MW 1200 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	1650 MW 650 MW
			TTC with All Lines In Service	2900 MW 1850 MW
<b>HOPATCON-RAMAPO__500_5018</b>			FWD	
Mon 02/01/2021	to	Wed 02/03/2021	(Import)	
0001	Continuous	2200	UPNY CONED	<b>6025 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	195 MW
			TTC with All Lines In Service	6220 MW
<b>RAMAPO__345_345_PAR3500</b>			FWD	REV
Mon 02/01/2021	to	Wed 02/03/2021	(Import) (Export)	
0001	Continuous	2200	SCH - PJ - NY	<b>2150 MW 1250 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	750 MW 600 MW
			TTC with All Lines In Service	2900 MW 1850 MW
<b>RAMAPO__345_345_PAR4500</b>			FWD	REV
Mon 02/01/2021	to	Wed 02/03/2021	(Import) (Export)	
0001	Continuous	2200	SCH - PJ - NY	<b>2150 MW 1250 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	750 MW 600 MW
			TTC with All Lines In Service	2900 MW 1850 MW
<b>RAMAPO__500_345_BK 1500</b>			FWD	REV
Mon 02/01/2021	to	Wed 02/03/2021	(Import) (Export)	
0001	Continuous	2200	SCH - PJ - NY	<b>1250 MW 1200 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	1650 MW 650 MW
			TTC with All Lines In Service	2900 MW 1850 MW
<b>RAMAPO__500_345_BK 1500</b>			FWD	
Mon 02/01/2021	to	Wed 02/03/2021	(Import)	
0001	Continuous	2200	UPNY CONED	<b>6025 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	195 MW
			TTC with All Lines In Service	6220 MW
<b>PLSNTVLY-WOOD_ST__345_F30</b>			FWD	
Mon 02/15/2021	to	Tue 02/16/2021	(Import)	
0001	Continuous	0200	UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	2220 MW
			TTC with All Lines In Service	6220 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,May 26, 2020 to Thursday ,November 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY\_345KV\_RNS5

FWD

Mon 02/15/2021 to Tue 02/16/2021

(Import)

0001 Continuous 0200

UPNY CONED

3800 MW

Impacts Total Transfer Capability 2420 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

EFISHKIL-WOOD\_ST\_\_345\_F39

FWD

Thu 02/18/2021 to Sat 02/20/2021

(Import)

2100 Continuous 0200

UPDATED by CE 04/01/2020

UPNY CONED

4000 MW

Impacts Total Transfer Capability 2220 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

WOOD\_ST\_-PLSNTVLE\_345\_Y87

FWD

Thu 02/18/2021 to Sat 02/20/2021

(Import)

2100 Continuous 0200

UPDATED by CE 04/01/2020

UPNY CONED

5905 MW

Impacts Total Transfer Capability 315 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

DUNWODIE\_345KV\_3

FWD

Mon 03/01/2021 to Mon 03/01/2021

(Import)

0001 Continuous 0030

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

DUNWODIE\_345KV\_5

FWD

Mon 03/01/2021 to Mon 03/01/2021

(Import)

0001 Continuous 0030

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

EASTVIEW-SPRNBK\_\_345\_W64

FWD

Mon 03/01/2021 to Mon 03/01/2021

(Import)

0001 Continuous 0030

UPDATED by CONED 01/23/2020

UPNY CONED

4350 MW

Impacts Total Transfer Capability 1870 MW

TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

SPRNBK\_\_345KV\_RNS5

FWD

Mon 03/01/2021 to Mon 03/01/2021

(Import)

0001 Continuous 0030

UPDATED by CONED 01/23/2020

SPR/DUN-SOUTH

3200 MW

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd



# NYISO TRANSFER LIMITATIONS

Tuesday ,May 26, 2020 to Thursday ,November 25, 2021

Seasonal Limits

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MILLWOOD-EASTVIEW\_345\_W99**

Mon 03/01/2021 to Mon 03/22/2021  
0001 Continuous 0200

Work scheduled by: ConEd

**UPDATED by CONED 01/23/2020**

UPNY CONED **5985 MW**  
Impacts Total Transfer Capability 235 MW  
TTC with All Lines In Service 6220 MW

FWD  
(Import)

**DUNWODIE-MOTTHAVN\_345\_71**

Mon 03/01/2021 to Mon 04/05/2021  
0001 Continuous 0300

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

FWD  
(Import)

**MOTTHAVN-RAINEY\_345\_Q11**

Mon 03/01/2021 to Tue 04/06/2021  
0001 Continuous 0700

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

FWD  
(Import)

**EASTVIEW-SPRNBRK\_345\_W64**

Mon 03/22/2021 to Mon 03/22/2021  
0130 Continuous 0200

Work scheduled by: ConEd

**UPDATED by CONED 01/23/2020**

UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 1870 MW  
TTC with All Lines In Service 6220 MW

FWD  
(Import)

**SPRNBRK\_345KV\_RNS5**

Mon 03/22/2021 to Mon 03/22/2021  
0130 Continuous 0200

Work scheduled by: ConEd

**UPDATED by CONED 01/23/2020**

SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

FWD  
(Import)

**CLAY-EDIC\_345\_2-15**

Mon 03/29/2021 to Fri 04/16/2021  
0800 Continuous 1730

Work scheduled by: NYPA

OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

FWD  
(Import)

**DUNWODIE\_345KV\_3**

Mon 04/05/2021 to Mon 04/05/2021  
0230 Continuous 0300

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

FWD  
(Import)

# NYISO TRANSFER LIMITATIONS

Tuesday ,May 26, 2020 to Thursday ,November 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE\_345KV\_5**

Mon 04/05/2021 to Mon 04/05/2021  
 0230 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**SPRNBRK\_-TREMONT\_345\_X28**

Mon 04/19/2021 to Tue 04/20/2021  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **4200 MW**  
 Impacts Total Transfer Capability 400 MW  
 TTC with All Lines In Service 4600 MW

**SCH-IMO-NYISO\_LIMIT\_1600**

Sat 05/01/2021 to Sun 10/31/2021 **UPDATED by IESO 05/03/2019**  
 0001 Continuous 2359  
 Work scheduled by: IESO

FWD  
 (Import)  
 SCH - OH - NY **1900 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 1900 MW

**PANNELL\_-CLAY\_345\_2**

Mon 05/03/2021 to Fri 05/28/2021  
 0700 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
 WEST CENTRAL **1300 MW**  
 Impacts Total Transfer Capability 950 MW  
 TTC with All Lines In Service 2250 MW

**MOSES\_-ADIRNDCK\_230\_MA2**

Tue 06/01/2021 to Sun 11/14/2021  
 0700 Continuous 1300  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2100 MW**  
 Impacts Total Transfer Capability 1050 MW  
 TTC with All Lines In Service 3150 MW

**SPRNBRK\_-W49TH\_ST\_345\_M51**

Fri 10/01/2021 to Sun 10/17/2021  
 0001 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

**SPRNBRK\_345KV\_RNS5**

Fri 10/01/2021 to Sun 10/17/2021  
 0001 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,May 26, 2020 to Thursday ,November 25, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO-NYISO\_LIMIT\_1750

FWD

Mon 11/01/2021 to Fri 12/31/2021 UPDATED by IESO 05/03/2019  
 0001 Continuous 2359

(Import)

Work scheduled by: IESO

SCH - OH - NY **2050 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 2050 MW

SCH-NYISO-IMO\_LIMIT\_1600

REV

Mon 11/01/2021 to Fri 12/31/2021 UPDATED by IESO 05/03/2019  
 0001 Continuous 2359

(Export)

Work scheduled by: IESO

SCH - OH - NY **1900 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 1900 MW