

# NYISO TRANSFER LIMITATIONS

Thursday ,May 28, 2020 to Saturday ,November 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
<b>HUDSONP_-FARRAGUT_345_B3402</b>						
Mon 01/15/2018	to	Thu 10/01/2020	<u>EXTENDED</u>	<u>by CONED</u>	<u>05/03/2020</u>	
0001	Continuous	2359				
Work scheduled by: ConEd					SCH - PJ - NY	<b>2050 MW</b>
					Impacts Total Transfer Capability	150 MW
					TTC with All Lines In Service	2200 MW
<b>HUDSONP_-FARRAGUT_345_B3402 &amp; MARION_-FARRAGUT_345_C3403</b>						
Mon 01/15/2018	to	Thu 10/01/2020				
0001		2359				
Work scheduled by:					SCH - PJ - NY	<b>2000 MW</b>
					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	2200 MW
<b>MARION_-FARRAGUT_345_C3403</b>						
Mon 01/15/2018	to	Thu 10/01/2020	<u>EXTENDED</u>	<u>by CONED</u>	<u>05/03/2020</u>	
0001	Continuous	2359				
Work scheduled by: ConEd					SCH - PJ - NY	<b>2050 MW</b>
					Impacts Total Transfer Capability	150 MW
					TTC with All Lines In Service	2200 MW
<b>STLAWRNC-MOSES_230_L33P</b>						
Mon 04/30/2018	to	Fri 12/31/2021	<u>EXT FORCE</u>	<u>by IESO</u>	<u>08/21/2018</u>	
0456	Continuous	2359				
Work scheduled by: IESO					SCH - OH - NY	
					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
<b>SCH-IMO-NYISO_LIMIT_1600</b>						
Fri 05/01/2020	to	Sat 10/31/2020	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	
0001	Continuous	2359				
Work scheduled by: IESO					SCH - OH - NY	<b>1900 MW</b>
					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	1950 MW
<b>MOSES_-ADIRNDCK_230_MA2</b>						
Mon 05/04/2020	to	Sun 09/13/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>04/20/2020</u>	
0700	Continuous	1730				
Work scheduled by: NYPA					MOSES SOUTH	<b>2100 MW</b>
					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	3150 MW
<b>E13THSTA-FARRAGUT_345_45</b>						
Sun 05/10/2020	to	Sat 05/30/2020	<u>EXTENDED</u>	<u>by CONED</u>	<u>05/28/2020</u>	
0001	Continuous	2300				
Work scheduled by: ConEd					SPR/DUN-SOUTH	<b>3800 MW</b>
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 28, 2020 to Saturday ,November 27, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>W49TH_ST-E13THSTA_345_M54</b>					FWD	
Mon 05/11/2020	to	Sat 05/30/2020	<b>EXTENDED</b>	<b>by CONED</b>	<b>05/28/2020</b>	(Import)
0842	Continuous	2300				<b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW	
					TTC with All Lines In Service 4600 MW	
<b>EGRDNCTY_345_138_AT1</b>					FWD	
Mon 05/18/2020	to	Sat 05/23/2020				(Import)
0001	Continuous	0200				<b>1250 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability 250 MW	
					TTC with All Lines In Service 1500 MW	
<b>EGRDNCTY_345_138_AT2</b>					FWD	
Mon 05/18/2020	to	Sat 05/23/2020				(Import)
0001	Continuous	0200				<b>1250 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability 250 MW	
					TTC with All Lines In Service 1500 MW	
<b>SPRNBRK_-EGRDNCTR_345_Y49</b>					FWD	
Mon 05/18/2020	to	Sat 05/23/2020				(Import)
0001	Continuous	0200				<b>775 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability 725 MW	
					TTC with All Lines In Service 1500 MW	
<b>SCH-NE-NYISO_LIMIT_500</b>					FWD	
Mon 05/18/2020	to	Fri 05/29/2020	<b>UPDATED</b>	<b>by ISONE</b>	<b>05/14/2020</b>	(Import)
0700	Daily	2259				<b>700 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability 700 MW	
					TTC with All Lines In Service 1400 MW	
<b>SCH-NYISO-NE_LIMIT_700</b>					REV	
Mon 05/18/2020	to	Fri 05/29/2020	<b>UPDATED</b>	<b>by ISONE</b>	<b>05/14/2020</b>	(Export)
0700	Daily	2259				<b>900 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability 700 MW	
					TTC with All Lines In Service 1600 MW	
<b>BERKSHIR-ALPS_____345_393</b>					FWD	
Mon 05/18/2020	to	Sat 05/30/2020	<b>UPDATED</b>	<b>by ISONE</b>	<b>05/14/2020</b>	(Import) (Export)
0700	Continuous	1700				<b>950 MW 1300 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability 450 MW	
					TTC with All Lines In Service 1400 MW 1600 MW	
					<b>ARR: 78</b>	

# NYISO TRANSFER LIMITATIONS

Thursday ,May 28, 2020 to Saturday ,November 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
<b>BERKSHIR-ALPS</b> _____ <b>345_393</b>							
Mon 05/18/2020	to	Sat 05/30/2020	<b>UPDATED</b>	<b>by ISONE</b>	<b>05/14/2020</b>		
0700	Continuous	1700				SCH - NPX_1385	<b>100 MW</b>
Work scheduled by: ISONE							
						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
							200 MW
<b>SCH-NYISO-NE_LIMIT_500</b>							REV
Mon 05/18/2020	to	Sat 05/30/2020	<b>UPDATED</b>	<b>by ISONE</b>	<b>05/14/2020</b>		(Export)
2300	Daily	0659				SCH - NE - NY	<b>700 MW</b>
Work scheduled by: ISONE							
						Impacts Total Transfer Capability	900 MW
						TTC with All Lines In Service	1600 MW
<b>MARCY</b> _____ <b>345KV_CSC</b>						FWD	
Sat 05/23/2020	to	Sat 05/23/2020				(Import)	
0600	Continuous	1830				CENTRAL EAST - VC	<b>2925 MW</b>
Work scheduled by: NYPA							
						Impacts Total Transfer Capability	50 MW
						TTC with All Lines In Service	2975 MW
<b>SPRNBK_-TREMONT</b> _____ <b>345_X28</b>						FWD	
Sun 05/24/2020	to	Sun 05/24/2020	<b>UPDATED</b>	<b>by CONED</b>	<b>05/11/2020</b>	(Import)	
0001	Continuous	1800				SPR/DUN-SOUTH	<b>4200 MW</b>
Work scheduled by: ConEd							
						Impacts Total Transfer Capability	400 MW
						TTC with All Lines In Service	4600 MW
<b>LINDN_CG-LNDVFT</b> _____ <b>345_V-3022</b>						FWD	REV
Sun 05/24/2020	to	Sat 05/30/2020	<b>UPDATED</b>	<b>by PJM</b>	<b>02/28/2020</b>	(Import)	(Export)
1400	Continuous	1400				SCH - PJM_VFT	<b>0 MW</b>
Work scheduled by: PJM							
						Impacts Total Transfer Capability	315 MW
						TTC with All Lines In Service	315 MW
<b>MILLWOOD_345KV_18</b>						FWD	
Thu 05/28/2020	to	Thu 05/28/2020	<b>UPDATED</b>	<b>by CONED</b>	<b>04/09/2020</b>	(Import)	
0400	Continuous	0430				UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd							
						Impacts Total Transfer Capability	1870 MW
						TTC with All Lines In Service	6220 MW
<b>LEEDS</b> _____ <b>345KV_R395</b>						FWD	
Thu 05/28/2020	to	Thu 06/11/2020	<b>CANCELLED</b>	<b>by NGrid</b>	<b>05/27/2020</b>	(Import)	
0700	Continuous	1800				UPNY CONED	<b>3800 MW</b>
Work scheduled by: NGrid							
						Impacts Total Transfer Capability	2420 MW
						TTC with All Lines In Service	6220 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 28, 2020 to Saturday ,November 27, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
<b>INDPDNCE-SCRIBA</b> <u>345_25</u>			FWD
Thu 05/28/2020 to Thu 05/28/2020	<b>CANCELLED</b> by <b>NGrid</b> <u>05/28/2020</u>	OSWEGO EXPORT	(Import)
0800 Daily(No Weekends) 1630		Impacts Total Transfer Capability	<b>5250 MW</b>
Work scheduled by: NGrid		TTC with All Lines In Service	0 MW
<hr/>			
<b>SCH-NE-NYISO_LIMIT_500</b>			FWD
Sat 05/30/2020 to Sat 05/30/2020	<b>UPDATED</b> by <b>ISONE</b> <u>05/14/2020</u>	SCH - NE - NY	(Import)
0700 Daily 1700		Impacts Total Transfer Capability	<b>700 MW</b>
Work scheduled by: ISONE		TTC with All Lines In Service	700 MW
<hr/>			
<b>SCH-NYISO-NE_LIMIT_700</b>			REV
Sat 05/30/2020 to Sat 05/30/2020	<b>UPDATED</b> by <b>ISONE</b> <u>05/14/2020</u>	SCH - NE - NY	(Export)
0700 Daily 1700		Impacts Total Transfer Capability	<b>900 MW</b>
Work scheduled by: ISONE		TTC with All Lines In Service	700 MW
<hr/>			
<b>BERKSHIR-ALPS</b> <u>345_393</u> & <b>BERKSHIR-NORTHFLD</b> <u>345_312</u>			FWD REV
Sat 05/30/2020 to Sat 05/30/2020		SCH - NE - NY	(Import) (Export)
1500 1700		Impacts Total Transfer Capability	<b>950 MW 1300 MW</b>
Work scheduled by:	<b>ARR: 78</b>	TTC with All Lines In Service	450 MW 300 MW
<hr/>			
<b>BERKSHIR-NORTHFLD_345_312</b>			FWD REV
Sat 05/30/2020 to Sat 05/30/2020	<b>UPDATED</b> by <b>ISONE</b> <u>05/14/2020</u>	SCH - NE - NY	(Import) (Export)
1500 Continuous 1700		Impacts Total Transfer Capability	<b>900 MW 1500 MW</b>
Work scheduled by: ISONE		TTC with All Lines In Service	500 MW 100 MW
<hr/>			
<b>BERKSHIR-NORTHFLD_345_312</b>			FWD REV
Sat 05/30/2020 to Sat 05/30/2020	<b>UPDATED</b> by <b>ISONE</b> <u>05/14/2020</u>	SCH - NPX_1385	(Import) (Export)
1500 Continuous 1700		Impacts Total Transfer Capability	<b>100 MW 100 MW</b>
Work scheduled by: ISONE		TTC with All Lines In Service	100 MW 100 MW
<hr/>			
<b>SCH-NYISO-IMO_NIAGARA_CB_3002</b>			FWD REV
Mon 06/01/2020 to Tue 06/02/2020	<b>UPDATED</b> by <b>NYPA</b> <u>05/20/2020</u>	SCH - OH - NY	(Import) (Export)
0500 Continuous 1700		Impacts Total Transfer Capability	<b>1300 MW 1150 MW</b>
Work scheduled by: NYPA		TTC with All Lines In Service	650 MW 550 MW
<hr/>			

# NYISO TRANSFER LIMITATIONS

Thursday ,May 28, 2020 to Saturday ,November 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

	FWD	REV
<hr/>		
<b>SHOR_NPX-SHOREHAM_138_CSC</b>		
Mon 06/01/2020 to Tue 06/02/2020		(Import) (Export)
0501 Continuous 2330		
Work scheduled by: LI		
<b>UPDATED by ISONE 03/04/2020</b>		
SCH - NPX_CSC	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	330 MW	330 MW
TTC with All Lines In Service	330 MW	330 MW
<hr/>		
<b>STONYRDG-HILLSIDE_230_72</b>		
Mon 06/01/2020 to Mon 06/01/2020		(Import)
0800 Continuous 1530		
Work scheduled by: NYSEG		
DYSINGER EAST	<b>2850 MW</b>	
Impacts Total Transfer Capability	300 MW	
TTC with All Lines In Service	3150 MW	
<hr/>		
<b>S.RIPLEY-DUNKIRK_230_68</b>		
Mon 06/01/2020 to Fri 06/05/2020		
1600 Continuous 1500		
Work scheduled by: PJM		
SCH - PJ - NY		
Impacts Total Transfer Capability		
TTC with All Lines In Service		
<hr/>		
<b>SCH-IMO_NY_NIAG_CB_3122_W/BB</b>		
Wed 06/03/2020 to Thu 06/04/2020		(Import) (Export)
0500 Continuous 1700		
Work scheduled by: NYPA		
SCH - OH - NY	<b>1700 MW</b>	<b>1400 MW</b>
Impacts Total Transfer Capability	250 MW	300 MW
TTC with All Lines In Service	1950 MW	1700 MW
<hr/>		
<b>ROCHESTR-PANNELL_345_RP1</b>		
Wed 06/03/2020 to Fri 06/05/2020		(Import)
0800 Continuous 1500		
Work scheduled by: RGE		
DYSINGER EAST	<b>2300 MW</b>	
Impacts Total Transfer Capability	850 MW	
TTC with All Lines In Service	3150 MW	
<hr/>		
<b>DUNWODIE_345KV_3</b>		
Fri 06/05/2020 to Sat 06/06/2020		(Import)
0001 Continuous 0200		
Work scheduled by: ConEd		
SPR/DUN-SOUTH	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	
<hr/>		
<b>DUNWODIE_345KV_4</b>		
Fri 06/05/2020 to Sat 06/06/2020		(Import)
0001 Continuous 0200		
Work scheduled by: ConEd		
SPR/DUN-SOUTH	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

# NYISO TRANSFER LIMITATIONS

Thursday ,May 28, 2020 to Saturday ,November 27, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**PLSNTVLE-DUNWODIE\_345\_W89**

Fri 06/05/2020 to Sat 06/06/2020  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
**UPNY CONED 4000 MW**  
 Impacts Total Transfer Capability 2220 MW  
 TTC with All Lines In Service 6220 MW

-----  
**SCH-NYISO-IMO\_NIAGARA\_CB\_3108**

Fri 06/05/2020 to Fri 06/05/2020 **UPDATED by NYPA 05/26/2020**  
 0500 Continuous 1700  
 Work scheduled by: NYPA

REV  
 (Export)  
**SCH - OH - NY 1500 MW**  
 Impacts Total Transfer Capability 200 MW  
 TTC with All Lines In Service 1700 MW

-----  
**OSWEGO\_COMPLEX\_AVR\_O/S**

Sun 06/07/2020 to Sun 06/07/2020  
 0900 Continuous 0930  
 Work scheduled by: Gen

FWD  
 (Import)  
**CENTRAL EAST - VC 2870 MW**  
 Impacts Total Transfer Capability 105 MW  
 TTC with All Lines In Service 2975 MW

-----  
**RAMAPO\_\_-LADENTWN\_345\_W72**

Mon 06/08/2020 to Tue 06/09/2020  
 0001 Continuous 0200  
 Work scheduled by: ORU

FWD  
 (Import)  
**UPNY CONED 4400 MW**  
 Impacts Total Transfer Capability 1820 MW  
 TTC with All Lines In Service 6220 MW

-----  
**FROST\_BR-LONG\_MTN\_345\_352**

Mon 06/08/2020 to Fri 06/26/2020  
 0700 Continuous 1600  
 Work scheduled by: ISONE

FWD  
 (Import)  
**SCH - NE - NY 1150 MW**  
 Impacts Total Transfer Capability 250 MW  
 TTC with All Lines In Service 1400 MW

-----  
**SCH-NE-NYISO\_LIMIT\_300**

Mon 06/08/2020 to Fri 06/26/2020  
 0700 Continuous 1600  
 Work scheduled by: ISONE

FWD  
 (Import)  
**SCH - NE - NY 500 MW**  
 Impacts Total Transfer Capability 900 MW  
 TTC with All Lines In Service 1400 MW

-----  
**ROCHESTR-PANNELL\_345\_RP2**

Mon 06/08/2020 to Wed 06/10/2020  
 0800 Continuous 1500  
 Work scheduled by: RGE

FWD  
 (Import)  
**DYSINGER EAST 2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 28, 2020 to Saturday ,November 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**PLSNTVLY-EFISHKIL\_345\_F36**

Wed 06/10/2020 to Thu 06/11/2020  
 0001 Continuous 0200  
 Work scheduled by: ConEd

UPNY CONED  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

-----  
**HOPATCON-RAMAPO\_\_500\_5018**

Fri 06/12/2020 to Fri 06/12/2020 **UPDATED by CONED 04/17/2020**  
 0001 Continuous 2200  
 Work scheduled by: ConEd

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>1100 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	1100 MW	250 MW
TTC with All Lines In Service	2200 MW	1250 MW

-----  
**HOPATCON-RAMAPO\_\_500\_5018**

Fri 06/12/2020 to Fri 06/12/2020 **UPDATED by CONED 04/17/2020**  
 0001 Continuous 2200  
 Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	<b>6025 MW</b>
Impacts Total Transfer Capability	195 MW
TTC with All Lines In Service	6220 MW

-----  
**RAMAPO\_\_345\_345\_PAR3500**

Fri 06/12/2020 to Fri 06/12/2020 **UPDATED by CONED 04/17/2020**  
 0001 Continuous 2200  
 Work scheduled by: ConEd

	FWD
	(Import)
SCH - PJ - NY	<b>1750 MW</b>
Impacts Total Transfer Capability	450 MW
TTC with All Lines In Service	2200 MW

-----  
**RAMAPO\_\_345\_345\_PAR4500**

Fri 06/12/2020 to Fri 06/12/2020 **UPDATED by CONED 04/17/2020**  
 0001 Continuous 2200  
 Work scheduled by: ConEd

	FWD
	(Import)
SCH - PJ - NY	<b>1750 MW</b>
Impacts Total Transfer Capability	450 MW
TTC with All Lines In Service	2200 MW

-----  
**RAMAPO\_\_500\_345\_BK 1500**

Fri 06/12/2020 to Fri 06/12/2020 **UPDATED by CONED 04/17/2020**  
 0001 Continuous 2200  
 Work scheduled by: ConEd

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>1100 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	1100 MW	250 MW
TTC with All Lines In Service	2200 MW	1250 MW

-----  
**RAMAPO\_\_500\_345\_BK 1500**

Fri 06/12/2020 to Fri 06/12/2020 **UPDATED by CONED 04/17/2020**  
 0001 Continuous 2200  
 Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	<b>6025 MW</b>
Impacts Total Transfer Capability	195 MW
TTC with All Lines In Service	6220 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 28, 2020 to Saturday ,November 27, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>W49TH_ST-E13THSTA_345_M55</b>		FWD
Sat 06/13/2020 to Sun 06/14/2020		(Import)
0001 Continuous 0200	SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd	Impacts Total Transfer Capability	800 MW
	TTC with All Lines In Service	4600 MW
<hr style="border-top: 1px dashed #000;"/>		
<b>W49TH_ST_345KV_6</b>		FWD
Sat 06/13/2020 to Sun 06/14/2020		(Import)
0001 Continuous 0200	SCH - PJM_HTP	<b>300 MW</b>
Work scheduled by: ConEd	Impacts Total Transfer Capability	360 MW
	TTC with All Lines In Service	660 MW
<hr style="border-top: 1px dashed #000;"/>		
<b>BUCHAN_N-EASTVIEW_345_W93</b>		FWD
Sun 06/14/2020 to Sun 06/14/2020	<b>UPDATED by CONED 05/27/2020</b>	(Import)
0001 Continuous 0030	UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd	Impacts Total Transfer Capability	1870 MW
	TTC with All Lines In Service	6220 MW
<hr style="border-top: 1px dashed #000;"/>		
<b>RAMAPO__-BUCHAN_N_345_Y94</b>		FWD
Sun 06/14/2020 to Sun 06/14/2020	<b>UPDATED by CONED 05/27/2020</b>	(Import)
0001 Continuous 0030	UPNY CONED	<b>5765 MW</b>
Work scheduled by: ConEd	Impacts Total Transfer Capability	455 MW
	TTC with All Lines In Service	6220 MW
<hr style="border-top: 1px dashed #000;"/>		
<b>CHAT_DC_GC1</b>		FWD
Sun 06/14/2020 to Sun 06/14/2020		(Import)
0001 Continuous 0200	MOSES SOUTH	<b>2850 MW</b>
Work scheduled by: HQ	Impacts Total Transfer Capability	300 MW
	TTC with All Lines In Service	3150 MW
<hr style="border-top: 1px dashed #000;"/>		
<b>CHAT_DC_GC1</b>		REV
Sun 06/14/2020 to Sun 06/14/2020		(Export)
0001 Continuous 0200	SCH - HQ - NY	<b>500 MW</b>
Work scheduled by: HQ	Impacts Total Transfer Capability	500 MW
	TTC with All Lines In Service	1000 MW
<hr style="border-top: 1px dashed #000;"/>		
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>		FWD
Sun 06/14/2020 to Sun 06/14/2020		(Import)
0001 Continuous 0200	MOSES SOUTH	<b>2550 MW</b>
Work scheduled by:	Impacts Total Transfer Capability	600 MW
	TTC with All Lines In Service	3150 MW



# NYISO TRANSFER LIMITATIONS

Thursday ,May 28, 2020 to Saturday ,November 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC1 & CHAT_DC_GC2		FWD	REV
		(Import)	(Export)
Sun 06/14/2020	to Sun 06/14/2020		
0001	0200	SCH - HQ - NY	<b>1370 MW 0 MW</b>
Work scheduled by:		Impacts Total Transfer Capability	130 MW 1000 MW
		TTC with All Lines In Service	1500 MW 1000 MW
CHAT_DC_GC2		FWD	
		(Import)	
Sun 06/14/2020	to Sun 06/14/2020		
0001	Continuous 0200	MOSES SOUTH	<b>2850 MW</b>
Work scheduled by: HQ		Impacts Total Transfer Capability	300 MW
		TTC with All Lines In Service	3150 MW
CHAT_DC_GC2			REV
			(Export)
Sun 06/14/2020	to Sun 06/14/2020		
0001	Continuous 0200	SCH - HQ - NY	<b>500 MW</b>
Work scheduled by: HQ		Impacts Total Transfer Capability	500 MW
		TTC with All Lines In Service	1000 MW
SCH-HQ-NYISO_LIMIT_1150		FWD	
		(Import)	
Sun 06/14/2020	to Sun 06/14/2020		
0001	Continuous 0200	SCH - HQ - NY	<b>1150 MW</b>
Work scheduled by: HQ		Impacts Total Transfer Capability	350 MW
		TTC with All Lines In Service	1500 MW
BUCHAN_N-EASTVIEW_345_W93		FWD	
		(Import)	
Sun 06/14/2020	to Sun 06/14/2020		
1030	Continuous 1100	<b>UPDATED by CONED 05/27/2020</b>	
Work scheduled by: ConEd		UPNY CONED	<b>4350 MW</b>
		Impacts Total Transfer Capability	1870 MW
		TTC with All Lines In Service	6220 MW
RAMAPO__-BUCHAN_N_345_Y94		FWD	
		(Import)	
Sun 06/14/2020	to Sun 06/14/2020		
1030	Continuous 1100	<b>UPDATED by CONED 05/27/2020</b>	
Work scheduled by: ConEd		UPNY CONED	<b>5765 MW</b>
		Impacts Total Transfer Capability	455 MW
		TTC with All Lines In Service	6220 MW
ROSETON_-EFISHRIL_345_RFK305		FWD	
		(Import)	
Mon 06/15/2020	to Mon 06/15/2020		
0700	Daily 1600	UPNY CONED	<b>5990 MW</b>
Work scheduled by: CHGE		Impacts Total Transfer Capability	230 MW
		TTC with All Lines In Service	6220 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 28, 2020 to Saturday ,November 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**PLSNTVLY\_345KV\_RNS4**

Wed 06/17/2020 to Wed 06/17/2020  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 2420 MW  
 TTC with All Lines In Service 6220 MW

-----  
**PLSNTVLY-WOOD\_ST\_345\_F31**

Wed 06/17/2020 to Thu 06/18/2020  
 0001 Continuous 2200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 2220 MW  
 TTC with All Lines In Service 6220 MW

-----  
**PLSNTVLY\_345KV\_RNS4**

Thu 06/18/2020 to Thu 06/18/2020  
 2130 Continuous 2200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 2420 MW  
 TTC with All Lines In Service 6220 MW

-----  
**SPRNBRK\_345KV\_RNS3**

Tue 06/23/2020 to Tue 06/23/2020  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

-----  
**DUNWODIE\_345KV\_5**

Tue 06/23/2020 to Tue 06/23/2020  
 0001 Continuous 2100  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

-----  
**DUNWODIE\_345KV\_7**

Tue 06/23/2020 to Tue 06/23/2020  
 0001 Continuous 2100  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

-----  
**SPRNBRK\_-DUNWODIE\_345\_W75**

Tue 06/23/2020 to Tue 06/23/2020  
 0001 Continuous 2100  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 28, 2020 to Saturday ,November 27, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SPRNBK__345KV_RNS3</b>			FWD
Tue 06/23/2020	to	Tue 06/23/2020	(Import)
2030	Continuous	2100	SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability 800 MW
			TTC with All Lines In Service 4600 MW
<b>SPRNBK_-W49TH_ST_345_M51</b>			FWD
Sat 06/27/2020	to	Mon 06/29/2020	(Import)
0001	Continuous	0300	SPR/DUN-SOUTH <b>3200 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability 1400 MW
			TTC with All Lines In Service 4600 MW
<b>SPRNBK__345KV_RNS5</b>			FWD
Sat 06/27/2020	to	Mon 06/29/2020	(Import)
0001	Continuous	0300	SPR/DUN-SOUTH <b>3200 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability 1400 MW
			TTC with All Lines In Service 4600 MW
<b>CHAT_DC_GC1</b>			FWD
Sun 06/28/2020	to	Sun 06/28/2020	(Import)
0001	Continuous	0200	MOSES SOUTH <b>2850 MW</b>
Work scheduled by: HQ			Impacts Total Transfer Capability 300 MW
			TTC with All Lines In Service 3150 MW
<b>CHAT_DC_GC1</b>			REV
Sun 06/28/2020	to	Sun 06/28/2020	(Export)
0001	Continuous	0200	SCH - HQ - NY <b>500 MW</b>
Work scheduled by: HQ			Impacts Total Transfer Capability 500 MW
			TTC with All Lines In Service 1000 MW
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>			FWD
Sun 06/28/2020	to	Sun 06/28/2020	(Import)
0001		0200	MOSES SOUTH <b>2550 MW</b>
Work scheduled by:			Impacts Total Transfer Capability 600 MW
			TTC with All Lines In Service 3150 MW
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>			FWD      REV
Sun 06/28/2020	to	Sun 06/28/2020	(Import) (Export)
0001		0200	SCH - HQ - NY <b>1370 MW   0 MW</b>
Work scheduled by:			Impacts Total Transfer Capability 130 MW   1000 MW
			TTC with All Lines In Service 1500 MW   1000 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 28, 2020 to Saturday ,November 27, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CHAT_DC_GC2</b>			FWD
Sun 06/28/2020	to	Sun 06/28/2020	(Import)
0001	Continuous	0200	<b>MOSES SOUTH 2850 MW</b>
Work scheduled by: HQ			Impacts Total Transfer Capability 300 MW
			TTC with All Lines In Service 3150 MW
<b>CHAT_DC_GC2</b>			REV
Sun 06/28/2020	to	Sun 06/28/2020	(Export)
0001	Continuous	0200	<b>SCH - HQ - NY 500 MW</b>
Work scheduled by: HQ			Impacts Total Transfer Capability 500 MW
			TTC with All Lines In Service 1000 MW
<b>SCH-HQ-NYISO_LIMIT_1150</b>			FWD
Sun 06/28/2020	to	Sun 06/28/2020	(Import)
0001	Continuous	0200	<b>SCH - HQ - NY 1150 MW</b>
Work scheduled by: HQ			Impacts Total Transfer Capability 350 MW
			TTC with All Lines In Service 1500 MW
<b>NIAGARA_345_230_AT4</b>			FWD      REV
Mon 06/29/2020	to	Tue 06/30/2020	(Import) (Export)
0500	Continuous	1530	<b>SCH - OH - NY 1900 MW 1400 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability 50 MW 300 MW
			TTC with All Lines In Service 1950 MW 1700 MW
<b>PORTER_-ROTTRDAM_230_31</b>			FWD
Tue 07/07/2020	to	Tue 07/07/2020	(Import)
0830	Daily(No Weekends)	1130	<b>CENTRAL EAST - VC 2805 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability 170 MW
			TTC with All Lines In Service 2975 MW
<b>SCH-IMO-NYISO_NIAG_CB_3008_W/BB</b>			REV
Mon 07/27/2020	to	Fri 08/07/2020	(Export)
0500	Continuous	1530	<b>SCH - OH - NY 1450 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability 250 MW
			TTC with All Lines In Service 1700 MW
<b>SAND_BAR-PLATSBRG_115_PV20</b>			
Sun 08/09/2020	to	Sun 08/16/2020	
0800	Daily	1600	<b>SCH - NE - NY</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability
			TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

Thursday ,May 28, 2020 to Saturday ,November 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SAND\_BAR-PLATSBRG\_115\_PV20**

Sat 08/22/2020 to Sat 08/29/2020  
0800 Daily 1600

Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**MEYER -CANANDGA\_230\_60**

Thu 09/10/2020 to Thu 09/10/2020  
0730 Continuous 1630

Work scheduled by: NYSEG

FWD  
(Import)  
DYSINGER EAST **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

**MARCY 765\_345\_AT1**

Mon 09/14/2020 to Mon 09/14/2020  
0500 Continuous 1730

Work scheduled by: NYPA

**UPDATED by NYPA 03/31/2020**

**ARR: 19**

FWD  
(Import)  
MOSES SOUTH **1750 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 3150 MW

**NIAGARA -KINTIGH\_345\_NS1-38**

Mon 09/14/2020 to Thu 09/17/2020  
0500 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

**BRANCHBG-HOPATCON\_500\_5060**

Tue 09/15/2020 to Wed 09/16/2020  
0200 Continuous 2300

Work scheduled by: PJM

**UPDATED by PJM 04/20/2020**

FWD  
(Import)  
UPNY CONED **6025 MW**  
Impacts Total Transfer Capability 195 MW  
TTC with All Lines In Service 6220 MW

**MOSES -ADIRNDCK\_230\_MA2**

Tue 09/15/2020 to Sat 11/14/2020  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

**NIAGARA -ROCHESTR\_345\_NR2**

Fri 09/18/2020 to Sat 11/14/2020  
0500 Continuous 2330

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 28, 2020 to Saturday ,November 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>EASTVIEW-SPRNBK__345_W65</b>			FWD
Sat 09/19/2020	to	Sat 09/19/2020	(Import)
0001	Continuous	0030	UPNY CONED <b>4350 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability 1870 MW
			TTC with All Lines In Service 6220 MW
<b>MILLWOOD-EASTVIEW_345_W82</b>			FWD
Sat 09/19/2020	to	Sat 09/19/2020	(Import)
0001	Continuous	0030	UPNY CONED <b>5985 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability 235 MW
			TTC with All Lines In Service 6220 MW
<b>SPRNBK__345KV_RNS4</b>			FWD
Sat 09/19/2020	to	Sat 09/19/2020	(Import)
0001	Continuous	0030	SPR/DUN-SOUTH <b>3200 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability 1400 MW
			TTC with All Lines In Service 4600 MW
<b>EASTVIEW-SPRNBK__345_W65</b>			FWD
Sat 09/19/2020	to	Sat 09/19/2020	(Import)
0330	Continuous	0400	UPNY CONED <b>4350 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability 1870 MW
			TTC with All Lines In Service 6220 MW
<b>MILLWOOD-EASTVIEW_345_W82</b>			FWD
Sat 09/19/2020	to	Sat 09/19/2020	(Import)
0330	Continuous	0400	UPNY CONED <b>5985 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability 235 MW
			TTC with All Lines In Service 6220 MW
<b>SPRNBK__345KV_RNS4</b>			FWD
Sat 09/19/2020	to	Sat 09/19/2020	(Import)
0330	Continuous	0400	SPR/DUN-SOUTH <b>3200 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability 1400 MW
			TTC with All Lines In Service 4600 MW
<b>MILLWOOD_345KV_18</b>			FWD
Sun 09/20/2020	to	Sun 09/20/2020	(Import)
0001	Continuous	0030	UPNY CONED <b>4350 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability 1870 MW
			TTC with All Lines In Service 6220 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 28, 2020 to Saturday ,November 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BUCHAN_S-MILLWOOD_345_W98</b>					FWD
Sun 09/20/2020	to	Fri 09/25/2020			(Import)
0001	Continuous	0200		UPNY CONED	<b>6135 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 85 MW
					TTC with All Lines In Service 6220 MW
<b>CLAY -EDIC 345_1-16</b>					FWD
Mon 09/21/2020	to	Fri 09/25/2020			(Import)
0700	Continuous	1530		OSWEGO EXPORT	<b>4850 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 400 MW
					TTC with All Lines In Service 5250 MW
<b>FRASANX-COOPERS 345_UCC2-41</b>					FWD
Mon 09/21/2020	to	Sun 09/27/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>04/15/2020</u>
0700	Continuous	1730			(Import)
Work scheduled by: NYPA					CENTRAL EAST - VC <b>2500 MW</b>
					Impacts Total Transfer Capability 475 MW
					TTC with All Lines In Service 2975 MW
<b>MARCY -FRASANX 345_UCC2-41</b>					FWD
Mon 09/21/2020	to	Sun 09/27/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>04/15/2020</u>
0700	Continuous	1730			(Import)
Work scheduled by: NYPA					CENTRAL EAST - VC <b>2500 MW</b>
					Impacts Total Transfer Capability 475 MW
					TTC with All Lines In Service 2975 MW
<b>ROSETON -ROCKTVRN 345_311</b>					FWD
Mon 09/21/2020	to	Fri 10/23/2020	<u>UPDATED</u>	<u>by CHGE</u>	<u>10/09/2019</u>
0800	Continuous	1600			(Import)
Work scheduled by: CHGE					UPNY CONED <b>4400 MW</b>
					Impacts Total Transfer Capability 1820 MW
					TTC with All Lines In Service 6220 MW
<b>MILLWOOD_345KV_18</b>					FWD
Fri 09/25/2020	to	Fri 09/25/2020			(Import)
0130	Continuous	0200		UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 1870 MW
					TTC with All Lines In Service 6220 MW
<b>EASTVIEW-SPRNBK 345_W78</b>					FWD
Sat 09/26/2020	to	Sun 09/27/2020			(Import)
0001	Continuous	0200		UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 1870 MW
					TTC with All Lines In Service 6220 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 28, 2020 to Saturday ,November 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MILLWOOD-EASTVIEW\_345\_W85**

Sat 09/26/2020 to Sun 09/27/2020  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **5985 MW**  
 Impacts Total Transfer Capability 235 MW  
 TTC with All Lines In Service 6220 MW

**SPRNBRK\_345KV\_RNS3**

Sat 09/26/2020 to Sun 09/27/2020  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_3**

Mon 09/28/2020 to Sat 10/31/2020  
 0001 Continuous 0100  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_4**

Mon 09/28/2020 to Sat 10/31/2020  
 0001 Continuous 0100  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**PLSNTVLE-DUNWODIE\_345\_W89**

Mon 09/28/2020 to Sat 10/31/2020  
 0001 Continuous 0100  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 2220 MW  
 TTC with All Lines In Service 6220 MW

**CLAY-EDIC\_345\_2-15**

Mon 09/28/2020 to Fri 10/02/2020  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 OSWEGO EXPORT **4850 MW**  
 Impacts Total Transfer Capability 400 MW  
 TTC with All Lines In Service 5250 MW

**MOTTHAVN-RAINEY\_345\_Q11**

Thu 10/01/2020 to Thu 11/05/2020 **UPDATED by CONED 12/17/2019**  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW



# NYISO TRANSFER LIMITATIONS

Thursday ,May 28, 2020 to Saturday ,November 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>HUDSONTP-W49TH_ST_345_Y56</b>					FWD	
Fri 10/02/2020	to	Thu 10/08/2020			(Import)	
0001	Continuous	0300		SCH - PJM_HTP	<b>0 MW</b>	
Work scheduled by: ConEd					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	660 MW
<b>W49TH_ST_345KV_7</b>					FWD	
Fri 10/02/2020	to	Thu 10/08/2020			(Import)	
0001	Continuous	0300		SCH - PJM_HTP	<b>365 MW</b>	
Work scheduled by: ConEd					Impacts Total Transfer Capability	295 MW
					TTC with All Lines In Service	660 MW
<b>W49TH_ST_345KV_8</b>					FWD	
Fri 10/02/2020	to	Thu 10/08/2020			(Import)	
0001	Continuous	0300		SCH - PJM_HTP	<b>450 MW</b>	
Work scheduled by: ConEd					Impacts Total Transfer Capability	210 MW
					TTC with All Lines In Service	660 MW
<b>PANNELL -CLAY 345_1</b>					FWD	
Mon 10/05/2020	to	Fri 10/09/2020	<b>UPDATED</b>	<b>by NYPA</b>	<b>05/07/2020</b>	
0700	Continuous	1530		WEST CENTRAL	<b>1300 MW</b>	
Work scheduled by: NYPA					Impacts Total Transfer Capability	950 MW
					TTC with All Lines In Service	2250 MW
<b>SAND_BAR-PLATSBURG_115_PV20</b>						
Sat 10/17/2020	to	Sat 11/14/2020				
0600	Continuous	1800		SCH - NE - NY		
Work scheduled by: ISONE					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
<b>ROCHESTR-PANNELL 345_RP1</b>					FWD	
Mon 10/19/2020	to	Fri 10/23/2020	<b>UPDATED</b>	<b>by NYPA</b>	<b>03/10/2020</b>	
0500	Continuous	1700		DYSINGER EAST	<b>2300 MW</b>	
Work scheduled by: NYPA					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
<b>SHOR_NPX-SHOREHAM_138_CSC</b>					FWD	REV
Mon 10/19/2020	to	Fri 10/23/2020	<b>UPDATED</b>	<b>by LI</b>	<b>03/02/2020</b>	
0700	Continuous	1500		SCH - NPX_CSC	<b>0 MW</b>	<b>0 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability	330 MW
					TTC with All Lines In Service	330 MW



# NYISO TRANSFER LIMITATIONS

Thursday ,May 28, 2020 to Saturday ,November 27, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>LEEDS__-HURLYAVE_345_301</b>					FWD
Mon 10/26/2020	to	Fri 12/04/2020			(Import)
0800	Continuous	1600		UPNY CONED	<b>4100 MW</b>
Work scheduled by: CHGE					Impacts Total Transfer Capability 2120 MW
					TTC with All Lines In Service 6220 MW
<b>SCH-IMO-NYISO_LIMIT_1750</b>					FWD
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>
0001	Continuous	2359		SCH - OH - NY	<b>2050 MW</b>
Work scheduled by: IESO					Impacts Total Transfer Capability 0 MW
					TTC with All Lines In Service 2050 MW
<b>SCH-NYISO-IMO_LIMIT_1600</b>					REV
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>
0001	Continuous	2359		SCH - OH - NY	<b>1900 MW</b>
Work scheduled by: IESO					Impacts Total Transfer Capability 0 MW
					TTC with All Lines In Service 1900 MW
<b>SPRNBRK_-W49TH_ST_345_M51</b>					FWD
Thu 11/12/2020	to	Mon 11/16/2020			(Import)
0001	Continuous	0300		SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW
<b>SPRNBRK__345KV_RNS5</b>					FWD
Thu 11/12/2020	to	Mon 11/16/2020			(Import)
0001	Continuous	0300		SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW
<b>CHATGUAY-MASSENA__765_7040</b>					FWD
Sun 11/15/2020	to	Mon 11/30/2020			(Import)
0100	Continuous	1900		MOSES SOUTH	<b>1550 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 1600 MW
					TTC with All Lines In Service 3150 MW
<b>CHATGUAY-MASSENA__765_7040</b>					FWD
Sun 11/15/2020	to	Mon 11/30/2020			(Import) (Export)
0100	Continuous	1900		SCH - HQ - NY	<b>0 MW</b> <b>0 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 1500 MW 1000 MW
					TTC with All Lines In Service 1500 MW 1000 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 28, 2020 to Saturday ,November 27, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MARCY___765_345_AT1</b>		FWD
Sun 11/15/2020	to Mon 11/30/2020	(Import)
0100	Continuous 1900	MOSES SOUTH <b>1750 MW</b>
Work scheduled by: NYPA	<b>ARR: 19</b>	Impacts Total Transfer Capability 1400 MW
		TTC with All Lines In Service 3150 MW
<b>MARCY___765_345_AT2</b>		FWD
Sun 11/15/2020	to Mon 11/30/2020	(Import)
0100	Continuous 1900	MOSES SOUTH <b>1700 MW</b>
Work scheduled by: NYPA	<b>ARR: 19</b>	Impacts Total Transfer Capability 1450 MW
		TTC with All Lines In Service 3150 MW
<b>MASSENA_-MARCY___765_MSU1</b>		FWD
Sun 11/15/2020	to Mon 11/30/2020	(Import)
0100	Continuous 1900	CENTRAL EAST - VC <b>2265 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability 710 MW
		TTC with All Lines In Service 2975 MW
<b>MASSENA_-MARCY___765_MSU1</b>		FWD
Sun 11/15/2020	to Mon 11/30/2020	(Import)
0100	Continuous 1900	MOSES SOUTH <b>500 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability 2650 MW
		TTC with All Lines In Service 3150 MW
<b>MASSENA_-MARCY___765_MSU1</b>		FWD
Sun 11/15/2020	to Mon 11/30/2020	(Import) (Export)
0100	Continuous 1900	SCH - HQ - NY <b>475 MW 1000 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability 1025 MW 0 MW
		TTC with All Lines In Service 1500 MW 1000 MW
<b>MASSENA_-MARCY___765_MSU1</b>		FWD
Sun 11/15/2020	to Mon 11/30/2020	(Import)
0100	Continuous 1900	SCH - HQ_CEDARS <b>90 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability 109 MW
		TTC with All Lines In Service 199 MW
<b>MASSENA_-MARCY___765_MSU1 &amp; CHATGUAY-MASSENA_765_7040</b>		FWD
Sun 11/15/2020	to Mon 11/30/2020	(Import)
0100	Continuous 1900	MOSES SOUTH <b>500 MW</b>
Work scheduled by:		Impacts Total Transfer Capability 2650 MW
		TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 28, 2020 to Saturday ,November 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES ___-MASSENA___ 230_MMS1 & MOSES ___-MASSENA___ 230_MMS2	FWD	REV
	(Import)	(Export)
Sun 11/15/2020 to Mon 11/30/2020		
0100 1900		
Work scheduled by:	SCH - HQ - NY	850 MW 0 MW
	Impacts Total Transfer Capability	650 MW 1000 MW
	TTC with All Lines In Service	1500 MW 1000 MW
<hr/>		
MOSES ___-MASSENA___ 230_MMS1 & MOSES ___-MASSENA___ 230_MMS2	FWD	
	(Import)	
Sun 11/15/2020 to Mon 11/30/2020		
0100 1900		
Work scheduled by:	SCH - HQ_CEDARS	90 MW
	Impacts Total Transfer Capability	109 MW
	TTC with All Lines In Service	199 MW
<hr/>		
STLAWRNC-MOSES___ 230_L33P & MASSENA_-MARCY___ 765_MSU1	FWD	
	(Import)	
Sun 11/15/2020 to Mon 11/30/2020		
0100 1900		
Work scheduled by:	SCH - HQ_CEDARS	90 MW
	Impacts Total Transfer Capability	109 MW
	TTC with All Lines In Service	199 MW
<hr/>		
STLAWRNC-MOSES___ 230_L33P & MOSES ___-MASSENA___ 230_MMS1 & MOSES ___-MASSENA___ 230_MMS2	FWD	
	(Import)	
Sun 11/15/2020 to Mon 11/30/2020		
0100 1900		
Work scheduled by:	SCH - HQ_CEDARS	90 MW
	Impacts Total Transfer Capability	109 MW
	TTC with All Lines In Service	199 MW
<hr/>		
PLSNTVLE-DUNWODIE_345_W89	FWD	
	(Import)	
Mon 11/16/2020 to Mon 11/16/2020		
0001 Continuous 0030		
Work scheduled by: ConEd	UPNY CONED	4000 MW
	Impacts Total Transfer Capability	2220 MW
	TTC with All Lines In Service	6220 MW
<hr/>		
PLSNTVLE-DUNWODIE_345_W89	FWD	
	(Import)	
Thu 11/26/2020 to Thu 11/26/2020		
0230 Continuous 0300		
Work scheduled by: ConEd	UPNY CONED	4000 MW
	Impacts Total Transfer Capability	2220 MW
	TTC with All Lines In Service	6220 MW
<hr/>		
LADENTWN-BUCHAN_S_345_Y88	FWD	
	(Import)	
Mon 11/30/2020 to Thu 01/14/2021		
0001 Continuous 2359		
Work scheduled by: ORU	UPNY CONED	5930 MW
	Impacts Total Transfer Capability	290 MW
	TTC with All Lines In Service	6220 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 28, 2020 to Saturday ,November 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE**

Mon 11/30/2020 to Sun 12/20/2020  
0600 Continuous 1600

UPDATED by LI 04/29/2020

Work scheduled by: PJM

FWD  
(Import)  
**0 MW**  
SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

**NEWBRDGE-DUFFYAVE\_345\_501**

Mon 11/30/2020 to Sun 12/20/2020  
0600 Continuous 1600

UPDATED by LI 04/29/2020

Work scheduled by: PJM

FWD  
(Import)  
**0 MW**  
SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

**MARCY\_\_\_345KV\_CSC**

Tue 12/01/2020 to Fri 12/11/2020  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
**2925 MW**  
CENTRAL EAST - VC  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

Tue 12/01/2020 to Mon 05/31/2021  
0700 Continuous 1300

Work scheduled by: NYPA

FWD  
(Import)  
**2300 MW**  
MOSES SOUTH  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**SAND\_BAR-PLATSBRG\_115\_PV20**

Mon 12/07/2020 to Fri 12/11/2020  
0700 Continuous 1530

Work scheduled by: NYPA

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**LONG\_MTN-CRICKVLY\_345\_398**

Tue 12/08/2020 to Thu 12/10/2020  
0700 Continuous 1600

Work scheduled by: ISONE

FWD REV  
(Import) (Export)  
**700 MW 1300 MW**  
SCH - NE - NY  
Impacts Total Transfer Capability 700 MW 400 MW  
TTC with All Lines In Service 1400 MW 1700 MW

**LONG\_MTN-CRICKVLY\_345\_398**

Tue 12/08/2020 to Thu 12/10/2020  
0700 Continuous 1600

Work scheduled by: ISONE

FWD REV  
(Import) (Export)  
**100 MW 100 MW**  
SCH - NPX\_1385  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 28, 2020 to Saturday ,November 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_400				FWD	
Tue 12/08/2020	to	Thu 12/10/2020		(Import)	
0700	Continuous	1600		SCH - NE - NY	<b>600 MW</b>
Work scheduled by: ISONE				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	1400 MW
<hr/>					
SCH-NYISO-NE_LIMIT_1000					REV
Tue 12/08/2020	to	Thu 12/10/2020		(Export)	
0700	Continuous	1600		SCH - NE - NY	<b>1200 MW</b>
Work scheduled by: ISONE				Impacts Total Transfer Capability	500 MW
				TTC with All Lines In Service	1700 MW
<hr/>					
MARCY -EDIC 345_UE1-7				FWD	
Mon 12/14/2020	to	Mon 12/14/2020		(Import)	
0700	Continuous	1730		OSWEGO EXPORT	<b>5250 MW</b>
Work scheduled by: NYPA			<b>ARR: 19&amp;16</b>	Impacts Total Transfer Capability	0 MW
				TTC with All Lines In Service	5250 MW
<hr/>					
SAND_BAR-PLATSBRG_115_PV20					
Mon 12/14/2020	to	Fri 12/18/2020		SCH - NE - NY	
0700	Continuous	1530		Impacts Total Transfer Capability	
Work scheduled by: NYPA				TTC with All Lines In Service	
<hr/>					
FRASANNX-COOPERS_345_UCC2-41				FWD	
Tue 12/15/2020	to	Wed 12/16/2020		(Import)	
0700	Continuous	1530		CENTRAL EAST - VC	<b>2500 MW</b>
Work scheduled by: NYPA			<b>ARR: 19</b>	Impacts Total Transfer Capability	475 MW
				TTC with All Lines In Service	2975 MW
<hr/>					
MARCY -FRASANNX_345_UCC2-41				FWD	
Tue 12/15/2020	to	Wed 12/16/2020		(Import)	
0700	Continuous	1530		CENTRAL EAST - VC	<b>2500 MW</b>
Work scheduled by: NYPA			<b>ARR: 19</b>	Impacts Total Transfer Capability	475 MW
				TTC with All Lines In Service	2975 MW
<hr/>					
HOPATCON-RAMAPO_500_5018				FWD	REV
Mon 02/01/2021	to	Wed 02/03/2021		(Import)	(Export)
0001	Continuous	2200		SCH - PJ - NY	<b>1250 MW 1200 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	1650 MW 650 MW
				TTC with All Lines In Service	2900 MW 1850 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 28, 2020 to Saturday ,November 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>HOPATCON-RAMAPO__500_5018</b>			FWD	
Mon 02/01/2021	to	Wed 02/03/2021	(Import)	
0001	Continuous	2200	UPNY CONED	<b>6025 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	195 MW
			TTC with All Lines In Service	6220 MW
<b>RAMAPO__345_345_PAR3500</b>			FWD	REV
Mon 02/01/2021	to	Wed 02/03/2021	(Import)	(Export)
0001	Continuous	2200	SCH - PJ - NY	<b>2150 MW 1250 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	750 MW 600 MW
			TTC with All Lines In Service	2900 MW 1850 MW
<b>RAMAPO__345_345_PAR4500</b>			FWD	REV
Mon 02/01/2021	to	Wed 02/03/2021	(Import)	(Export)
0001	Continuous	2200	SCH - PJ - NY	<b>2150 MW 1250 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	750 MW 600 MW
			TTC with All Lines In Service	2900 MW 1850 MW
<b>RAMAPO__500_345_BK 1500</b>			FWD	REV
Mon 02/01/2021	to	Wed 02/03/2021	(Import)	(Export)
0001	Continuous	2200	SCH - PJ - NY	<b>1250 MW 1200 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	1650 MW 650 MW
			TTC with All Lines In Service	2900 MW 1850 MW
<b>RAMAPO__500_345_BK 1500</b>			FWD	
Mon 02/01/2021	to	Wed 02/03/2021	(Import)	
0001	Continuous	2200	UPNY CONED	<b>6025 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	195 MW
			TTC with All Lines In Service	6220 MW
<b>PLSNTVLY-WOOD_ST__345_F30</b>			FWD	
Mon 02/15/2021	to	Tue 02/16/2021	(Import)	
0001	Continuous	0200	UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	2220 MW
			TTC with All Lines In Service	6220 MW
<b>PLSNTVLY_345KV_RNS5</b>			FWD	
Mon 02/15/2021	to	Tue 02/16/2021	(Import)	
0001	Continuous	0200	UPNY CONED	<b>3800 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	2420 MW
			TTC with All Lines In Service	6220 MW



# NYISO TRANSFER LIMITATIONS

Thursday ,May 28, 2020 to Saturday ,November 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>EFISHKIL-WOOD_ST__345_F39</b>					FWD
Thu 02/18/2021	to	Sat 02/20/2021	<b>UPDATED</b>	<b>by CE</b>	<b>04/01/2020</b>
2100	Continuous	0200			
Work scheduled by: ConEd					
					(Import)
					UPNY CONED <b>4000 MW</b>
					Impacts Total Transfer Capability 2220 MW
					TTC with All Lines In Service 6220 MW
<b>WOOD_ST_-PLSNTVLE_345_Y87</b>					FWD
Thu 02/18/2021	to	Sat 02/20/2021	<b>UPDATED</b>	<b>by CE</b>	<b>04/01/2020</b>
2100	Continuous	0200			
Work scheduled by: ConEd					
					(Import)
					UPNY CONED <b>5905 MW</b>
					Impacts Total Transfer Capability 315 MW
					TTC with All Lines In Service 6220 MW
<b>DUNWODIE_345KV_3</b>					FWD
Mon 03/01/2021	to	Mon 03/01/2021			
0001	Continuous	0030			
Work scheduled by: ConEd					
					(Import)
					SPR/DUN-SOUTH <b>3800 MW</b>
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
<b>DUNWODIE_345KV_5</b>					FWD
Mon 03/01/2021	to	Mon 03/01/2021			
0001	Continuous	0030			
Work scheduled by: ConEd					
					(Import)
					SPR/DUN-SOUTH <b>3800 MW</b>
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
<b>EASTVIEW-SPRNBK__345_W64</b>					FWD
Mon 03/01/2021	to	Mon 03/01/2021	<b>UPDATED</b>	<b>by CONED</b>	<b>01/23/2020</b>
0001	Continuous	0030			
Work scheduled by: ConEd					
					(Import)
					UPNY CONED <b>4350 MW</b>
					Impacts Total Transfer Capability 1870 MW
					TTC with All Lines In Service 6220 MW
<b>SPRNBK__345KV_RNS5</b>					FWD
Mon 03/01/2021	to	Mon 03/01/2021	<b>UPDATED</b>	<b>by CONED</b>	<b>01/23/2020</b>
0001	Continuous	0030			
Work scheduled by: ConEd					
					(Import)
					SPR/DUN-SOUTH <b>3200 MW</b>
					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW
<b>MILLWOOD-EASTVIEW_345_W99</b>					FWD
Mon 03/01/2021	to	Mon 03/22/2021	<b>UPDATED</b>	<b>by CONED</b>	<b>01/23/2020</b>
0001	Continuous	0200			
Work scheduled by: ConEd					
					(Import)
					UPNY CONED <b>5985 MW</b>
					Impacts Total Transfer Capability 235 MW
					TTC with All Lines In Service 6220 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 28, 2020 to Saturday ,November 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE-MOTTHAVN\_345\_71**

Mon 03/01/2021 to Mon 04/05/2021  
 0001 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**MOTTHAVN-RAINEY\_345\_Q11**

Mon 03/01/2021 to Tue 04/06/2021  
 0001 Continuous 0700  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**EASTVIEW-SPRNBK\_345\_W64**

Mon 03/22/2021 to Mon 03/22/2021 **UPDATED by CONED 01/23/2020**  
 0130 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1870 MW  
 TTC with All Lines In Service 6220 MW

**SPRNBK\_345KV\_RNS5**

Mon 03/22/2021 to Mon 03/22/2021 **UPDATED by CONED 01/23/2020**  
 0130 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

**CLAY\_-EDIC\_345\_2-15**

Mon 03/29/2021 to Fri 04/16/2021  
 0800 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
 OSWEGO EXPORT **4850 MW**  
 Impacts Total Transfer Capability 400 MW  
 TTC with All Lines In Service 5250 MW

**DUNWODIE\_345KV\_3**

Mon 04/05/2021 to Mon 04/05/2021  
 0230 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_5**

Mon 04/05/2021 to Mon 04/05/2021  
 0230 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 28, 2020 to Saturday ,November 27, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>				
<b>SPRNBK_-TREMONT__345_X28</b>				
FWD				
Mon 04/19/2021	to	Tue 04/20/2021		(Import)
0001	Continuous	0200	SPR/DUN-SOUTH	<b>4200 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	400 MW
			TTC with All Lines In Service	4600 MW
<hr/>				
<b>SCH-IMO-NYISO_LIMIT_1600</b>				
FWD				
Sat 05/01/2021	to	Sun 10/31/2021	<b>UPDATED</b>	(Import)
0001	Continuous	2359	<b>by IESO</b>	<b>05/03/2019</b>
Work scheduled by: IESO			SCH - OH - NY	<b>1900 MW</b>
			Impacts Total Transfer Capability	50 MW
			TTC with All Lines In Service	1950 MW
<hr/>				
<b>PANNELL_-CLAY____345_2</b>				
FWD				
Mon 05/03/2021	to	Fri 05/28/2021		(Import)
0700	Continuous	1730	WEST CENTRAL	<b>1300 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	950 MW
			TTC with All Lines In Service	2250 MW
<hr/>				
<b>MOSES_-ADIRNDCK_230_MA2</b>				
FWD				
Tue 06/01/2021	to	Sun 11/14/2021		(Import)
0700	Continuous	1300	MOSES SOUTH	<b>2100 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	1050 MW
			TTC with All Lines In Service	3150 MW
<hr/>				
<b>SPRNBK_-W49TH_ST_345_M51</b>				
FWD				
Fri 10/01/2021	to	Sun 10/17/2021		(Import)
0001	Continuous	0300	SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	1400 MW
			TTC with All Lines In Service	4600 MW
<hr/>				
<b>SPRNBK__345KV_RNS5</b>				
FWD				
Fri 10/01/2021	to	Sun 10/17/2021		(Import)
0001	Continuous	0300	SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	1400 MW
			TTC with All Lines In Service	4600 MW
<hr/>				
<b>SCH-IMO-NYISO_LIMIT_1750</b>				
FWD				
Mon 11/01/2021	to	Fri 12/31/2021	<b>UPDATED</b>	(Import)
0001	Continuous	2359	<b>by IESO</b>	<b>05/03/2019</b>
Work scheduled by: IESO			SCH - OH - NY	<b>2050 MW</b>
			Impacts Total Transfer Capability	0 MW
			TTC with All Lines In Service	2050 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 28, 2020 to Saturday ,November 27, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

SCH-NYISO-IMO\_LIMIT\_1600

Mon 11/01/2021 to Fri 12/31/2021  
 0001 Continuous 2359  
 Work scheduled by: IESO

UPDATED by IESO 05/03/2019

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

REV  
 (Export)  
**1900 MW**  
 0 MW  
 1900 MW