

# NYISO TRANSFER LIMITATIONS

Friday ,May 29, 2020 to Sunday ,November 28, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>HUDSONP_-FARRAGUT_345_B3402</b>					FWD	REV
Mon 01/15/2018	to	Thu 10/01/2020	<u><b>EXTENDED</b></u>	<u><b>by CONED</b></u>	<u><b>05/03/2020</b></u>	(Import) (Export)
0001	Continuous	2359				<b>2050 MW 1150 MW</b>
Work scheduled by: ConEd					SCH - PJ - NY	
					Impacts Total Transfer Capability	150 MW 100 MW
					TTC with All Lines In Service	2200 MW 1250 MW
<hr/>						
<b>HUDSONP_-FARRAGUT_345_B3402 &amp; MARION_-FARRAGUT_345_C3403</b>					FWD	REV
Mon 01/15/2018	to	Thu 10/01/2020				(Import) (Export)
0001		2359				<b>2000 MW 1000 MW</b>
Work scheduled by:					SCH - PJ - NY	
					Impacts Total Transfer Capability	200 MW 250 MW
					TTC with All Lines In Service	2200 MW 1250 MW
<hr/>						
<b>MARION_-FARRAGUT_345_C3403</b>					FWD	REV
Mon 01/15/2018	to	Thu 10/01/2020	<u><b>EXTENDED</b></u>	<u><b>by CONED</b></u>	<u><b>05/03/2020</b></u>	(Import) (Export)
0001	Continuous	2359				<b>2050 MW 1150 MW</b>
Work scheduled by: ConEd					SCH - PJ - NY	
					Impacts Total Transfer Capability	150 MW 100 MW
					TTC with All Lines In Service	2200 MW 1250 MW
<hr/>						
<b>STLAWRNC-MOSES_230_L33P</b>						
Mon 04/30/2018	to	Fri 12/31/2021	<u><b>EXT FORCE</b></u>	<u><b>by IESO</b></u>	<u><b>08/21/2018</b></u>	
0456	Continuous	2359				
Work scheduled by: IESO					SCH - OH - NY	
					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
<hr/>						
<b>SCH-IMO-NYISO_LIMIT_1600</b>					FWD	
Fri 05/01/2020	to	Sat 10/31/2020	<u><b>UPDATED</b></u>	<u><b>by IESO</b></u>	<u><b>05/03/2019</b></u>	(Import)
0001	Continuous	2359				<b>1900 MW</b>
Work scheduled by: IESO					SCH - OH - NY	
					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	1950 MW
<hr/>						
<b>MOSES_-ADIRNDCK_230_MA2</b>					FWD	
Mon 05/04/2020	to	Sun 09/13/2020	<u><b>UPDATED</b></u>	<u><b>by NYPA</b></u>	<u><b>04/20/2020</b></u>	(Import)
0700	Continuous	1730				<b>2100 MW</b>
Work scheduled by: NYPA					MOSES SOUTH	
					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	3150 MW
<hr/>						
<b>E13THSTA-FARRAGUT_345_45</b>					FWD	
Sun 05/10/2020	to	Sat 05/30/2020	<u><b>EXTENDED</b></u>	<u><b>by CONED</b></u>	<u><b>05/28/2020</b></u>	(Import)
0001	Continuous	2300				<b>3800 MW</b>
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW

# NYISO TRANSFER LIMITATIONS

Friday ,May 29, 2020 to Sunday ,November 28, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>W49TH_ST-E13THSTA_345_M54</b>					FWD	
Mon 05/11/2020	to	Sat 05/30/2020	<u>EXTENDED</u>	<u>by CONED</u>	<u>05/28/2020</u>	(Import)
0842	Continuous	2300				<b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW	
					TTC with All Lines In Service 4600 MW	
<b>SCH-NE-NYISO_LIMIT_500</b>					FWD	
Mon 05/18/2020	to	Fri 05/29/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>05/14/2020</u>	(Import)
0700	Daily	2259				<b>700 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability 700 MW	
					TTC with All Lines In Service 1400 MW	
<b>SCH-NYISO-NE_LIMIT_700</b>					REV	
Mon 05/18/2020	to	Fri 05/29/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>05/14/2020</u>	(Export)
0700	Daily	2259				<b>900 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability 700 MW	
					TTC with All Lines In Service 1600 MW	
<b>BERKSHIR-ALPS_____345_393</b>					FWD	
Mon 05/18/2020	to	Sat 05/30/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>05/14/2020</u>	(Import) (Export)
0700	Continuous	1700				<b>950 MW 1300 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability 450 MW 300 MW	
					TTC with All Lines In Service 1400 MW 1600 MW	
<b>BERKSHIR-ALPS_____345_393</b>					FWD	
Mon 05/18/2020	to	Sat 05/30/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>05/14/2020</u>	(Import) (Export)
0700	Continuous	1700				<b>100 MW 100 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability 100 MW 100 MW	
					TTC with All Lines In Service 200 MW 200 MW	
<b>SCH-NYISO-NE_LIMIT_500</b>					REV	
Mon 05/18/2020	to	Sat 05/30/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>05/14/2020</u>	(Export)
2300	Daily	0659				<b>700 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability 900 MW	
					TTC with All Lines In Service 1600 MW	
<b>SPRNBRK_-TREMONT__345_X28</b>					FWD	
Sun 05/24/2020	to	Sun 05/24/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>05/11/2020</u>	(Import)
0001	Continuous	1800				<b>4200 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 400 MW	
					TTC with All Lines In Service 4600 MW	

# NYISO TRANSFER LIMITATIONS

Friday ,May 29, 2020 to Sunday ,November 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
<b>LINDN_CG-LNDVFT___345_V-3022</b>							
Sun 05/24/2020	to	Fri 05/29/2020	<u>UPDATED</u>	<u>by PJM</u>	<u>02/28/2020</u>		
1400	Continuous	1630				SCH - PJM_VFT	0 MW 0 MW
Work scheduled by: PJM						Impacts Total Transfer Capability	315 MW 315 MW
						TTC with All Lines In Service	315 MW 315 MW
<b>MILLWOOD_345KV_18</b>						FWD	
						(Import)	
Thu 05/28/2020	to	Thu 05/28/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>04/09/2020</u>	UPNY CONED	4350 MW
0400	Continuous	0430				Impacts Total Transfer Capability	1870 MW
Work scheduled by: ConEd						TTC with All Lines In Service	6220 MW
<b>LEEDS___345KV_R395</b>						FWD	
						(Import)	
Thu 05/28/2020	to	Thu 06/11/2020	<u>CANCELLED</u>	<u>by NGrid</u>	<u>05/27/2020</u>	UPNY CONED	3800 MW
0700	Continuous	1800				Impacts Total Transfer Capability	2420 MW
Work scheduled by: NGrid						TTC with All Lines In Service	6220 MW
<b>INDPDNCE-SCRIBA___345_25</b>						FWD	
						(Import)	
Thu 05/28/2020	to	Thu 05/28/2020	<u>CANCELLED</u>	<u>by NGrid</u>	<u>05/28/2020</u>	OSWEGO EXPORT	5250 MW
0800	Daily(No Weekends)	1630				Impacts Total Transfer Capability	0 MW
Work scheduled by: NGrid						TTC with All Lines In Service	5250 MW
<b>SCH-NE-NYISO_LIMIT_500</b>						FWD	
						(Import)	
Sat 05/30/2020	to	Sat 05/30/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>05/14/2020</u>	SCH - NE - NY	700 MW
0700	Daily	1700				Impacts Total Transfer Capability	700 MW
Work scheduled by: ISONE						TTC with All Lines In Service	1400 MW
<b>SCH-NYISO-NE_LIMIT_700</b>							REV
							(Export)
Sat 05/30/2020	to	Sat 05/30/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>05/14/2020</u>	SCH - NE - NY	900 MW
0700	Daily	1700				Impacts Total Transfer Capability	700 MW
Work scheduled by: ISONE						TTC with All Lines In Service	1600 MW
<b>BERKSHIR-ALPS___345_393 &amp; BERKSHIR-NORTHFLD_345_312</b>						FWD	REV
						(Import)	(Export)
Sat 05/30/2020	to	Sat 05/30/2020				SCH - NE - NY	950 MW 1300 MW
1500		1700				Impacts Total Transfer Capability	450 MW 300 MW
Work scheduled by: <b>ARR: 78</b>						TTC with All Lines In Service	1400 MW 1600 MW

# NYISO TRANSFER LIMITATIONS

Friday ,May 29, 2020 to Sunday ,November 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
<b>BERKSHIR-NORTHFLD_345_312</b>						
Sat 05/30/2020	to	Sat 05/30/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>05/14/2020</u>	
1500	Continuous	1700				
Work scheduled by: ISONE					SCH - NE - NY	<b>900 MW</b>
					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1400 MW
<b>BERKSHIR-NORTHFLD_345_312</b>						
Sat 05/30/2020	to	Sat 05/30/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>05/14/2020</u>	
1500	Continuous	1700				
Work scheduled by: ISONE					SCH - NPX_1385	<b>100 MW</b>
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
<b>SCH-NYISO-IMO_NIAGARA_CB_3002</b>						
Mon 06/01/2020	to	Tue 06/02/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/20/2020</u>	
0500	Continuous	1700				
Work scheduled by: NYPA					SCH - OH - NY	<b>1300 MW</b>
					Impacts Total Transfer Capability	650 MW
					TTC with All Lines In Service	1950 MW
<b>SHOR_NPX-SHOREHAM_138_CSC</b>						
Mon 06/01/2020	to	Tue 06/02/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>03/04/2020</u>	
0501	Continuous	2330				
Work scheduled by: LI					SCH - NPX_CSC	<b>0 MW</b>
					Impacts Total Transfer Capability	330 MW
					TTC with All Lines In Service	330 MW
<b>STONYRDG-HILLSIDE_230_72</b>						
Mon 06/01/2020	to	Mon 06/01/2020				
0800	Continuous	1530				
Work scheduled by: NYSEG					DYSINGER EAST	<b>2850 MW</b>
					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW
<b>S.RIPLEY-DUNKIRK_230_68</b>						
Mon 06/01/2020	to	Fri 06/05/2020				
1600	Continuous	1500				
Work scheduled by: PJM					SCH - PJ - NY	
					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
<b>SCH-IMO_NY_NIAG_CB_3122_W/BB</b>						
Wed 06/03/2020	to	Thu 06/04/2020				
0500	Continuous	1700				
Work scheduled by: NYPA					SCH - OH - NY	<b>1700 MW</b>
					Impacts Total Transfer Capability	250 MW
					TTC with All Lines In Service	1950 MW

# NYISO TRANSFER LIMITATIONS

Friday ,May 29, 2020 to Sunday ,November 28, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>ROCHESTR-PANNELL__345_RP1</b>				FWD
Wed 06/03/2020	to	Fri 06/05/2020		(Import)
0800	Continuous	1500	DYSINGER EAST	<b>2300 MW</b>
Work scheduled by: RGE				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW
<b>DUNWODIE_345KV_3</b>				FWD
Fri 06/05/2020	to	Sat 06/06/2020		(Import)
0001	Continuous	0200	SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
<b>DUNWODIE_345KV_4</b>				FWD
Fri 06/05/2020	to	Sat 06/06/2020		(Import)
0001	Continuous	0200	SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
<b>PLSNTVLE-DUNWODIE_345_W89</b>				FWD
Fri 06/05/2020	to	Sat 06/06/2020		(Import)
0001	Continuous	0200	UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 2220 MW
				TTC with All Lines In Service 6220 MW
<b>SCH-NYISO-IMO_NIAGARA_CB_3108</b>				REV
Fri 06/05/2020	to	Fri 06/05/2020	<b>UPDATED by NYPA 05/26/2020</b>	(Export)
0500	Continuous	1700	SCH - OH - NY	<b>1500 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability 200 MW
				TTC with All Lines In Service 1700 MW
<b>OSWEGO_COMPLEX_AVR_O/S</b>				FWD
Sun 06/07/2020	to	Sun 06/07/2020		(Import)
0900	Continuous	0930	CENTRAL EAST - VC	<b>2870 MW</b>
Work scheduled by: Gen				Impacts Total Transfer Capability 105 MW
				TTC with All Lines In Service 2975 MW
<b>W49TH_ST_345KV_5</b>				FWD
Mon 06/08/2020	to	Mon 06/08/2020		(Import)
0001	Continuous	0030	SCH - PJM_HTP	<b>300 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 360 MW
				TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

Friday ,May 29, 2020 to Sunday ,November 28, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**RAMAPO\_\_-LADENTWN\_345\_W72**

Mon 06/08/2020 to Tue 06/09/2020  
 0001 Continuous 0200  
 Work scheduled by: ORU

FWD  
 (Import)  
 UPNY CONED **4400 MW**  
 Impacts Total Transfer Capability 1820 MW  
 TTC with All Lines In Service 6220 MW

-----  
**SPRNBRK\_-W49TH\_ST\_345\_M52**

Mon 06/08/2020 to Wed 06/10/2020  
 0001 Continuous 2200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

-----  
**SPRNBRK\_\_345KV\_RNS4**

Mon 06/08/2020 to Wed 06/10/2020  
 0001 Continuous 2200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

-----  
**FROST\_BR-LONG\_MTN\_345\_352**

Mon 06/08/2020 to Fri 06/26/2020  
 0700 Continuous 1600  
 Work scheduled by: ISONE

FWD  
 (Import)  
 SCH - NE - NY **1150 MW**  
 Impacts Total Transfer Capability 250 MW  
 TTC with All Lines In Service 1400 MW

-----  
**SCH-NE-NYISO\_LIMIT\_300**

Mon 06/08/2020 to Fri 06/26/2020  
 0700 Continuous 1600  
 Work scheduled by: ISONE

FWD  
 (Import)  
 SCH - NE - NY **500 MW**  
 Impacts Total Transfer Capability 900 MW  
 TTC with All Lines In Service 1400 MW

-----  
**ROCHESTR-PANNELL\_\_345\_RP2**

Mon 06/08/2020 to Wed 06/10/2020  
 0800 Continuous 1500  
 Work scheduled by: RGE

FWD  
 (Import)  
 DYSINGER EAST **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

-----  
**PLSNTVLY-EFISHKIL\_345\_F36**

Wed 06/10/2020 to Thu 06/11/2020  
 0001 Continuous 0200  
 Work scheduled by: ConEd

UPNY CONED  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

Friday ,May 29, 2020 to Sunday ,November 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST\_345KV\_5**

Wed 06/10/2020 to Wed 06/10/2020  
 2130 Continuous 2200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

**HOPATCON-RAMAPO\_\_500\_5018**

Fri 06/12/2020 to Fri 06/12/2020 UPDATED by CONED 04/17/2020  
 0001 Continuous 2200  
 Work scheduled by: ConEd

FWD REV  
 (Import) (Export)  
 SCH - PJ - NY **1100 MW 1000 MW**  
 Impacts Total Transfer Capability 1100 MW 250 MW  
 TTC with All Lines In Service 2200 MW 1250 MW

**HOPATCON-RAMAPO\_\_500\_5018**

Fri 06/12/2020 to Fri 06/12/2020 UPDATED by CONED 04/17/2020  
 0001 Continuous 2200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **6025 MW**  
 Impacts Total Transfer Capability 195 MW  
 TTC with All Lines In Service 6220 MW

**RAMAPO\_\_345\_345\_PAR3500**

Fri 06/12/2020 to Fri 06/12/2020 UPDATED by CONED 04/17/2020  
 0001 Continuous 2200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SCH - PJ - NY **1750 MW**  
 Impacts Total Transfer Capability 450 MW  
 TTC with All Lines In Service 2200 MW

**RAMAPO\_\_345\_345\_PAR4500**

Fri 06/12/2020 to Fri 06/12/2020 UPDATED by CONED 04/17/2020  
 0001 Continuous 2200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SCH - PJ - NY **1750 MW**  
 Impacts Total Transfer Capability 450 MW  
 TTC with All Lines In Service 2200 MW

**RAMAPO\_\_500\_345\_BK 1500**

Fri 06/12/2020 to Fri 06/12/2020 UPDATED by CONED 04/17/2020  
 0001 Continuous 2200  
 Work scheduled by: ConEd

FWD REV  
 (Import) (Export)  
 SCH - PJ - NY **1100 MW 1000 MW**  
 Impacts Total Transfer Capability 1100 MW 250 MW  
 TTC with All Lines In Service 2200 MW 1250 MW

**RAMAPO\_\_500\_345\_BK 1500**

Fri 06/12/2020 to Fri 06/12/2020 UPDATED by CONED 04/17/2020  
 0001 Continuous 2200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **6025 MW**  
 Impacts Total Transfer Capability 195 MW  
 TTC with All Lines In Service 6220 MW

# NYISO TRANSFER LIMITATIONS

Friday ,May 29, 2020 to Sunday ,November 28, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST-E13THSTA\_345\_M55**

Sat 06/13/2020 to Sun 06/14/2020  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**W49TH\_ST\_345KV\_6**

Sat 06/13/2020 to Sun 06/14/2020  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

**BUCHAN\_N-EASTVIEW\_345\_W93**

Sun 06/14/2020 to Sun 06/14/2020 **UPDATED by CONED 05/27/2020**  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1870 MW  
 TTC with All Lines In Service 6220 MW

**RAMAPO\_\_-BUCHAN\_N\_345\_Y94**

Sun 06/14/2020 to Sun 06/14/2020 **UPDATED by CONED 05/27/2020**  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **5765 MW**  
 Impacts Total Transfer Capability 455 MW  
 TTC with All Lines In Service 6220 MW

**CHAT\_DC\_GC1**

Sun 06/14/2020 to Sun 06/14/2020  
 0001 Continuous 0200  
 Work scheduled by: HQ

FWD  
 (Import)  
 MOSES SOUTH **2850 MW**  
 Impacts Total Transfer Capability 300 MW  
 TTC with All Lines In Service 3150 MW

**CHAT\_DC\_GC1**

Sun 06/14/2020 to Sun 06/14/2020  
 0001 Continuous 0200  
 Work scheduled by: HQ

REV  
 (Export)  
 SCH - HQ - NY **500 MW**  
 Impacts Total Transfer Capability 500 MW  
 TTC with All Lines In Service 1000 MW

**CHAT\_DC\_GC1 & CHAT\_DC\_GC2**

Sun 06/14/2020 to Sun 06/14/2020  
 0001 0200  
 Work scheduled by:

FWD  
 (Import)  
 MOSES SOUTH **2550 MW**  
 Impacts Total Transfer Capability 600 MW  
 TTC with All Lines In Service 3150 MW



# NYISO TRANSFER LIMITATIONS

Friday ,May 29, 2020 to Sunday ,November 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>				FWD	REV
				(Import)	(Export)
Sun 06/14/2020	to	Sun 06/14/2020		SCH - HQ - NY	<b>1370 MW 0 MW</b>
0001		0200		Impacts Total Transfer Capability	130 MW 1000 MW
Work scheduled by:				TTC with All Lines In Service	1500 MW 1000 MW
<b>CHAT_DC_GC2</b>				FWD	
				(Import)	
Sun 06/14/2020	to	Sun 06/14/2020		MOSES SOUTH	<b>2850 MW</b>
0001	Continuous	0200		Impacts Total Transfer Capability	300 MW
Work scheduled by: HQ				TTC with All Lines In Service	3150 MW
<b>CHAT_DC_GC2</b>					REV
					(Export)
Sun 06/14/2020	to	Sun 06/14/2020		SCH - HQ - NY	<b>500 MW</b>
0001	Continuous	0200		Impacts Total Transfer Capability	500 MW
Work scheduled by: HQ				TTC with All Lines In Service	1000 MW
<b>SCH-HQ-NYISO_LIMIT_1150</b>				FWD	
				(Import)	
Sun 06/14/2020	to	Sun 06/14/2020		SCH - HQ - NY	<b>1150 MW</b>
0001	Continuous	0200		Impacts Total Transfer Capability	350 MW
Work scheduled by: HQ				TTC with All Lines In Service	1500 MW
<b>BUCHAN_N-EASTVIEW_345_W93</b>				FWD	
				(Import)	
Sun 06/14/2020	to	Sun 06/14/2020	<b>UPDATED by CONED 05/27/2020</b>	UPNY CONED	<b>4350 MW</b>
1030	Continuous	1100		Impacts Total Transfer Capability	1870 MW
Work scheduled by: ConEd				TTC with All Lines In Service	6220 MW
<b>RAMAPO__-BUCHAN_N_345_Y94</b>				FWD	
				(Import)	
Sun 06/14/2020	to	Sun 06/14/2020	<b>UPDATED by CONED 05/27/2020</b>	UPNY CONED	<b>5765 MW</b>
1030	Continuous	1100		Impacts Total Transfer Capability	455 MW
Work scheduled by: ConEd				TTC with All Lines In Service	6220 MW
<b>ROSETON_-EFISHRIL_345_RFK305</b>				FWD	
				(Import)	
Mon 06/15/2020	to	Mon 06/15/2020		UPNY CONED	<b>5990 MW</b>
0700	Daily	1600		Impacts Total Transfer Capability	230 MW
Work scheduled by: CHGE				TTC with All Lines In Service	6220 MW

# NYISO TRANSFER LIMITATIONS

Friday ,May 29, 2020 to Sunday ,November 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**PLSNTVLY\_345KV\_RNS4**

Wed 06/17/2020 to Wed 06/17/2020  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 2420 MW  
 TTC with All Lines In Service 6220 MW

-----  
**PLSNTVLY-WOOD\_ST\_345\_F31**

Wed 06/17/2020 to Thu 06/18/2020  
 0001 Continuous 2200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 2220 MW  
 TTC with All Lines In Service 6220 MW

-----  
**PLSNTVLY\_345KV\_RNS4**

Thu 06/18/2020 to Thu 06/18/2020  
 2130 Continuous 2200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 2420 MW  
 TTC with All Lines In Service 6220 MW

-----  
**SPRNBRK\_345KV\_RNS3**

Tue 06/23/2020 to Tue 06/23/2020  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

-----  
**DUNWODIE\_345KV\_5**

Tue 06/23/2020 to Tue 06/23/2020  
 0001 Continuous 2100  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

-----  
**DUNWODIE\_345KV\_7**

Tue 06/23/2020 to Tue 06/23/2020  
 0001 Continuous 2100  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

-----  
**SPRNBRK\_-DUNWODIE\_345\_W75**

Tue 06/23/2020 to Tue 06/23/2020  
 0001 Continuous 2100  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Friday ,May 29, 2020 to Sunday ,November 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**SPRNBRK\_\_345KV\_RNS3**

Tue 06/23/2020 to Tue 06/23/2020  
 2030 Continuous 2100  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

-----  
**SPRNBRK\_-W49TH\_ST\_345\_M51**

Sat 06/27/2020 to Mon 06/29/2020  
 0001 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

-----  
**SPRNBRK\_\_345KV\_RNS5**

Sat 06/27/2020 to Mon 06/29/2020  
 0001 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

-----  
**CHAT\_DC\_GC1**

Sun 06/28/2020 to Sun 06/28/2020  
 0001 Continuous 0200  
 Work scheduled by: HQ

FWD  
 (Import)  
 MOSES SOUTH **2850 MW**  
 Impacts Total Transfer Capability 300 MW  
 TTC with All Lines In Service 3150 MW

-----  
**CHAT\_DC\_GC1**

Sun 06/28/2020 to Sun 06/28/2020  
 0001 Continuous 0200  
 Work scheduled by: HQ

REV  
 (Export)  
 SCH - HQ - NY **500 MW**  
 Impacts Total Transfer Capability 500 MW  
 TTC with All Lines In Service 1000 MW

-----  
**CHAT\_DC\_GC1 & CHAT\_DC\_GC2**

Sun 06/28/2020 to Sun 06/28/2020  
 0001 0200  
 Work scheduled by:

FWD  
 (Import)  
 MOSES SOUTH **2550 MW**  
 Impacts Total Transfer Capability 600 MW  
 TTC with All Lines In Service 3150 MW

-----  
**CHAT\_DC\_GC1 & CHAT\_DC\_GC2**

Sun 06/28/2020 to Sun 06/28/2020  
 0001 0200  
 Work scheduled by:

FWD REV  
 (Import) (Export)  
 SCH - HQ - NY **1370 MW 0 MW**  
 Impacts Total Transfer Capability 130 MW 1000 MW  
 TTC with All Lines In Service 1500 MW 1000 MW

# NYISO TRANSFER LIMITATIONS

Friday ,May 29, 2020 to Sunday ,November 28, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CHAT_DC_GC2</b>			FWD
Sun 06/28/2020	to	Sun 06/28/2020	(Import)
0001	Continuous	0200	<b>MOSES SOUTH</b> <b>2850 MW</b>
Work scheduled by: HQ			Impacts Total Transfer Capability 300 MW TTC with All Lines In Service 3150 MW
<b>CHAT_DC_GC2</b>			REV
Sun 06/28/2020	to	Sun 06/28/2020	(Export)
0001	Continuous	0200	<b>SCH - HQ - NY</b> <b>500 MW</b>
Work scheduled by: HQ			Impacts Total Transfer Capability 500 MW TTC with All Lines In Service 1000 MW
<b>SCH-HQ-NYISO_LIMIT_1150</b>			FWD
Sun 06/28/2020	to	Sun 06/28/2020	(Import)
0001	Continuous	0200	<b>SCH - HQ - NY</b> <b>1150 MW</b>
Work scheduled by: HQ			Impacts Total Transfer Capability 350 MW TTC with All Lines In Service 1500 MW
<b>NIAGARA_345_230_AT4</b>			FWD      REV
Mon 06/29/2020	to	Tue 06/30/2020	(Import) (Export)
0500	Continuous	1530	<b>SCH - OH - NY</b> <b>1900 MW    1400 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability 50 MW    300 MW TTC with All Lines In Service 1950 MW    1700 MW
<b>PORTER_-ROTTRDAM_230_31</b>			FWD
Tue 07/07/2020	to	Tue 07/07/2020	(Import)
0830	Daily(No Weekends)	1130	<b>CENTRAL EAST - VC</b> <b>2805 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability 170 MW TTC with All Lines In Service 2975 MW
<b>SCH-IMO-NYISO_NIAG_CB_3008_W/BB</b>			REV
Mon 07/27/2020	to	Fri 08/07/2020	(Export)
0500	Continuous	1530	<b>SCH - OH - NY</b> <b>1450 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability 250 MW TTC with All Lines In Service 1700 MW
<b>SAND_BAR-PLATSBRG_115_PV20</b>			
Sun 08/09/2020	to	Sun 08/16/2020	
0800	Daily	1600	<b>SCH - NE - NY</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

Friday ,May 29, 2020 to Sunday ,November 28, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SAND\_BAR-PLATSBRG\_115\_PV20**

Sat 08/22/2020 to Sat 08/29/2020  
 0800 Daily 1600  
 Work scheduled by: ISONE

SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**MEYER -CANANDGA\_230\_60**

Thu 09/10/2020 to Thu 09/10/2020  
 0730 Continuous 1630  
 Work scheduled by: NYSEG

FWD  
 (Import)  
 DYSINGER EAST **2850 MW**  
 Impacts Total Transfer Capability 300 MW  
 TTC with All Lines In Service 3150 MW

**MARCY 765\_345\_AT1**

Mon 09/14/2020 to Mon 09/14/2020 **UPDATED by NYPA 03/31/2020**  
 0500 Continuous 1730  
 Work scheduled by: NYPA **ARR: 19**

FWD  
 (Import)  
 MOSES SOUTH **1750 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 3150 MW

**NIAGARA -KINTIGH\_345\_NS1-38**

Mon 09/14/2020 to Thu 09/17/2020  
 0500 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 DYSINGER EAST **1400 MW**  
 Impacts Total Transfer Capability 1750 MW  
 TTC with All Lines In Service 3150 MW

**BRANCHBG-HOPATCON\_500\_5060**

Tue 09/15/2020 to Wed 09/16/2020 **UPDATED by PJM 04/20/2020**  
 0200 Continuous 2300  
 Work scheduled by: PJM

FWD  
 (Import)  
 UPNY CONED **6025 MW**  
 Impacts Total Transfer Capability 195 MW  
 TTC with All Lines In Service 6220 MW

**MOSES -ADIRNDCK\_230\_MA2**

Tue 09/15/2020 to Sat 11/14/2020  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2100 MW**  
 Impacts Total Transfer Capability 1050 MW  
 TTC with All Lines In Service 3150 MW

**NIAGARA -ROCHESTR\_345\_NR2**

Fri 09/18/2020 to Sat 11/14/2020  
 0500 Continuous 2330  
 Work scheduled by: NYPA

FWD  
 (Import)  
 DYSINGER EAST **1400 MW**  
 Impacts Total Transfer Capability 1750 MW  
 TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Friday ,May 29, 2020 to Sunday ,November 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>EASTVIEW-SPRNBK__345_W65</b>			FWD
Sat 09/19/2020	to	Sat 09/19/2020	(Import)
0001	Continuous	0030	UPNY CONED <b>4350 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability 1870 MW
			TTC with All Lines In Service 6220 MW
<b>MILLWOOD-EASTVIEW_345_W82</b>			FWD
Sat 09/19/2020	to	Sat 09/19/2020	(Import)
0001	Continuous	0030	UPNY CONED <b>5985 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability 235 MW
			TTC with All Lines In Service 6220 MW
<b>SPRNBK__345KV_RNS4</b>			FWD
Sat 09/19/2020	to	Sat 09/19/2020	(Import)
0001	Continuous	0030	SPR/DUN-SOUTH <b>3200 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability 1400 MW
			TTC with All Lines In Service 4600 MW
<b>EASTVIEW-SPRNBK__345_W65</b>			FWD
Sat 09/19/2020	to	Sat 09/19/2020	(Import)
0330	Continuous	0400	UPNY CONED <b>4350 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability 1870 MW
			TTC with All Lines In Service 6220 MW
<b>MILLWOOD-EASTVIEW_345_W82</b>			FWD
Sat 09/19/2020	to	Sat 09/19/2020	(Import)
0330	Continuous	0400	UPNY CONED <b>5985 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability 235 MW
			TTC with All Lines In Service 6220 MW
<b>SPRNBK__345KV_RNS4</b>			FWD
Sat 09/19/2020	to	Sat 09/19/2020	(Import)
0330	Continuous	0400	SPR/DUN-SOUTH <b>3200 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability 1400 MW
			TTC with All Lines In Service 4600 MW
<b>MILLWOOD_345KV_18</b>			FWD
Sun 09/20/2020	to	Sun 09/20/2020	(Import)
0001	Continuous	0030	UPNY CONED <b>4350 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability 1870 MW
			TTC with All Lines In Service 6220 MW

# NYISO TRANSFER LIMITATIONS

Friday ,May 29, 2020 to Sunday ,November 28, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>				
<p><b>BUCHAN_S-MILLWOOD_345_W98</b></p> <p>Sun 09/20/2020 to Fri 09/25/2020</p> <p>0001 Continuous 0200</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>UPNY CONED <b>6135 MW</b></p> <p>Impacts Total Transfer Capability 85 MW</p> <p>TTC with All Lines In Service 6220 MW</p>			
<hr/>				
<p><b>CLAY -EDIC 345_1-16</b></p> <p>Mon 09/21/2020 to Fri 09/25/2020</p> <p>0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>OSWEGO EXPORT <b>4850 MW</b></p> <p>Impacts Total Transfer Capability 400 MW</p> <p>TTC with All Lines In Service 5250 MW</p>			
<hr/>				
<p><b>FRASANX-COOPERS 345_UCC2-41</b></p> <p>Mon 09/21/2020 to Sun 09/27/2020</p> <p>0700 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p><b>UPDATED by NYPA 04/15/2020</b></p> <p>CENTRAL EAST - VC <b>2500 MW</b></p> <p>Impacts Total Transfer Capability 475 MW</p> <p>TTC with All Lines In Service 2975 MW</p> <p><b>ARR: 19</b></p>			
<hr/>				
<p><b>MARCY -FRASANX 345_UCC2-41</b></p> <p>Mon 09/21/2020 to Sun 09/27/2020</p> <p>0700 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p><b>UPDATED by NYPA 04/15/2020</b></p> <p>CENTRAL EAST - VC <b>2500 MW</b></p> <p>Impacts Total Transfer Capability 475 MW</p> <p>TTC with All Lines In Service 2975 MW</p> <p><b>ARR: 19</b></p>			
<hr/>				
<p><b>ROSETON -ROCKTVRN 345_311</b></p> <p>Mon 09/21/2020 to Fri 10/23/2020</p> <p>0800 Continuous 1600</p> <p>Work scheduled by: CHGE</p>	<p style="text-align: right;">FWD (Import)</p> <p><b>UPDATED by CHGE 10/09/2019</b></p> <p>UPNY CONED <b>4400 MW</b></p> <p>Impacts Total Transfer Capability 1820 MW</p> <p>TTC with All Lines In Service 6220 MW</p>			
<hr/>				
<p><b>MILLWOOD_345KV_18</b></p> <p>Fri 09/25/2020 to Fri 09/25/2020</p> <p>0130 Continuous 0200</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>UPNY CONED <b>4350 MW</b></p> <p>Impacts Total Transfer Capability 1870 MW</p> <p>TTC with All Lines In Service 6220 MW</p>			
<hr/>				
<p><b>EASTVIEW-SPRNBK 345_W78</b></p> <p>Sat 09/26/2020 to Sun 09/27/2020</p> <p>0001 Continuous 0200</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>UPNY CONED <b>4350 MW</b></p> <p>Impacts Total Transfer Capability 1870 MW</p> <p>TTC with All Lines In Service 6220 MW</p>			

# NYISO TRANSFER LIMITATIONS

Friday ,May 29, 2020 to Sunday ,November 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD-EASTVIEW\_345\_W85

Sat 09/26/2020 to Sun 09/27/2020  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **5985 MW**  
 Impacts Total Transfer Capability 235 MW  
 TTC with All Lines In Service 6220 MW

SPRNBRK\_345KV\_RNS3

Sat 09/26/2020 to Sun 09/27/2020  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

DUNWODIE\_345KV\_3

Mon 09/28/2020 to Sat 10/31/2020  
 0001 Continuous 0100  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

DUNWODIE\_345KV\_4

Mon 09/28/2020 to Sat 10/31/2020  
 0001 Continuous 0100  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

PLSNTVLE-DUNWODIE\_345\_W89

Mon 09/28/2020 to Sat 10/31/2020  
 0001 Continuous 0100  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 2220 MW  
 TTC with All Lines In Service 6220 MW

CLAY-EDIC\_345\_2-15

Mon 09/28/2020 to Fri 10/02/2020  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 OSWEGO EXPORT **4850 MW**  
 Impacts Total Transfer Capability 400 MW  
 TTC with All Lines In Service 5250 MW

MOTTHAVN-RAINEY\_345\_Q11

Thu 10/01/2020 to Thu 11/05/2020 **UPDATED by CONED 12/17/2019**  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW



# NYISO TRANSFER LIMITATIONS

Friday ,May 29, 2020 to Sunday ,November 28, 2021

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>				
<b>HUDSONTP-W49TH_ST_345_Y56</b>				FWD
Fri 10/02/2020	to	Thu 10/08/2020		(Import)
0001	Continuous	0300	SCH - PJM_HTP	<b>0 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	660 MW
			TTC with All Lines In Service	660 MW
<hr/>				
<b>W49TH_ST_345KV_7</b>				FWD
Fri 10/02/2020	to	Thu 10/08/2020		(Import)
0001	Continuous	0300	SCH - PJM_HTP	<b>365 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	295 MW
			TTC with All Lines In Service	660 MW
<hr/>				
<b>W49TH_ST_345KV_8</b>				FWD
Fri 10/02/2020	to	Thu 10/08/2020		(Import)
0001	Continuous	0300	SCH - PJM_HTP	<b>450 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	210 MW
			TTC with All Lines In Service	660 MW
<hr/>				
<b>PANNELL -CLAY 345_1</b>				FWD
Mon 10/05/2020	to	Fri 10/09/2020	<b>UPDATED</b>	(Import)
0700	Continuous	1530	<b>by NYPA</b>	<b>1300 MW</b>
Work scheduled by: NYPA			<b>05/07/2020</b>	WEST CENTRAL
			Impacts Total Transfer Capability	950 MW
			TTC with All Lines In Service	2250 MW
<hr/>				
<b>SAND_BAR-PLATSBURG_115_PV20</b>				
Sat 10/17/2020	to	Sat 11/14/2020		
0600	Continuous	1800	SCH - NE - NY	
Work scheduled by: ISONE			Impacts Total Transfer Capability	
			TTC with All Lines In Service	
<hr/>				
<b>ROCHESTR-PANNELL 345_RP1</b>				FWD
Mon 10/19/2020	to	Fri 10/23/2020	<b>UPDATED</b>	(Import)
0500	Continuous	1700	<b>by NYPA</b>	<b>2300 MW</b>
Work scheduled by: NYPA			<b>03/10/2020</b>	DYSINGER EAST
			Impacts Total Transfer Capability	850 MW
			TTC with All Lines In Service	3150 MW
<hr/>				
<b>SHOR_NPX-SHOREHAM_138_CSC</b>				FWD
Mon 10/19/2020	to	Fri 10/23/2020	<b>UPDATED</b>	(Import) (Export)
0700	Continuous	1500	<b>by LI</b>	<b>0 MW</b> <b>0 MW</b>
Work scheduled by: LI			<b>03/02/2020</b>	SCH - NPX_CSC
			Impacts Total Transfer Capability	330 MW 330 MW
			TTC with All Lines In Service	330 MW 330 MW

# NYISO TRANSFER LIMITATIONS

Friday ,May 29, 2020 to Sunday ,November 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>PANNELL -CLAY</b> _____ <b>345_2</b>					FWD	
Mon 10/19/2020	to	Fri 10/23/2020	<b>UPDATED</b>	<b>by NYPA</b>	<b>05/07/2020</b>	(Import)
0700	Continuous	1530				WEST CENTRAL <b>1300 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability 950 MW
						TTC with All Lines In Service 2250 MW
<b>BERKSHIR-ALPS</b> _____ <b>345_393</b>					FWD	REV
Mon 10/19/2020	to	Tue 11/10/2020	<b>UPDATED</b>	<b>by ISONE</b>	<b>04/01/2020</b>	(Import) (Export)
0730	Continuous	1330				SCH - NE - NY <b>950 MW 1300 MW</b>
Work scheduled by: NGrid				<b>ARR: 78</b>		Impacts Total Transfer Capability 450 MW 300 MW
						TTC with All Lines In Service 1400 MW 1600 MW
<b>BERKSHIR-ALPS</b> _____ <b>345_393</b>					FWD	REV
Mon 10/19/2020	to	Tue 11/10/2020	<b>UPDATED</b>	<b>by ISONE</b>	<b>04/01/2020</b>	(Import) (Export)
0730	Continuous	1330				SCH - NPX_1385 <b>100 MW 100 MW</b>
Work scheduled by: NGrid				<b>ARR: 78</b>		Impacts Total Transfer Capability 100 MW 100 MW
						TTC with All Lines In Service 200 MW 200 MW
<b>BERKSHIR-ALPS</b> _____ <b>345_393 &amp; BERKSHIR-NORTHFLD_345_312</b>					FWD	REV
Mon 10/19/2020	to	Tue 11/10/2020				(Import) (Export)
0730		1330				SCH - NE - NY <b>950 MW 1300 MW</b>
Work scheduled by:				<b>ARR: 78</b>		Impacts Total Transfer Capability 450 MW 300 MW
						TTC with All Lines In Service 1400 MW 1600 MW
<b>BERKSHIR-NORTHFLD_345_312</b>					FWD	REV
Mon 10/19/2020	to	Tue 11/10/2020	<b>UPDATED</b>	<b>by ISONE</b>	<b>04/01/2020</b>	(Import) (Export)
0730	Continuous	1330				SCH - NE - NY <b>900 MW 1500 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability 500 MW 100 MW
						TTC with All Lines In Service 1400 MW 1600 MW
<b>BERKSHIR-NORTHFLD_345_312</b>					FWD	REV
Mon 10/19/2020	to	Tue 11/10/2020	<b>UPDATED</b>	<b>by ISONE</b>	<b>04/01/2020</b>	(Import) (Export)
0730	Continuous	1330				SCH - NPX_1385 <b>100 MW 100 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability 100 MW 100 MW
						TTC with All Lines In Service 200 MW 200 MW
<b>LEEDS</b> _____ <b>345_LEEDS SVC</b>					FWD	
Mon 10/26/2020	to	Fri 10/30/2020				(Import)
0800	Continuous	1600				CENTRAL EAST - VC <b>2950 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability 25 MW
						TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Friday ,May 29, 2020 to Sunday ,November 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>LEEDS___-HURLYAVE_345_301</b>					FWD	
Mon 10/26/2020	to	Fri 12/04/2020			(Import)	
0800	Continuous	1600		UPNY CONED	<b>4100 MW</b>	
Work scheduled by: CHGE					Impacts Total Transfer Capability	2120 MW
					TTC with All Lines In Service	6220 MW
<b>SCH-IMO-NYISO_LIMIT_1750</b>					FWD	
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Import)
0001	Continuous	2359		SCH - OH - NY	<b>2050 MW</b>	
Work scheduled by: IESO					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	2050 MW
<b>SCH-NYISO-IMO_LIMIT_1600</b>						REV
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Export)
0001	Continuous	2359		SCH - OH - NY	<b>1900 MW</b>	
Work scheduled by: IESO					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	1900 MW
<b>SPRNBRK_-W49TH_ST_345_M51</b>					FWD	
Thu 11/12/2020	to	Mon 11/16/2020			(Import)	
0001	Continuous	0300		SPR/DUN-SOUTH	<b>3200 MW</b>	
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
<b>SPRNBRK__345KV_RNS5</b>					FWD	
Thu 11/12/2020	to	Mon 11/16/2020			(Import)	
0001	Continuous	0300		SPR/DUN-SOUTH	<b>3200 MW</b>	
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
<b>CHATGUAY-MASSENA__765_7040</b>					FWD	
Sun 11/15/2020	to	Mon 11/30/2020			(Import)	
0100	Continuous	1900		MOSES SOUTH	<b>1550 MW</b>	
Work scheduled by: NYPA					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	3150 MW
<b>CHATGUAY-MASSENA__765_7040</b>					FWD	REV
Sun 11/15/2020	to	Mon 11/30/2020			(Import)	(Export)
0100	Continuous	1900		SCH - HQ - NY	<b>0 MW</b>	<b>0 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	1500 MW 1000 MW
					TTC with All Lines In Service	1500 MW 1000 MW

# NYISO TRANSFER LIMITATIONS

Friday ,May 29, 2020 to Sunday ,November 28, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MARCY___765_345_AT1</b>			FWD
Sun 11/15/2020	to	Mon 11/30/2020	(Import)
0100	Continuous	1900	MOSES SOUTH <b>1750 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability 1400 MW
			TTC with All Lines In Service 3150 MW
<b>MARCY___765_345_AT2</b>			FWD
Sun 11/15/2020	to	Mon 11/30/2020	(Import)
0100	Continuous	1900	MOSES SOUTH <b>1700 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability 1450 MW
			TTC with All Lines In Service 3150 MW
<b>MASSENA_-MARCY___765_MSU1</b>			FWD
Sun 11/15/2020	to	Mon 11/30/2020	(Import)
0100	Continuous	1900	CENTRAL EAST - VC <b>2265 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability 710 MW
			TTC with All Lines In Service 2975 MW
<b>MASSENA_-MARCY___765_MSU1</b>			FWD
Sun 11/15/2020	to	Mon 11/30/2020	(Import)
0100	Continuous	1900	MOSES SOUTH <b>500 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability 2650 MW
			TTC with All Lines In Service 3150 MW
<b>MASSENA_-MARCY___765_MSU1</b>			FWD
Sun 11/15/2020	to	Mon 11/30/2020	(Import) (Export)
0100	Continuous	1900	SCH - HQ - NY <b>475 MW 1000 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability 1025 MW 0 MW
			TTC with All Lines In Service 1500 MW 1000 MW
<b>MASSENA_-MARCY___765_MSU1</b>			FWD
Sun 11/15/2020	to	Mon 11/30/2020	(Import)
0100	Continuous	1900	SCH - HQ_CEDARS <b>90 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability 109 MW
			TTC with All Lines In Service 199 MW
<b>MASSENA_-MARCY___765_MSU1 &amp; CHATGUAY-MASSENA_765_7040</b>			FWD
Sun 11/15/2020	to	Mon 11/30/2020	(Import)
0100		1900	MOSES SOUTH <b>500 MW</b>
Work scheduled by:			Impacts Total Transfer Capability 2650 MW
			TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Friday ,May 29, 2020 to Sunday ,November 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -MASSENA 230\_MMS1 & MOSES -MASSENA 230\_MMS2

Sun 11/15/2020 to Mon 11/30/2020  
0100 1900

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	850 MW	0 MW
Impacts Total Transfer Capability	650 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

MOSES -MASSENA 230\_MMS1 & MOSES -MASSENA 230\_MMS2

Sun 11/15/2020 to Mon 11/30/2020  
0100 1900

Work scheduled by:

	FWD	
	(Import)	
SCH - HQ_CEDARS	90 MW	
Impacts Total Transfer Capability	109 MW	
TTC with All Lines In Service	199 MW	

STLAWRNC-MOSES 230\_L33P & MASSENA -MARCY 765\_MSU1

Sun 11/15/2020 to Mon 11/30/2020  
0100 1900

Work scheduled by:

	FWD	
	(Import)	
SCH - HQ_CEDARS	90 MW	
Impacts Total Transfer Capability	109 MW	
TTC with All Lines In Service	199 MW	

STLAWRNC-MOSES 230\_L33P & MOSES -MASSENA 230\_MMS1 & MOSES -MASSENA 230\_MMS2

Sun 11/15/2020 to Mon 11/30/2020  
0100 1900

Work scheduled by:

	FWD	
	(Import)	
SCH - HQ_CEDARS	90 MW	
Impacts Total Transfer Capability	109 MW	
TTC with All Lines In Service	199 MW	

PLSNTVLE-DUNWODIE\_345\_W89

Mon 11/16/2020 to Mon 11/16/2020  
0001 Continuous 0030

Work scheduled by: ConEd

	FWD	
	(Import)	
UPNY CONED	4000 MW	
Impacts Total Transfer Capability	2220 MW	
TTC with All Lines In Service	6220 MW	

PLSNTVLE-DUNWODIE\_345\_W89

Thu 11/26/2020 to Thu 11/26/2020  
0230 Continuous 0300

Work scheduled by: ConEd

	FWD	
	(Import)	
UPNY CONED	4000 MW	
Impacts Total Transfer Capability	2220 MW	
TTC with All Lines In Service	6220 MW	

LADENTWN-BUCHAN\_S\_345\_Y88

Mon 11/30/2020 to Thu 01/14/2021  
0001 Continuous 2359 **CANCELLED by ConEd 05/28/2020**

Work scheduled by: ORU

	FWD	
	(Import)	
UPNY CONED	5930 MW	
Impacts Total Transfer Capability	290 MW	
TTC with All Lines In Service	6220 MW	

# NYISO TRANSFER LIMITATIONS

Friday ,May 29, 2020 to Sunday ,November 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE**

Mon 11/30/2020 to Sun 12/20/2020  
0600 Continuous 1600

UPDATED by LI 04/29/2020

Work scheduled by: PJM

FWD  
(Import)  
**0 MW**  
SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

**NEWBRDGE-DUFFYAVE\_345\_501**

Mon 11/30/2020 to Sun 12/20/2020  
0600 Continuous 1600

UPDATED by LI 04/29/2020

Work scheduled by: PJM

FWD  
(Import)  
**0 MW**  
SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

**MARCY\_\_\_345KV\_CSC**

Tue 12/01/2020 to Fri 12/11/2020  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
**2925 MW**  
CENTRAL EAST - VC  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MAL**

Tue 12/01/2020 to Mon 05/31/2021  
0700 Continuous 1300

Work scheduled by: NYPA

FWD  
(Import)  
**2300 MW**  
MOSES SOUTH  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**SAND\_BAR-PLATSBRG\_115\_PV20**

Mon 12/07/2020 to Fri 12/11/2020  
0700 Continuous 1530

Work scheduled by: NYPA

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**LONG\_MTN-CRICKVLY\_345\_398**

Tue 12/08/2020 to Thu 12/10/2020  
0700 Continuous 1600

Work scheduled by: ISONE

FWD REV  
(Import) (Export)  
**700 MW 1300 MW**  
SCH - NE - NY  
Impacts Total Transfer Capability 700 MW 400 MW  
TTC with All Lines In Service 1400 MW 1700 MW

**LONG\_MTN-CRICKVLY\_345\_398**

Tue 12/08/2020 to Thu 12/10/2020  
0700 Continuous 1600

Work scheduled by: ISONE

FWD REV  
(Import) (Export)  
**100 MW 100 MW**  
SCH - NPX\_1385  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

# NYISO TRANSFER LIMITATIONS

Friday ,May 29, 2020 to Sunday ,November 28, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SCH-NE-NYISO\_LIMIT\_400**

Tue 12/08/2020 to Thu 12/10/2020  
 0700 Continuous 1600  
 Work scheduled by: ISONE

FWD  
 (Import)  
 SCH - NE - NY **600 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 1400 MW

**SCH-NYISO-NE\_LIMIT\_1000**

Tue 12/08/2020 to Thu 12/10/2020  
 0700 Continuous 1600  
 Work scheduled by: ISONE

REV  
 (Export)  
 SCH - NE - NY **1200 MW**  
 Impacts Total Transfer Capability 500 MW  
 TTC with All Lines In Service 1700 MW

**MARCY -EDIC 345\_UE1-7**

Mon 12/14/2020 to Mon 12/14/2020  
 0700 Continuous 1730  
 Work scheduled by: NYPA

**ARR: 19&16**

FWD  
 (Import)  
 OSWEGO EXPORT **5250 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 5250 MW

**SAND\_BAR-PLATSBRG\_115\_PV20**

Mon 12/14/2020 to Fri 12/18/2020  
 0700 Continuous 1530  
 Work scheduled by: NYPA

SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**FRASANNX-COOPERS 345\_UCC2-41**

Tue 12/15/2020 to Wed 12/16/2020  
 0700 Continuous 1530  
 Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
 CENTRAL EAST - VC **2500 MW**  
 Impacts Total Transfer Capability 475 MW  
 TTC with All Lines In Service 2975 MW

**MARCY -FRASANNX 345\_UCC2-41**

Tue 12/15/2020 to Wed 12/16/2020  
 0700 Continuous 1530  
 Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
 CENTRAL EAST - VC **2500 MW**  
 Impacts Total Transfer Capability 475 MW  
 TTC with All Lines In Service 2975 MW

**HOPATCON-RAMAPO 500\_5018**

Mon 02/01/2021 to Wed 02/03/2021  
 0001 Continuous 2200  
 Work scheduled by: ConEd

FWD REV  
 (Import) (Export)  
 SCH - PJ - NY **1250 MW 1200 MW**  
 Impacts Total Transfer Capability 1650 MW 650 MW  
 TTC with All Lines In Service 2900 MW 1850 MW

# NYISO TRANSFER LIMITATIONS

Friday ,May 29, 2020 to Sunday ,November 28, 2021

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p><b>HOPATCON-RAMAPO___500_5018</b></p> <p>Mon 02/01/2021 to Wed 02/03/2021</p> <p>0001 Continuous 2200</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>UPNY CONED <b>6025 MW</b></p> <p>Impacts Total Transfer Capability 195 MW</p> <p>TTC with All Lines In Service 6220 MW</p>
<p><b>RAMAPO___345_345_PAR3500</b></p> <p>Mon 02/01/2021 to Wed 02/03/2021</p> <p>0001 Continuous 2200</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD REV</p> <p style="text-align: right;">(Import) (Export)</p> <p>SCH - PJ - NY <b>2150 MW 1250 MW</b></p> <p>Impacts Total Transfer Capability 750 MW 600 MW</p> <p>TTC with All Lines In Service 2900 MW 1850 MW</p>
<p><b>RAMAPO___345_345_PAR4500</b></p> <p>Mon 02/01/2021 to Wed 02/03/2021</p> <p>0001 Continuous 2200</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD REV</p> <p style="text-align: right;">(Import) (Export)</p> <p>SCH - PJ - NY <b>2150 MW 1250 MW</b></p> <p>Impacts Total Transfer Capability 750 MW 600 MW</p> <p>TTC with All Lines In Service 2900 MW 1850 MW</p>
<p><b>RAMAPO___500_345_BK 1500</b></p> <p>Mon 02/01/2021 to Wed 02/03/2021</p> <p>0001 Continuous 2200</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD REV</p> <p style="text-align: right;">(Import) (Export)</p> <p>SCH - PJ - NY <b>1250 MW 1200 MW</b></p> <p>Impacts Total Transfer Capability 1650 MW 650 MW</p> <p>TTC with All Lines In Service 2900 MW 1850 MW</p>
<p><b>RAMAPO___500_345_BK 1500</b></p> <p>Mon 02/01/2021 to Wed 02/03/2021</p> <p>0001 Continuous 2200</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>UPNY CONED <b>6025 MW</b></p> <p>Impacts Total Transfer Capability 195 MW</p> <p>TTC with All Lines In Service 6220 MW</p>
<p><b>PLSNTVLY-WOOD_ST___345_F30</b></p> <p>Mon 02/15/2021 to Tue 02/16/2021</p> <p>0001 Continuous 0200</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>UPNY CONED <b>4000 MW</b></p> <p>Impacts Total Transfer Capability 2220 MW</p> <p>TTC with All Lines In Service 6220 MW</p>
<p><b>PLSNTVLY_345KV_RNS5</b></p> <p>Mon 02/15/2021 to Tue 02/16/2021</p> <p>0001 Continuous 0200</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>UPNY CONED <b>3800 MW</b></p> <p>Impacts Total Transfer Capability 2420 MW</p> <p>TTC with All Lines In Service 6220 MW</p>



# NYISO TRANSFER LIMITATIONS

Friday ,May 29, 2020 to Sunday ,November 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**EFISHKIL-WOOD\_ST\_\_345\_F39**

Thu 02/18/2021 to Sat 02/20/2021  
2100 Continuous 0200

**UPDATED by CE 04/01/2020**

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 2220 MW  
TTC with All Lines In Service 6220 MW

**WOOD\_ST\_-PLSNTVLE\_345\_Y87**

Thu 02/18/2021 to Sat 02/20/2021  
2100 Continuous 0200

**UPDATED by CE 04/01/2020**

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **5905 MW**  
Impacts Total Transfer Capability 315 MW  
TTC with All Lines In Service 6220 MW

**DUNWODIE\_345KV\_3**

Mon 03/01/2021 to Mon 03/01/2021  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_5**

Mon 03/01/2021 to Mon 03/01/2021  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**EASTVIEW-SPRNBK\_\_345\_W64**

Mon 03/01/2021 to Mon 03/01/2021  
0001 Continuous 0030

**UPDATED by CONED 01/23/2020**

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 1870 MW  
TTC with All Lines In Service 6220 MW

**SPRNBK\_\_345KV\_RNS5**

Mon 03/01/2021 to Mon 03/01/2021  
0001 Continuous 0030

**UPDATED by CONED 01/23/2020**

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

**MILLWOOD-EASTVIEW\_345\_W99**

Mon 03/01/2021 to Mon 03/22/2021  
0001 Continuous 0200

**UPDATED by CONED 01/23/2020**

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **5985 MW**  
Impacts Total Transfer Capability 235 MW  
TTC with All Lines In Service 6220 MW

# NYISO TRANSFER LIMITATIONS

Friday ,May 29, 2020 to Sunday ,November 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE-MOTTHAVN\_345\_71**

Mon 03/01/2021 to Mon 04/05/2021  
 0001 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**MOTTHAVN-RAINEY\_345\_Q11**

Mon 03/01/2021 to Tue 04/06/2021  
 0001 Continuous 0700  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**EASTVIEW-SPRNBK\_345\_W64**

Mon 03/22/2021 to Mon 03/22/2021 **UPDATED by CONED 01/23/2020**  
 0130 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1870 MW  
 TTC with All Lines In Service 6220 MW

**SPRNBK\_345KV\_RNS5**

Mon 03/22/2021 to Mon 03/22/2021 **UPDATED by CONED 01/23/2020**  
 0130 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

**CLAY-EDIC\_345\_2-15**

Mon 03/29/2021 to Fri 04/16/2021  
 0800 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
 OSWEGO EXPORT **4850 MW**  
 Impacts Total Transfer Capability 400 MW  
 TTC with All Lines In Service 5250 MW

**DUNWODIE\_345KV\_3**

Mon 04/05/2021 to Mon 04/05/2021  
 0230 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_5**

Mon 04/05/2021 to Mon 04/05/2021  
 0230 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Friday ,May 29, 2020 to Sunday ,November 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SPRNBK\_-TREMONT\_\_345\_X28**

Mon 04/19/2021 to Tue 04/20/2021  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **4200 MW**  
 Impacts Total Transfer Capability 400 MW  
 TTC with All Lines In Service 4600 MW

**SCH-IMO-NYISO\_LIMIT\_1600**

Sat 05/01/2021 to Sun 10/31/2021 **UPDATED by IESO 05/03/2019**  
 0001 Continuous 2359  
 Work scheduled by: IESO

FWD  
 (Import)  
 SCH - OH - NY **1900 MW**  
 Impacts Total Transfer Capability 50 MW  
 TTC with All Lines In Service 1950 MW

**PANNELL\_-CLAY\_\_\_\_345\_2**

Mon 05/03/2021 to Fri 05/28/2021  
 0700 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
 WEST CENTRAL **1300 MW**  
 Impacts Total Transfer Capability 950 MW  
 TTC with All Lines In Service 2250 MW

**MOSES\_-ADIRNDCK\_230\_MA2**

Tue 06/01/2021 to Sun 11/14/2021  
 0700 Continuous 1300  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2100 MW**  
 Impacts Total Transfer Capability 1050 MW  
 TTC with All Lines In Service 3150 MW

**SPRNBK\_-W49TH\_ST\_345\_M51**

Fri 10/01/2021 to Sun 10/17/2021  
 0001 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

**SPRNBK\_\_345KV\_RNS5**

Fri 10/01/2021 to Sun 10/17/2021  
 0001 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

**SCH-IMO-NYISO\_LIMIT\_1750**

Mon 11/01/2021 to Fri 12/31/2021 **UPDATED by IESO 05/03/2019**  
 0001 Continuous 2359  
 Work scheduled by: IESO

FWD  
 (Import)  
 SCH - OH - NY **2050 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 2050 MW

# NYISO TRANSFER LIMITATIONS

Friday ,May 29, 2020 to Sunday ,November 28, 2021

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-IMO\_LIMIT\_1600

Mon 11/01/2021 to Fri 12/31/2021  
 0001 Continuous 2359  
 Work scheduled by: IESO

UPDATED by IESO 05/03/2019

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

REV  
 (Export)  
**1900 MW**  
 0 MW  
 1900 MW