

NYISO TRANSFER LIMITATIONS

Thursday ,July 30, 2020 to Saturday ,January 29, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_9_BYPASS & DUNWODIE_345KV_10_BYPASS & SPRNBRK__345KV_R4S3_BYPASS & SPRNBRK__345KV_R5S3_BYPASS

Sun 02/01/2015 to Sat 02/01/2025
0000 0000

Work scheduled by:

UPNY CONED
Impacts Total Transfer Capability
TTC with All Lines In Service

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Thu 10/01/2020
0001 Continuous 2359

Work scheduled by: ConEd

EXTENDED by CONED 05/03/2020

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2050 MW	1150 MW
Impacts Total Transfer Capability	150 MW	100 MW
TTC with All Lines In Service	2200 MW	1250 MW

HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Thu 10/01/2020
0001 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2000 MW	1000 MW
Impacts Total Transfer Capability	200 MW	250 MW
TTC with All Lines In Service	2200 MW	1250 MW

MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Thu 10/01/2020
0001 Continuous 2359

Work scheduled by: ConEd

EXTENDED by CONED 05/03/2020

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2050 MW	1150 MW
Impacts Total Transfer Capability	150 MW	100 MW
TTC with All Lines In Service	2200 MW	1250 MW

STLAWRNC-MOSES__230_L33P

Mon 04/30/2018 to Fri 12/31/2021
0456 Continuous 2359

Work scheduled by: IESO

EXT FORCE by IESO 08/21/2018

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

SCH-IMO-NYISO_LIMIT_1600

Fri 05/01/2020 to Sat 10/31/2020
0001 Continuous 2359

Work scheduled by: IESO

UPDATED by IESO 05/03/2019

	FWD
	(Import)
SCH - OH - NY	1900 MW
Impacts Total Transfer Capability	50 MW
TTC with All Lines In Service	1950 MW

SHOR_NPX-SHOREHAM_138_CSC

Wed 07/08/2020 to Wed 09/02/2020
1247 Continuous 2359

Work scheduled by: LI

EXT FORCE by ISONE 07/20/2020

	FWD	REV
	(Import)	(Export)
SCH - NPX_CSC	0 MW	0 MW
Impacts Total Transfer Capability	330 MW	330 MW
TTC with All Lines In Service	330 MW	330 MW

NYISO TRANSFER LIMITATIONS

Thursday ,July 30, 2020 to Saturday ,January 29, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES ___-ADIRNDCK_230_MA2

Fri 07/24/2020 to Sun 07/26/2020
0500 Continuous 2200

Work scheduled by: NYPA

UPDATED by NYPA 07/27/2020

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

HOMRC_NY-MAINS_NY_345_47

Fri 07/24/2020 to Sun 07/26/2020
1833 Continuous 2359

Work scheduled by: NYSEG

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

BECK ___-NIAGARA_230_PA27

Sat 07/25/2020 to Mon 07/27/2020
0700 Continuous 1000

Work scheduled by: IESO

UPDATED by IESO 07/14/2020

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

SCH-IMO-NYISO_LIMIT_1450

Sat 07/25/2020 to Mon 07/27/2020
0700 Continuous 1000

Work scheduled by: IESO

UPDATED by IESO 07/14/2020

FWD
(Import)
SCH - OH - NY **1750 MW**
Impacts Total Transfer Capability 200 MW
TTC with All Lines In Service 1950 MW

BECK ___-NIAGARA_345_PA302

Thu 07/30/2020 to Fri 07/31/2020
0600 Continuous 1800

Work scheduled by: IESO

CANCELLED by IESO 07/28/2020

FWD REV
(Import) (Export)
SCH - OH - NY **900 MW 800 MW**
Impacts Total Transfer Capability 1050 MW 900 MW
TTC with All Lines In Service 1950 MW 1700 MW

DUNWODIE_345KV_4

Fri 07/31/2020 to Fri 07/31/2020
0001 Continuous 0030

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_6

Fri 07/31/2020 to Fri 07/31/2020
0001 Continuous 0030

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Thursday ,July 30, 2020 to Saturday ,January 29, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE-SHORE_RD_345_Y50

Fri 07/31/2020 to Tue 08/04/2020
 0001 Continuous 0259
 Work scheduled by: ConEd

FWD
 (Import)
 CONED - LIPA **800 MW**
 Impacts Total Transfer Capability 700 MW
 TTC with All Lines In Service 1500 MW

SHORE_RD_345_138_BK 1

Fri 07/31/2020 to Tue 08/04/2020
 0001 Continuous 0259
 Work scheduled by: ConEd

FWD
 (Import)
 CONED - LIPA **1350 MW**
 Impacts Total Transfer Capability 150 MW
 TTC with All Lines In Service 1500 MW

SHORE_RD_345_138_BK 2

Fri 07/31/2020 to Tue 08/04/2020
 0001 Continuous 0259
 Work scheduled by: ConEd

FWD
 (Import)
 CONED - LIPA **1350 MW**
 Impacts Total Transfer Capability 150 MW
 TTC with All Lines In Service 1500 MW

MOSES__-ADIRNDCK_230_MA2

Fri 07/31/2020 to Sat 09/12/2020 **UPDATED by NYPA 07/27/2020**
 0500 Continuous 2359
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2100 MW**
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW

DUNWODIE_345KV_6

Sat 08/01/2020 to Sat 08/01/2020
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_8

Sat 08/01/2020 to Sat 08/01/2020
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

EFISHKIL-WOOD_ST_345_F39

Sat 08/01/2020 to Sat 08/01/2020
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 2220 MW
 TTC with All Lines In Service 6220 MW

NYISO TRANSFER LIMITATIONS

Thursday ,July 30, 2020 to Saturday ,January 29, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLE-DUNWODIE_345_W90

Sat 08/01/2020 to Sat 08/01/2020
 0001 Continuous 1800
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 2220 MW
 TTC with All Lines In Service 6220 MW

WOOD_ST_-PLSNTVLE_345_Y87

Sat 08/01/2020 to Sat 08/01/2020
 0001 Continuous 1800
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **5905 MW**
 Impacts Total Transfer Capability 315 MW
 TTC with All Lines In Service 6220 MW

DUNWODIE_345KV_6

Sat 08/01/2020 to Sat 08/01/2020
 1730 Continuous 1800
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_8

Sat 08/01/2020 to Sat 08/01/2020
 1730 Continuous 1800
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

EFISHKIL-WOOD_ST__345_F39

Sat 08/01/2020 to Sat 08/01/2020
 1730 Continuous 1800
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 2220 MW
 TTC with All Lines In Service 6220 MW

DUNWODIE_345KV_4

Tue 08/04/2020 to Tue 08/04/2020
 0230 Continuous 0259
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_6

Tue 08/04/2020 to Tue 08/04/2020
 0230 Continuous 0259
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Thursday ,July 30, 2020 to Saturday ,January 29, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
INDPDNCE-SCRIBA__345_25			FWD
Thu 08/06/2020	to Thu 08/06/2020	<u>UPDATED</u> <u>by NGRID</u> <u>07/29/2020</u>	(Import)
0600	Daily(No Weekends) 1630		OSWEGO EXPORT 5250 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability 0 MW
			TTC with All Lines In Service 5250 MW
<hr/>			
SAND_BAR-PLATSBRG_115_PV20			
Sun 08/09/2020	to Sun 08/16/2020	<u>UPDATED</u> <u>by ISONE</u> <u>07/28/2020</u>	
0800	Continuous 1900		SCH - NE - NY
Work scheduled by: ISONE			Impacts Total Transfer Capability
			TTC with All Lines In Service
<hr/>			
NIAGARA__345KV_3002			FWD REV
Wed 08/12/2020	to Wed 08/12/2020	<u>UPDATED</u> <u>by NYPA</u> <u>07/20/2020</u>	(Import) (Export)
0500	Continuous 0530		SCH - OH - NY 1300 MW 1150 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 650 MW 550 MW
			TTC with All Lines In Service 1950 MW 1700 MW
<hr/>			
NIAGARA__345KV_3002			FWD REV
Thu 08/13/2020	to Thu 08/13/2020	<u>UPDATED</u> <u>by NYPA</u> <u>07/20/2020</u>	(Import) (Export)
1830	Continuous 1900		SCH - OH - NY 1300 MW 1150 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 650 MW 550 MW
			TTC with All Lines In Service 1950 MW 1700 MW
<hr/>			
S.RIPLEY-DUNKIRK__230_68			
Mon 08/17/2020	to Fri 08/21/2020		SCH - PJ - NY
0900	Continuous 1500		Impacts Total Transfer Capability
Work scheduled by: PJM			TTC with All Lines In Service
<hr/>			
SAND_BAR-PLATSBRG_115_PV20			
Sat 08/22/2020	to Sat 08/29/2020	<u>UPDATED</u> <u>by ISONE</u> <u>07/28/2020</u>	
0800	Continuous 1900		SCH - NE - NY
Work scheduled by: ISONE			Impacts Total Transfer Capability
			TTC with All Lines In Service
<hr/>			
NIAGARA__345KV_3102			FWD REV
Wed 08/26/2020	to Wed 08/26/2020		(Import) (Export)
0500	Continuous 1700		SCH - OH - NY 1700 MW 1400 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 250 MW 300 MW
			TTC with All Lines In Service 1950 MW 1700 MW

NYISO TRANSFER LIMITATIONS

Thursday ,July 30, 2020 to Saturday ,January 29, 2022

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STOLLERD-HISHELDN_230_67

Wed 08/26/2020 to Wed 08/26/2020
0900 Continuous 1000

Work scheduled by: NYSEG

FWD

(Import)

DYSINGER EAST **2850 MW**
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 3150 MW

OSWEGO_COMPLEX_AVR_O/S

Sun 09/06/2020 to Sun 09/06/2020
0900 Continuous 0930

Work scheduled by: Gen

FWD

(Import)

CENTRAL EAST - VC **2870 MW**
Impacts Total Transfer Capability 105 MW
TTC with All Lines In Service 2975 MW

MARCY__-N.SCTLND_345_18

Wed 09/09/2020 to Wed 09/09/2020
0800 Daily(No Weekends) 1500

Work scheduled by: NGrid

ARR: 19

FWD

(Import)

CENTRAL EAST - VC **2090 MW**
Impacts Total Transfer Capability 885 MW
TTC with All Lines In Service 2975 MW

MEYER__-CANANDGA_230_60

Thu 09/10/2020 to Thu 09/10/2020
0730 Continuous 1630

Work scheduled by: NYSEG

FWD

(Import)

DYSINGER EAST **2850 MW**
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 3150 MW

SPRNBK_-DUNWODIE_345_W75

Sat 09/12/2020 to Sat 09/12/2020
0001 Continuous 0030

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

SPRNBK_345KV_RNS3

Sat 09/12/2020 to Sat 09/12/2020
0001 Continuous 0030

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_5

Sat 09/12/2020 to Sat 09/12/2020
0001 Continuous 2100

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Thursday ,July 30, 2020 to Saturday ,January 29, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_7				FWD	
Sat 09/12/2020	to	Sat 09/12/2020		(Import)	
0001	Continuous	2100	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
SPRNBRK_-DUNWODIE_345_W75				FWD	
Sat 09/12/2020	to	Sat 09/12/2020		(Import)	
2030	Continuous	2100	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
SPRNBRK__345KV_RNS3				FWD	
Sat 09/12/2020	to	Sat 09/12/2020		(Import)	
2030	Continuous	2100	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
MOSES__-ADIRNDCK_230_MA2				FWD	
Sun 09/13/2020	to	Sat 11/14/2020	<u>UPDATED</u>	(Import)	
0001	Continuous	1300	<u>by NYPA</u>	<u>07/24/2020</u>	
Work scheduled by: NYPA				MOSES SOUTH	2100 MW
				Impacts Total Transfer Capability	1050 MW
				TTC with All Lines In Service	3150 MW
KINTIGH_-ROCHESTR_345_SRL-39				FWD	
Mon 09/14/2020	to	Thu 09/17/2020		(Import)	
0500	Continuous	1530	DYSINGER EAST	1400 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	1750 MW
				TTC with All Lines In Service	3150 MW
NIAGARA_-KINTIGH__345_NS1-38				FWD	
Mon 09/14/2020	to	Thu 09/17/2020		(Import)	
0500	Continuous	1530	DYSINGER EAST	1400 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	1750 MW
				TTC with All Lines In Service	3150 MW
LINDN_CG-LNDVFT__345_V-3022				FWD	REV
Mon 09/14/2020	to	Wed 09/16/2020		(Import)	(Export)
0800	Continuous	2000	SCH - PJM_VFT	0 MW	0 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	315 MW
				TTC with All Lines In Service	315 MW

NYISO TRANSFER LIMITATIONS

Thursday ,July 30, 2020 to Saturday ,January 29, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

WOOD_ST_-PLSNTVLE_345_Y87						FWD
Tue 09/15/2020	to	Tue 09/15/2020	<u>UPDATED</u>	<u>by CE</u>	<u>07/27/2020</u>	(Import)
0001	Continuous	2230				UPNY CONED 5905 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 315 MW
						TTC with All Lines In Service 6220 MW
EFISHKIL-WOOD_ST__345_F39						FWD
Tue 09/15/2020	to	Wed 09/16/2020	<u>UPDATED</u>	<u>by CE</u>	<u>07/27/2020</u>	(Import)
0001	Continuous	2200				UPNY CONED 4000 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 2220 MW
						TTC with All Lines In Service 6220 MW
BRANCHBG-HOPATCON_500_5060						FWD
Tue 09/15/2020	to	Wed 09/16/2020	<u>UPDATED</u>	<u>by PJM</u>	<u>04/20/2020</u>	(Import)
0200	Continuous	2300				UPNY CONED 6025 MW
Work scheduled by: PJM						Impacts Total Transfer Capability 195 MW
						TTC with All Lines In Service 6220 MW
DOLSONAV-ROCKTVRN_345_DART44						FWD
Wed 09/16/2020	to	Wed 09/30/2020				(Import)
0700	Continuous	1730				CENTRAL EAST - VC 2720 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 255 MW
						TTC with All Lines In Service 2975 MW
WOOD_ST_-PLSNTVLE_345_Y87						FWD
Wed 09/16/2020	to	Wed 09/16/2020	<u>UPDATED</u>	<u>by CE</u>	<u>07/27/2020</u>	(Import)
2130	Continuous	2200				UPNY CONED 5905 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 315 MW
						TTC with All Lines In Service 6220 MW
NIAGARA_-ROCHESTR_345_NR2						FWD
Fri 09/18/2020	to	Sat 11/14/2020				(Import)
0500	Continuous	2330				DYSINGER EAST 1400 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 1750 MW
						TTC with All Lines In Service 3150 MW
NIAGARA__345KV_3108						REV
Fri 09/18/2020	to	Sat 11/14/2020				(Export)
0500	Continuous	2330				SCH - OH - NY 1500 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 200 MW
						TTC with All Lines In Service 1700 MW

NYISO TRANSFER LIMITATIONS

Thursday ,July 30, 2020 to Saturday ,January 29, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Transfer Capability	Start Date	End Date	Time	Work Scheduled by	Impact	TTC with All Lines In Service	FWD	REV
EASTVIEW-SPRNBRK__345_W65	Sat 09/19/2020	Sat 09/19/2020	0001 Continuous 0030	ConEd	UPNY CONED	6220 MW	FWD (Import)	
Impacts Total Transfer Capability					1870 MW			
MILLWOOD-EASTVIEW_345_W82	Sat 09/19/2020	Sat 09/19/2020	0001 Continuous 0030	ConEd	UPNY CONED	6220 MW	FWD (Import)	
Impacts Total Transfer Capability					235 MW			
SPRNBRK__345KV_RNS4	Sat 09/19/2020	Sat 09/19/2020	0001 Continuous 0030	ConEd	SPR/DUN-SOUTH	4600 MW	FWD (Import)	
Impacts Total Transfer Capability					1400 MW			
EASTVIEW-SPRNBRK__345_W65	Sat 09/19/2020	Sat 09/19/2020	0330 Continuous 0400	ConEd	UPNY CONED	6220 MW	FWD (Import)	
Impacts Total Transfer Capability					1870 MW			
MILLWOOD-EASTVIEW_345_W82	Sat 09/19/2020	Sat 09/19/2020	0330 Continuous 0400	ConEd	UPNY CONED	6220 MW	FWD (Import)	
Impacts Total Transfer Capability					235 MW			
SPRNBRK__345KV_RNS4	Sat 09/19/2020	Sat 09/19/2020	0330 Continuous 0400	ConEd	SPR/DUN-SOUTH	4600 MW	FWD (Import)	
Impacts Total Transfer Capability					1400 MW			
NIAGARA__345KV_3002	Sat 09/19/2020	Sat 09/19/2020	0500 Continuous 2100	NYPA	SCH - OH - NY	1950 MW	FWD (Import)	REV (Export)
Impacts Total Transfer Capability					650 MW			550 MW
TTC with All Lines In Service					1950 MW			1700 MW

NYISO TRANSFER LIMITATIONS

Thursday ,July 30, 2020 to Saturday ,January 29, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA__345KV_3022

Sat 09/19/2020 to Sat 09/19/2020
 0500 Continuous 2100
 Work scheduled by: NYPA

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

MILLWOOD_345KV_18

Sun 09/20/2020 to Sun 09/20/2020
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1870 MW
 TTC with All Lines In Service 6220 MW

BUCHAN_S-MILLWOOD_345_W98

Sun 09/20/2020 to Fri 09/25/2020
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **6135 MW**
 Impacts Total Transfer Capability 85 MW
 TTC with All Lines In Service 6220 MW

NIAGARA__345KV_3102

Sun 09/20/2020 to Sun 09/20/2020
 0500 Continuous 2100
 Work scheduled by: NYPA

FWD REV
 (Import) (Export)
 SCH - OH - NY **1700 MW 1400 MW**
 Impacts Total Transfer Capability 250 MW 300 MW
 TTC with All Lines In Service 1950 MW 1700 MW

NIAGARA__345_230_AT4

Sun 09/20/2020 to Sun 09/20/2020
 0500 Continuous 2100
 Work scheduled by: NYPA

FWD REV
 (Import) (Export)
 SCH - OH - NY **1900 MW 1400 MW**
 Impacts Total Transfer Capability 50 MW 300 MW
 TTC with All Lines In Service 1950 MW 1700 MW

CLAY__-EDIC__345_1-16

Mon 09/21/2020 to Fri 09/25/2020
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 OSWEGO EXPORT **4850 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 5250 MW

FRASANNX-COOPERS__345_UCC2-41

Mon 09/21/2020 to Wed 09/30/2020 **EXTENDED by NYPA 07/21/2020**
 0700 Continuous 1730
 Work scheduled by: NYPA **ARR: 19**

FWD
 (Import)
 CENTRAL EAST - VC **2500 MW**
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Thursday ,July 30, 2020 to Saturday ,January 29, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___-FRASANNX_345_UCC2-41					FWD	
Mon 09/21/2020	to	Wed 09/30/2020	<u>EXTENDED</u>	<u>by NYPA</u>	<u>07/21/2020</u>	(Import)
0700	Continuous	1730				2500 MW
Work scheduled by: NYPA					ARR: 19	CENTRAL EAST - VC Impacts Total Transfer Capability 475 MW TTC with All Lines In Service 2975 MW
ROSETON_-ROCKTVRN_345_311					FWD	
Mon 09/21/2020	to	Fri 10/23/2020	<u>UPDATED</u>	<u>by CHGE</u>	<u>10/09/2019</u>	(Import)
0800	Continuous	1600				4400 MW
Work scheduled by: CHGE						UPNY CONED Impacts Total Transfer Capability 1820 MW TTC with All Lines In Service 6220 MW
GOETHALS_345KV_5						
Tue 09/22/2020	to	Tue 09/22/2020	<u>UPDATED</u>	<u>by CE</u>	<u>06/24/2020</u>	
0200	Continuous	0230				STATEN ISLAND Impacts Total Transfer Capability TTC with All Lines In Service
Work scheduled by: PJM						
LINDEN_-GOETHALS_230_A2253					FWD	REV
Tue 09/22/2020	to	Wed 09/23/2020	<u>UPDATED</u>	<u>by CE</u>	<u>06/24/2020</u>	(Import) (Export)
0200	Continuous	2359				2050 MW 1150 MW
Work scheduled by: PJM					SCH - PJ - NY	Impacts Total Transfer Capability 150 MW 100 MW TTC with All Lines In Service 2200 MW 1250 MW
LINDEN_-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402					FWD	REV
Tue 09/22/2020	to	Wed 09/23/2020				(Import) (Export)
0200		2359				2000 MW 1000 MW
Work scheduled by:					SCH - PJ - NY	Impacts Total Transfer Capability 200 MW 250 MW TTC with All Lines In Service 2200 MW 1250 MW
LINDEN_-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403					FWD	REV
Tue 09/22/2020	to	Wed 09/23/2020				(Import) (Export)
0200		2359				2000 MW 1000 MW
Work scheduled by:					SCH - PJ - NY	Impacts Total Transfer Capability 200 MW 250 MW TTC with All Lines In Service 2200 MW 1250 MW
LINDEN_-GOETHALS_230_A2253 & MARION_-FARRAGUT_345_C3403					FWD	REV
Tue 09/22/2020	to	Wed 09/23/2020				(Import) (Export)
0200		2359				2000 MW 1000 MW
Work scheduled by:					SCH - PJ - NY	Impacts Total Transfer Capability 200 MW 250 MW TTC with All Lines In Service 2200 MW 1250 MW

NYISO TRANSFER LIMITATIONS

Thursday ,July 30, 2020 to Saturday ,January 29, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>SCRIBA__-VOLNEY__345_21</p> <p>Wed 09/23/2020 to Thu 09/24/2020</p> <p style="padding-left: 40px;">0800 Continuous 1630</p> <p>Work scheduled by: NGrid</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>OSWEGO EXPORT 5250 MW</p> <p>Impacts Total Transfer Capability 0 MW</p> <p>TTC with All Lines In Service 5250 MW</p>
<p>LINDEN__-GOETHALS_230_A2253</p> <p>Thu 09/24/2020 to Sat 09/26/2020 UPDATED by PJM 07/06/2020</p> <p style="padding-left: 40px;">0001 Continuous 0300</p> <p>Work scheduled by: PJM</p>	<p style="text-align: right;">FWD REV</p> <p style="text-align: right;">(Import) (Export)</p> <p>SCH - PJ - NY 2050 MW 1150 MW</p> <p>Impacts Total Transfer Capability 150 MW 100 MW</p> <p>TTC with All Lines In Service 2200 MW 1250 MW</p>
<p>LINDEN__-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402</p> <p>Thu 09/24/2020 to Sat 09/26/2020</p> <p style="padding-left: 40px;">0001 0300</p> <p>Work scheduled by:</p>	<p style="text-align: right;">FWD REV</p> <p style="text-align: right;">(Import) (Export)</p> <p>SCH - PJ - NY 2000 MW 1000 MW</p> <p>Impacts Total Transfer Capability 200 MW 250 MW</p> <p>TTC with All Lines In Service 2200 MW 1250 MW</p>
<p>LINDEN__-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402 & MARION__-FARRAGUT_345_C3403</p> <p>Thu 09/24/2020 to Sat 09/26/2020</p> <p style="padding-left: 40px;">0001 0300</p> <p>Work scheduled by:</p>	<p style="text-align: right;">FWD REV</p> <p style="text-align: right;">(Import) (Export)</p> <p>SCH - PJ - NY 2000 MW 1000 MW</p> <p>Impacts Total Transfer Capability 200 MW 250 MW</p> <p>TTC with All Lines In Service 2200 MW 1250 MW</p>
<p>LINDEN__-GOETHALS_230_A2253 & MARION__-FARRAGUT_345_C3403</p> <p>Thu 09/24/2020 to Sat 09/26/2020</p> <p style="padding-left: 40px;">0001 0300</p> <p>Work scheduled by:</p>	<p style="text-align: right;">FWD REV</p> <p style="text-align: right;">(Import) (Export)</p> <p>SCH - PJ - NY 2000 MW 1000 MW</p> <p>Impacts Total Transfer Capability 200 MW 250 MW</p> <p>TTC with All Lines In Service 2200 MW 1250 MW</p>
<p>W49TH_ST_345KV_5</p> <p>Fri 09/25/2020 to Sat 09/26/2020 CANCELLED by ConEd 07/25/2020</p> <p style="padding-left: 40px;">0001 Continuous 0300</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>SCH - PJM_HTP 300 MW</p> <p>Impacts Total Transfer Capability 360 MW</p> <p>TTC with All Lines In Service 660 MW</p>
<p>W49TH_ST_345KV_5</p> <p>Fri 09/25/2020 to Sat 09/26/2020</p> <p style="padding-left: 40px;">0001 Continuous 0300</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>SCH - PJM_HTP 300 MW</p> <p>Impacts Total Transfer Capability 360 MW</p> <p>TTC with All Lines In Service 660 MW</p>

NYISO TRANSFER LIMITATIONS

Thursday ,July 30, 2020 to Saturday ,January 29, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_7

Fri 09/25/2020 to Sat 09/26/2020
 0001 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

W49TH_ST_345KV_7

Fri 09/25/2020 to Sat 09/26/2020 **CANCELLED by ConEd 07/25/2020**
 0001 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

MILLWOOD_345KV_18

Fri 09/25/2020 to Fri 09/25/2020
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1870 MW
 TTC with All Lines In Service 6220 MW

EASTVIEW-SPRNBRK__345_W78

Sat 09/26/2020 to Sun 09/27/2020 **UPDATED by CONED 06/16/2020**
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1870 MW
 TTC with All Lines In Service 6220 MW

MILLWOOD-EASTVIEW_345_W85

Sat 09/26/2020 to Sun 09/27/2020 **UPDATED by CONED 06/16/2020**
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **5985 MW**
 Impacts Total Transfer Capability 235 MW
 TTC with All Lines In Service 6220 MW

SPRNBRK__345KV_RNS3

Sat 09/26/2020 to Sun 09/27/2020 **UPDATED by CONED 06/16/2020**
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

GOETHALS_345KV_5

Sat 09/26/2020 to Sat 09/26/2020 **UPDATED by PJM 07/06/2020**
 0230 Continuous 0300
 Work scheduled by: PJM

FWD
 (Import)
 STATEN ISLAND
 Impacts Total Transfer Capability
 TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Thursday ,July 30, 2020 to Saturday ,January 29, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CRICKVLY-PLSNTVLY_345_F83	FWD	REV
Mon 09/28/2020 to Sun 10/04/2020	(Import)	(Export)
0001 Continuous 2200	SCH - NE - NY 350 MW	
Work scheduled by: ConEd	Impacts Total Transfer Capability 1050 MW	
	TTC with All Lines In Service 1400 MW	
CRICKVLY-PLSNTVLY_345_F83	FWD	REV
Mon 09/28/2020 to Sun 10/04/2020	(Import)	(Export)
0001 Continuous 2200	SCH - NPX_1385 100 MW	100 MW
Work scheduled by: ConEd	Impacts Total Transfer Capability 100 MW	100 MW
	TTC with All Lines In Service 200 MW	200 MW
NRTH1385-NOR HBR_138_601 & CRICKVLY-PLSNTVLY_345_F83	FWD	REV
Mon 09/28/2020 to Sun 10/04/2020	(Import)	(Export)
0500 2200	SCH - NPX_1385 0 MW	0 MW
Work scheduled by:	Impacts Total Transfer Capability 200 MW	200 MW
	TTC with All Lines In Service 200 MW	200 MW
NRTH1385-NOR HBR_138_602 & CRICKVLY-PLSNTVLY_345_F83	FWD	REV
Mon 09/28/2020 to Sun 10/04/2020	(Import)	(Export)
0500 2200	SCH - NPX_1385 0 MW	0 MW
Work scheduled by:	Impacts Total Transfer Capability 200 MW	200 MW
	TTC with All Lines In Service 200 MW	200 MW
NRTH1385-NOR HBR_138_603 & CRICKVLY-PLSNTVLY_345_F83	FWD	REV
Mon 09/28/2020 to Sun 10/04/2020	(Import)	(Export)
0500 2200	SCH - NPX_1385 0 MW	0 MW
Work scheduled by:	Impacts Total Transfer Capability 200 MW	200 MW
	TTC with All Lines In Service 200 MW	200 MW
NRTH1385-NOR HBR_138_601	FWD	REV
Mon 09/28/2020 to Sat 10/17/2020	(Import)	(Export)
0500 Continuous 2359 UPDATED by LIPA 07/10/2020	SCH - NPX_1385 100 MW	100 MW
Work scheduled by: LI	Impacts Total Transfer Capability 100 MW	100 MW
	TTC with All Lines In Service 200 MW	200 MW
NRTH1385-NOR HBR_138_601 & NRTH1385-NOR HBR_138_602	FWD	REV
Mon 09/28/2020 to Sat 10/17/2020	(Import)	(Export)
0500 2359	SCH - NPX_1385 0 MW	0 MW
Work scheduled by:	Impacts Total Transfer Capability 200 MW	200 MW
	TTC with All Lines In Service 200 MW	200 MW

NYISO TRANSFER LIMITATIONS

Thursday ,July 30, 2020 to Saturday ,January 29, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_603							
Mon 09/28/2020	to	Sat 10/17/2020					
0500		2359			SCH - NPX_1385	0 MW	0 MW
Work scheduled by:						Impacts Total Transfer Capability	200 MW
						TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR__138_602						FWD	REV
						(Import)	(Export)
Mon 09/28/2020	to	Sat 10/17/2020	UPDATED	by LIPA	07/10/2020		
0500	Continuous	2359			SCH - NPX_1385	100 MW	100 MW
Work scheduled by: LI						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR__138_602 & NRTH1385-NOR HBR__138_603						FWD	REV
						(Import)	(Export)
Mon 09/28/2020	to	Sat 10/17/2020					
0500		2359			SCH - NPX_1385	0 MW	0 MW
Work scheduled by:						Impacts Total Transfer Capability	200 MW
						TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR__138_603						FWD	REV
						(Import)	(Export)
Mon 09/28/2020	to	Sat 10/17/2020	UPDATED	by LIPA	07/10/2020		
0500	Continuous	2359			SCH - NPX_1385	100 MW	100 MW
Work scheduled by: LI						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
NRTH1385-NRTHPORT_138_NNC						FWD	REV
						(Import)	(Export)
Mon 09/28/2020	to	Sat 10/17/2020	UPDATED	by LIPA	07/10/2020		
0500	Continuous	2359			SCH - NPX_1385	0 MW	0 MW
Work scheduled by: LI						Impacts Total Transfer Capability	200 MW
						TTC with All Lines In Service	200 MW
CLAY__-EDIC__345_2-15						FWD	
						(Import)	
Mon 09/28/2020	to	Fri 10/02/2020					
0700	Continuous	1530			OSWEGO EXPORT	4850 MW	
Work scheduled by: NYPA						Impacts Total Transfer Capability	400 MW
						TTC with All Lines In Service	5250 MW
MOTTHAVN-RAINEY__345_Q11						FWD	
						(Import)	
Thu 10/01/2020	to	Thu 11/05/2020	UPDATED	by CONED	12/17/2019		
0001	Continuous	0200			SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Thursday ,July 30, 2020 to Saturday ,January 29, 2022

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EDIC -FRASER 345_EF24-40

Thu 10/01/2020 to Fri 10/02/2020
 0700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2500 MW**
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

HUDSONTP-W49TH_ST_345_Y56

Fri 10/02/2020 to Thu 10/08/2020
 0001 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

W49TH_ST_345KV_7

Fri 10/02/2020 to Thu 10/08/2020
 0001 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

W49TH_ST_345KV_8

Fri 10/02/2020 to Thu 10/08/2020
 0001 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **450 MW**
 Impacts Total Transfer Capability 210 MW
 TTC with All Lines In Service 660 MW

PANNELL -CLAY 345_1

Mon 10/05/2020 to Fri 10/09/2020 **UPDATED by NYPA 05/07/2020**
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 WEST CENTRAL **1300 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

DUNWODIE-MOTTHAVN_345_71

Wed 10/07/2020 to Thu 10/08/2020 **UPDATED by CONED 07/22/2020**
 0001 Continuous 0100
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_5

Wed 10/07/2020 to Thu 10/08/2020 **UPDATED by CONED 07/22/2020**
 0001 Continuous 0100
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Thursday ,July 30, 2020 to Saturday ,January 29, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_3					FWD	
Wed 10/07/2020	to	Thu 11/12/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>07/22/2020</u>	(Import)
0001	Continuous	0100				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_4					FWD	
Wed 10/07/2020	to	Thu 11/12/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>07/22/2020</u>	(Import)
0001	Continuous	0100				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service	4600 MW
PLSNTVLE-DUNWODIE_345_W89					FWD	
Wed 10/07/2020	to	Thu 11/12/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>07/22/2020</u>	(Import)
0001	Continuous	0100				4000 MW
Work scheduled by: ConEd					UPNY CONED	Impacts Total Transfer Capability 2220 MW
					TTC with All Lines In Service	6220 MW
SAND_BAR-PLATSBRG_115_PV20						
Sat 10/17/2020	to	Sat 11/14/2020				
0600	Continuous	1800				
Work scheduled by: ISONE					SCH - NE - NY	Impacts Total Transfer Capability
					TTC with All Lines In Service	
ROCHESTR-PANNELL_345_RP1					FWD	
Mon 10/19/2020	to	Fri 10/23/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>03/10/2020</u>	(Import)
0500	Continuous	1700				2300 MW
Work scheduled by: NYPA					DYSINGER EAST	Impacts Total Transfer Capability 850 MW
					TTC with All Lines In Service	3150 MW
SCH-NE-NYISO_LIMIT_600					FWD	
Mon 10/19/2020	to	Sat 10/31/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>06/05/2020</u>	(Import)
0630	Continuous	2359				800 MW
Work scheduled by: NGrid					SCH - NE - NY	Impacts Total Transfer Capability 600 MW
					TTC with All Lines In Service	1400 MW
SCH-NYISO-NE_LIMIT_800					REV	
Mon 10/19/2020	to	Sat 10/31/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>06/05/2020</u>	(Export)
0630	Continuous	2359				1000 MW
Work scheduled by: NGrid					SCH - NE - NY	Impacts Total Transfer Capability 600 MW
					TTC with All Lines In Service	1600 MW

NYISO TRANSFER LIMITATIONS

Thursday ,July 30, 2020 to Saturday ,January 29, 2022

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					FWD	REV
BERKSHIR-ALPS	345_393				(Import)	(Export)
Mon 10/19/2020	to	Tue 11/10/2020	UPDATED	by ISONE	06/05/2020	
0630	Continuous	1630				
Work scheduled by: NGrid				ARR: 78		
					SCH - NE - NY	950 MW
					Impacts Total Transfer Capability	450 MW
					TTC with All Lines In Service	1400 MW
<hr/>					FWD	REV
BERKSHIR-ALPS	345_393				(Import)	(Export)
Mon 10/19/2020	to	Tue 11/10/2020	UPDATED	by ISONE	06/05/2020	
0630	Continuous	1630				
Work scheduled by: NGrid				ARR: 78		
					SCH - NPX_1385	100 MW
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
<hr/>					FWD	REV
BERKSHIR-ALPS	345_393	& BERKSHIR-NORTHFLD_345_312			(Import)	(Export)
Mon 10/19/2020	to	Tue 11/10/2020				
0630		1630				
Work scheduled by:				ARR: 78		
					SCH - NE - NY	950 MW
					Impacts Total Transfer Capability	450 MW
					TTC with All Lines In Service	1400 MW
<hr/>					FWD	REV
BERKSHIR-NORTHFLD_345_312					(Import)	(Export)
Mon 10/19/2020	to	Tue 11/10/2020	UPDATED	by ISONE	06/05/2020	
0630	Continuous	1630				
Work scheduled by: NGrid						
					SCH - NE - NY	900 MW
					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1400 MW
<hr/>					FWD	REV
BERKSHIR-NORTHFLD_345_312					(Import)	(Export)
Mon 10/19/2020	to	Tue 11/10/2020	UPDATED	by ISONE	06/05/2020	
0630	Continuous	1630				
Work scheduled by: NGrid						
					SCH - NPX_1385	100 MW
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
<hr/>					FWD	REV
SHOR_NPX-SHOREHAM_138_CSC					(Import)	(Export)
Mon 10/19/2020	to	Fri 10/23/2020	UPDATED	by LI	03/02/2020	
0700	Continuous	1500				
Work scheduled by: LI						
					SCH - NPX_CSC	0 MW
					Impacts Total Transfer Capability	330 MW
					TTC with All Lines In Service	330 MW
<hr/>					FWD	REV
PANNELL_-CLAY_345_2					(Import)	(Export)
Mon 10/19/2020	to	Fri 10/23/2020	UPDATED	by NYPA	05/07/2020	
0700	Continuous	1530				
Work scheduled by: NYPA						
					WEST CENTRAL	1300 MW
					Impacts Total Transfer Capability	950 MW
					TTC with All Lines In Service	2250 MW

NYISO TRANSFER LIMITATIONS

Thursday ,July 30, 2020 to Saturday ,January 29, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

COOPERS_-DOLSONAV_345_CCDA42				FWD
Mon 10/19/2020	to	Fri 11/06/2020		(Import)
0700	Continuous	1730	CENTRAL EAST - VC	2720 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 255 MW
				TTC with All Lines In Service 2975 MW
SPRNBRK_-TREMONT__345_X28				FWD
Mon 10/26/2020	to	Mon 10/26/2020		(Import)
0001	Continuous	0030	SPR/DUN-SOUTH	4200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 400 MW
				TTC with All Lines In Service 4600 MW
LEEDS___345_LEEDS SVC				FWD
Mon 10/26/2020	to	Fri 10/30/2020		(Import)
0800	Continuous	1600	CENTRAL EAST - VC	2950 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 25 MW
				TTC with All Lines In Service 2975 MW
LEEDS___-HURLYAVE_345_301				FWD
Mon 10/26/2020	to	Fri 12/04/2020		(Import)
0800	Continuous	1600	UPNY CONED	4100 MW
Work scheduled by: CHGE				Impacts Total Transfer Capability 2120 MW
				TTC with All Lines In Service 6220 MW
SCH-NE-NYISO_LIMIT_800				FWD
Sun 11/01/2020	to	Tue 11/10/2020	UPDATED by ISONE 06/05/2020	(Import)
0001	Continuous	1630	SCH - NE - NY	1000 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 400 MW
				TTC with All Lines In Service 1400 MW
SCH-NYISO-NE_LIMIT_700				REV
Sun 11/01/2020	to	Tue 11/10/2020	UPDATED by ISONE 06/05/2020	(Export)
0001	Continuous	1630	SCH - NE - NY	900 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 1700 MW
SCH-IMO-NYISO_LIMIT_1750				FWD
Sun 11/01/2020	to	Fri 04/30/2021	UPDATED by IESO 05/03/2019	(Import)
0001	Continuous	2359	SCH - OH - NY	2050 MW
Work scheduled by: IESO				Impacts Total Transfer Capability 0 MW
				TTC with All Lines In Service 2050 MW

NYISO TRANSFER LIMITATIONS

Thursday ,July 30, 2020 to Saturday ,January 29, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>							
SCH-NYISO-IMO_LIMIT_1600							REV
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>		(Export)
0001	Continuous	2359				SCH - OH - NY	1900 MW
Work scheduled by: IESO						Impacts Total Transfer Capability	0 MW
						TTC with All Lines In Service	1900 MW
<hr/>							
NIAGARA_345KV_3002							FWD REV
Thu 11/05/2020	to	Thu 11/05/2020				(Import) (Export)	
0500	Continuous	2100				SCH - OH - NY	1550 MW 1400 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	500 MW 500 MW
						TTC with All Lines In Service	2050 MW 1900 MW
<hr/>							
NIAGARA_345KV_3022							FWD REV
Thu 11/05/2020	to	Thu 11/05/2020				(Import) (Export)	
0500	Continuous	2100				SCH - OH - NY	1550 MW 1400 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	500 MW 500 MW
						TTC with All Lines In Service	2050 MW 1900 MW
<hr/>							
SPRNBRK_-TREMONT_345_X28							FWD
Fri 11/06/2020	to	Sat 11/07/2020				(Import)	
0001	Continuous	0059				SPR/DUN-SOUTH	4200 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	400 MW
						TTC with All Lines In Service	4600 MW
<hr/>							
NIAGARA_345KV_3102							FWD REV
Fri 11/06/2020	to	Fri 11/06/2020				(Import) (Export)	
0500	Continuous	2100				SCH - OH - NY	2000 MW 1700 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	50 MW 200 MW
						TTC with All Lines In Service	2050 MW 1900 MW
<hr/>							
NIAGARA_345_230_AT4							REV
Fri 11/06/2020	to	Fri 11/06/2020				(Export)	
0500	Continuous	2100				SCH - OH - NY	1750 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	150 MW
						TTC with All Lines In Service	1900 MW
<hr/>							
SPRNBRK_-TREMONT_345_X28							FWD
Mon 11/09/2020	to	Mon 11/09/2020				(Import)	
0030	Continuous	0059				SPR/DUN-SOUTH	4200 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	400 MW
						TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Thursday ,July 30, 2020 to Saturday ,January 29, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE-MOTTHAVN_345_71				FWD
Tue 11/10/2020	to	Thu 11/12/2020	UPDATED	(Import)
0001	Continuous	0100	by CONED 07/22/2020	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_5				FWD
Tue 11/10/2020	to	Thu 11/12/2020	UPDATED	(Import)
0001	Continuous	0100	by CONED 07/22/2020	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
CHATGUAY-MASSENA_765_7040				FWD
Sun 11/15/2020	to	Mon 11/30/2020		(Import)
0100	Continuous	1900		1550 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 1600 MW
				TTC with All Lines In Service 3150 MW
CHATGUAY-MASSENA_765_7040				FWD REV
Sun 11/15/2020	to	Mon 11/30/2020		(Import) (Export)
0100	Continuous	1900		0 MW 0 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 1500 MW 1000 MW
				TTC with All Lines In Service 1500 MW 1000 MW
MARCY___765_345_AT1				FWD
Sun 11/15/2020	to	Mon 11/30/2020		(Import)
0100	Continuous	1900		1750 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 1400 MW
ARR: 19				TTC with All Lines In Service 3150 MW
MARCY___765_345_AT2				FWD
Sun 11/15/2020	to	Mon 11/30/2020		(Import)
0100	Continuous	1900		1700 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 1450 MW
ARR: 19				TTC with All Lines In Service 3150 MW
MASSENA_-MARCY___765_MSU1				FWD
Sun 11/15/2020	to	Mon 11/30/2020		(Import)
0100	Continuous	1900		2265 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 710 MW
				TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Thursday ,July 30, 2020 to Saturday ,January 29, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA -MARCY 765_MSU1		FWD	
Sun 11/15/2020	to Mon 11/30/2020	(Import)	
0100	Continuous 1900	MOSES SOUTH	500 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	2650 MW
		TTC with All Lines In Service	3150 MW
MASSENA -MARCY 765_MSU1		FWD	REV
Sun 11/15/2020	to Mon 11/30/2020	(Import)	(Export)
0100	Continuous 1900	SCH - HQ - NY	475 MW 1000 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	1025 MW 0 MW
		TTC with All Lines In Service	1500 MW 1000 MW
MASSENA -MARCY 765_MSU1		FWD	
Sun 11/15/2020	to Mon 11/30/2020	(Import)	
0100	Continuous 1900	SCH - HQ_CEDARS	90 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	109 MW
		TTC with All Lines In Service	199 MW
MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040		FWD	
Sun 11/15/2020	to Mon 11/30/2020	(Import)	
0100	1900	MOSES SOUTH	500 MW
Work scheduled by:		Impacts Total Transfer Capability	2650 MW
		TTC with All Lines In Service	3150 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2		FWD	REV
Sun 11/15/2020	to Mon 11/30/2020	(Import)	(Export)
0100	1900	SCH - HQ - NY	850 MW 0 MW
Work scheduled by:		Impacts Total Transfer Capability	650 MW 1000 MW
		TTC with All Lines In Service	1500 MW 1000 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2		FWD	
Sun 11/15/2020	to Mon 11/30/2020	(Import)	
0100	1900	SCH - HQ_CEDARS	90 MW
Work scheduled by:		Impacts Total Transfer Capability	109 MW
		TTC with All Lines In Service	199 MW
STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1		FWD	
Sun 11/15/2020	to Mon 11/30/2020	(Import)	
0100	1900	SCH - HQ_CEDARS	90 MW
Work scheduled by:		Impacts Total Transfer Capability	109 MW
		TTC with All Lines In Service	199 MW

NYISO TRANSFER LIMITATIONS

Thursday ,July 30, 2020 to Saturday ,January 29, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE-DUFFYAVE_345_501

Mon 11/30/2020 to Sun 12/20/2020
0600 Continuous 1600

Work scheduled by: PJM

UPDATED by LI 04/29/2020

FWD
(Import)
0 MW
SCH - PJM_NEPTUNE
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

MARCY_345KV_CSC

Tue 12/01/2020 to Fri 12/11/2020
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
2925 MW
CENTRAL EAST - VC
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

MOSES-ADIRNDCK_230_MA1

Tue 12/01/2020 to Sat 02/27/2021
0700 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 07/27/2020

FWD
(Import)
2300 MW
MOSES SOUTH
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

KINTIGH-ROCHESTR_345_SR1-39

Thu 12/03/2020 to Tue 12/15/2020
0800 Continuous 1900

Work scheduled by: RGE

UPDATED by NYISO 06/24/2020

FWD
(Import)
1700 MW
DYSINGER EAST
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

NIAGARA-KINTIGH_345_NS1-38

Thu 12/03/2020 to Tue 12/15/2020
0800 Continuous 1900

Work scheduled by: RGE

UPDATED by NYISO 06/24/2020

FWD
(Import)
1700 MW
DYSINGER EAST
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

BECK-PACKARD_230_BP76

Fri 12/04/2020 to Fri 12/04/2020
0730 Daily(No Weekends) 1530

Work scheduled by: NGrid

FWD REV
(Import) (Export)
1650 MW 1400 MW
SCH - OH - NY
Impacts Total Transfer Capability 400 MW 500 MW
TTC with All Lines In Service 2050 MW 1900 MW

SAND_BAR-PLATSBRG_115_PV20

Mon 12/07/2020 to Fri 12/11/2020
0700 Continuous 1530

Work scheduled by: NYPA

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Thursday ,July 30, 2020 to Saturday ,January 29, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_6			FWD	
Tue 12/08/2020	to	Tue 12/08/2020	(Import)	
0301	Continuous	0330	SCH - PJM_HTP	300 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	360 MW
			TTC with All Lines In Service	660 MW
E13THSTA-FARRAGUT_345_46			FWD	
Tue 12/08/2020	to	Fri 12/11/2020	(Import)	
0301	Continuous	0300	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW
W49TH_ST-E13THSTA_345_M55			FWD	
Tue 12/08/2020	to	Fri 12/11/2020	(Import)	
0301	Continuous	0300	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW
LONG_MTN-CRICKVLY_345_398			FWD	REV
Tue 12/08/2020	to	Thu 12/10/2020	(Import)	(Export)
0700	Continuous	1600	SCH - NE - NY	700 MW 1300 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	700 MW 400 MW
			TTC with All Lines In Service	1400 MW 1700 MW
LONG_MTN-CRICKVLY_345_398			FWD	REV
Tue 12/08/2020	to	Thu 12/10/2020	(Import)	(Export)
0700	Continuous	1600	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
SCH-NE-NYISO_LIMIT_400			FWD	
Tue 12/08/2020	to	Thu 12/10/2020	(Import)	
0700	Continuous	1600	SCH - NE - NY	600 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	1400 MW
SCH-NYISO-NE_LIMIT_1000				REV
Tue 12/08/2020	to	Thu 12/10/2020		(Export)
0700	Continuous	1600	SCH - NE - NY	1200 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	500 MW
			TTC with All Lines In Service	1700 MW

NYISO TRANSFER LIMITATIONS

Thursday ,July 30, 2020 to Saturday ,January 29, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>W49TH_ST_345KV_6</p> <p>Fri 12/11/2020 to Fri 12/11/2020 0230 Continuous 0300</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>SCH - PJM_HTP 300 MW</p> <p>Impacts Total Transfer Capability 360 MW</p> <p>TTC with All Lines In Service 660 MW</p>
<p>MARCY -EDIC 345 UE1-7</p> <p>Mon 12/14/2020 to Mon 12/14/2020 0700 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>OSWEGO EXPORT 5250 MW</p> <p>Impacts Total Transfer Capability 0 MW</p> <p>TTC with All Lines In Service 5250 MW</p>
<p>SAND_BAR-PLATSBURG_115_PV20</p> <p>Mon 12/14/2020 to Fri 12/18/2020 0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>SCH - NE - NY</p> <p>Impacts Total Transfer Capability</p> <p>TTC with All Lines In Service</p>
<p>LADENTWN-BUCHAN_S_345_Y88</p> <p>Tue 12/15/2020 to Sat 01/30/2021 0001 Continuous 0300</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>UPNY CONED 5930 MW</p> <p>Impacts Total Transfer Capability 290 MW</p> <p>TTC with All Lines In Service 6220 MW</p>
<p>FRASANX-COOPERS 345 UCC2-41</p> <p>Tue 12/15/2020 to Wed 12/16/2020 0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC 2500 MW</p> <p>Impacts Total Transfer Capability 475 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p>MARCY -FRASANX 345 UCC2-41</p> <p>Tue 12/15/2020 to Wed 12/16/2020 0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC 2500 MW</p> <p>Impacts Total Transfer Capability 475 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p>HOPATCON-RAMAPO 500_5018</p> <p>Mon 02/01/2021 to Wed 02/03/2021 0001 Continuous 2200</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD REV (Import) (Export)</p> <p>SCH - PJ - NY 1250 MW 1200 MW</p> <p>Impacts Total Transfer Capability 1650 MW 650 MW</p> <p>TTC with All Lines In Service 2900 MW 1850 MW</p>

NYISO TRANSFER LIMITATIONS

Thursday ,July 30, 2020 to Saturday ,January 29, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HOPATCON-RAMAPO___500_5018			FWD
Mon 02/01/2021	to	Wed 02/03/2021	(Import)
0001	Continuous	2200	UPNY CONED 6025 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 195 MW
			TTC with All Lines In Service 6220 MW
RAMAPO___345_345_PAR3500			FWD REV
Mon 02/01/2021	to	Wed 02/03/2021	(Import) (Export)
0001	Continuous	2200	SCH - PJ - NY 2150 MW 1250 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 750 MW 600 MW
			TTC with All Lines In Service 2900 MW 1850 MW
RAMAPO___345_345_PAR4500			FWD REV
Mon 02/01/2021	to	Wed 02/03/2021	(Import) (Export)
0001	Continuous	2200	SCH - PJ - NY 2150 MW 1250 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 750 MW 600 MW
			TTC with All Lines In Service 2900 MW 1850 MW
RAMAPO___500_345_BK 1500			FWD REV
Mon 02/01/2021	to	Wed 02/03/2021	(Import) (Export)
0001	Continuous	2200	SCH - PJ - NY 1250 MW 1200 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 1650 MW 650 MW
			TTC with All Lines In Service 2900 MW 1850 MW
RAMAPO___500_345_BK 1500			FWD
Mon 02/01/2021	to	Wed 02/03/2021	(Import)
0001	Continuous	2200	UPNY CONED 6025 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 195 MW
			TTC with All Lines In Service 6220 MW
PLSNTVLY-WOOD_ST___345_F30			FWD
Mon 02/15/2021	to	Tue 02/16/2021	(Import)
0001	Continuous	0200	UPNY CONED 4000 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 2220 MW
			TTC with All Lines In Service 6220 MW
PLSNTVLY_345KV_RNS5			FWD
Mon 02/15/2021	to	Tue 02/16/2021	(Import)
0001	Continuous	0200	UPNY CONED 3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 2420 MW
			TTC with All Lines In Service 6220 MW

NYISO TRANSFER LIMITATIONS

Thursday ,July 30, 2020 to Saturday ,January 29, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EFISHKIL-WOOD_ST__345_F39					FWD	
Thu 02/18/2021	to	Sat 02/20/2021	<u>UPDATED</u>	<u>by CE</u>	<u>04/01/2020</u>	(Import)
2100	Continuous	0200				UPNY CONED 4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 2220 MW	
					TTC with All Lines In Service 6220 MW	
WOOD_ST_-PLSNTVLE_345_Y87					FWD	
Thu 02/18/2021	to	Sat 02/20/2021	<u>UPDATED</u>	<u>by CE</u>	<u>04/01/2020</u>	(Import)
2100	Continuous	0200				UPNY CONED 5905 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 315 MW	
					TTC with All Lines In Service 6220 MW	
CHATGUAY-MASSENA__765_7040					FWD	
Sun 02/28/2021	to	Mon 03/01/2021				(Import)
0500	Continuous	1730				MOSES SOUTH 1550 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 1600 MW	
					TTC with All Lines In Service 3150 MW	
CHATGUAY-MASSENA__765_7040					FWD	REV
Sun 02/28/2021	to	Mon 03/01/2021				(Import) (Export)
0500	Continuous	1730				SCH - HQ - NY 0 MW 0 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 1500 MW	1000 MW
					TTC with All Lines In Service 1500 MW	1000 MW
MASSENA_-MARCY___765_MSU1					FWD	
Sun 02/28/2021	to	Mon 03/01/2021				(Import)
0500	Continuous	1730				CENTRAL EAST - VC 2265 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 710 MW	
					TTC with All Lines In Service 2975 MW	
MASSENA_-MARCY___765_MSU1					FWD	
Sun 02/28/2021	to	Mon 03/01/2021				(Import)
0500	Continuous	1730				MOSES SOUTH 500 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 2650 MW	
					TTC with All Lines In Service 3150 MW	
MASSENA_-MARCY___765_MSU1					FWD	REV
Sun 02/28/2021	to	Mon 03/01/2021				(Import) (Export)
0500	Continuous	1730				SCH - HQ - NY 475 MW 1000 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 1025 MW	0 MW
					TTC with All Lines In Service 1500 MW	1000 MW

NYISO TRANSFER LIMITATIONS

Thursday ,July 30, 2020 to Saturday ,January 29, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA_-MARCY___765_MSU1

Sun 02/28/2021 to Mon 03/01/2021
0500 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)

SCH - HQ_CEDARS **90 MW**
Impacts Total Transfer Capability 109 MW
TTC with All Lines In Service 199 MW

MASSENA_-MARCY___765_MSU1 & CHATGUAY-MASSENA_765_7040

Sun 02/28/2021 to Mon 03/01/2021
0500 1730

Work scheduled by:

FWD
(Import)

MOSES SOUTH **500 MW**
Impacts Total Transfer Capability 2650 MW
TTC with All Lines In Service 3150 MW

STLAWRNC-MOSES___230_L33P & MASSENA_-MARCY___765_MSU1

Sun 02/28/2021 to Mon 03/01/2021
0500 1730

Work scheduled by:

FWD
(Import)

SCH - HQ_CEDARS **90 MW**
Impacts Total Transfer Capability 109 MW
TTC with All Lines In Service 199 MW

DUNWODIE_345KV_3

Mon 03/01/2021 to Mon 03/01/2021
0001 Continuous 0030

Work scheduled by: ConEd

FWD
(Import)

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_5

Mon 03/01/2021 to Mon 03/01/2021
0001 Continuous 0030

Work scheduled by: ConEd

FWD
(Import)

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

EASTVIEW-SPRNBK___345_W64

Mon 03/01/2021 to Mon 03/01/2021 **UPDATED by CONED 01/23/2020**
0001 Continuous 0030

Work scheduled by: ConEd

FWD
(Import)

UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1870 MW
TTC with All Lines In Service 6220 MW

SPRNBK___345KV_RNS5

Mon 03/01/2021 to Mon 03/01/2021 **UPDATED by CONED 01/23/2020**
0001 Continuous 0030

Work scheduled by: ConEd

FWD
(Import)

SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Thursday ,July 30, 2020 to Saturday ,January 29, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD-EASTVIEW_345_W99					FWD	
Mon 03/01/2021	to	Mon 03/22/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>01/23/2020</u>	(Import)
0001	Continuous	0200				UPNY CONED 5985 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 235 MW	
					TTC with All Lines In Service 6220 MW	
DUNWODIE-MOTTHAVN_345_71					FWD	
Mon 03/01/2021	to	Mon 04/05/2021				(Import)
0001	Continuous	0300				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW	
					TTC with All Lines In Service 4600 MW	
MOTTHAVN-RAINEY___345_Q11					FWD	
Mon 03/01/2021	to	Tue 04/06/2021				(Import)
0001	Continuous	0700				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW	
					TTC with All Lines In Service 4600 MW	
MOSES___-ADIRNDCK_230_MA1					FWD	
Tue 03/02/2021	to	Mon 05/31/2021				(Import)
0700	Continuous	1300				MOSES SOUTH 2300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 850 MW	
					TTC with All Lines In Service 3150 MW	
NIAGARA_-ROBNSNRD_230_64					REV	
Fri 03/12/2021	to	Fri 03/12/2021				(Export)
0500	Continuous	1700				SCH - OH - NY 1900 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 0 MW	
					TTC with All Lines In Service 1900 MW	
MARCY___345KV_CSC					FWD	
Sat 03/13/2021	to	Sat 03/13/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>07/29/2020</u>	(Import)
0700	Continuous	1730				CENTRAL EAST - VC 2925 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 50 MW	
					TTC with All Lines In Service 2975 MW	
EASTVIEW-SPRNBK__345_W64					FWD	
Mon 03/22/2021	to	Mon 03/22/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>01/23/2020</u>	(Import)
0130	Continuous	0200				UPNY CONED 4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1870 MW	
					TTC with All Lines In Service 6220 MW	

NYISO TRANSFER LIMITATIONS

Thursday ,July 30, 2020 to Saturday ,January 29, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK	Zone	Start	End	Work by	Update	Impact	TTC	FWD	REV
SPRNBRK__345KV_RNS5								FWD	
Mon 03/22/2021	to	Mon 03/22/2021			<u>UPDATED</u> <u>by CONED</u> <u>01/23/2020</u>			(Import)	
0130	Continuous	0200				SPR/DUN-SOUTH	3200 MW		
Work scheduled by: ConEd							Impacts Total Transfer Capability	1400 MW	
							TTC with All Lines In Service	4600 MW	
CLAY__-EDIC__345_2-15								FWD	
Mon 03/29/2021	to	Fri 04/16/2021						(Import)	
0800	Continuous	1730				OSWEGO EXPORT	4850 MW		
Work scheduled by: NYPA							Impacts Total Transfer Capability	400 MW	
							TTC with All Lines In Service	5250 MW	
ROCHESTR-PANNELL__345_RP2								FWD	
Wed 03/31/2021	to	Mon 04/12/2021						(Import)	
0500	Continuous	1700				DYSINGER EAST	2300 MW		
Work scheduled by: NYPA							Impacts Total Transfer Capability	850 MW	
							TTC with All Lines In Service	3150 MW	
DUNWODIE_345KV_3								FWD	
Mon 04/05/2021	to	Mon 04/05/2021						(Import)	
0230	Continuous	0300				SPR/DUN-SOUTH	3800 MW		
Work scheduled by: ConEd							Impacts Total Transfer Capability	800 MW	
							TTC with All Lines In Service	4600 MW	
DUNWODIE_345KV_5								FWD	
Mon 04/05/2021	to	Mon 04/05/2021						(Import)	
0230	Continuous	0300				SPR/DUN-SOUTH	3800 MW		
Work scheduled by: ConEd							Impacts Total Transfer Capability	800 MW	
							TTC with All Lines In Service	4600 MW	
SPRNBRK_-TREMONT__345_X28								FWD	
Mon 04/19/2021	to	Tue 04/20/2021						(Import)	
0001	Continuous	0200				SPR/DUN-SOUTH	4200 MW		
Work scheduled by: ConEd							Impacts Total Transfer Capability	400 MW	
							TTC with All Lines In Service	4600 MW	
NIAGARA__345KV_3002								FWD	REV
Mon 04/26/2021	to	Mon 04/26/2021						(Import)	(Export)
0500	Continuous	1700				SCH - OH - NY	1550 MW	1400 MW	
Work scheduled by: NYPA							Impacts Total Transfer Capability	500 MW	500 MW
							TTC with All Lines In Service	2050 MW	1900 MW

NYISO TRANSFER LIMITATIONS

Thursday ,July 30, 2020 to Saturday ,January 29, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO-NYISO_LIMIT_1600

Sat 05/01/2021 to Sun 10/31/2021
0001 Continuous 2359

Work scheduled by: IESO

UPDATED by IESO 05/03/2019

FWD
(Import)
1900 MW
SCH - OH - NY
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 1950 MW

PANNELL -CLAY_345_2

Mon 05/03/2021 to Fri 05/28/2021
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
1300 MW
WEST CENTRAL
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

NIAGARA_345KV_3022

Tue 05/04/2021 to Wed 05/05/2021
0500 Continuous 1700

Work scheduled by: NYPA

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

NIAGARA_345KV_3202

Tue 05/04/2021 to Wed 05/05/2021
0500 Continuous 1700

Work scheduled by: NYPA

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

NIAGARA_345KV_3102

Thu 05/06/2021 to Fri 05/07/2021
0500 Continuous 1700

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
	1700 MW	1400 MW
	Impacts Total Transfer Capability 250 MW	300 MW
	TTC with All Lines In Service 1950 MW	1700 MW

NIAGARA_345KV_3302

Mon 05/10/2021 to Wed 05/12/2021
0500 Continuous 1700

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
	1000 MW	1600 MW
	Impacts Total Transfer Capability 950 MW	100 MW
	TTC with All Lines In Service 1950 MW	1700 MW

NIAGARA_345KV_3108

Thu 05/13/2021 to Fri 05/14/2021
0500 Continuous 1700

Work scheduled by: NYPA

		REV
		(Export)
		1500 MW
	Impacts Total Transfer Capability	200 MW
	TTC with All Lines In Service	1700 MW

NYISO TRANSFER LIMITATIONS

Thursday ,July 30, 2020 to Saturday ,January 29, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -ADIRNDCK_230_MA2				FWD
Tue 06/01/2021	to	Sun 11/14/2021		(Import)
0700	Continuous	1300	MOSES SOUTH	2100 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 1050 MW
				TTC with All Lines In Service 3150 MW
NIAGARA -KINTIGH_345_NS1-38				FWD
Mon 09/13/2021	to	Fri 09/17/2021		(Import)
0500	Continuous	1700	DYSINGER EAST	1400 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 1750 MW
				TTC with All Lines In Service 3150 MW
SPRNBRK -W49TH_ST_345_M51				FWD
Fri 10/01/2021	to	Sun 10/17/2021	UPDATED by NYISO 06/21/2020	(Import)
0001	Continuous	0300	SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW
SPRNBRK_345KV_RNS5				FWD
Fri 10/01/2021	to	Sun 10/17/2021	UPDATED by NYISO 06/21/2020	(Import)
0001	Continuous	0300	SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW
SCH-IMO-NYISO_LIMIT_1750				FWD
Mon 11/01/2021	to	Fri 12/31/2021	UPDATED by IESO 05/03/2019	(Import)
0001	Continuous	2359	SCH - OH - NY	2050 MW
Work scheduled by: IESO				Impacts Total Transfer Capability 0 MW
				TTC with All Lines In Service 2050 MW
SCH-NYISO-IMO_LIMIT_1600				REV
Mon 11/01/2021	to	Fri 12/31/2021	UPDATED by IESO 05/03/2019	(Export)
0001	Continuous	2359	SCH - OH - NY	1900 MW
Work scheduled by: IESO				Impacts Total Transfer Capability 0 MW
				TTC with All Lines In Service 1900 MW
MOSES -ADIRNDCK_230_MA1				FWD
Wed 12/01/2021	to	Tue 05/31/2022		(Import)
0700	Continuous	1300	MOSES SOUTH	2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW