

NYISO TRANSFER LIMITATIONS

Friday ,July 31, 2020 to Sunday ,January 30, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_9_BYPASS & DUNWODIE_345KV_10_BYPASS & SPRNBRK__345KV_R4S3_BYPASS & SPRNBRK__345KV_R5S3_BYPASS

Sun 02/01/2015 to Sat 02/01/2025
0000 0000

Work scheduled by:

UPNY CONED
Impacts Total Transfer Capability
TTC with All Lines In Service

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Thu 10/01/2020
0001 Continuous 2359

Work scheduled by: ConEd

EXTENDED by CONED 05/03/2020

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2050 MW	1150 MW
Impacts Total Transfer Capability	150 MW	100 MW
TTC with All Lines In Service	2200 MW	1250 MW

HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Thu 10/01/2020
0001 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2000 MW	1000 MW
Impacts Total Transfer Capability	200 MW	250 MW
TTC with All Lines In Service	2200 MW	1250 MW

MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Thu 10/01/2020
0001 Continuous 2359

Work scheduled by: ConEd

EXTENDED by CONED 05/03/2020

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2050 MW	1150 MW
Impacts Total Transfer Capability	150 MW	100 MW
TTC with All Lines In Service	2200 MW	1250 MW

STLAWRNC-MOSES__230_L33P

Mon 04/30/2018 to Fri 12/31/2021
0456 Continuous 2359

Work scheduled by: IESO

EXT FORCE by IESO 08/21/2018

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

SCH-IMO-NYISO_LIMIT_1600

Fri 05/01/2020 to Sat 10/31/2020
0001 Continuous 2359

Work scheduled by: IESO

UPDATED by IESO 05/03/2019

	FWD
	(Import)
SCH - OH - NY	1900 MW
Impacts Total Transfer Capability	50 MW
TTC with All Lines In Service	1950 MW

SHOR_NPX-SHOREHAM_138_CSC

Wed 07/08/2020 to Wed 09/02/2020
1247 Continuous 2359

Work scheduled by: LI

EXT FORCE by ISONE 07/20/2020

	FWD	REV
	(Import)	(Export)
SCH - NPX_CSC	0 MW	0 MW
Impacts Total Transfer Capability	330 MW	330 MW
TTC with All Lines In Service	330 MW	330 MW

NYISO TRANSFER LIMITATIONS

Friday ,July 31, 2020 to Sunday ,January 30, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES ___-ADIRNDCK_230_MA2

Fri 07/24/2020 to Sun 07/26/2020
0500 Continuous 2200

Work scheduled by: NYPA

UPDATED by NYPA 07/27/2020

FWD
(Import)

MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

HOMRC_NY-MAINS_NY_345_47

Fri 07/24/2020 to Sun 07/26/2020
1833 Continuous 2359

Work scheduled by: NYSEG

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

BECK ___-NIAGARA_230_PA27

Sat 07/25/2020 to Mon 07/27/2020
0700 Continuous 1000

Work scheduled by: IESO

UPDATED by IESO 07/14/2020

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

SCH-IMO-NYISO_LIMIT_1450

Sat 07/25/2020 to Mon 07/27/2020
0700 Continuous 1000

Work scheduled by: IESO

UPDATED by IESO 07/14/2020

FWD
(Import)
SCH - OH - NY **1750 MW**
Impacts Total Transfer Capability 200 MW
TTC with All Lines In Service 1950 MW

BECK ___-NIAGARA_345_PA302

Thu 07/30/2020 to Fri 07/31/2020
0600 Continuous 1800

Work scheduled by: IESO

CANCELLED by IESO 07/28/2020

FWD REV
(Import) (Export)
SCH - OH - NY **900 MW 800 MW**
Impacts Total Transfer Capability 1050 MW 900 MW
TTC with All Lines In Service 1950 MW 1700 MW

DUNWODIE_345KV_4

Fri 07/31/2020 to Fri 07/31/2020
0001 Continuous 0030

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_6

Fri 07/31/2020 to Fri 07/31/2020
0001 Continuous 0030

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Friday ,July 31, 2020 to Sunday ,January 30, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE-SHORE_RD_345_Y50				FWD
Fri 07/31/2020	to	Tue 08/04/2020		(Import)
0001	Continuous	0259	CONED - LIPA	800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 700 MW
				TTC with All Lines In Service 1500 MW
SHORE_RD_345_138_BK 1				FWD
Fri 07/31/2020	to	Tue 08/04/2020		(Import)
0001	Continuous	0259	CONED - LIPA	1350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 150 MW
				TTC with All Lines In Service 1500 MW
SHORE_RD_345_138_BK 2				FWD
Fri 07/31/2020	to	Tue 08/04/2020		(Import)
0001	Continuous	0259	CONED - LIPA	1350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 150 MW
				TTC with All Lines In Service 1500 MW
MOSES__-ADIRNDCK_230_MA2				FWD
Fri 07/31/2020	to	Sat 09/12/2020	UPDATED by NYPA 07/27/2020	(Import)
0500	Continuous	2359	MOSES SOUTH	2100 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 1050 MW
				TTC with All Lines In Service 3150 MW
DUNWODIE_345KV_6				FWD
Sat 08/01/2020	to	Sat 08/01/2020	UPDATED by CONED 07/31/2020	(Import)
0001	Continuous	0030	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_8				FWD
Sat 08/01/2020	to	Sat 08/01/2020	UPDATED by CONED 07/31/2020	(Import)
0001	Continuous	0030	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
PLSNTVLE-DUNWODIE_345_W90				FWD
Sat 08/01/2020	to	Sat 08/01/2020	UPDATED by CONED 07/31/2020	(Import)
0001	Continuous	1800	UPNY CONED	4000 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 2220 MW
				TTC with All Lines In Service 6220 MW

NYISO TRANSFER LIMITATIONS

Friday ,July 31, 2020 to Sunday ,January 30, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					FWD			
WOOD_ST_-PLSNTVLE_345_Y87					(Import)			
Sat 08/01/2020	to	Sat 08/01/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>07/31/2020</u>	UPNY CONED	5905 MW	
0001	Continuous	1800				Impacts Total Transfer Capability	315 MW	
Work scheduled by: ConEd					TTC with All Lines In Service	6220 MW		
<hr/>					FWD			
DUNWODIE_345KV_6					(Import)			
Sat 08/01/2020	to	Sat 08/01/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>07/31/2020</u>	SPR/DUN-SOUTH	3800 MW	
1730	Continuous	1800				Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd					TTC with All Lines In Service	4600 MW		
<hr/>					FWD			
DUNWODIE_345KV_8					(Import)			
Sat 08/01/2020	to	Sat 08/01/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>07/31/2020</u>	SPR/DUN-SOUTH	3800 MW	
1730	Continuous	1800				Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd					TTC with All Lines In Service	4600 MW		
<hr/>					FWD			
DUNWODIE_345KV_4					(Import)			
Tue 08/04/2020	to	Tue 08/04/2020				SPR/DUN-SOUTH	3800 MW	
0230	Continuous	0259				Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd					TTC with All Lines In Service	4600 MW		
<hr/>					FWD			
DUNWODIE_345KV_6					(Import)			
Tue 08/04/2020	to	Tue 08/04/2020				SPR/DUN-SOUTH	3800 MW	
0230	Continuous	0259				Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd					TTC with All Lines In Service	4600 MW		
<hr/>					FWD	REV		
NRTH1385-NOR HBR_138_601					(Import)	(Export)		
Wed 08/05/2020	to	Fri 08/07/2020				SCH - NPX_1385	100 MW	100 MW
0800	Continuous	1500				Impacts Total Transfer Capability	100 MW	100 MW
Work scheduled by: LI					TTC with All Lines In Service	200 MW	200 MW	
<hr/>					FWD	REV		
NRTH1385-NOR HBR_138_601 & NRTH1385-NOR HBR_138_602					(Import)	(Export)		
Wed 08/05/2020	to	Fri 08/07/2020				SCH - NPX_1385	0 MW	0 MW
0800		1500				Impacts Total Transfer Capability	200 MW	200 MW
Work scheduled by:					TTC with All Lines In Service	200 MW	200 MW	

NYISO TRANSFER LIMITATIONS

Friday ,July 31, 2020 to Sunday ,January 30, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_603 Wed 08/05/2020 to Fri 08/07/2020 0800 1500 Work scheduled by:	SCH - NPX_1385 Impacts Total Transfer Capability TTC with All Lines In Service	FWD (Import) 0 MW 200 MW 200 MW	REV (Export) 0 MW 200 MW 200 MW
<hr/>			
NRTH1385-NOR HBR__138_602 Wed 08/05/2020 to Fri 08/07/2020 0800 Continuous 1500 Work scheduled by: LI	SCH - NPX_1385 Impacts Total Transfer Capability TTC with All Lines In Service	FWD (Import) 100 MW 100 MW 200 MW	REV (Export) 100 MW 100 MW 200 MW
<hr/>			
NRTH1385-NOR HBR__138_602 & NRTH1385-NOR HBR__138_603 Wed 08/05/2020 to Fri 08/07/2020 0800 1500 Work scheduled by:	SCH - NPX_1385 Impacts Total Transfer Capability TTC with All Lines In Service	FWD (Import) 0 MW 200 MW 200 MW	REV (Export) 0 MW 200 MW 200 MW
<hr/>			
NRTH1385-NOR HBR__138_603 Wed 08/05/2020 to Fri 08/07/2020 0800 Continuous 1500 Work scheduled by: LI	SCH - NPX_1385 Impacts Total Transfer Capability TTC with All Lines In Service	FWD (Import) 100 MW 100 MW 200 MW	REV (Export) 100 MW 100 MW 200 MW
<hr/>			
NRTH1385-NRTHPORT_138_NNC Wed 08/05/2020 to Fri 08/07/2020 0800 Continuous 1500 Work scheduled by: LI	SCH - NPX_1385 Impacts Total Transfer Capability TTC with All Lines In Service	FWD (Import) 0 MW 200 MW 200 MW	REV (Export) 0 MW 200 MW 200 MW
<hr/>			
INDPDNCE-SCRIBA__345_25 Thu 08/06/2020 to Thu 08/06/2020 0600 Daily(No Weekends) 1630 Work scheduled by: NGrid	OSWEGO EXPORT Impacts Total Transfer Capability TTC with All Lines In Service	FWD (Import) 5250 MW 0 MW 5250 MW	REV (Export) 5250 MW 0 MW 5250 MW
<hr/>			
CRICKVLY-PLSNTVLY_345_F83 Sat 08/08/2020 to Sat 08/08/2020 0001 Continuous 2200 Work scheduled by: ConEd	SCH - NE - NY Impacts Total Transfer Capability TTC with All Lines In Service	FWD (Import) 350 MW 1050 MW 1400 MW	REV (Export) 350 MW 1050 MW 1400 MW
<hr/>			

NYISO TRANSFER LIMITATIONS

Friday ,July 31, 2020 to Sunday ,January 30, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

	FWD	REV
	(Import)	(Export)
<hr/>		
CRICKVLY-PLSNTVLY_345_F83		
Sat 08/08/2020 to Sat 08/08/2020		
0001 Continuous 2200		
Work scheduled by: ConEd		
	SCH - NPX_1385	100 MW
	Impacts Total Transfer Capability	100 MW
	TTC with All Lines In Service	200 MW
<hr/>		
BECK -NIAGARA_345_PA302		
Sat 08/08/2020 to Sun 08/09/2020		
0500 Continuous 1700		
Work scheduled by: IESO		
	SCH - OH - NY	900 MW
	Impacts Total Transfer Capability	1050 MW
	TTC with All Lines In Service	1950 MW
<hr/>		
SAND_BAR-PLATSBRG_115_PV20		
Sun 08/09/2020 to Sun 08/16/2020		
0800 Continuous 1900		
Work scheduled by: ISONE		
	UPDATED by ISONE 07/28/2020	
	SCH - NE - NY	
	Impacts Total Transfer Capability	
	TTC with All Lines In Service	
<hr/>		
NIAGARA_345KV_3002		
Wed 08/12/2020 to Wed 08/12/2020		
0500 Continuous 0530		
Work scheduled by: NYPA		
	UPDATED by NYPA 07/20/2020	
	SCH - OH - NY	1300 MW
	Impacts Total Transfer Capability	650 MW
	TTC with All Lines In Service	1950 MW
<hr/>		
NIAGARA_345KV_3002		
Thu 08/13/2020 to Thu 08/13/2020		
1830 Continuous 1900		
Work scheduled by: NYPA		
	UPDATED by NYPA 07/20/2020	
	SCH - OH - NY	1300 MW
	Impacts Total Transfer Capability	650 MW
	TTC with All Lines In Service	1950 MW
<hr/>		
S.RIPLEY-DUNKIRK_230_68		
Mon 08/17/2020 to Fri 08/21/2020		
0900 Continuous 1500		
Work scheduled by: PJM		
	SCH - PJ - NY	
	Impacts Total Transfer Capability	
	TTC with All Lines In Service	
<hr/>		
SAND_BAR-PLATSBRG_115_PV20		
Sat 08/22/2020 to Sat 08/29/2020		
0800 Continuous 1900		
Work scheduled by: ISONE		
	UPDATED by ISONE 07/28/2020	
	SCH - NE - NY	
	Impacts Total Transfer Capability	
	TTC with All Lines In Service	

NYISO TRANSFER LIMITATIONS

Friday ,July 31, 2020 to Sunday ,January 30, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA__345KV_3102

Wed 08/26/2020 to Wed 08/26/2020
0500 Continuous 1700

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	1700 MW	1400 MW
Impacts Total Transfer Capability	250 MW	300 MW
TTC with All Lines In Service	1950 MW	1700 MW

STOLLERD-HISHELDN_230_67

Wed 08/26/2020 to Wed 08/26/2020
0900 Continuous 1000

Work scheduled by: NYSEG

	FWD
	(Import)
DYSINGER EAST	2850 MW
Impacts Total Transfer Capability	300 MW
TTC with All Lines In Service	3150 MW

OSWEGO_COMPLEX_AVR_O/S

Sun 09/06/2020 to Sun 09/06/2020
0900 Continuous 0930

Work scheduled by: Gen

	FWD
	(Import)
CENTRAL EAST - VC	2870 MW
Impacts Total Transfer Capability	105 MW
TTC with All Lines In Service	2975 MW

MARCY__-N.SCTLND_345_18

Wed 09/09/2020 to Wed 09/09/2020
0800 Daily(No Weekends) 1500

Work scheduled by: NGrid

ARR: 19

	FWD
	(Import)
CENTRAL EAST - VC	2090 MW
Impacts Total Transfer Capability	885 MW
TTC with All Lines In Service	2975 MW

MEYER__-CANANDGA_230_60

Thu 09/10/2020 to Thu 09/10/2020
0730 Continuous 1630

Work scheduled by: NYSEG

	FWD
	(Import)
DYSINGER EAST	2850 MW
Impacts Total Transfer Capability	300 MW
TTC with All Lines In Service	3150 MW

SPRNBRK_-DUNWODIE_345_W75

Sat 09/12/2020 to Sat 09/12/2020
0001 Continuous 0030

Work scheduled by: ConEd

	FWD
	(Import)
SPR/DUN-SOUTH	3800 MW
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

SPRNBRK__345KV_RNS3

Sat 09/12/2020 to Sat 09/12/2020
0001 Continuous 0030

Work scheduled by: ConEd

	FWD
	(Import)
SPR/DUN-SOUTH	3800 MW
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Friday ,July 31, 2020 to Sunday ,January 30, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_5				FWD
Sat 09/12/2020	to	Sat 09/12/2020		(Import)
0001	Continuous	2100	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_7				FWD
Sat 09/12/2020	to	Sat 09/12/2020		(Import)
0001	Continuous	2100	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
SPRNBRK_-DUNWODIE_345_W75				FWD
Sat 09/12/2020	to	Sat 09/12/2020		(Import)
2030	Continuous	2100	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
SPRNBRK__345KV_RNS3				FWD
Sat 09/12/2020	to	Sat 09/12/2020		(Import)
2030	Continuous	2100	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
MOSES__-ADIRNDCK_230_MA2				FWD
Sun 09/13/2020	to	Sat 11/14/2020	UPDATED by NYPA 07/24/2020	(Import)
0001	Continuous	1300	MOSES SOUTH	2100 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 1050 MW
				TTC with All Lines In Service 3150 MW
KINTIGH_-ROCHESTR_345_SR1-39				FWD
Mon 09/14/2020	to	Thu 09/17/2020		(Import)
0500	Continuous	1530	DYSINGER EAST	1400 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 1750 MW
				TTC with All Lines In Service 3150 MW
NIAGARA_-KINTIGH__345_NS1-38				FWD
Mon 09/14/2020	to	Thu 09/17/2020		(Import)
0500	Continuous	1530	DYSINGER EAST	1400 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 1750 MW
				TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,July 31, 2020 to Sunday ,January 30, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
LINDN_CG-LNDVFT_345_V-3022							
Mon 09/14/2020	to	Wed 09/16/2020					
0800	Continuous	2000			SCH - PJM_VFT	0 MW	0 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	315 MW
						TTC with All Lines In Service	315 MW
WOOD_ST_-PLSNTVLE_345_Y87						FWD	
Tue 09/15/2020	to	Tue 09/15/2020	<u>UPDATED</u>	<u>by CE</u>	<u>07/27/2020</u>	(Import)	
0001	Continuous	2230			UPNY CONED	5905 MW	
Work scheduled by: ConEd						Impacts Total Transfer Capability	315 MW
						TTC with All Lines In Service	6220 MW
EFISHKIL-WOOD_ST_345_F39						FWD	
Tue 09/15/2020	to	Wed 09/16/2020	<u>UPDATED</u>	<u>by CE</u>	<u>07/27/2020</u>	(Import)	
0001	Continuous	2200			UPNY CONED	4000 MW	
Work scheduled by: ConEd						Impacts Total Transfer Capability	2220 MW
						TTC with All Lines In Service	6220 MW
BRANCHBG-HOPATCON_500_5060						FWD	
Tue 09/15/2020	to	Wed 09/16/2020	<u>UPDATED</u>	<u>by PJM</u>	<u>04/20/2020</u>	(Import)	
0200	Continuous	2300			UPNY CONED	6025 MW	
Work scheduled by: PJM						Impacts Total Transfer Capability	195 MW
						TTC with All Lines In Service	6220 MW
DOLSONAV-ROCKTVRN_345_DART44						FWD	
Wed 09/16/2020	to	Wed 09/30/2020				(Import)	
0700	Continuous	1730			CENTRAL EAST - VC	2720 MW	
Work scheduled by: NYPA						Impacts Total Transfer Capability	255 MW
						TTC with All Lines In Service	2975 MW
WOOD_ST_-PLSNTVLE_345_Y87						FWD	
Wed 09/16/2020	to	Wed 09/16/2020	<u>UPDATED</u>	<u>by CE</u>	<u>07/27/2020</u>	(Import)	
2130	Continuous	2200			UPNY CONED	5905 MW	
Work scheduled by: ConEd						Impacts Total Transfer Capability	315 MW
						TTC with All Lines In Service	6220 MW
S.RIPLEY-DUNKIRK_230_68							
Thu 09/17/2020	to	Fri 09/18/2020					
0900	Continuous	1500			SCH - PJ - NY		
Work scheduled by: PJM						Impacts Total Transfer Capability	
						TTC with All Lines In Service	

NYISO TRANSFER LIMITATIONS

Friday ,July 31, 2020 to Sunday ,January 30, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-ROCHESTR_345_NR2

Fri 09/18/2020 to Sat 11/14/2020
0500 Continuous 2330

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

NIAGARA_345KV_3108

Fri 09/18/2020 to Sat 11/14/2020
0500 Continuous 2330

Work scheduled by: NYPA

REV

(Export)

SCH - OH - NY **1500 MW**
Impacts Total Transfer Capability 200 MW
TTC with All Lines In Service 1700 MW

EASTVIEW-SPRNBRK_345_W65

Sat 09/19/2020 to Sat 09/19/2020
0001 Continuous 0030

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1870 MW
TTC with All Lines In Service 6220 MW

MILLWOOD-EASTVIEW_345_W82

Sat 09/19/2020 to Sat 09/19/2020
0001 Continuous 0030

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **5985 MW**
Impacts Total Transfer Capability 235 MW
TTC with All Lines In Service 6220 MW

SPRNBRK_345KV_RNS4

Sat 09/19/2020 to Sat 09/19/2020
0001 Continuous 0030

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

EASTVIEW-SPRNBRK_345_W65

Sat 09/19/2020 to Sat 09/19/2020
0330 Continuous 0400

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1870 MW
TTC with All Lines In Service 6220 MW

MILLWOOD-EASTVIEW_345_W82

Sat 09/19/2020 to Sat 09/19/2020
0330 Continuous 0400

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **5985 MW**
Impacts Total Transfer Capability 235 MW
TTC with All Lines In Service 6220 MW

NYISO TRANSFER LIMITATIONS

Friday ,July 31, 2020 to Sunday ,January 30, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event ID	Start Date	End Date	Time	Duration	Work by	Impact	TTC	FWD	REV
SPRNBK__345KV_RNS4	Sat 09/19/2020	Sat 09/19/2020	0330	0400	Continuous	ConEd	SPR/DUN-SOUTH	3200 MW	
							Impacts Total Transfer Capability	1400 MW	
							TTC with All Lines In Service	4600 MW	
NIAGARA__345KV_3002	Sat 09/19/2020	Sat 09/19/2020	0500	2100	Continuous	NYPA	SCH - OH - NY	1300 MW	1150 MW
							Impacts Total Transfer Capability	650 MW	550 MW
							TTC with All Lines In Service	1950 MW	1700 MW
NIAGARA__345KV_3022	Sat 09/19/2020	Sat 09/19/2020	0500	2100	Continuous	NYPA	SCH - OH - NY		
							Impacts Total Transfer Capability		
							TTC with All Lines In Service		
MILLWOOD_345KV_18	Sun 09/20/2020	Sun 09/20/2020	0001	0030	Continuous	ConEd	UPNY CONED	4350 MW	
							Impacts Total Transfer Capability	1870 MW	
							TTC with All Lines In Service	6220 MW	
BUCHAN_S-MILLWOOD_345_W98	Sun 09/20/2020	Fri 09/25/2020	0001	0200	Continuous	ConEd	UPNY CONED	6135 MW	
							Impacts Total Transfer Capability	85 MW	
							TTC with All Lines In Service	6220 MW	
NIAGARA__345KV_3102	Sun 09/20/2020	Sun 09/20/2020	0500	2100	Continuous	NYPA	SCH - OH - NY	1700 MW	1400 MW
							Impacts Total Transfer Capability	250 MW	300 MW
							TTC with All Lines In Service	1950 MW	1700 MW
NIAGARA__345_230_AT4	Sun 09/20/2020	Sun 09/20/2020	0500	2100	Continuous	NYPA	SCH - OH - NY	1900 MW	1400 MW
							Impacts Total Transfer Capability	50 MW	300 MW
							TTC with All Lines In Service	1950 MW	1700 MW

NYISO TRANSFER LIMITATIONS

Friday ,July 31, 2020 to Sunday ,January 30, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CLAY	-EDIC	345_1-16							
Mon 09/21/2020	to	Fri 09/25/2020							FWD
0700	Continuous	1530							(Import)
Work scheduled by: NYPA					OSWEGO EXPORT				4850 MW
					Impacts Total Transfer Capability				400 MW
					TTC with All Lines In Service				5250 MW
<hr/>									
FRASANX-COOPERS	345_UCC2-41								FWD
Mon 09/21/2020	to	Wed 09/30/2020	EXTENDED	by NYPA	07/21/2020				(Import)
0700	Continuous	1730							CENTRAL EAST - VC
Work scheduled by: NYPA					ARR: 19				2500 MW
					Impacts Total Transfer Capability				475 MW
					TTC with All Lines In Service				2975 MW
<hr/>									
MARCY	-FRASANX	345_UCC2-41							FWD
Mon 09/21/2020	to	Wed 09/30/2020	EXTENDED	by NYPA	07/21/2020				(Import)
0700	Continuous	1730							CENTRAL EAST - VC
Work scheduled by: NYPA					ARR: 19				2500 MW
					Impacts Total Transfer Capability				475 MW
					TTC with All Lines In Service				2975 MW
<hr/>									
ROSETON	-ROCKTVRN	345_311							FWD
Mon 09/21/2020	to	Fri 10/23/2020	UPDATED	by CHGE	10/09/2019				(Import)
0800	Continuous	1600							UPNY CONED
Work scheduled by: CHGE									4400 MW
					Impacts Total Transfer Capability				1820 MW
					TTC with All Lines In Service				6220 MW
<hr/>									
GOETHALS	345KV_5								FWD
Tue 09/22/2020	to	Tue 09/22/2020	UPDATED	by CE	06/24/2020				(Import)
0200	Continuous	0230							STATEN ISLAND
Work scheduled by: PJM									Impacts Total Transfer Capability
					TTC with All Lines In Service				
<hr/>									
LINDEN	-GOETHALS	230_A2253							FWD
Tue 09/22/2020	to	Wed 09/23/2020	UPDATED	by CE	06/24/2020				(Import)
0200	Continuous	2359							REV
Work scheduled by: PJM									(Export)
					SCH - PJ - NY				2050 MW
					Impacts Total Transfer Capability				150 MW
					TTC with All Lines In Service				2200 MW
									1150 MW
									100 MW
									1250 MW
<hr/>									
LINDEN	-GOETHALS	230_A2253 & HUDSONP	-FARRAGUT	345_B3402					FWD
Tue 09/22/2020	to	Wed 09/23/2020							(Import)
0200		2359							REV
Work scheduled by:									(Export)
					SCH - PJ - NY				2000 MW
					Impacts Total Transfer Capability				200 MW
					TTC with All Lines In Service				250 MW
									1250 MW

NYISO TRANSFER LIMITATIONS

Friday ,July 31, 2020 to Sunday ,January 30, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LINDEN__-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402 & MARION__-FARRAGUT_345_C3403	FWD	REV
	(Import)	(Export)
Tue 09/22/2020 to Wed 09/23/2020	SCH - PJ - NY	2000 MW 1000 MW
0200 to 2359	Impacts Total Transfer Capability	200 MW 250 MW
	TTC with All Lines In Service	2200 MW 1250 MW

Work scheduled by:

LINDEN__-GOETHALS_230_A2253 & MARION__-FARRAGUT_345_C3403	FWD	REV
	(Import)	(Export)
Tue 09/22/2020 to Wed 09/23/2020	SCH - PJ - NY	2000 MW 1000 MW
0200 to 2359	Impacts Total Transfer Capability	200 MW 250 MW
	TTC with All Lines In Service	2200 MW 1250 MW

Work scheduled by:

SCRIBA__-VOLNEY__345_21	FWD	
	(Import)	
Wed 09/23/2020 to Thu 09/24/2020	OSWEGO EXPORT	5250 MW
0800 Continuous 1630	Impacts Total Transfer Capability	0 MW
	TTC with All Lines In Service	5250 MW

Work scheduled by: NGrid

LINDEN__-GOETHALS_230_A2253	FWD	REV
	(Import)	(Export)
Thu 09/24/2020 to Sat 09/26/2020	SCH - PJ - NY	2050 MW 1150 MW
0001 Continuous 0300	Impacts Total Transfer Capability	150 MW 100 MW
	TTC with All Lines In Service	2200 MW 1250 MW

Work scheduled by: PJM

LINDEN__-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402	FWD	REV
	(Import)	(Export)
Thu 09/24/2020 to Sat 09/26/2020	SCH - PJ - NY	2000 MW 1000 MW
0001 to 0300	Impacts Total Transfer Capability	200 MW 250 MW
	TTC with All Lines In Service	2200 MW 1250 MW

Work scheduled by:

LINDEN__-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402 & MARION__-FARRAGUT_345_C3403	FWD	REV
	(Import)	(Export)
Thu 09/24/2020 to Sat 09/26/2020	SCH - PJ - NY	2000 MW 1000 MW
0001 to 0300	Impacts Total Transfer Capability	200 MW 250 MW
	TTC with All Lines In Service	2200 MW 1250 MW

Work scheduled by:

NYISO TRANSFER LIMITATIONS

Friday ,July 31, 2020 to Sunday ,January 30, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LINDEN__-GOETHALS_230_A2253 & MARION__-FARRAGUT_345_C3403

Thu 09/24/2020 to Sat 09/26/2020
0001 0300

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2000 MW	1000 MW
Impacts Total Transfer Capability	200 MW	250 MW
TTC with All Lines In Service	2200 MW	1250 MW

W49TH_ST_345KV_5

Fri 09/25/2020 to Sat 09/26/2020
0001 Continuous 0300

Work scheduled by: ConEd

	FWD
	(Import)
SCH - PJM_HTP	300 MW
Impacts Total Transfer Capability	360 MW
TTC with All Lines In Service	660 MW

W49TH_ST_345KV_7

Fri 09/25/2020 to Sat 09/26/2020
0001 Continuous 0300

Work scheduled by: ConEd

	FWD
	(Import)
SCH - PJM_HTP	300 MW
Impacts Total Transfer Capability	360 MW
TTC with All Lines In Service	660 MW

MILLWOOD_345KV_18

Fri 09/25/2020 to Fri 09/25/2020
0130 Continuous 0200

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	4350 MW
Impacts Total Transfer Capability	1870 MW
TTC with All Lines In Service	6220 MW

EASTVIEW-SPRNBK__345_W78

Sat 09/26/2020 to Sun 09/27/2020 **UPDATED by CONED 06/16/2020**
0001 Continuous 0200

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	4350 MW
Impacts Total Transfer Capability	1870 MW
TTC with All Lines In Service	6220 MW

MILLWOOD-EASTVIEW_345_W85

Sat 09/26/2020 to Sun 09/27/2020 **UPDATED by CONED 06/16/2020**
0001 Continuous 0200

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	5985 MW
Impacts Total Transfer Capability	235 MW
TTC with All Lines In Service	6220 MW

SPRNBK__345KV_RNS3

Sat 09/26/2020 to Sun 09/27/2020 **UPDATED by CONED 06/16/2020**
0001 Continuous 0200

Work scheduled by: ConEd

	FWD
	(Import)
SPR/DUN-SOUTH	3800 MW
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Friday ,July 31, 2020 to Sunday ,January 30, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

GOETHALS_345KV_5

Sat 09/26/2020 to Sat 09/26/2020 **UPDATED by PJM 07/06/2020**

0230 Continuous 0300

Work scheduled by: PJM

STATEN ISLAND
 Impacts Total Transfer Capability
 TTC with All Lines In Service

CRICKVLY-PLSNTVLY_345_F83

Mon 09/28/2020 to Sun 10/04/2020

0001 Continuous 2200

Work scheduled by: ConEd

FWD
 (Import)
 SCH - NE - NY **350 MW**
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 1400 MW

CRICKVLY-PLSNTVLY_345_F83

Mon 09/28/2020 to Sun 10/04/2020

0001 Continuous 2200

Work scheduled by: ConEd

FWD REV
 (Import) (Export)
 SCH - NPX_1385 **100 MW 100 MW**
 Impacts Total Transfer Capability 100 MW 100 MW
 TTC with All Lines In Service 200 MW 200 MW

NRTH1385-NOR HBR_138_601 & CRICKVLY-PLSNTVLY_345_F83

Mon 09/28/2020 to Sun 10/04/2020

0500 2200

Work scheduled by:

FWD REV
 (Import) (Export)
 SCH - NPX_1385 **0 MW 0 MW**
 Impacts Total Transfer Capability 200 MW 200 MW
 TTC with All Lines In Service 200 MW 200 MW

NRTH1385-NOR HBR_138_602 & CRICKVLY-PLSNTVLY_345_F83

Mon 09/28/2020 to Sun 10/04/2020

0500 2200

Work scheduled by:

FWD REV
 (Import) (Export)
 SCH - NPX_1385 **0 MW 0 MW**
 Impacts Total Transfer Capability 200 MW 200 MW
 TTC with All Lines In Service 200 MW 200 MW

NRTH1385-NOR HBR_138_603 & CRICKVLY-PLSNTVLY_345_F83

Mon 09/28/2020 to Sun 10/04/2020

0500 2200

Work scheduled by:

FWD REV
 (Import) (Export)
 SCH - NPX_1385 **0 MW 0 MW**
 Impacts Total Transfer Capability 200 MW 200 MW
 TTC with All Lines In Service 200 MW 200 MW

NRTH1385-NOR HBR_138_601

Mon 09/28/2020 to Sat 10/17/2020 **UPDATED by LIPA 07/10/2020**

0500 Continuous 2359

Work scheduled by: LI

FWD REV
 (Import) (Export)
 SCH - NPX_1385 **100 MW 100 MW**
 Impacts Total Transfer Capability 100 MW 100 MW
 TTC with All Lines In Service 200 MW 200 MW

NYISO TRANSFER LIMITATIONS

Friday ,July 31, 2020 to Sunday ,January 30, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NOR HBR_138_601 & NRTH1385-NOR HBR_138_602					FWD	REV
Mon 09/28/2020	to	Sat 10/17/2020			(Import)	(Export)
0500		2359		SCH - NPX_1385	0 MW	0 MW
Work scheduled by:					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR_138_601 & NRTH1385-NOR HBR_138_603					FWD	REV
Mon 09/28/2020	to	Sat 10/17/2020			(Import)	(Export)
0500		2359		SCH - NPX_1385	0 MW	0 MW
Work scheduled by:					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR_138_602					FWD	REV
Mon 09/28/2020	to	Sat 10/17/2020	<u>UPDATED</u>	<u>by LIPA</u> <u>07/10/2020</u>	(Import)	(Export)
0500	Continuous	2359			100 MW	100 MW
Work scheduled by: LI					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR_138_602 & NRTH1385-NOR HBR_138_603					FWD	REV
Mon 09/28/2020	to	Sat 10/17/2020			(Import)	(Export)
0500		2359		SCH - NPX_1385	0 MW	0 MW
Work scheduled by:					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR_138_603					FWD	REV
Mon 09/28/2020	to	Sat 10/17/2020	<u>UPDATED</u>	<u>by LIPA</u> <u>07/10/2020</u>	(Import)	(Export)
0500	Continuous	2359			100 MW	100 MW
Work scheduled by: LI					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
NRTH1385-NRTHPORT_138_NNC					FWD	REV
Mon 09/28/2020	to	Sat 10/17/2020	<u>UPDATED</u>	<u>by LIPA</u> <u>07/10/2020</u>	(Import)	(Export)
0500	Continuous	2359			0 MW	0 MW
Work scheduled by: LI					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	200 MW
CLAY -EDIC 345_2-15					FWD	
Mon 09/28/2020	to	Fri 10/02/2020			(Import)	
0700	Continuous	1530		OSWEGO EXPORT	4850 MW	
Work scheduled by: NYPA					Impacts Total Transfer Capability	400 MW
					TTC with All Lines In Service	5250 MW

NYISO TRANSFER LIMITATIONS

Friday ,July 31, 2020 to Sunday ,January 30, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						
MOTTHAVN-RAINEY <u>345_Q11</u>					FWD	
Thu 10/01/2020	to	Thu 11/05/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>12/17/2019</u>	(Import)
0001	Continuous	0200				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	800 MW
					Impacts Total Transfer Capability	4600 MW
					TTC with All Lines In Service	4600 MW
<hr/>						
EDIC <u>-FRASER</u> <u>345_EF24-40</u>					FWD	
Thu 10/01/2020	to	Fri 10/02/2020				(Import)
0700	Continuous	1730				2500 MW
Work scheduled by: NYPA					CENTRAL EAST - VC	475 MW
					Impacts Total Transfer Capability	2975 MW
					TTC with All Lines In Service	2975 MW
<hr/>						
HUDSONTP-W49TH_ST <u>345_Y56</u>					FWD	
Fri 10/02/2020	to	Thu 10/08/2020				(Import)
0001	Continuous	0300				0 MW
Work scheduled by: ConEd					SCH - PJM_HTP	660 MW
					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	660 MW
<hr/>						
W49TH_ST <u>345KV_7</u>					FWD	
Fri 10/02/2020	to	Thu 10/08/2020				(Import)
0001	Continuous	0300				300 MW
Work scheduled by: ConEd					SCH - PJM_HTP	360 MW
					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	660 MW
<hr/>						
W49TH_ST <u>345KV_8</u>					FWD	
Fri 10/02/2020	to	Thu 10/08/2020				(Import)
0001	Continuous	0300				450 MW
Work scheduled by: ConEd					SCH - PJM_HTP	210 MW
					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	660 MW
<hr/>						
PANNELL <u>-CLAY</u> <u>345_1</u>					FWD	
Mon 10/05/2020	to	Fri 10/09/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/07/2020</u>	(Import)
0700	Continuous	1530				1300 MW
Work scheduled by: NYPA					WEST CENTRAL	950 MW
					Impacts Total Transfer Capability	2250 MW
					TTC with All Lines In Service	2250 MW
<hr/>						
DUNWODIE-MOTTHAVN <u>345_71</u>					FWD	
Wed 10/07/2020	to	Thu 10/08/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>07/22/2020</u>	(Import)
0001	Continuous	0100				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	800 MW
					Impacts Total Transfer Capability	4600 MW
					TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Friday ,July 31, 2020 to Sunday ,January 30, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						FWD
DUNWODIE_345KV_5						(Import)
Wed 10/07/2020	to	Thu 10/08/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>07/22/2020</u>	
0001	Continuous	0100				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	3800 MW
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<hr/>						
DUNWODIE_345KV_3						FWD
						(Import)
Wed 10/07/2020	to	Thu 11/12/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>07/22/2020</u>	
0001	Continuous	0100				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	3800 MW
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<hr/>						
DUNWODIE_345KV_4						FWD
						(Import)
Wed 10/07/2020	to	Thu 11/12/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>07/22/2020</u>	
0001	Continuous	0100				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	3800 MW
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<hr/>						
PLSNTVLE-DUNWODIE_345_W89						FWD
						(Import)
Wed 10/07/2020	to	Thu 11/12/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>07/22/2020</u>	
0001	Continuous	0100				4000 MW
Work scheduled by: ConEd					UPNY CONED	4000 MW
					Impacts Total Transfer Capability	2220 MW
					TTC with All Lines In Service	6220 MW
<hr/>						
SAND_BAR-PLATSBURG_115_PV20						
Sat 10/17/2020	to	Sat 11/14/2020				
0600	Continuous	1800				
Work scheduled by: ISONE					SCH - NE - NY	
					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
<hr/>						
ROCHESTR-PANNELL_345_RP1						FWD
						(Import)
Mon 10/19/2020	to	Fri 10/23/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>03/10/2020</u>	
0500	Continuous	1700				2300 MW
Work scheduled by: NYPA					DYSINGER EAST	2300 MW
					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
<hr/>						
SCH-NE-NYISO_LIMIT_600						FWD
						(Import)
Mon 10/19/2020	to	Sat 10/31/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>06/05/2020</u>	
0630	Continuous	2359				800 MW
Work scheduled by: NGrid					SCH - NE - NY	800 MW
					Impacts Total Transfer Capability	600 MW
					TTC with All Lines In Service	1400 MW

NYISO TRANSFER LIMITATIONS

Friday ,July 31, 2020 to Sunday ,January 30, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>								
SCH-NYISO-NE_LIMIT_800							REV	
Mon 10/19/2020	to	Sat 10/31/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>06/05/2020</u>		(Export)	
0630	Continuous	2359				SCH - NE - NY	1000 MW	
Work scheduled by: NGrid						Impacts Total Transfer Capability	600 MW	
						TTC with All Lines In Service	1600 MW	
<hr/>								
BERKSHIR-ALPS_____345_393							FWD	REV
Mon 10/19/2020	to	Tue 11/10/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>06/05/2020</u>		(Import)	(Export)
0630	Continuous	1630				SCH - NE - NY	950 MW	1300 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability	450 MW	300 MW
						TTC with All Lines In Service	1400 MW	1600 MW
<hr/>								
BERKSHIR-ALPS_____345_393							FWD	REV
Mon 10/19/2020	to	Tue 11/10/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>06/05/2020</u>		(Import)	(Export)
0630	Continuous	1630				SCH - NPX_1385	100 MW	100 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability	100 MW	100 MW
						TTC with All Lines In Service	200 MW	200 MW
<hr/>								
BERKSHIR-ALPS_____345_393 & BERKSHIR-NORTHFLD_345_312							FWD	REV
Mon 10/19/2020	to	Tue 11/10/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>06/05/2020</u>		(Import)	(Export)
0630		1630				SCH - NE - NY	950 MW	1300 MW
Work scheduled by:						Impacts Total Transfer Capability	450 MW	300 MW
						TTC with All Lines In Service	1400 MW	1600 MW
<hr/>								
BERKSHIR-NORTHFLD_345_312							FWD	REV
Mon 10/19/2020	to	Tue 11/10/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>06/05/2020</u>		(Import)	(Export)
0630	Continuous	1630				SCH - NE - NY	900 MW	1500 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability	500 MW	100 MW
						TTC with All Lines In Service	1400 MW	1600 MW
<hr/>								
BERKSHIR-NORTHFLD_345_312							FWD	REV
Mon 10/19/2020	to	Tue 11/10/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>06/05/2020</u>		(Import)	(Export)
0630	Continuous	1630				SCH - NPX_1385	100 MW	100 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability	100 MW	100 MW
						TTC with All Lines In Service	200 MW	200 MW
<hr/>								
SHOR_NPX-SHOREHAM_138_CSC							FWD	REV
Mon 10/19/2020	to	Fri 10/23/2020	<u>UPDATED</u>	<u>by LI</u>	<u>03/02/2020</u>		(Import)	(Export)
0700	Continuous	1500				SCH - NPX_CSC	0 MW	0 MW
Work scheduled by: LI						Impacts Total Transfer Capability	330 MW	330 MW
						TTC with All Lines In Service	330 MW	330 MW

NYISO TRANSFER LIMITATIONS

Friday ,July 31, 2020 to Sunday ,January 30, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						FWD
PANNELL_-CLAY_345_2						(Import)
Mon 10/19/2020	to	Fri 10/23/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/07/2020</u>	
0700	Continuous	1530				WEST CENTRAL 1300 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 950 MW
						TTC with All Lines In Service 2250 MW
<hr/>						FWD
COOPERS_-DOLSONAV_345_CCDA42						(Import)
Mon 10/19/2020	to	Fri 11/06/2020				
0700	Continuous	1730				CENTRAL EAST - VC 2720 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 255 MW
						TTC with All Lines In Service 2975 MW
<hr/>						FWD
SPRNBK_-TREMONT_345_X28						(Import)
Mon 10/26/2020	to	Mon 10/26/2020				
0001	Continuous	0030				SPR/DUN-SOUTH 4200 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 400 MW
						TTC with All Lines In Service 4600 MW
<hr/>						FWD
LEEDS_345_LEEDS SVC						(Import)
Mon 10/26/2020	to	Fri 10/30/2020				
0800	Continuous	1600				CENTRAL EAST - VC 2950 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability 25 MW
						TTC with All Lines In Service 2975 MW
<hr/>						FWD
LEEDS_-HURLYAVE_345_301						(Import)
Mon 10/26/2020	to	Fri 12/04/2020				
0800	Continuous	1600				UPNY CONED 4100 MW
Work scheduled by: CHGE						Impacts Total Transfer Capability 2120 MW
						TTC with All Lines In Service 6220 MW
<hr/>						FWD
SCH-NE-NYISO_LIMIT_800						(Import)
Sun 11/01/2020	to	Tue 11/10/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>06/05/2020</u>	
0001	Continuous	1630				SCH - NE - NY 1000 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability 400 MW
						TTC with All Lines In Service 1400 MW
<hr/>						REV
SCH-NYISO-NE_LIMIT_700						(Export)
Sun 11/01/2020	to	Tue 11/10/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>06/05/2020</u>	
0001	Continuous	1630				SCH - NE - NY 900 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 1700 MW

NYISO TRANSFER LIMITATIONS

Friday ,July 31, 2020 to Sunday ,January 30, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
SCH-IMO-NYISO_LIMIT_1750						(Import)	
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>		
0001	Continuous	2359				SCH - OH - NY	2050 MW
Work scheduled by: IESO						Impacts Total Transfer Capability	0 MW
						TTC with All Lines In Service	2050 MW
SCH-NYISO-IMO_LIMIT_1600							REV
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>		(Export)
0001	Continuous	2359				SCH - OH - NY	1900 MW
Work scheduled by: IESO						Impacts Total Transfer Capability	0 MW
						TTC with All Lines In Service	1900 MW
NIAGARA__345KV_3002						FWD	REV
Thu 11/05/2020	to	Thu 11/05/2020				(Import)	(Export)
0500	Continuous	2100				SCH - OH - NY	1550 MW 1400 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	500 MW 500 MW
						TTC with All Lines In Service	2050 MW 1900 MW
NIAGARA__345KV_3022						FWD	REV
Thu 11/05/2020	to	Thu 11/05/2020				(Import)	(Export)
0500	Continuous	2100				SCH - OH - NY	1550 MW 1400 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	500 MW 500 MW
						TTC with All Lines In Service	2050 MW 1900 MW
SPRNBK_-TREMONT__345_X28						FWD	
Fri 11/06/2020	to	Sat 11/07/2020				(Import)	
0001	Continuous	0059				SPR/DUN-SOUTH	4200 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	400 MW
						TTC with All Lines In Service	4600 MW
NIAGARA__345KV_3102						FWD	REV
Fri 11/06/2020	to	Fri 11/06/2020				(Import)	(Export)
0500	Continuous	2100				SCH - OH - NY	2000 MW 1700 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	50 MW 200 MW
						TTC with All Lines In Service	2050 MW 1900 MW
NIAGARA__345_230_AT4							REV
Fri 11/06/2020	to	Fri 11/06/2020				(Export)	
0500	Continuous	2100				SCH - OH - NY	1750 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	150 MW
						TTC with All Lines In Service	1900 MW

NYISO TRANSFER LIMITATIONS

Friday ,July 31, 2020 to Sunday ,January 30, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
<p>SPRNBK_-TREMONT__345_X28</p> <p>Mon 11/09/2020 to Mon 11/09/2020 0030 Continuous 0059</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>SPR/DUN-SOUTH 4200 MW</p> <p>Impacts Total Transfer Capability 400 MW</p> <p>TTC with All Lines In Service 4600 MW</p>		
<hr/>			
<p>DUNWODIE-MOTTHAVN_345_71</p> <p>Tue 11/10/2020 to Thu 11/12/2020 0001 Continuous 0100</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>SPR/DUN-SOUTH 3800 MW</p> <p>Impacts Total Transfer Capability 800 MW</p> <p>TTC with All Lines In Service 4600 MW</p>		
<hr/>			
<p>DUNWODIE_345KV_5</p> <p>Tue 11/10/2020 to Thu 11/12/2020 0001 Continuous 0100</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>SPR/DUN-SOUTH 3800 MW</p> <p>Impacts Total Transfer Capability 800 MW</p> <p>TTC with All Lines In Service 4600 MW</p>		
<hr/>			
<p>CHATGUAY-MASSENA__765_7040</p> <p>Sun 11/15/2020 to Mon 11/30/2020 0100 Continuous 1900</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH 1550 MW</p> <p>Impacts Total Transfer Capability 1600 MW</p> <p>TTC with All Lines In Service 3150 MW</p>		
<hr/>			
<p>CHATGUAY-MASSENA__765_7040</p> <p>Sun 11/15/2020 to Mon 11/30/2020 0100 Continuous 1900</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD REV (Import) (Export)</p> <p>SCH - HQ - NY 0 MW 0 MW</p> <p>Impacts Total Transfer Capability 1500 MW 1000 MW</p> <p>TTC with All Lines In Service 1500 MW 1000 MW</p>		
<hr/>			
<p>MARCY__765_345_AT1</p> <p>Sun 11/15/2020 to Mon 11/30/2020 0100 Continuous 1900</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH 1750 MW</p> <p>Impacts Total Transfer Capability 1400 MW</p> <p>TTC with All Lines In Service 3150 MW</p>		
<hr/>			
<p>MARCY__765_345_AT2</p> <p>Sun 11/15/2020 to Mon 11/30/2020 0100 Continuous 1900</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH 1700 MW</p> <p>Impacts Total Transfer Capability 1450 MW</p> <p>TTC with All Lines In Service 3150 MW</p>		

ARR: 19

ARR: 19

NYISO TRANSFER LIMITATIONS

Friday ,July 31, 2020 to Sunday ,January 30, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>MASSENA -MARCY 765_MSU1</p> <p>Sun 11/15/2020 to Mon 11/30/2020 0100 Continuous 1900</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC 2265 MW</p> <p>Impacts Total Transfer Capability 710 MW</p> <p>TTC with All Lines In Service 2975 MW</p>															
<p>MASSENA -MARCY 765_MSU1</p> <p>Sun 11/15/2020 to Mon 11/30/2020 0100 Continuous 1900</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH 500 MW</p> <p>Impacts Total Transfer Capability 2650 MW</p> <p>TTC with All Lines In Service 3150 MW</p>															
<p>MASSENA -MARCY 765_MSU1</p> <p>Sun 11/15/2020 to Mon 11/30/2020 0100 Continuous 1900</p> <p>Work scheduled by: NYPA</p>	<table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 60%;"></td> <td style="width: 20%; text-align: right;">FWD</td> <td style="width: 20%; text-align: right;">REV</td> </tr> <tr> <td></td> <td style="text-align: right;">(Import)</td> <td style="text-align: right;">(Export)</td> </tr> <tr> <td>SCH - HQ - NY</td> <td style="text-align: right;">475 MW</td> <td style="text-align: right;">1000 MW</td> </tr> <tr> <td>Impacts Total Transfer Capability</td> <td style="text-align: right;">1025 MW</td> <td style="text-align: right;">0 MW</td> </tr> <tr> <td>TTC with All Lines In Service</td> <td style="text-align: right;">1500 MW</td> <td style="text-align: right;">1000 MW</td> </tr> </table>		FWD	REV		(Import)	(Export)	SCH - HQ - NY	475 MW	1000 MW	Impacts Total Transfer Capability	1025 MW	0 MW	TTC with All Lines In Service	1500 MW	1000 MW
	FWD	REV														
	(Import)	(Export)														
SCH - HQ - NY	475 MW	1000 MW														
Impacts Total Transfer Capability	1025 MW	0 MW														
TTC with All Lines In Service	1500 MW	1000 MW														
<p>MASSENA -MARCY 765_MSU1</p> <p>Sun 11/15/2020 to Mon 11/30/2020 0100 Continuous 1900</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>SCH - HQ_CEDARS 90 MW</p> <p>Impacts Total Transfer Capability 109 MW</p> <p>TTC with All Lines In Service 199 MW</p>															
<p>MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040</p> <p>Sun 11/15/2020 to Mon 11/30/2020 0100 1900</p> <p>Work scheduled by:</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH 500 MW</p> <p>Impacts Total Transfer Capability 2650 MW</p> <p>TTC with All Lines In Service 3150 MW</p>															
<p>MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2</p> <p>Sun 11/15/2020 to Mon 11/30/2020 0100 1900</p> <p>Work scheduled by:</p>	<table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 60%;"></td> <td style="width: 20%; text-align: right;">FWD</td> <td style="width: 20%; text-align: right;">REV</td> </tr> <tr> <td></td> <td style="text-align: right;">(Import)</td> <td style="text-align: right;">(Export)</td> </tr> <tr> <td>SCH - HQ - NY</td> <td style="text-align: right;">850 MW</td> <td style="text-align: right;">0 MW</td> </tr> <tr> <td>Impacts Total Transfer Capability</td> <td style="text-align: right;">650 MW</td> <td style="text-align: right;">1000 MW</td> </tr> <tr> <td>TTC with All Lines In Service</td> <td style="text-align: right;">1500 MW</td> <td style="text-align: right;">1000 MW</td> </tr> </table>		FWD	REV		(Import)	(Export)	SCH - HQ - NY	850 MW	0 MW	Impacts Total Transfer Capability	650 MW	1000 MW	TTC with All Lines In Service	1500 MW	1000 MW
	FWD	REV														
	(Import)	(Export)														
SCH - HQ - NY	850 MW	0 MW														
Impacts Total Transfer Capability	650 MW	1000 MW														
TTC with All Lines In Service	1500 MW	1000 MW														
<p>MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2</p> <p>Sun 11/15/2020 to Mon 11/30/2020 0100 1900</p> <p>Work scheduled by:</p>	<p style="text-align: right;">FWD (Import)</p> <p>SCH - HQ_CEDARS 90 MW</p> <p>Impacts Total Transfer Capability 109 MW</p> <p>TTC with All Lines In Service 199 MW</p>															

NYISO TRANSFER LIMITATIONS

Friday ,July 31, 2020 to Sunday ,January 30, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1</p> <p>Sun 11/15/2020 to Mon 11/30/2020 0100 1900</p> <p>Work scheduled by:</p>	<p>FWD (Import)</p> <p>SCH - HQ_CEDARS 90 MW</p> <p>Impacts Total Transfer Capability 109 MW</p> <p>TTC with All Lines In Service 199 MW</p>
<p>STLAWRNC-MOSES 230_L33P & MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2</p> <p>Sun 11/15/2020 to Mon 11/30/2020 0100 1900</p> <p>Work scheduled by:</p>	<p>FWD (Import)</p> <p>SCH - HQ_CEDARS 90 MW</p> <p>Impacts Total Transfer Capability 109 MW</p> <p>TTC with All Lines In Service 199 MW</p>
<p>PLSNTVLY-WOOD_ST_345_F30</p> <p>Mon 11/16/2020 to Mon 11/16/2020 0001 Continuous 0030</p> <p>Work scheduled by: ConEd</p>	<p>FWD (Import)</p> <p>UPNY CONED 4000 MW</p> <p>Impacts Total Transfer Capability 2220 MW</p> <p>TTC with All Lines In Service 6220 MW</p>
<p>PLSNTVLY_345KV_RNS5</p> <p>Mon 11/16/2020 to Mon 11/16/2020 0001 Continuous 0030</p> <p>Work scheduled by: ConEd</p>	<p>FWD (Import)</p> <p>UPNY CONED 3800 MW</p> <p>Impacts Total Transfer Capability 2420 MW</p> <p>TTC with All Lines In Service 6220 MW</p>
<p>MILLWOOD_345KV_18</p> <p>Mon 11/16/2020 to Tue 11/17/2020 0001 Continuous 0200</p> <p>Work scheduled by: ConEd</p>	<p>FWD (Import)</p> <p>UPNY CONED 4350 MW</p> <p>Impacts Total Transfer Capability 1870 MW</p> <p>TTC with All Lines In Service 6220 MW</p>
<p>PLSNTVLY-WOOD_ST_345_F30</p> <p>Tue 11/17/2020 to Tue 11/17/2020 0130 Continuous 0200</p> <p>Work scheduled by: ConEd</p>	<p>FWD (Import)</p> <p>UPNY CONED 4000 MW</p> <p>Impacts Total Transfer Capability 2220 MW</p> <p>TTC with All Lines In Service 6220 MW</p>
<p>PLSNTVLY_345KV_RNS5</p> <p>Tue 11/17/2020 to Tue 11/17/2020 0130 Continuous 0200</p> <p>Work scheduled by: ConEd</p>	<p>FWD (Import)</p> <p>UPNY CONED 3800 MW</p> <p>Impacts Total Transfer Capability 2420 MW</p> <p>TTC with All Lines In Service 6220 MW</p>

NYISO TRANSFER LIMITATIONS

Friday ,July 31, 2020 to Sunday ,January 30, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Mon 11/30/2020 to Sun 12/20/2020
0600 Continuous 1600

UPDATED by LI 04/29/2020

Work scheduled by: PJM

FWD (Import)
0 MW
SCH - PJM_NEPTUNE
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

NEWBRDGE-DUFFYAVE_345_501

Mon 11/30/2020 to Sun 12/20/2020
0600 Continuous 1600

UPDATED by LI 04/29/2020

Work scheduled by: PJM

FWD (Import)
0 MW
SCH - PJM_NEPTUNE
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

MARCY___345KV_CSC

Tue 12/01/2020 to Fri 12/11/2020
0700 Continuous 1730

Work scheduled by: NYPA

FWD (Import)
2925 MW
CENTRAL EAST - VC
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

MOSES_-ADIRNDCK_230_MA1

Tue 12/01/2020 to Sat 02/27/2021
0700 Continuous 1730

UPDATED by NYPA 07/27/2020

Work scheduled by: NYPA

FWD (Import)
2300 MW
MOSES SOUTH
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

KINTIGH_-ROCHESTR_345_SR1-39

Thu 12/03/2020 to Tue 12/15/2020
0800 Continuous 1900

UPDATED by NYISO 06/24/2020

Work scheduled by: RGE

FWD (Import)
1700 MW
DYSINGER EAST
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

NIAGARA_-KINTIGH_345_NS1-38

Thu 12/03/2020 to Tue 12/15/2020
0800 Continuous 1900

UPDATED by NYISO 06/24/2020

Work scheduled by: RGE

FWD (Import)
1700 MW
DYSINGER EAST
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

BECK___-PACKARD_230_BP76

Fri 12/04/2020 to Fri 12/04/2020
0730 Daily(No Weekends) 1530

Work scheduled by: NGrid

FWD REV
(Import) (Export)
1650 MW 1400 MW
SCH - OH - NY
Impacts Total Transfer Capability 400 MW 500 MW
TTC with All Lines In Service 2050 MW 1900 MW

NYISO TRANSFER LIMITATIONS

Friday ,July 31, 2020 to Sunday ,January 30, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SAND_BAR-PLATSBURG_115_PV20

Mon 12/07/2020 to Fri 12/11/2020
 0700 Continuous 1530
 Work scheduled by: NYPA

SCH - NE - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

W49TH_ST_345KV_6

Tue 12/08/2020 to Tue 12/08/2020
 0301 Continuous 0330
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

E13THSTA-FARRAGUT_345_46

Tue 12/08/2020 to Fri 12/11/2020
 0301 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

W49TH_ST-E13THSTA_345_M55

Tue 12/08/2020 to Fri 12/11/2020
 0301 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

LONG_MTN-CRICKVLY_345_398

Tue 12/08/2020 to Thu 12/10/2020
 0700 Continuous 1600
 Work scheduled by: ISONE

FWD REV
 (Import) (Export)
 SCH - NE - NY **700 MW 1300 MW**
 Impacts Total Transfer Capability 700 MW 400 MW
 TTC with All Lines In Service 1400 MW 1700 MW

LONG_MTN-CRICKVLY_345_398

Tue 12/08/2020 to Thu 12/10/2020
 0700 Continuous 1600
 Work scheduled by: ISONE

FWD REV
 (Import) (Export)
 SCH - NPX_1385 **100 MW 100 MW**
 Impacts Total Transfer Capability 100 MW 100 MW
 TTC with All Lines In Service 200 MW 200 MW

SCH-NE-NYISO_LIMIT_400

Tue 12/08/2020 to Thu 12/10/2020
 0700 Continuous 1600
 Work scheduled by: ISONE

FWD
 (Import)
 SCH - NE - NY **600 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 1400 MW

NYISO TRANSFER LIMITATIONS

Friday ,July 31, 2020 to Sunday ,January 30, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-NE_LIMIT_1000

Tue 12/08/2020 to Thu 12/10/2020
 0700 Continuous 1600
 Work scheduled by: ISONE

REV
(Export)
1200 MW
 SCH - NE - NY
 Impacts Total Transfer Capability 500 MW
 TTC with All Lines In Service 1700 MW

W49TH_ST_345KV_6

Fri 12/11/2020 to Fri 12/11/2020
 0230 Continuous 0300
 Work scheduled by: ConEd

FWD
(Import)
300 MW
 SCH - PJM_HTP
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

MARCY -EDIC 345_UE1-7

Mon 12/14/2020 to Mon 12/14/2020
 0700 Continuous 1730
 Work scheduled by: NYPA

ARR: 19&16

FWD
(Import)
5250 MW
 OSWEGO EXPORT
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 5250 MW

SAND_BAR-PLATSBRG_115_PV20

Mon 12/14/2020 to Fri 12/18/2020
 0700 Continuous 1530
 Work scheduled by: NYPA

SCH - NE - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

LADENTWN-BUCHAN_S_345_Y88

Tue 12/15/2020 to Sat 01/30/2021
 0001 Continuous 0300
 Work scheduled by: ConEd

FWD
(Import)
5930 MW
 UPNY CONED
 Impacts Total Transfer Capability 290 MW
 TTC with All Lines In Service 6220 MW

FRASANX-COOPERS 345_UCC2-41

Tue 12/15/2020 to Wed 12/16/2020
 0700 Continuous 1530
 Work scheduled by: NYPA

ARR: 19

FWD
(Import)
2500 MW
 CENTRAL EAST - VC
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

MARCY -FRASANX_345_UCC2-41

Tue 12/15/2020 to Wed 12/16/2020
 0700 Continuous 1530
 Work scheduled by: NYPA

ARR: 19

FWD
(Import)
2500 MW
 CENTRAL EAST - VC
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Friday ,July 31, 2020 to Sunday ,January 30, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HOPATCON-RAMAPO___500_5018			FWD	REV
Mon 02/01/2021	to	Wed 02/03/2021	(Import) (Export)	
0001	Continuous	2200	SCH - PJ - NY	1250 MW 1200 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	1650 MW 650 MW
			TTC with All Lines In Service	2900 MW 1850 MW
HOPATCON-RAMAPO___500_5018			FWD	
Mon 02/01/2021	to	Wed 02/03/2021	(Import)	
0001	Continuous	2200	UPNY CONED	6025 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	195 MW
			TTC with All Lines In Service	6220 MW
RAMAPO___345_345_PAR3500			FWD	REV
Mon 02/01/2021	to	Wed 02/03/2021	(Import) (Export)	
0001	Continuous	2200	SCH - PJ - NY	2150 MW 1250 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	750 MW 600 MW
			TTC with All Lines In Service	2900 MW 1850 MW
RAMAPO___345_345_PAR4500			FWD	REV
Mon 02/01/2021	to	Wed 02/03/2021	(Import) (Export)	
0001	Continuous	2200	SCH - PJ - NY	2150 MW 1250 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	750 MW 600 MW
			TTC with All Lines In Service	2900 MW 1850 MW
RAMAPO___500_345_BK 1500			FWD	REV
Mon 02/01/2021	to	Wed 02/03/2021	(Import) (Export)	
0001	Continuous	2200	SCH - PJ - NY	1250 MW 1200 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	1650 MW 650 MW
			TTC with All Lines In Service	2900 MW 1850 MW
RAMAPO___500_345_BK 1500			FWD	
Mon 02/01/2021	to	Wed 02/03/2021	(Import)	
0001	Continuous	2200	UPNY CONED	6025 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	195 MW
			TTC with All Lines In Service	6220 MW
PLSNTVLY-WOOD_ST__345_F30			FWD	
Mon 02/15/2021	to	Tue 02/16/2021	(Import)	
0001	Continuous	0200	UPNY CONED	4000 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	2220 MW
			TTC with All Lines In Service	6220 MW

NYISO TRANSFER LIMITATIONS

Friday ,July 31, 2020 to Sunday ,January 30, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RNS5

Mon 02/15/2021 to Tue 02/16/2021
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 2420 MW
 TTC with All Lines In Service 6220 MW

EFISHKIL-WOOD_ST__345_F39

Thu 02/18/2021 to Sat 02/20/2021 **UPDATED by CE 04/01/2020**
 2100 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 2220 MW
 TTC with All Lines In Service 6220 MW

WOOD_ST_-PLSNTVLE_345_Y87

Thu 02/18/2021 to Sat 02/20/2021 **UPDATED by CE 04/01/2020**
 2100 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **5905 MW**
 Impacts Total Transfer Capability 315 MW
 TTC with All Lines In Service 6220 MW

CHATGUAY-MASSENA__765_7040

Sun 02/28/2021 to Mon 03/01/2021
 0500 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **1550 MW**
 Impacts Total Transfer Capability 1600 MW
 TTC with All Lines In Service 3150 MW

CHATGUAY-MASSENA__765_7040

Sun 02/28/2021 to Mon 03/01/2021
 0500 Continuous 1730
 Work scheduled by: NYPA

FWD REV
 (Import) (Export)
 SCH - HQ - NY **0 MW 0 MW**
 Impacts Total Transfer Capability 1500 MW 1000 MW
 TTC with All Lines In Service 1500 MW 1000 MW

MASSENA_-MARCY____765_MSU1

Sun 02/28/2021 to Mon 03/01/2021
 0500 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2265 MW**
 Impacts Total Transfer Capability 710 MW
 TTC with All Lines In Service 2975 MW

MASSENA_-MARCY____765_MSU1

Sun 02/28/2021 to Mon 03/01/2021
 0500 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **500 MW**
 Impacts Total Transfer Capability 2650 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,July 31, 2020 to Sunday ,January 30, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA_-MARCY___765_MSU1					
Sun 02/28/2021	to	Mon 03/01/2021			
0500	Continuous	1730			
Work scheduled by: NYPA					
			SCH - HQ - NY	FWD	REV
			Impacts Total Transfer Capability	(Import)	(Export)
			TTC with All Lines In Service	475 MW	1000 MW
				1025 MW	0 MW
				1500 MW	1000 MW
<hr/>					
MASSENA_-MARCY___765_MSU1				FWD	
Sun 02/28/2021	to	Mon 03/01/2021		(Import)	
0500	Continuous	1730			
Work scheduled by: NYPA					
			SCH - HQ_CEDARS		
			Impacts Total Transfer Capability	90 MW	
			TTC with All Lines In Service	109 MW	
				199 MW	
<hr/>					
MASSENA_-MARCY___765_MSU1 & CHATGUAY-MASSENA_765_7040				FWD	
Sun 02/28/2021	to	Mon 03/01/2021		(Import)	
0500		1730			
Work scheduled by:					
			MOSES SOUTH		
			Impacts Total Transfer Capability	500 MW	
			TTC with All Lines In Service	2650 MW	
				3150 MW	
<hr/>					
STLAWRNC-MOSES___230_L33P & MASSENA_-MARCY___765_MSU1				FWD	
Sun 02/28/2021	to	Mon 03/01/2021		(Import)	
0500		1730			
Work scheduled by:					
			SCH - HQ_CEDARS		
			Impacts Total Transfer Capability	90 MW	
			TTC with All Lines In Service	109 MW	
				199 MW	
<hr/>					
DUNWODIE_345KV_3				FWD	
Mon 03/01/2021	to	Mon 03/01/2021		(Import)	
0001	Continuous	0030			
Work scheduled by: ConEd					
			SPR/DUN-SOUTH		
			Impacts Total Transfer Capability	3800 MW	
			TTC with All Lines In Service	800 MW	
				4600 MW	
<hr/>					
DUNWODIE_345KV_5				FWD	
Mon 03/01/2021	to	Mon 03/01/2021		(Import)	
0001	Continuous	0030			
Work scheduled by: ConEd					
			SPR/DUN-SOUTH		
			Impacts Total Transfer Capability	3800 MW	
			TTC with All Lines In Service	800 MW	
				4600 MW	
<hr/>					
EASTVIEW-SPRBRK___345_W64				FWD	
Mon 03/01/2021	to	Mon 03/01/2021	UPDATED	(Import)	
0001	Continuous	0030	by CONED 01/23/2020		
Work scheduled by: ConEd					
			UPNY CONED		
			Impacts Total Transfer Capability	4350 MW	
			TTC with All Lines In Service	1870 MW	
				6220 MW	

NYISO TRANSFER LIMITATIONS

Friday ,July 31, 2020 to Sunday ,January 30, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK__345KV_RNS5					FWD	
Mon 03/01/2021	to	Mon 03/01/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>01/23/2020</u>	(Import)
0001	Continuous	0030				3200 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
MILLWOOD-EASTVIEW_345_W99					FWD	
Mon 03/01/2021	to	Mon 03/22/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>01/23/2020</u>	(Import)
0001	Continuous	0200				5985 MW
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	235 MW
					TTC with All Lines In Service	6220 MW
DUNWODIE-MOTTHAVN_345_71					FWD	
Mon 03/01/2021	to	Mon 04/05/2021				(Import)
0001	Continuous	0300				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
MOTTHAVN-RAINEY__345_Q11					FWD	
Mon 03/01/2021	to	Tue 04/06/2021				(Import)
0001	Continuous	0700				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
MOSES__-ADIRNDCK_230_MAI					FWD	
Tue 03/02/2021	to	Mon 05/31/2021				(Import)
0700	Continuous	1300				2300 MW
Work scheduled by: NYPA					MOSES SOUTH	
					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
NIAGARA_-ROBNSNRD_230_64					REV	
Fri 03/12/2021	to	Fri 03/12/2021				(Export)
0500	Continuous	1700				1900 MW
Work scheduled by: NYPA					SCH - OH - NY	
					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	1900 MW
MARCY__345KV_CSC					FWD	
Sat 03/13/2021	to	Sat 03/13/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>07/29/2020</u>	(Import)
0700	Continuous	1730				2925 MW
Work scheduled by: NYPA					CENTRAL EAST - VC	
					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Friday ,July 31, 2020 to Sunday ,January 30, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EASTVIEW-SPRNBK__345_W64				FWD
Mon 03/22/2021	to	Mon 03/22/2021	UPDATED	(Import)
0130	Continuous	0200	by CONED	01/23/2020
Work scheduled by: ConEd				UPNY CONED 4350 MW
				Impacts Total Transfer Capability 1870 MW
				TTC with All Lines In Service 6220 MW
SPRNBK__345KV_RNS5				FWD
Mon 03/22/2021	to	Mon 03/22/2021	UPDATED	(Import)
0130	Continuous	0200	by CONED	01/23/2020
Work scheduled by: ConEd				SPR/DUN-SOUTH 3200 MW
				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW
CLAY__-EDIC__345_2-15				FWD
Mon 03/29/2021	to	Fri 04/16/2021		(Import)
0800	Continuous	1730		OSWEGO EXPORT 4850 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 400 MW
				TTC with All Lines In Service 5250 MW
ROCHESTR-PANNELL__345_RP2				FWD
Wed 03/31/2021	to	Mon 04/12/2021		(Import)
0500	Continuous	1700		DYSINGER EAST 2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW
DUNWODIE_345KV_3				FWD
Mon 04/05/2021	to	Mon 04/05/2021		(Import)
0230	Continuous	0300		SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_5				FWD
Mon 04/05/2021	to	Mon 04/05/2021		(Import)
0230	Continuous	0300		SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
SPRNBK_-TREMONT__345_X28				FWD
Mon 04/19/2021	to	Tue 04/20/2021		(Import)
0001	Continuous	0200		SPR/DUN-SOUTH 4200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 400 MW
				TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Friday ,July 31, 2020 to Sunday ,January 30, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					FWD	REV
NIAGARA__345KV_3002					(Import)	(Export)
Mon 04/26/2021	to	Mon 04/26/2021				
0500	Continuous	1700		SCH - OH - NY	1550 MW	1400 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	2050 MW
<hr/>						
SCH-IMO-NYISO_LIMIT_1600					FWD	
					(Import)	
Sat 05/01/2021	to	Sun 10/31/2021	UPDATED	by IESO	05/03/2019	
0001	Continuous	2359		SCH - OH - NY	1900 MW	
Work scheduled by: IESO					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	1950 MW
<hr/>						
PANNELL_-CLAY____345_2					FWD	
					(Import)	
Mon 05/03/2021	to	Fri 05/28/2021		WEST CENTRAL	1300 MW	
0700	Continuous	1730		Impacts Total Transfer Capability	950 MW	
Work scheduled by: NYPA					TTC with All Lines In Service	2250 MW
<hr/>						
NIAGARA__345KV_3022						
Tue 05/04/2021	to	Wed 05/05/2021		SCH - OH - NY		
0500	Continuous	1700		Impacts Total Transfer Capability		
Work scheduled by: NYPA					TTC with All Lines In Service	
<hr/>						
NIAGARA__345KV_3202						
Tue 05/04/2021	to	Wed 05/05/2021		SCH - OH - NY		
0500	Continuous	1700		Impacts Total Transfer Capability		
Work scheduled by: NYPA					TTC with All Lines In Service	
<hr/>						
NIAGARA__345KV_3102					FWD	REV
					(Import)	(Export)
Thu 05/06/2021	to	Fri 05/07/2021		SCH - OH - NY	1700 MW	1400 MW
0500	Continuous	1700		Impacts Total Transfer Capability	250 MW	300 MW
Work scheduled by: NYPA					TTC with All Lines In Service	1950 MW
<hr/>						
NIAGARA__345KV_3302					FWD	REV
					(Import)	(Export)
Mon 05/10/2021	to	Wed 05/12/2021		SCH - OH - NY	1000 MW	1600 MW
0500	Continuous	1700		Impacts Total Transfer Capability	950 MW	100 MW
Work scheduled by: NYPA					TTC with All Lines In Service	1950 MW

NYISO TRANSFER LIMITATIONS

Friday ,July 31, 2020 to Sunday ,January 30, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA__345KV_3108

Thu 05/13/2021 to Fri 05/14/2021
 0500 Continuous 1700
 Work scheduled by: NYPA

REV
(Export)
1500 MW
 SCH - OH - NY
 Impacts Total Transfer Capability 200 MW
 TTC with All Lines In Service 1700 MW

MOSES__-ADIRNDCK_230_MA2

Tue 06/01/2021 to Sun 11/14/2021
 0700 Continuous 1300
 Work scheduled by: NYPA

FWD
(Import)
2100 MW
 MOSES SOUTH
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW

NIAGARA_-KINTIGH__345_NS1-38

Mon 09/13/2021 to Fri 09/17/2021
 0500 Continuous 1700
 Work scheduled by: NYPA

FWD
(Import)
1400 MW
 DYSINGER EAST
 Impacts Total Transfer Capability 1750 MW
 TTC with All Lines In Service 3150 MW

SPRNBRK_-W49TH_ST_345_M51

Fri 10/01/2021 to Sun 10/17/2021 **UPDATED by NYISO 06/21/2020**
 0001 Continuous 0300
 Work scheduled by: ConEd

FWD
(Import)
3200 MW
 SPR/DUN-SOUTH
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

SPRNBRK__345KV_RNS5

Fri 10/01/2021 to Sun 10/17/2021 **UPDATED by NYISO 06/21/2020**
 0001 Continuous 0300
 Work scheduled by: ConEd

FWD
(Import)
3200 MW
 SPR/DUN-SOUTH
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

SCH-IMO-NYISO_LIMIT_1750

Mon 11/01/2021 to Fri 12/31/2021 **UPDATED by IESO 05/03/2019**
 0001 Continuous 2359
 Work scheduled by: IESO

FWD
(Import)
2050 MW
 SCH - OH - NY
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 2050 MW

SCH-NYISO-IMO_LIMIT_1600

Mon 11/01/2021 to Fri 12/31/2021 **UPDATED by IESO 05/03/2019**
 0001 Continuous 2359
 Work scheduled by: IESO

REV
(Export)
1900 MW
 SCH - OH - NY
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 1900 MW

NYISO TRANSFER LIMITATIONS

Friday ,July 31, 2020 to Sunday ,January 30, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA1

FWD

Wed 12/01/2021 to Tue 05/31/2022

(Import)

0700 Continuous 1300

MOSES SOUTH

2300 MW

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA