

# NYISO TRANSFER LIMITATIONS

Saturday ,August 01, 2020 to Monday ,January 31, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE\_345KV\_9\_BYPASS & DUNWODIE\_345KV\_10\_BYPASS & SPRNBRK\_\_345KV\_R4S3\_BYPASS & SPRNBRK\_\_345KV\_R5S3\_BYPASS**

Sun 02/01/2015 to Sat 02/01/2025  
0000 0000

Work scheduled by:

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**HUDSONP\_-FARRAGUT\_345\_B3402**

Mon 01/15/2018 to Thu 10/01/2020  
0001 Continuous 2359

Work scheduled by: ConEd

**EXTENDED by CONED 05/03/2020**

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2050 MW</b>	<b>1150 MW</b>
Impacts Total Transfer Capability	150 MW	100 MW
TTC with All Lines In Service	2200 MW	1250 MW

**HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_-FARRAGUT\_345\_C3403**

Mon 01/15/2018 to Thu 10/01/2020  
0001 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2000 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	200 MW	250 MW
TTC with All Lines In Service	2200 MW	1250 MW

**MARION\_-FARRAGUT\_345\_C3403**

Mon 01/15/2018 to Thu 10/01/2020  
0001 Continuous 2359

Work scheduled by: ConEd

**EXTENDED by CONED 05/03/2020**

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2050 MW</b>	<b>1150 MW</b>
Impacts Total Transfer Capability	150 MW	100 MW
TTC with All Lines In Service	2200 MW	1250 MW

**STLAWRNC-MOSES\_\_230\_L33P**

Mon 04/30/2018 to Fri 12/31/2021  
0456 Continuous 2359

Work scheduled by: IESO

**EXT FORCE by IESO 08/21/2018**

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**SCH-IMO-NYISO\_LIMIT\_1600**

Fri 05/01/2020 to Sat 10/31/2020  
0001 Continuous 2359

Work scheduled by: IESO

**UPDATED by IESO 05/03/2019**

	FWD
	(Import)
SCH - OH - NY	<b>1900 MW</b>
Impacts Total Transfer Capability	50 MW
TTC with All Lines In Service	1950 MW

**SHOR\_NPX-SHOREHAM\_138\_CSC**

Wed 07/08/2020 to Wed 09/02/2020  
1247 Continuous 2359

Work scheduled by: LI

**EXT FORCE by ISONE 07/20/2020**

	FWD	REV
	(Import)	(Export)
SCH - NPX_CSC	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	330 MW	330 MW
TTC with All Lines In Service	330 MW	330 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,August 01, 2020 to Monday ,January 31, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**BECK -NIAGARA 230\_PA27**

Sat 07/25/2020 to Mon 07/27/2020 **UPDATED by IESO 07/14/2020**  
 0700 Continuous 1000  
 Work scheduled by: IESO  
 SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**SCH-IMO-NYISO\_LIMIT\_1450**

Sat 07/25/2020 to Mon 07/27/2020 **UPDATED by IESO 07/14/2020**  
 0700 Continuous 1000  
 Work scheduled by: IESO  
 SCH - OH - NY  
 Impacts Total Transfer Capability 200 MW  
 TTC with All Lines In Service 1950 MW

FWD  
(Import)

**BECK -NIAGARA 345\_PA302**

Thu 07/30/2020 to Fri 07/31/2020 **CANCELLED by IESO 07/28/2020**  
 0600 Continuous 1800  
 Work scheduled by: IESO  
 SCH - OH - NY  
 Impacts Total Transfer Capability 1050 MW 900 MW  
 TTC with All Lines In Service 1950 MW 1700 MW

FWD REV  
(Import) (Export)

**DUNWODIE\_345KV\_4**

Fri 07/31/2020 to Fri 07/31/2020  
 0001 Continuous 0030  
 Work scheduled by: ConEd  
 SPR/DUN-SOUTH  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

FWD  
(Import)

**DUNWODIE\_345KV\_6**

Fri 07/31/2020 to Fri 07/31/2020  
 0001 Continuous 0030  
 Work scheduled by: ConEd  
 SPR/DUN-SOUTH  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

FWD  
(Import)

**DUNWODIE-SHORE\_RD\_345\_Y50**

Fri 07/31/2020 to Tue 08/04/2020  
 0001 Continuous 0259  
 Work scheduled by: ConEd  
 CONED - LIPA  
 Impacts Total Transfer Capability 700 MW  
 TTC with All Lines In Service 1500 MW

FWD  
(Import)

**SHORE\_RD\_345\_138\_BK\_1**

Fri 07/31/2020 to Tue 08/04/2020  
 0001 Continuous 0259  
 Work scheduled by: ConEd  
 CONED - LIPA  
 Impacts Total Transfer Capability 150 MW  
 TTC with All Lines In Service 1500 MW

FWD  
(Import)

# NYISO TRANSFER LIMITATIONS

Saturday ,August 01, 2020 to Monday ,January 31, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SHORE_RD_345_138_BK 2</b>					FWD
Fri 07/31/2020	to	Tue 08/04/2020			(Import)
0001	Continuous	0259		CONED - LIPA	<b>1350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 150 MW
					TTC with All Lines In Service 1500 MW
<b>MOSES -ADIRNDCK_230_MA2</b>					FWD
Fri 07/31/2020	to	Sat 09/12/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>07/27/2020</u>
0500	Continuous	2359		MOSES SOUTH	<b>2100 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 1050 MW
					TTC with All Lines In Service 3150 MW
<b>DUNWODIE_345KV_6</b>					FWD
Sat 08/01/2020	to	Sat 08/01/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>07/31/2020</u>
0001	Continuous	0030		SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
<b>DUNWODIE_345KV_8</b>					FWD
Sat 08/01/2020	to	Sat 08/01/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>07/31/2020</u>
0001	Continuous	0030		SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
<b>PLSNTVLE-DUNWODIE_345_W90</b>					FWD
Sat 08/01/2020	to	Sat 08/01/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>07/31/2020</u>
0001	Continuous	1800		UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 2220 MW
					TTC with All Lines In Service 6220 MW
<b>WOOD_ST -PLSNTVLE_345_Y87</b>					FWD
Sat 08/01/2020	to	Sat 08/01/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>07/31/2020</u>
0001	Continuous	1800		UPNY CONED	<b>5905 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 315 MW
					TTC with All Lines In Service 6220 MW
<b>DUNWODIE_345KV_6</b>					FWD
Sat 08/01/2020	to	Sat 08/01/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>07/31/2020</u>
1730	Continuous	1800		SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,August 01, 2020 to Monday ,January 31, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Work Scheduled	Start	End	Update	By	Effective	Zone	FWD	REV
DUNWODIE_345KV_8	Sat 08/01/2020	to	Sat 08/01/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>07/31/2020</u>	FWD	
1730 Continuous	1800					SPR/DUN-SOUTH	(Import)	
Work scheduled by: ConEd						Impacts Total Transfer Capability	3800 MW	
						TTC with All Lines In Service	800 MW	
							4600 MW	
DUNWODIE_345KV_4	Tue 08/04/2020	to	Tue 08/04/2020				FWD	
0230 Continuous	0259					SPR/DUN-SOUTH	(Import)	
Work scheduled by: ConEd						Impacts Total Transfer Capability	3800 MW	
						TTC with All Lines In Service	800 MW	
							4600 MW	
DUNWODIE_345KV_6	Tue 08/04/2020	to	Tue 08/04/2020				FWD	
0230 Continuous	0259					SPR/DUN-SOUTH	(Import)	
Work scheduled by: ConEd						Impacts Total Transfer Capability	3800 MW	
						TTC with All Lines In Service	800 MW	
							4600 MW	
NRTH1385-NOR HBR__138_601	Wed 08/05/2020	to	Fri 08/07/2020				FWD	REV
0800 Continuous	1500					SCH - NPX_1385	(Import)	(Export)
Work scheduled by: LI						Impacts Total Transfer Capability	100 MW	100 MW
						TTC with All Lines In Service	100 MW	100 MW
							200 MW	200 MW
NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_602	Wed 08/05/2020	to	Fri 08/07/2020				FWD	REV
0800	1500					SCH - NPX_1385	(Import)	(Export)
Work scheduled by:						Impacts Total Transfer Capability	0 MW	0 MW
						TTC with All Lines In Service	200 MW	200 MW
							200 MW	200 MW
NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_603	Wed 08/05/2020	to	Fri 08/07/2020				FWD	REV
0800	1500					SCH - NPX_1385	(Import)	(Export)
Work scheduled by:						Impacts Total Transfer Capability	0 MW	0 MW
						TTC with All Lines In Service	200 MW	200 MW
							200 MW	200 MW
NRTH1385-NOR HBR__138_602	Wed 08/05/2020	to	Fri 08/07/2020				FWD	REV
0800 Continuous	1500					SCH - NPX_1385	(Import)	(Export)
Work scheduled by: LI						Impacts Total Transfer Capability	100 MW	100 MW
						TTC with All Lines In Service	100 MW	100 MW
							200 MW	200 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,August 01, 2020 to Monday ,January 31, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NOR HBR__138_602 & NRTH1385-NOR HBR__138_603		FWD	REV
		(Import)	(Export)
Wed 08/05/2020	to Fri 08/07/2020		
0800	1500		
Work scheduled by:		SCH - NPX_1385	<b>0 MW 0 MW</b>
		Impacts Total Transfer Capability	200 MW 200 MW
		TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_603		FWD	REV
		(Import)	(Export)
Wed 08/05/2020	to Fri 08/07/2020		
0800	Continuous 1500		
Work scheduled by: LI		SCH - NPX_1385	<b>100 MW 100 MW</b>
		Impacts Total Transfer Capability	100 MW 100 MW
		TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NRTHPORT_138_NNC		FWD	REV
		(Import)	(Export)
Wed 08/05/2020	to Fri 08/07/2020		
0800	Continuous 1500		
Work scheduled by: LI		SCH - NPX_1385	<b>0 MW 0 MW</b>
		Impacts Total Transfer Capability	200 MW 200 MW
		TTC with All Lines In Service	200 MW 200 MW
INDPDNCE-SCRIBA__345_25		FWD	REV
		(Import)	
Thu 08/06/2020	to Thu 08/06/2020		
0600	Daily(No Weekends) 1630		
Work scheduled by: NGrid		OSWEGO EXPORT	<b>5250 MW</b>
		Impacts Total Transfer Capability	0 MW
		TTC with All Lines In Service	5250 MW
CRICKVLY-PLSNTVLY_345_F83		FWD	REV
		(Import)	
Sat 08/08/2020	to Sat 08/08/2020		
0001	Continuous 2200		
Work scheduled by: ConEd		SCH - NE - NY	<b>350 MW</b>
		Impacts Total Transfer Capability	1050 MW
		TTC with All Lines In Service	1400 MW
CRICKVLY-PLSNTVLY_345_F83		FWD	REV
		(Import)	(Export)
Sat 08/08/2020	to Sat 08/08/2020		
0001	Continuous 2200		
Work scheduled by: ConEd		SCH - NPX_1385	<b>100 MW 100 MW</b>
		Impacts Total Transfer Capability	100 MW 100 MW
		TTC with All Lines In Service	200 MW 200 MW
BECK__-NIAGARA_345_PA302		FWD	REV
		(Import)	(Export)
Sat 08/08/2020	to Sun 08/09/2020		
0500	Continuous 1700		
Work scheduled by: IESO		SCH - OH - NY	<b>900 MW 800 MW</b>
		Impacts Total Transfer Capability	1050 MW 900 MW
		TTC with All Lines In Service	1950 MW 1700 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,August 01, 2020 to Monday ,January 31, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SAND\_BAR-PLATSBURG\_115\_PV20**

Sun 08/09/2020 to Sun 08/16/2020 **UPDATED** by ISONE 07/28/2020  
 0800 Continuous 1900  
 Work scheduled by: ISONE  
 SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**NIAGARA\_345KV\_3002**

Wed 08/12/2020 to Wed 08/12/2020 **UPDATED** by NYPA 07/20/2020  
 0500 Continuous 0530  
 Work scheduled by: NYPA  
 SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD	REV
(Import)	(Export)
1300 MW	1150 MW
650 MW	550 MW
1950 MW	1700 MW

**NIAGARA\_345KV\_3002**

Thu 08/13/2020 to Thu 08/13/2020 **UPDATED** by NYPA 07/20/2020  
 1830 Continuous 1900  
 Work scheduled by: NYPA  
 SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD	REV
(Import)	(Export)
1300 MW	1150 MW
650 MW	550 MW
1950 MW	1700 MW

**S.RIPLEY-DUNKIRK\_230\_68**

Mon 08/17/2020 to Fri 08/21/2020  
 0900 Continuous 1500  
 Work scheduled by: PJM  
 SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**SAND\_BAR-PLATSBURG\_115\_PV20**

Sat 08/22/2020 to Sat 08/29/2020 **UPDATED** by ISONE 07/28/2020  
 0800 Continuous 1900  
 Work scheduled by: ISONE  
 SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**NIAGARA\_345KV\_3102**

Wed 08/26/2020 to Wed 08/26/2020  
 0500 Continuous 1700  
 Work scheduled by: NYPA  
 SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD	REV
(Import)	(Export)
1700 MW	1400 MW
250 MW	300 MW
1950 MW	1700 MW

**STOLLERD-HISHELDN\_230\_67**

Wed 08/26/2020 to Wed 08/26/2020  
 0900 Continuous 1000  
 Work scheduled by: NYSEG  
 DYSINGER EAST  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD
(Import)
2850 MW
300 MW
3150 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,August 01, 2020 to Monday ,January 31, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**OSWEGO\_COMPLEX\_AVR\_O/S**

Sun 09/06/2020 to Sun 09/06/2020  
0900 Continuous 0930

Work scheduled by: Gen

FWD  
(Import)  
CENTRAL EAST - VC **2870 MW**  
Impacts Total Transfer Capability 105 MW  
TTC with All Lines In Service 2975 MW

**MARCY\_\_-N.SCTLND\_345\_18**

Wed 09/09/2020 to Wed 09/09/2020  
0800 Daily(No Weekends) 1500

Work scheduled by: NGrid

**ARR: 19**

FWD  
(Import)  
CENTRAL EAST - VC **2090 MW**  
Impacts Total Transfer Capability 885 MW  
TTC with All Lines In Service 2975 MW

**MEYER\_\_-CANANDGA\_230\_60**

Thu 09/10/2020 to Thu 09/10/2020  
0730 Continuous 1630

Work scheduled by: NYSEG

FWD  
(Import)  
DYSINGER EAST **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

**SPRNBRK\_-DUNWODIE\_345\_W75**

Sat 09/12/2020 to Sat 09/12/2020  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**SPRNBRK\_\_345KV\_RNS3**

Sat 09/12/2020 to Sat 09/12/2020  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_5**

Sat 09/12/2020 to Sat 09/12/2020  
0001 Continuous 2100

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_7**

Sat 09/12/2020 to Sat 09/12/2020  
0001 Continuous 2100

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,August 01, 2020 to Monday ,January 31, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SPRNBK_-DUNWODIE_345_W75</b>					FWD	
Sat 09/12/2020	to	Sat 09/12/2020			(Import)	
2030	Continuous	2100		SPR/DUN-SOUTH	<b>3800 MW</b>	
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>SPRNBK_345KV_RNS3</b>					FWD	
Sat 09/12/2020	to	Sat 09/12/2020			(Import)	
2030	Continuous	2100		SPR/DUN-SOUTH	<b>3800 MW</b>	
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>MOSES_-ADIRNDCK_230_MA2</b>					FWD	
Sun 09/13/2020	to	Sat 11/14/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>07/24/2020</u>	
0001	Continuous	1300		MOSES SOUTH	<b>2100 MW</b>	
Work scheduled by: NYPA					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	3150 MW
<b>KINTIGH_-ROCHESTR_345_SR1-39</b>					FWD	
Mon 09/14/2020	to	Thu 09/17/2020			(Import)	
0500	Continuous	1530		DYSINGER EAST	<b>1400 MW</b>	
Work scheduled by: NYPA					Impacts Total Transfer Capability	1750 MW
					TTC with All Lines In Service	3150 MW
<b>NIAGARA_-KINTIGH_345_NS1-38</b>					FWD	
Mon 09/14/2020	to	Thu 09/17/2020			(Import)	
0500	Continuous	1530		DYSINGER EAST	<b>1400 MW</b>	
Work scheduled by: NYPA					Impacts Total Transfer Capability	1750 MW
					TTC with All Lines In Service	3150 MW
<b>LINDN_CG-LNDVFT_345_V-3022</b>					FWD	REV
Mon 09/14/2020	to	Wed 09/16/2020			(Import)	(Export)
0800	Continuous	2000		SCH - PJM_VFT	<b>0 MW</b>	<b>0 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	315 MW 315 MW
					TTC with All Lines In Service	315 MW 315 MW
<b>WOOD_ST_-PLSNTVLE_345_Y87</b>					FWD	
Tue 09/15/2020	to	Tue 09/15/2020	<u>UPDATED</u>	<u>by CE</u>	<u>07/27/2020</u>	
0001	Continuous	2230		UPNY CONED	<b>5905 MW</b>	
Work scheduled by: ConEd					Impacts Total Transfer Capability	315 MW
					TTC with All Lines In Service	6220 MW



# NYISO TRANSFER LIMITATIONS

Saturday ,August 01, 2020 to Monday ,January 31, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**EFISHKIL-WOOD\_ST\_\_345\_F39**

Tue 09/15/2020 to Wed 09/16/2020  
 0001 Continuous 2200  
 Work scheduled by: ConEd

**UPDATED by CE 07/27/2020**

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 2220 MW  
 TTC with All Lines In Service 6220 MW

**BRANCHBG-HOPATCON\_500\_5060**

Tue 09/15/2020 to Wed 09/16/2020  
 0200 Continuous 2300  
 Work scheduled by: PJM

**UPDATED by PJM 04/20/2020**

FWD  
 (Import)  
 UPNY CONED **6025 MW**  
 Impacts Total Transfer Capability 195 MW  
 TTC with All Lines In Service 6220 MW

**DOLSONAV-ROCKTVRN\_345\_DART44**

Wed 09/16/2020 to Wed 09/30/2020  
 0700 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2720 MW**  
 Impacts Total Transfer Capability 255 MW  
 TTC with All Lines In Service 2975 MW

**WOOD\_ST\_-PLSNTVLE\_345\_Y87**

Wed 09/16/2020 to Wed 09/16/2020  
 2130 Continuous 2200  
 Work scheduled by: ConEd

**UPDATED by CE 07/27/2020**

FWD  
 (Import)  
 UPNY CONED **5905 MW**  
 Impacts Total Transfer Capability 315 MW  
 TTC with All Lines In Service 6220 MW

**S.RIPLEY-DUNKIRK\_\_230\_68**

Thu 09/17/2020 to Fri 09/18/2020  
 0900 Continuous 1500  
 Work scheduled by: PJM

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**NIAGARA\_-ROCHESTR\_345\_NR2**

Fri 09/18/2020 to Sat 11/14/2020  
 0500 Continuous 2330  
 Work scheduled by: NYPA

FWD  
 (Import)  
 DYSINGER EAST **1400 MW**  
 Impacts Total Transfer Capability 1750 MW  
 TTC with All Lines In Service 3150 MW

**NIAGARA\_\_345KV\_3108**

Fri 09/18/2020 to Sat 11/14/2020  
 0500 Continuous 2330  
 Work scheduled by: NYPA

REV  
 (Export)  
 SCH - OH - NY **1500 MW**  
 Impacts Total Transfer Capability 200 MW  
 TTC with All Lines In Service 1700 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,August 01, 2020 to Monday ,January 31, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Transfer Capability	Start Date	End Date	Time	Work Scheduled by	Impact	TTC with All Lines In Service	Other
EASTVIEW-SPRNBRK__345_W65	Sat 09/19/2020	Sat 09/19/2020	0001 Continuous 0030	ConEd	UPNY CONED	4350 MW	FWD (Import)
					Impacts Total Transfer Capability	1870 MW	
					TTC with All Lines In Service	6220 MW	
MILLWOOD-EASTVIEW_345_W82	Sat 09/19/2020	Sat 09/19/2020	0001 Continuous 0030	ConEd	UPNY CONED	5985 MW	FWD (Import)
					Impacts Total Transfer Capability	235 MW	
					TTC with All Lines In Service	6220 MW	
SPRNBRK__345KV_RNS4	Sat 09/19/2020	Sat 09/19/2020	0001 Continuous 0030	ConEd	SPR/DUN-SOUTH	3200 MW	FWD (Import)
					Impacts Total Transfer Capability	1400 MW	
					TTC with All Lines In Service	4600 MW	
EASTVIEW-SPRNBRK__345_W65	Sat 09/19/2020	Sat 09/19/2020	0330 Continuous 0400	ConEd	UPNY CONED	4350 MW	FWD (Import)
					Impacts Total Transfer Capability	1870 MW	
					TTC with All Lines In Service	6220 MW	
MILLWOOD-EASTVIEW_345_W82	Sat 09/19/2020	Sat 09/19/2020	0330 Continuous 0400	ConEd	UPNY CONED	5985 MW	FWD (Import)
					Impacts Total Transfer Capability	235 MW	
					TTC with All Lines In Service	6220 MW	
SPRNBRK__345KV_RNS4	Sat 09/19/2020	Sat 09/19/2020	0330 Continuous 0400	ConEd	SPR/DUN-SOUTH	3200 MW	FWD (Import)
					Impacts Total Transfer Capability	1400 MW	
					TTC with All Lines In Service	4600 MW	
NIAGARA__345KV_3002	Sat 09/19/2020	Sat 09/19/2020	0500 Continuous 2100	NYPA	SCH - OH - NY	1300 MW	FWD REV (Import) (Export)
					Impacts Total Transfer Capability	650 MW	550 MW
					TTC with All Lines In Service	1950 MW	1700 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,August 01, 2020 to Monday ,January 31, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NIAGARA\_\_345KV\_3022**

Sat 09/19/2020 to Sat 09/19/2020  
 0500 Continuous 2100  
 Work scheduled by: NYPA

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**MILLWOOD\_345KV\_18**

Sun 09/20/2020 to Sun 09/20/2020  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1870 MW  
 TTC with All Lines In Service 6220 MW

**BUCHAN\_S-MILLWOOD\_345\_W98**

Sun 09/20/2020 to Fri 09/25/2020  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **6135 MW**  
 Impacts Total Transfer Capability 85 MW  
 TTC with All Lines In Service 6220 MW

**NIAGARA\_\_345KV\_3102**

Sun 09/20/2020 to Sun 09/20/2020  
 0500 Continuous 2100  
 Work scheduled by: NYPA

FWD REV  
 (Import) (Export)  
 SCH - OH - NY **1700 MW 1400 MW**  
 Impacts Total Transfer Capability 250 MW 300 MW  
 TTC with All Lines In Service 1950 MW 1700 MW

**NIAGARA\_\_345\_230\_AT4**

Sun 09/20/2020 to Sun 09/20/2020  
 0500 Continuous 2100  
 Work scheduled by: NYPA

FWD REV  
 (Import) (Export)  
 SCH - OH - NY **1900 MW 1400 MW**  
 Impacts Total Transfer Capability 50 MW 300 MW  
 TTC with All Lines In Service 1950 MW 1700 MW

**CLAY\_\_-EDIC\_\_345\_1-16**

Mon 09/21/2020 to Fri 09/25/2020  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 OSWEGO EXPORT **4850 MW**  
 Impacts Total Transfer Capability 400 MW  
 TTC with All Lines In Service 5250 MW

**FRASANNX-COOPERS\_\_345\_UCC2-41**

Mon 09/21/2020 to Wed 09/30/2020 **EXTENDED by NYPA 07/21/2020**  
 0700 Continuous 1730  
 Work scheduled by: NYPA **ARR: 19**

FWD  
 (Import)  
 CENTRAL EAST - VC **2500 MW**  
 Impacts Total Transfer Capability 475 MW  
 TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,August 01, 2020 to Monday ,January 31, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MARCY__-FRASANNX_345_UCC2-41</b>					FWD		
Mon 09/21/2020	to	Wed 09/30/2020	<u>EXTENDED</u>	<u>by NYPA</u>	<u>07/21/2020</u>	(Import)	
0700	Continuous	1730				<b>2500 MW</b>	
Work scheduled by: NYPA					<b>ARR: 19</b>	CENTRAL EAST - VC	
						Impacts Total Transfer Capability 475 MW	
						TTC with All Lines In Service 2975 MW	
<b>ROSETON_-ROCKTVRN_345_311</b>					FWD		
Mon 09/21/2020	to	Fri 10/23/2020	<u>UPDATED</u>	<u>by CHGE</u>	<u>10/09/2019</u>	(Import)	
0800	Continuous	1600				<b>4400 MW</b>	
Work scheduled by: CHGE						UPNY CONED	
						Impacts Total Transfer Capability 1820 MW	
						TTC with All Lines In Service 6220 MW	
<b>GOETHALS_345KV_5</b>							
Tue 09/22/2020	to	Tue 09/22/2020	<u>UPDATED</u>	<u>by CE</u>	<u>06/24/2020</u>		
0200	Continuous	0230					
Work scheduled by: PJM						STATEN ISLAND	
						Impacts Total Transfer Capability	
						TTC with All Lines In Service	
<b>LINDEN_-GOETHALS_230_A2253</b>					FWD	REV	
Tue 09/22/2020	to	Wed 09/23/2020	<u>UPDATED</u>	<u>by CE</u>	<u>06/24/2020</u>	(Import)	(Export)
0200	Continuous	2359				<b>2050 MW</b>	<b>1150 MW</b>
Work scheduled by: PJM						SCH - PJ - NY	
						Impacts Total Transfer Capability 150 MW	100 MW
						TTC with All Lines In Service 2200 MW	1250 MW
<b>LINDEN_-GOETHALS_230_A2253 &amp; HUDSONP_-FARRAGUT_345_B3402</b>					FWD	REV	
Tue 09/22/2020	to	Wed 09/23/2020				(Import)	(Export)
0200		2359				<b>2000 MW</b>	<b>1000 MW</b>
Work scheduled by:						SCH - PJ - NY	
						Impacts Total Transfer Capability 200 MW	250 MW
						TTC with All Lines In Service 2200 MW	1250 MW
<b>LINDEN_-GOETHALS_230_A2253 &amp; HUDSONP_-FARRAGUT_345_B3402 &amp; MARION_-FARRAGUT_345_C3403</b>					FWD	REV	
Tue 09/22/2020	to	Wed 09/23/2020				(Import)	(Export)
0200		2359				<b>2000 MW</b>	<b>1000 MW</b>
Work scheduled by:						SCH - PJ - NY	
						Impacts Total Transfer Capability 200 MW	250 MW
						TTC with All Lines In Service 2200 MW	1250 MW
<b>LINDEN_-GOETHALS_230_A2253 &amp; MARION_-FARRAGUT_345_C3403</b>					FWD	REV	
Tue 09/22/2020	to	Wed 09/23/2020				(Import)	(Export)
0200		2359				<b>2000 MW</b>	<b>1000 MW</b>
Work scheduled by:						SCH - PJ - NY	
						Impacts Total Transfer Capability 200 MW	250 MW
						TTC with All Lines In Service 2200 MW	1250 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,August 01, 2020 to Monday ,January 31, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>								
<b>SCRIBA__-VOLNEY__345_21</b>							FWD	
Wed 09/23/2020	to	Thu 09/24/2020	<u>UPDATED</u>	<u>by NGRID</u>	<u>08/01/2020</u>		(Import)	
0800	Continuous	1630				OSWEGO EXPORT	<b>5250 MW</b>	
Work scheduled by: NGrid						Impacts Total Transfer Capability	0 MW	
						TTC with All Lines In Service	5250 MW	
<hr/>								
<b>LINDEN__-GOETHALS_230_A2253</b>							FWD	REV
Thu 09/24/2020	to	Sat 09/26/2020	<u>UPDATED</u>	<u>by PJM</u>	<u>07/06/2020</u>		(Import)	(Export)
0001	Continuous	0300				SCH - PJ - NY	<b>2050 MW</b>	<b>1150 MW</b>
Work scheduled by: PJM						Impacts Total Transfer Capability	150 MW	100 MW
						TTC with All Lines In Service	2200 MW	1250 MW
<hr/>								
<b>LINDEN__-GOETHALS_230_A2253 &amp; HUDSONP_-FARRAGUT_345_B3402</b>							FWD	REV
Thu 09/24/2020	to	Sat 09/26/2020					(Import)	(Export)
0001		0300				SCH - PJ - NY	<b>2000 MW</b>	<b>1000 MW</b>
Work scheduled by:						Impacts Total Transfer Capability	200 MW	250 MW
						TTC with All Lines In Service	2200 MW	1250 MW
<hr/>								
<b>LINDEN__-GOETHALS_230_A2253 &amp; HUDSONP_-FARRAGUT_345_B3402 &amp; MARION__-FARRAGUT_345_C3403</b>							FWD	REV
Thu 09/24/2020	to	Sat 09/26/2020					(Import)	(Export)
0001		0300				SCH - PJ - NY	<b>2000 MW</b>	<b>1000 MW</b>
Work scheduled by:						Impacts Total Transfer Capability	200 MW	250 MW
						TTC with All Lines In Service	2200 MW	1250 MW
<hr/>								
<b>LINDEN__-GOETHALS_230_A2253 &amp; MARION__-FARRAGUT_345_C3403</b>							FWD	REV
Thu 09/24/2020	to	Sat 09/26/2020					(Import)	(Export)
0001		0300				SCH - PJ - NY	<b>2000 MW</b>	<b>1000 MW</b>
Work scheduled by:						Impacts Total Transfer Capability	200 MW	250 MW
						TTC with All Lines In Service	2200 MW	1250 MW
<hr/>								
<b>W49TH_ST_345KV_5</b>							FWD	
Fri 09/25/2020	to	Sat 09/26/2020					(Import)	
0001	Continuous	0300				SCH - PJM_HTP	<b>300 MW</b>	
Work scheduled by: ConEd						Impacts Total Transfer Capability	360 MW	
						TTC with All Lines In Service	660 MW	
<hr/>								
<b>W49TH_ST_345KV_7</b>							FWD	
Fri 09/25/2020	to	Sat 09/26/2020					(Import)	
0001	Continuous	0300				SCH - PJM_HTP	<b>300 MW</b>	
Work scheduled by: ConEd						Impacts Total Transfer Capability	360 MW	
						TTC with All Lines In Service	660 MW	

# NYISO TRANSFER LIMITATIONS

Saturday ,August 01, 2020 to Monday ,January 31, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MILLWOOD_345KV_18</b>					FWD	
Fri 09/25/2020	to	Fri 09/25/2020			(Import)	
0130	Continuous	0200		UPNY CONED	<b>4350 MW</b>	
Work scheduled by: ConEd					Impacts Total Transfer Capability	1870 MW
					TTC with All Lines In Service	6220 MW
<b>EASTVIEW-SPRNBK__345_W78</b>					FWD	
Sat 09/26/2020	to	Sun 09/27/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>06/16/2020</u>	
0001	Continuous	0200		UPNY CONED	<b>4350 MW</b>	
Work scheduled by: ConEd					Impacts Total Transfer Capability	1870 MW
					TTC with All Lines In Service	6220 MW
<b>MILLWOOD-EASTVIEW_345_W85</b>					FWD	
Sat 09/26/2020	to	Sun 09/27/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>06/16/2020</u>	
0001	Continuous	0200		UPNY CONED	<b>5985 MW</b>	
Work scheduled by: ConEd					Impacts Total Transfer Capability	235 MW
					TTC with All Lines In Service	6220 MW
<b>SPRNBK__345KV_RNS3</b>					FWD	
Sat 09/26/2020	to	Sun 09/27/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>06/16/2020</u>	
0001	Continuous	0200		SPR/DUN-SOUTH	<b>3800 MW</b>	
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>GOETHALS_345KV_5</b>						
Sat 09/26/2020	to	Sat 09/26/2020	<u>UPDATED</u>	<u>by PJM</u>	<u>07/06/2020</u>	
0230	Continuous	0300		STATEN ISLAND		
Work scheduled by: PJM					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
<b>CRICKVLY-PLSNTVLY_345_F83</b>					FWD	
Mon 09/28/2020	to	Sun 10/04/2020			(Import)	
0001	Continuous	2200		SCH - NE - NY	<b>350 MW</b>	
Work scheduled by: ConEd					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	1400 MW
<b>CRICKVLY-PLSNTVLY_345_F83</b>					FWD	REV
Mon 09/28/2020	to	Sun 10/04/2020			(Import)	(Export)
0001	Continuous	2200		SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,August 01, 2020 to Monday ,January 31, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**NRTH1385-NOR HBR\_\_138\_601 & CRICKVLY-PLSNTVLY\_345\_F83**

Mon 09/28/2020 to Sun 10/04/2020  
 0500 2200

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

-----  
**NRTH1385-NOR HBR\_\_138\_602 & CRICKVLY-PLSNTVLY\_345\_F83**

Mon 09/28/2020 to Sun 10/04/2020  
 0500 2200

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

-----  
**NRTH1385-NOR HBR\_\_138\_603 & CRICKVLY-PLSNTVLY\_345\_F83**

Mon 09/28/2020 to Sun 10/04/2020  
 0500 2200

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

-----  
**NRTH1385-NOR HBR\_\_138\_601**

Mon 09/28/2020 to Sat 10/17/2020 **UPDATED by LIPA 07/10/2020**  
 0500 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

-----  
**NRTH1385-NOR HBR\_\_138\_601 & NRTH1385-NOR HBR\_\_138\_602**

Mon 09/28/2020 to Sat 10/17/2020  
 0500 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

-----  
**NRTH1385-NOR HBR\_\_138\_601 & NRTH1385-NOR HBR\_\_138\_603**

Mon 09/28/2020 to Sat 10/17/2020  
 0500 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

-----  
**NRTH1385-NOR HBR\_\_138\_602**

Mon 09/28/2020 to Sat 10/17/2020 **UPDATED by LIPA 07/10/2020**  
 0500 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,August 01, 2020 to Monday ,January 31, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**NRTH1385-NOR HBR\_\_138\_602 & NRTH1385-NOR HBR\_\_138\_603**

Mon 09/28/2020 to Sat 10/17/2020  
 0500 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

-----  
**NRTH1385-NOR HBR\_\_138\_603**

Mon 09/28/2020 to Sat 10/17/2020 **UPDATED** **by LIPA** **07/10/2020**  
 0500 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

-----  
**NRTH1385-NRTHPORT\_138\_NNC**

Mon 09/28/2020 to Sat 10/17/2020 **UPDATED** **by LIPA** **07/10/2020**  
 0500 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

-----  
**CLAY\_\_-EDIC\_\_345\_2-15**

Mon 09/28/2020 to Fri 10/02/2020  
 0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
OSWEGO EXPORT	<b>4850 MW</b>
Impacts Total Transfer Capability	400 MW
TTC with All Lines In Service	5250 MW

-----  
**MOTTHAVN-RAINEY\_\_345\_Q11**

Thu 10/01/2020 to Thu 11/05/2020 **UPDATED** **by CONED** **12/17/2019**  
 0001 Continuous 0200

Work scheduled by: ConEd

	FWD
	(Import)
SPR/DUN-SOUTH	<b>3800 MW</b>
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

-----  
**EDIC\_\_-FRASER\_\_345\_EF24-40**

Thu 10/01/2020 to Fri 10/02/2020  
 0700 Continuous 1730

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	<b>2500 MW</b>
Impacts Total Transfer Capability	475 MW
TTC with All Lines In Service	2975 MW

-----  
**HUDSONTP-W49TH\_ST\_345\_Y56**

Fri 10/02/2020 to Thu 10/08/2020  
 0001 Continuous 0300

Work scheduled by: ConEd

	FWD
	(Import)
SCH - PJM_HTP	<b>0 MW</b>
Impacts Total Transfer Capability	660 MW
TTC with All Lines In Service	660 MW



# NYISO TRANSFER LIMITATIONS

Saturday ,August 01, 2020 to Monday ,January 31, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST\_345KV\_7**

Fri 10/02/2020 to Thu 10/08/2020  
 0001 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

**W49TH\_ST\_345KV\_8**

Fri 10/02/2020 to Thu 10/08/2020  
 0001 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SCH - PJM\_HTP **450 MW**  
 Impacts Total Transfer Capability 210 MW  
 TTC with All Lines In Service 660 MW

**PANNELL\_-CLAY\_\_\_\_345\_1**

Mon 10/05/2020 to Fri 10/09/2020 **UPDATED by NYPA 05/07/2020**  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 WEST CENTRAL **1300 MW**  
 Impacts Total Transfer Capability 950 MW  
 TTC with All Lines In Service 2250 MW

**DUNWODIE-MOTTHAVN\_345\_71**

Wed 10/07/2020 to Thu 10/08/2020 **UPDATED by CONED 07/22/2020**  
 0001 Continuous 0100  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_5**

Wed 10/07/2020 to Thu 10/08/2020 **UPDATED by CONED 07/22/2020**  
 0001 Continuous 0100  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_3**

Wed 10/07/2020 to Thu 11/12/2020 **UPDATED by CONED 07/22/2020**  
 0001 Continuous 0100  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_4**

Wed 10/07/2020 to Thu 11/12/2020 **UPDATED by CONED 07/22/2020**  
 0001 Continuous 0100  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,August 01, 2020 to Monday ,January 31, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						FWD	
<b>PLSNTVLE-DUNWODIE_345_W89</b>						(Import)	
Wed 10/07/2020	to	Thu 11/12/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>07/22/2020</u>		
0001	Continuous	0100				UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	2220 MW
						TTC with All Lines In Service	6220 MW
<hr/>							
<b>SAND_BAR-PLATSBRG_115_PV20</b>							
Sat 10/17/2020	to	Sat 11/14/2020				SCH - NE - NY	
0600	Continuous	1800				Impacts Total Transfer Capability	
Work scheduled by: ISONE						TTC with All Lines In Service	
<hr/>							
<b>ROCHESTR-PANNELL_345_RP1</b>						FWD	
						(Import)	
Mon 10/19/2020	to	Fri 10/23/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>03/10/2020</u>		
0500	Continuous	1700				DYSINGER EAST	<b>2300 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	850 MW
						TTC with All Lines In Service	3150 MW
<hr/>							
<b>SCH-NE-NYISO_LIMIT_600</b>						FWD	
						(Import)	
Mon 10/19/2020	to	Sat 10/31/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>06/05/2020</u>		
0630	Continuous	2359				SCH - NE - NY	<b>800 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	600 MW
						TTC with All Lines In Service	1400 MW
<hr/>							
<b>SCH-NYISO-NE_LIMIT_800</b>							REV
						(Export)	
Mon 10/19/2020	to	Sat 10/31/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>06/05/2020</u>		
0630	Continuous	2359				SCH - NE - NY	<b>1000 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	600 MW
						TTC with All Lines In Service	1600 MW
<hr/>							
<b>BERKSHIR-ALPS_345_393</b>						FWD	REV
						(Import)	(Export)
Mon 10/19/2020	to	Tue 11/10/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>06/05/2020</u>		
0630	Continuous	1630				SCH - NE - NY	<b>950 MW 1300 MW</b>
Work scheduled by: NGrid					<b>ARR: 78</b>	Impacts Total Transfer Capability	450 MW 300 MW
						TTC with All Lines In Service	1400 MW 1600 MW
<hr/>							
<b>BERKSHIR-ALPS_345_393</b>						FWD	REV
						(Import)	(Export)
Mon 10/19/2020	to	Tue 11/10/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>06/05/2020</u>		
0630	Continuous	1630				SCH - NPX_1385	<b>100 MW 100 MW</b>
Work scheduled by: NGrid					<b>ARR: 78</b>	Impacts Total Transfer Capability	100 MW 100 MW
						TTC with All Lines In Service	200 MW 200 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,August 01, 2020 to Monday ,January 31, 2022

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-ALPS _____ 345_393 & BERKSHIR-NORTHFLD_345_312					FWD	REV	
Mon 10/19/2020	to	Tue 11/10/2020			(Import)	(Export)	
0630		1630		SCH - NE - NY	<b>950 MW</b>	<b>1300 MW</b>	
Work scheduled by:					Impacts Total Transfer Capability	450 MW	300 MW
<b>ARR: 78</b>					TTC with All Lines In Service	1400 MW	1600 MW
BERKSHIR-NORTHFLD_345_312					FWD	REV	
Mon 10/19/2020	to	Tue 11/10/2020	<b>UPDATED</b>	<b>by ISONE 06/05/2020</b>	(Import)	(Export)	
0630	Continuous	1630		SCH - NE - NY	<b>900 MW</b>	<b>1500 MW</b>	
Work scheduled by: NGrid					Impacts Total Transfer Capability	500 MW	100 MW
					TTC with All Lines In Service	1400 MW	1600 MW
BERKSHIR-NORTHFLD_345_312					FWD	REV	
Mon 10/19/2020	to	Tue 11/10/2020	<b>UPDATED</b>	<b>by ISONE 06/05/2020</b>	(Import)	(Export)	
0630	Continuous	1630		SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>	
Work scheduled by: NGrid					Impacts Total Transfer Capability	100 MW	100 MW
					TTC with All Lines In Service	200 MW	200 MW
SHOR_NPX-SHOREHAM_138_CSC					FWD	REV	
Mon 10/19/2020	to	Fri 10/23/2020	<b>UPDATED</b>	<b>by LI 03/02/2020</b>	(Import)	(Export)	
0700	Continuous	1500		SCH - NPX_CSC	<b>0 MW</b>	<b>0 MW</b>	
Work scheduled by: LI					Impacts Total Transfer Capability	330 MW	330 MW
					TTC with All Lines In Service	330 MW	330 MW
PANNELL_-CLAY_____345_2					FWD		
Mon 10/19/2020	to	Fri 10/23/2020	<b>UPDATED</b>	<b>by NYPA 05/07/2020</b>	(Import)		
0700	Continuous	1530		WEST CENTRAL	<b>1300 MW</b>		
Work scheduled by: NYPA					Impacts Total Transfer Capability	950 MW	
					TTC with All Lines In Service	2250 MW	
COOPERS_-DOLSONAV_345_CCDA42					FWD		
Mon 10/19/2020	to	Fri 11/06/2020			(Import)		
0700	Continuous	1730		CENTRAL EAST - VC	<b>2720 MW</b>		
Work scheduled by: NYPA					Impacts Total Transfer Capability	255 MW	
					TTC with All Lines In Service	2975 MW	
SPRNBK_-TREMONT__345_X28					FWD		
Mon 10/26/2020	to	Mon 10/26/2020			(Import)		
0001	Continuous	0030		SPR/DUN-SOUTH	<b>4200 MW</b>		
Work scheduled by: ConEd					Impacts Total Transfer Capability	400 MW	
					TTC with All Lines In Service	4600 MW	

# NYISO TRANSFER LIMITATIONS

Saturday ,August 01, 2020 to Monday ,January 31, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>LEEDS___345_LEEDS SVC</b>				FWD	
Mon 10/26/2020	to	Fri 10/30/2020		(Import)	
0800	Continuous	1600	CENTRAL EAST - VC	<b>2950 MW</b>	
Work scheduled by: NGrid			Impacts Total Transfer Capability	25 MW	
			TTC with All Lines In Service	2975 MW	
<b>LEEDS___-HURLYAVE_345_301</b>				FWD	
Mon 10/26/2020	to	Fri 12/04/2020		(Import)	
0800	Continuous	1600	UPNY CONED	<b>4100 MW</b>	
Work scheduled by: CHGE			Impacts Total Transfer Capability	2120 MW	
			TTC with All Lines In Service	6220 MW	
<b>SCH-NE-NYISO_LIMIT_800</b>				FWD	
Sun 11/01/2020	to	Tue 11/10/2020	<u>UPDATED</u> <u>by ISONE</u> <u>06/05/2020</u>	(Import)	
0001	Continuous	1630	SCH - NE - NY	<b>1000 MW</b>	
Work scheduled by: NGrid			Impacts Total Transfer Capability	400 MW	
			TTC with All Lines In Service	1400 MW	
<b>SCH-NYISO-NE_LIMIT_700</b>				REV	
Sun 11/01/2020	to	Tue 11/10/2020	<u>UPDATED</u> <u>by ISONE</u> <u>06/05/2020</u>	(Export)	
0001	Continuous	1630	SCH - NE - NY	<b>900 MW</b>	
Work scheduled by: NGrid			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	1700 MW	
<b>SCH-IMO-NYISO_LIMIT_1750</b>				FWD	
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u> <u>by IESO</u> <u>05/03/2019</u>	(Import)	
0001	Continuous	2359	SCH - OH - NY	<b>2050 MW</b>	
Work scheduled by: IESO			Impacts Total Transfer Capability	0 MW	
			TTC with All Lines In Service	2050 MW	
<b>SCH-NYISO-IMO_LIMIT_1600</b>				REV	
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u> <u>by IESO</u> <u>05/03/2019</u>	(Export)	
0001	Continuous	2359	SCH - OH - NY	<b>1900 MW</b>	
Work scheduled by: IESO			Impacts Total Transfer Capability	0 MW	
			TTC with All Lines In Service	1900 MW	
<b>NIAGARA__345KV_3002</b>				FWD	REV
Thu 11/05/2020	to	Thu 11/05/2020		(Import)	(Export)
0500	Continuous	2100	SCH - OH - NY	<b>1550 MW</b>	<b>1400 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	500 MW	500 MW
			TTC with All Lines In Service	2050 MW	1900 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,August 01, 2020 to Monday ,January 31, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**NIAGARA\_\_345KV\_3022**

Thu 11/05/2020 to Thu 11/05/2020  
 0500 Continuous 2100

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>1550 MW</b>	<b>1400 MW</b>
Impacts Total Transfer Capability	500 MW	500 MW
TTC with All Lines In Service	2050 MW	1900 MW

-----  
**SPRNBRK\_-TREMONT\_\_345\_X28**

Fri 11/06/2020 to Sat 11/07/2020  
 0001 Continuous 0059

Work scheduled by: ConEd

	FWD	
	(Import)	
SPR/DUN-SOUTH	<b>4200 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	4600 MW	

-----  
**NIAGARA\_\_345KV\_3102**

Fri 11/06/2020 to Fri 11/06/2020  
 0500 Continuous 2100

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>2000 MW</b>	<b>1700 MW</b>
Impacts Total Transfer Capability	50 MW	200 MW
TTC with All Lines In Service	2050 MW	1900 MW

-----  
**NIAGARA\_\_345\_230\_AT4**

Fri 11/06/2020 to Fri 11/06/2020  
 0500 Continuous 2100

Work scheduled by: NYPA

		REV
		(Export)
SCH - OH - NY		<b>1750 MW</b>
Impacts Total Transfer Capability		150 MW
TTC with All Lines In Service		1900 MW

-----  
**SPRNBRK\_-TREMONT\_\_345\_X28**

Mon 11/09/2020 to Mon 11/09/2020  
 0030 Continuous 0059

Work scheduled by: ConEd

	FWD	
	(Import)	
SPR/DUN-SOUTH	<b>4200 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	4600 MW	

-----  
**DUNWODIE-MOTTHAVN\_345\_71**

Tue 11/10/2020 to Thu 11/12/2020 **UPDATED by CONED 07/22/2020**  
 0001 Continuous 0100

Work scheduled by: ConEd

	FWD	
	(Import)	
SPR/DUN-SOUTH	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

-----  
**DUNWODIE\_345KV\_5**

Tue 11/10/2020 to Thu 11/12/2020 **UPDATED by CONED 07/22/2020**  
 0001 Continuous 0100

Work scheduled by: ConEd

	FWD	
	(Import)	
SPR/DUN-SOUTH	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

# NYISO TRANSFER LIMITATIONS

Saturday ,August 01, 2020 to Monday ,January 31, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Transfer ID	Start Date	End Date	Time	Duration	Work by	From Zone	To Zone	Capacity (MW)	Impact (MW)	TTC (MW)
CHATGUAY-MASSENA__765_7040	Sun 11/15/2020	Mon 11/30/2020	0100	Continuous	1900	NYPA	MOSES SOUTH	1550 MW	1600 MW	3150 MW
							FWD			
							(Import)			
							MOSES SOUTH	1550 MW		
							Impacts Total Transfer Capability	1600 MW		
							TTC with All Lines In Service	3150 MW		
CHATGUAY-MASSENA__765_7040	Sun 11/15/2020	Mon 11/30/2020	0100	Continuous	1900	NYPA	SCH - HQ - NY	0 MW	1000 MW	1000 MW
							FWD			
							(Import)			
							(Export)			
							SCH - HQ - NY	0 MW	0 MW	
							Impacts Total Transfer Capability	1500 MW	1000 MW	
							TTC with All Lines In Service	1500 MW	1000 MW	
MARCY__765_345_AT1	Sun 11/15/2020	Mon 11/30/2020	0100	Continuous	1900	NYPA	MOSES SOUTH	1750 MW	1400 MW	3150 MW
							FWD			
							(Import)			
							MOSES SOUTH	1750 MW		
							Impacts Total Transfer Capability	1400 MW		
							TTC with All Lines In Service	3150 MW		
							ARR: 19			
MARCY__765_345_AT2	Sun 11/15/2020	Mon 11/30/2020	0100	Continuous	1900	NYPA	MOSES SOUTH	1700 MW	1450 MW	3150 MW
							FWD			
							(Import)			
							MOSES SOUTH	1700 MW		
							Impacts Total Transfer Capability	1450 MW		
							TTC with All Lines In Service	3150 MW		
							ARR: 19			
MASSENA_-MARCY__765_MSU1	Sun 11/15/2020	Mon 11/30/2020	0100	Continuous	1900	NYPA	CENTRAL EAST - VC	2265 MW	710 MW	2975 MW
							FWD			
							(Import)			
							CENTRAL EAST - VC	2265 MW		
							Impacts Total Transfer Capability	710 MW		
							TTC with All Lines In Service	2975 MW		
MASSENA_-MARCY__765_MSU1	Sun 11/15/2020	Mon 11/30/2020	0100	Continuous	1900	NYPA	MOSES SOUTH	500 MW	2650 MW	3150 MW
							FWD			
							(Import)			
							MOSES SOUTH	500 MW		
							Impacts Total Transfer Capability	2650 MW		
							TTC with All Lines In Service	3150 MW		
MASSENA_-MARCY__765_MSU1	Sun 11/15/2020	Mon 11/30/2020	0100	Continuous	1900	NYPA	SCH - HQ - NY	475 MW	1000 MW	1000 MW
							FWD			
							(Import)			
							(Export)			
							SCH - HQ - NY	475 MW	1000 MW	
							Impacts Total Transfer Capability	1025 MW	0 MW	
							TTC with All Lines In Service	1500 MW	1000 MW	

# NYISO TRANSFER LIMITATIONS

Saturday ,August 01, 2020 to Monday ,January 31, 2022

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MASSENA -MARCY 765_MSU1</b>			FWD	
Sun 11/15/2020	to	Mon 11/30/2020	(Import)	
0100	Continuous	1900	SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	109 MW
			TTC with All Lines In Service	199 MW
<b>MASSENA -MARCY 765_MSU1 &amp; CHATGUAY-MASSENA 765_7040</b>			FWD	
Sun 11/15/2020	to	Mon 11/30/2020	(Import)	
0100		1900	MOSES SOUTH	<b>500 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	2650 MW
			TTC with All Lines In Service	3150 MW
<b>MOSES -MASSENA 230_MMS1 &amp; MOSES -MASSENA 230_MMS2</b>			FWD	REV
Sun 11/15/2020	to	Mon 11/30/2020	(Import)	(Export)
0100		1900	SCH - HQ - NY	<b>850 MW 0 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	650 MW 1000 MW
			TTC with All Lines In Service	1500 MW 1000 MW
<b>MOSES -MASSENA 230_MMS1 &amp; MOSES -MASSENA 230_MMS2</b>			FWD	
Sun 11/15/2020	to	Mon 11/30/2020	(Import)	
0100		1900	SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	109 MW
			TTC with All Lines In Service	199 MW
<b>STLAWRNC-MOSES 230_L33P &amp; MASSENA -MARCY 765_MSU1</b>			FWD	
Sun 11/15/2020	to	Mon 11/30/2020	(Import)	
0100		1900	SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	109 MW
			TTC with All Lines In Service	199 MW
<b>STLAWRNC-MOSES 230_L33P &amp; MOSES -MASSENA 230_MMS1 &amp; MOSES -MASSENA 230_MMS2</b>			FWD	
Sun 11/15/2020	to	Mon 11/30/2020	(Import)	
0100		1900	SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	109 MW
			TTC with All Lines In Service	199 MW
<b>PLSNTVLY-WOOD_ST 345_F30</b>			FWD	
Mon 11/16/2020	to	Mon 11/16/2020	(Import)	
0001	Continuous	0030	UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	2220 MW
			TTC with All Lines In Service	6220 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,August 01, 2020 to Monday ,January 31, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**PLSNTVLY\_345KV\_RNS5**

Mon 11/16/2020 to Mon 11/16/2020  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 2420 MW  
 TTC with All Lines In Service 6220 MW

**MILLWOOD\_345KV\_18**

Mon 11/16/2020 to Tue 11/17/2020  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1870 MW  
 TTC with All Lines In Service 6220 MW

**PLSNTVLY-WOOD\_ST\_345\_F30**

Tue 11/17/2020 to Tue 11/17/2020  
 0130 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 2220 MW  
 TTC with All Lines In Service 6220 MW

**PLSNTVLY\_345KV\_RNS5**

Tue 11/17/2020 to Tue 11/17/2020  
 0130 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 2420 MW  
 TTC with All Lines In Service 6220 MW

**NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE**

Mon 11/30/2020 to Sun 12/20/2020 **UPDATED by LI 04/29/2020**  
 0600 Continuous 1600  
 Work scheduled by: PJM

FWD  
 (Import)  
 SCH - PJM\_NEPTUNE **0 MW**  
 Impacts Total Transfer Capability 660 MW  
 TTC with All Lines In Service 660 MW

**NEWBRDGE-DUFFYAVE\_345\_501**

Mon 11/30/2020 to Sun 12/20/2020 **UPDATED by LI 04/29/2020**  
 0600 Continuous 1600  
 Work scheduled by: PJM

FWD  
 (Import)  
 SCH - PJM\_NEPTUNE **0 MW**  
 Impacts Total Transfer Capability 660 MW  
 TTC with All Lines In Service 660 MW

**MARCY\_345KV\_CSC**

Tue 12/01/2020 to Fri 12/11/2020  
 0700 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2925 MW**  
 Impacts Total Transfer Capability 50 MW  
 TTC with All Lines In Service 2975 MW



# NYISO TRANSFER LIMITATIONS

Saturday ,August 01, 2020 to Monday ,January 31, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MOSES -ADIRNDCK_230_MA1</b>				FWD
Tue 12/01/2020	to	Sat 02/27/2021	<u>UPDATED</u> <u>by NYPA</u> <u>07/27/2020</u>	(Import)
0700	Continuous	1730		<b>MOSES SOUTH 2300 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW
<b>KINTIGH -ROCHESTR_345_SR1-39</b>				FWD
Thu 12/03/2020	to	Tue 12/15/2020	<u>UPDATED</u> <u>by NYISO</u> <u>06/24/2020</u>	(Import)
0800	Continuous	1900		<b>DYSINGER EAST 1700 MW</b>
Work scheduled by: RGE				Impacts Total Transfer Capability 1450 MW
				TTC with All Lines In Service 3150 MW
<b>NIAGARA -KINTIGH_345_NS1-38</b>				FWD
Thu 12/03/2020	to	Tue 12/15/2020	<u>UPDATED</u> <u>by NYISO</u> <u>06/24/2020</u>	(Import)
0800	Continuous	1900		<b>DYSINGER EAST 1700 MW</b>
Work scheduled by: RGE				Impacts Total Transfer Capability 1450 MW
				TTC with All Lines In Service 3150 MW
<b>BECK -PACKARD_230_BP76</b>				FWD      REV
Fri 12/04/2020	to	Fri 12/04/2020		(Import) (Export)
0730	Daily(No Weekends)	1530		<b>SCH - OH - NY 1650 MW 1400 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability 400 MW 500 MW
				TTC with All Lines In Service 2050 MW 1900 MW
<b>SAND_BAR-PLATSBRG_115_PV20</b>				
Mon 12/07/2020	to	Fri 12/11/2020		SCH - NE - NY
0700	Continuous	1530		Impacts Total Transfer Capability
Work scheduled by: NYPA				TTC with All Lines In Service
<b>W49TH_ST_345KV_6</b>				FWD
Tue 12/08/2020	to	Tue 12/08/2020		(Import)
0301	Continuous	0330		<b>SCH - PJM_HTP 300 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 360 MW
				TTC with All Lines In Service 660 MW
<b>E13THSTA-FARRAGUT_345_46</b>				FWD
Tue 12/08/2020	to	Fri 12/11/2020		(Import)
0301	Continuous	0300		<b>SPR/DUN-SOUTH 3800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,August 01, 2020 to Monday ,January 31, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>W49TH_ST-E13THSTA_345_M55</b>			FWD	
Tue 12/08/2020	to	Fri 12/11/2020	(Import)	
0301	Continuous	0300	SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW
<b>LONG_MTN-CRICKVLY_345_398</b>			FWD	REV
Tue 12/08/2020	to	Thu 12/10/2020	(Import)	(Export)
0700	Continuous	1600	SCH - NE - NY	<b>700 MW 1300 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	700 MW 400 MW
			TTC with All Lines In Service	1400 MW 1700 MW
<b>LONG_MTN-CRICKVLY_345_398</b>			FWD	REV
Tue 12/08/2020	to	Thu 12/10/2020	(Import)	(Export)
0700	Continuous	1600	SCH - NPX_1385	<b>100 MW 100 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
<b>SCH-NE-NYISO_LIMIT_400</b>			FWD	
Tue 12/08/2020	to	Thu 12/10/2020	(Import)	
0700	Continuous	1600	SCH - NE - NY	<b>600 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	1400 MW
<b>SCH-NYISO-NE_LIMIT_1000</b>				REV
Tue 12/08/2020	to	Thu 12/10/2020		(Export)
0700	Continuous	1600	SCH - NE - NY	<b>1200 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	500 MW
			TTC with All Lines In Service	1700 MW
<b>W49TH_ST_345KV_6</b>			FWD	
Fri 12/11/2020	to	Fri 12/11/2020	(Import)	
0230	Continuous	0300	SCH - PJM_HTP	<b>300 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	360 MW
			TTC with All Lines In Service	660 MW
<b>MARCY -EDIC 345_U01-7</b>			FWD	
Mon 12/14/2020	to	Mon 12/14/2020	(Import)	
0700	Continuous	1730	OSWEGO EXPORT	<b>5250 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	0 MW
			TTC with All Lines In Service	5250 MW

ARR: 19&16

# NYISO TRANSFER LIMITATIONS

Saturday ,August 01, 2020 to Monday ,January 31, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SAND\_BAR-PLATSBURG\_115\_PV20**

Mon 12/14/2020 to Fri 12/18/2020  
 0700 Continuous 1530  
 Work scheduled by: NYPA

SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**LADENTWEN-BUCHANAN\_S\_345\_Y88**

Tue 12/15/2020 to Sat 01/30/2021  
 0001 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **5930 MW**  
 Impacts Total Transfer Capability 290 MW  
 TTC with All Lines In Service 6220 MW

**FRASANNEX-COOPERS\_345\_UCC2-41**

Tue 12/15/2020 to Wed 12/16/2020  
 0700 Continuous 1530  
 Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
 CENTRAL EAST - VC **2500 MW**  
 Impacts Total Transfer Capability 475 MW  
 TTC with All Lines In Service 2975 MW

**MARCY -FRASANNEX\_345\_UCC2-41**

Tue 12/15/2020 to Wed 12/16/2020  
 0700 Continuous 1530  
 Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
 CENTRAL EAST - VC **2500 MW**  
 Impacts Total Transfer Capability 475 MW  
 TTC with All Lines In Service 2975 MW

**HOPATCON-RAMAPO\_500\_5018**

Mon 02/01/2021 to Wed 02/03/2021  
 0001 Continuous 2200  
 Work scheduled by: ConEd

FWD REV  
 (Import) (Export)  
 SCH - PJ - NY **1250 MW 1200 MW**  
 Impacts Total Transfer Capability 1650 MW 650 MW  
 TTC with All Lines In Service 2900 MW 1850 MW

**HOPATCON-RAMAPO\_500\_5018**

Mon 02/01/2021 to Wed 02/03/2021  
 0001 Continuous 2200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **6025 MW**  
 Impacts Total Transfer Capability 195 MW  
 TTC with All Lines In Service 6220 MW

**RAMAPO\_345\_345\_PAR3500**

Mon 02/01/2021 to Wed 02/03/2021  
 0001 Continuous 2200  
 Work scheduled by: ConEd

FWD REV  
 (Import) (Export)  
 SCH - PJ - NY **2150 MW 1250 MW**  
 Impacts Total Transfer Capability 750 MW 600 MW  
 TTC with All Lines In Service 2900 MW 1850 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,August 01, 2020 to Monday ,January 31, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
<b>RAMAPO__345_345_PAR4500</b>					
Mon 02/01/2021	to	Wed 02/03/2021			
0001	Continuous	2200	SCH - PJ - NY	<b>2150 MW</b>	<b>1250 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	750 MW 600 MW
				TTC with All Lines In Service	2900 MW 1850 MW
<b>RAMAPO__500_345_BK 1500</b>					
Mon 02/01/2021	to	Wed 02/03/2021			
0001	Continuous	2200	SCH - PJ - NY	<b>1250 MW</b>	<b>1200 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	1650 MW 650 MW
				TTC with All Lines In Service	2900 MW 1850 MW
<b>RAMAPO__500_345_BK 1500</b>					
Mon 02/01/2021	to	Wed 02/03/2021			
0001	Continuous	2200	UPNY CONED	<b>6025 MW</b>	
Work scheduled by: ConEd				Impacts Total Transfer Capability	195 MW
				TTC with All Lines In Service	6220 MW
<b>PLSNTVLY-WOOD_ST__345_F30</b>					
Mon 02/15/2021	to	Tue 02/16/2021			
0001	Continuous	0200	UPNY CONED	<b>4000 MW</b>	
Work scheduled by: ConEd				Impacts Total Transfer Capability	2220 MW
				TTC with All Lines In Service	6220 MW
<b>PLSNTVLY_345KV_RNS5</b>					
Mon 02/15/2021	to	Tue 02/16/2021			
0001	Continuous	0200	UPNY CONED	<b>3800 MW</b>	
Work scheduled by: ConEd				Impacts Total Transfer Capability	2420 MW
				TTC with All Lines In Service	6220 MW
<b>EFISHKIL-WOOD_ST__345_F39</b>					
Thu 02/18/2021	to	Sat 02/20/2021	<b>UPDATED</b>	<b>by CE</b>	<b>04/01/2020</b>
2100	Continuous	0200	UPNY CONED	<b>4000 MW</b>	
Work scheduled by: ConEd				Impacts Total Transfer Capability	2220 MW
				TTC with All Lines In Service	6220 MW
<b>WOOD_ST_-PLSNTVLE_345_Y87</b>					
Thu 02/18/2021	to	Sat 02/20/2021	<b>UPDATED</b>	<b>by CE</b>	<b>04/01/2020</b>
2100	Continuous	0200	UPNY CONED	<b>5905 MW</b>	
Work scheduled by: ConEd				Impacts Total Transfer Capability	315 MW
				TTC with All Lines In Service	6220 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,August 01, 2020 to Monday ,January 31, 2022

Seasonal Limits

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**CHATGUAY-MASSENA\_\_765\_7040**

Sun 02/28/2021 to Mon 03/01/2021  
 0500 Continuous 1730

Work scheduled by: NYPA

FWD  
 (Import)  
**MOSES SOUTH 1550 MW**  
 Impacts Total Transfer Capability 1600 MW  
 TTC with All Lines In Service 3150 MW

-----  
**CHATGUAY-MASSENA\_\_765\_7040**

Sun 02/28/2021 to Mon 03/01/2021  
 0500 Continuous 1730

Work scheduled by: NYPA

FWD REV  
 (Import) (Export)  
**SCH - HQ - NY 0 MW 0 MW**  
 Impacts Total Transfer Capability 1500 MW 1000 MW  
 TTC with All Lines In Service 1500 MW 1000 MW

-----  
**MASSENA\_-MARCY\_\_\_765\_MSU1**

Sun 02/28/2021 to Mon 03/01/2021  
 0500 Continuous 1730

Work scheduled by: NYPA

FWD  
 (Import)  
**CENTRAL EAST - VC 2265 MW**  
 Impacts Total Transfer Capability 710 MW  
 TTC with All Lines In Service 2975 MW

-----  
**MASSENA\_-MARCY\_\_\_765\_MSU1**

Sun 02/28/2021 to Mon 03/01/2021  
 0500 Continuous 1730

Work scheduled by: NYPA

FWD  
 (Import)  
**MOSES SOUTH 500 MW**  
 Impacts Total Transfer Capability 2650 MW  
 TTC with All Lines In Service 3150 MW

-----  
**MASSENA\_-MARCY\_\_\_765\_MSU1**

Sun 02/28/2021 to Mon 03/01/2021  
 0500 Continuous 1730

Work scheduled by: NYPA

FWD REV  
 (Import) (Export)  
**SCH - HQ - NY 475 MW 1000 MW**  
 Impacts Total Transfer Capability 1025 MW 0 MW  
 TTC with All Lines In Service 1500 MW 1000 MW

-----  
**MASSENA\_-MARCY\_\_\_765\_MSU1**

Sun 02/28/2021 to Mon 03/01/2021  
 0500 Continuous 1730

Work scheduled by: NYPA

FWD  
 (Import)  
**SCH - HQ\_CEDARS 90 MW**  
 Impacts Total Transfer Capability 109 MW  
 TTC with All Lines In Service 199 MW

-----  
**MASSENA\_-MARCY\_\_\_765\_MSU1 & CHATGUAY-MASSENA\_\_765\_7040**

Sun 02/28/2021 to Mon 03/01/2021  
 0500 1730

Work scheduled by:

FWD  
 (Import)  
**MOSES SOUTH 500 MW**  
 Impacts Total Transfer Capability 2650 MW  
 TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,August 01, 2020 to Monday ,January 31, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
<b>STLAWRNC-MOSES</b> _____ <b>230_L33P &amp; MASSENA -MARCY</b> _____ <b>765_MSU1</b>			FWD
Sun 02/28/2021	to	Mon 03/01/2021	(Import)
0500		1730	SCH - HQ_CEDARS <b>90 MW</b>
Work scheduled by:			
		Impacts Total Transfer Capability	109 MW
		TTC with All Lines In Service	199 MW
<hr/>			
<b>DUNWODIE_345KV_3</b>			FWD
Mon 03/01/2021	to	Mon 03/01/2021	(Import)
0001	Continuous	0030	SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd			
		Impacts Total Transfer Capability	800 MW
		TTC with All Lines In Service	4600 MW
<hr/>			
<b>DUNWODIE_345KV_5</b>			FWD
Mon 03/01/2021	to	Mon 03/01/2021	(Import)
0001	Continuous	0030	SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd			
		Impacts Total Transfer Capability	800 MW
		TTC with All Lines In Service	4600 MW
<hr/>			
<b>EASTVIEW-SPRNBRK_345_W64</b>			FWD
Mon 03/01/2021	to	Mon 03/01/2021	(Import)
0001	Continuous	0030	UPNY CONED <b>4350 MW</b>
Work scheduled by: ConEd			
		Impacts Total Transfer Capability	1870 MW
		TTC with All Lines In Service	6220 MW
<hr/>			
<b>SPRNBRK_345KV_RNS5</b>			FWD
Mon 03/01/2021	to	Mon 03/01/2021	(Import)
0001	Continuous	0030	SPR/DUN-SOUTH <b>3200 MW</b>
Work scheduled by: ConEd			
		Impacts Total Transfer Capability	1400 MW
		TTC with All Lines In Service	4600 MW
<hr/>			
<b>MILLWOOD-EASTVIEW_345_W99</b>			FWD
Mon 03/01/2021	to	Mon 03/22/2021	(Import)
0001	Continuous	0200	UPNY CONED <b>5985 MW</b>
Work scheduled by: ConEd			
		Impacts Total Transfer Capability	235 MW
		TTC with All Lines In Service	6220 MW
<hr/>			
<b>DUNWODIE-MOTTHAVN_345_71</b>			FWD
Mon 03/01/2021	to	Mon 04/05/2021	(Import)
0001	Continuous	0300	SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd			
		Impacts Total Transfer Capability	800 MW
		TTC with All Lines In Service	4600 MW
<hr/>			

# NYISO TRANSFER LIMITATIONS

Saturday ,August 01, 2020 to Monday ,January 31, 2022

Seasonal Limits

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p><b>MOTTHAVN-RAINEY___345_Q11</b></p> <p>Mon 03/01/2021 to Tue 04/06/2021</p> <p>0001 Continuous 0700</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>SPR/DUN-SOUTH <b>3800 MW</b></p> <p>Impacts Total Transfer Capability 800 MW</p> <p>TTC with All Lines In Service 4600 MW</p>
<p><b>MOSES___-ADIRNDCK_230_MAI</b></p> <p>Tue 03/02/2021 to Mon 05/31/2021</p> <p>0700 Continuous 1300</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH <b>2300 MW</b></p> <p>Impacts Total Transfer Capability 850 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p><b>NIAGARA_-ROBNSNRD_230_64</b></p> <p>Fri 03/12/2021 to Fri 03/12/2021</p> <p>0500 Continuous 1700</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">REV (Export)</p> <p>SCH - OH - NY <b>1900 MW</b></p> <p>Impacts Total Transfer Capability 0 MW</p> <p>TTC with All Lines In Service 1900 MW</p>
<p><b>MARCY___345KV_CSC</b></p> <p>Sat 03/13/2021 to Sat 03/13/2021 <b><u>UPDATED</u></b> <b><u>by NYPA</u></b> <b><u>07/29/2020</u></b></p> <p>0700 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC <b>2925 MW</b></p> <p>Impacts Total Transfer Capability 50 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p><b>EASTVIEW-SPRNBK__345_W64</b></p> <p>Mon 03/22/2021 to Mon 03/22/2021 <b><u>UPDATED</u></b> <b><u>by CONED</u></b> <b><u>01/23/2020</u></b></p> <p>0130 Continuous 0200</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>UPNY CONED <b>4350 MW</b></p> <p>Impacts Total Transfer Capability 1870 MW</p> <p>TTC with All Lines In Service 6220 MW</p>
<p><b>SPRNBK__345KV_RNS5</b></p> <p>Mon 03/22/2021 to Mon 03/22/2021 <b><u>UPDATED</u></b> <b><u>by CONED</u></b> <b><u>01/23/2020</u></b></p> <p>0130 Continuous 0200</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>SPR/DUN-SOUTH <b>3200 MW</b></p> <p>Impacts Total Transfer Capability 1400 MW</p> <p>TTC with All Lines In Service 4600 MW</p>
<p><b>CLAY___-EDIC___345_2-15</b></p> <p>Mon 03/29/2021 to Fri 04/16/2021</p> <p>0800 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>OSWEGO EXPORT <b>4850 MW</b></p> <p>Impacts Total Transfer Capability 400 MW</p> <p>TTC with All Lines In Service 5250 MW</p>

# NYISO TRANSFER LIMITATIONS

Saturday ,August 01, 2020 to Monday ,January 31, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>ROCHESTR-PANNELL__345_RP2</b>				FWD	
Wed 03/31/2021	to	Mon 04/12/2021		(Import)	
0500	Continuous	1700	DYSINGER EAST	<b>2300 MW</b>	
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
<b>DUNWODIE_345KV_3</b>				FWD	
Mon 04/05/2021	to	Mon 04/05/2021		(Import)	
0230	Continuous	0300	SPR/DUN-SOUTH	<b>3800 MW</b>	
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
<b>DUNWODIE_345KV_5</b>				FWD	
Mon 04/05/2021	to	Mon 04/05/2021		(Import)	
0230	Continuous	0300	SPR/DUN-SOUTH	<b>3800 MW</b>	
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
<b>SPRNBK_-TREMONT__345_X28</b>				FWD	
Mon 04/19/2021	to	Tue 04/20/2021		(Import)	
0001	Continuous	0200	SPR/DUN-SOUTH	<b>4200 MW</b>	
Work scheduled by: ConEd				Impacts Total Transfer Capability	400 MW
				TTC with All Lines In Service	4600 MW
<b>NIAGARA__345KV_3002</b>				FWD	REV
Mon 04/26/2021	to	Mon 04/26/2021		(Import)	(Export)
0500	Continuous	1700	SCH - OH - NY	<b>1550 MW</b>	<b>1400 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	500 MW
				TTC with All Lines In Service	2050 MW
<b>SCH-IMO-NYISO_LIMIT_1600</b>				FWD	
Sat 05/01/2021	to	Sun 10/31/2021	<b>UPDATED by IESO 05/03/2019</b>	(Import)	
0001	Continuous	2359	SCH - OH - NY	<b>1900 MW</b>	
Work scheduled by: IESO				Impacts Total Transfer Capability	50 MW
				TTC with All Lines In Service	1950 MW
<b>PANNELL_-CLAY____345_2</b>				FWD	
Mon 05/03/2021	to	Fri 05/28/2021		(Import)	
0700	Continuous	1730	WEST CENTRAL	<b>1300 MW</b>	
Work scheduled by: NYPA				Impacts Total Transfer Capability	950 MW
				TTC with All Lines In Service	2250 MW



# NYISO TRANSFER LIMITATIONS

Saturday ,August 01, 2020 to Monday ,January 31, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**NIAGARA\_\_345KV\_3022**

Tue 05/04/2021 to Wed 05/05/2021  
 0500 Continuous 1700  
 Work scheduled by: NYPA

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

-----  
**NIAGARA\_\_345KV\_3202**

Tue 05/04/2021 to Wed 05/05/2021  
 0500 Continuous 1700  
 Work scheduled by: NYPA

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

-----  
**NIAGARA\_\_345KV\_3102**

Thu 05/06/2021 to Fri 05/07/2021  
 0500 Continuous 1700  
 Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>1700 MW</b>	<b>1400 MW</b>
Impacts Total Transfer Capability	250 MW	300 MW
TTC with All Lines In Service	1950 MW	1700 MW

-----  
**NIAGARA\_\_345KV\_3302**

Mon 05/10/2021 to Wed 05/12/2021  
 0500 Continuous 1700  
 Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>1000 MW</b>	<b>1600 MW</b>
Impacts Total Transfer Capability	950 MW	100 MW
TTC with All Lines In Service	1950 MW	1700 MW

-----  
**NIAGARA\_\_345KV\_3108**

Thu 05/13/2021 to Fri 05/14/2021  
 0500 Continuous 1700  
 Work scheduled by: NYPA

		REV
		(Export)
SCH - OH - NY		<b>1500 MW</b>
Impacts Total Transfer Capability		200 MW
TTC with All Lines In Service		1700 MW

-----  
**MOSES\_\_-ADIRNDCK\_230\_MA2**

Tue 06/01/2021 to Sun 11/14/2021  
 0700 Continuous 1300  
 Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>2100 MW</b>
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	3150 MW

-----  
**NIAGARA\_-KINTIGH\_\_345\_NS1-38**

Mon 09/13/2021 to Fri 09/17/2021  
 0500 Continuous 1700  
 Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	<b>1400 MW</b>
Impacts Total Transfer Capability	1750 MW
TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,August 01, 2020 to Monday ,January 31, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO-NYISO\_LIMIT\_1750

FWD

Mon 11/01/2021 to Fri 12/31/2021 UPDATED by IESO 05/03/2019  
 0001 Continuous 2359

(Import)

Work scheduled by: IESO

SCH - OH - NY **2050 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 2050 MW

SCH-NYISO-IMO\_LIMIT\_1600

REV

Mon 11/01/2021 to Fri 12/31/2021 UPDATED by IESO 05/03/2019  
 0001 Continuous 2359

(Export)

Work scheduled by: IESO

SCH - OH - NY **1900 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 1900 MW

MOSES\_\_-ADIRNDCK\_230\_MAL

FWD

Wed 12/01/2021 to Tue 05/31/2022  
 0700 Continuous 1300

(Import)

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW