

NYISO TRANSFER LIMITATIONS

Tuesday ,August 04, 2020 to Thursday ,February 03, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_9_BYPASS & DUNWODIE_345KV_10_BYPASS & SPRNBRK__345KV_R4S3_BYPASS & SPRNBRK__345KV_R5S3_BYPASS

Sun 02/01/2015 to Sat 02/01/2025
0000 0000

Work scheduled by:

UPNY CONED
Impacts Total Transfer Capability
TTC with All Lines In Service

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Thu 10/01/2020
0001 Continuous 2359

Work scheduled by: ConEd

EXTENDED by CONED 05/03/2020

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2050 MW	1150 MW
Impacts Total Transfer Capability	150 MW	100 MW
TTC with All Lines In Service	2200 MW	1250 MW

HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Thu 10/01/2020
0001 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2000 MW	1000 MW
Impacts Total Transfer Capability	200 MW	250 MW
TTC with All Lines In Service	2200 MW	1250 MW

MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Thu 10/01/2020
0001 Continuous 2359

Work scheduled by: ConEd

EXTENDED by CONED 05/03/2020

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2050 MW	1150 MW
Impacts Total Transfer Capability	150 MW	100 MW
TTC with All Lines In Service	2200 MW	1250 MW

STLAWRNC-MOSES__230_L33P

Mon 04/30/2018 to Fri 12/31/2021
0456 Continuous 2359

Work scheduled by: IESO

EXT FORCE by IESO 08/21/2018

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

SCH-IMO-NYISO_LIMIT_1600

Fri 05/01/2020 to Sat 10/31/2020
0001 Continuous 2359

Work scheduled by: IESO

UPDATED by IESO 05/03/2019

	FWD
	(Import)
SCH - OH - NY	1900 MW
Impacts Total Transfer Capability	50 MW
TTC with All Lines In Service	1950 MW

SHOR_NPX-SHOREHAM_138_CSC

Wed 07/08/2020 to Wed 09/02/2020
1247 Continuous 2359

Work scheduled by: LI

EXT FORCE by ISONE 07/20/2020

	FWD	REV
	(Import)	(Export)
SCH - NPX_CSC	0 MW	0 MW
Impacts Total Transfer Capability	330 MW	330 MW
TTC with All Lines In Service	330 MW	330 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,August 04, 2020 to Thursday ,February 03, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
<p>DUNWODIE_345KV_4</p> <p>Fri 07/31/2020 to Fri 07/31/2020</p> <p>0001 Continuous 0030</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>SPR/DUN-SOUTH 3800 MW</p> <p>Impacts Total Transfer Capability 800 MW</p> <p>TTC with All Lines In Service 4600 MW</p>		
<hr/>			
<p>DUNWODIE_345KV_6</p> <p>Fri 07/31/2020 to Fri 07/31/2020</p> <p>0001 Continuous 0030</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>SPR/DUN-SOUTH 3800 MW</p> <p>Impacts Total Transfer Capability 800 MW</p> <p>TTC with All Lines In Service 4600 MW</p>		
<hr/>			
<p>DUNWODIE-SHORE_RD_345_Y50</p> <p>Fri 07/31/2020 to Tue 08/04/2020</p> <p>0001 Continuous 0259</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>CONED - LIPA 800 MW</p> <p>Impacts Total Transfer Capability 700 MW</p> <p>TTC with All Lines In Service 1500 MW</p>		
<hr/>			
<p>SHORE_RD_345_138_BK 1</p> <p>Fri 07/31/2020 to Tue 08/04/2020</p> <p>0001 Continuous 0259</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>CONED - LIPA 1350 MW</p> <p>Impacts Total Transfer Capability 150 MW</p> <p>TTC with All Lines In Service 1500 MW</p>		
<hr/>			
<p>SHORE_RD_345_138_BK 2</p> <p>Fri 07/31/2020 to Tue 08/04/2020</p> <p>0001 Continuous 0259</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>CONED - LIPA 1350 MW</p> <p>Impacts Total Transfer Capability 150 MW</p> <p>TTC with All Lines In Service 1500 MW</p>		
<hr/>			
<p>MOSES -ADIRNDCK_230_MA2</p> <p>Fri 07/31/2020 to Sat 09/12/2020</p> <p>0500 Continuous 2359</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>UPDATED by NYPA 07/27/2020</p> <p>MOSES SOUTH 2100 MW</p> <p>Impacts Total Transfer Capability 1050 MW</p> <p>TTC with All Lines In Service 3150 MW</p>		
<hr/>			
<p>DUNWODIE_345KV_6</p> <p>Sat 08/01/2020 to Sat 08/01/2020</p> <p>0001 Continuous 0030</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>UPDATED by CONED 07/31/2020</p> <p>SPR/DUN-SOUTH 3800 MW</p> <p>Impacts Total Transfer Capability 800 MW</p> <p>TTC with All Lines In Service 4600 MW</p>		

NYISO TRANSFER LIMITATIONS

Tuesday ,August 04, 2020 to Thursday ,February 03, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_8					FWD	
Sat 08/01/2020	to	Sat 08/01/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>07/31/2020</u>	(Import)
0001	Continuous	0030				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<hr/>						
PLSNTVLE-DUNWODIE_345_W90					FWD	
Sat 08/01/2020	to	Sat 08/01/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>07/31/2020</u>	(Import)
0001	Continuous	1800				4000 MW
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	2220 MW
					TTC with All Lines In Service	6220 MW
<hr/>						
WOOD_ST_-PLSNTVLE_345_Y87					FWD	
Sat 08/01/2020	to	Sat 08/01/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>07/31/2020</u>	(Import)
0001	Continuous	1800				5905 MW
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	315 MW
					TTC with All Lines In Service	6220 MW
<hr/>						
DUNWODIE_345KV_6					FWD	
Sat 08/01/2020	to	Sat 08/01/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>07/31/2020</u>	(Import)
1730	Continuous	1800				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<hr/>						
DUNWODIE_345KV_8					FWD	
Sat 08/01/2020	to	Sat 08/01/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>07/31/2020</u>	(Import)
1730	Continuous	1800				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<hr/>						
DUNWODIE_345KV_4					FWD	
Tue 08/04/2020	to	Tue 08/04/2020				(Import)
0230	Continuous	0259				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<hr/>						
DUNWODIE_345KV_6					FWD	
Tue 08/04/2020	to	Tue 08/04/2020				(Import)
0230	Continuous	0259				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,August 04, 2020 to Thursday ,February 03, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV	
					(Import)	(Export)	
NRTH1385-NOR HBR__138_601							
Wed 08/05/2020	to	Fri 08/07/2020	CANCELLED	by LI	08/04/2020		
0800	Continuous	1500					
Work scheduled by: LI					SCH - NPX_1385	100 MW	
					Impacts Total Transfer Capability	100 MW	
					TTC with All Lines In Service	200 MW	
NRTH1385-NOR HBR__138_602							
Wed 08/05/2020	to	Fri 08/07/2020	CANCELLED	by LI	08/04/2020		
0800	Continuous	1500					
Work scheduled by: LI					SCH - NPX_1385	100 MW	
					Impacts Total Transfer Capability	100 MW	
					TTC with All Lines In Service	200 MW	
NRTH1385-NOR HBR__138_603							
Wed 08/05/2020	to	Fri 08/07/2020	CANCELLED	by LI	08/04/2020		
0800	Continuous	1500					
Work scheduled by: LI					SCH - NPX_1385	100 MW	
					Impacts Total Transfer Capability	100 MW	
					TTC with All Lines In Service	200 MW	
NRTH1385-NRTHPORT_138_NNC							
Wed 08/05/2020	to	Fri 08/07/2020	CANCELLED	by LI	08/04/2020		
0800	Continuous	1500					
Work scheduled by: LI					SCH - NPX_1385	0 MW	
					Impacts Total Transfer Capability	200 MW	
					TTC with All Lines In Service	200 MW	
INDPDNCE-SCRIBA__345_25							
Thu 08/06/2020	to	Thu 08/06/2020	UPDATED	by NGRID	07/29/2020		
0600	Daily(No Weekends)	1630					
Work scheduled by: NGrid					OSWEGO EXPORT	5250 MW	
					Impacts Total Transfer Capability	0 MW	
					TTC with All Lines In Service	5250 MW	
CRICKVLY-PLSNTVLY_345_F83							
Sat 08/08/2020	to	Sat 08/08/2020					
0001	Continuous	2200					
Work scheduled by: ConEd					SCH - NE - NY	350 MW	
					Impacts Total Transfer Capability	1050 MW	
					TTC with All Lines In Service	1400 MW	
CRICKVLY-PLSNTVLY_345_F83							
Sat 08/08/2020	to	Sat 08/08/2020					
0001	Continuous	2200					
Work scheduled by: ConEd					SCH - NPX_1385	100 MW	
					Impacts Total Transfer Capability	100 MW	
					TTC with All Lines In Service	200 MW	

NYISO TRANSFER LIMITATIONS

Tuesday ,August 04, 2020 to Thursday ,February 03, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					FWD	REV
BECK -NIAGARA 345_PA302					(Import)	(Export)
Sat 08/08/2020	to	Sun 08/09/2020	<u>CANCELLED</u>	<u>by IESO</u>	<u>08/04/2020</u>	
0500	Continuous	1700				
Work scheduled by: IESO					SCH - OH - NY	900 MW 800 MW
					Impacts Total Transfer Capability	1050 MW 900 MW
					TTC with All Lines In Service	1950 MW 1700 MW
<hr/>						
SAND_BAR-PLATSBRG_115_PV20						
Sun 08/09/2020	to	Sun 08/16/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>07/28/2020</u>	
0800	Continuous	1900				
Work scheduled by: ISONE					SCH - NE - NY	
					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
<hr/>						
NIAGARA 345KV_3002					FWD	REV
					(Import)	(Export)
Wed 08/12/2020	to	Wed 08/12/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>07/20/2020</u>	
0500	Continuous	0530				
Work scheduled by: NYPA					SCH - OH - NY	1300 MW 1150 MW
					Impacts Total Transfer Capability	650 MW 550 MW
					TTC with All Lines In Service	1950 MW 1700 MW
<hr/>						
NIAGARA 345KV_3002					FWD	REV
					(Import)	(Export)
Thu 08/13/2020	to	Thu 08/13/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>07/20/2020</u>	
1830	Continuous	1900				
Work scheduled by: NYPA					SCH - OH - NY	1300 MW 1150 MW
					Impacts Total Transfer Capability	650 MW 550 MW
					TTC with All Lines In Service	1950 MW 1700 MW
<hr/>						
S.RIPLEY-DUNKIRK_230_68						
Mon 08/17/2020	to	Fri 08/21/2020				
0900	Continuous	1500				
Work scheduled by: PJM					SCH - PJ - NY	
					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
<hr/>						
SAND_BAR-PLATSBRG_115_PV20						
Sat 08/22/2020	to	Sat 08/29/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>07/28/2020</u>	
0800	Continuous	1900				
Work scheduled by: ISONE					SCH - NE - NY	
					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
<hr/>						
NIAGARA 345KV_3102					FWD	REV
					(Import)	(Export)
Wed 08/26/2020	to	Wed 08/26/2020				
0500	Continuous	1700				
Work scheduled by: NYPA					SCH - OH - NY	1700 MW 1400 MW
					Impacts Total Transfer Capability	250 MW 300 MW
					TTC with All Lines In Service	1950 MW 1700 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,August 04, 2020 to Thursday ,February 03, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STOLLERD-HISHELDN_230_67

Wed 08/26/2020 to Wed 08/26/2020
0900 Continuous 1000

Work scheduled by: NYSEG

FWD
(Import)
DYSINGER EAST **2850 MW**
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 3150 MW

OSWEGO_COMPLEX_AVR_O/S

Sun 09/06/2020 to Sun 09/06/2020
0900 Continuous 0930

Work scheduled by: Gen

FWD
(Import)
CENTRAL EAST - VC **2870 MW**
Impacts Total Transfer Capability 105 MW
TTC with All Lines In Service 2975 MW

MARCY__-N.SCTLND_345_18

Wed 09/09/2020 to Wed 09/09/2020
0800 Daily(No Weekends) 1500

Work scheduled by: NGrid

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2090 MW**
Impacts Total Transfer Capability 885 MW
TTC with All Lines In Service 2975 MW

MEYER__-CANANDGA_230_60

Thu 09/10/2020 to Thu 09/10/2020
0730 Continuous 1630

Work scheduled by: NYSEG

FWD
(Import)
DYSINGER EAST **2850 MW**
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 3150 MW

SPRNBK_-DUNWODIE_345_W75

Sat 09/12/2020 to Sat 09/12/2020
0001 Continuous 0030

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

SPRNBK__345KV_RNS3

Sat 09/12/2020 to Sat 09/12/2020
0001 Continuous 0030

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_5

Sat 09/12/2020 to Sat 09/12/2020
0001 Continuous 2100

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,August 04, 2020 to Thursday ,February 03, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_7				FWD	
Sat 09/12/2020	to	Sat 09/12/2020		(Import)	
0001	Continuous	2100	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
SPRNBRK_-DUNWODIE_345_W75				FWD	
Sat 09/12/2020	to	Sat 09/12/2020		(Import)	
2030	Continuous	2100	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
SPRNBRK__345KV_RNS3				FWD	
Sat 09/12/2020	to	Sat 09/12/2020		(Import)	
2030	Continuous	2100	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
MOSES_-ADIRNDCK_230_MA2				FWD	
Sun 09/13/2020	to	Sat 11/14/2020	UPDATED	by NYPA	07/24/2020
0001	Continuous	1300	MOSES SOUTH	2100 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1050 MW	
			TTC with All Lines In Service	3150 MW	
KINTIGH_-ROCHESTR_345_SRL-39				FWD	
Mon 09/14/2020	to	Thu 09/17/2020		(Import)	
0500	Continuous	1530	DYSINGER EAST	1400 MW	
Work scheduled by: NYSEG			Impacts Total Transfer Capability	1750 MW	
			TTC with All Lines In Service	3150 MW	
NIAGARA_-KINTIGH__345_NS1-38				FWD	
Mon 09/14/2020	to	Thu 09/17/2020		(Import)	
0500	Continuous	1530	DYSINGER EAST	1400 MW	
Work scheduled by: NYSEG			Impacts Total Transfer Capability	1750 MW	
			TTC with All Lines In Service	3150 MW	
LINDN_CG-LNDVFT__345_V-3022				FWD	REV
Mon 09/14/2020	to	Wed 09/16/2020		(Import)	(Export)
0800	Continuous	2000	SCH - PJM_VFT	0 MW	0 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	315 MW	315 MW
			TTC with All Lines In Service	315 MW	315 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,August 04, 2020 to Thursday ,February 03, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

WOOD_ST_-PLSNTVLE_345_Y87

Tue 09/15/2020 to Tue 09/15/2020
 0001 Continuous 2230
 Work scheduled by: ConEd

UPDATED by CE 07/27/2020

FWD
 (Import)
 UPNY CONED **5905 MW**
 Impacts Total Transfer Capability 315 MW
 TTC with All Lines In Service 6220 MW

EFISHKIL-WOOD_ST__345_F39

Tue 09/15/2020 to Wed 09/16/2020
 0001 Continuous 2200
 Work scheduled by: ConEd

UPDATED by CE 07/27/2020

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 2220 MW
 TTC with All Lines In Service 6220 MW

BRANCHBG-HOPATCON_500_5060

Tue 09/15/2020 to Wed 09/16/2020
 0200 Continuous 2300
 Work scheduled by: PJM

UPDATED by PJM 04/20/2020

FWD
 (Import)
 UPNY CONED **6025 MW**
 Impacts Total Transfer Capability 195 MW
 TTC with All Lines In Service 6220 MW

ADIRNDCK-CHASLAKE_230_13

Tue 09/15/2020 to Tue 09/15/2020
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2100 MW**
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW

DOLSONAV-ROCKTVRN_345_DART44

Wed 09/16/2020 to Wed 09/30/2020
 0700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2720 MW**
 Impacts Total Transfer Capability 255 MW
 TTC with All Lines In Service 2975 MW

WOOD_ST_-PLSNTVLE_345_Y87

Wed 09/16/2020 to Wed 09/16/2020
 2130 Continuous 2200
 Work scheduled by: ConEd

UPDATED by CE 07/27/2020

FWD
 (Import)
 UPNY CONED **5905 MW**
 Impacts Total Transfer Capability 315 MW
 TTC with All Lines In Service 6220 MW

S.RIPLEY-DUNKIRK__230_68

Thu 09/17/2020 to Fri 09/18/2020
 0900 Continuous 1500
 Work scheduled by: PJM

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Tuesday ,August 04, 2020 to Thursday ,February 03, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-ROCHESTR_345_NR2

Fri 09/18/2020 to Sat 11/14/2020
0500 Continuous 2330

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

NIAGARA_345KV_3108

Fri 09/18/2020 to Sat 11/14/2020
0500 Continuous 2330

Work scheduled by: NYPA

REV

(Export)

SCH - OH - NY **1500 MW**
Impacts Total Transfer Capability 200 MW
TTC with All Lines In Service 1700 MW

EASTVIEW-SPRNBK_345_W65

Sat 09/19/2020 to Sat 09/19/2020
0001 Continuous 0030

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1870 MW
TTC with All Lines In Service 6220 MW

MILLWOOD-EASTVIEW_345_W82

Sat 09/19/2020 to Sat 09/19/2020
0001 Continuous 0030

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **5985 MW**
Impacts Total Transfer Capability 235 MW
TTC with All Lines In Service 6220 MW

SPRNBK_345KV_RNS4

Sat 09/19/2020 to Sat 09/19/2020
0001 Continuous 0030

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

EASTVIEW-SPRNBK_345_W65

Sat 09/19/2020 to Sat 09/19/2020
0330 Continuous 0400

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1870 MW
TTC with All Lines In Service 6220 MW

MILLWOOD-EASTVIEW_345_W82

Sat 09/19/2020 to Sat 09/19/2020
0330 Continuous 0400

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **5985 MW**
Impacts Total Transfer Capability 235 MW
TTC with All Lines In Service 6220 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,August 04, 2020 to Thursday ,February 03, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Work Scheduled	Work Scheduled by	Impact	TTC
SPRNBKR_345KV_RNS4			
Sat 09/19/2020 0330 to Sat 09/19/2020 0400	Continuous	SPR/DUN-SOUTH	FWD (Import) 3200 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability	1400 MW
		TTC with All Lines In Service	4600 MW
NIAGARA_345KV_3002			
Sat 09/19/2020 0500 to Sat 09/19/2020 2100	Continuous	SCH - OH - NY	FWD (Import) REV (Export) 1300 MW 1150 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	650 MW 550 MW
		TTC with All Lines In Service	1950 MW 1700 MW
NIAGARA_345KV_3022			
Sat 09/19/2020 0500 to Sat 09/19/2020 2100	Continuous	SCH - OH - NY	FWD (Import) REV (Export) 1300 MW 1150 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	650 MW 550 MW
		TTC with All Lines In Service	1950 MW 1700 MW
MILLWOOD_345KV_18			
Sun 09/20/2020 0001 to Sun 09/20/2020 0030	Continuous	UPNY CONED	FWD (Import) 4350 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability	1870 MW
		TTC with All Lines In Service	6220 MW
BUCHAN_S-MILLWOOD_345_W98			
Sun 09/20/2020 0001 to Fri 09/25/2020 0200	Continuous	UPNY CONED	FWD (Import) 6135 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability	85 MW
		TTC with All Lines In Service	6220 MW
NIAGARA_345KV_3102			
Sun 09/20/2020 0500 to Sun 09/20/2020 2100	Continuous	SCH - OH - NY	FWD (Import) REV (Export) 1700 MW 1400 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	250 MW 300 MW
		TTC with All Lines In Service	1950 MW 1700 MW
NIAGARA_345_230_AT4			
Sun 09/20/2020 0500 to Sun 09/20/2020 2100	Continuous	SCH - OH - NY	FWD (Import) REV (Export) 1900 MW 1400 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	50 MW 300 MW
		TTC with All Lines In Service	1950 MW 1700 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,August 04, 2020 to Thursday ,February 03, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>CLAY ___ - EDIC ___ 345_1-16</p> <p>Mon 09/21/2020 to Fri 09/25/2020</p> <p>0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>OSWEGO EXPORT 4850 MW</p> <p>Impacts Total Transfer Capability 400 MW</p> <p>TTC with All Lines In Service 5250 MW</p>
<p>FRASANX-COOPERS ___ 345_UCC2-41</p> <p>Mon 09/21/2020 to Wed 09/30/2020</p> <p>0700 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>EXTENDED by NYPA 07/21/2020</p> <p>CENTRAL EAST - VC 2500 MW</p> <p>Impacts Total Transfer Capability 475 MW</p> <p>TTC with All Lines In Service 2975 MW</p> <p>ARR: 19</p>
<p>MARCY ___ - FRASANX 345_UCC2-41</p> <p>Mon 09/21/2020 to Wed 09/30/2020</p> <p>0700 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>EXTENDED by NYPA 07/21/2020</p> <p>CENTRAL EAST - VC 2500 MW</p> <p>Impacts Total Transfer Capability 475 MW</p> <p>TTC with All Lines In Service 2975 MW</p> <p>ARR: 19</p>
<p>ROSETON ___ - ROCKTVRN 345_311</p> <p>Mon 09/21/2020 to Fri 10/23/2020</p> <p>0800 Continuous 1600</p> <p>Work scheduled by: CHGE</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>UPDATED by CHGE 10/09/2019</p> <p>UPNY CONED 4400 MW</p> <p>Impacts Total Transfer Capability 1820 MW</p> <p>TTC with All Lines In Service 6220 MW</p>
<p>GOETHALS 345KV_5</p> <p>Tue 09/22/2020 to Tue 09/22/2020</p> <p>0200 Continuous 0230</p> <p>Work scheduled by: PJM</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>UPDATED by CE 06/24/2020</p> <p>STATEN ISLAND</p> <p>Impacts Total Transfer Capability</p> <p>TTC with All Lines In Service</p>
<p>LINDEN ___ - GOETHALS 230_A2253</p> <p>Tue 09/22/2020 to Wed 09/23/2020</p> <p>0200 Continuous 2359</p> <p>Work scheduled by: PJM</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">REV</p> <p style="text-align: right;">(Import) (Export)</p> <p>UPDATED by CE 06/24/2020</p> <p>SCH - PJ - NY 2050 MW 1150 MW</p> <p>Impacts Total Transfer Capability 150 MW 100 MW</p> <p>TTC with All Lines In Service 2200 MW 1250 MW</p>
<p>LINDEN ___ - GOETHALS 230_A2253 & HUDSONP ___ - FARRAGUT 345_B3402</p> <p>Tue 09/22/2020 to Wed 09/23/2020</p> <p>0200 Continuous 2359</p> <p>Work scheduled by:</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">REV</p> <p style="text-align: right;">(Import) (Export)</p> <p>UPDATED by CE 06/24/2020</p> <p>SCH - PJ - NY 2000 MW 1000 MW</p> <p>Impacts Total Transfer Capability 200 MW 250 MW</p> <p>TTC with All Lines In Service 2200 MW 1250 MW</p>

NYISO TRANSFER LIMITATIONS

Tuesday ,August 04, 2020 to Thursday ,February 03, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LINDEN__-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402 & MARION__-
FARRAGUT_345_C3403

Tue 09/22/2020 to Wed 09/23/2020
0200 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2000 MW	1000 MW
Impacts Total Transfer Capability	200 MW	250 MW
TTC with All Lines In Service	2200 MW	1250 MW

LINDEN__-GOETHALS_230_A2253 & MARION__-FARRAGUT_345_C3403

Tue 09/22/2020 to Wed 09/23/2020
0200 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2000 MW	1000 MW
Impacts Total Transfer Capability	200 MW	250 MW
TTC with All Lines In Service	2200 MW	1250 MW

ADIRNDCK-CHASLAKE_230_13

Wed 09/23/2020 to Wed 09/23/2020
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2100 MW
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	3150 MW

SCRIBA__-VOLNEY__345_21

Wed 09/23/2020 to Thu 09/24/2020 **UPDATED by NGRID 08/01/2020**
0800 Continuous 1630

Work scheduled by: NGrid

	FWD
	(Import)
OSWEGO EXPORT	5250 MW
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	5250 MW

LINDEN__-GOETHALS_230_A2253

Thu 09/24/2020 to Sat 09/26/2020 **UPDATED by PJM 07/06/2020**
0001 Continuous 0300

Work scheduled by: PJM

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2050 MW	1150 MW
Impacts Total Transfer Capability	150 MW	100 MW
TTC with All Lines In Service	2200 MW	1250 MW

LINDEN__-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402

Thu 09/24/2020 to Sat 09/26/2020
0001 0300

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2000 MW	1000 MW
Impacts Total Transfer Capability	200 MW	250 MW
TTC with All Lines In Service	2200 MW	1250 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,August 04, 2020 to Thursday ,February 03, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LINDEN__-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402 & MARION__-FARRAGUT_345_C3403		FWD	REV
		(Import)	(Export)
Thu 09/24/2020	to Sat 09/26/2020	SCH - PJ - NY	2000 MW 1000 MW
0001	0300	Impacts Total Transfer Capability	200 MW 250 MW
Work scheduled by:		TTC with All Lines In Service	2200 MW 1250 MW

LINDEN__-GOETHALS_230_A2253 & MARION__-FARRAGUT_345_C3403		FWD	REV
		(Import)	(Export)
Thu 09/24/2020	to Sat 09/26/2020	SCH - PJ - NY	2000 MW 1000 MW
0001	0300	Impacts Total Transfer Capability	200 MW 250 MW
Work scheduled by:		TTC with All Lines In Service	2200 MW 1250 MW

W49TH_ST_345KV_5		FWD	
		(Import)	
Fri 09/25/2020	to Sat 09/26/2020	SCH - PJM_HTP	300 MW
0001	Continuous 0300	Impacts Total Transfer Capability	360 MW
Work scheduled by: ConEd		TTC with All Lines In Service	660 MW

W49TH_ST_345KV_7		FWD	
		(Import)	
Fri 09/25/2020	to Sat 09/26/2020	SCH - PJM_HTP	300 MW
0001	Continuous 0300	Impacts Total Transfer Capability	360 MW
Work scheduled by: ConEd		TTC with All Lines In Service	660 MW

MILLWOOD_345KV_18		FWD	
		(Import)	
Fri 09/25/2020	to Fri 09/25/2020	UPNY CONED	4350 MW
0130	Continuous 0200	Impacts Total Transfer Capability	1870 MW
Work scheduled by: ConEd		TTC with All Lines In Service	6220 MW

EASTVIEW-SPRNBK__345_W78		FWD	
		(Import)	
Sat 09/26/2020	to Sun 09/27/2020	UPNY CONED	4350 MW
0001	Continuous 0200	Impacts Total Transfer Capability	1870 MW
Work scheduled by: ConEd		TTC with All Lines In Service	6220 MW

MILLWOOD-EASTVIEW_345_W85		FWD	
		(Import)	
Sat 09/26/2020	to Sun 09/27/2020	UPNY CONED	5985 MW
0001	Continuous 0200	Impacts Total Transfer Capability	235 MW
Work scheduled by: ConEd		TTC with All Lines In Service	6220 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,August 04, 2020 to Thursday ,February 03, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK__345KV_RNS3

FWD

Sat 09/26/2020 to Sun 09/27/2020 UPDATED by CONED 06/16/2020
 0001 Continuous 0200

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

GOETHALS_345KV_5

Sat 09/26/2020 to Sat 09/26/2020 UPDATED by PJM 07/06/2020
 0230 Continuous 0300

Work scheduled by: PJM

STATEN ISLAND
 Impacts Total Transfer Capability
 TTC with All Lines In Service

CRICKVLY-PLSNTVLY_345_F83

FWD

Mon 09/28/2020 to Sun 10/04/2020
 0001 Continuous 2200

(Import)

Work scheduled by: ConEd

SCH - NE - NY **350 MW**
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 1400 MW

CRICKVLY-PLSNTVLY_345_F83

FWD

REV

Mon 09/28/2020 to Sun 10/04/2020
 0001 Continuous 2200

(Import) (Export)

Work scheduled by: ConEd

SCH - NPX_1385 **100 MW** **100 MW**
 Impacts Total Transfer Capability 100 MW 100 MW
 TTC with All Lines In Service 200 MW 200 MW

NRTH1385-NOR HBR__138_601 & CRICKVLY-PLSNTVLY_345_F83

FWD

REV

Mon 09/28/2020 to Sun 10/04/2020
 0500 2200

(Import) (Export)

Work scheduled by:

SCH - NPX_1385 **0 MW** **0 MW**
 Impacts Total Transfer Capability 200 MW 200 MW
 TTC with All Lines In Service 200 MW 200 MW

NRTH1385-NOR HBR__138_602 & CRICKVLY-PLSNTVLY_345_F83

FWD

REV

Mon 09/28/2020 to Sun 10/04/2020
 0500 2200

(Import) (Export)

Work scheduled by:

SCH - NPX_1385 **0 MW** **0 MW**
 Impacts Total Transfer Capability 200 MW 200 MW
 TTC with All Lines In Service 200 MW 200 MW

NRTH1385-NOR HBR__138_603 & CRICKVLY-PLSNTVLY_345_F83

FWD

REV

Mon 09/28/2020 to Sun 10/04/2020
 0500 2200

(Import) (Export)

Work scheduled by:

SCH - NPX_1385 **0 MW** **0 MW**
 Impacts Total Transfer Capability 200 MW 200 MW
 TTC with All Lines In Service 200 MW 200 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,August 04, 2020 to Thursday ,February 03, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
NRTH1385-NOR HBR__138_601							
Mon 09/28/2020	to	Sat 10/17/2020	<u>UPDATED</u>	<u>by LIPA</u>	<u>07/10/2020</u>		
0500	Continuous	2359				SCH - NPX_1385	100 MW
Work scheduled by: LI						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_602							
Mon 09/28/2020	to	Sat 10/17/2020				SCH - NPX_1385	0 MW
0500		2359				Impacts Total Transfer Capability	200 MW
Work scheduled by:						TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_603							
Mon 09/28/2020	to	Sat 10/17/2020				SCH - NPX_1385	0 MW
0500		2359				Impacts Total Transfer Capability	200 MW
Work scheduled by:						TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR__138_602							
Mon 09/28/2020	to	Sat 10/17/2020	<u>UPDATED</u>	<u>by LIPA</u>	<u>07/10/2020</u>		
0500	Continuous	2359				SCH - NPX_1385	100 MW
Work scheduled by: LI						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR__138_602 & NRTH1385-NOR HBR__138_603							
Mon 09/28/2020	to	Sat 10/17/2020				SCH - NPX_1385	0 MW
0500		2359				Impacts Total Transfer Capability	200 MW
Work scheduled by:						TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR__138_603							
Mon 09/28/2020	to	Sat 10/17/2020	<u>UPDATED</u>	<u>by LIPA</u>	<u>07/10/2020</u>		
0500	Continuous	2359				SCH - NPX_1385	100 MW
Work scheduled by: LI						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
NRTH1385-NRTHPORT_138_NNC							
Mon 09/28/2020	to	Sat 10/17/2020	<u>UPDATED</u>	<u>by LIPA</u>	<u>07/10/2020</u>		
0500	Continuous	2359				SCH - NPX_1385	0 MW
Work scheduled by: LI						Impacts Total Transfer Capability	200 MW
						TTC with All Lines In Service	200 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,August 04, 2020 to Thursday ,February 03, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>CLAY -EDIC 345_2-15</p> <p>Mon 09/28/2020 to Fri 10/02/2020</p> <p>0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>OSWEGO EXPORT 4850 MW</p> <p>Impacts Total Transfer Capability 400 MW</p> <p>TTC with All Lines In Service 5250 MW</p>
<p>MOTTHAVN-RAINEY 345_Q11</p> <p>Thu 10/01/2020 to Thu 11/05/2020 UPDATED by CONED 12/17/2019</p> <p>0001 Continuous 0200</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>SPR/DUN-SOUTH 3800 MW</p> <p>Impacts Total Transfer Capability 800 MW</p> <p>TTC with All Lines In Service 4600 MW</p>
<p>EDIC -FRASER 345_EF24-40</p> <p>Thu 10/01/2020 to Fri 10/02/2020</p> <p>0700 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC 2500 MW</p> <p>Impacts Total Transfer Capability 475 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p>HUDSONTP-W49TH_ST_345_Y56</p> <p>Fri 10/02/2020 to Thu 10/08/2020</p> <p>0001 Continuous 0300</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>SCH - PJM_HTP 0 MW</p> <p>Impacts Total Transfer Capability 660 MW</p> <p>TTC with All Lines In Service 660 MW</p>
<p>W49TH_ST_345KV_7</p> <p>Fri 10/02/2020 to Thu 10/08/2020</p> <p>0001 Continuous 0300</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>SCH - PJM_HTP 300 MW</p> <p>Impacts Total Transfer Capability 360 MW</p> <p>TTC with All Lines In Service 660 MW</p>
<p>W49TH_ST_345KV_8</p> <p>Fri 10/02/2020 to Thu 10/08/2020</p> <p>0001 Continuous 0300</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>SCH - PJM_HTP 450 MW</p> <p>Impacts Total Transfer Capability 210 MW</p> <p>TTC with All Lines In Service 660 MW</p>
<p>PANNELL -CLAY 345_1</p> <p>Mon 10/05/2020 to Fri 10/09/2020 UPDATED by NYPA 05/07/2020</p> <p>0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>WEST CENTRAL 1300 MW</p> <p>Impacts Total Transfer Capability 950 MW</p> <p>TTC with All Lines In Service 2250 MW</p>

NYISO TRANSFER LIMITATIONS

Tuesday ,August 04, 2020 to Thursday ,February 03, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						FWD
DUNWODIE-MOTTHAVN_345_71						(Import)
Wed 10/07/2020	to	Thu 10/08/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>07/22/2020</u>	
0001	Continuous	0100				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	3800 MW
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<hr/>						
DUNWODIE_345KV_5						FWD
						(Import)
Wed 10/07/2020	to	Thu 10/08/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>07/22/2020</u>	
0001	Continuous	0100				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	3800 MW
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<hr/>						
DUNWODIE_345KV_3						FWD
						(Import)
Wed 10/07/2020	to	Thu 11/12/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>07/22/2020</u>	
0001	Continuous	0100				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	3800 MW
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<hr/>						
DUNWODIE_345KV_4						FWD
						(Import)
Wed 10/07/2020	to	Thu 11/12/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>07/22/2020</u>	
0001	Continuous	0100				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	3800 MW
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<hr/>						
PLSNTVLE-DUNWODIE_345_W89						FWD
						(Import)
Wed 10/07/2020	to	Thu 11/12/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>07/22/2020</u>	
0001	Continuous	0100				4000 MW
Work scheduled by: ConEd					UPNY CONED	4000 MW
					Impacts Total Transfer Capability	2220 MW
					TTC with All Lines In Service	6220 MW
<hr/>						
SAND_BAR-PLATSBRG_115_PV20						
Sat 10/17/2020	to	Sat 11/14/2020				
0600	Continuous	1800				
Work scheduled by: ISONE					SCH - NE - NY	
					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
<hr/>						
ROCHESTR-PANNELL_345_RP1						FWD
						(Import)
Mon 10/19/2020	to	Fri 10/23/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>03/10/2020</u>	
0500	Continuous	1700				2300 MW
Work scheduled by: NYPA					DYSINGER EAST	2300 MW
					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,August 04, 2020 to Thursday ,February 03, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
SCH-NE-NYISO_LIMIT_600						(Import)	
Mon 10/19/2020	to	Sat 10/31/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>06/05/2020</u>	SCH - NE - NY	800 MW
0630	Continuous	2359				Impacts Total Transfer Capability	600 MW
Work scheduled by: NGrid						TTC with All Lines In Service	1400 MW
SCH-NYISO-NE_LIMIT_800						(Export)	
Mon 10/19/2020	to	Sat 10/31/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>06/05/2020</u>	SCH - NE - NY	1000 MW
0630	Continuous	2359				Impacts Total Transfer Capability	600 MW
Work scheduled by: NGrid						TTC with All Lines In Service	1600 MW
BERKSHIR-ALPS_____345_393						(Import)	(Export)
Mon 10/19/2020	to	Tue 11/10/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>06/05/2020</u>	SCH - NE - NY	950 MW 1300 MW
0630	Continuous	1630				Impacts Total Transfer Capability	450 MW 300 MW
Work scheduled by: NGrid						TTC with All Lines In Service	1400 MW 1600 MW
							ARR: 78
BERKSHIR-ALPS_____345_393						(Import)	(Export)
Mon 10/19/2020	to	Tue 11/10/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>06/05/2020</u>	SCH - NPX_1385	100 MW 100 MW
0630	Continuous	1630				Impacts Total Transfer Capability	100 MW 100 MW
Work scheduled by: NGrid						TTC with All Lines In Service	200 MW 200 MW
							ARR: 78
BERKSHIR-ALPS_____345_393 & BERKSHIR-NORTHFLD_345_312						(Import)	(Export)
Mon 10/19/2020	to	Tue 11/10/2020				SCH - NE - NY	950 MW 1300 MW
0630		1630				Impacts Total Transfer Capability	450 MW 300 MW
Work scheduled by:						TTC with All Lines In Service	1400 MW 1600 MW
							ARR: 78
BERKSHIR-NORTHFLD_345_312						(Import)	(Export)
Mon 10/19/2020	to	Tue 11/10/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>06/05/2020</u>	SCH - NE - NY	900 MW 1500 MW
0630	Continuous	1630				Impacts Total Transfer Capability	500 MW 100 MW
Work scheduled by: NGrid						TTC with All Lines In Service	1400 MW 1600 MW
BERKSHIR-NORTHFLD_345_312						(Import)	(Export)
Mon 10/19/2020	to	Tue 11/10/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>06/05/2020</u>	SCH - NPX_1385	100 MW 100 MW
0630	Continuous	1630				Impacts Total Transfer Capability	100 MW 100 MW
Work scheduled by: NGrid						TTC with All Lines In Service	200 MW 200 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,August 04, 2020 to Thursday ,February 03, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
SHOR_NPX-SHOREHAM_138_CSC							
Mon 10/19/2020	to	Fri 10/23/2020	<u>UPDATED</u>	<u>by LI</u>	<u>03/02/2020</u>		
0700	Continuous	1500				0 MW	0 MW
Work scheduled by: LI						Impacts Total Transfer Capability	330 MW
						TTC with All Lines In Service	330 MW
PANNELL -CLAY_345_2						FWD	
Mon 10/19/2020	to	Fri 10/23/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/07/2020</u>		
0700	Continuous	1530				1300 MW	
Work scheduled by: NYPA						Impacts Total Transfer Capability	950 MW
						TTC with All Lines In Service	2250 MW
COOPERS -DOLSONAV_345_CCDA42						FWD	
Mon 10/19/2020	to	Fri 11/06/2020					
0700	Continuous	1730				2720 MW	
Work scheduled by: NYPA						Impacts Total Transfer Capability	255 MW
						TTC with All Lines In Service	2975 MW
SPRNBRK -TREMONT_345_X28						FWD	
Mon 10/26/2020	to	Mon 10/26/2020					
0001	Continuous	0030				4200 MW	
Work scheduled by: ConEd						Impacts Total Transfer Capability	400 MW
						TTC with All Lines In Service	4600 MW
LEEDS_345_LEEDS SVC						FWD	
Mon 10/26/2020	to	Fri 10/30/2020					
0800	Continuous	1600				2950 MW	
Work scheduled by: NGrid						Impacts Total Transfer Capability	25 MW
						TTC with All Lines In Service	2975 MW
LEEDS -HURLYAVE_345_301						FWD	
Mon 10/26/2020	to	Fri 12/04/2020					
0800	Continuous	1600				4100 MW	
Work scheduled by: CHGE						Impacts Total Transfer Capability	2120 MW
						TTC with All Lines In Service	6220 MW
DUNWODIE_345KV_6						FWD	
Sun 11/01/2020	to	Sun 11/01/2020	<u>CANCELLED</u>	<u>by ConEd</u>	<u>08/04/2020</u>		
0001	Continuous	0030				3800 MW	
Work scheduled by: ConEd						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,August 04, 2020 to Thursday ,February 03, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					FWD
SCH-NE-NYISO_LIMIT_800					(Import)
Sun 11/01/2020	to	Tue 11/10/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>06/05/2020</u>
0001	Continuous	1630			
Work scheduled by: NGrid					SCH - NE - NY 1000 MW
					Impacts Total Transfer Capability 400 MW
					TTC with All Lines In Service 1400 MW
<hr/>					
SCH-NYISO-NE_LIMIT_700					REV
					(Export)
Sun 11/01/2020	to	Tue 11/10/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>06/05/2020</u>
0001	Continuous	1630			
Work scheduled by: NGrid					SCH - NE - NY 900 MW
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 1700 MW
<hr/>					
DUNWODIE-SHORE_RD_345_Y50					FWD
					(Import)
Sun 11/01/2020	to	Wed 11/11/2020	<u>CANCELLED</u>	<u>by ConEd</u>	<u>08/04/2020</u>
0001	Continuous	0200			
Work scheduled by: ConEd					CONED - LIPA 800 MW
					Impacts Total Transfer Capability 700 MW
					TTC with All Lines In Service 1500 MW
<hr/>					
SHORE_RD_345_138_BK_1					FWD
					(Import)
Sun 11/01/2020	to	Wed 11/11/2020	<u>CANCELLED</u>	<u>by ConEd</u>	<u>08/04/2020</u>
0001	Continuous	0200			
Work scheduled by: ConEd					CONED - LIPA 1350 MW
					Impacts Total Transfer Capability 150 MW
					TTC with All Lines In Service 1500 MW
<hr/>					
SHORE_RD_345_138_BK_2					FWD
					(Import)
Sun 11/01/2020	to	Wed 11/11/2020	<u>CANCELLED</u>	<u>by ConEd</u>	<u>08/04/2020</u>
0001	Continuous	0200			
Work scheduled by: ConEd					CONED - LIPA 1350 MW
					Impacts Total Transfer Capability 150 MW
					TTC with All Lines In Service 1500 MW
<hr/>					
SCH-IMO-NYISO_LIMIT_1750					FWD
					(Import)
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>
0001	Continuous	2359			
Work scheduled by: IESO					SCH - OH - NY 2050 MW
					Impacts Total Transfer Capability 0 MW
					TTC with All Lines In Service 2050 MW
<hr/>					
SCH-NYISO-IMO_LIMIT_1600					REV
					(Export)
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>
0001	Continuous	2359			
Work scheduled by: IESO					SCH - OH - NY 1900 MW
					Impacts Total Transfer Capability 0 MW
					TTC with All Lines In Service 1900 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,August 04, 2020 to Thursday ,February 03, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA__345KV_3002

Thu 11/05/2020 to Thu 11/05/2020
 0500 Continuous 2100
 Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	1550 MW	1400 MW
Impacts Total Transfer Capability	500 MW	500 MW
TTC with All Lines In Service	2050 MW	1900 MW

NIAGARA__345KV_3022

Thu 11/05/2020 to Thu 11/05/2020
 0500 Continuous 2100
 Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	1550 MW	1400 MW
Impacts Total Transfer Capability	500 MW	500 MW
TTC with All Lines In Service	2050 MW	1900 MW

SPRNBRK_-TREMONT__345_X28

Fri 11/06/2020 to Sat 11/07/2020
 0001 Continuous 0059
 Work scheduled by: ConEd

	FWD
	(Import)
SPR/DUN-SOUTH	4200 MW
Impacts Total Transfer Capability	400 MW
TTC with All Lines In Service	4600 MW

NIAGARA__345KV_3102

Fri 11/06/2020 to Fri 11/06/2020
 0500 Continuous 2100
 Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	2000 MW	1700 MW
Impacts Total Transfer Capability	50 MW	200 MW
TTC with All Lines In Service	2050 MW	1900 MW

NIAGARA__345_230_AT4

Fri 11/06/2020 to Fri 11/06/2020
 0500 Continuous 2100
 Work scheduled by: NYPA

		REV
		(Export)
SCH - OH - NY		1750 MW
Impacts Total Transfer Capability		150 MW
TTC with All Lines In Service		1900 MW

SPRNBRK_-TREMONT__345_X28

Mon 11/09/2020 to Mon 11/09/2020
 0030 Continuous 0059
 Work scheduled by: ConEd

	FWD
	(Import)
SPR/DUN-SOUTH	4200 MW
Impacts Total Transfer Capability	400 MW
TTC with All Lines In Service	4600 MW

DUNWODIE-MOTTHAVN_345_71

Tue 11/10/2020 to Thu 11/12/2020 **UPDATED by CONED 07/22/2020**
 0001 Continuous 0100
 Work scheduled by: ConEd

	FWD
	(Import)
SPR/DUN-SOUTH	3800 MW
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,August 04, 2020 to Thursday ,February 03, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_5				FWD	
Tue 11/10/2020	to	Thu 11/12/2020	UPDATED	by CONED	07/22/2020
0001	Continuous	0100			
Work scheduled by: ConEd				SPR/DUN-SOUTH	3800 MW
				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_6				FWD	
Wed 11/11/2020	to	Wed 11/11/2020	CANCELLED	by ConEd	08/04/2020
0130	Continuous	0200			
Work scheduled by: ConEd				SPR/DUN-SOUTH	3800 MW
				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
CHATGUAY-MASSENA_765_7040				FWD	
Sun 11/15/2020	to	Mon 11/30/2020			
0100	Continuous	1900			
Work scheduled by: NYPA				MOSES SOUTH	1550 MW
				Impacts Total Transfer Capability	1600 MW
				TTC with All Lines In Service	3150 MW
CHATGUAY-MASSENA_765_7040				FWD	REV
Sun 11/15/2020	to	Mon 11/30/2020			
0100	Continuous	1900			
Work scheduled by: NYPA				SCH - HQ - NY	0 MW 0 MW
				Impacts Total Transfer Capability	1500 MW 1000 MW
				TTC with All Lines In Service	1500 MW 1000 MW
MARCY___765_345_AT1				FWD	
Sun 11/15/2020	to	Mon 11/30/2020			
0100	Continuous	1900			
Work scheduled by: NYPA				MOSES SOUTH	1750 MW
				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	3150 MW
					ARR: 19
MARCY___765_345_AT2				FWD	
Sun 11/15/2020	to	Mon 11/30/2020			
0100	Continuous	1900			
Work scheduled by: NYPA				MOSES SOUTH	1700 MW
				Impacts Total Transfer Capability	1450 MW
				TTC with All Lines In Service	3150 MW
					ARR: 19
MASSENA_-MARCY___765_MSU1				FWD	
Sun 11/15/2020	to	Mon 11/30/2020			
0100	Continuous	1900			
Work scheduled by: NYPA				CENTRAL EAST - VC	2265 MW
				Impacts Total Transfer Capability	710 MW
				TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,August 04, 2020 to Thursday ,February 03, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Transfer Description	Start Date	End Date	Time	Day	Transfer Type	Impact	TTC
MASSENA -MARCY 765_MSU1	Sun 11/15/2020	Mon 11/30/2020	0100	Continuous	FWD (Import)	MOSES SOUTH	500 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability		2650 MW
					TTC with All Lines In Service		3150 MW
MASSENA -MARCY 765_MSU1	Sun 11/15/2020	Mon 11/30/2020	0100	Continuous	FWD (Import)	SCH - HQ - NY	475 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability		1025 MW
					TTC with All Lines In Service		1500 MW
					REV (Export)		1000 MW
MASSENA -MARCY 765_MSU1	Sun 11/15/2020	Mon 11/30/2020	0100	Continuous	FWD (Import)	SCH - HQ_CEDARS	90 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability		109 MW
					TTC with All Lines In Service		199 MW
MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040	Sun 11/15/2020	Mon 11/30/2020	0100	Continuous	FWD (Import)	MOSES SOUTH	500 MW
Work scheduled by:					Impacts Total Transfer Capability		2650 MW
					TTC with All Lines In Service		3150 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2	Sun 11/15/2020	Mon 11/30/2020	0100	Continuous	FWD (Import)	SCH - HQ - NY	850 MW
Work scheduled by:					Impacts Total Transfer Capability		650 MW
					TTC with All Lines In Service		1500 MW
					REV (Export)		1000 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2	Sun 11/15/2020	Mon 11/30/2020	0100	Continuous	FWD (Import)	SCH - HQ_CEDARS	90 MW
Work scheduled by:					Impacts Total Transfer Capability		109 MW
					TTC with All Lines In Service		199 MW
STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1	Sun 11/15/2020	Mon 11/30/2020	0100	Continuous	FWD (Import)	SCH - HQ_CEDARS	90 MW
Work scheduled by:					Impacts Total Transfer Capability		109 MW
					TTC with All Lines In Service		199 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,August 04, 2020 to Thursday ,February 03, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STLAWRNC-MOSES___230_L33P & MOSES___-MASSENA_230_MMS1 & MOSES___-		FWD
MASSENA_230_MMS2		(Import)
Sun 11/15/2020	to Mon 11/30/2020	SCH - HQ_CEDARS 90 MW
0100	1900	Impacts Total Transfer Capability 109 MW
Work scheduled by:		TTC with All Lines In Service 199 MW
-----		-----
PLSNTVLY-WOOD_ST__345_F30		FWD
		(Import)
Mon 11/16/2020	to Mon 11/16/2020	UPNY CONED 4000 MW
0001	Continuous 0030	Impacts Total Transfer Capability 2220 MW
Work scheduled by: ConEd		TTC with All Lines In Service 6220 MW
-----		-----
PLSNTVLY_345KV_RNS5		FWD
		(Import)
Mon 11/16/2020	to Mon 11/16/2020	UPNY CONED 3800 MW
0001	Continuous 0030	Impacts Total Transfer Capability 2420 MW
Work scheduled by: ConEd		TTC with All Lines In Service 6220 MW
-----		-----
MILLWOOD_345KV_18		FWD
		(Import)
Mon 11/16/2020	to Tue 11/17/2020	UPNY CONED 4350 MW
0001	Continuous 0200	Impacts Total Transfer Capability 1870 MW
Work scheduled by: ConEd		TTC with All Lines In Service 6220 MW
-----		-----
PLSNTVLY-WOOD_ST__345_F30		FWD
		(Import)
Tue 11/17/2020	to Tue 11/17/2020	UPNY CONED 4000 MW
0130	Continuous 0200	Impacts Total Transfer Capability 2220 MW
Work scheduled by: ConEd		TTC with All Lines In Service 6220 MW
-----		-----
PLSNTVLY_345KV_RNS5		FWD
		(Import)
Tue 11/17/2020	to Tue 11/17/2020	UPNY CONED 3800 MW
0130	Continuous 0200	Impacts Total Transfer Capability 2420 MW
Work scheduled by: ConEd		TTC with All Lines In Service 6220 MW
-----		-----
NEPTUNE_-DUFFYAVE_345_NEPTUNE		FWD
		(Import)
Mon 11/30/2020	to Sun 12/20/2020	SCH - PJM_NEPTUNE 0 MW
0600	Continuous 1600	Impacts Total Transfer Capability 660 MW
Work scheduled by: PJM		TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,August 04, 2020 to Thursday ,February 03, 2022

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE-DUFFYAVE_345_501

Mon 11/30/2020 to Sun 12/20/2020
0600 Continuous 1600

Work scheduled by: PJM

UPDATED by LI 04/29/2020

SCH - PJM_NEPTUNE
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

FWD
(Import)

0 MW

MARCY_345KV_CSC

Tue 12/01/2020 to Fri 12/11/2020
0700 Continuous 1730

Work scheduled by: NYPA

CENTRAL EAST - VC
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

FWD
(Import)

2925 MW

MOSES-ADIRNDCK_230_MA1

Tue 12/01/2020 to Sat 02/27/2021
0700 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 07/27/2020

MOSES SOUTH
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

FWD
(Import)

2300 MW

KINTIGH-ROCHESTR_345_SR1-39

Thu 12/03/2020 to Tue 12/15/2020
0800 Continuous 1900

Work scheduled by: RGE

UPDATED by NYISO 06/24/2020

DYSINGER EAST
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

FWD
(Import)

1700 MW

NIAGARA-KINTIGH_345_NS1-38

Thu 12/03/2020 to Tue 12/15/2020
0800 Continuous 1900

Work scheduled by: RGE

UPDATED by NYISO 06/24/2020

DYSINGER EAST
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

FWD
(Import)

1700 MW

BECK-PACKARD_230_BP76

Fri 12/04/2020 to Fri 12/04/2020
0730 Daily(No Weekends) 1530

Work scheduled by: NGrid

SCH - OH - NY
Impacts Total Transfer Capability 400 MW 500 MW
TTC with All Lines In Service 2050 MW 1900 MW

FWD REV
(Import) (Export)

1650 MW 1400 MW

SAND_BAR-PLATSBRG_115_PV20

Mon 12/07/2020 to Fri 12/11/2020
0700 Continuous 1530

Work scheduled by: NYPA

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Tuesday ,August 04, 2020 to Thursday ,February 03, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_6

Tue 12/08/2020 to Tue 12/08/2020
 0301 Continuous 0330
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

E13THSTA-FARRAGUT_345_46

Tue 12/08/2020 to Fri 12/11/2020
 0301 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

W49TH_ST-E13THSTA_345_M55

Tue 12/08/2020 to Fri 12/11/2020
 0301 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

LONG_MTN-CRICKVLY_345_398

Tue 12/08/2020 to Thu 12/10/2020
 0700 Continuous 1600
 Work scheduled by: ISONE

FWD REV
 (Import) (Export)
 SCH - NE - NY **700 MW 1300 MW**
 Impacts Total Transfer Capability 700 MW 400 MW
 TTC with All Lines In Service 1400 MW 1700 MW

LONG_MTN-CRICKVLY_345_398

Tue 12/08/2020 to Thu 12/10/2020
 0700 Continuous 1600
 Work scheduled by: ISONE

FWD REV
 (Import) (Export)
 SCH - NPX_1385 **100 MW 100 MW**
 Impacts Total Transfer Capability 100 MW 100 MW
 TTC with All Lines In Service 200 MW 200 MW

SCH-NE-NYISO_LIMIT_400

Tue 12/08/2020 to Thu 12/10/2020
 0700 Continuous 1600
 Work scheduled by: ISONE

FWD
 (Import)
 SCH - NE - NY **600 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 1400 MW

SCH-NYISO-NE_LIMIT_1000

Tue 12/08/2020 to Thu 12/10/2020
 0700 Continuous 1600
 Work scheduled by: ISONE

REV
 (Export)
 SCH - NE - NY **1200 MW**
 Impacts Total Transfer Capability 500 MW
 TTC with All Lines In Service 1700 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,August 04, 2020 to Thursday ,February 03, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>W49TH_ST_345KV_6</p> <p>Fri 12/11/2020 to Fri 12/11/2020</p> <p>0230 Continuous 0300</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>SCH - PJM_HTP 300 MW</p> <p>Impacts Total Transfer Capability 360 MW</p> <p>TTC with All Lines In Service 660 MW</p>
<p>MARCY -EDIC 345 UE1-7</p> <p>Mon 12/14/2020 to Mon 12/14/2020</p> <p>0700 Continuous 1730</p> <p>Work scheduled by: NYPA</p> <p style="text-align: right;">ARR: 19&16</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>OSWEGO EXPORT 5250 MW</p> <p>Impacts Total Transfer Capability 0 MW</p> <p>TTC with All Lines In Service 5250 MW</p>
<p>SAND_BAR-PLATSBURG_115_PV20</p> <p>Mon 12/14/2020 to Fri 12/18/2020</p> <p>0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p>SCH - NE - NY</p> <p>Impacts Total Transfer Capability</p> <p>TTC with All Lines In Service</p>
<p>LADENTWN-BUCHAN_S_345_Y88</p> <p>Tue 12/15/2020 to Sat 01/30/2021</p> <p>0001 Continuous 0300</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>UPNY CONED 5930 MW</p> <p>Impacts Total Transfer Capability 290 MW</p> <p>TTC with All Lines In Service 6220 MW</p>
<p>FRASANNX-COOPERS_345_UCC2-41</p> <p>Tue 12/15/2020 to Wed 12/16/2020</p> <p>0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p> <p style="text-align: right;">ARR: 19</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>CENTRAL EAST - VC 2500 MW</p> <p>Impacts Total Transfer Capability 475 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p>MARCY -FRASANNX_345_UCC2-41</p> <p>Tue 12/15/2020 to Wed 12/16/2020</p> <p>0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p> <p style="text-align: right;">ARR: 19</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>CENTRAL EAST - VC 2500 MW</p> <p>Impacts Total Transfer Capability 475 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p>HOPATCON-RAMAPO_500_5018</p> <p>Mon 02/01/2021 to Wed 02/03/2021</p> <p>0001 Continuous 2200</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD REV</p> <p style="text-align: right;">(Import) (Export)</p> <p>SCH - PJ - NY 1250 MW 1200 MW</p> <p>Impacts Total Transfer Capability 1650 MW 650 MW</p> <p>TTC with All Lines In Service 2900 MW 1850 MW</p>

NYISO TRANSFER LIMITATIONS

Tuesday ,August 04, 2020 to Thursday ,February 03, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HOPATCON-RAMAPO___500_5018			FWD
Mon 02/01/2021	to	Wed 02/03/2021	(Import)
0001	Continuous	2200	UPNY CONED 6025 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 195 MW
			TTC with All Lines In Service 6220 MW
RAMAPO___345_345_PAR3500			FWD REV
Mon 02/01/2021	to	Wed 02/03/2021	(Import) (Export)
0001	Continuous	2200	SCH - PJ - NY 2150 MW 1250 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 750 MW 600 MW
			TTC with All Lines In Service 2900 MW 1850 MW
RAMAPO___345_345_PAR4500			FWD REV
Mon 02/01/2021	to	Wed 02/03/2021	(Import) (Export)
0001	Continuous	2200	SCH - PJ - NY 2150 MW 1250 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 750 MW 600 MW
			TTC with All Lines In Service 2900 MW 1850 MW
RAMAPO___500_345_BK 1500			FWD REV
Mon 02/01/2021	to	Wed 02/03/2021	(Import) (Export)
0001	Continuous	2200	SCH - PJ - NY 1250 MW 1200 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 1650 MW 650 MW
			TTC with All Lines In Service 2900 MW 1850 MW
RAMAPO___500_345_BK 1500			FWD
Mon 02/01/2021	to	Wed 02/03/2021	(Import)
0001	Continuous	2200	UPNY CONED 6025 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 195 MW
			TTC with All Lines In Service 6220 MW
PLSNTVLY-WOOD_ST__345_F30			FWD
Mon 02/15/2021	to	Tue 02/16/2021	(Import)
0001	Continuous	0200	UPNY CONED 4000 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 2220 MW
			TTC with All Lines In Service 6220 MW
PLSNTVLY_345KV_RNS5			FWD
Mon 02/15/2021	to	Tue 02/16/2021	(Import)
0001	Continuous	0200	UPNY CONED 3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 2420 MW
			TTC with All Lines In Service 6220 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,August 04, 2020 to Thursday ,February 03, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EFISHKIL-WOOD_ST__345_F39					FWD
Thu 02/18/2021	to	Sat 02/20/2021	<u>UPDATED</u>	<u>by CE</u>	(Import)
2100	Continuous	0200		<u>04/01/2020</u>	UPNY CONED 4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 2220 MW
					TTC with All Lines In Service 6220 MW
WOOD_ST_-PLSNTVLE_345_Y87					FWD
Thu 02/18/2021	to	Sat 02/20/2021	<u>UPDATED</u>	<u>by CE</u>	(Import)
2100	Continuous	0200		<u>04/01/2020</u>	UPNY CONED 5905 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 315 MW
					TTC with All Lines In Service 6220 MW
CHATGUAY-MASSENA__765_7040					FWD
Sun 02/28/2021	to	Mon 03/01/2021			(Import)
0500	Continuous	1730			MOSES SOUTH 1550 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 1600 MW
					TTC with All Lines In Service 3150 MW
CHATGUAY-MASSENA__765_7040					FWD
Sun 02/28/2021	to	Mon 03/01/2021			REV (Export)
0500	Continuous	1730			SCH - HQ - NY 0 MW 0 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 1500 MW 1000 MW
					TTC with All Lines In Service 1500 MW 1000 MW
MASSENA_-MARCY___765_MSU1					FWD
Sun 02/28/2021	to	Mon 03/01/2021			(Import)
0500	Continuous	1730			CENTRAL EAST - VC 2265 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 710 MW
					TTC with All Lines In Service 2975 MW
MASSENA_-MARCY___765_MSU1					FWD
Sun 02/28/2021	to	Mon 03/01/2021			(Import)
0500	Continuous	1730			MOSES SOUTH 500 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 2650 MW
					TTC with All Lines In Service 3150 MW
MASSENA_-MARCY___765_MSU1					FWD
Sun 02/28/2021	to	Mon 03/01/2021			REV (Export)
0500	Continuous	1730			SCH - HQ - NY 475 MW 1000 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 1025 MW 0 MW
					TTC with All Lines In Service 1500 MW 1000 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,August 04, 2020 to Thursday ,February 03, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA_-MARCY___765_MSU1

Sun 02/28/2021 to Mon 03/01/2021
0500 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
SCH - HQ_CEDARS **90 MW**
Impacts Total Transfer Capability 109 MW
TTC with All Lines In Service 199 MW

MASSENA_-MARCY___765_MSU1 & CHATGUAY-MASSENA_765_7040

Sun 02/28/2021 to Mon 03/01/2021
0500 1730

Work scheduled by:

FWD
(Import)
MOSES SOUTH **500 MW**
Impacts Total Transfer Capability 2650 MW
TTC with All Lines In Service 3150 MW

STLAWRNC-MOSES___230_L33P & MASSENA_-MARCY___765_MSU1

Sun 02/28/2021 to Mon 03/01/2021
0500 1730

Work scheduled by:

FWD
(Import)
SCH - HQ_CEDARS **90 MW**
Impacts Total Transfer Capability 109 MW
TTC with All Lines In Service 199 MW

DUNWODIE_345KV_3

Mon 03/01/2021 to Mon 03/01/2021
0001 Continuous 0030

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_5

Mon 03/01/2021 to Mon 03/01/2021
0001 Continuous 0030

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

EASTVIEW-SPRNBK___345_W64

Mon 03/01/2021 to Mon 03/01/2021 **UPDATED by CONED 01/23/2020**
0001 Continuous 0030

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1870 MW
TTC with All Lines In Service 6220 MW

SPRNBK___345KV_RNS5

Mon 03/01/2021 to Mon 03/01/2021 **UPDATED by CONED 01/23/2020**
0001 Continuous 0030

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,August 04, 2020 to Thursday ,February 03, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD-EASTVIEW_345_W99					FWD	
Mon 03/01/2021	to	Mon 03/22/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>01/23/2020</u>	(Import)
0001	Continuous	0200				UPNY CONED 5985 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	235 MW
					TTC with All Lines In Service	6220 MW
DUNWODIE-MOTTHAVN_345_71					FWD	
Mon 03/01/2021	to	Mon 04/05/2021				(Import)
0001	Continuous	0300				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
MOTTHAVN-RAINEY___345_Q11					FWD	
Mon 03/01/2021	to	Tue 04/06/2021				(Import)
0001	Continuous	0700				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
MOSES___-ADIRNDCK_230_MA1					FWD	
Tue 03/02/2021	to	Mon 05/31/2021				(Import)
0700	Continuous	1300				MOSES SOUTH 2300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
NIAGARA_-ROBNSNRD_230_64					REV	
Fri 03/12/2021	to	Fri 03/12/2021				(Export)
0500	Continuous	1700				SCH - OH - NY 1900 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	1900 MW
MARCY___345KV_CSC					FWD	
Sat 03/13/2021	to	Sat 03/13/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>07/29/2020</u>	(Import)
0700	Continuous	1730				CENTRAL EAST - VC 2925 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	2975 MW
EASTVIEW-SPRNBK__345_W64					FWD	
Mon 03/22/2021	to	Mon 03/22/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>01/23/2020</u>	(Import)
0130	Continuous	0200				UPNY CONED 4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1870 MW
					TTC with All Lines In Service	6220 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,August 04, 2020 to Thursday ,February 03, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK	Zone	Start	End	Work by	Update	Impact	TTC	FWD	REV
SPRNBRK__345KV_RNS5								FWD	
Mon 03/22/2021	to	Mon 03/22/2021			<u>UPDATED</u> <u>by CONED</u> <u>01/23/2020</u>			(Import)	
0130	Continuous	0200				SPR/DUN-SOUTH		3200 MW	
Work scheduled by: ConEd						Impacts Total Transfer Capability		1400 MW	
						TTC with All Lines In Service		4600 MW	
CLAY__-EDIC__345_2-15								FWD	
Mon 03/29/2021	to	Fri 04/16/2021						(Import)	
0800	Continuous	1730				OSWEGO EXPORT		4850 MW	
Work scheduled by: NYPA						Impacts Total Transfer Capability		400 MW	
						TTC with All Lines In Service		5250 MW	
ROCHESTR-PANNELL__345_RP2								FWD	
Wed 03/31/2021	to	Mon 04/12/2021						(Import)	
0500	Continuous	1700				DYSINGER EAST		2300 MW	
Work scheduled by: NYPA						Impacts Total Transfer Capability		850 MW	
						TTC with All Lines In Service		3150 MW	
DUNWODIE_345KV_3								FWD	
Mon 04/05/2021	to	Mon 04/05/2021						(Import)	
0230	Continuous	0300				SPR/DUN-SOUTH		3800 MW	
Work scheduled by: ConEd						Impacts Total Transfer Capability		800 MW	
						TTC with All Lines In Service		4600 MW	
DUNWODIE_345KV_5								FWD	
Mon 04/05/2021	to	Mon 04/05/2021						(Import)	
0230	Continuous	0300				SPR/DUN-SOUTH		3800 MW	
Work scheduled by: ConEd						Impacts Total Transfer Capability		800 MW	
						TTC with All Lines In Service		4600 MW	
SPRNBRK_-TREMONT__345_X28								FWD	
Mon 04/19/2021	to	Tue 04/20/2021						(Import)	
0001	Continuous	0200				SPR/DUN-SOUTH		4200 MW	
Work scheduled by: ConEd						Impacts Total Transfer Capability		400 MW	
						TTC with All Lines In Service		4600 MW	
NIAGARA__345KV_3002								FWD	REV
Mon 04/26/2021	to	Mon 04/26/2021						(Import)	(Export)
0500	Continuous	1700				SCH - OH - NY		1550 MW	1400 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability		500 MW	500 MW
						TTC with All Lines In Service		2050 MW	1900 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,August 04, 2020 to Thursday ,February 03, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO-NYISO_LIMIT_1600

Sat 05/01/2021 to Sun 10/31/2021
0001 Continuous 2359

Work scheduled by: IESO

UPDATED by IESO 05/03/2019

SCH - OH - NY
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 1950 MW

FWD
(Import)

PANNELL -CLAY_345_2

Mon 05/03/2021 to Fri 05/28/2021
0700 Continuous 1730

Work scheduled by: NYPA

WEST CENTRAL
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

FWD
(Import)

NIAGARA_345KV_3022

Tue 05/04/2021 to Wed 05/05/2021
0500 Continuous 1700

Work scheduled by: NYPA

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

NIAGARA_345KV_3202

Tue 05/04/2021 to Wed 05/05/2021
0500 Continuous 1700

Work scheduled by: NYPA

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

NIAGARA_345KV_3102

Thu 05/06/2021 to Fri 05/07/2021
0500 Continuous 1700

Work scheduled by: NYPA

SCH - OH - NY
Impacts Total Transfer Capability 250 MW 300 MW
TTC with All Lines In Service 1950 MW 1700 MW

FWD REV
(Import) (Export)

NIAGARA_345KV_3302

Mon 05/10/2021 to Wed 05/12/2021
0500 Continuous 1700

Work scheduled by: NYPA

SCH - OH - NY
Impacts Total Transfer Capability 950 MW 100 MW
TTC with All Lines In Service 1950 MW 1700 MW

FWD REV
(Import) (Export)

NIAGARA_345KV_3108

Thu 05/13/2021 to Fri 05/14/2021
0500 Continuous 1700

Work scheduled by: NYPA

SCH - OH - NY
Impacts Total Transfer Capability 200 MW
TTC with All Lines In Service 1700 MW

REV
(Export)

NYISO TRANSFER LIMITATIONS

Tuesday ,August 04, 2020 to Thursday ,February 03, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES__-ADIRNDCK_230_MA2

Tue 06/01/2021 to Sun 11/14/2021
0700 Continuous 1300

Work scheduled by: NYPA

FWD
(Import)

MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

NIAGARA_-KINTIGH_345_NS1-38

Mon 09/13/2021 to Fri 09/17/2021
0500 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)

DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

SCH-IMO-NYISO_LIMIT_1750

Mon 11/01/2021 to Fri 12/31/2021 **UPDATED by IESO 05/03/2019**
0001 Continuous 2359

Work scheduled by: IESO

FWD
(Import)

SCH - OH - NY **2050 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 2050 MW

SCH-NYISO-IMO_LIMIT_1600

Mon 11/01/2021 to Fri 12/31/2021 **UPDATED by IESO 05/03/2019**
0001 Continuous 2359

Work scheduled by: IESO

REV
(Export)

SCH - OH - NY **1900 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 1900 MW

MOSES__-ADIRNDCK_230_MA1

Wed 12/01/2021 to Tue 05/31/2022
0700 Continuous 1300

Work scheduled by: NYPA

FWD
(Import)

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW