

# NYISO TRANSFER LIMITATIONS

Friday ,August 07, 2020 to Sunday ,February 06, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE\_345KV\_9\_BYPASS & DUNWODIE\_345KV\_10\_BYPASS & SPRNBRK\_\_345KV\_R4S3\_BYPASS & SPRNBRK\_\_345KV\_R5S3\_BYPASS**

Sun 02/01/2015 to Sat 02/01/2025  
0000 0000

Work scheduled by:

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**HUDSONP\_-FARRAGUT\_345\_B3402**

Mon 01/15/2018 to Thu 10/01/2020  
0001 Continuous 2359

Work scheduled by: ConEd

**EXTENDED by CONED 05/03/2020**

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2050 MW</b>	<b>1150 MW</b>
Impacts Total Transfer Capability	150 MW	100 MW
TTC with All Lines In Service	2200 MW	1250 MW

**HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_-FARRAGUT\_345\_C3403**

Mon 01/15/2018 to Thu 10/01/2020  
0001 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2000 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	200 MW	250 MW
TTC with All Lines In Service	2200 MW	1250 MW

**MARION\_-FARRAGUT\_345\_C3403**

Mon 01/15/2018 to Thu 10/01/2020  
0001 Continuous 2359

Work scheduled by: ConEd

**EXTENDED by CONED 05/03/2020**

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2050 MW</b>	<b>1150 MW</b>
Impacts Total Transfer Capability	150 MW	100 MW
TTC with All Lines In Service	2200 MW	1250 MW

**STLAWRNC-MOSES\_\_230\_L33P**

Mon 04/30/2018 to Fri 12/31/2021  
0456 Continuous 2359

Work scheduled by: IESO

**EXT FORCE by IESO 08/21/2018**

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**SCH-IMO-NYISO\_LIMIT\_1600**

Fri 05/01/2020 to Sat 10/31/2020  
0001 Continuous 2359

Work scheduled by: IESO

**UPDATED by IESO 05/03/2019**

	FWD
	(Import)
SCH - OH - NY	<b>1900 MW</b>
Impacts Total Transfer Capability	50 MW
TTC with All Lines In Service	1950 MW

**SHOR\_NPX-SHOREHAM\_138\_CSC**

Wed 07/08/2020 to Wed 09/02/2020  
1247 Continuous 2359

Work scheduled by: LI

**EXT FORCE by ISONE 07/20/2020**

	FWD	REV
	(Import)	(Export)
SCH - NPX_CSC	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	330 MW	330 MW
TTC with All Lines In Service	330 MW	330 MW

# NYISO TRANSFER LIMITATIONS

Friday ,August 07, 2020 to Sunday ,February 06, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE-SHORE\_RD\_345\_Y50**

Fri 07/31/2020 to Tue 08/04/2020  
 0001 Continuous 0259  
 Work scheduled by: ConEd

FWD  
 (Import)  
 CONED - LIPA **800 MW**  
 Impacts Total Transfer Capability 700 MW  
 TTC with All Lines In Service 1500 MW

**SHORE\_RD\_345\_138\_BK 1**

Fri 07/31/2020 to Tue 08/04/2020  
 0001 Continuous 0259  
 Work scheduled by: ConEd

FWD  
 (Import)  
 CONED - LIPA **1350 MW**  
 Impacts Total Transfer Capability 150 MW  
 TTC with All Lines In Service 1500 MW

**SHORE\_RD\_345\_138\_BK 2**

Fri 07/31/2020 to Tue 08/04/2020  
 0001 Continuous 0259  
 Work scheduled by: ConEd

FWD  
 (Import)  
 CONED - LIPA **1350 MW**  
 Impacts Total Transfer Capability 150 MW  
 TTC with All Lines In Service 1500 MW

**MOSES\_\_-ADIRNDCK\_230\_MA2**

Fri 07/31/2020 to Mon 08/10/2020 **UPDATED by NYPA 08/07/2020**  
 0500 Continuous 2300  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2100 MW**  
 Impacts Total Transfer Capability 1050 MW  
 TTC with All Lines In Service 3150 MW

**DUNWODIE\_345KV\_4**

Tue 08/04/2020 to Tue 08/04/2020  
 0230 Continuous 0259  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_6**

Tue 08/04/2020 to Tue 08/04/2020  
 0230 Continuous 0259  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**LADENTWN-BUCHAN\_S\_345\_Y88**

Tue 08/04/2020 to Thu 08/06/2020 **FORCED by CONED 08/05/2020**  
 1411 Continuous 2359  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **5930 MW**  
 Impacts Total Transfer Capability 290 MW  
 TTC with All Lines In Service 6220 MW

# NYISO TRANSFER LIMITATIONS

Friday ,August 07, 2020 to Sunday ,February 06, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>RAMAPO__-LADENTWN_345_W72</b>						FWD		
Tue 08/04/2020	to	Thu 08/06/2020	<b>FORCED</b>	<b>by CONED</b>	<b>08/05/2020</b>	(Import)		
1515	Continuous	2359				UPNY CONED	<b>4400 MW</b>	
Work scheduled by: ConEd						Impacts Total Transfer Capability	1820 MW	
						TTC with All Lines In Service	6220 MW	
<b>EASTVIEW-SPRNBK_345_W64</b>						FWD		
Tue 08/04/2020	to	Sun 08/09/2020	<b>FORCED</b>	<b>by CONED</b>	<b>08/05/2020</b>	(Import)		
1754	Continuous	2359				UPNY CONED	<b>4350 MW</b>	
Work scheduled by: ConEd						Impacts Total Transfer Capability	1870 MW	
						TTC with All Lines In Service	6220 MW	
<b>NRTH1385-NOR HBR_138_601</b>						FWD	REV	
Wed 08/05/2020	to	Fri 08/07/2020	<b>CANCELLED</b>	<b>by LI</b>	<b>08/04/2020</b>	(Import)	(Export)	
0800	Continuous	1500				SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability	100 MW	100 MW
						TTC with All Lines In Service	200 MW	200 MW
<b>NRTH1385-NOR HBR_138_602</b>						FWD	REV	
Wed 08/05/2020	to	Fri 08/07/2020	<b>CANCELLED</b>	<b>by LI</b>	<b>08/04/2020</b>	(Import)	(Export)	
0800	Continuous	1500				SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability	100 MW	100 MW
						TTC with All Lines In Service	200 MW	200 MW
<b>NRTH1385-NOR HBR_138_603</b>						FWD	REV	
Wed 08/05/2020	to	Fri 08/07/2020	<b>CANCELLED</b>	<b>by LI</b>	<b>08/04/2020</b>	(Import)	(Export)	
0800	Continuous	1500				SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability	100 MW	100 MW
						TTC with All Lines In Service	200 MW	200 MW
<b>NRTH1385-NRTHPORT_138_NNC</b>						FWD	REV	
Wed 08/05/2020	to	Fri 08/07/2020	<b>CANCELLED</b>	<b>by LI</b>	<b>08/04/2020</b>	(Import)	(Export)	
0800	Continuous	1500				SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability	200 MW	200 MW
						TTC with All Lines In Service	200 MW	200 MW
<b>INDPDNCE-SCRIBA__345_25</b>						FWD		
Thu 08/06/2020	to	Thu 08/06/2020	<b>UPDATED</b>	<b>by NGRID</b>	<b>07/29/2020</b>	(Import)		
0600	Daily(No Weekends)	1630				OSWEGO EXPORT	<b>5250 MW</b>	
Work scheduled by: NGrid						Impacts Total Transfer Capability	0 MW	
						TTC with All Lines In Service	5250 MW	

# NYISO TRANSFER LIMITATIONS

Friday ,August 07, 2020 to Sunday ,February 06, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CRICKVLY-PLSNTVLY_345_F83</b>				FWD
Sat 08/08/2020	to	Sat 08/08/2020	<b><u>CANCELLED</u> by ConEd <u>08/07/2020</u></b>	(Import)
0001	Continuous	2200		<b>350 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 1050 MW
				TTC with All Lines In Service 1400 MW
<b>CRICKVLY-PLSNTVLY_345_F83</b>				FWD
Sat 08/08/2020	to	Sat 08/08/2020	<b><u>CANCELLED</u> by ConEd <u>08/07/2020</u></b>	(Import) (Export)
0001	Continuous	2200		<b>100 MW 100 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 100 MW 100 MW
				TTC with All Lines In Service 200 MW 200 MW
<b>BECK -NIAGARA_345_PA302</b>				FWD
Sat 08/08/2020	to	Sun 08/09/2020	<b><u>CANCELLED</u> by IESO <u>08/04/2020</u></b>	(Import) (Export)
0500	Continuous	1700		<b>900 MW 800 MW</b>
Work scheduled by: IESO				Impacts Total Transfer Capability 1050 MW 900 MW
				TTC with All Lines In Service 1950 MW 1700 MW
<b>W49TH_ST_345KV_6</b>				FWD
Sun 08/09/2020	to	Sun 08/09/2020		(Import)
0001	Continuous	0030		<b>300 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 360 MW
				TTC with All Lines In Service 660 MW
<b>W49TH_ST_345KV_8</b>				FWD
Sun 08/09/2020	to	Sun 08/09/2020		(Import)
0001	Continuous	0030		<b>450 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 210 MW
				TTC with All Lines In Service 660 MW
<b>SAND_BAR-PLATSBRG_115_PV20</b>				
Sun 08/09/2020	to	Sun 08/16/2020	<b><u>UPDATED</u> by ISONE <u>07/28/2020</u></b>	
0800	Continuous	1900		
Work scheduled by: ISONE				SCH - NE - NY
				Impacts Total Transfer Capability
				TTC with All Lines In Service
<b>W49TH_ST_345KV_6</b>				FWD
Sun 08/09/2020	to	Sun 08/09/2020		(Import)
1730	Continuous	1800		<b>300 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 360 MW
				TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

Friday ,August 07, 2020 to Sunday ,February 06, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST\_345KV\_8**

Sun 08/09/2020 to Sun 08/09/2020  
 1730 Continuous 1800  
 Work scheduled by: ConEd

FWD  
 (Import)  
**450 MW**  
 SCH - PJM\_HTP  
 Impacts Total Transfer Capability 210 MW  
 TTC with All Lines In Service 660 MW

**SCH-NYISO-IMO\_LIMIT\_1200**

Tue 08/11/2020 to Sat 08/15/2020  
 0600 Continuous 1800  
 Work scheduled by: IESO

REV  
 (Export)  
**1500 MW**  
 SCH - OH - NY  
 Impacts Total Transfer Capability 200 MW  
 TTC with All Lines In Service 1700 MW

**NIAGARA\_\_345KV\_3002**

Wed 08/12/2020 to Wed 08/12/2020 **UPDATED by NYPA 08/05/2020**  
 0500 Continuous 0530  
 Work scheduled by: NYPA

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**MOSES\_\_-ADIRNDCK\_230\_MA2**

Wed 08/12/2020 to Sat 09/12/2020 **UPDATED by NYPA 08/07/2020**  
 0500 Continuous 2359  
 Work scheduled by: NYPA

FWD  
 (Import)  
**2100 MW**  
 MOSES SOUTH  
 Impacts Total Transfer Capability 1050 MW  
 TTC with All Lines In Service 3150 MW

**NIAGARA\_\_345KV\_3002**

Thu 08/13/2020 to Thu 08/13/2020 **UPDATED by NYPA 08/05/2020**  
 1830 Continuous 1900  
 Work scheduled by: NYPA

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**S.RIPLEY-DUNKIRK\_\_230\_68**

Mon 08/17/2020 to Fri 08/21/2020  
 0900 Continuous 1500  
 Work scheduled by: PJM

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**SAND\_BAR-PLATSBURG\_115\_PV20**

Sat 08/22/2020 to Sat 08/29/2020 **UPDATED by ISONE 07/28/2020**  
 0800 Continuous 1900  
 Work scheduled by: ISONE

SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

Friday ,August 07, 2020 to Sunday ,February 06, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NIAGARA\_\_345KV\_3102**

Wed 08/26/2020 to Wed 08/26/2020  
0500 Continuous 1700

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>1700 MW</b>	<b>1400 MW</b>
Impacts Total Transfer Capability	250 MW	300 MW
TTC with All Lines In Service	1950 MW	1700 MW

**STOLLERD-HISHELDN\_230\_67**

Wed 08/26/2020 to Wed 08/26/2020  
0900 Continuous 1000

Work scheduled by: NYSEG

	FWD
	(Import)
DYSINGER EAST	<b>2850 MW</b>
Impacts Total Transfer Capability	300 MW
TTC with All Lines In Service	3150 MW

**HOMRC\_NY-MAINS\_NY\_345\_47**

Tue 09/01/2020 to Fri 10/09/2020  
0700 Continuous 1600

Work scheduled by: PJM

SCH - PJ - NY	
Impacts Total Transfer Capability	
TTC with All Lines In Service	

**OSWEGO\_COMPLEX\_AVR\_O/S**

Sun 09/06/2020 to Sun 09/06/2020  
0900 Continuous 0930

Work scheduled by: Gen

	FWD
	(Import)
CENTRAL EAST - VC	<b>2870 MW</b>
Impacts Total Transfer Capability	105 MW
TTC with All Lines In Service	2975 MW

**MARCY\_\_-N.SCTLND\_345\_18**

Wed 09/09/2020 to Wed 09/09/2020  
0800 Daily(No Weekends) 1500

Work scheduled by: NGrid

**ARR: 19**

	FWD
	(Import)
CENTRAL EAST - VC	<b>2090 MW</b>
Impacts Total Transfer Capability	885 MW
TTC with All Lines In Service	2975 MW

**MEYER\_\_-CANANDGA\_230\_60**

Thu 09/10/2020 to Thu 09/10/2020  
0730 Continuous 1630

Work scheduled by: NYSEG

	FWD
	(Import)
DYSINGER EAST	<b>2850 MW</b>
Impacts Total Transfer Capability	300 MW
TTC with All Lines In Service	3150 MW

**SPRNBRK\_-DUNWODIE\_345\_W75**

Sat 09/12/2020 to Sat 09/12/2020  
0001 Continuous 0030

Work scheduled by: ConEd

	FWD
	(Import)
SPR/DUN-SOUTH	<b>3800 MW</b>
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

# NYISO TRANSFER LIMITATIONS

Friday ,August 07, 2020 to Sunday ,February 06, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SPRNBK__345KV_RNS3</b>				FWD
Sat 09/12/2020	to	Sat 09/12/2020		(Import)
0001	Continuous	0030	SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
<b>DUNWODIE_345KV_5</b>				FWD
Sat 09/12/2020	to	Sat 09/12/2020		(Import)
0001	Continuous	2100	SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
<b>DUNWODIE_345KV_7</b>				FWD
Sat 09/12/2020	to	Sat 09/12/2020		(Import)
0001	Continuous	2100	SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
<b>SPRNBK_-DUNWODIE_345_W75</b>				FWD
Sat 09/12/2020	to	Sat 09/12/2020		(Import)
2030	Continuous	2100	SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
<b>SPRNBK__345KV_RNS3</b>				FWD
Sat 09/12/2020	to	Sat 09/12/2020		(Import)
2030	Continuous	2100	SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
<b>MOSES__-ADIRNDCK_230_MA2</b>				FWD
Sun 09/13/2020	to	Sat 11/14/2020	<b>UPDATED by NYPA 07/24/2020</b>	(Import)
0001	Continuous	1300	MOSES SOUTH	<b>2100 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability 1050 MW
				TTC with All Lines In Service 3150 MW
<b>KINTIGH_-ROCHESTR_345_SRL-39</b>				FWD
Mon 09/14/2020	to	Thu 09/17/2020		(Import)
0500	Continuous	1530	DYSINGER EAST	<b>1400 MW</b>
Work scheduled by: NYSEG				Impacts Total Transfer Capability 1750 MW
				TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Friday ,August 07, 2020 to Sunday ,February 06, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>NIAGARA_-KINTIGH__345_NS1-38</b>					FWD
Mon 09/14/2020	to	Thu 09/17/2020			(Import)
0500	Continuous	1530			DYSINGER EAST <b>1400 MW</b>
Work scheduled by: NYSEG					Impacts Total Transfer Capability 1750 MW
					TTC with All Lines In Service 3150 MW
<b>LINDN_CG-LNDVFT__345_V-3022</b>					FWD REV
Mon 09/14/2020	to	Wed 09/16/2020			(Import) (Export)
0800	Continuous	2000			SCH - PJM_VFT <b>0 MW 0 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 315 MW 315 MW
					TTC with All Lines In Service 315 MW 315 MW
<b>WOOD_ST_-PLSNTVLE_345_Y87</b>					FWD
Tue 09/15/2020	to	Tue 09/15/2020	<b>UPDATED</b>	<b>by CE</b>	<b>07/27/2020</b>
0001	Continuous	2230			(Import)
Work scheduled by: ConEd					UPNY CONED <b>5905 MW</b>
					Impacts Total Transfer Capability 315 MW
					TTC with All Lines In Service 6220 MW
<b>EFISHKIL-WOOD_ST__345_F39</b>					FWD
Tue 09/15/2020	to	Wed 09/16/2020	<b>UPDATED</b>	<b>by CE</b>	<b>07/27/2020</b>
0001	Continuous	2200			(Import)
Work scheduled by: ConEd					UPNY CONED <b>4000 MW</b>
					Impacts Total Transfer Capability 2220 MW
					TTC with All Lines In Service 6220 MW
<b>BRANCHBG-HOPATCON_500_5060</b>					FWD
Tue 09/15/2020	to	Wed 09/16/2020	<b>UPDATED</b>	<b>by PJM</b>	<b>04/20/2020</b>
0200	Continuous	2300			(Import)
Work scheduled by: PJM					UPNY CONED <b>6025 MW</b>
					Impacts Total Transfer Capability 195 MW
					TTC with All Lines In Service 6220 MW
<b>ADIRNDCK-CHASLAKE_230_13</b>					FWD
Tue 09/15/2020	to	Tue 09/15/2020	<b>UPDATED</b>	<b>by NGRID</b>	<b>08/06/2020</b>
0700	Continuous	1530			(Import)
Work scheduled by: NYPA					MOSES SOUTH <b>2100 MW</b>
					Impacts Total Transfer Capability 1050 MW
					TTC with All Lines In Service 3150 MW
<b>DOLSONAV-ROCKTVRN_345_DART44</b>					FWD
Wed 09/16/2020	to	Wed 09/30/2020			(Import)
0700	Continuous	1730			CENTRAL EAST - VC <b>2720 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 255 MW
					TTC with All Lines In Service 2975 MW



# NYISO TRANSFER LIMITATIONS

Friday ,August 07, 2020 to Sunday ,February 06, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>WOOD_ST_-PLSNTVLE_345_Y87</b>				FWD
Wed 09/16/2020	to	Wed 09/16/2020	<b>UPDATED by CE</b>	(Import)
2130	Continuous	2200		<b>5905 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 315 MW
				TTC with All Lines In Service 6220 MW
<hr/>				
<b>S.RIPLEY-DUNKIRK_230_68</b>				
Thu 09/17/2020	to	Fri 09/18/2020		
0900	Continuous	1500		SCH - PJ - NY
Work scheduled by: PJM				Impacts Total Transfer Capability
				TTC with All Lines In Service
<hr/>				
<b>NIAGARA_-ROCHESTR_345_NR2</b>				FWD
Fri 09/18/2020	to	Sat 11/14/2020		(Import)
0500	Continuous	2330		<b>1400 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability 1750 MW
				TTC with All Lines In Service 3150 MW
<hr/>				
<b>NIAGARA_345KV_3108</b>				REV
Fri 09/18/2020	to	Sat 11/14/2020		(Export)
0500	Continuous	2330		<b>1500 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability 200 MW
				TTC with All Lines In Service 1700 MW
<hr/>				
<b>EASTVIEW-SPRNBK_345_W65</b>				FWD
Sat 09/19/2020	to	Sat 09/19/2020		(Import)
0001	Continuous	0030		<b>4350 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 1870 MW
				TTC with All Lines In Service 6220 MW
<hr/>				
<b>MILLWOOD-EASTVIEW_345_W82</b>				FWD
Sat 09/19/2020	to	Sat 09/19/2020		(Import)
0001	Continuous	0030		<b>5985 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 235 MW
				TTC with All Lines In Service 6220 MW
<hr/>				
<b>SPRNBK_345KV_RNS4</b>				FWD
Sat 09/19/2020	to	Sat 09/19/2020		(Import)
0001	Continuous	0030		<b>3200 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Friday ,August 07, 2020 to Sunday ,February 06, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**EASTVIEW-SPRNBK\_\_345\_W65**

Sat 09/19/2020 to Sat 09/19/2020  
 0330 Continuous 0400  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1870 MW  
 TTC with All Lines In Service 6220 MW

**MILLWOOD-EASTVIEW\_345\_W82**

Sat 09/19/2020 to Sat 09/19/2020  
 0330 Continuous 0400  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **5985 MW**  
 Impacts Total Transfer Capability 235 MW  
 TTC with All Lines In Service 6220 MW

**SPRNBK\_\_345KV\_RNS4**

Sat 09/19/2020 to Sat 09/19/2020  
 0330 Continuous 0400  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

**NIAGARA\_\_345KV\_3002**

Sat 09/19/2020 to Sat 09/19/2020  
 0500 Continuous 2100  
 Work scheduled by: NYPA

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**NIAGARA\_\_345KV\_3022**

Sat 09/19/2020 to Sat 09/19/2020  
 0500 Continuous 2100  
 Work scheduled by: NYPA

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**MILLWOOD\_345KV\_18**

Sun 09/20/2020 to Sun 09/20/2020  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1870 MW  
 TTC with All Lines In Service 6220 MW

**BUCHAN\_S-MILLWOOD\_345\_W98**

Sun 09/20/2020 to Fri 09/25/2020  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **6135 MW**  
 Impacts Total Transfer Capability 85 MW  
 TTC with All Lines In Service 6220 MW

# NYISO TRANSFER LIMITATIONS

Friday ,August 07, 2020 to Sunday ,February 06, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NIAGARA\_\_345KV\_3102**

Sun 09/20/2020 to Sun 09/20/2020  
0500 Continuous 2100

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>1700 MW</b>	<b>1400 MW</b>
Impacts Total Transfer Capability	250 MW	300 MW
TTC with All Lines In Service	1950 MW	1700 MW

**NIAGARA\_\_345\_230\_AT4**

Sun 09/20/2020 to Sun 09/20/2020  
0500 Continuous 2100

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>1900 MW</b>	<b>1400 MW</b>
Impacts Total Transfer Capability	50 MW	300 MW
TTC with All Lines In Service	1950 MW	1700 MW

**CLAY\_\_-EDIC\_\_345\_1-16**

Mon 09/21/2020 to Fri 09/25/2020  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
OSWEGO EXPORT	<b>4850 MW</b>
Impacts Total Transfer Capability	400 MW
TTC with All Lines In Service	5250 MW

**FRASANX-COOPERS\_\_345\_UCC2-41**

Mon 09/21/2020 to Wed 09/30/2020 **EXTENDED** **by NYPA** **07/21/2020**  
0700 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

	FWD	(Import)
CENTRAL EAST - VC	<b>2500 MW</b>	
Impacts Total Transfer Capability	475 MW	
TTC with All Lines In Service	2975 MW	

**MARCY\_\_-FRASANX\_345\_UCC2-41**

Mon 09/21/2020 to Wed 09/30/2020 **EXTENDED** **by NYPA** **07/21/2020**  
0700 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

	FWD	(Import)
CENTRAL EAST - VC	<b>2500 MW</b>	
Impacts Total Transfer Capability	475 MW	
TTC with All Lines In Service	2975 MW	

**ROSETON\_-ROCKTVRN\_345\_311**

Mon 09/21/2020 to Fri 10/23/2020 **UPDATED** **by CHGE** **10/09/2019**  
0800 Continuous 1600

Work scheduled by: CHGE

	FWD	(Import)
UPNY CONED	<b>4400 MW</b>	
Impacts Total Transfer Capability	1820 MW	
TTC with All Lines In Service	6220 MW	

**GOETHALS\_345KV\_5**

Tue 09/22/2020 to Tue 09/22/2020 **UPDATED** **by CE** **06/24/2020**  
0200 Continuous 0230

Work scheduled by: PJM

STATEN ISLAND	
Impacts Total Transfer Capability	
TTC with All Lines In Service	

# NYISO TRANSFER LIMITATIONS

Friday ,August 07, 2020 to Sunday ,February 06, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>LINDEN__-GOETHALS_230_A2253</b>					FWD	REV
Tue 09/22/2020	to	Wed 09/23/2020	<u>UPDATED</u>	<u>by CE</u>	<u>06/24/2020</u>	(Import) (Export)
0200	Continuous	2359				
Work scheduled by: PJM					SCH - PJ - NY	<b>2050 MW 1150 MW</b>
					Impacts Total Transfer Capability	150 MW 100 MW
					TTC with All Lines In Service	2200 MW 1250 MW
<hr/>						
<b>LINDEN__-GOETHALS_230_A2253 &amp; HUDSONP_-FARRAGUT_345_B3402</b>					FWD	REV
Tue 09/22/2020	to	Wed 09/23/2020				(Import) (Export)
0200		2359				
Work scheduled by:					SCH - PJ - NY	<b>2000 MW 1000 MW</b>
					Impacts Total Transfer Capability	200 MW 250 MW
					TTC with All Lines In Service	2200 MW 1250 MW
<hr/>						
<b>LINDEN__-GOETHALS_230_A2253 &amp; HUDSONP_-FARRAGUT_345_B3402 &amp; MARION__-FARRAGUT_345_C3403</b>					FWD	REV
Tue 09/22/2020	to	Wed 09/23/2020				(Import) (Export)
0200		2359				
Work scheduled by:					SCH - PJ - NY	<b>2000 MW 1000 MW</b>
					Impacts Total Transfer Capability	200 MW 250 MW
					TTC with All Lines In Service	2200 MW 1250 MW
<hr/>						
<b>LINDEN__-GOETHALS_230_A2253 &amp; MARION__-FARRAGUT_345_C3403</b>					FWD	REV
Tue 09/22/2020	to	Wed 09/23/2020				(Import) (Export)
0200		2359				
Work scheduled by:					SCH - PJ - NY	<b>2000 MW 1000 MW</b>
					Impacts Total Transfer Capability	200 MW 250 MW
					TTC with All Lines In Service	2200 MW 1250 MW
<hr/>						
<b>ADIRNDCK-CHASLAKE_230_13</b>					FWD	
Wed 09/23/2020	to	Wed 09/23/2020	<u>UPDATED</u>	<u>by NGRID</u>	<u>08/06/2020</u>	(Import)
0700	Continuous	1530				
Work scheduled by: NYPA					MOSES SOUTH	<b>2100 MW</b>
					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	3150 MW
<hr/>						
<b>SCRIBA__-VOLNEY__345_21</b>					FWD	
Wed 09/23/2020	to	Thu 09/24/2020	<u>UPDATED</u>	<u>by NGRID</u>	<u>08/01/2020</u>	(Import)
0800	Continuous	1630				
Work scheduled by: NGrid					OSWEGO EXPORT	<b>5250 MW</b>
					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	5250 MW
<hr/>						
<b>LINDEN__-GOETHALS_230_A2253</b>					FWD	REV
Thu 09/24/2020	to	Sat 09/26/2020	<u>UPDATED</u>	<u>by PJM</u>	<u>07/06/2020</u>	(Import) (Export)
0001	Continuous	0300				
Work scheduled by: PJM					SCH - PJ - NY	<b>2050 MW 1150 MW</b>
					Impacts Total Transfer Capability	150 MW 100 MW
					TTC with All Lines In Service	2200 MW 1250 MW

# NYISO TRANSFER LIMITATIONS

Friday ,August 07, 2020 to Sunday ,February 06, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LINDEN__-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402		FWD	REV
Thu 09/24/2020	to Sat 09/26/2020	(Import)	(Export)
0001	0300	SCH - PJ - NY	<b>2000 MW 1000 MW</b>
Work scheduled by:		Impacts Total Transfer Capability	200 MW 250 MW
		TTC with All Lines In Service	2200 MW 1250 MW
LINDEN__-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402 & MARION__-FARRAGUT_345_C3403		FWD	REV
Thu 09/24/2020	to Sat 09/26/2020	(Import)	(Export)
0001	0300	SCH - PJ - NY	<b>2000 MW 1000 MW</b>
Work scheduled by:		Impacts Total Transfer Capability	200 MW 250 MW
		TTC with All Lines In Service	2200 MW 1250 MW
LINDEN__-GOETHALS_230_A2253 & MARION__-FARRAGUT_345_C3403		FWD	REV
Thu 09/24/2020	to Sat 09/26/2020	(Import)	(Export)
0001	0300	SCH - PJ - NY	<b>2000 MW 1000 MW</b>
Work scheduled by:		Impacts Total Transfer Capability	200 MW 250 MW
		TTC with All Lines In Service	2200 MW 1250 MW
W49TH_ST_345KV_5		FWD	
Fri 09/25/2020	to Sat 09/26/2020	(Import)	
0001	Continuous 0300	SCH - PJM_HTP	<b>300 MW</b>
Work scheduled by: ConEd		Impacts Total Transfer Capability	360 MW
		TTC with All Lines In Service	660 MW
W49TH_ST_345KV_7		FWD	
Fri 09/25/2020	to Sat 09/26/2020	(Import)	
0001	Continuous 0300	SCH - PJM_HTP	<b>300 MW</b>
Work scheduled by: ConEd		Impacts Total Transfer Capability	360 MW
		TTC with All Lines In Service	660 MW
MILLWOOD_345KV_18		FWD	
Fri 09/25/2020	to Fri 09/25/2020	(Import)	
0130	Continuous 0200	UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd		Impacts Total Transfer Capability	1870 MW
		TTC with All Lines In Service	6220 MW
EASTVIEW-SPRNBRK__345_W78		FWD	
Sat 09/26/2020	to Sun 09/27/2020	(Import)	
0001	Continuous 0200	<b>UPDATED by CONED 06/16/2020</b>	
Work scheduled by: ConEd		UPNY CONED	<b>4350 MW</b>
		Impacts Total Transfer Capability	1870 MW
		TTC with All Lines In Service	6220 MW

# NYISO TRANSFER LIMITATIONS

Friday ,August 07, 2020 to Sunday ,February 06, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MILLWOOD-EASTVIEW\_345\_W85**

Sat 09/26/2020 to Sun 09/27/2020  
0001 Continuous 0200

UPDATED by CONED 06/16/2020

Work scheduled by: ConEd

FWD  
(Import)  
**5985 MW**  
UPNY CONED  
Impacts Total Transfer Capability 235 MW  
TTC with All Lines In Service 6220 MW

**SPRNBRK\_345KV\_RNS3**

Sat 09/26/2020 to Sun 09/27/2020  
0001 Continuous 0200

UPDATED by CONED 06/16/2020

Work scheduled by: ConEd

FWD  
(Import)  
**3800 MW**  
SPR/DUN-SOUTH  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**GOETHALS\_345KV\_5**

Sat 09/26/2020 to Sat 09/26/2020  
0230 Continuous 0300

UPDATED by PJM 07/06/2020

Work scheduled by: PJM

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**CRICKVLY-PLSNTVLY\_345\_F83**

Mon 09/28/2020 to Sun 10/04/2020  
0001 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
**350 MW**  
SCH - NE - NY  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 1400 MW

**CRICKVLY-PLSNTVLY\_345\_F83**

Mon 09/28/2020 to Sun 10/04/2020  
0001 Continuous 2200

Work scheduled by: ConEd

FWD REV  
(Import) (Export)  
**100 MW 100 MW**  
SCH - NPX\_1385  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

**NRTH1385-NOR HBR\_138\_601 & CRICKVLY-PLSNTVLY\_345\_F83**

Mon 09/28/2020 to Sun 10/04/2020  
0500 2200

Work scheduled by:

FWD REV  
(Import) (Export)  
**0 MW 0 MW**  
SCH - NPX\_1385  
Impacts Total Transfer Capability 200 MW 200 MW  
TTC with All Lines In Service 200 MW 200 MW

**NRTH1385-NOR HBR\_138\_602 & CRICKVLY-PLSNTVLY\_345\_F83**

Mon 09/28/2020 to Sun 10/04/2020  
0500 2200

Work scheduled by:

FWD REV  
(Import) (Export)  
**0 MW 0 MW**  
SCH - NPX\_1385  
Impacts Total Transfer Capability 200 MW 200 MW  
TTC with All Lines In Service 200 MW 200 MW

# NYISO TRANSFER LIMITATIONS

Friday ,August 07, 2020 to Sunday ,February 06, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
<b>NRTH1385-NOR HBR_138_603 &amp; CRICKVLY-PLSNTVLY_345_F83</b>							
Mon 09/28/2020	to	Sun 10/04/2020					
0500		2200			SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Work scheduled by:						Impacts Total Transfer Capability	200 MW
						TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR HBR_138_601</b>						FWD	REV
						(Import)	(Export)
Mon 09/28/2020	to	Sat 10/17/2020	<b>UPDATED</b>	<b>by LIPA</b>	<b>07/10/2020</b>		
0500	Continuous	2359			SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR HBR_138_601 &amp; NRTH1385-NOR HBR_138_602</b>						FWD	REV
						(Import)	(Export)
Mon 09/28/2020	to	Sat 10/17/2020					
0500		2359			SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Work scheduled by:						Impacts Total Transfer Capability	200 MW
						TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR HBR_138_601 &amp; NRTH1385-NOR HBR_138_603</b>						FWD	REV
						(Import)	(Export)
Mon 09/28/2020	to	Sat 10/17/2020					
0500		2359			SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Work scheduled by:						Impacts Total Transfer Capability	200 MW
						TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR HBR_138_602</b>						FWD	REV
						(Import)	(Export)
Mon 09/28/2020	to	Sat 10/17/2020	<b>UPDATED</b>	<b>by LIPA</b>	<b>07/10/2020</b>		
0500	Continuous	2359			SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR HBR_138_602 &amp; NRTH1385-NOR HBR_138_603</b>						FWD	REV
						(Import)	(Export)
Mon 09/28/2020	to	Sat 10/17/2020					
0500		2359			SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Work scheduled by:						Impacts Total Transfer Capability	200 MW
						TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR HBR_138_603</b>						FWD	REV
						(Import)	(Export)
Mon 09/28/2020	to	Sat 10/17/2020	<b>UPDATED</b>	<b>by LIPA</b>	<b>07/10/2020</b>		
0500	Continuous	2359			SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW

# NYISO TRANSFER LIMITATIONS

Friday ,August 07, 2020 to Sunday ,February 06, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
<b>NRTH1385-NRTHPORT_138_NNC</b>		FWD	REV
Mon 09/28/2020 to Sat 10/17/2020	<b>UPDATED by LIPA 07/10/2020</b>	(Import)	(Export)
0500 Continuous 2359		<b>0 MW</b>	<b>0 MW</b>
Work scheduled by: LI		SCH - NPX_1385	
		Impacts Total Transfer Capability	200 MW
		TTC with All Lines In Service	200 MW
<hr/>			
<b>STONYRDG-HILLSIDE_230_72</b>		FWD	
Mon 09/28/2020 to Mon 09/28/2020		(Import)	
0600 Continuous 0630		DYSINGER EAST	<b>2850 MW</b>
Work scheduled by: NYSEG		Impacts Total Transfer Capability	300 MW
		TTC with All Lines In Service	3150 MW
<hr/>			
<b>CLAY -EDIC 345_2-15</b>		FWD	
Mon 09/28/2020 to Fri 10/02/2020		(Import)	
0700 Continuous 1530		OSWEGO EXPORT	<b>4850 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability	400 MW
		TTC with All Lines In Service	5250 MW
<hr/>			
<b>MOTTHAVN-RAINEY 345_Q11</b>		FWD	
Thu 10/01/2020 to Thu 11/05/2020	<b>UPDATED by CONED 12/17/2019</b>	(Import)	
0001 Continuous 0200		SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd		Impacts Total Transfer Capability	800 MW
		TTC with All Lines In Service	4600 MW
<hr/>			
<b>EDIC -FRASER 345_EF24-40</b>		FWD	
Thu 10/01/2020 to Fri 10/02/2020		(Import)	
0700 Continuous 1730		CENTRAL EAST - VC	<b>2500 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability	475 MW
		TTC with All Lines In Service	2975 MW
<hr/>			
<b>HUDSONTP-W49TH_ST_345_Y56</b>		FWD	
Fri 10/02/2020 to Thu 10/08/2020		(Import)	
0001 Continuous 0300		SCH - PJM_HTP	<b>0 MW</b>
Work scheduled by: ConEd		Impacts Total Transfer Capability	660 MW
		TTC with All Lines In Service	660 MW
<hr/>			
<b>W49TH_ST_345KV_7</b>		FWD	
Fri 10/02/2020 to Thu 10/08/2020		(Import)	
0001 Continuous 0300		SCH - PJM_HTP	<b>300 MW</b>
Work scheduled by: ConEd		Impacts Total Transfer Capability	360 MW
		TTC with All Lines In Service	660 MW



# NYISO TRANSFER LIMITATIONS

Friday ,August 07, 2020 to Sunday ,February 06, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST\_345KV\_8**

Fri 10/02/2020 to Thu 10/08/2020  
 0001 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SCH - PJM\_HTP **450 MW**  
 Impacts Total Transfer Capability 210 MW  
 TTC with All Lines In Service 660 MW

**STONYRDG-HILLSIDE\_230\_72**

Sun 10/04/2020 to Sun 10/04/2020  
 1500 Continuous 1530  
 Work scheduled by: NYSEG

FWD  
 (Import)  
 DYSINGER EAST **2850 MW**  
 Impacts Total Transfer Capability 300 MW  
 TTC with All Lines In Service 3150 MW

**PANNELL\_-CLAY\_345\_1**

Mon 10/05/2020 to Fri 10/09/2020 **UPDATED by NYPA 05/07/2020**  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 WEST CENTRAL **1300 MW**  
 Impacts Total Transfer Capability 950 MW  
 TTC with All Lines In Service 2250 MW

**DUNWODIE-MOTTHAVN\_345\_71**

Wed 10/07/2020 to Thu 10/08/2020 **UPDATED by CONED 07/22/2020**  
 0001 Continuous 0100  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_5**

Wed 10/07/2020 to Thu 10/08/2020 **UPDATED by CONED 07/22/2020**  
 0001 Continuous 0100  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_3**

Wed 10/07/2020 to Thu 11/12/2020 **UPDATED by CONED 07/22/2020**  
 0001 Continuous 0100  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_4**

Wed 10/07/2020 to Thu 11/12/2020 **UPDATED by CONED 07/22/2020**  
 0001 Continuous 0100  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Friday ,August 07, 2020 to Sunday ,February 06, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>PLSNTVLE-DUNWODIE_345_W89</b>					FWD	
Wed 10/07/2020	to	Thu 11/12/2020	<b>UPDATED</b>	<b>by CONED</b>	<b>07/22/2020</b>	(Import)
0001	Continuous	0100				<b>4000 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 2220 MW	
					TTC with All Lines In Service 6220 MW	
<b>HOMR_NYW-PIERC_NY_345_48</b>						
Mon 10/12/2020	to	Fri 10/30/2020	<b>UPDATED</b>	<b>by PJM</b>	<b>08/06/2020</b>	SCH - PJ - NY
0800	Continuous	1600				Impacts Total Transfer Capability
Work scheduled by: PJM					TTC with All Lines In Service	
<b>SAND_BAR-PLATSBURG_115_PV20</b>						
Sat 10/17/2020	to	Sat 11/14/2020				SCH - NE - NY
0600	Continuous	1800				Impacts Total Transfer Capability
Work scheduled by: ISONE					TTC with All Lines In Service	
<b>MILLWOOD_345KV_18</b>					FWD	
Mon 10/19/2020	to	Mon 10/19/2020				(Import)
0001	Continuous	0030				<b>4350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 1870 MW	
					TTC with All Lines In Service 6220 MW	
<b>ROCHESTR-PANNELL_345_RP1</b>					FWD	
Mon 10/19/2020	to	Fri 10/23/2020	<b>UPDATED</b>	<b>by NYPA</b>	<b>03/10/2020</b>	(Import)
0500	Continuous	1700				<b>2300 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 850 MW	
					TTC with All Lines In Service 3150 MW	
<b>SCH-NE-NYISO_LIMIT_600</b>					FWD	
Mon 10/19/2020	to	Sat 10/31/2020	<b>UPDATED</b>	<b>by ISONE</b>	<b>06/05/2020</b>	(Import)
0630	Continuous	2359				<b>800 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability 600 MW	
					TTC with All Lines In Service 1400 MW	
<b>SCH-NYISO-NE_LIMIT_800</b>					REV	
Mon 10/19/2020	to	Sat 10/31/2020	<b>UPDATED</b>	<b>by ISONE</b>	<b>06/05/2020</b>	(Export)
0630	Continuous	2359				<b>1000 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability 600 MW	
					TTC with All Lines In Service 1600 MW	

# NYISO TRANSFER LIMITATIONS

Friday ,August 07, 2020 to Sunday ,February 06, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>									
<b>BERKSHIR-ALPS</b> _____ <b>345_393</b>							FWD	REV	
Mon 10/19/2020	to	Tue 11/10/2020	<b>UPDATED</b>	<b>by ISONE</b>	<b>06/05/2020</b>		(Import)	(Export)	
0630	Continuous	1630				SCH - NE - NY	<b>950 MW</b>	<b>1300 MW</b>	
Work scheduled by: NGrid							Impacts Total Transfer Capability	450 MW	300 MW
							TTC with All Lines In Service	1400 MW	1600 MW
<hr/>									
<b>BERKSHIR-ALPS</b> _____ <b>345_393</b>							FWD	REV	
Mon 10/19/2020	to	Tue 11/10/2020	<b>UPDATED</b>	<b>by ISONE</b>	<b>06/05/2020</b>		(Import)	(Export)	
0630	Continuous	1630				SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>	
Work scheduled by: NGrid							Impacts Total Transfer Capability	100 MW	100 MW
							TTC with All Lines In Service	200 MW	200 MW
<hr/>									
<b>BERKSHIR-ALPS</b> _____ <b>345_393</b> & <b>BERKSHIR-NORTHFLD_345_312</b>							FWD	REV	
Mon 10/19/2020	to	Tue 11/10/2020					(Import)	(Export)	
0630		1630				SCH - NE - NY	<b>950 MW</b>	<b>1300 MW</b>	
Work scheduled by:							Impacts Total Transfer Capability	450 MW	300 MW
							TTC with All Lines In Service	1400 MW	1600 MW
<hr/>									
<b>BERKSHIR-NORTHFLD_345_312</b>							FWD	REV	
Mon 10/19/2020	to	Tue 11/10/2020	<b>UPDATED</b>	<b>by ISONE</b>	<b>06/05/2020</b>		(Import)	(Export)	
0630	Continuous	1630				SCH - NE - NY	<b>900 MW</b>	<b>1500 MW</b>	
Work scheduled by: NGrid							Impacts Total Transfer Capability	500 MW	100 MW
							TTC with All Lines In Service	1400 MW	1600 MW
<hr/>									
<b>BERKSHIR-NORTHFLD_345_312</b>							FWD	REV	
Mon 10/19/2020	to	Tue 11/10/2020	<b>UPDATED</b>	<b>by ISONE</b>	<b>06/05/2020</b>		(Import)	(Export)	
0630	Continuous	1630				SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>	
Work scheduled by: NGrid							Impacts Total Transfer Capability	100 MW	100 MW
							TTC with All Lines In Service	200 MW	200 MW
<hr/>									
<b>SHOR_NPX-SHOREHAM_138_CSC</b>							FWD	REV	
Mon 10/19/2020	to	Fri 10/23/2020	<b>UPDATED</b>	<b>by LI</b>	<b>03/02/2020</b>		(Import)	(Export)	
0700	Continuous	1500				SCH - NPX_CSC	<b>0 MW</b>	<b>0 MW</b>	
Work scheduled by: LI							Impacts Total Transfer Capability	330 MW	330 MW
							TTC with All Lines In Service	330 MW	330 MW
<hr/>									
<b>PANNELL_-CLAY_____345_2</b>							FWD		
Mon 10/19/2020	to	Fri 10/23/2020	<b>UPDATED</b>	<b>by NYPA</b>	<b>05/07/2020</b>		(Import)		
0700	Continuous	1530				WEST CENTRAL	<b>1300 MW</b>		
Work scheduled by: NYPA							Impacts Total Transfer Capability	950 MW	
							TTC with All Lines In Service	2250 MW	

# NYISO TRANSFER LIMITATIONS

Friday ,August 07, 2020 to Sunday ,February 06, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**COOPERS\_-DOLSONAV\_345\_CCDA42**

Mon 10/19/2020 to Fri 11/06/2020  
0700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC **2720 MW**  
Impacts Total Transfer Capability 255 MW  
TTC with All Lines In Service 2975 MW

**MILLWOOD\_345KV\_18**

Fri 10/23/2020 to Fri 10/23/2020  
2130 Continuous 2200

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 1870 MW  
TTC with All Lines In Service 6220 MW

**SPRNBK\_-TREMONT\_345\_X28**

Mon 10/26/2020 to Mon 10/26/2020  
0001 Continuous 0030

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH **4200 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 4600 MW

**LEEDS\_\_\_345\_LEEDS SVC**

Mon 10/26/2020 to Fri 10/30/2020  
0800 Continuous 1600

Work scheduled by: NGrid

FWD

(Import)

CENTRAL EAST - VC **2950 MW**  
Impacts Total Transfer Capability 25 MW  
TTC with All Lines In Service 2975 MW

**LEEDS\_\_\_-HURLYAVE\_345\_301**

Mon 10/26/2020 to Fri 12/04/2020  
0800 Continuous 1600

Work scheduled by: CHGE

FWD

(Import)

UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 2120 MW  
TTC with All Lines In Service 6220 MW

**DUNWODIE\_345KV\_6**

Sun 11/01/2020 to Sun 11/01/2020 **CANCELLED by ConEd 08/04/2020**  
0001 Continuous 0030

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**SCH-NE-NYISO\_LIMIT\_800**

Sun 11/01/2020 to Tue 11/10/2020 **UPDATED by ISONE 06/05/2020**  
0001 Continuous 1630

Work scheduled by: NGrid

FWD

(Import)

SCH - NE - NY **1000 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 1400 MW

# NYISO TRANSFER LIMITATIONS

Friday ,August 07, 2020 to Sunday ,February 06, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-NE_LIMIT_700						REV
Sun 11/01/2020	to	Tue 11/10/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>06/05/2020</u>	(Export)
0001	Continuous	1630				900 MW
Work scheduled by: NGrid						800 MW
						TTC with All Lines In Service 1700 MW
DUNWODIE-SHORE_RD_345_Y50						FWD
Sun 11/01/2020	to	Wed 11/11/2020	<u>CANCELLED</u>	<u>by ConEd</u>	<u>08/04/2020</u>	(Import)
0001	Continuous	0200				800 MW
Work scheduled by: ConEd						700 MW
						TTC with All Lines In Service 1500 MW
SHORE_RD_345_138_BK 1						FWD
Sun 11/01/2020	to	Wed 11/11/2020	<u>CANCELLED</u>	<u>by ConEd</u>	<u>08/04/2020</u>	(Import)
0001	Continuous	0200				1350 MW
Work scheduled by: ConEd						150 MW
						TTC with All Lines In Service 1500 MW
SHORE_RD_345_138_BK 2						FWD
Sun 11/01/2020	to	Wed 11/11/2020	<u>CANCELLED</u>	<u>by ConEd</u>	<u>08/04/2020</u>	(Import)
0001	Continuous	0200				1350 MW
Work scheduled by: ConEd						150 MW
						TTC with All Lines In Service 1500 MW
SCH-IMO-NYISO_LIMIT_1750						FWD
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Import)
0001	Continuous	2359				2050 MW
Work scheduled by: IESO						0 MW
						TTC with All Lines In Service 2050 MW
SCH-NYISO-IMO_LIMIT_1600						REV
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Export)
0001	Continuous	2359				1900 MW
Work scheduled by: IESO						0 MW
						TTC with All Lines In Service 1900 MW
NIAGARA_345KV_3002						FWD REV
Thu 11/05/2020	to	Thu 11/05/2020				(Import) (Export)
0500	Continuous	2100				1550 MW 1400 MW
Work scheduled by: NYPA						500 MW 500 MW
						TTC with All Lines In Service 2050 MW 1900 MW

# NYISO TRANSFER LIMITATIONS

Friday ,August 07, 2020 to Sunday ,February 06, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NIAGARA\_\_345KV\_3022**

Thu 11/05/2020 to Thu 11/05/2020  
0500 Continuous 2100

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>1550 MW</b>	<b>1400 MW</b>
Impacts Total Transfer Capability	500 MW	500 MW
TTC with All Lines In Service	2050 MW	1900 MW

**SPRNBRK\_-TREMONT\_\_345\_X28**

Fri 11/06/2020 to Sat 11/07/2020  
0001 Continuous 0059

Work scheduled by: ConEd

	FWD	
	(Import)	
SPR/DUN-SOUTH	<b>4200 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	4600 MW	

**NIAGARA\_\_345KV\_3102**

Fri 11/06/2020 to Fri 11/06/2020  
0500 Continuous 2100

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>2000 MW</b>	<b>1700 MW</b>
Impacts Total Transfer Capability	50 MW	200 MW
TTC with All Lines In Service	2050 MW	1900 MW

**NIAGARA\_\_345\_230\_AT4**

Fri 11/06/2020 to Fri 11/06/2020  
0500 Continuous 2100

Work scheduled by: NYPA

		REV
		(Export)
SCH - OH - NY		<b>1750 MW</b>
Impacts Total Transfer Capability		150 MW
TTC with All Lines In Service		1900 MW

**SPRNBRK\_-TREMONT\_\_345\_X28**

Mon 11/09/2020 to Mon 11/09/2020  
0030 Continuous 0059

Work scheduled by: ConEd

	FWD	
	(Import)	
SPR/DUN-SOUTH	<b>4200 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	4600 MW	

**DUNWODIE-MOTTHAVN\_345\_71**

Tue 11/10/2020 to Thu 11/12/2020 **UPDATED by CONED 07/22/2020**  
0001 Continuous 0100

Work scheduled by: ConEd

	FWD	
	(Import)	
SPR/DUN-SOUTH	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

**DUNWODIE\_345KV\_5**

Tue 11/10/2020 to Thu 11/12/2020 **UPDATED by CONED 07/22/2020**  
0001 Continuous 0100

Work scheduled by: ConEd

	FWD	
	(Import)	
SPR/DUN-SOUTH	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

# NYISO TRANSFER LIMITATIONS

Friday ,August 07, 2020 to Sunday ,February 06, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE\_345KV\_6**

Wed 11/11/2020 to Wed 11/11/2020  
0130 Continuous 0200

Work scheduled by: ConEd

**CANCELLED by ConEd 08/04/2020**

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

FWD  
(Import)

**CHATGUAY-MASSENA\_765\_7040**

Sun 11/15/2020 to Mon 11/30/2020  
0100 Continuous 1900

Work scheduled by: NYPA

MOSES SOUTH **1550 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 3150 MW

FWD  
(Import)

**CHATGUAY-MASSENA\_765\_7040**

Sun 11/15/2020 to Mon 11/30/2020  
0100 Continuous 1900

Work scheduled by: NYPA

SCH - HQ - NY **0 MW 0 MW**  
Impacts Total Transfer Capability 1500 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

FWD REV  
(Import) (Export)

**MARCY\_765\_345\_AT1**

Sun 11/15/2020 to Mon 11/30/2020  
0100 Continuous 1900

Work scheduled by: NYPA

**ARR: 19**

MOSES SOUTH **1750 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 3150 MW

FWD  
(Import)

**MARCY\_765\_345\_AT2**

Sun 11/15/2020 to Mon 11/30/2020  
0100 Continuous 1900

Work scheduled by: NYPA

**ARR: 19**

MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

FWD  
(Import)

**MASSENA -MARCY\_765\_MSU1**

Sun 11/15/2020 to Mon 11/30/2020  
0100 Continuous 1900

Work scheduled by: NYPA

CENTRAL EAST - VC **2265 MW**  
Impacts Total Transfer Capability 710 MW  
TTC with All Lines In Service 2975 MW

FWD  
(Import)

**MASSENA -MARCY\_765\_MSU1**

Sun 11/15/2020 to Mon 11/30/2020  
0100 Continuous 1900

Work scheduled by: NYPA

MOSES SOUTH **500 MW**  
Impacts Total Transfer Capability 2650 MW  
TTC with All Lines In Service 3150 MW

FWD  
(Import)

# NYISO TRANSFER LIMITATIONS

Friday ,August 07, 2020 to Sunday ,February 06, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Transfer Capability		FWD	REV
		(Import)	(Export)
<b>MASSENA -MARCY 765_MSU1</b>			
Sun 11/15/2020	to Mon 11/30/2020		
0100	Continuous 1900	SCH - HQ - NY	<b>475 MW 1000 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability	1025 MW 0 MW
		TTC with All Lines In Service	1500 MW 1000 MW
<b>MASSENA -MARCY 765_MSU1</b>			
Sun 11/15/2020	to Mon 11/30/2020		
0100	Continuous 1900	SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability	109 MW
		TTC with All Lines In Service	199 MW
<b>MASSENA -MARCY 765_MSU1 &amp; CHATGUAY-MASSENA 765_7040</b>			
Sun 11/15/2020	to Mon 11/30/2020		
0100	1900	MOSES SOUTH	<b>500 MW</b>
Work scheduled by:		Impacts Total Transfer Capability	2650 MW
		TTC with All Lines In Service	3150 MW
<b>MOSES -MASSENA 230_MMS1 &amp; MOSES -MASSENA 230_MMS2</b>			
Sun 11/15/2020	to Mon 11/30/2020		
0100	1900	SCH - HQ - NY	<b>850 MW 0 MW</b>
Work scheduled by:		Impacts Total Transfer Capability	650 MW 1000 MW
		TTC with All Lines In Service	1500 MW 1000 MW
<b>MOSES -MASSENA 230_MMS1 &amp; MOSES -MASSENA 230_MMS2</b>			
Sun 11/15/2020	to Mon 11/30/2020		
0100	1900	SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by:		Impacts Total Transfer Capability	109 MW
		TTC with All Lines In Service	199 MW
<b>STLAWRNC-MOSES 230_L33P &amp; MASSENA -MARCY 765_MSU1</b>			
Sun 11/15/2020	to Mon 11/30/2020		
0100	1900	SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by:		Impacts Total Transfer Capability	109 MW
		TTC with All Lines In Service	199 MW
<b>STLAWRNC-MOSES 230_L33P &amp; MOSES -MASSENA 230_MMS1 &amp; MOSES -MASSENA 230_MMS2</b>			
Sun 11/15/2020	to Mon 11/30/2020		
0100	1900	SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by:		Impacts Total Transfer Capability	109 MW
		TTC with All Lines In Service	199 MW



# NYISO TRANSFER LIMITATIONS

Friday ,August 07, 2020 to Sunday ,February 06, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**PLSNTVLY-WOOD\_ST\_\_345\_F30**

Mon 11/16/2020 to Mon 11/16/2020  
 0001 Continuous 0030

Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 2220 MW  
 TTC with All Lines In Service 6220 MW

-----  
**PLSNTVLY\_345KV\_RNS5**

Mon 11/16/2020 to Mon 11/16/2020  
 0001 Continuous 0030

Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 2420 MW  
 TTC with All Lines In Service 6220 MW

-----  
**MILLWOOD\_345KV\_18**

Mon 11/16/2020 to Tue 11/17/2020  
 0001 Continuous 0200

Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1870 MW  
 TTC with All Lines In Service 6220 MW

-----  
**PLSNTVLY-WOOD\_ST\_\_345\_F30**

Tue 11/17/2020 to Tue 11/17/2020  
 0130 Continuous 0200

Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 2220 MW  
 TTC with All Lines In Service 6220 MW

-----  
**PLSNTVLY\_345KV\_RNS5**

Tue 11/17/2020 to Tue 11/17/2020  
 0130 Continuous 0200

Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 2420 MW  
 TTC with All Lines In Service 6220 MW

-----  
**W49TH\_ST\_345KV\_6**

Fri 11/20/2020 to Wed 11/25/2020 **UPDATED by CE 08/06/2020**  
 0001 Continuous 2300

Work scheduled by: ConEd

FWD  
 (Import)  
 SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

-----  
**W49TH\_ST\_345KV\_8**

Fri 11/20/2020 to Wed 11/25/2020 **UPDATED by CE 08/06/2020**  
 0001 Continuous 2300

Work scheduled by: ConEd

FWD  
 (Import)  
 SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

Friday ,August 07, 2020 to Sunday ,February 06, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE**

Mon 11/30/2020 to Sun 12/20/2020  
0600 Continuous 1600

**UPDATED by LI 04/29/2020**

Work scheduled by: PJM

FWD  
(Import)  
**0 MW**  
SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

**NEWBRDGE-DUFFYAVE\_345\_501**

Mon 11/30/2020 to Sun 12/20/2020  
0600 Continuous 1600

**UPDATED by LI 04/29/2020**

Work scheduled by: PJM

FWD  
(Import)  
**0 MW**  
SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

**MARCY\_\_\_345KV\_CSC**

Tue 12/01/2020 to Fri 12/11/2020  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
**2925 MW**  
CENTRAL EAST - VC  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

**MOSES\_-ADIRNDCK\_230\_MA1**

Tue 12/01/2020 to Sat 02/27/2021  
0700 Continuous 1730

**UPDATED by NYPA 07/27/2020**

Work scheduled by: NYPA

FWD  
(Import)  
**2300 MW**  
MOSES SOUTH  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**W49TH\_ST\_345KV\_6**

Tue 12/01/2020 to Tue 12/01/2020  
2230 Continuous 2300

**UPDATED by CE 08/06/2020**

Work scheduled by: ConEd

FWD  
(Import)  
**300 MW**  
SCH - PJM\_HTP  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

**W49TH\_ST\_345KV\_8**

Tue 12/01/2020 to Tue 12/01/2020  
2230 Continuous 2300

**UPDATED by CE 08/06/2020**

Work scheduled by: ConEd

FWD  
(Import)  
**300 MW**  
SCH - PJM\_HTP  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

**KINTIGH\_-ROCHESTR\_345\_SRL-39**

Thu 12/03/2020 to Tue 12/15/2020  
0800 Continuous 1900

**UPDATED by NYISO 06/24/2020**

Work scheduled by: RGE

FWD  
(Import)  
**1700 MW**  
DYSINGER EAST  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Friday ,August 07, 2020 to Sunday ,February 06, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Line ID	Start Date	End Date	Time	Duration	Work by	Impact	TTC	FWD	REV
<b>NIAGARA_-KINTIGH_345_NS1-38</b>	Thu 12/03/2020	Tue 12/15/2020	0800	Continuous	RGE	DYSINGER EAST	1700 MW	(Import)	
						Impacts Total Transfer Capability	1450 MW		
						TTC with All Lines In Service	3150 MW		
<b>BECK_-PACKARD_230_BP76</b>	Fri 12/04/2020	Fri 12/04/2020	0730	Daily(No Weekends)	NGrid	SCH - OH - NY	1650 MW	(Import)	(Export)
						Impacts Total Transfer Capability	400 MW		500 MW
						TTC with All Lines In Service	2050 MW		1900 MW
<b>SAND_BAR-PLATSBURG_115_PV20</b>	Mon 12/07/2020	Fri 12/11/2020	0700	Continuous	NYPA	SCH - NE - NY			
						Impacts Total Transfer Capability			
						TTC with All Lines In Service			
<b>W49TH_ST_345KV_6</b>	Tue 12/08/2020	Tue 12/08/2020	0301	Continuous	ConEd	SCH - PJM_HTP	300 MW	(Import)	
						Impacts Total Transfer Capability	360 MW		
						TTC with All Lines In Service	660 MW		
<b>E13THSTA-FARRAGUT_345_46</b>	Tue 12/08/2020	Fri 12/11/2020	0301	Continuous	ConEd	SPR/DUN-SOUTH	3800 MW	(Import)	
						Impacts Total Transfer Capability	800 MW		
						TTC with All Lines In Service	4600 MW		
<b>W49TH_ST-E13THSTA_345_M55</b>	Tue 12/08/2020	Fri 12/11/2020	0301	Continuous	ConEd	SPR/DUN-SOUTH	3800 MW	(Import)	
						Impacts Total Transfer Capability	800 MW		
						TTC with All Lines In Service	4600 MW		
<b>LONG_MTN-CRICKVLY_345_398</b>	Tue 12/08/2020	Thu 12/10/2020	0700	Continuous	ISONE	SCH - NE - NY	700 MW	(Import)	(Export)
						Impacts Total Transfer Capability	700 MW		400 MW
						TTC with All Lines In Service	1400 MW		1700 MW

# NYISO TRANSFER LIMITATIONS

Friday ,August 07, 2020 to Sunday ,February 06, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event ID	Start Date	End Date	Time	Duration	Work Scheduled by	Schedule	FWD (Import)	REV (Export)
<b>LONG_MTN-CRICKVLY_345_398</b>	Tue 12/08/2020	Thu 12/10/2020	0700	Continuous	ISONE	SCH - NPX_1385	100 MW	100 MW
							Impacts Total Transfer Capability	100 MW
							TTC with All Lines In Service	200 MW
<b>SCH-NE-NYISO_LIMIT_400</b>	Tue 12/08/2020	Thu 12/10/2020	0700	Continuous	ISONE	SCH - NE - NY	600 MW	
							Impacts Total Transfer Capability	800 MW
							TTC with All Lines In Service	1400 MW
<b>SCH-NYISO-NE_LIMIT_1000</b>	Tue 12/08/2020	Thu 12/10/2020	0700	Continuous	ISONE	SCH - NE - NY		1200 MW
							Impacts Total Transfer Capability	500 MW
							TTC with All Lines In Service	1700 MW
<b>W49TH_ST_345KV_6</b>	Fri 12/11/2020	Fri 12/11/2020	0230	Continuous	ConEd	SCH - PJM_HTP	300 MW	
							Impacts Total Transfer Capability	360 MW
							TTC with All Lines In Service	660 MW
<b>MARCY__-EDIC____345_UE1-7</b>	Mon 12/14/2020	Mon 12/14/2020	0700	Continuous	NYPA	OSWEGO EXPORT	5250 MW	
							Impacts Total Transfer Capability	0 MW
							TTC with All Lines In Service	5250 MW
<b>SAND_BAR-PLATSBRG_115_PV20</b>	Mon 12/14/2020	Fri 12/18/2020	0700	Continuous	NYPA	SCH - NE - NY		
							Impacts Total Transfer Capability	
							TTC with All Lines In Service	
<b>LADENTWN-BUCHAN_S_345_Y88</b>	Tue 12/15/2020	Sat 01/30/2021	0001	Continuous	ConEd	UPNY CONED	5930 MW	
							Impacts Total Transfer Capability	290 MW
							TTC with All Lines In Service	6220 MW

ARR: 19&16

# NYISO TRANSFER LIMITATIONS

Friday ,August 07, 2020 to Sunday ,February 06, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**FRASANX-COOPERS\_\_345\_UCC2-41**

Tue 12/15/2020 to Wed 12/16/2020  
0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

**MARCY\_\_-FRASANX\_345\_UCC2-41**

Tue 12/15/2020 to Wed 12/16/2020  
0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

**HOPATCON-RAMAPO\_\_500\_5018**

Mon 02/01/2021 to Wed 02/03/2021  
0001 Continuous 2200

Work scheduled by: ConEd

FWD REV  
(Import) (Export)  
SCH - PJ - NY **1250 MW 1200 MW**  
Impacts Total Transfer Capability 1650 MW 650 MW  
TTC with All Lines In Service 2900 MW 1850 MW

**HOPATCON-RAMAPO\_\_500\_5018**

Mon 02/01/2021 to Wed 02/03/2021  
0001 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **6025 MW**  
Impacts Total Transfer Capability 195 MW  
TTC with All Lines In Service 6220 MW

**RAMAPO\_\_345\_345\_PAR3500**

Mon 02/01/2021 to Wed 02/03/2021  
0001 Continuous 2200

Work scheduled by: ConEd

FWD REV  
(Import) (Export)  
SCH - PJ - NY **2150 MW 1250 MW**  
Impacts Total Transfer Capability 750 MW 600 MW  
TTC with All Lines In Service 2900 MW 1850 MW

**RAMAPO\_\_345\_345\_PAR4500**

Mon 02/01/2021 to Wed 02/03/2021  
0001 Continuous 2200

Work scheduled by: ConEd

FWD REV  
(Import) (Export)  
SCH - PJ - NY **2150 MW 1250 MW**  
Impacts Total Transfer Capability 750 MW 600 MW  
TTC with All Lines In Service 2900 MW 1850 MW

**RAMAPO\_\_500\_345\_BK 1500**

Mon 02/01/2021 to Wed 02/03/2021  
0001 Continuous 2200

Work scheduled by: ConEd

FWD REV  
(Import) (Export)  
SCH - PJ - NY **1250 MW 1200 MW**  
Impacts Total Transfer Capability 1650 MW 650 MW  
TTC with All Lines In Service 2900 MW 1850 MW

# NYISO TRANSFER LIMITATIONS

Friday ,August 07, 2020 to Sunday ,February 06, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>RAMAPO__500_345_BK 1500</b>					FWD	
Mon 02/01/2021	to	Wed 02/03/2021			(Import)	
0001	Continuous	2200		UPNY CONED	<b>6025 MW</b>	
Work scheduled by: ConEd					Impacts Total Transfer Capability	195 MW
					TTC with All Lines In Service	6220 MW
<b>PLSNTVLY-WOOD_ST__345_F30</b>					FWD	
Mon 02/15/2021	to	Tue 02/16/2021			(Import)	
0001	Continuous	0200		UPNY CONED	<b>4000 MW</b>	
Work scheduled by: ConEd					Impacts Total Transfer Capability	2220 MW
					TTC with All Lines In Service	6220 MW
<b>PLSNTVLY_345KV_RNS5</b>					FWD	
Mon 02/15/2021	to	Tue 02/16/2021			(Import)	
0001	Continuous	0200		UPNY CONED	<b>3800 MW</b>	
Work scheduled by: ConEd					Impacts Total Transfer Capability	2420 MW
					TTC with All Lines In Service	6220 MW
<b>EFISHKIL-WOOD_ST__345_F39</b>					FWD	
Thu 02/18/2021	to	Sat 02/20/2021	<b>UPDATED</b>	<b>by CE</b>	<b>04/01/2020</b>	(Import)
2100	Continuous	0200				
Work scheduled by: ConEd					UPNY CONED	<b>4000 MW</b>
					Impacts Total Transfer Capability	2220 MW
					TTC with All Lines In Service	6220 MW
<b>WOOD_ST_-PLSNTVLE_345_Y87</b>					FWD	
Thu 02/18/2021	to	Sat 02/20/2021	<b>UPDATED</b>	<b>by CE</b>	<b>04/01/2020</b>	(Import)
2100	Continuous	0200				
Work scheduled by: ConEd					UPNY CONED	<b>5905 MW</b>
					Impacts Total Transfer Capability	315 MW
					TTC with All Lines In Service	6220 MW
<b>CHATGUAY-MASSENA__765_7040</b>					FWD	
Sun 02/28/2021	to	Mon 03/01/2021			(Import)	
0500	Continuous	1730		MOSES SOUTH	<b>1550 MW</b>	
Work scheduled by: NYPA					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	3150 MW
<b>CHATGUAY-MASSENA__765_7040</b>					FWD	REV
Sun 02/28/2021	to	Mon 03/01/2021			(Import)	(Export)
0500	Continuous	1730		SCH - HQ - NY	<b>0 MW</b>	<b>0 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	1500 MW 1000 MW
					TTC with All Lines In Service	1500 MW 1000 MW

# NYISO TRANSFER LIMITATIONS

Friday ,August 07, 2020 to Sunday ,February 06, 2022

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MASSENA_-MARCY_765_MSU1</b>			FWD	
Sun 02/28/2021	to	Mon 03/01/2021	(Import)	
0500	Continuous	1730	CENTRAL EAST - VC	<b>2265 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	710 MW
			TTC with All Lines In Service	2975 MW
<b>MASSENA_-MARCY_765_MSU1</b>			FWD	
Sun 02/28/2021	to	Mon 03/01/2021	(Import)	
0500	Continuous	1730	MOSES SOUTH	<b>500 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	2650 MW
			TTC with All Lines In Service	3150 MW
<b>MASSENA_-MARCY_765_MSU1</b>			FWD	REV
Sun 02/28/2021	to	Mon 03/01/2021	(Import)	(Export)
0500	Continuous	1730	SCH - HQ - NY	<b>475 MW 1000 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	1025 MW 0 MW
			TTC with All Lines In Service	1500 MW 1000 MW
<b>MASSENA_-MARCY_765_MSU1</b>			FWD	
Sun 02/28/2021	to	Mon 03/01/2021	(Import)	
0500	Continuous	1730	SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	109 MW
			TTC with All Lines In Service	199 MW
<b>MASSENA_-MARCY_765_MSU1 &amp; CHATGUAY-MASSENA_765_7040</b>			FWD	
Sun 02/28/2021	to	Mon 03/01/2021	(Import)	
0500		1730	MOSES SOUTH	<b>500 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	2650 MW
			TTC with All Lines In Service	3150 MW
<b>STLAWRNC-MOSES_230_L33P &amp; MASSENA_-MARCY_765_MSU1</b>			FWD	
Sun 02/28/2021	to	Mon 03/01/2021	(Import)	
0500		1730	SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	109 MW
			TTC with All Lines In Service	199 MW
<b>DUNWODIE_345KV_3</b>			FWD	
Mon 03/01/2021	to	Mon 03/01/2021	(Import)	
0001	Continuous	0030	SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW

# NYISO TRANSFER LIMITATIONS

Friday ,August 07, 2020 to Sunday ,February 06, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>				
<b>DUNWODIE_345KV_5</b>				FWD
Mon 03/01/2021	to	Mon 03/01/2021		(Import)
0001	Continuous	0030	SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
<hr/>				
<b>EASTVIEW-SPRNBK__345_W64</b>				FWD
Mon 03/01/2021	to	Mon 03/01/2021	<b>UPDATED by CONED 01/23/2020</b>	(Import)
0001	Continuous	0030	UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 1870 MW
				TTC with All Lines In Service 6220 MW
<hr/>				
<b>SPRNBK__345KV_RNS5</b>				FWD
Mon 03/01/2021	to	Mon 03/01/2021	<b>UPDATED by CONED 01/23/2020</b>	(Import)
0001	Continuous	0030	SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW
<hr/>				
<b>MILLWOOD-EASTVIEW_345_W99</b>				FWD
Mon 03/01/2021	to	Mon 03/22/2021	<b>UPDATED by CONED 01/23/2020</b>	(Import)
0001	Continuous	0200	UPNY CONED	<b>5985 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 235 MW
				TTC with All Lines In Service 6220 MW
<hr/>				
<b>DUNWODIE-MOTTHAVN_345_71</b>				FWD
Mon 03/01/2021	to	Mon 04/05/2021		(Import)
0001	Continuous	0300	SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
<hr/>				
<b>MOTTHAVN-RAINEY__345_Q11</b>				FWD
Mon 03/01/2021	to	Tue 04/06/2021		(Import)
0001	Continuous	0700	SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
<hr/>				
<b>MOSES__-ADIRNDCK_230_MAL</b>				FWD
Tue 03/02/2021	to	Mon 05/31/2021		(Import)
0700	Continuous	1300	MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW



# NYISO TRANSFER LIMITATIONS

Friday ,August 07, 2020 to Sunday ,February 06, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>NIAGARA_-ROBNSNRD_230_64</b>					REV
Fri 03/12/2021	to	Fri 03/12/2021			(Export)
0500	Continuous	1700		SCH - OH - NY	<b>1900 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability
					TTC with All Lines In Service
					1900 MW
<b>MARCY_345KV_CSC</b>					FWD
Sat 03/13/2021	to	Sat 03/13/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>07/29/2020</u>
0700	Continuous	1730			(Import)
Work scheduled by: NYPA					CENTRAL EAST - VC
					<b>2925 MW</b>
					Impacts Total Transfer Capability
					TTC with All Lines In Service
					50 MW
					2975 MW
<b>EASTVIEW-SPRNBK_345_W64</b>					FWD
Mon 03/22/2021	to	Mon 03/22/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>01/23/2020</u>
0130	Continuous	0200			(Import)
Work scheduled by: ConEd					UPNY CONED
					<b>4350 MW</b>
					Impacts Total Transfer Capability
					TTC with All Lines In Service
					1870 MW
					6220 MW
<b>SPRNBK_345KV_RNS5</b>					FWD
Mon 03/22/2021	to	Mon 03/22/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>01/23/2020</u>
0130	Continuous	0200			(Import)
Work scheduled by: ConEd					SPR/DUN-SOUTH
					<b>3200 MW</b>
					Impacts Total Transfer Capability
					TTC with All Lines In Service
					1400 MW
					4600 MW
<b>CLAY_-EDIC_345_2-15</b>					FWD
Mon 03/29/2021	to	Fri 04/16/2021			(Import)
0800	Continuous	1730		OSWEGO EXPORT	<b>4850 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability
					TTC with All Lines In Service
					400 MW
					5250 MW
<b>ROCHESTR-PANNELL_345_RP2</b>					FWD
Wed 03/31/2021	to	Mon 04/12/2021			(Import)
0500	Continuous	1700		DYSINGER EAST	<b>2300 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability
					TTC with All Lines In Service
					850 MW
					3150 MW
<b>DUNWODIE_345KV_3</b>					FWD
Mon 04/05/2021	to	Mon 04/05/2021			(Import)
0230	Continuous	0300		SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability
					TTC with All Lines In Service
					800 MW
					4600 MW

# NYISO TRANSFER LIMITATIONS

Friday ,August 07, 2020 to Sunday ,February 06, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE\_345KV\_5**

Mon 04/05/2021 to Mon 04/05/2021  
 0230 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**SPRNBRK\_-TREMONT\_\_345\_X28**

Mon 04/19/2021 to Tue 04/20/2021  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **4200 MW**  
 Impacts Total Transfer Capability 400 MW  
 TTC with All Lines In Service 4600 MW

**NIAGARA\_\_345KV\_3002**

Mon 04/26/2021 to Mon 04/26/2021  
 0500 Continuous 1700  
 Work scheduled by: NYPA

FWD REV  
 (Import) (Export)  
 SCH - OH - NY **1550 MW 1400 MW**  
 Impacts Total Transfer Capability 500 MW 500 MW  
 TTC with All Lines In Service 2050 MW 1900 MW

**SCH-IMO-NYISO\_LIMIT\_1600**

Sat 05/01/2021 to Sun 10/31/2021 **UPDATED by IESO 05/03/2019**  
 0001 Continuous 2359  
 Work scheduled by: IESO

FWD  
 (Import)  
 SCH - OH - NY **1900 MW**  
 Impacts Total Transfer Capability 50 MW  
 TTC with All Lines In Service 1950 MW

**PANNELL\_-CLAY\_\_\_\_345\_2**

Mon 05/03/2021 to Fri 05/28/2021  
 0700 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
 WEST CENTRAL **1300 MW**  
 Impacts Total Transfer Capability 950 MW  
 TTC with All Lines In Service 2250 MW

**NIAGARA\_\_345KV\_3022**

Tue 05/04/2021 to Wed 05/05/2021  
 0500 Continuous 1700  
 Work scheduled by: NYPA

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**NIAGARA\_\_345KV\_3202**

Tue 05/04/2021 to Wed 05/05/2021  
 0500 Continuous 1700  
 Work scheduled by: NYPA

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

Friday ,August 07, 2020 to Sunday ,February 06, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NIAGARA\_\_345KV\_3102**

Thu 05/06/2021 to Fri 05/07/2021  
 0500 Continuous 1700  
 Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>1700 MW</b>	<b>1400 MW</b>
Impacts Total Transfer Capability	250 MW	300 MW
TTC with All Lines In Service	1950 MW	1700 MW

**NIAGARA\_\_345KV\_3302**

Mon 05/10/2021 to Wed 05/12/2021  
 0500 Continuous 1700  
 Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>1000 MW</b>	<b>1600 MW</b>
Impacts Total Transfer Capability	950 MW	100 MW
TTC with All Lines In Service	1950 MW	1700 MW

**NIAGARA\_\_345KV\_3108**

Thu 05/13/2021 to Fri 05/14/2021  
 0500 Continuous 1700  
 Work scheduled by: NYPA

		REV
		(Export)
SCH - OH - NY		<b>1500 MW</b>
Impacts Total Transfer Capability		200 MW
TTC with All Lines In Service		1700 MW

**MOSES\_\_-ADIRNDCK\_230\_MA2**

Tue 06/01/2021 to Sun 11/14/2021  
 0700 Continuous 1300  
 Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>2100 MW</b>
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	3150 MW

**NIAGARA\_-KINTIGH\_\_345\_NS1-38**

Mon 09/13/2021 to Fri 09/17/2021  
 0500 Continuous 1700  
 Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	<b>1400 MW</b>
Impacts Total Transfer Capability	1750 MW
TTC with All Lines In Service	3150 MW

**W49TH\_ST\_345KV\_6**

Tue 09/28/2021 to Tue 09/28/2021  
 0100 Continuous 0130  
 Work scheduled by: ConEd

	FWD
	(Import)
SCH - PJM_HTP	<b>300 MW</b>
Impacts Total Transfer Capability	360 MW
TTC with All Lines In Service	660 MW

**E13THSTA-FARRAGUT\_345\_46**

Tue 09/28/2021 to Tue 10/26/2021  
 0100 Continuous 0300  
 Work scheduled by: ConEd

	FWD
	(Import)
SPR/DUN-SOUTH	<b>3800 MW</b>
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

# NYISO TRANSFER LIMITATIONS

Friday ,August 07, 2020 to Sunday ,February 06, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST-E13THSTA\_345\_M55**

Tue 09/28/2021 to Tue 10/26/2021  
 0100 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**W49TH\_ST\_345KV\_6**

Tue 10/26/2021 to Tue 10/26/2021  
 0230 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

**SCH-IMO-NYISO\_LIMIT\_1750**

Mon 11/01/2021 to Fri 12/31/2021 **UPDATED by IESO 05/03/2019**  
 0001 Continuous 2359  
 Work scheduled by: IESO

FWD  
 (Import)  
 SCH - OH - NY **2050 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 2050 MW

**SCH-NYISO-IMO\_LIMIT\_1600**

Mon 11/01/2021 to Fri 12/31/2021 **UPDATED by IESO 05/03/2019**  
 0001 Continuous 2359  
 Work scheduled by: IESO

REV  
 (Export)  
 SCH - OH - NY **1900 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 1900 MW

**MOSES\_\_-ADIRNDCK\_230\_MAI**

Wed 12/01/2021 to Tue 05/31/2022  
 0700 Continuous 1300  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW