

NYISO TRANSFER LIMITATIONS

Wednesday, October 14, 2020 to Friday, April 15, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_9_BYPASS & DUNWODIE_345KV_10_BYPASS & SPRNBRK__345KV_R5S3_BYPASS & SPRNBRK__345KV_R4S3_BYPASS

FWD
(Import)

Sun 02/01/2015 to Sun 11/01/2020
0000 2359

SPR/DUN-SOUTH **4350 MW**
Impacts Total Transfer Capability 250 MW
TTC with All Lines In Service 4600 MW

Work scheduled by:

DUNWODIE_345KV_9_BYPASS & DUNWODIE_345KV_10_BYPASS & SPRNBRK__345KV_R5S3_BYPASS & SPRNBRK__345KV_R4S3_BYPASS

Sun 02/01/2015 to Sun 11/01/2020
0000 2359

UPNY CONED
Impacts Total Transfer Capability
TTC with All Lines In Service

Work scheduled by:

HUDSONP_-FARRAGUT_345_B3402

FWD REV
(Import) (Export)

Mon 01/15/2018 to Sun 02/28/2021 **EXT FORCE by CONED 08/28/2020**
0001 Continuous 2359

SCH - PJ - NY **2050 MW 1150 MW**
Impacts Total Transfer Capability 150 MW 100 MW
TTC with All Lines In Service 2200 MW 1250 MW

Work scheduled by: ConEd

HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403

FWD REV
(Import) (Export)

Mon 01/15/2018 to Sun 02/28/2021
0001 2359

SCH - PJ - NY **2000 MW 1000 MW**
Impacts Total Transfer Capability 200 MW 250 MW
TTC with All Lines In Service 2200 MW 1250 MW

Work scheduled by:

MARION_-FARRAGUT_345_C3403

FWD REV
(Import) (Export)

Mon 01/15/2018 to Sun 02/28/2021 **EXT FORCE by CONED 08/28/2020**
0001 Continuous 2359

SCH - PJ - NY **2050 MW 1150 MW**
Impacts Total Transfer Capability 150 MW 100 MW
TTC with All Lines In Service 2200 MW 1250 MW

Work scheduled by: ConEd

STLAWRNC-MOSES__230_L33P

Mon 04/30/2018 to Mon 10/31/2022 **EXT FORCE by IESO 10/01/2020**
0456 Continuous 1600

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

Work scheduled by: IESO

NYISO TRANSFER LIMITATIONS

Wednesday, October 14, 2020 to Friday, April 15, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO-NYISO_LIMIT_1600					FWD	
Fri 05/01/2020	to	Sat 10/31/2020	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Import)
0001	Continuous	2359				1900 MW
Work scheduled by: IESO					SCH - OH - NY	Impacts Total Transfer Capability 50 MW
					TTC with All Lines In Service	1950 MW
SHOR_NPX-SHOREHAM_138_CSC					FWD	REV
Wed 07/08/2020	to	Wed 10/21/2020	<u>EXT FORCE</u>	<u>by LIPA</u>	<u>10/14/2020</u>	(Import) (Export)
1247	Continuous	0659				0 MW 0 MW
Work scheduled by: LI					SCH - NPX_CSC	Impacts Total Transfer Capability 330 MW 330 MW
					TTC with All Lines In Service	330 MW 330 MW
SPRNBRK_-W49TH_ST_345_M52					FWD	
Sun 08/16/2020	to	Sat 10/17/2020		<u>by CONED</u>	<u>10/13/2020</u>	(Import)
1149	Continuous	2359				3200 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service	4600 MW
BECK_-NIAGARA_230_PA27						
Mon 08/31/2020	to	Mon 11/30/2020				
0700	Continuous	0700				
Work scheduled by: IESO					SCH - OH - NY	Impacts Total Transfer Capability
					TTC with All Lines In Service	
SCH-IMO-NYISO_LIMIT_1450					FWD	
Mon 08/31/2020	to	Mon 11/30/2020				(Import)
0700	Continuous	0700				1750 MW
Work scheduled by: IESO					SCH - OH - NY	Impacts Total Transfer Capability 200 MW
					TTC with All Lines In Service	1950 MW
HOMRC_NY-MAINS_NY_345_47						
Tue 09/01/2020	to	Fri 10/09/2020				
0700	Continuous	1600				
Work scheduled by: PJM					SCH - PJ - NY	Impacts Total Transfer Capability
					TTC with All Lines In Service	
NEWBRDGE_345_138_BK_1					FWD	
Wed 09/02/2020	to	Thu 12/31/2020	<u>EXT FORCE</u>	<u>by LI</u>	<u>09/03/2020</u>	(Import)
1807	Continuous	2359				375 MW
Work scheduled by: LI					SCH - PJM_NEPTUNE	Impacts Total Transfer Capability 285 MW
					TTC with All Lines In Service	660 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 14, 2020 to Friday, April 15, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -ADIRNDCK_230_MA2						FWD
Wed 09/09/2020	to	Sat 11/14/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/04/2020</u>	(Import)
0700	Continuous	1300				MOSES SOUTH 2100 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 1050 MW
						TTC with All Lines In Service 3150 MW
SCH-IMO-NYISO_LIMIT_1350						FWD
Fri 09/18/2020	to	Sat 10/31/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/16/2020</u>	(Import)
0500	Continuous	2359				SCH - OH - NY 1650 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 300 MW
						TTC with All Lines In Service 1950 MW
NIAGARA -ROCHESTR_345_NR2						FWD
Fri 09/18/2020	to	Sat 11/14/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/16/2020</u>	(Import)
0500	Continuous	2330				DYSINGER EAST 1400 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 1750 MW
						TTC with All Lines In Service 3150 MW
NIAGARA_345KV_3108						REV
Fri 09/18/2020	to	Sat 11/14/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/16/2020</u>	(Export)
0500	Continuous	2330				SCH - OH - NY 1500 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 200 MW
						TTC with All Lines In Service 1700 MW
CHAT_DC_GC1						FWD
Sat 09/26/2020	to	Tue 10/20/2020	<u>UPDATED</u>	<u>by HQ</u>	<u>09/30/2020</u>	(Import)
2000	Continuous	2300				MOSES SOUTH 2850 MW
Work scheduled by: HQ						Impacts Total Transfer Capability 300 MW
						TTC with All Lines In Service 3150 MW
CHAT_DC_GC1						REV
Sat 09/26/2020	to	Tue 10/20/2020	<u>UPDATED</u>	<u>by HQ</u>	<u>09/30/2020</u>	(Export)
2000	Continuous	2300				SCH - HQ - NY 500 MW
Work scheduled by: HQ						Impacts Total Transfer Capability 500 MW
						TTC with All Lines In Service 1000 MW
SCH-NYISO-HQ_LIMIT_500						REV
Sun 09/27/2020	to	Tue 10/20/2020	<u>UPDATED</u>	<u>by HQ</u>	<u>09/30/2020</u>	(Export)
0500	Continuous	2300				SCH - HQ - NY 500 MW
Work scheduled by: HQ						Impacts Total Transfer Capability 500 MW
						TTC with All Lines In Service 1000 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 14, 2020 to Friday, April 15, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_5

Tue 09/29/2020 to Sat 10/17/2020
 0201 Continuous 2359
 Work scheduled by: ConEd

by CONED 10/13/2020

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

SPRNBRK_345KV_RNS4

Thu 10/01/2020 to Sat 10/17/2020
 0001 Continuous 2359
 Work scheduled by: ConEd

by CONED 10/13/2020

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

SPRNBRK_-EGRDNCTR_345_Y49

Thu 10/01/2020 to Sat 10/24/2020
 0404 Continuous 2359
 Work scheduled by: LI

UPDATED by LI 10/11/2020

FWD
 (Import)
 CONED - LIPA **775 MW**
 Impacts Total Transfer Capability 725 MW
 TTC with All Lines In Service 1500 MW

SCH-HQ-NYISO_LIMIT_1150

Fri 10/02/2020 to Fri 10/09/2020
 0915 Continuous 1730
 Work scheduled by: NYPA

UPDATED by NYPA 10/09/2020

FWD
 (Import)
 SCH - HQ - NY **1150 MW**
 Impacts Total Transfer Capability 350 MW
 TTC with All Lines In Service 1500 MW

PANNELL_-CLAY_345_1

Mon 10/05/2020 to Fri 10/09/2020
 0700 Continuous 1530
 Work scheduled by: NYPA

UPDATED by NYPA 05/07/2020

FWD
 (Import)
 WEST CENTRAL **1300 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

EGRDNCTY_345_138_AT2

Sat 10/10/2020 to Sat 10/24/2020
 1815 Continuous 2359
 Work scheduled by: LI

UPDATED by LI 10/11/2020

FWD
 (Import)
 CONED - LIPA **1250 MW**
 Impacts Total Transfer Capability 250 MW
 TTC with All Lines In Service 1500 MW

EGRDNCTY_345_138_AT1

Sat 10/10/2020 to Sat 10/24/2020
 1856 Continuous 2359
 Work scheduled by: LI

UPDATED by LI 10/11/2020

FWD
 (Import)
 CONED - LIPA **1250 MW**
 Impacts Total Transfer Capability 250 MW
 TTC with All Lines In Service 1500 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 14, 2020 to Friday, April 15, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HOMR_NYW-PIERC_NY_345_48

Mon 10/12/2020 to Fri 10/30/2020 **UPDATED** by **PJM** 10/09/2020
 0800 Continuous 1600
 Work scheduled by: PJM

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

HURLYAVE-ROSETON_345_303

Tue 10/13/2020 to Fri 10/16/2020 **UPDATED** by **CHGE** 09/10/2020
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4100 MW**
 Impacts Total Transfer Capability 2120 MW
 TTC with All Lines In Service 6220 MW

ALCOA_PA_115KV_R8105

Wed 10/14/2020 to Wed 10/14/2020 **UPDATED** by **NGRID** 10/12/2020
 0700 Daily(No Weekends) 1400
 Work scheduled by: NGrid

FWD
 (Import)
 MOSES SOUTH **3100 MW**
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 3150 MW

SPRNBRK_345KV_RNS3

Thu 10/15/2020 to Thu 10/15/2020 **CANCELLED** by **ConEd** 10/13/2020
 0301 Continuous 0330
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_3

Sat 10/17/2020 to Tue 11/24/2020 **UPDATED** by **CONED** 10/14/2020
 0001 Continuous 0159
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_4

Sat 10/17/2020 to Tue 11/24/2020 **UPDATED** by **CONED** 10/14/2020
 0001 Continuous 0159
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

PLSNTVLE-DUNWODIE_345_W89

Sat 10/17/2020 to Tue 11/24/2020 **UPDATED** by **CONED** 10/14/2020
 0001 Continuous 0159
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 2220 MW
 TTC with All Lines In Service 6220 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 14, 2020 to Friday, April 15, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD_345KV_18					FWD
Mon 10/19/2020	to	Mon 10/19/2020			(Import)
0001	Continuous	0030		UPNY CONED	4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1870 MW
					TTC with All Lines In Service 6220 MW
SPRNBRK_345KV_RNS3					FWD
Mon 10/19/2020	to	Mon 10/19/2020			(Import)
0001	Continuous	0030		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
DUNWODIE-MOTTHAVN_345_71					FWD
Mon 10/19/2020	to	Tue 10/20/2020	UPDATED	by CONED	10/14/2020
0001	Continuous	0159			
Work scheduled by: ConEd					SPR/DUN-SOUTH 3800 MW
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_5					FWD
Mon 10/19/2020	to	Tue 10/20/2020	UPDATED	by CONED	10/14/2020
0001	Continuous	0159			
Work scheduled by: ConEd					SPR/DUN-SOUTH 3800 MW
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
SAND_BAR-PLATSBURG_115_PV20					FWD
Mon 10/19/2020	to	Fri 11/13/2020	UPDATED	by ISONE	10/08/2020
0600	Continuous	1800			
Work scheduled by: ISONE					SCH - NE - NY
					Impacts Total Transfer Capability
					TTC with All Lines In Service
SCH-NE-NYISO_LIMIT_600					FWD
Mon 10/19/2020	to	Sat 10/31/2020	UPDATED	by ISONE	06/05/2020
0630	Continuous	2359			
Work scheduled by: NGrid					SCH - NE - NY 800 MW
					Impacts Total Transfer Capability 600 MW
					TTC with All Lines In Service 1400 MW
SCH-NYISO-NE_LIMIT_800					REV
Mon 10/19/2020	to	Sat 10/31/2020	UPDATED	by ISONE	06/05/2020
0630	Continuous	2359			
Work scheduled by: NGrid					SCH - NE - NY 1000 MW
					Impacts Total Transfer Capability 600 MW
					TTC with All Lines In Service 1600 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 14, 2020 to Friday, April 15, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-ALPS _____ 345_393						FWD	REV
Mon 10/19/2020	to	Tue 11/10/2020	UPDATED	by ISONE	06/05/2020	(Import)	(Export)
0630	Continuous	1630				950 MW	1300 MW
Work scheduled by: NGrid							
						Impacts Total Transfer Capability	450 MW 300 MW
						TTC with All Lines In Service	1400 MW 1600 MW
BERKSHIR-ALPS _____ 345_393						FWD	REV
Mon 10/19/2020	to	Tue 11/10/2020	UPDATED	by ISONE	06/05/2020	(Import)	(Export)
0630	Continuous	1630				100 MW	100 MW
Work scheduled by: NGrid							
						Impacts Total Transfer Capability	100 MW 100 MW
						TTC with All Lines In Service	200 MW 200 MW
BERKSHIR-ALPS _____ 345_393 & BERKSHIR-NORTHFLD 345_312						FWD	REV
Mon 10/19/2020	to	Tue 11/10/2020				(Import)	(Export)
0630		1630				950 MW	1300 MW
Work scheduled by:							
						Impacts Total Transfer Capability	450 MW 300 MW
						TTC with All Lines In Service	1400 MW 1600 MW
BERKSHIR-NORTHFLD 345_312						FWD	REV
Mon 10/19/2020	to	Tue 11/10/2020	UPDATED	by ISONE	06/05/2020	(Import)	(Export)
0630	Continuous	1630				900 MW	1500 MW
Work scheduled by: NGrid							
						Impacts Total Transfer Capability	500 MW 100 MW
						TTC with All Lines In Service	1400 MW 1600 MW
BERKSHIR-NORTHFLD 345_312						FWD	REV
Mon 10/19/2020	to	Tue 11/10/2020	UPDATED	by ISONE	06/05/2020	(Import)	(Export)
0630	Continuous	1630				100 MW	100 MW
Work scheduled by: NGrid							
						Impacts Total Transfer Capability	100 MW 100 MW
						TTC with All Lines In Service	200 MW 200 MW
SHOR_NPX-SHOREHAM 138_CSC						FWD	REV
Mon 10/19/2020	to	Fri 10/23/2020	CANCELLED	by LI	10/09/2020	(Import)	(Export)
0700	Continuous	1500				0 MW	0 MW
Work scheduled by: LI							
						Impacts Total Transfer Capability	330 MW 330 MW
						TTC with All Lines In Service	330 MW 330 MW
PANNELL_-CLAY _____ 345_2						FWD	
Mon 10/19/2020	to	Fri 10/23/2020	UPDATED	by NYPA	05/07/2020	(Import)	
0700	Continuous	1530				1300 MW	
Work scheduled by: NYPA							
						WEST CENTRAL	1300 MW
						Impacts Total Transfer Capability	950 MW
						TTC with All Lines In Service	2250 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 14, 2020 to Friday, April 15, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

COOPERS_-DOLSONAV_345_CCDA42

Mon 10/19/2020 to Fri 11/06/2020
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2720 MW**
Impacts Total Transfer Capability 255 MW
TTC with All Lines In Service 2975 MW

BRANCHBG-HOPATCON_500_5060

Tue 10/20/2020 to Tue 10/20/2020 UPDATED by PJM 10/07/2020
0200 Continuous 1500

Work scheduled by: PJM

FWD
(Import)
UPNY CONED **6025 MW**
Impacts Total Transfer Capability 195 MW
TTC with All Lines In Service 6220 MW

W49TH_ST_345KV_6

Tue 10/20/2020 to Tue 10/20/2020 UPDATED by CONED 10/14/2020
0331 Continuous 0400

Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **300 MW**
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

E13THSTA-FARRAGUT_345_46

Tue 10/20/2020 to Tue 10/20/2020 UPDATED by CONED 10/14/2020
0331 Continuous 2300

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

W49TH_ST-E13THSTA_345_M55

Tue 10/20/2020 to Tue 10/20/2020 UPDATED by CONED 10/14/2020
0331 Continuous 2300

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

W49TH_ST_345KV_6

Tue 10/20/2020 to Tue 10/20/2020 UPDATED by CONED 10/14/2020
2230 Continuous 2300

Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **300 MW**
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

MILLWOOD_345KV_18

Fri 10/23/2020 to Fri 10/23/2020
2130 Continuous 2200

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1870 MW
TTC with All Lines In Service 6220 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 14, 2020 to Friday, April 15, 2022

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONTP-W49TH_ST_345_Y56

Sat 10/24/2020 to Fri 10/30/2020
0001 Continuous 0300

Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **0 MW**
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

W49TH_ST_345KV_7

Sat 10/24/2020 to Fri 10/30/2020
0001 Continuous 0300

Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **300 MW**
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

W49TH_ST_345KV_8

Sat 10/24/2020 to Fri 10/30/2020
0001 Continuous 0300

Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **450 MW**
Impacts Total Transfer Capability 210 MW
TTC with All Lines In Service 660 MW

SPRNBK_-TREMONT_345_X28

Mon 10/26/2020 to Mon 10/26/2020
0001 Continuous 0030

Work scheduled by: ConEd

UPDATED by CONED 10/10/2020

FWD
(Import)
SPR/DUN-SOUTH **4200 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 4600 MW

LEEDS_345_LEEDS SVC

Mon 10/26/2020 to Fri 10/30/2020
0800 Continuous 1600

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **2950 MW**
Impacts Total Transfer Capability 25 MW
TTC with All Lines In Service 2975 MW

LEEDS_345KV_R94301

Mon 10/26/2020 to Wed 11/25/2020
0800 Continuous 1600

Work scheduled by: NGrid

FWD
(Import)
UPNY CONED **3800 MW**
Impacts Total Transfer Capability 2420 MW
TTC with All Lines In Service 6220 MW

LEEDS_-HURLYAVE_345_301

Mon 10/26/2020 to Fri 12/04/2020
0800 Continuous 1600

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 2120 MW
TTC with All Lines In Service 6220 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 14, 2020 to Friday, April 15, 2022

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>SCRIBA__ -VOLNEY__ 345_21</p> <p>Wed 10/28/2020 to Wed 10/28/2020</p> <p style="padding-left: 40px;">0800 Daily(No Weekends) 1630</p> <p>Work scheduled by: NGrid</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>OSWEGO EXPORT 5250 MW</p> <p>Impacts Total Transfer Capability 0 MW</p> <p>TTC with All Lines In Service 5250 MW</p>
<p>W49TH_ST_345KV_5</p> <p>Fri 10/30/2020 to Sat 10/31/2020 UPDATED by CONED 10/11/2020</p> <p style="padding-left: 40px;">0301 Continuous 0300</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>SCH - PJM_HTP 300 MW</p> <p>Impacts Total Transfer Capability 360 MW</p> <p>TTC with All Lines In Service 660 MW</p>
<p>W49TH_ST_345KV_7</p> <p>Fri 10/30/2020 to Sat 10/31/2020 UPDATED by CONED 10/11/2020</p> <p style="padding-left: 40px;">0301 Continuous 0300</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>SCH - PJM_HTP 300 MW</p> <p>Impacts Total Transfer Capability 360 MW</p> <p>TTC with All Lines In Service 660 MW</p>
<p>SPRNBRK__345KV_RS3 & SPRNBRK__345KV_RS4</p> <p>Sat 10/31/2020 to Sat 10/31/2020</p> <p style="padding-left: 40px;">0001 0030</p> <p>Work scheduled by:</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>SPR/DUN-SOUTH 3200 MW</p> <p>Impacts Total Transfer Capability 1400 MW</p> <p>TTC with All Lines In Service 4600 MW</p>
<p>SCH-NE-NYISO_LIMIT_800</p> <p>Sun 11/01/2020 to Tue 11/10/2020 UPDATED by ISONE 06/05/2020</p> <p style="padding-left: 40px;">0001 Continuous 1630</p> <p>Work scheduled by: NGrid</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>SCH - NE - NY 1000 MW</p> <p>Impacts Total Transfer Capability 400 MW</p> <p>TTC with All Lines In Service 1400 MW</p>
<p>SCH-NYISO-NE_LIMIT_700</p> <p>Sun 11/01/2020 to Tue 11/10/2020 UPDATED by ISONE 06/05/2020</p> <p style="padding-left: 40px;">0001 Continuous 1630</p> <p>Work scheduled by: NGrid</p>	<p style="text-align: right;">REV</p> <p style="text-align: right;">(Export)</p> <p>SCH - NE - NY 900 MW</p> <p>Impacts Total Transfer Capability 800 MW</p> <p>TTC with All Lines In Service 1700 MW</p>
<p>SCH-IMO-NYISO_LIMIT_1750</p> <p>Sun 11/01/2020 to Fri 04/30/2021 UPDATED by IESO 05/03/2019</p> <p style="padding-left: 40px;">0001 Continuous 2359</p> <p>Work scheduled by: IESO</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>SCH - OH - NY 2050 MW</p> <p>Impacts Total Transfer Capability 0 MW</p> <p>TTC with All Lines In Service 2050 MW</p>

NYISO TRANSFER LIMITATIONS

Wednesday, October 14, 2020 to Friday, April 15, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-IMO_LIMIT_1600						REV
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Export)
0001	Continuous	2359				1900 MW
Work scheduled by: IESO						Impacts Total Transfer Capability 0 MW
						TTC with All Lines In Service 1900 MW
SPRNBK_345KV_RS3 & SPRNBK_345KV_RS4						FWD
Sun 11/01/2020	to	Sun 11/01/2020				(Import)
0130		0200				3800 MW
Work scheduled by:						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
EGRDNCTY_345_138_AT1						FWD
Sun 11/01/2020	to	Fri 11/13/2020				(Import)
0800	Continuous	2159				1250 MW
Work scheduled by: LI						Impacts Total Transfer Capability 250 MW
						TTC with All Lines In Service 1500 MW
EGRDNCTY_345_138_AT2						FWD
Sun 11/01/2020	to	Fri 11/13/2020				(Import)
0800	Continuous	2159				1250 MW
Work scheduled by: LI						Impacts Total Transfer Capability 250 MW
						TTC with All Lines In Service 1500 MW
SPRNBK_-EGRDNCTR_345_Y49						FWD
Sun 11/01/2020	to	Fri 11/13/2020				(Import)
0800	Continuous	2159				775 MW
Work scheduled by: LI						Impacts Total Transfer Capability 725 MW
						TTC with All Lines In Service 1500 MW
S.RIPLEY-DUNKIRK_230_68						
Mon 11/02/2020	to	Fri 11/20/2020	<u>UPDATED</u>	<u>by PJM</u>	<u>09/28/2020</u>	
0700	Continuous	1800				
Work scheduled by: NGrid						SCH - PJ - NY
						Impacts Total Transfer Capability
						TTC with All Lines In Service
DUNWODIE_345KV_9_BYPASS & DUNWODIE_345KV_10_BYPASS & SPRNBK_345KV_R5S3_BYPASS & SPRNBK_345KV_R4S3_BYPASS						FWD
Mon 11/02/2020	to	Sat 02/01/2025				(Import)
1800		0000				4350 MW
Work scheduled by:						Impacts Total Transfer Capability 250 MW
						TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 14, 2020 to Friday, April 15, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_9_BYPASS & DUNWODIE_345KV_10_BYPASS & SPRNBRK__345KV_R5S3_BYPASS & SPRNBRK__345KV_R4S3_BYPASS

Mon 11/02/2020 to Sat 02/01/2025
1800 0000

Work scheduled by:

UPNY CONED
Impacts Total Transfer Capability
TTC with All Lines In Service

SPRNBRK_-TREMONT__345_X28

Fri 11/06/2020 to Sat 11/07/2020
0001 Continuous 0059

Work scheduled by: ConEd

UPDATED by CONED 10/10/2020

FWD
(Import)
SPR/DUN-SOUTH **4200 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 4600 MW

NIAGARA__345KV_3102

Fri 11/06/2020 to Fri 11/06/2020
0500 Continuous 2100

Work scheduled by: NYPA

FWD REV
(Import) (Export)
SCH - OH - NY **2000 MW 1700 MW**
Impacts Total Transfer Capability 50 MW 200 MW
TTC with All Lines In Service 2050 MW 1900 MW

NIAGARA__345_230_AT4

Fri 11/06/2020 to Fri 11/06/2020
0500 Continuous 2100

Work scheduled by: NYPA

REV
(Export)
SCH - OH - NY **1750 MW**
Impacts Total Transfer Capability 150 MW
TTC with All Lines In Service 1900 MW

SPRNBRK_-TREMONT__345_X28

Mon 11/09/2020 to Mon 11/09/2020
0030 Continuous 0059

Work scheduled by: ConEd

UPDATED by CONED 10/10/2020

FWD
(Import)
SPR/DUN-SOUTH **4200 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 4600 MW

ROSETON_-ROCKTVRN_345_311

Mon 11/09/2020 to Fri 11/20/2020
0800 Continuous 1600

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4400 MW**
Impacts Total Transfer Capability 1820 MW
TTC with All Lines In Service 6220 MW

DUNWODIE-MOTTHAVN_345_71

Thu 11/12/2020 to Thu 11/12/2020
0001 Continuous 0030

Work scheduled by: ConEd

UPDATED by CONED 10/14/2020

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 14, 2020 to Friday, April 15, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_5				FWD
Thu 11/12/2020	to	Fri 11/13/2020	UPDATED	(Import)
0001	Continuous	0100	by CONED	10/14/2020
Work scheduled by: ConEd				SPR/DUN-SOUTH 3800 MW
				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
DUNWODIE-MOTTHAVN_345_71				FWD
Fri 11/13/2020	to	Fri 11/13/2020	UPDATED	(Import)
0030	Continuous	0100	by CONED	10/14/2020
Work scheduled by: ConEd				SPR/DUN-SOUTH 3800 MW
				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
CHATGUAY-MASSENA_765_7040				FWD
Sun 11/15/2020	to	Mon 11/30/2020		(Import)
0100	Continuous	1900		MOSES SOUTH 1550 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 1600 MW
				TTC with All Lines In Service 3150 MW
CHATGUAY-MASSENA_765_7040				FWD
Sun 11/15/2020	to	Mon 11/30/2020		REV (Import) (Export)
0100	Continuous	1900		SCH - HQ - NY 0 MW 0 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 1500 MW 1000 MW
				TTC with All Lines In Service 1500 MW 1000 MW
MARCY___765_345_AT1				FWD
Sun 11/15/2020	to	Mon 11/30/2020		(Import)
0100	Continuous	1900		MOSES SOUTH 1750 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 3150 MW
				ARR: 19
MARCY___765_345_AT2				FWD
Sun 11/15/2020	to	Mon 11/30/2020		(Import)
0100	Continuous	1900		MOSES SOUTH 1700 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 1450 MW
				TTC with All Lines In Service 3150 MW
				ARR: 19
MASSENA_-MARCY___765_MSU1				FWD
Sun 11/15/2020	to	Mon 11/30/2020		(Import)
0100	Continuous	1900		CENTRAL EAST - VC 2265 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 710 MW
				TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 14, 2020 to Friday, April 15, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Zone	Start	End	Time	Day	Impact	TTC	FWD	REV
MASSENA -MARCY 765_MSU1	Sun 11/15/2020	Mon 11/30/2020	0100	Continuous	1900	MOSES SOUTH	500 MW	
Work scheduled by: NYPA						Impacts Total Transfer Capability	2650 MW	
						TTC with All Lines In Service	3150 MW	
MASSENA -MARCY 765_MSU1	Sun 11/15/2020	Mon 11/30/2020	0100	Continuous	1900	SCH - HQ - NY	475 MW	1000 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	1025 MW	0 MW
						TTC with All Lines In Service	1500 MW	1000 MW
MASSENA -MARCY 765_MSU1	Sun 11/15/2020	Mon 11/30/2020	0100	Continuous	1900	SCH - HQ_CEDARS	90 MW	
Work scheduled by: NYPA						Impacts Total Transfer Capability	109 MW	
						TTC with All Lines In Service	199 MW	
MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040	Sun 11/15/2020	Mon 11/30/2020	0100		1900	MOSES SOUTH	500 MW	
Work scheduled by:						Impacts Total Transfer Capability	2650 MW	
						TTC with All Lines In Service	3150 MW	
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2	Sun 11/15/2020	Mon 11/30/2020	0100		1900	SCH - HQ - NY	850 MW	0 MW
Work scheduled by:						Impacts Total Transfer Capability	650 MW	1000 MW
						TTC with All Lines In Service	1500 MW	1000 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2	Sun 11/15/2020	Mon 11/30/2020	0100		1900	SCH - HQ_CEDARS	90 MW	
Work scheduled by:						Impacts Total Transfer Capability	109 MW	
						TTC with All Lines In Service	199 MW	
STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1	Sun 11/15/2020	Mon 11/30/2020	0100		1900	SCH - HQ_CEDARS	90 MW	
Work scheduled by:						Impacts Total Transfer Capability	109 MW	
						TTC with All Lines In Service	199 MW	

NYISO TRANSFER LIMITATIONS

Wednesday, October 14, 2020 to Friday, April 15, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STLAWRNC-MOSES 230_L33P & MOSES -MASSENA 230_MMS1 & MOSES -				FWD
MASSENA 230_MMS2				(Import)
Sun 11/15/2020	to	Mon 11/30/2020		SCH - HQ_CEDARS 90 MW
0100		1900		Impacts Total Transfer Capability 109 MW
				TTC with All Lines In Service 199 MW
Work scheduled by:				
W49TH_ST_345KV_5				FWD
				(Import)
Tue 11/17/2020	to	Tue 11/17/2020		SCH - PJM_HTP 300 MW
0001	Continuous	0030		Impacts Total Transfer Capability 360 MW
Work scheduled by: ConEd				TTC with All Lines In Service 660 MW
W49TH_ST_345KV_7				FWD
				(Import)
Tue 11/17/2020	to	Tue 11/17/2020		SCH - PJM_HTP 300 MW
0001	Continuous	0030		Impacts Total Transfer Capability 360 MW
Work scheduled by: ConEd				TTC with All Lines In Service 660 MW
W49TH_ST_345KV_5				FWD
				(Import)
Thu 11/19/2020	to	Thu 11/19/2020		SCH - PJM_HTP 300 MW
1830	Continuous	1900		Impacts Total Transfer Capability 360 MW
Work scheduled by: ConEd				TTC with All Lines In Service 660 MW
W49TH_ST_345KV_7				FWD
				(Import)
Thu 11/19/2020	to	Thu 11/19/2020		SCH - PJM_HTP 300 MW
1830	Continuous	1900		Impacts Total Transfer Capability 360 MW
Work scheduled by: ConEd				TTC with All Lines In Service 660 MW
W49TH_ST_345KV_6				FWD
				(Import)
Fri 11/20/2020	to	Wed 11/25/2020	<u>UPDATED by CE 08/06/2020</u>	SCH - PJM_HTP 300 MW
0001	Continuous	2300		Impacts Total Transfer Capability 360 MW
Work scheduled by: ConEd				TTC with All Lines In Service 660 MW
W49TH_ST_345KV_8				FWD
				(Import)
Fri 11/20/2020	to	Wed 11/25/2020	<u>UPDATED by CE 08/06/2020</u>	SCH - PJM_HTP 300 MW
0001	Continuous	2300		Impacts Total Transfer Capability 360 MW
Work scheduled by: ConEd				TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 14, 2020 to Friday, April 15, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_-TREMONT__345_X28						FWD
Sat 11/21/2020	to	Sun 11/22/2020	<u>UPDATED</u>	<u>by CE</u>	<u>10/09/2020</u>	(Import)
0101	Continuous	0300				SPR/DUN-SOUTH 4200 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 400 MW
						TTC with All Lines In Service 4600 MW
BUCHAN_N-EASTVIEW_345_W93						FWD
Sun 11/22/2020	to	Sun 11/22/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>10/09/2020</u>	(Import)
0301	Continuous	0330				UPNY CONED 4350 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 1870 MW
						TTC with All Lines In Service 6220 MW
EASTVIEW-SPRNBK__345_W79						FWD
Sun 11/22/2020	to	Mon 11/23/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>10/09/2020</u>	(Import)
0301	Continuous	0200				UPNY CONED 4350 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 1870 MW
						TTC with All Lines In Service 6220 MW
BUCHAN_N-EASTVIEW_345_W93						FWD
Mon 11/23/2020	to	Mon 11/23/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>10/09/2020</u>	(Import)
0130	Continuous	0200				UPNY CONED 4350 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 1870 MW
						TTC with All Lines In Service 6220 MW
MOTHAVN-RAINEY__345_Q12						FWD
Sat 11/28/2020	to	Thu 12/03/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>10/09/2020</u>	(Import)
0201	Continuous	0159				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
DOLSONAV-ROCKTVRN_345_DART44						FWD
Mon 11/30/2020	to	Mon 12/14/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/27/2020</u>	(Import)
0700	Continuous	1730				CENTRAL EAST - VC 2720 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 255 MW
						TTC with All Lines In Service 2975 MW
NEPTUNE_-DUFFYAVE_345_NEPTUNE						FWD
Mon 11/30/2020	to	Fri 12/11/2020		<u>by LI</u>	<u>09/14/2020</u>	(Import)
0800	Continuous	1600				SCH - PJM_NEPTUNE 0 MW
Work scheduled by: PJM						Impacts Total Transfer Capability 660 MW
						TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 14, 2020 to Friday, April 15, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE-DUFFYAVE_345_501

Mon 11/30/2020 to Fri 12/11/2020
 0800 Continuous 1600

by LI 09/14/2020

Work scheduled by: PJM

FWD
(Import)

SCH - PJM_NEPTUNE **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

MARCY_345KV_CSC

Tue 12/01/2020 to Fri 12/11/2020
 0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)

CENTRAL EAST - VC **2925 MW**
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 2975 MW

MOSES-ADIRNDCK_230_MA1

Tue 12/01/2020 to Sat 02/27/2021
 0700 Continuous 1730

UPDATED by NYPA 07/27/2020

Work scheduled by: NYPA

FWD
(Import)

MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

LAFAYTTE-CLRKSCRN_345_4-46

Tue 12/01/2020 to Tue 12/01/2020
 0730 Daily(No Weekends) 1230

UPDATED by NGRID 10/05/2020

Work scheduled by: NGrid

FWD
(Import)

CENTRAL EAST - VC **2650 MW**
 Impacts Total Transfer Capability 325 MW
 TTC with All Lines In Service 2975 MW

W49TH_ST_345KV_6

Tue 12/01/2020 to Tue 12/01/2020
 2230 Continuous 2300

UPDATED by CE 08/06/2020

Work scheduled by: ConEd

FWD
(Import)

SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

W49TH_ST_345KV_8

Tue 12/01/2020 to Tue 12/01/2020
 2230 Continuous 2300

UPDATED by CE 08/06/2020

Work scheduled by: ConEd

FWD
(Import)

SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

MOTTHAVN-RAINEY_345_Q11

Thu 12/03/2020 to Tue 12/08/2020
 0201 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)

SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 14, 2020 to Friday, April 15, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

KINTIGH_-ROCHESTR_345_SR1-39				FWD
Thu 12/03/2020	to	Tue 12/15/2020	UPDATED	(Import)
0800	Continuous	1900	by NYISO	1700 MW
Work scheduled by: RGE				Impacts Total Transfer Capability 1450 MW
				TTC with All Lines In Service 3150 MW
NIAGARA_-KINTIGH_345_NS1-38				FWD
Thu 12/03/2020	to	Tue 12/15/2020	UPDATED	(Import)
0800	Continuous	1900	by NYISO	1700 MW
Work scheduled by: RGE				Impacts Total Transfer Capability 1450 MW
				TTC with All Lines In Service 3150 MW
BECK_-PACKARD_230_BP76				FWD
Fri 12/04/2020	to	Fri 12/04/2020		(Import) (Export)
0730	Daily(No Weekends)	1530		1650 MW 1400 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 400 MW 500 MW
				TTC with All Lines In Service 2050 MW 1900 MW
OSWEGO_COMPLEX_AVR_O/S				FWD
Sun 12/06/2020	to	Sun 12/06/2020		(Import)
0900	Continuous	0930		2870 MW
Work scheduled by: Gen				Impacts Total Transfer Capability 105 MW
				TTC with All Lines In Service 2975 MW
SAND_BAR-PLATSBURG_115_PV20				
Mon 12/07/2020	to	Fri 12/11/2020		SCH - NE - NY
0700	Continuous	1530		Impacts Total Transfer Capability
Work scheduled by: NYPA				TTC with All Lines In Service
LONG_MTN-CRICKVLY_345_398				FWD
Tue 12/08/2020	to	Thu 12/10/2020		(Import) (Export)
0700	Continuous	1600		700 MW 1300 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability 700 MW 400 MW
				TTC with All Lines In Service 1400 MW 1700 MW
LONG_MTN-CRICKVLY_345_398				FWD
Tue 12/08/2020	to	Thu 12/10/2020		(Import) (Export)
0700	Continuous	1600		100 MW 100 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability 100 MW 100 MW
				TTC with All Lines In Service 200 MW 200 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 14, 2020 to Friday, April 15, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_400					FWD
Tue 12/08/2020	to	Thu 12/10/2020			(Import)
0700	Continuous	1600			SCH - NE - NY 600 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 1400 MW
SCH-NYISO-NE_LIMIT_1000					REV
Tue 12/08/2020	to	Thu 12/10/2020			(Export)
0700	Continuous	1600			SCH - NE - NY 1200 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability 500 MW
					TTC with All Lines In Service 1700 MW
BUCHAN_N-EASTVIEW_345_W93					FWD
Sat 12/12/2020	to	Tue 12/15/2020	<u>UPDATED</u>	<u>by CE</u>	<u>09/17/2020</u>
0001	Continuous	0259			UPNY CONED 4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1870 MW
					TTC with All Lines In Service 6220 MW
EASTVIEW-SPRNBK__345_W79					FWD
Sat 12/12/2020	to	Tue 12/15/2020	<u>UPDATED</u>	<u>by CE</u>	<u>09/17/2020</u>
0001	Continuous	0259			UPNY CONED 4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1870 MW
					TTC with All Lines In Service 6220 MW
MARCY__-EDIC____345_UE1-7					FWD
Mon 12/14/2020	to	Mon 12/14/2020			(Import)
0700	Continuous	1730			OSWEGO EXPORT 5250 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 0 MW
					TTC with All Lines In Service 5250 MW
SAND_BAR-PLATSBRG_115_PV20					
Mon 12/14/2020	to	Fri 12/18/2020			SCH - NE - NY
0700	Continuous	1530			Impacts Total Transfer Capability
Work scheduled by: NYPA					TTC with All Lines In Service
LADENTWN-BUCHAN_S_345_Y88					FWD
Tue 12/15/2020	to	Sat 01/30/2021	<u>UPDATED</u>	<u>by CE</u>	<u>10/05/2020</u>
0300	Continuous	0300			UPNY CONED 5930 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 290 MW
					TTC with All Lines In Service 6220 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 14, 2020 to Friday, April 15, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASANX-COOPERS__345_UCC2-41				FWD	
Tue 12/15/2020	to	Wed 12/16/2020		(Import)	
0700	Continuous	1530		CENTRAL EAST - VC	2500 MW
Work scheduled by: NYPA			ARR: 19	Impacts Total Transfer Capability	475 MW
				TTC with All Lines In Service	2975 MW
MARCY__-FRASANX_345_UCC2-41				FWD	
Tue 12/15/2020	to	Wed 12/16/2020		(Import)	
0700	Continuous	1530		CENTRAL EAST - VC	2500 MW
Work scheduled by: NYPA			ARR: 19	Impacts Total Transfer Capability	475 MW
				TTC with All Lines In Service	2975 MW
STONYRDG-HILLSIDE_230_72				FWD	
Wed 12/16/2020	to	Mon 12/21/2020		(Import)	
0800	Continuous	0300		DYSINGER EAST	2850 MW
Work scheduled by: NYSEG				Impacts Total Transfer Capability	300 MW
				TTC with All Lines In Service	3150 MW
N.SCTLND-LEEDS__345_93				FWD	
Thu 12/17/2020	to	Fri 12/18/2020		(Import)	
0800	Continuous	1500		CENTRAL EAST - VC	2650 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	325 MW
				TTC with All Lines In Service	2975 MW
SPRNBRK_-TREMONT__345_X28				FWD	
Tue 12/22/2020	to	Fri 12/25/2020	by CE 10/09/2020	(Import)	
0301	Continuous	0300		SPR/DUN-SOUTH	4200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	400 MW
				TTC with All Lines In Service	4600 MW
SPRNBRK_-TREMONT__345_X28				FWD	
Sun 12/27/2020	to	Sun 12/27/2020	by CE 10/09/2020	(Import)	
2130	Continuous	2200		SPR/DUN-SOUTH	4200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	400 MW
				TTC with All Lines In Service	4600 MW
HOPATCON-RAMAPO__500_5018				FWD	REV
Mon 02/01/2021	to	Sat 02/06/2021	CANCELLED by ConEd 10/13/2020	(Import)	(Export)
0001	Continuous	0200		SCH - PJ - NY	1250 MW 1200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	1650 MW 650 MW
				TTC with All Lines In Service	2900 MW 1850 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 14, 2020 to Friday, April 15, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HOPATCON-RAMAPO__500_5018				FWD	
Mon 02/01/2021	to	Sat 02/06/2021	CANCELLED by ConEd 10/13/2020	(Import)	
0001	Continuous	0200		UPNY CONED	6025 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	195 MW
				TTC with All Lines In Service	6220 MW
RAMAPO__345_345_PAR3500				FWD	REV
Mon 02/01/2021	to	Sat 02/06/2021	CANCELLED by ConEd 10/13/2020	(Import)	(Export)
0001	Continuous	0200		SCH - PJ - NY	2150 MW 1250 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	750 MW 600 MW
				TTC with All Lines In Service	2900 MW 1850 MW
RAMAPO__345_345_PAR4500				FWD	REV
Mon 02/01/2021	to	Sat 02/06/2021	CANCELLED by ConEd 10/13/2020	(Import)	(Export)
0001	Continuous	0200		SCH - PJ - NY	2150 MW 1250 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	750 MW 600 MW
				TTC with All Lines In Service	2900 MW 1850 MW
RAMAPO__500_345_BK 1500				FWD	REV
Mon 02/01/2021	to	Sat 02/06/2021	CANCELLED by ConEd 10/13/2020	(Import)	(Export)
0001	Continuous	0200		SCH - PJ - NY	1250 MW 1200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	1650 MW 650 MW
				TTC with All Lines In Service	2900 MW 1850 MW
RAMAPO__500_345_BK 1500				FWD	
Mon 02/01/2021	to	Sat 02/06/2021	CANCELLED by ConEd 10/13/2020	(Import)	
0001	Continuous	0200		UPNY CONED	6025 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	195 MW
				TTC with All Lines In Service	6220 MW
PORTER__-ROTTRDAM 230_31				FWD	
Mon 02/01/2021	to	Sat 02/27/2021		(Import)	
0600	Continuous	1830		CENTRAL EAST - VC	2805 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	170 MW
				TTC with All Lines In Service	2975 MW
PLSNTVLY-WOOD_ST__345_F30				FWD	
Sun 02/14/2021	to	Tue 02/16/2021	UPDATED by CONED 09/28/2020	(Import)	
2000	Continuous	0200		UPNY CONED	4000 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	2220 MW
				TTC with All Lines In Service	6220 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 14, 2020 to Friday, April 15, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RNS5

Sun 02/14/2021 to Tue 02/16/2021
 2000 Continuous 0200
 Work scheduled by: ConEd

UPDATED by CONED 09/28/2020

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 2420 MW
 TTC with All Lines In Service 6220 MW

BERKSHIR-ALPS 345_393

Wed 02/17/2021 to Fri 02/19/2021
 0730 Continuous 1600
 Work scheduled by: NGrid

ARR: 78

FWD REV
 (Import) (Export)
 SCH - NE - NY **1150 MW 1700 MW**
 Impacts Total Transfer Capability 250 MW 0 MW
 TTC with All Lines In Service 1400 MW 1700 MW

BERKSHIR-ALPS 345_393

Wed 02/17/2021 to Fri 02/19/2021
 0730 Continuous 1600
 Work scheduled by: NGrid

ARR: 78

FWD REV
 (Import) (Export)
 SCH - NPX_1385 **100 MW 100 MW**
 Impacts Total Transfer Capability 100 MW 100 MW
 TTC with All Lines In Service 200 MW 200 MW

EFISHKIL-WOOD_ST 345_F39

Thu 02/18/2021 to Sat 02/20/2021
 2100 Continuous 0200
 Work scheduled by: ConEd

UPDATED by CE 04/01/2020

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 2220 MW
 TTC with All Lines In Service 6220 MW

WOOD_ST-PLSNTVLE 345_Y87

Thu 02/18/2021 to Sat 02/20/2021
 2100 Continuous 0200
 Work scheduled by: ConEd

UPDATED by CE 04/01/2020

FWD
 (Import)
 UPNY CONED **5905 MW**
 Impacts Total Transfer Capability 315 MW
 TTC with All Lines In Service 6220 MW

CHATGUAY-MASSENA 765_7040

Sun 02/28/2021 to Mon 03/01/2021
 0500 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **1550 MW**
 Impacts Total Transfer Capability 1600 MW
 TTC with All Lines In Service 3150 MW

CHATGUAY-MASSENA 765_7040

Sun 02/28/2021 to Mon 03/01/2021
 0500 Continuous 1730
 Work scheduled by: NYPA

FWD REV
 (Import) (Export)
 SCH - HQ - NY **0 MW 0 MW**
 Impacts Total Transfer Capability 1500 MW 1000 MW
 TTC with All Lines In Service 1500 MW 1000 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 14, 2020 to Friday, April 15, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA -MARCY 765_MSU1			FWD	
Sun 02/28/2021	to	Mon 03/01/2021	(Import)	
0500	Continuous	1730	CENTRAL EAST - VC	2265 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	710 MW
			TTC with All Lines In Service	2975 MW
MASSENA -MARCY 765_MSU1			FWD	
Sun 02/28/2021	to	Mon 03/01/2021	(Import)	
0500	Continuous	1730	MOSES SOUTH	500 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	2650 MW
			TTC with All Lines In Service	3150 MW
MASSENA -MARCY 765_MSU1			FWD	REV
Sun 02/28/2021	to	Mon 03/01/2021	(Import)	(Export)
0500	Continuous	1730	SCH - HQ - NY	475 MW 1000 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1025 MW 0 MW
			TTC with All Lines In Service	1500 MW 1000 MW
MASSENA -MARCY 765_MSU1			FWD	
Sun 02/28/2021	to	Mon 03/01/2021	(Import)	
0500	Continuous	1730	SCH - HQ_CEDARS	90 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	109 MW
			TTC with All Lines In Service	199 MW
MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040			FWD	
Sun 02/28/2021	to	Mon 03/01/2021	(Import)	
0500		1730	MOSES SOUTH	500 MW
Work scheduled by:			Impacts Total Transfer Capability	2650 MW
			TTC with All Lines In Service	3150 MW
STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1			FWD	
Sun 02/28/2021	to	Mon 03/01/2021	(Import)	
0500		1730	SCH - HQ_CEDARS	90 MW
Work scheduled by:			Impacts Total Transfer Capability	109 MW
			TTC with All Lines In Service	199 MW
DUNWODIE_345KV_3			FWD	
Mon 03/01/2021	to	Mon 03/01/2021	(Import)	
0001	Continuous	0030	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 14, 2020 to Friday, April 15, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_5					FWD
Mon 03/01/2021	to	Mon 03/01/2021			(Import)
0001	Continuous	0030		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
EASTVIEW-SPRNBK_345_W64					FWD
Mon 03/01/2021	to	Mon 03/01/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>01/23/2020</u>
0001	Continuous	0030		UPNY CONED	4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1870 MW
					TTC with All Lines In Service 6220 MW
SPRNBK_345KV_RNS5					FWD
Mon 03/01/2021	to	Mon 03/01/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>01/23/2020</u>
0001	Continuous	0030		SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW
MILLWOOD-EASTVIEW_345_W99					FWD
Mon 03/01/2021	to	Mon 03/22/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>01/23/2020</u>
0001	Continuous	0200		UPNY CONED	5985 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 235 MW
					TTC with All Lines In Service 6220 MW
DUNWODIE-MOTTHAVN_345_71					FWD
Mon 03/01/2021	to	Mon 04/05/2021			(Import)
0001	Continuous	0300		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
MOTTHAVN-RAINEY_345_Q11					FWD
Mon 03/01/2021	to	Tue 04/06/2021			(Import)
0001	Continuous	0700		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
EDIC-N.SCTLND_345_14					FWD
Tue 03/02/2021	to	Mon 05/31/2021			(Import)
0600	Continuous	1830		CENTRAL EAST - VC	2240 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 735 MW
					TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 14, 2020 to Friday, April 15, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PORTER__-ROTTRDAM_230_31				FWD
Tue 03/02/2021	to	Mon 05/31/2021		(Import)
0600	Continuous	1830		CENTRAL EAST - VC 2805 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 170 MW
				TTC with All Lines In Service 2975 MW
MOSES__-ADIRNDCK_230_MAI				FWD
Tue 03/02/2021	to	Mon 05/31/2021		(Import)
0700	Continuous	1300		MOSES SOUTH 2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW
NIAGARA_-ROBNSNRD_230_64				REV
Fri 03/12/2021	to	Fri 03/12/2021		(Export)
0500	Continuous	1700		SCH - OH - NY 1900 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 0 MW
				TTC with All Lines In Service 1900 MW
MARCY___345KV_CSC				FWD
Sat 03/13/2021	to	Sat 03/13/2021	<u>UPDATED</u> <u>by NYPA</u> <u>07/29/2020</u>	(Import)
0700	Continuous	1730		CENTRAL EAST - VC 2925 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 50 MW
				TTC with All Lines In Service 2975 MW
EASTVIEW-SPRNBK__345_W64				FWD
Mon 03/22/2021	to	Mon 03/22/2021	<u>UPDATED</u> <u>by CONED</u> <u>01/23/2020</u>	(Import)
0130	Continuous	0200		UPNY CONED 4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1870 MW
				TTC with All Lines In Service 6220 MW
SPRNBK__345KV_RNS5				FWD
Mon 03/22/2021	to	Mon 03/22/2021	<u>UPDATED</u> <u>by CONED</u> <u>01/23/2020</u>	(Import)
0130	Continuous	0200		SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW
W49TH_ST_345KV_5				FWD
Fri 03/26/2021	to	Wed 05/05/2021	<u>UPDATED</u> <u>by CONED</u> <u>10/06/2020</u>	(Import)
0001	Continuous	0300		SCH - PJM_HTP 300 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 360 MW
				TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 14, 2020 to Friday, April 15, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CLAY - EDIC 345_2-15			FWD	
Mon 03/29/2021	to	Fri 04/16/2021	(Import)	
0800	Continuous	1730		OSWEGO EXPORT 4850 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	400 MW
			TTC with All Lines In Service	5250 MW
ROCHESTR-PANNELL 345_RP2			FWD	
Wed 03/31/2021	to	Mon 04/12/2021	(Import)	
0500	Continuous	1700		DYSINGER EAST 2300 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW
			TTC with All Lines In Service	3150 MW
LINDN_CG-LNDVFT 345_V-3022			FWD	REV
Sun 04/04/2021	to	Sat 04/10/2021	(Import)	(Export)
1400	Continuous	1400		SCH - PJM_VFT 0 MW 0 MW
Work scheduled by: PJM			Impacts Total Transfer Capability	315 MW 315 MW
			TTC with All Lines In Service	315 MW 315 MW
DUNWODIE_345KV_3			FWD	
Mon 04/05/2021	to	Mon 04/05/2021	(Import)	
0230	Continuous	0300		SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_5			FWD	
Mon 04/05/2021	to	Mon 04/05/2021	(Import)	
0230	Continuous	0300		SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW
PLSNTVLY-WOOD_ST 345_F31			FWD	
Tue 04/27/2021	to	Wed 04/28/2021	(Import)	
0001	Continuous	0159		UPNY CONED 4000 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	2220 MW
			TTC with All Lines In Service	6220 MW
PLSNTVLY_345KV_RNS4			FWD	
Tue 04/27/2021	to	Wed 04/28/2021	(Import)	
0001	Continuous	0159		UPNY CONED 3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	2420 MW
			TTC with All Lines In Service	6220 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 14, 2020 to Friday, April 15, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					FWD
SPRNBRK__345KV_RNS4					(Import)
Sat 05/01/2021	to	Sat 05/01/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>10/06/2020</u>
0001	Continuous	0030			
Work scheduled by: ConEd					SPR/DUN-SOUTH 3200 MW
					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW
<hr/>					FWD
SPRNBRK_-W49TH_ST_345_M52					(Import)
Sat 05/01/2021	to	Tue 05/04/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>10/06/2020</u>
0001	Continuous	0300			
Work scheduled by: ConEd					SPR/DUN-SOUTH 3200 MW
					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW
<hr/>					FWD
W49TH_ST_345KV_7					(Import)
Sat 05/01/2021	to	Tue 05/04/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>10/06/2020</u>
0001	Continuous	0300			
Work scheduled by: ConEd					SCH - PJM_HTP 300 MW
					Impacts Total Transfer Capability 360 MW
					TTC with All Lines In Service 660 MW
<hr/>					FWD
SCH-IMO-NYISO_LIMIT_1600					(Import)
Sat 05/01/2021	to	Sun 10/31/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>
0001	Continuous	2359			
Work scheduled by: IESO					SCH - OH - NY 1900 MW
					Impacts Total Transfer Capability 50 MW
					TTC with All Lines In Service 1950 MW
<hr/>					FWD
CLAY___-EDIC___345_2-15					(Import)
Mon 05/03/2021	to	Fri 05/07/2021			
0700	Continuous	1530			
Work scheduled by: NYPA					OSWEGO EXPORT 4850 MW
					Impacts Total Transfer Capability 400 MW
					TTC with All Lines In Service 5250 MW
<hr/>					FWD
PANNELL_-CLAY___345_2					(Import)
Mon 05/03/2021	to	Sun 05/30/2021			
0700	Continuous	1730			
Work scheduled by: NYPA					WEST CENTRAL 1300 MW
					Impacts Total Transfer Capability 950 MW
					TTC with All Lines In Service 2250 MW
<hr/>					FWD
HURLYAVE-ROSETON__345_303					(Import)
Mon 05/03/2021	to	Fri 05/21/2021			
0800	Continuous	1600			
Work scheduled by: CHGE					UPNY CONED 4100 MW
					Impacts Total Transfer Capability 2120 MW
					TTC with All Lines In Service 6220 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 14, 2020 to Friday, April 15, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
SPRNBK__345KV_RNS4			FWD
Tue 05/04/2021	to	Tue 05/04/2021	(Import)
0230	Continuous	0300	3200 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 1400 MW
			TTC with All Lines In Service 4600 MW
<hr/>			
NIAGARA__345KV_3102			FWD REV
Thu 05/06/2021	to	Fri 05/07/2021	(Import) (Export)
0500	Continuous	1700	1700 MW 1400 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 250 MW 300 MW
			TTC with All Lines In Service 1950 MW 1700 MW
<hr/>			
NIAGARA__345KV_3302			FWD REV
Mon 05/10/2021	to	Wed 05/12/2021	(Import) (Export)
0500	Continuous	1700	1000 MW 1600 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 950 MW 100 MW
			TTC with All Lines In Service 1950 MW 1700 MW
<hr/>			
CLAY__-EDIC__345_1-16			FWD
Mon 05/10/2021	to	Fri 05/14/2021	(Import)
0700	Continuous	1530	4850 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 400 MW
			TTC with All Lines In Service 5250 MW
<hr/>			
NIAGARA__345KV_3108			REV
Thu 05/13/2021	to	Fri 05/14/2021	(Export)
0500	Continuous	1700	1500 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 200 MW
			TTC with All Lines In Service 1700 MW
<hr/>			
VOLNEY__-MARCY__345_19			FWD
Tue 06/01/2021	to	Wed 06/02/2021	(Import)
0700	Continuous	1730	2825 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 150 MW
			TTC with All Lines In Service 2975 MW
<hr/>			
VOLNEY__-MARCY__345_19			FWD
Tue 06/01/2021	to	Wed 06/02/2021	(Import)
0700	Continuous	1730	4900 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 350 MW
			TTC with All Lines In Service 5250 MW

ARR: 19

ARR: 19

NYISO TRANSFER LIMITATIONS

Wednesday, October 14, 2020 to Friday, April 15, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASER -GILBOA 345_GF5-35

Tue 06/01/2021 to Mon 06/07/2021
0700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC **2650 MW**
Impacts Total Transfer Capability 325 MW
TTC with All Lines In Service 2975 MW

MOSES -ADIRNDCK 230_MA2

Tue 06/01/2021 to Sun 11/14/2021
0700 Continuous 1300

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

PORTER -ROTTRDAM 230_30

Thu 06/03/2021 to Wed 09/15/2021
0600 Continuous 0559

Work scheduled by: NGrid

FWD

(Import)

CENTRAL EAST - VC **2805 MW**
Impacts Total Transfer Capability 170 MW
TTC with All Lines In Service 2975 MW

MARCY -EDIC 345_UE1-7

Thu 06/03/2021 to Fri 06/04/2021
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19&16

FWD

(Import)

OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

MARCY 345KV_CSC

Sat 06/05/2021 to Sat 06/05/2021
0700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC **2925 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

MOSES -ADIRNDCK 230_MA2 & MARCY 345KV_3102 & MARCY 345KV_3202 & MARCY 345KV_3302

Sat 06/05/2021 to Sat 06/05/2021
0700 Continuous 1730

Work scheduled by:

FWD

(Import)

MOSES SOUTH **1800 MW**
Impacts Total Transfer Capability 1350 MW
TTC with All Lines In Service 3150 MW

SAND_BAR-PLATSBRG 115_PV20

Tue 08/03/2021 to Tue 08/03/2021
0700 Continuous 1830

Work scheduled by: NYPA

SCH - NE - NY

Impacts Total Transfer Capability
TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Wednesday, October 14, 2020 to Friday, April 15, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASANX-COOPERS__345_UCC2-41

Tue 09/07/2021 to Wed 09/15/2021
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

MARCY__-FRASANX_345_UCC2-41

Tue 09/07/2021 to Wed 09/15/2021
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

NIAGARA_-KINTIGH__345_NS1-38

Mon 09/13/2021 to Fri 09/17/2021
0500 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

PORTER__-ROTRDAM_230_30

Wed 09/15/2021 to Tue 11/30/2021
0600 Continuous 1830

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **2805 MW**
Impacts Total Transfer Capability 170 MW
TTC with All Lines In Service 2975 MW

EDIC__-N.SCTLND_345_14

Thu 09/16/2021 to Sun 11/14/2021
0600 Continuous 1830

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **2240 MW**
Impacts Total Transfer Capability 735 MW
TTC with All Lines In Service 2975 MW

HURLYAVE-ROSETON__345_303

Thu 09/16/2021 to Sun 10/17/2021 **UPDATED by CHGE 09/22/2020**
0800 Continuous 1600

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 2120 MW
TTC with All Lines In Service 6220 MW

PANNELL_-CLAY____345_1

Mon 09/20/2021 to Fri 09/24/2021
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 14, 2020 to Friday, April 15, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PANNELL_-CLAY_345_2		FWD
Mon 09/27/2021	to Fri 10/01/2021	(Import)
0700	Continuous 1530	WEST CENTRAL 1300 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability 950 MW
		TTC with All Lines In Service 2250 MW
W49TH_ST_345KV_6		FWD
Tue 09/28/2021	to Tue 09/28/2021	(Import)
0100	Continuous 0130	SCH - PJM_HTP 300 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability 360 MW
		TTC with All Lines In Service 660 MW
E13THSTA-FARRAGUT_345_46		FWD
Tue 09/28/2021	to Tue 10/26/2021	(Import)
0100	Continuous 0300	SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability 800 MW
		TTC with All Lines In Service 4600 MW
W49TH_ST-E13THSTA_345_M55		FWD
Tue 09/28/2021	to Tue 10/26/2021	(Import)
0100	Continuous 0300	SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability 800 MW
		TTC with All Lines In Service 4600 MW
LEEDS_-HURLYAVE_345_301		FWD
Mon 10/18/2021	to Fri 11/19/2021	(Import)
0800	Continuous 1600	UPNY CONED 4100 MW
Work scheduled by: CHGE		Impacts Total Transfer Capability 2120 MW
		TTC with All Lines In Service 6220 MW
W49TH_ST_345KV_6		FWD
Tue 10/26/2021	to Tue 10/26/2021	(Import)
0230	Continuous 0300	SCH - PJM_HTP 300 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability 360 MW
		TTC with All Lines In Service 660 MW
SCH-IMO-NYISO_LIMIT_1750		FWD
Mon 11/01/2021	to Fri 12/31/2021	(Import)
0001	Continuous 2359	SCH - OH - NY 2050 MW
Work scheduled by: IESO		Impacts Total Transfer Capability 0 MW
		TTC with All Lines In Service 2050 MW

NYISO TRANSFER LIMITATIONS

Wednesday, October 14, 2020 to Friday, April 15, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-IMO_LIMIT_1600

REV

Mon 11/01/2021 to Fri 12/31/2021 UPDATED by IESO 05/03/2019
 0001 Continuous 2359

(Export)

Work scheduled by: IESO

SCH - OH - NY

1900 MW

Impacts Total Transfer Capability

0 MW

TTC with All Lines In Service

1900 MW

MOSES-ADIRNDCK_230_MAI

FWD

Wed 12/01/2021 to Tue 05/31/2022
 0700 Continuous 1300

(Import)

Work scheduled by: NYPA

MOSES SOUTH

2300 MW

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service

3150 MW