

NYISO TRANSFER LIMITATIONS

Friday ,October 16, 2020 to Sunday ,April 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_9_BYPASS & DUNWODIE_345KV_10_BYPASS & SPRNBRK__345KV_R5S3_BYPASS & SPRNBRK__345KV_R4S3_BYPASS

FWD
(Import)

Sun 02/01/2015 to Sun 11/01/2020
0000 2359

SPR/DUN-SOUTH **4350 MW**
Impacts Total Transfer Capability 250 MW
TTC with All Lines In Service 4600 MW

Work scheduled by:

DUNWODIE_345KV_9_BYPASS & DUNWODIE_345KV_10_BYPASS & SPRNBRK__345KV_R5S3_BYPASS & SPRNBRK__345KV_R4S3_BYPASS

Sun 02/01/2015 to Sun 11/01/2020
0000 2359

UPNY CONED
Impacts Total Transfer Capability
TTC with All Lines In Service

Work scheduled by:

HUDSONP_-FARRAGUT_345_B3402

FWD REV
(Import) (Export)

Mon 01/15/2018 to Sun 02/28/2021 **EXT FORCE by CONED 08/28/2020**
0001 Continuous 2359

SCH - PJ - NY **2050 MW 1150 MW**
Impacts Total Transfer Capability 150 MW 100 MW
TTC with All Lines In Service 2200 MW 1250 MW

Work scheduled by: ConEd

HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403

FWD REV
(Import) (Export)

Mon 01/15/2018 to Sun 02/28/2021
0001 2359

SCH - PJ - NY **2000 MW 1000 MW**
Impacts Total Transfer Capability 200 MW 250 MW
TTC with All Lines In Service 2200 MW 1250 MW

Work scheduled by:

MARION_-FARRAGUT_345_C3403

FWD REV
(Import) (Export)

Mon 01/15/2018 to Sun 02/28/2021 **EXT FORCE by CONED 08/28/2020**
0001 Continuous 2359

SCH - PJ - NY **2050 MW 1150 MW**
Impacts Total Transfer Capability 150 MW 100 MW
TTC with All Lines In Service 2200 MW 1250 MW

Work scheduled by: ConEd

STLAWRNC-MOSES__230_L33P

Mon 04/30/2018 to Mon 10/31/2022 **EXT FORCE by IESO 10/01/2020**
0456 Continuous 1600

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

Work scheduled by: IESO

NYISO TRANSFER LIMITATIONS

Friday ,October 16, 2020 to Sunday ,April 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO-NYISO_LIMIT_1600					FWD	
Fri 05/01/2020	to	Sat 10/31/2020	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Import)
0001	Continuous	2359				1900 MW
Work scheduled by: IESO					SCH - OH - NY	Impacts Total Transfer Capability 50 MW
					TTC with All Lines In Service	1950 MW
SHOR_NPX-SHOREHAM_138_CSC					FWD	REV
Wed 07/08/2020	to	Wed 10/21/2020	<u>EXT FORCE</u>	<u>by LIPA</u>	<u>10/14/2020</u>	(Import) (Export)
1247	Continuous	0659				0 MW 0 MW
Work scheduled by: LI					SCH - NPX_CSC	Impacts Total Transfer Capability 330 MW 330 MW
					TTC with All Lines In Service	330 MW 330 MW
SPRNBRK_-W49TH_ST_345_M52					FWD	
Sun 08/16/2020	to	Sun 10/18/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>10/15/2020</u>	(Import)
1149	Continuous	0300				3200 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service	4600 MW
BECK_-NIAGARA_230_PA27						
Mon 08/31/2020	to	Mon 11/30/2020				
0700	Continuous	0700				
Work scheduled by: IESO					SCH - OH - NY	Impacts Total Transfer Capability
					TTC with All Lines In Service	
SCH-IMO-NYISO_LIMIT_1450					FWD	
Mon 08/31/2020	to	Mon 11/30/2020				(Import)
0700	Continuous	0700				1750 MW
Work scheduled by: IESO					SCH - OH - NY	Impacts Total Transfer Capability 200 MW
					TTC with All Lines In Service	1950 MW
NEWBRDGE_345_138_BK_1					FWD	
Wed 09/02/2020	to	Thu 12/31/2020	<u>EXT FORCE</u>	<u>by LI</u>	<u>09/03/2020</u>	(Import)
1807	Continuous	2359				375 MW
Work scheduled by: LI					SCH - PJM_NEPTUNE	Impacts Total Transfer Capability 285 MW
					TTC with All Lines In Service	660 MW
MOSES_-ADIRNDCK_230_MA2					FWD	
Wed 09/09/2020	to	Sat 11/14/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/04/2020</u>	(Import)
0700	Continuous	1300				2100 MW
Work scheduled by: NYPA					MOSES SOUTH	Impacts Total Transfer Capability 1050 MW
					TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 16, 2020 to Sunday ,April 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>							FWD
SCH-IMO-NYISO_LIMIT_1350							(Import)
Fri 09/18/2020	to	Sat 10/31/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/16/2020</u>	SCH - OH - NY	1650 MW
0500	Continuous	2359				Impacts Total Transfer Capability	300 MW
Work scheduled by: NYPA						TTC with All Lines In Service	1950 MW
<hr/>							FWD
NIAGARA_-ROCHESTR_345_NR2							(Import)
Fri 09/18/2020	to	Sat 11/14/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/16/2020</u>	DYSINGER EAST	1400 MW
0500	Continuous	2330				Impacts Total Transfer Capability	1750 MW
Work scheduled by: NYPA						TTC with All Lines In Service	3150 MW
<hr/>							REV
NIAGARA__345KV_3108							(Export)
Fri 09/18/2020	to	Sat 11/14/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/16/2020</u>	SCH - OH - NY	1500 MW
0500	Continuous	2330				Impacts Total Transfer Capability	200 MW
Work scheduled by: NYPA						TTC with All Lines In Service	1700 MW
<hr/>							FWD
CHAT_DC_GC1							(Import)
Sat 09/26/2020	to	Tue 10/20/2020	<u>UPDATED</u>	<u>by HQ</u>	<u>09/30/2020</u>	MOSES SOUTH	2850 MW
2000	Continuous	2300				Impacts Total Transfer Capability	300 MW
Work scheduled by: HQ						TTC with All Lines In Service	3150 MW
<hr/>							REV
CHAT_DC_GC1							(Export)
Sat 09/26/2020	to	Tue 10/20/2020	<u>UPDATED</u>	<u>by HQ</u>	<u>09/30/2020</u>	SCH - HQ - NY	500 MW
2000	Continuous	2300				Impacts Total Transfer Capability	500 MW
Work scheduled by: HQ						TTC with All Lines In Service	1000 MW
<hr/>							REV
SCH-NYISO-HQ_LIMIT_500							(Export)
Sun 09/27/2020	to	Tue 10/20/2020	<u>UPDATED</u>	<u>by HQ</u>	<u>09/30/2020</u>	SCH - HQ - NY	500 MW
0500	Continuous	2300				Impacts Total Transfer Capability	500 MW
Work scheduled by: HQ						TTC with All Lines In Service	1000 MW
<hr/>							FWD
W49TH_ST_345KV_5							(Import)
Tue 09/29/2020	to	Sun 10/18/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>10/15/2020</u>	SCH - PJM_HTP	300 MW
0201	Continuous	0300				Impacts Total Transfer Capability	360 MW
Work scheduled by: ConEd						TTC with All Lines In Service	660 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 16, 2020 to Sunday ,April 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK__345KV_RNS4					FWD	
Thu 10/01/2020	to	Wed 10/14/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>10/15/2020</u>	(Import)
0001	Continuous	2359				SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
SPRNBRK_-EGRDNCTR_345_Y49					FWD	
Thu 10/01/2020	to	Mon 11/30/2020	<u>UPDATED</u>	<u>by LI</u>	<u>10/11/2020</u>	(Import)
0404	Continuous	2359				CONED - LIPA 775 MW
Work scheduled by: LI					Impacts Total Transfer Capability	725 MW
					TTC with All Lines In Service	1500 MW
EGRDNCTY_345_138_AT2					FWD	
Sat 10/10/2020	to	Mon 11/30/2020	<u>UPDATED</u>	<u>by LI</u>	<u>10/11/2020</u>	(Import)
1815	Continuous	2359				CONED - LIPA 1250 MW
Work scheduled by: LI					Impacts Total Transfer Capability	250 MW
					TTC with All Lines In Service	1500 MW
EGRDNCTY_345_138_AT1					FWD	
Sat 10/10/2020	to	Mon 11/30/2020	<u>UPDATED</u>	<u>by LI</u>	<u>10/11/2020</u>	(Import)
1856	Continuous	2359				CONED - LIPA 1250 MW
Work scheduled by: LI					Impacts Total Transfer Capability	250 MW
					TTC with All Lines In Service	1500 MW
HOMR_NYW-PIERC_NY_345_48						
Mon 10/12/2020	to	Fri 10/30/2020	<u>UPDATED</u>	<u>by PJM</u>	<u>10/09/2020</u>	
0800	Continuous	1600				SCH - PJ - NY
Work scheduled by: PJM					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
HURLYAVE-ROSETON__345_303					FWD	
Tue 10/13/2020	to	Fri 10/16/2020	<u>UPDATED</u>	<u>by CHGE</u>	<u>09/10/2020</u>	(Import)
0800	Continuous	1600				UPNY CONED 4100 MW
Work scheduled by: CHGE					Impacts Total Transfer Capability	2120 MW
					TTC with All Lines In Service	6220 MW
ALCOA_PA_115KV_R8105					FWD	
Wed 10/14/2020	to	Wed 10/14/2020	<u>UPDATED</u>	<u>by NGRID</u>	<u>10/12/2020</u>	(Import)
0700	Daily(No Weekends)	1400				MOSES SOUTH 3100 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 16, 2020 to Sunday ,April 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK__345KV_RNS3				FWD
Thu 10/15/2020	to	Thu 10/15/2020	CANCELLED by ConEd <u>10/13/2020</u>	(Import)
0301	Continuous	0330		SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
SPRNBRK__345KV_RNS3				FWD
Sun 10/18/2020	to	Sun 10/18/2020	UPDATED by CONED <u>10/16/2020</u>	(Import)
0330	Continuous	0400		SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
MILLWOOD_345KV_18				FWD
Mon 10/19/2020	to	Mon 10/19/2020		(Import)
0001	Continuous	0030		UPNY CONED 4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1870 MW
				TTC with All Lines In Service 6220 MW
DUNWODIE-MOTTHAVN_345_71				FWD
Mon 10/19/2020	to	Tue 10/20/2020	UPDATED by CONED <u>10/15/2020</u>	(Import)
0001	Continuous	0159		SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_5				FWD
Mon 10/19/2020	to	Tue 10/20/2020	UPDATED by CONED <u>10/15/2020</u>	(Import)
0001	Continuous	0159		SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_3				FWD
Mon 10/19/2020	to	Tue 11/24/2020	UPDATED by CONED <u>10/15/2020</u>	(Import)
0001	Continuous	0159		SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_4				FWD
Mon 10/19/2020	to	Tue 11/24/2020	UPDATED by CONED <u>10/15/2020</u>	(Import)
0001	Continuous	0159		SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 16, 2020 to Sunday ,April 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					FWD
PLSNTVLE-DUNWODIE_345_W89					(Import)
Mon 10/19/2020	to	Tue 11/24/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>10/15/2020</u>
0001	Continuous	0159			
Work scheduled by: ConEd					UPNY CONED 4000 MW
					Impacts Total Transfer Capability 2220 MW
					TTC with All Lines In Service 6220 MW
<hr/>					
SAND_BAR-PLATSBRG_115_PV20					
Mon 10/19/2020	to	Fri 11/13/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/08/2020</u>
0600	Continuous	1800			
Work scheduled by: ISONE					SCH - NE - NY
					Impacts Total Transfer Capability
					TTC with All Lines In Service
<hr/>					
BERKSHIR-ALPS_____345_393					FWD REV
					(Import) (Export)
Mon 10/19/2020	to	Tue 11/10/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/16/2020</u>
0630	Continuous	1600			
Work scheduled by: NGrid					SCH - NE - NY 950 MW 1300 MW
					Impacts Total Transfer Capability 450 MW 300 MW
					TTC with All Lines In Service 1400 MW 1600 MW
<hr/>					
BERKSHIR-ALPS_____345_393					FWD REV
					(Import) (Export)
Mon 10/19/2020	to	Tue 11/10/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/16/2020</u>
0630	Continuous	1600			
Work scheduled by: NGrid					SCH - NPX_1385 100 MW 100 MW
					Impacts Total Transfer Capability 100 MW 100 MW
					TTC with All Lines In Service 200 MW 200 MW
<hr/>					
BERKSHIR-ALPS_____345_393 & BERKSHIR-NORTHFLD_345_312					FWD REV
					(Import) (Export)
Mon 10/19/2020	to	Tue 11/10/2020			
0630		1600			
Work scheduled by:					SCH - NE - NY 950 MW 1300 MW
					Impacts Total Transfer Capability 450 MW 300 MW
					TTC with All Lines In Service 1400 MW 1600 MW
<hr/>					
BERKSHIR-NORTHFLD_345_312					FWD REV
					(Import) (Export)
Mon 10/19/2020	to	Tue 11/10/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/16/2020</u>
0630	Continuous	1600			
Work scheduled by: NGrid					SCH - NE - NY 900 MW 1500 MW
					Impacts Total Transfer Capability 500 MW 100 MW
					TTC with All Lines In Service 1400 MW 1600 MW
<hr/>					
BERKSHIR-NORTHFLD_345_312					FWD REV
					(Import) (Export)
Mon 10/19/2020	to	Tue 11/10/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/16/2020</u>
0630	Continuous	1600			
Work scheduled by: NGrid					SCH - NPX_1385 100 MW 100 MW
					Impacts Total Transfer Capability 100 MW 100 MW
					TTC with All Lines In Service 200 MW 200 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 16, 2020 to Sunday ,April 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_700					FWD	
Mon 10/19/2020	to	Tue 11/10/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/16/2020</u>	(Import)
0630	Continuous	1600				900 MW
Work scheduled by: NGrid					SCH - NE - NY	Impacts Total Transfer Capability 500 MW
					TTC with All Lines In Service	1400 MW
SCH-NYISO-NE_LIMIT_800					REV	
Mon 10/19/2020	to	Tue 11/10/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/16/2020</u>	(Export)
0630	Continuous	1600				1000 MW
Work scheduled by: NGrid					SCH - NE - NY	Impacts Total Transfer Capability 600 MW
					TTC with All Lines In Service	1600 MW
PIERCBRK-FIVEMILE_345_37						
Mon 10/19/2020	to	Fri 10/23/2020	<u>UPDATED</u>	<u>by NGRID</u>	<u>10/16/2020</u>	
0700	Continuous	1400				
Work scheduled by: NYSEG					SCH - PJ - NY	Impacts Total Transfer Capability
					TTC with All Lines In Service	
PANNELL_-CLAY_345_2					FWD	
Mon 10/19/2020	to	Fri 10/23/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/07/2020</u>	(Import)
0700	Continuous	1530				1300 MW
Work scheduled by: NYPA					WEST CENTRAL	Impacts Total Transfer Capability 950 MW
					TTC with All Lines In Service	2250 MW
SCH-NE-NYISO_LIMIT_700					FWD	
Mon 10/19/2020	to	Fri 10/23/2020	<u>CANCELLED</u>	<u>by ISONE</u>	<u>10/16/2020</u>	(Import)
0700	Continuous	1600				900 MW
Work scheduled by: ISONE					SCH - NE - NY	Impacts Total Transfer Capability 500 MW
					TTC with All Lines In Service	1400 MW
COOPERS_-DOLSONAV_345_CCDA42					FWD	
Mon 10/19/2020	to	Fri 11/06/2020				(Import)
0700	Continuous	1730				2720 MW
Work scheduled by: NYPA					CENTRAL EAST - VC	Impacts Total Transfer Capability 255 MW
					TTC with All Lines In Service	2975 MW
W49TH_ST_345KV_6					FWD	
Tue 10/20/2020	to	Tue 10/20/2020	<u>EXTENDED</u>	<u>by CONED</u>	<u>10/15/2020</u>	(Import)
0331	Continuous	0400				300 MW
Work scheduled by: ConEd					SCH - PJM_HTP	Impacts Total Transfer Capability 360 MW
					TTC with All Lines In Service	660 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 16, 2020 to Sunday ,April 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

E13THSTA-FARRAGUT_345_46					FWD
Tue 10/20/2020	to	Fri 10/23/2020	<u>EXTENDED</u>	<u>by CONED</u>	(Import)
0331	Continuous	2300			3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
W49TH_ST-E13THSTA_345_M55					FWD
Tue 10/20/2020	to	Fri 10/23/2020	<u>EXTENDED</u>	<u>by CONED</u>	(Import)
0331	Continuous	2300			3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
CHAT_DC_GC2					FWD
Wed 10/21/2020	to	Sat 11/14/2020			(Import)
0500	Continuous	2300			2850 MW
Work scheduled by: HQ					Impacts Total Transfer Capability 300 MW
					TTC with All Lines In Service 3150 MW
CHAT_DC_GC2					REV
Wed 10/21/2020	to	Sat 11/14/2020			(Export)
0500	Continuous	2300			500 MW
Work scheduled by: HQ					Impacts Total Transfer Capability 500 MW
					TTC with All Lines In Service 1000 MW
SCH-NYISO-HQ_LIMIT_500					REV
Wed 10/21/2020	to	Sat 11/14/2020			(Export)
0500	Continuous	2300			500 MW
Work scheduled by: HQ					Impacts Total Transfer Capability 500 MW
					TTC with All Lines In Service 1000 MW
MILLWOOD_345KV_18					FWD
Fri 10/23/2020	to	Fri 10/23/2020			(Import)
2130	Continuous	2200			4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1870 MW
					TTC with All Lines In Service 6220 MW
W49TH_ST_345KV_6					FWD
Fri 10/23/2020	to	Fri 10/23/2020	<u>EXTENDED</u>	<u>by CONED</u>	(Import)
2230	Continuous	2300			300 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 360 MW
					TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 16, 2020 to Sunday ,April 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONTP-W49TH_ST_345_Y56

Sat 10/24/2020 to Fri 10/30/2020
 0001 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

W49TH_ST_345KV_7

Sat 10/24/2020 to Fri 10/30/2020
 0001 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

W49TH_ST_345KV_8

Sat 10/24/2020 to Fri 10/30/2020
 0001 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **450 MW**
 Impacts Total Transfer Capability 210 MW
 TTC with All Lines In Service 660 MW

SPRNBK_-TREMONT_345_X28

Mon 10/26/2020 to Mon 10/26/2020 **UPDATED by CONED 10/16/2020**
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **4200 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 4600 MW

LEEDS___345_LEEDS SVC

Mon 10/26/2020 to Fri 10/30/2020
 0800 Continuous 1600
 Work scheduled by: NGrid

FWD
 (Import)
 CENTRAL EAST - VC **2950 MW**
 Impacts Total Transfer Capability 25 MW
 TTC with All Lines In Service 2975 MW

LEEDS___345KV_R94301

Mon 10/26/2020 to Wed 11/25/2020
 0800 Continuous 1600
 Work scheduled by: NGrid

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 2420 MW
 TTC with All Lines In Service 6220 MW

LEEDS___-HURLYAVE_345_301

Mon 10/26/2020 to Fri 12/04/2020
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4100 MW**
 Impacts Total Transfer Capability 2120 MW
 TTC with All Lines In Service 6220 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 16, 2020 to Sunday ,April 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BRANCHBG-HOPATCON_500_5060					FWD	
Tue 10/27/2020	to	Tue 10/27/2020	<u>UPDATED</u>	<u>by PJM</u>	<u>10/15/2020</u>	(Import)
0200	Continuous	1500				6025 MW
Work scheduled by: PJM					UPNY CONED	
					Impacts Total Transfer Capability	195 MW
					TTC with All Lines In Service	6220 MW
SCRIBA -VOLNEY_345_21					FWD	
Wed 10/28/2020	to	Wed 10/28/2020				(Import)
0800	Daily(No Weekends)	1630				5250 MW
Work scheduled by: NGrid					OSWEGO EXPORT	
					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	5250 MW
W49TH_ST_345KV_5					FWD	
Fri 10/30/2020	to	Sat 10/31/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>10/11/2020</u>	(Import)
0301	Continuous	0300				300 MW
Work scheduled by: ConEd					SCH - PJM_HTP	
					Impacts Total Transfer Capability	360 MW
					TTC with All Lines In Service	660 MW
W49TH_ST_345KV_7					FWD	
Fri 10/30/2020	to	Sat 10/31/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>10/11/2020</u>	(Import)
0301	Continuous	0300				300 MW
Work scheduled by: ConEd					SCH - PJM_HTP	
					Impacts Total Transfer Capability	360 MW
					TTC with All Lines In Service	660 MW
SPRNBK_345KV_RS3 & SPRNBK_345KV_RS4					FWD	
Sat 10/31/2020	to	Sat 10/31/2020				(Import)
0001		0030				3200 MW
Work scheduled by:					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
SCH-IMO-NYISO_LIMIT_1750					FWD	
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Import)
0001	Continuous	2359				2050 MW
Work scheduled by: IESO					SCH - OH - NY	
					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	2050 MW
SCH-NYISO-IMO_LIMIT_1600					REV	
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Export)
0001	Continuous	2359				1900 MW
Work scheduled by: IESO					SCH - OH - NY	
					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	1900 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 16, 2020 to Sunday ,April 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK__345KV_RS3 & SPRNBK__345KV_RS4
 Sun 11/01/2020 to Sun 11/01/2020
 0130 0200
 Work scheduled by:

FWD
 (Import)
SPR/DUN-SOUTH 3800 MW
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

EGRDNCTY_345_138_AT1
 Sun 11/01/2020 to Fri 11/13/2020 **CANCELLED by LI 10/16/2020**
 0800 Continuous 2159
 Work scheduled by: LI

FWD
 (Import)
CONED - LIPA 1250 MW
 Impacts Total Transfer Capability 250 MW
 TTC with All Lines In Service 1500 MW

EGRDNCTY_345_138_AT2
 Sun 11/01/2020 to Fri 11/13/2020 **CANCELLED by LI 10/16/2020**
 0800 Continuous 2159
 Work scheduled by: LI

FWD
 (Import)
CONED - LIPA 1250 MW
 Impacts Total Transfer Capability 250 MW
 TTC with All Lines In Service 1500 MW

SPRNBK_-EGRDNCTR_345_Y49
 Sun 11/01/2020 to Fri 11/13/2020 **CANCELLED by LI 10/16/2020**
 0800 Continuous 2159
 Work scheduled by: LI

FWD
 (Import)
CONED - LIPA 775 MW
 Impacts Total Transfer Capability 725 MW
 TTC with All Lines In Service 1500 MW

S.RIPLEY-DUNKIRK__230_68
 Mon 11/02/2020 to Fri 11/20/2020 **UPDATED by PJM 09/28/2020**
 0700 Continuous 1800
 Work scheduled by: NGrid

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

DUNWODIE_345KV_9_BYPASS & DUNWODIE_345KV_10_BYPASS & SPRNBK__345KV_R5S3_BYPASS & SPRNBK__345KV_R4S3_BYPASS
 Mon 11/02/2020 to Sat 02/01/2025
 1800 0000
 Work scheduled by:

FWD
 (Import)
SPR/DUN-SOUTH 4350 MW
 Impacts Total Transfer Capability 250 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 16, 2020 to Sunday ,April 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_9_BYPASS & DUNWODIE_345KV_10_BYPASS & SPRNBRK__345KV_R5S3_BYPASS & SPRNBRK__345KV_R4S3_BYPASS

Mon 11/02/2020 to Sat 02/01/2025
1800 0000

Work scheduled by:

UPNY CONED
Impacts Total Transfer Capability
TTC with All Lines In Service

SPRNBRK_-TREMONT__345_X28

Fri 11/06/2020 to Sat 11/07/2020
0001 Continuous 0059

Work scheduled by: ConEd

UPDATED by CONED 10/16/2020

FWD
(Import)
SPR/DUN-SOUTH **4200 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 4600 MW

NIAGARA__345KV_3102

Fri 11/06/2020 to Fri 11/06/2020
0500 Continuous 2100

Work scheduled by: NYPA

FWD REV
(Import) (Export)
SCH - OH - NY **2000 MW 1700 MW**
Impacts Total Transfer Capability 50 MW 200 MW
TTC with All Lines In Service 2050 MW 1900 MW

NIAGARA__345_230_AT4

Fri 11/06/2020 to Fri 11/06/2020
0500 Continuous 2100

Work scheduled by: NYPA

REV
(Export)
SCH - OH - NY **1750 MW**
Impacts Total Transfer Capability 150 MW
TTC with All Lines In Service 1900 MW

SPRNBRK_-TREMONT__345_X28

Mon 11/09/2020 to Mon 11/09/2020
0030 Continuous 0059

Work scheduled by: ConEd

UPDATED by CONED 10/16/2020

FWD
(Import)
SPR/DUN-SOUTH **4200 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 4600 MW

ROSETON_-ROCKTVRN_345_311

Mon 11/09/2020 to Fri 11/20/2020
0800 Continuous 1600

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4400 MW**
Impacts Total Transfer Capability 1820 MW
TTC with All Lines In Service 6220 MW

DUNWODIE-MOTTHAVN_345_71

Thu 11/12/2020 to Thu 11/12/2020
0001 Continuous 0030

Work scheduled by: ConEd

UPDATED by CONED 10/15/2020

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 16, 2020 to Sunday ,April 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_5				FWD
Thu 11/12/2020	to	Fri 11/13/2020	UPDATED	(Import)
0001	Continuous	0100	by CONED	10/15/2020
Work scheduled by: ConEd				SPR/DUN-SOUTH 3800 MW
				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
DUNWODIE-MOTTHAVN_345_71				FWD
Fri 11/13/2020	to	Fri 11/13/2020	UPDATED	(Import)
0030	Continuous	0100	by CONED	10/15/2020
Work scheduled by: ConEd				SPR/DUN-SOUTH 3800 MW
				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
CHATGUAY-MASSENA_765_7040				FWD
Sun 11/15/2020	to	Mon 11/30/2020		(Import)
0100	Continuous	1900		MOSES SOUTH 1550 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 1600 MW
				TTC with All Lines In Service 3150 MW
CHATGUAY-MASSENA_765_7040				FWD
Sun 11/15/2020	to	Mon 11/30/2020		REV (Import) (Export)
0100	Continuous	1900		SCH - HQ - NY 0 MW 0 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 1500 MW 1000 MW
				TTC with All Lines In Service 1500 MW 1000 MW
MARCY___765_345_AT1				FWD
Sun 11/15/2020	to	Mon 11/30/2020		(Import)
0100	Continuous	1900		MOSES SOUTH 1750 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 3150 MW
				ARR: 19
MARCY___765_345_AT2				FWD
Sun 11/15/2020	to	Mon 11/30/2020		(Import)
0100	Continuous	1900		MOSES SOUTH 1700 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 1450 MW
				TTC with All Lines In Service 3150 MW
				ARR: 19
MASSENA_-MARCY___765_MSU1				FWD
Sun 11/15/2020	to	Mon 11/30/2020		(Import)
0100	Continuous	1900		CENTRAL EAST - VC 2265 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 710 MW
				TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 16, 2020 to Sunday ,April 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA -MARCY 765_MSU1		FWD	
Sun 11/15/2020	to Mon 11/30/2020	(Import)	
0100	Continuous 1900	MOSES SOUTH	500 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	2650 MW
		TTC with All Lines In Service	3150 MW
MASSENA -MARCY 765_MSU1		FWD	REV
Sun 11/15/2020	to Mon 11/30/2020	(Import)	(Export)
0100	Continuous 1900	SCH - HQ - NY	475 MW 1000 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	1025 MW 0 MW
		TTC with All Lines In Service	1500 MW 1000 MW
MASSENA -MARCY 765_MSU1		FWD	
Sun 11/15/2020	to Mon 11/30/2020	(Import)	
0100	Continuous 1900	SCH - HQ_CEDARS	90 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	109 MW
		TTC with All Lines In Service	199 MW
MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040		FWD	
Sun 11/15/2020	to Mon 11/30/2020	(Import)	
0100	1900	MOSES SOUTH	500 MW
Work scheduled by:		Impacts Total Transfer Capability	2650 MW
		TTC with All Lines In Service	3150 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2		FWD	REV
Sun 11/15/2020	to Mon 11/30/2020	(Import)	(Export)
0100	1900	SCH - HQ - NY	850 MW 0 MW
Work scheduled by:		Impacts Total Transfer Capability	650 MW 1000 MW
		TTC with All Lines In Service	1500 MW 1000 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2		FWD	
Sun 11/15/2020	to Mon 11/30/2020	(Import)	
0100	1900	SCH - HQ_CEDARS	90 MW
Work scheduled by:		Impacts Total Transfer Capability	109 MW
		TTC with All Lines In Service	199 MW
STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1		FWD	
Sun 11/15/2020	to Mon 11/30/2020	(Import)	
0100	1900	SCH - HQ_CEDARS	90 MW
Work scheduled by:		Impacts Total Transfer Capability	109 MW
		TTC with All Lines In Service	199 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 16, 2020 to Sunday ,April 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STLAWRNC-MOSES___230_L33P & MOSES___-MASSENA_230_MMS1 & MOSES___-				FWD
MASSENA_230_MMS2				(Import)
Sun 11/15/2020	to	Mon 11/30/2020		SCH - HQ_CEDARS
0100		1900		90 MW
Work scheduled by:				Impacts Total Transfer Capability 109 MW
				TTC with All Lines In Service 199 MW

W49TH_ST_345KV_5				FWD
				(Import)
Tue 11/17/2020	to	Tue 11/17/2020		SCH - PJM_HTP
0001	Continuous	0030		300 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 360 MW
				TTC with All Lines In Service 660 MW

W49TH_ST_345KV_7				FWD
				(Import)
Tue 11/17/2020	to	Tue 11/17/2020		SCH - PJM_HTP
0001	Continuous	0030		300 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 360 MW
				TTC with All Lines In Service 660 MW

W49TH_ST_345KV_5				FWD
				(Import)
Thu 11/19/2020	to	Thu 11/19/2020		SCH - PJM_HTP
1830	Continuous	1900		300 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 360 MW
				TTC with All Lines In Service 660 MW

W49TH_ST_345KV_7				FWD
				(Import)
Thu 11/19/2020	to	Thu 11/19/2020		SCH - PJM_HTP
1830	Continuous	1900		300 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 360 MW
				TTC with All Lines In Service 660 MW

W49TH_ST_345KV_6				FWD
				(Import)
Fri 11/20/2020	to	Wed 11/25/2020	<u>UPDATED</u> <u>by CE</u> <u>08/06/2020</u>	SCH - PJM_HTP
0001	Continuous	2300		300 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 360 MW
				TTC with All Lines In Service 660 MW

W49TH_ST_345KV_8				FWD
				(Import)
Fri 11/20/2020	to	Wed 11/25/2020	<u>UPDATED</u> <u>by CE</u> <u>08/06/2020</u>	SCH - PJM_HTP
0001	Continuous	2300		300 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 360 MW
				TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 16, 2020 to Sunday ,April 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_-TREMONT__345_X28					FWD	
Tue 11/24/2020	to	Wed 11/25/2020	<u>UPDATED</u>	<u>by CE</u>	<u>10/16/2020</u>	(Import)
0101	Continuous	0300				4200 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	400 MW
					TTC with All Lines In Service	4600 MW
BUCHAN_N-EASTVIEW_345_W93					FWD	
Wed 11/25/2020	to	Wed 11/25/2020		<u>by CONED</u>	<u>10/16/2020</u>	(Import)
0301	Continuous	0330				4350 MW
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	1870 MW
					TTC with All Lines In Service	6220 MW
EASTVIEW-SPRNBK__345_W79					FWD	
Wed 11/25/2020	to	Thu 11/26/2020		<u>by CONED</u>	<u>10/16/2020</u>	(Import)
0301	Continuous	0300				4350 MW
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	1870 MW
					TTC with All Lines In Service	6220 MW
MOTTHAVN-RAINEY__345_Q12					FWD	
Wed 11/25/2020	to	Thu 12/03/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>10/16/2020</u>	(Import)
0301	Continuous	0159				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
BUCHAN_N-EASTVIEW_345_W93					FWD	
Thu 11/26/2020	to	Thu 11/26/2020		<u>by CONED</u>	<u>10/16/2020</u>	(Import)
0130	Continuous	0300				4350 MW
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	1870 MW
					TTC with All Lines In Service	6220 MW
DOLSONAV-ROCKTVRN_345_DART44					FWD	
Mon 11/30/2020	to	Mon 12/14/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/27/2020</u>	(Import)
0700	Continuous	1730				2720 MW
Work scheduled by: NYPA					CENTRAL EAST - VC	
					Impacts Total Transfer Capability	255 MW
					TTC with All Lines In Service	2975 MW
NEPTUNE_-DUFFYAVE_345_NEPTUNE					FWD	
Mon 11/30/2020	to	Fri 12/11/2020		<u>by LI</u>	<u>09/14/2020</u>	(Import)
0800	Continuous	1600				0 MW
Work scheduled by: PJM					SCH - PJM_NEPTUNE	
					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	660 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 16, 2020 to Sunday ,April 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE-DUFFYAVE_345_501

Mon 11/30/2020 to Fri 12/11/2020
 0800 Continuous 1600
 Work scheduled by: PJM

by LI 09/14/2020

FWD
 (Import)
 SCH - PJM_NEPTUNE **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

MARCY_345KV_CSC

Tue 12/01/2020 to Fri 12/11/2020
 0700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2925 MW**
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 2975 MW

MOSES-ADIRNDCK_230_MAL

Tue 12/01/2020 to Sat 02/27/2021
 0700 Continuous 1730
 Work scheduled by: NYPA

UPDATED by NYPA 07/27/2020

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

LAFAYTTE-CLRKSCRN_345_4-46

Tue 12/01/2020 to Tue 12/01/2020
 0730 Daily(No Weekends) 1230
 Work scheduled by: NGrid

UPDATED by NGRID 10/05/2020

FWD
 (Import)
 CENTRAL EAST - VC **2650 MW**
 Impacts Total Transfer Capability 325 MW
 TTC with All Lines In Service 2975 MW

W49TH_ST_345KV_6

Tue 12/01/2020 to Tue 12/01/2020
 2230 Continuous 2300
 Work scheduled by: ConEd

UPDATED by CE 08/06/2020

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

W49TH_ST_345KV_8

Tue 12/01/2020 to Tue 12/01/2020
 2230 Continuous 2300
 Work scheduled by: ConEd

UPDATED by CE 08/06/2020

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

MOTTHAVN-RAINEY_345_Q11

Thu 12/03/2020 to Tue 12/08/2020
 0201 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 16, 2020 to Sunday ,April 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

KINTIGH_-ROCHESTR_345_SR1-39				FWD
Thu 12/03/2020	to	Tue 12/15/2020	UPDATED by NYISO 06/24/2020	(Import)
0800	Continuous	1900		DYSINGER EAST 1700 MW
Work scheduled by: RGE				Impacts Total Transfer Capability 1450 MW
				TTC with All Lines In Service 3150 MW
NIAGARA_-KINTIGH_345_NS1-38				FWD
Thu 12/03/2020	to	Tue 12/15/2020	UPDATED by NYISO 06/24/2020	(Import)
0800	Continuous	1900		DYSINGER EAST 1700 MW
Work scheduled by: RGE				Impacts Total Transfer Capability 1450 MW
				TTC with All Lines In Service 3150 MW
BECK_-PACKARD_230_BP76				FWD REV
Fri 12/04/2020	to	Fri 12/04/2020		(Import) (Export)
0730	Daily(No Weekends)	1530		SCH - OH - NY 1650 MW 1400 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 400 MW 500 MW
				TTC with All Lines In Service 2050 MW 1900 MW
OSWEGO_COMPLEX_AVR_O/S				FWD
Sun 12/06/2020	to	Sun 12/06/2020		(Import)
0900	Continuous	0930		CENTRAL EAST - VC 2870 MW
Work scheduled by: Gen				Impacts Total Transfer Capability 105 MW
				TTC with All Lines In Service 2975 MW
SAND_BAR-PLATSBRG_115_PV20				
Mon 12/07/2020	to	Fri 12/11/2020		SCH - NE - NY
0700	Continuous	1530		Impacts Total Transfer Capability
Work scheduled by: NYPA				TTC with All Lines In Service
LONG_MTN-CRICKVLY_345_398				FWD REV
Tue 12/08/2020	to	Thu 12/10/2020		(Import) (Export)
0700	Continuous	1600		SCH - NE - NY 700 MW 1300 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability 700 MW 400 MW
				TTC with All Lines In Service 1400 MW 1700 MW
LONG_MTN-CRICKVLY_345_398				FWD REV
Tue 12/08/2020	to	Thu 12/10/2020		(Import) (Export)
0700	Continuous	1600		SCH - NPX_1385 100 MW 100 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability 100 MW 100 MW
				TTC with All Lines In Service 200 MW 200 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 16, 2020 to Sunday ,April 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
SCH-NE-NYISO_LIMIT_400			FWD
Tue 12/08/2020 to Thu 12/10/2020			(Import)
0700 Continuous 1600		SCH - NE - NY	600 MW
Work scheduled by: ISONE		Impacts Total Transfer Capability	800 MW
		TTC with All Lines In Service	1400 MW
<hr/>			
SCH-NYISO-NE_LIMIT_1000			REV
Tue 12/08/2020 to Thu 12/10/2020			(Export)
0700 Continuous 1600		SCH - NE - NY	1200 MW
Work scheduled by: ISONE		Impacts Total Transfer Capability	500 MW
		TTC with All Lines In Service	1700 MW
<hr/>			
MARCY -EDIC 345_UE1-7			FWD
Mon 12/14/2020 to Mon 12/14/2020			(Import)
0700 Continuous 1730		OSWEGO EXPORT	5250 MW
Work scheduled by: NYPA	ARR: 19&16	Impacts Total Transfer Capability	0 MW
		TTC with All Lines In Service	5250 MW
<hr/>			
SAND_BAR-PLATSBRG_115_PV20			
Mon 12/14/2020 to Fri 12/18/2020		SCH - NE - NY	
0700 Continuous 1530		Impacts Total Transfer Capability	
Work scheduled by: NYPA		TTC with All Lines In Service	
<hr/>			
FRASANNX-COOPERS 345_UCC2-41			FWD
Tue 12/15/2020 to Wed 12/16/2020			(Import)
0700 Continuous 1530		CENTRAL EAST - VC	2500 MW
Work scheduled by: NYPA	ARR: 19	Impacts Total Transfer Capability	475 MW
		TTC with All Lines In Service	2975 MW
<hr/>			
MARCY -FRASANNX_345_UCC2-41			FWD
Tue 12/15/2020 to Wed 12/16/2020			(Import)
0700 Continuous 1530		CENTRAL EAST - VC	2500 MW
Work scheduled by: NYPA	ARR: 19	Impacts Total Transfer Capability	475 MW
		TTC with All Lines In Service	2975 MW
<hr/>			
STONYRDG-HILLSIDE_230_72			FWD
Wed 12/16/2020 to Mon 12/21/2020			(Import)
0800 Continuous 0300		DYSINGER EAST	2850 MW
Work scheduled by: NYSEG		Impacts Total Transfer Capability	300 MW
		TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 16, 2020 to Sunday ,April 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

N. SCTLND-LEEDS__345_93

Thu 12/17/2020 to Fri 12/18/2020
 0800 Continuous 1500
 Work scheduled by: NGrid

FWD
 (Import)
 CENTRAL EAST - VC **2650 MW**
 Impacts Total Transfer Capability 325 MW
 TTC with All Lines In Service 2975 MW

BUCHAN_N-EASTVIEW_345_W93

Tue 12/22/2020 to Tue 12/22/2020 **UPDATED by CE 10/16/2020**
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1870 MW
 TTC with All Lines In Service 6220 MW

EASTVIEW-SPRNBK__345_W79

Tue 12/22/2020 to Fri 12/25/2020 **UPDATED by CE 10/16/2020**
 0001 Continuous 0259
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1870 MW
 TTC with All Lines In Service 6220 MW

BUCHAN_N-EASTVIEW_345_W93

Fri 12/25/2020 to Fri 12/25/2020 **UPDATED by CE 10/16/2020**
 0230 Continuous 0259
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1870 MW
 TTC with All Lines In Service 6220 MW

SPRNBK_-TREMONT__345_X28

Sat 12/26/2020 to Tue 12/29/2020 **UPDATED by CE 10/16/2020**
 0301 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **4200 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 4600 MW

LADENTWN-BUCHAN_S_345_Y88

Mon 12/28/2020 to Fri 02/12/2021 **UPDATED by CE 10/16/2020**
 0300 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **5930 MW**
 Impacts Total Transfer Capability 290 MW
 TTC with All Lines In Service 6220 MW

SPRNBK_-TREMONT__345_X28

Wed 12/30/2020 to Wed 12/30/2020 **UPDATED by CE 10/16/2020**
 2130 Continuous 2200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **4200 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 16, 2020 to Sunday ,April 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

	FWD	REV
HOPATCON-RAMAPO 500_5018		
Mon 02/01/2021 to Sat 02/06/2021	<u>CANCELLED</u> by ConEd <u>10/13/2020</u>	
0001 Continuous 0200		
Work scheduled by: ConEd		
	(Import)	(Export)
	1250 MW	1200 MW
	Impacts Total Transfer Capability	1650 MW 650 MW
	TTC with All Lines In Service	2900 MW 1850 MW
HOPATCON-RAMAPO 500_5018		
Mon 02/01/2021 to Sat 02/06/2021	<u>CANCELLED</u> by ConEd <u>10/13/2020</u>	
0001 Continuous 0200		
Work scheduled by: ConEd		
	FWD (Import)	
	6025 MW	
	Impacts Total Transfer Capability 195 MW	
	TTC with All Lines In Service 6220 MW	
RAMAPO 345_345_PAR3500		
Mon 02/01/2021 to Sat 02/06/2021	<u>CANCELLED</u> by ConEd <u>10/13/2020</u>	
0001 Continuous 0200		
Work scheduled by: ConEd		
	FWD (Import) (Export)	
	2150 MW	1250 MW
	Impacts Total Transfer Capability	750 MW 600 MW
	TTC with All Lines In Service	2900 MW 1850 MW
RAMAPO 345_345_PAR4500		
Mon 02/01/2021 to Sat 02/06/2021	<u>CANCELLED</u> by ConEd <u>10/13/2020</u>	
0001 Continuous 0200		
Work scheduled by: ConEd		
	FWD (Import) (Export)	
	2150 MW	1250 MW
	Impacts Total Transfer Capability	750 MW 600 MW
	TTC with All Lines In Service	2900 MW 1850 MW
RAMAPO 500_345_BK 1500		
Mon 02/01/2021 to Sat 02/06/2021	<u>CANCELLED</u> by ConEd <u>10/13/2020</u>	
0001 Continuous 0200		
Work scheduled by: ConEd		
	FWD (Import) (Export)	
	1250 MW	1200 MW
	Impacts Total Transfer Capability	1650 MW 650 MW
	TTC with All Lines In Service	2900 MW 1850 MW
RAMAPO 500_345_BK 1500		
Mon 02/01/2021 to Sat 02/06/2021	<u>CANCELLED</u> by ConEd <u>10/13/2020</u>	
0001 Continuous 0200		
Work scheduled by: ConEd		
	FWD (Import)	
	6025 MW	
	Impacts Total Transfer Capability 195 MW	
	TTC with All Lines In Service 6220 MW	
PORTER -ROTTDAM 230_31		
Mon 02/01/2021 to Sat 02/27/2021		
0600 Continuous 1830		
Work scheduled by: NGrid		
	FWD (Import)	
	2805 MW	
	Impacts Total Transfer Capability 170 MW	
	TTC with All Lines In Service 2975 MW	

NYISO TRANSFER LIMITATIONS

Friday ,October 16, 2020 to Sunday ,April 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY-WOOD_ST__345_F30					FWD	
Sun 02/14/2021	to	Tue 02/16/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>09/28/2020</u>	(Import)
2000	Continuous	0200				4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 2220 MW	
					TTC with All Lines In Service 6220 MW	
PLSNTVLY_345KV_RNS5					FWD	
Sun 02/14/2021	to	Tue 02/16/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>09/28/2020</u>	(Import)
2000	Continuous	0200				3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 2420 MW	
					TTC with All Lines In Service 6220 MW	
BERKSHIR-ALPS____345_393					FWD	REV
Wed 02/17/2021	to	Fri 02/19/2021				(Import) (Export)
0730	Continuous	1600				1150 MW 1700 MW
Work scheduled by: NGrid			ARR: 78			Impacts Total Transfer Capability 250 MW 0 MW
					TTC with All Lines In Service 1400 MW 1700 MW	
BERKSHIR-ALPS____345_393					FWD	REV
Wed 02/17/2021	to	Fri 02/19/2021				(Import) (Export)
0730	Continuous	1600				100 MW 100 MW
Work scheduled by: NGrid			ARR: 78			Impacts Total Transfer Capability 100 MW 100 MW
					TTC with All Lines In Service 200 MW 200 MW	
EFISHKIL-WOOD_ST__345_F39					FWD	
Thu 02/18/2021	to	Sat 02/20/2021	<u>UPDATED</u>	<u>by CE</u>	<u>04/01/2020</u>	(Import)
2100	Continuous	0200				4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 2220 MW	
					TTC with All Lines In Service 6220 MW	
WOOD_ST_-PLSNTVLE_345_Y87					FWD	
Thu 02/18/2021	to	Sat 02/20/2021	<u>UPDATED</u>	<u>by CE</u>	<u>04/01/2020</u>	(Import)
2100	Continuous	0200				5905 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 315 MW	
					TTC with All Lines In Service 6220 MW	
CHATGUAY-MASSENA__765_7040					FWD	
Sun 02/28/2021	to	Mon 03/01/2021				(Import)
0500	Continuous	1730				1550 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 1600 MW	
					TTC with All Lines In Service 3150 MW	

NYISO TRANSFER LIMITATIONS

Friday ,October 16, 2020 to Sunday ,April 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Transfer Capability	FWD	REV
	(Import)	(Export)
CHATGUAY-MASSENA__765_7040		
Sun 02/28/2021 to Mon 03/01/2021		
0500 Continuous 1730		
Work scheduled by: NYPA		
SCH - HQ - NY	0 MW	0 MW
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW
MASSENA_-MARCY___765_MSU1		
Sun 02/28/2021 to Mon 03/01/2021		
0500 Continuous 1730		
Work scheduled by: NYPA		
CENTRAL EAST - VC	2265 MW	
Impacts Total Transfer Capability	710 MW	
TTC with All Lines In Service	2975 MW	
MASSENA_-MARCY___765_MSU1		
Sun 02/28/2021 to Mon 03/01/2021		
0500 Continuous 1730		
Work scheduled by: NYPA		
MOSES SOUTH	500 MW	
Impacts Total Transfer Capability	2650 MW	
TTC with All Lines In Service	3150 MW	
MASSENA_-MARCY___765_MSU1		
Sun 02/28/2021 to Mon 03/01/2021		
0500 Continuous 1730		
Work scheduled by: NYPA		
SCH - HQ - NY	475 MW	1000 MW
Impacts Total Transfer Capability	1025 MW	0 MW
TTC with All Lines In Service	1500 MW	1000 MW
MASSENA_-MARCY___765_MSU1		
Sun 02/28/2021 to Mon 03/01/2021		
0500 Continuous 1730		
Work scheduled by: NYPA		
SCH - HQ_CEDARS	90 MW	
Impacts Total Transfer Capability	109 MW	
TTC with All Lines In Service	199 MW	
MASSENA_-MARCY___765_MSU1 & CHATGUAY-MASSENA_765_7040		
Sun 02/28/2021 to Mon 03/01/2021		
0500 1730		
Work scheduled by:		
MOSES SOUTH	500 MW	
Impacts Total Transfer Capability	2650 MW	
TTC with All Lines In Service	3150 MW	
STLAWRNC-MOSES___230_L33P & MASSENA_-MARCY___765_MSU1		
Sun 02/28/2021 to Mon 03/01/2021		
0500 1730		
Work scheduled by:		
SCH - HQ_CEDARS	90 MW	
Impacts Total Transfer Capability	109 MW	
TTC with All Lines In Service	199 MW	

NYISO TRANSFER LIMITATIONS

Friday ,October 16, 2020 to Sunday ,April 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_3				FWD
Mon 03/01/2021	to	Mon 03/01/2021		(Import)
0001	Continuous	0030	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_5				FWD
Mon 03/01/2021	to	Mon 03/01/2021		(Import)
0001	Continuous	0030	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
EASTVIEW-SPRNBK__345_W64				FWD
Mon 03/01/2021	to	Mon 03/01/2021	<u>UPDATED</u> <u>by CONED</u> <u>01/23/2020</u>	(Import)
0001	Continuous	0030	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1870 MW
				TTC with All Lines In Service 6220 MW
SPRNBK__345KV_RNS5				FWD
Mon 03/01/2021	to	Mon 03/01/2021	<u>UPDATED</u> <u>by CONED</u> <u>01/23/2020</u>	(Import)
0001	Continuous	0030	SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW
MILLWOOD-EASTVIEW_345_W99				FWD
Mon 03/01/2021	to	Mon 03/22/2021	<u>UPDATED</u> <u>by CONED</u> <u>01/23/2020</u>	(Import)
0001	Continuous	0200	UPNY CONED	5985 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 235 MW
				TTC with All Lines In Service 6220 MW
DUNWODIE-MOTTHAVN_345_71				FWD
Mon 03/01/2021	to	Mon 04/05/2021		(Import)
0001	Continuous	0300	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
MOTTHAVN-RAINEY__345_Q11				FWD
Mon 03/01/2021	to	Tue 04/06/2021		(Import)
0001	Continuous	0700	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 16, 2020 to Sunday ,April 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
<p>EDIC___-N.SCTLND_345_14</p> <p>Tue 03/02/2021 to Mon 05/31/2021</p> <p style="padding-left: 20px;">0600 Continuous 1830</p> <p>Work scheduled by: NGrid</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC 2240 MW</p> <p>Impacts Total Transfer Capability 735 MW</p> <p>TTC with All Lines In Service 2975 MW</p>		
<hr/>			
<p>PORTER_-ROTRDAM_230_31</p> <p>Tue 03/02/2021 to Mon 05/31/2021</p> <p style="padding-left: 20px;">0600 Continuous 1830</p> <p>Work scheduled by: NGrid</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC 2805 MW</p> <p>Impacts Total Transfer Capability 170 MW</p> <p>TTC with All Lines In Service 2975 MW</p>		
<hr/>			
<p>MOSES_-ADIRNDCK_230_MA1</p> <p>Tue 03/02/2021 to Mon 05/31/2021</p> <p style="padding-left: 20px;">0700 Continuous 1300</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH 2300 MW</p> <p>Impacts Total Transfer Capability 850 MW</p> <p>TTC with All Lines In Service 3150 MW</p>		
<hr/>			
<p>NIAGARA_-ROBNSNRD_230_64</p> <p>Fri 03/12/2021 to Fri 03/12/2021</p> <p style="padding-left: 20px;">0500 Continuous 1700</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">REV (Export)</p> <p>SCH - OH - NY 1900 MW</p> <p>Impacts Total Transfer Capability 0 MW</p> <p>TTC with All Lines In Service 1900 MW</p>		
<hr/>			
<p>MARCY___345KV_CSC</p> <p>Sat 03/13/2021 to Sat 03/13/2021</p> <p style="padding-left: 20px;">0700 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC 2925 MW</p> <p>Impacts Total Transfer Capability 50 MW</p> <p>TTC with All Lines In Service 2975 MW</p>		
<hr/>			
<p>EASTVIEW-SPRNBK_345_W64</p> <p>Mon 03/22/2021 to Mon 03/22/2021</p> <p style="padding-left: 20px;">0130 Continuous 0200</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>UPNY CONED 4350 MW</p> <p>Impacts Total Transfer Capability 1870 MW</p> <p>TTC with All Lines In Service 6220 MW</p>		
<hr/>			
<p>SPRNBK_345KV_RNS5</p> <p>Mon 03/22/2021 to Mon 03/22/2021</p> <p style="padding-left: 20px;">0130 Continuous 0200</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>SPR/DUN-SOUTH 3200 MW</p> <p>Impacts Total Transfer Capability 1400 MW</p> <p>TTC with All Lines In Service 4600 MW</p>		

NYISO TRANSFER LIMITATIONS

Friday ,October 16, 2020 to Sunday ,April 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_5				FWD
Fri 03/26/2021	to	Wed 05/05/2021	UPDATED by CONED 10/06/2020	(Import)
0001	Continuous	0300		300 MW
Work scheduled by: ConEd				SCH - PJM_HTP
				Impacts Total Transfer Capability 360 MW
				TTC with All Lines In Service 660 MW
CLAY -EDIC 345 2-15				FWD
Mon 03/29/2021	to	Fri 04/16/2021	09/12/2020	(Import)
0800	Continuous	1730		4850 MW
Work scheduled by: NYPA				OSWEGO EXPORT
				Impacts Total Transfer Capability 400 MW
				TTC with All Lines In Service 5250 MW
ROCHESTR-PANNELL 345 RP2				FWD
Wed 03/31/2021	to	Mon 04/12/2021		(Import)
0500	Continuous	1700		2300 MW
Work scheduled by: NYPA				DYSINGER EAST
				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW
LINDN_CG-LNDVFT 345 V-3022				FWD REV
Sun 04/04/2021	to	Sat 04/10/2021		(Import) (Export)
1400	Continuous	1400		0 MW 0 MW
Work scheduled by: PJM				SCH - PJM_VFT
				Impacts Total Transfer Capability 315 MW 315 MW
				TTC with All Lines In Service 315 MW 315 MW
DUNWODIE_345KV_3				FWD
Mon 04/05/2021	to	Mon 04/05/2021		(Import)
0230	Continuous	0300		3800 MW
Work scheduled by: ConEd				SPR/DUN-SOUTH
				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_5				FWD
Mon 04/05/2021	to	Mon 04/05/2021		(Import)
0230	Continuous	0300		3800 MW
Work scheduled by: ConEd				SPR/DUN-SOUTH
				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
PLSNTVLY-WOOD_ST 345 F31				FWD
Tue 04/27/2021	to	Wed 04/28/2021		(Import)
0001	Continuous	0159		4000 MW
Work scheduled by: ConEd				UPNY CONED
				Impacts Total Transfer Capability 2220 MW
				TTC with All Lines In Service 6220 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 16, 2020 to Sunday ,April 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RNS4

Tue 04/27/2021 to Wed 04/28/2021
 0001 Continuous 0159
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 2420 MW
 TTC with All Lines In Service 6220 MW

SPRNBRK_345KV_RNS4

Sat 05/01/2021 to Sat 05/01/2021 **UPDATED by CONED 10/06/2020**
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

SPRNBRK_-W49TH_ST_345_M52

Sat 05/01/2021 to Tue 05/04/2021 **UPDATED by CONED 10/06/2020**
 0001 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

W49TH_ST_345KV_7

Sat 05/01/2021 to Tue 05/04/2021 **UPDATED by CONED 10/06/2020**
 0001 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

SCH-IMO-NYISO_LIMIT_1600

Sat 05/01/2021 to Sun 10/31/2021 **UPDATED by IESO 05/03/2019**
 0001 Continuous 2359
 Work scheduled by: IESO

FWD
 (Import)
 SCH - OH - NY **1900 MW**
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 1950 MW

CLAY_-EDIC_345_2-15

Mon 05/03/2021 to Fri 05/07/2021
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 OSWEGO EXPORT **4850 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 5250 MW

PANNELL_-CLAY_345_2

Mon 05/03/2021 to Sun 05/30/2021
 0700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 WEST CENTRAL **1300 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 16, 2020 to Sunday ,April 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HURLYAVE-ROSETON__345_303

Mon 05/03/2021 to Fri 05/21/2021
0800 Continuous 1600

Work scheduled by: CHGE

FWD

(Import)

UPNY CONED **4100 MW**
Impacts Total Transfer Capability 2120 MW
TTC with All Lines In Service 6220 MW

SPRNBRK__345KV_RNS4

Tue 05/04/2021 to Tue 05/04/2021
0230 Continuous 0300

Work scheduled by: ConEd

UPDATED by CONED 10/06/2020

FWD

(Import)

SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

NIAGARA__345KV_3102

Thu 05/06/2021 to Fri 05/07/2021
0500 Continuous 1700

Work scheduled by: NYPA

FWD

REV (Export)

SCH - OH - NY **1700 MW 1400 MW**
Impacts Total Transfer Capability 250 MW 300 MW
TTC with All Lines In Service 1950 MW 1700 MW

NIAGARA__345KV_3302

Mon 05/10/2021 to Wed 05/12/2021
0500 Continuous 1700

Work scheduled by: NYPA

FWD

REV (Export)

SCH - OH - NY **1000 MW 1600 MW**
Impacts Total Transfer Capability 950 MW 100 MW
TTC with All Lines In Service 1950 MW 1700 MW

CLAY__-EDIC__345_1-16

Mon 05/10/2021 to Fri 05/14/2021
0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

OSWEGO EXPORT **4850 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 5250 MW

NIAGARA__345KV_3108

Thu 05/13/2021 to Fri 05/14/2021
0500 Continuous 1700

Work scheduled by: NYPA

REV

(Export)

SCH - OH - NY **1500 MW**
Impacts Total Transfer Capability 200 MW
TTC with All Lines In Service 1700 MW

VOLNEY__-MARCY__345_19

Tue 06/01/2021 to Wed 06/02/2021
0700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC **2825 MW**
Impacts Total Transfer Capability 150 MW
TTC with All Lines In Service 2975 MW

ARR: 19

NYISO TRANSFER LIMITATIONS

Friday ,October 16, 2020 to Sunday ,April 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

VOLNEY__-MARCY___345_19

Tue 06/01/2021 to Wed 06/02/2021
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
OSWEGO EXPORT **4900 MW**
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 5250 MW

FRASER__-GILBOA___345_GF5-35

Tue 06/01/2021 to Mon 06/07/2021
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2650 MW**
Impacts Total Transfer Capability 325 MW
TTC with All Lines In Service 2975 MW

MOSES__-ADIRNDCK_230_MA2

Tue 06/01/2021 to Sun 11/14/2021
0700 Continuous 1300

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

PORTER__-ROTTRDAM_230_30

Thu 06/03/2021 to Wed 09/15/2021
0600 Continuous 0559

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **2805 MW**
Impacts Total Transfer Capability 170 MW
TTC with All Lines In Service 2975 MW

MARCY__-EDIC___345_UE1-7

Thu 06/03/2021 to Fri 06/04/2021
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19&16

FWD
(Import)
OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

MARCY___345KV_CSC

Sat 06/05/2021 to Sat 06/05/2021
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2925 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

MOSES__-ADIRNDCK_230_MA2 & MARCY___345KV_3102 & MARCY___345KV_3202 & MARCY___345KV_3302

Sat 06/05/2021 to Sat 06/05/2021
0700 Continuous 1730

Work scheduled by:

FWD
(Import)
MOSES SOUTH **1800 MW**
Impacts Total Transfer Capability 1350 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 16, 2020 to Sunday ,April 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SAND_BAR-PLATSBURG_115_PV20

Tue 08/03/2021 to Tue 08/03/2021
 0700 Continuous 1830
 Work scheduled by: NYPA

SCH - NE - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FRASANX-COOPERS_345_UCC2-41

Tue 09/07/2021 to Wed 09/15/2021
 0700 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 CENTRAL EAST - VC **2500 MW**
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

MARCY_-FRASANX_345_UCC2-41

Tue 09/07/2021 to Wed 09/15/2021
 0700 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 CENTRAL EAST - VC **2500 MW**
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

NIAGARA_-KINTIGH_345_NS1-38

Mon 09/13/2021 to Fri 09/17/2021
 0500 Continuous 1700
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **1400 MW**
 Impacts Total Transfer Capability 1750 MW
 TTC with All Lines In Service 3150 MW

PORTER_-ROTRDAM_230_30

Wed 09/15/2021 to Tue 11/30/2021
 0600 Continuous 1830
 Work scheduled by: NGrid

FWD
 (Import)
 CENTRAL EAST - VC **2805 MW**
 Impacts Total Transfer Capability 170 MW
 TTC with All Lines In Service 2975 MW

EDIC_-N.SCTLND_345_14

Thu 09/16/2021 to Sun 11/14/2021
 0600 Continuous 1830
 Work scheduled by: NGrid

FWD
 (Import)
 CENTRAL EAST - VC **2240 MW**
 Impacts Total Transfer Capability 735 MW
 TTC with All Lines In Service 2975 MW

HURLYAVE-ROSETON_345_303

Thu 09/16/2021 to Sun 10/17/2021
 0800 Continuous 1600
 Work scheduled by: CHGE

UPDATED by CHGE 09/22/2020

FWD
 (Import)
 UPNY CONED **4100 MW**
 Impacts Total Transfer Capability 2120 MW
 TTC with All Lines In Service 6220 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 16, 2020 to Sunday ,April 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PANNELL_-CLAY_____345_1

Mon 09/20/2021 to Fri 09/24/2021
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

PANNELL_-CLAY_____345_2

Mon 09/27/2021 to Fri 10/01/2021
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

W49TH_ST_345KV_6

Tue 09/28/2021 to Tue 09/28/2021
0100 Continuous 0130

Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **300 MW**
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

E13THSTA-FARRAGUT_345_46

Tue 09/28/2021 to Tue 10/26/2021
0100 Continuous 0300

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

W49TH_ST-E13THSTA_345_M55

Tue 09/28/2021 to Tue 10/26/2021
0100 Continuous 0300

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

LEEDS_-HURLYAVE_345_301

Mon 10/18/2021 to Fri 11/19/2021
0800 Continuous 1600

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 2120 MW
TTC with All Lines In Service 6220 MW

W49TH_ST_345KV_6

Tue 10/26/2021 to Tue 10/26/2021
0230 Continuous 0300

Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **300 MW**
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 16, 2020 to Sunday ,April 17, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO-NYISO_LIMIT_1750

FWD

Mon 11/01/2021 to Fri 12/31/2021 UPDATED by IESO 05/03/2019
 0001 Continuous 2359

(Import)

Work scheduled by: IESO

SCH - OH - NY **2050 MW**
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 2050 MW

SCH-NYISO-IMO_LIMIT_1600

REV

Mon 11/01/2021 to Fri 12/31/2021 UPDATED by IESO 05/03/2019
 0001 Continuous 2359

(Export)

Work scheduled by: IESO

SCH - OH - NY **1900 MW**
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 1900 MW

MOSES__-ADIRNDCK_230_MAL

FWD

Wed 12/01/2021 to Tue 05/31/2022
 0700 Continuous 1300

(Import)

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW