

# NYISO TRANSFER LIMITATIONS

Sunday ,October 18, 2020 to Tuesday ,April 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE\_345KV\_9\_BYPASS & DUNWODIE\_345KV\_10\_BYPASS & SPRNBRK\_\_345KV\_R5S3\_BYPASS & SPRNBRK\_\_345KV\_R4S3\_BYPASS**

FWD  
(Import)

Sun 02/01/2015 to Sun 11/01/2020  
0000 2359

SPR/DUN-SOUTH **4350 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 4600 MW

Work scheduled by:

**DUNWODIE\_345KV\_9\_BYPASS & DUNWODIE\_345KV\_10\_BYPASS & SPRNBRK\_\_345KV\_R5S3\_BYPASS & SPRNBRK\_\_345KV\_R4S3\_BYPASS**

Sun 02/01/2015 to Sun 11/01/2020  
0000 2359

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

Work scheduled by:

**HUDSONP\_-FARRAGUT\_345\_B3402**

FWD REV  
(Import) (Export)

Mon 01/15/2018 to Sun 02/28/2021 **EXT FORCE by CONED 08/28/2020**  
0001 Continuous 2359

SCH - PJ - NY **2050 MW 1150 MW**  
Impacts Total Transfer Capability 150 MW 100 MW  
TTC with All Lines In Service 2200 MW 1250 MW

Work scheduled by: ConEd

**HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_-FARRAGUT\_345\_C3403**

FWD REV  
(Import) (Export)

Mon 01/15/2018 to Sun 02/28/2021  
0001 2359

SCH - PJ - NY **2000 MW 1000 MW**  
Impacts Total Transfer Capability 200 MW 250 MW  
TTC with All Lines In Service 2200 MW 1250 MW

Work scheduled by:

**MARION\_-FARRAGUT\_345\_C3403**

FWD REV  
(Import) (Export)

Mon 01/15/2018 to Sun 02/28/2021 **EXT FORCE by CONED 08/28/2020**  
0001 Continuous 2359

SCH - PJ - NY **2050 MW 1150 MW**  
Impacts Total Transfer Capability 150 MW 100 MW  
TTC with All Lines In Service 2200 MW 1250 MW

Work scheduled by: ConEd

**STLAWRNC-MOSES\_\_230\_L33P**

Mon 04/30/2018 to Mon 10/31/2022 **EXT FORCE by IESO 10/01/2020**  
0456 Continuous 1600

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

Work scheduled by: IESO

# NYISO TRANSFER LIMITATIONS

Sunday ,October 18, 2020 to Tuesday ,April 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Transfer Limit	Start Date	End Date	Status	By	Effective Date	Impact	TTC
<b>SCH-IMO-NYISO_LIMIT_1600</b>	Fri 05/01/2020	Sat 10/31/2020	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	SCH - OH - NY	1900 MW
0001	Continuous	2359				Impacts Total Transfer Capability	50 MW
Work scheduled by: IESO						TTC with All Lines In Service	1950 MW
<b>SHOR_NPX-SHOREHAM_138_CSC</b>	Wed 07/08/2020	Wed 10/21/2020	<u>EXT FORCE</u>	<u>by LIPA</u>	<u>10/14/2020</u>	SCH - NPX_CSC	0 MW
1247	Continuous	0659				Impacts Total Transfer Capability	330 MW
Work scheduled by: LI						TTC with All Lines In Service	330 MW
<b>SPRNBRK_-W49TH_ST_345_M52</b>	Sun 08/16/2020	Sun 10/18/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>10/15/2020</u>	SPR/DUN-SOUTH	3200 MW
1149	Continuous	0300				Impacts Total Transfer Capability	1400 MW
Work scheduled by: ConEd						TTC with All Lines In Service	4600 MW
<b>BECK_-NIAGARA_230_PA27</b>	Mon 08/31/2020	Mon 11/30/2020				SCH - OH - NY	
0700	Continuous	0700				Impacts Total Transfer Capability	
Work scheduled by: IESO						TTC with All Lines In Service	
<b>SCH-IMO-NYISO_LIMIT_1450</b>	Mon 08/31/2020	Mon 11/30/2020				SCH - OH - NY	1750 MW
0700	Continuous	0700				Impacts Total Transfer Capability	200 MW
Work scheduled by: IESO						TTC with All Lines In Service	1950 MW
<b>NEWBRDGE_345_138_BK_1</b>	Wed 09/02/2020	Thu 12/31/2020	<u>EXT FORCE</u>	<u>by LI</u>	<u>09/03/2020</u>	SCH - PJM_NEPTUNE	375 MW
1807	Continuous	2359				Impacts Total Transfer Capability	285 MW
Work scheduled by: LI						TTC with All Lines In Service	660 MW
<b>MOSES_-ADIRNDCK_230_MA2</b>	Wed 09/09/2020	Sat 11/14/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/04/2020</u>	MOSES SOUTH	2100 MW
0700	Continuous	1300				Impacts Total Transfer Capability	1050 MW
Work scheduled by: NYPA						TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 18, 2020 to Tuesday ,April 19, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>							FWD
<b>SCH-IMO-NYISO_LIMIT_1350</b>							(Import)
Fri 09/18/2020	to	Sat 10/31/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/16/2020</u>	SCH - OH - NY	<b>1650 MW</b>
0500	Continuous	2359				Impacts Total Transfer Capability	300 MW
Work scheduled by: NYPA						TTC with All Lines In Service	1950 MW
<hr/>							FWD
<b>NIAGARA -ROCHESTR_345_NR2</b>							(Import)
Fri 09/18/2020	to	Sat 11/14/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/16/2020</u>	DYSINGER EAST	<b>1400 MW</b>
0500	Continuous	2330				Impacts Total Transfer Capability	1750 MW
Work scheduled by: NYPA						TTC with All Lines In Service	3150 MW
<hr/>							REV
<b>NIAGARA__345KV_3108</b>							(Export)
Fri 09/18/2020	to	Sat 11/14/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/16/2020</u>	SCH - OH - NY	<b>1500 MW</b>
0500	Continuous	2330				Impacts Total Transfer Capability	200 MW
Work scheduled by: NYPA						TTC with All Lines In Service	1700 MW
<hr/>							FWD
<b>CHAT_DC_GC1</b>							(Import)
Sat 09/26/2020	to	Tue 10/20/2020	<u>UPDATED</u>	<u>by HQ</u>	<u>09/30/2020</u>	MOSES SOUTH	<b>2850 MW</b>
2000	Continuous	2300				Impacts Total Transfer Capability	300 MW
Work scheduled by: HQ						TTC with All Lines In Service	3150 MW
<hr/>							REV
<b>CHAT_DC_GC1</b>							(Export)
Sat 09/26/2020	to	Tue 10/20/2020	<u>UPDATED</u>	<u>by HQ</u>	<u>09/30/2020</u>	SCH - HQ - NY	<b>500 MW</b>
2000	Continuous	2300				Impacts Total Transfer Capability	500 MW
Work scheduled by: HQ						TTC with All Lines In Service	1000 MW
<hr/>							REV
<b>SCH-NYISO-HQ_LIMIT_500</b>							(Export)
Sun 09/27/2020	to	Tue 10/20/2020	<u>UPDATED</u>	<u>by HQ</u>	<u>09/30/2020</u>	SCH - HQ - NY	<b>500 MW</b>
0500	Continuous	2300				Impacts Total Transfer Capability	500 MW
Work scheduled by: HQ						TTC with All Lines In Service	1000 MW
<hr/>							FWD
<b>W49TH_ST_345KV_5</b>							(Import)
Tue 09/29/2020	to	Sun 10/18/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>10/15/2020</u>	SCH - PJM_HTP	<b>300 MW</b>
0201	Continuous	0300				Impacts Total Transfer Capability	360 MW
Work scheduled by: ConEd						TTC with All Lines In Service	660 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 18, 2020 to Tuesday ,April 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SPRNBRK__345KV_RNS4</b>					FWD	
Thu 10/01/2020	to	Wed 10/14/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>10/15/2020</u>	(Import)
0001	Continuous	2359				SPR/DUN-SOUTH <b>3200 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 1400 MW	TTC with All Lines In Service 4600 MW
<b>SPRNBRK_-EGRDNCTR_345_Y49</b>					FWD	
Thu 10/01/2020	to	Mon 11/30/2020	<u>UPDATED</u>	<u>by LI</u>	<u>10/11/2020</u>	(Import)
0404	Continuous	2359				CONED - LIPA <b>775 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability 725 MW	TTC with All Lines In Service 1500 MW
<b>EGRDNCTY_345_138_AT2</b>					FWD	
Sat 10/10/2020	to	Mon 11/30/2020	<u>UPDATED</u>	<u>by LI</u>	<u>10/11/2020</u>	(Import)
1815	Continuous	2359				CONED - LIPA <b>1250 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability 250 MW	TTC with All Lines In Service 1500 MW
<b>EGRDNCTY_345_138_AT1</b>					FWD	
Sat 10/10/2020	to	Mon 11/30/2020	<u>UPDATED</u>	<u>by LI</u>	<u>10/11/2020</u>	(Import)
1856	Continuous	2359				CONED - LIPA <b>1250 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability 250 MW	TTC with All Lines In Service 1500 MW
<b>HOMR_NYW-PIERC_NY_345_48</b>						
Mon 10/12/2020	to	Fri 10/30/2020	<u>UPDATED</u>	<u>by PJM</u>	<u>10/09/2020</u>	
0800	Continuous	1600				SCH - PJ - NY
Work scheduled by: PJM					Impacts Total Transfer Capability	TTC with All Lines In Service
<b>HURLYAVE-ROSETON__345_303</b>					FWD	
Tue 10/13/2020	to	Fri 10/16/2020	<u>UPDATED</u>	<u>by CHGE</u>	<u>09/10/2020</u>	(Import)
0800	Continuous	1600				UPNY CONED <b>4100 MW</b>
Work scheduled by: CHGE					Impacts Total Transfer Capability 2120 MW	TTC with All Lines In Service 6220 MW
<b>ALCOA_PA_115KV_R8105</b>					FWD	
Wed 10/14/2020	to	Wed 10/14/2020	<u>UPDATED</u>	<u>by NGRID</u>	<u>10/12/2020</u>	(Import)
0700	Daily(No Weekends)	1400				MOSES SOUTH <b>3100 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability 50 MW	TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 18, 2020 to Tuesday ,April 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SPRNBRK__345KV_RNS3</b>					FWD
Thu 10/15/2020	to	Thu 10/15/2020	<b>CANCELLED</b>	<b>by ConEd</b>	<b>10/13/2020</b>
0301	Continuous	0330			
Work scheduled by: ConEd					
					(Import)
					SPR/DUN-SOUTH <b>3800 MW</b>
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
<b>SPRNBRK__345KV_RNS3</b>					FWD
Sun 10/18/2020	to	Sun 10/18/2020	<b>UPDATED</b>	<b>by CONED</b>	<b>10/16/2020</b>
0330	Continuous	0400			
Work scheduled by: ConEd					
					(Import)
					SPR/DUN-SOUTH <b>3800 MW</b>
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
<b>MILLWOOD_345KV_18</b>					FWD
Mon 10/19/2020	to	Mon 10/19/2020	<b>UPDATED</b>	<b>by CONED</b>	<b>10/18/2020</b>
0001	Continuous	0030			
Work scheduled by: ConEd					
					(Import)
					UPNY CONED <b>4350 MW</b>
					Impacts Total Transfer Capability 1870 MW
					TTC with All Lines In Service 6220 MW
<b>DUNWODIE-MOTTHAVN_345_71</b>					FWD
Mon 10/19/2020	to	Tue 10/20/2020	<b>UPDATED</b>	<b>by CONED</b>	<b>10/15/2020</b>
0001	Continuous	0159			
Work scheduled by: ConEd					
					(Import)
					SPR/DUN-SOUTH <b>3800 MW</b>
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
<b>DUNWODIE_345KV_5</b>					FWD
Mon 10/19/2020	to	Tue 10/20/2020	<b>UPDATED</b>	<b>by CONED</b>	<b>10/15/2020</b>
0001	Continuous	0159			
Work scheduled by: ConEd					
					(Import)
					SPR/DUN-SOUTH <b>3800 MW</b>
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
<b>DUNWODIE_345KV_3</b>					FWD
Mon 10/19/2020	to	Tue 11/24/2020	<b>UPDATED</b>	<b>by CONED</b>	<b>10/15/2020</b>
0001	Continuous	0159			
Work scheduled by: ConEd					
					(Import)
					SPR/DUN-SOUTH <b>3800 MW</b>
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
<b>DUNWODIE_345KV_4</b>					FWD
Mon 10/19/2020	to	Tue 11/24/2020	<b>UPDATED</b>	<b>by CONED</b>	<b>10/15/2020</b>
0001	Continuous	0159			
Work scheduled by: ConEd					
					(Import)
					SPR/DUN-SOUTH <b>3800 MW</b>
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 18, 2020 to Tuesday ,April 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>PLSNTVLE-DUNWODIE_345_W89</b>					FWD	
Mon 10/19/2020	to	Tue 11/24/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>10/15/2020</u>	(Import)
0001	Continuous	0159				4000 MW
Work scheduled by: ConEd					UPNY CONED	Impacts Total Transfer Capability 2220 MW
					TTC with All Lines In Service	6220 MW
<hr/>						
<b>SAND_BAR-PLATSBRG_115_PV20</b>						
Mon 10/19/2020	to	Fri 11/13/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/08/2020</u>	
0600	Continuous	1800				
Work scheduled by: ISONE					SCH - NE - NY	Impacts Total Transfer Capability
					TTC with All Lines In Service	
<hr/>						
<b>BERKSHIR-ALPS_____345_393</b>					FWD	REV
Mon 10/19/2020	to	Tue 11/10/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/16/2020</u>	(Import) (Export)
0630	Continuous	1600				950 MW 1300 MW
Work scheduled by: NGrid					ARR: 78	Impacts Total Transfer Capability 450 MW 300 MW
					TTC with All Lines In Service	1400 MW 1600 MW
<hr/>						
<b>BERKSHIR-ALPS_____345_393</b>					FWD	REV
Mon 10/19/2020	to	Tue 11/10/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/16/2020</u>	(Import) (Export)
0630	Continuous	1600				100 MW 100 MW
Work scheduled by: NGrid					ARR: 78	Impacts Total Transfer Capability 100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW
<hr/>						
<b>BERKSHIR-ALPS_____345_393 &amp; BERKSHIR-NORTHFLD_345_312</b>					FWD	REV
Mon 10/19/2020	to	Tue 11/10/2020				(Import) (Export)
0630		1600				950 MW 1300 MW
Work scheduled by:					ARR: 78	Impacts Total Transfer Capability 450 MW 300 MW
					TTC with All Lines In Service	1400 MW 1600 MW
<hr/>						
<b>BERKSHIR-NORTHFLD_345_312</b>					FWD	REV
Mon 10/19/2020	to	Tue 11/10/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/16/2020</u>	(Import) (Export)
0630	Continuous	1600				900 MW 1500 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability 500 MW 100 MW
					TTC with All Lines In Service	1400 MW 1600 MW
<hr/>						
<b>BERKSHIR-NORTHFLD_345_312</b>					FWD	REV
Mon 10/19/2020	to	Tue 11/10/2020	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/16/2020</u>	(Import) (Export)
0630	Continuous	1600				100 MW 100 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability 100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 18, 2020 to Tuesday ,April 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SCH-NE-NYISO_LIMIT_700</b>					FWD	
Mon 10/19/2020	to	Tue 11/10/2020	<b>UPDATED</b>	<b>by ISONE</b>	<b>10/16/2020</b>	(Import)
0630	Continuous	1600				<b>900 MW</b>
Work scheduled by: NGrid					SCH - NE - NY	Impacts Total Transfer Capability 500 MW
					TTC with All Lines In Service	1400 MW
<b>SCH-NYISO-NE_LIMIT_800</b>					REV	
Mon 10/19/2020	to	Tue 11/10/2020	<b>UPDATED</b>	<b>by ISONE</b>	<b>10/16/2020</b>	(Export)
0630	Continuous	1600				<b>1000 MW</b>
Work scheduled by: NGrid					SCH - NE - NY	Impacts Total Transfer Capability 600 MW
					TTC with All Lines In Service	1600 MW
<b>PIERCBRK-FIVEMILE_345_37</b>						
Mon 10/19/2020	to	Fri 10/23/2020	<b>UPDATED</b>	<b>by NGRID</b>	<b>10/16/2020</b>	
0700	Continuous	1400				
Work scheduled by: NYSEG					SCH - PJ - NY	Impacts Total Transfer Capability
					TTC with All Lines In Service	
<b>PANNELL_-CLAY_345_2</b>					FWD	
Mon 10/19/2020	to	Fri 10/23/2020	<b>UPDATED</b>	<b>by NYPA</b>	<b>05/07/2020</b>	(Import)
0700	Continuous	1530				<b>1300 MW</b>
Work scheduled by: NYPA					WEST CENTRAL	Impacts Total Transfer Capability 950 MW
					TTC with All Lines In Service	2250 MW
<b>SCH-NE-NYISO_LIMIT_700</b>					FWD	
Mon 10/19/2020	to	Fri 10/23/2020	<b>CANCELLED</b>	<b>by ISONE</b>	<b>10/16/2020</b>	(Import)
0700	Continuous	1600				<b>900 MW</b>
Work scheduled by: ISONE					SCH - NE - NY	Impacts Total Transfer Capability 500 MW
					TTC with All Lines In Service	1400 MW
<b>COOPERS_-DOLSONAV_345_CCDA42</b>					FWD	
Mon 10/19/2020	to	Fri 11/06/2020				(Import)
0700	Continuous	1730				<b>2720 MW</b>
Work scheduled by: NYPA					CENTRAL EAST - VC	Impacts Total Transfer Capability 255 MW
					TTC with All Lines In Service	2975 MW
<b>W49TH_ST_345KV_6</b>					FWD	
Tue 10/20/2020	to	Tue 10/20/2020	<b>EXTENDED</b>	<b>by CONED</b>	<b>10/15/2020</b>	(Import)
0331	Continuous	0400				<b>300 MW</b>
Work scheduled by: ConEd					SCH - PJM_HTP	Impacts Total Transfer Capability 360 MW
					TTC with All Lines In Service	660 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 18, 2020 to Tuesday ,April 19, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					FWD
<b>E13THSTA-FARRAGUT_345_46</b>					(Import)
Tue 10/20/2020	to	Fri 10/23/2020	<b><u>EXTENDED</u></b>	<b><u>by CONED</u></b>	<b><u>10/15/2020</u></b>
0331	Continuous	2300			
Work scheduled by: ConEd					SPR/DUN-SOUTH <b>3800 MW</b>
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
<hr/>					FWD
<b>W49TH_ST-E13THSTA_345_M55</b>					(Import)
Tue 10/20/2020	to	Fri 10/23/2020	<b><u>EXTENDED</u></b>	<b><u>by CONED</u></b>	<b><u>10/15/2020</u></b>
0331	Continuous	2300			
Work scheduled by: ConEd					SPR/DUN-SOUTH <b>3800 MW</b>
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
<hr/>					FWD
<b>CHAT_DC_GC2</b>					(Import)
Wed 10/21/2020	to	Sat 11/14/2020			
0500	Continuous	2300			
Work scheduled by: HQ					MOSES SOUTH <b>2850 MW</b>
					Impacts Total Transfer Capability 300 MW
					TTC with All Lines In Service 3150 MW
<hr/>					REV
<b>CHAT_DC_GC2</b>					(Export)
Wed 10/21/2020	to	Sat 11/14/2020			
0500	Continuous	2300			
Work scheduled by: HQ					SCH - HQ - NY <b>500 MW</b>
					Impacts Total Transfer Capability 500 MW
					TTC with All Lines In Service 1000 MW
<hr/>					REV
<b>SCH-NYISO-HQ_LIMIT_500</b>					(Export)
Wed 10/21/2020	to	Sat 11/14/2020			
0500	Continuous	2300			
Work scheduled by: HQ					SCH - HQ - NY <b>500 MW</b>
					Impacts Total Transfer Capability 500 MW
					TTC with All Lines In Service 1000 MW
<hr/>					FWD
<b>MILLWOOD_345KV_18</b>					(Import)
Fri 10/23/2020	to	Fri 10/23/2020	<b><u>UPDATED</u></b>	<b><u>by CONED</u></b>	<b><u>10/18/2020</u></b>
2130	Continuous	2200			
Work scheduled by: ConEd					UPNY CONED <b>4350 MW</b>
					Impacts Total Transfer Capability 1870 MW
					TTC with All Lines In Service 6220 MW
<hr/>					FWD
<b>W49TH_ST_345KV_6</b>					(Import)
Fri 10/23/2020	to	Fri 10/23/2020	<b><u>EXTENDED</u></b>	<b><u>by CONED</u></b>	<b><u>10/15/2020</u></b>
2230	Continuous	2300			
Work scheduled by: ConEd					SCH - PJM_HTP <b>300 MW</b>
					Impacts Total Transfer Capability 360 MW
					TTC with All Lines In Service 660 MW



# NYISO TRANSFER LIMITATIONS

Sunday ,October 18, 2020 to Tuesday ,April 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**HUDSONTP-W49TH\_ST\_345\_Y56**

Sat 10/24/2020 to Fri 10/30/2020  
 0001 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SCH - PJM\_HTP **0 MW**  
 Impacts Total Transfer Capability 660 MW  
 TTC with All Lines In Service 660 MW

**W49TH\_ST\_345KV\_7**

Sat 10/24/2020 to Fri 10/30/2020  
 0001 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

**W49TH\_ST\_345KV\_8**

Sat 10/24/2020 to Fri 10/30/2020  
 0001 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SCH - PJM\_HTP **450 MW**  
 Impacts Total Transfer Capability 210 MW  
 TTC with All Lines In Service 660 MW

**SPRNBK\_-TREMONT\_345\_X28**

Mon 10/26/2020 to Mon 10/26/2020 **UPDATED by CONED 10/18/2020**  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **4200 MW**  
 Impacts Total Transfer Capability 400 MW  
 TTC with All Lines In Service 4600 MW

**LEEDS\_\_\_345\_LEEDS SVC**

Mon 10/26/2020 to Fri 10/30/2020  
 0800 Continuous 1600  
 Work scheduled by: NGrid

FWD  
 (Import)  
 CENTRAL EAST - VC **2950 MW**  
 Impacts Total Transfer Capability 25 MW  
 TTC with All Lines In Service 2975 MW

**LEEDS\_\_\_345KV\_R94301**

Mon 10/26/2020 to Wed 11/25/2020  
 0800 Continuous 1600  
 Work scheduled by: NGrid

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 2420 MW  
 TTC with All Lines In Service 6220 MW

**LEEDS\_\_\_-HURLYAVE\_345\_301**

Mon 10/26/2020 to Fri 12/04/2020  
 0800 Continuous 1600  
 Work scheduled by: CHGE

FWD  
 (Import)  
 UPNY CONED **4100 MW**  
 Impacts Total Transfer Capability 2120 MW  
 TTC with All Lines In Service 6220 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 18, 2020 to Tuesday ,April 19, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BRANCHBG-HOPATCON_500_5060</b>					FWD	
Tue 10/27/2020	to	Tue 10/27/2020	<u>UPDATED</u>	<u>by PJM</u>	<u>10/15/2020</u>	(Import)
0200	Continuous	1500				<b>6025 MW</b>
Work scheduled by: PJM					UPNY CONED	
					Impacts Total Transfer Capability	195 MW
					TTC with All Lines In Service	6220 MW
<b>SCRIBA -VOLNEY_345_21</b>					FWD	
Wed 10/28/2020	to	Wed 10/28/2020				(Import)
0800	Daily(No Weekends)	1630				<b>5250 MW</b>
Work scheduled by: NGrid					OSWEGO EXPORT	
					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	5250 MW
<b>W49TH_ST_345KV_5</b>					FWD	
Fri 10/30/2020	to	Sat 10/31/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>10/11/2020</u>	(Import)
0301	Continuous	0300				<b>300 MW</b>
Work scheduled by: ConEd					SCH - PJM_HTP	
					Impacts Total Transfer Capability	360 MW
					TTC with All Lines In Service	660 MW
<b>W49TH_ST_345KV_7</b>					FWD	
Fri 10/30/2020	to	Sat 10/31/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>10/11/2020</u>	(Import)
0301	Continuous	0300				<b>300 MW</b>
Work scheduled by: ConEd					SCH - PJM_HTP	
					Impacts Total Transfer Capability	360 MW
					TTC with All Lines In Service	660 MW
<b>SPRNBK_345KV_RS3 &amp; SPRNBK_345KV_RS4</b>					FWD	
Sat 10/31/2020	to	Sat 10/31/2020				(Import)
0001		0030				<b>3200 MW</b>
Work scheduled by:					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
<b>SCH-IMO-NYISO_LIMIT_1750</b>					FWD	
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Import)
0001	Continuous	2359				<b>2050 MW</b>
Work scheduled by: IESO					SCH - OH - NY	
					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	2050 MW
<b>SCH-NYISO-IMO_LIMIT_1600</b>					REV	
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Export)
0001	Continuous	2359				<b>1900 MW</b>
Work scheduled by: IESO					SCH - OH - NY	
					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	1900 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 18, 2020 to Tuesday ,April 19, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SPRNBK\_\_345KV\_RS3 & SPRNBK\_\_345KV\_RS4**  
 Sun 11/01/2020 to Sun 11/01/2020  
 0130 0200  
 Work scheduled by:

FWD  
 (Import)  
**SPR/DUN-SOUTH 3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**EGRDNCTY\_345\_138\_AT1**  
 Sun 11/01/2020 to Fri 11/13/2020 **CANCELLED by LI 10/16/2020**  
 0800 Continuous 2159  
 Work scheduled by: LI

FWD  
 (Import)  
**CONED - LIPA 1250 MW**  
 Impacts Total Transfer Capability 250 MW  
 TTC with All Lines In Service 1500 MW

**EGRDNCTY\_345\_138\_AT2**  
 Sun 11/01/2020 to Fri 11/13/2020 **CANCELLED by LI 10/16/2020**  
 0800 Continuous 2159  
 Work scheduled by: LI

FWD  
 (Import)  
**CONED - LIPA 1250 MW**  
 Impacts Total Transfer Capability 250 MW  
 TTC with All Lines In Service 1500 MW

**SPRNBK\_-EGRDNCTR\_345\_Y49**  
 Sun 11/01/2020 to Fri 11/13/2020 **CANCELLED by LI 10/16/2020**  
 0800 Continuous 2159  
 Work scheduled by: LI

FWD  
 (Import)  
**CONED - LIPA 775 MW**  
 Impacts Total Transfer Capability 725 MW  
 TTC with All Lines In Service 1500 MW

**S.RIPLEY-DUNKIRK\_\_230\_68**  
 Mon 11/02/2020 to Fri 11/20/2020 **UPDATED by PJM 09/28/2020**  
 0700 Continuous 1800  
 Work scheduled by: NGrid

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**DUNWODIE\_345KV\_9\_BYPASS & DUNWODIE\_345KV\_10\_BYPASS & SPRNBK\_\_345KV\_R5S3\_BYPASS & SPRNBK\_\_345KV\_R4S3\_BYPASS**  
 Mon 11/02/2020 to Sat 02/01/2025  
 1800 0000  
 Work scheduled by:

FWD  
 (Import)  
**SPR/DUN-SOUTH 4350 MW**  
 Impacts Total Transfer Capability 250 MW  
 TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 18, 2020 to Tuesday ,April 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE\_345KV\_9\_BYPASS & DUNWODIE\_345KV\_10\_BYPASS & SPRNBRK\_\_345KV\_R5S3\_BYPASS  
& SPRNBRK\_\_345KV\_R4S3\_BYPASS

Mon 11/02/2020 to Sat 02/01/2025  
1800 0000

Work scheduled by:

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

SPRNBRK\_-TREMONT\_\_345\_X28

Fri 11/06/2020 to Sat 11/07/2020  
0001 Continuous 0059

Work scheduled by: ConEd

UPDATED by CONED 10/18/2020

FWD  
(Import)  
SPR/DUN-SOUTH **4200 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 4600 MW

NIAGARA\_\_345KV\_3102

Fri 11/06/2020 to Fri 11/06/2020  
0500 Continuous 2100

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **2000 MW 1700 MW**  
Impacts Total Transfer Capability 50 MW 200 MW  
TTC with All Lines In Service 2050 MW 1900 MW

NIAGARA\_\_345\_230\_AT4

Fri 11/06/2020 to Fri 11/06/2020  
0500 Continuous 2100

Work scheduled by: NYPA

REV  
(Export)  
SCH - OH - NY **1750 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 1900 MW

SPRNBRK\_-TREMONT\_\_345\_X28

Mon 11/09/2020 to Mon 11/09/2020  
0030 Continuous 0059

Work scheduled by: ConEd

UPDATED by CONED 10/18/2020

FWD  
(Import)  
SPR/DUN-SOUTH **4200 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 4600 MW

ROSETON\_-ROCKTVRN\_345\_311

Mon 11/09/2020 to Fri 11/20/2020  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4400 MW**  
Impacts Total Transfer Capability 1820 MW  
TTC with All Lines In Service 6220 MW

DUNWODIE-MOTTHAVN\_345\_71

Thu 11/12/2020 to Thu 11/12/2020  
0001 Continuous 0030

Work scheduled by: ConEd

UPDATED by CONED 10/15/2020

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 18, 2020 to Tuesday ,April 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>DUNWODIE_345KV_5</b>				FWD	
Thu 11/12/2020	to	Fri 11/13/2020	<u>UPDATED</u> <u>by CONED</u> <u>10/15/2020</u>	(Import)	
0001	Continuous	0100		SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
<b>DUNWODIE-MOTTHAVN_345_71</b>				FWD	
Fri 11/13/2020	to	Fri 11/13/2020	<u>UPDATED</u> <u>by CONED</u> <u>10/15/2020</u>	(Import)	
0030	Continuous	0100		SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
<b>CHATGUAY-MASSENA_765_7040</b>				FWD	
Sun 11/15/2020	to	Mon 11/30/2020		(Import)	
0100	Continuous	1900		MOSES SOUTH	<b>1550 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	1600 MW
				TTC with All Lines In Service	3150 MW
<b>CHATGUAY-MASSENA_765_7040</b>				FWD	REV
Sun 11/15/2020	to	Mon 11/30/2020		(Import) (Export)	
0100	Continuous	1900		SCH - HQ - NY	<b>0 MW 0 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	1500 MW 1000 MW
				TTC with All Lines In Service	1500 MW 1000 MW
<b>MARCY___765_345_AT1</b>				FWD	
Sun 11/15/2020	to	Mon 11/30/2020		(Import)	
0100	Continuous	1900		MOSES SOUTH	<b>1750 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	3150 MW
					<b>ARR: 19</b>
<b>MARCY___765_345_AT2</b>				FWD	
Sun 11/15/2020	to	Mon 11/30/2020		(Import)	
0100	Continuous	1900		MOSES SOUTH	<b>1700 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	1450 MW
				TTC with All Lines In Service	3150 MW
					<b>ARR: 19</b>
<b>MASSENA_-MARCY___765_MSU1</b>				FWD	
Sun 11/15/2020	to	Mon 11/30/2020		(Import)	
0100	Continuous	1900		CENTRAL EAST - VC	<b>2265 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	710 MW
				TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 18, 2020 to Tuesday ,April 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Transfer Description	Start	End	Time	Day	Impact	TTC	FWD	REV
MASSENA -MARCY 765_MSU1	Sun 11/15/2020	Mon 11/30/2020	0100	Continuous	1900	MOSES SOUTH	500 MW	
Work scheduled by: NYPA								
						Impacts Total Transfer Capability	2650 MW	
						TTC with All Lines In Service	3150 MW	
MASSENA -MARCY 765_MSU1	Sun 11/15/2020	Mon 11/30/2020	0100	Continuous	1900	SCH - HQ - NY	475 MW	1000 MW
Work scheduled by: NYPA								
						Impacts Total Transfer Capability	1025 MW	0 MW
						TTC with All Lines In Service	1500 MW	1000 MW
MASSENA -MARCY 765_MSU1	Sun 11/15/2020	Mon 11/30/2020	0100	Continuous	1900	SCH - HQ_CEDARS	90 MW	
Work scheduled by: NYPA								
						Impacts Total Transfer Capability	109 MW	
						TTC with All Lines In Service	199 MW	
MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040	Sun 11/15/2020	Mon 11/30/2020	0100		1900	MOSES SOUTH	500 MW	
Work scheduled by:								
						Impacts Total Transfer Capability	2650 MW	
						TTC with All Lines In Service	3150 MW	
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2	Sun 11/15/2020	Mon 11/30/2020	0100		1900	SCH - HQ - NY	850 MW	0 MW
Work scheduled by:								
						Impacts Total Transfer Capability	650 MW	1000 MW
						TTC with All Lines In Service	1500 MW	1000 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2	Sun 11/15/2020	Mon 11/30/2020	0100		1900	SCH - HQ_CEDARS	90 MW	
Work scheduled by:								
						Impacts Total Transfer Capability	109 MW	
						TTC with All Lines In Service	199 MW	
STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1	Sun 11/15/2020	Mon 11/30/2020	0100		1900	SCH - HQ_CEDARS	90 MW	
Work scheduled by:								
						Impacts Total Transfer Capability	109 MW	
						TTC with All Lines In Service	199 MW	

# NYISO TRANSFER LIMITATIONS

Sunday ,October 18, 2020 to Tuesday ,April 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STLAWRNC-MOSES___230_L33P & MOSES___-MASSENA_230_MMS1 & MOSES___-				FWD
MASSENA_230_MMS2				(Import)
Sun 11/15/2020	to	Mon 11/30/2020		SCH - HQ_CEDARS
0100		1900		Impacts Total Transfer Capability
Work scheduled by:				TTC with All Lines In Service
W49TH_ST_345KV_5				FWD
				(Import)
Tue 11/17/2020	to	Tue 11/17/2020		SCH - PJM_HTP
0001	Continuous	0030		Impacts Total Transfer Capability
Work scheduled by: ConEd				TTC with All Lines In Service
W49TH_ST_345KV_7				FWD
				(Import)
Tue 11/17/2020	to	Tue 11/17/2020		SCH - PJM_HTP
0001	Continuous	0030		Impacts Total Transfer Capability
Work scheduled by: ConEd				TTC with All Lines In Service
W49TH_ST_345KV_5				FWD
				(Import)
Thu 11/19/2020	to	Thu 11/19/2020		SCH - PJM_HTP
1830	Continuous	1900		Impacts Total Transfer Capability
Work scheduled by: ConEd				TTC with All Lines In Service
W49TH_ST_345KV_7				FWD
				(Import)
Thu 11/19/2020	to	Thu 11/19/2020		SCH - PJM_HTP
1830	Continuous	1900		Impacts Total Transfer Capability
Work scheduled by: ConEd				TTC with All Lines In Service
W49TH_ST_345KV_6				FWD
				(Import)
Fri 11/20/2020	to	Wed 11/25/2020	<u>UPDATED</u> <u>by CE</u> <u>08/06/2020</u>	SCH - PJM_HTP
0001	Continuous	2300		Impacts Total Transfer Capability
Work scheduled by: ConEd				TTC with All Lines In Service
W49TH_ST_345KV_8				FWD
				(Import)
Fri 11/20/2020	to	Wed 11/25/2020	<u>UPDATED</u> <u>by CE</u> <u>08/06/2020</u>	SCH - PJM_HTP
0001	Continuous	2300		Impacts Total Transfer Capability
Work scheduled by: ConEd				TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

Sunday ,October 18, 2020 to Tuesday ,April 19, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SPRNBK_-TREMONT__345_X28</b>					FWD	
Tue 11/24/2020	to	Wed 11/25/2020	<u>UPDATED</u>	<u>by CE</u>	<u>10/16/2020</u>	(Import)
0101	Continuous	0300				<b>4200 MW</b>
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	400 MW
					TTC with All Lines In Service	4600 MW
<b>BUCHAN_N-EASTVIEW_345_W93</b>					FWD	
Wed 11/25/2020	to	Wed 11/25/2020		<u>by CONED</u>	<u>10/16/2020</u>	(Import)
0301	Continuous	0330				<b>4350 MW</b>
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	1870 MW
					TTC with All Lines In Service	6220 MW
<b>EASTVIEW-SPRNBK__345_W79</b>					FWD	
Wed 11/25/2020	to	Thu 11/26/2020		<u>by CONED</u>	<u>10/16/2020</u>	(Import)
0301	Continuous	0300				<b>4350 MW</b>
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	1870 MW
					TTC with All Lines In Service	6220 MW
<b>MOTTHAVN-RAINEY__345_Q12</b>					FWD	
Wed 11/25/2020	to	Thu 12/03/2020	<u>UPDATED</u>	<u>by CONED</u>	<u>10/16/2020</u>	(Import)
0301	Continuous	0159				<b>3800 MW</b>
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>BUCHAN_N-EASTVIEW_345_W93</b>					FWD	
Thu 11/26/2020	to	Thu 11/26/2020		<u>by CONED</u>	<u>10/16/2020</u>	(Import)
0130	Continuous	0300				<b>4350 MW</b>
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	1870 MW
					TTC with All Lines In Service	6220 MW
<b>DOLSONAV-ROCKTVRN_345_DART44</b>					FWD	
Mon 11/30/2020	to	Mon 12/14/2020	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/27/2020</u>	(Import)
0700	Continuous	1730				<b>2720 MW</b>
Work scheduled by: NYPA					CENTRAL EAST - VC	
					Impacts Total Transfer Capability	255 MW
					TTC with All Lines In Service	2975 MW
<b>NEPTUNE_-DUFFYAVE_345_NEPTUNE</b>					FWD	
Mon 11/30/2020	to	Fri 12/11/2020		<u>by LI</u>	<u>09/14/2020</u>	(Import)
0800	Continuous	1600				<b>0 MW</b>
Work scheduled by: PJM					SCH - PJM_NEPTUNE	
					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	660 MW



# NYISO TRANSFER LIMITATIONS

Sunday ,October 18, 2020 to Tuesday ,April 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NEWBRDGE-DUFFYAVE\_345\_501**

Mon 11/30/2020 to Fri 12/11/2020  
0800 Continuous 1600

by LI 09/14/2020

Work scheduled by: PJM

FWD  
(Import)

SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

**MARCY\_345KV\_CSC**

Tue 12/01/2020 to Fri 12/11/2020  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)

CENTRAL EAST - VC **2925 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

**MOSES-ADIRNDCK\_230\_MA1**

Tue 12/01/2020 to Sat 02/27/2021  
0700 Continuous 1730

UPDATED by NYPA 07/27/2020

Work scheduled by: NYPA

FWD  
(Import)

MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**LAFAYTTE-CLRKSCRN\_345\_4-46**

Tue 12/01/2020 to Tue 12/01/2020  
0730 Daily(No Weekends) 1230

UPDATED by NGRID 10/05/2020

Work scheduled by: NGrid

FWD  
(Import)

CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

**W49TH\_ST\_345KV\_6**

Tue 12/01/2020 to Tue 12/01/2020  
2230 Continuous 2300

UPDATED by CE 08/06/2020

Work scheduled by: ConEd

FWD  
(Import)

SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

**W49TH\_ST\_345KV\_8**

Tue 12/01/2020 to Tue 12/01/2020  
2230 Continuous 2300

UPDATED by CE 08/06/2020

Work scheduled by: ConEd

FWD  
(Import)

SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

**MOTTHAVN-RAINEY\_345\_Q11**

Thu 12/03/2020 to Tue 12/08/2020  
0201 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 18, 2020 to Tuesday ,April 19, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>KINTIGH_-ROCHESTR_345_SR1-39</b>				FWD
Thu 12/03/2020	to	Tue 12/15/2020	<b>UPDATED</b>	(Import)
0800	Continuous	1900	<b>by NYISO</b>	<b>1700 MW</b>
Work scheduled by: RGE				DYSINGER EAST
				Impacts Total Transfer Capability 1450 MW
				TTC with All Lines In Service 3150 MW
<b>NIAGARA_-KINTIGH_345_NS1-38</b>				FWD
Thu 12/03/2020	to	Tue 12/15/2020	<b>UPDATED</b>	(Import)
0800	Continuous	1900	<b>by NYISO</b>	<b>1700 MW</b>
Work scheduled by: RGE				DYSINGER EAST
				Impacts Total Transfer Capability 1450 MW
				TTC with All Lines In Service 3150 MW
<b>BECK_-PACKARD_230_BP76</b>				FWD
Fri 12/04/2020	to	Fri 12/04/2020		REV
0730	Daily(No Weekends)	1530		(Import) (Export)
Work scheduled by: NGrid				SCH - OH - NY
				<b>1650 MW 1400 MW</b>
				Impacts Total Transfer Capability 400 MW 500 MW
				TTC with All Lines In Service 2050 MW 1900 MW
<b>OSWEGO_COMPLEX_AVR_O/S</b>				FWD
Sun 12/06/2020	to	Sun 12/06/2020		(Import)
0900	Continuous	0930		<b>2870 MW</b>
Work scheduled by: Gen				CENTRAL EAST - VC
				Impacts Total Transfer Capability 105 MW
				TTC with All Lines In Service 2975 MW
<b>SAND_BAR-PLATSBRG_115_PV20</b>				
Mon 12/07/2020	to	Fri 12/11/2020		
0700	Continuous	1530		
Work scheduled by: NYPA				SCH - NE - NY
				Impacts Total Transfer Capability
				TTC with All Lines In Service
<b>LONG_MTN-CRICKVLY_345_398</b>				FWD
Tue 12/08/2020	to	Thu 12/10/2020		REV
0700	Continuous	1600		(Import) (Export)
Work scheduled by: ISONE				SCH - NE - NY
				<b>700 MW 1300 MW</b>
				Impacts Total Transfer Capability 700 MW 400 MW
				TTC with All Lines In Service 1400 MW 1700 MW
<b>LONG_MTN-CRICKVLY_345_398</b>				FWD
Tue 12/08/2020	to	Thu 12/10/2020		REV
0700	Continuous	1600		(Import) (Export)
Work scheduled by: ISONE				SCH - NPX_1385
				<b>100 MW 100 MW</b>
				Impacts Total Transfer Capability 100 MW 100 MW
				TTC with All Lines In Service 200 MW 200 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 18, 2020 to Tuesday ,April 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SCH-NE-NYISO_LIMIT_400</b>			FWD
Tue 12/08/2020	to	Thu 12/10/2020	(Import)
0700	Continuous	1600	SCH - NE - NY <b>600 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability 800 MW
			TTC with All Lines In Service 1400 MW
<b>SCH-NYISO-NE_LIMIT_1000</b>			REV
Tue 12/08/2020	to	Thu 12/10/2020	(Export)
0700	Continuous	1600	SCH - NE - NY <b>1200 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability 500 MW
			TTC with All Lines In Service 1700 MW
<b>MARCY -EDIC 345_UE1-7</b>			FWD
Mon 12/14/2020	to	Mon 12/14/2020	(Import)
0700	Continuous	1730	OSWEGO EXPORT <b>5250 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability 0 MW
ARR: 19&16			TTC with All Lines In Service 5250 MW
<b>SAND_BAR-PLATSBRG_115_PV20</b>			
Mon 12/14/2020	to	Fri 12/18/2020	SCH - NE - NY
0700	Continuous	1530	Impacts Total Transfer Capability
Work scheduled by: NYPA			TTC with All Lines In Service
<b>FRASANNX-COOPERS_345_UCC2-41</b>			FWD
Tue 12/15/2020	to	Wed 12/16/2020	(Import)
0700	Continuous	1530	CENTRAL EAST - VC <b>2500 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability 475 MW
ARR: 19			TTC with All Lines In Service 2975 MW
<b>MARCY -FRASANNX_345_UCC2-41</b>			FWD
Tue 12/15/2020	to	Wed 12/16/2020	(Import)
0700	Continuous	1530	CENTRAL EAST - VC <b>2500 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability 475 MW
ARR: 19			TTC with All Lines In Service 2975 MW
<b>STONYRDG-HILLSIDE_230_72</b>			FWD
Wed 12/16/2020	to	Mon 12/21/2020	(Import)
0800	Continuous	0300	DYSINGER EAST <b>2850 MW</b>
Work scheduled by: NYSEG			Impacts Total Transfer Capability 300 MW
			TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 18, 2020 to Tuesday ,April 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**N. SCTLND-LEEDS\_\_\_345\_93**

Thu 12/17/2020 to Fri 12/18/2020  
 0800 Continuous 1500  
 Work scheduled by: NGrid

FWD  
 (Import)  
 CENTRAL EAST - VC **2650 MW**  
 Impacts Total Transfer Capability 325 MW  
 TTC with All Lines In Service 2975 MW

**BUCHAN\_N-EASTVIEW\_345\_W93**

Tue 12/22/2020 to Tue 12/22/2020 UPDATED by CE 10/16/2020  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1870 MW  
 TTC with All Lines In Service 6220 MW

**EASTVIEW-SPRNBK\_\_345\_W79**

Tue 12/22/2020 to Fri 12/25/2020 UPDATED by CE 10/16/2020  
 0001 Continuous 0259  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1870 MW  
 TTC with All Lines In Service 6220 MW

**BUCHAN\_N-EASTVIEW\_345\_W93**

Fri 12/25/2020 to Fri 12/25/2020 UPDATED by CE 10/16/2020  
 0230 Continuous 0259  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1870 MW  
 TTC with All Lines In Service 6220 MW

**SPRNBK\_-TREMONT\_\_345\_X28**

Sat 12/26/2020 to Tue 12/29/2020 UPDATED by CE 10/16/2020  
 0301 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **4200 MW**  
 Impacts Total Transfer Capability 400 MW  
 TTC with All Lines In Service 4600 MW

**LADENTWN-BUCHAN\_S\_345\_Y88**

Mon 12/28/2020 to Fri 02/12/2021 UPDATED by CE 10/16/2020  
 0300 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **5930 MW**  
 Impacts Total Transfer Capability 290 MW  
 TTC with All Lines In Service 6220 MW

**SPRNBK\_-TREMONT\_\_345\_X28**

Wed 12/30/2020 to Wed 12/30/2020 UPDATED by CE 10/16/2020  
 2130 Continuous 2200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **4200 MW**  
 Impacts Total Transfer Capability 400 MW  
 TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 18, 2020 to Tuesday ,April 19, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>HOPATCON-RAMAPO__500_5018</b>				FWD	REV
Mon 02/01/2021	to	Sat 02/06/2021	<b><u>CANCELLED</u></b> <b><u>by ConEd</u></b> <b><u>10/13/2020</u></b>	(Import)	(Export)
0001	Continuous	0200		<b>1250 MW</b>	<b>1200 MW</b>
Work scheduled by: ConEd				SCH - PJ - NY	
				Impacts Total Transfer Capability	1650 MW 650 MW
				TTC with All Lines In Service	2900 MW 1850 MW
<b>HOPATCON-RAMAPO__500_5018</b>				FWD	
Mon 02/01/2021	to	Sat 02/06/2021	<b><u>CANCELLED</u></b> <b><u>by ConEd</u></b> <b><u>10/13/2020</u></b>	(Import)	
0001	Continuous	0200		UPNY CONED	<b>6025 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	195 MW
				TTC with All Lines In Service	6220 MW
<b>RAMAPO__345_345_PAR3500</b>				FWD	REV
Mon 02/01/2021	to	Sat 02/06/2021	<b><u>CANCELLED</u></b> <b><u>by ConEd</u></b> <b><u>10/13/2020</u></b>	(Import)	(Export)
0001	Continuous	0200		SCH - PJ - NY	<b>2150 MW 1250 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	750 MW 600 MW
				TTC with All Lines In Service	2900 MW 1850 MW
<b>RAMAPO__345_345_PAR4500</b>				FWD	REV
Mon 02/01/2021	to	Sat 02/06/2021	<b><u>CANCELLED</u></b> <b><u>by ConEd</u></b> <b><u>10/13/2020</u></b>	(Import)	(Export)
0001	Continuous	0200		SCH - PJ - NY	<b>2150 MW 1250 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	750 MW 600 MW
				TTC with All Lines In Service	2900 MW 1850 MW
<b>RAMAPO__500_345_BK 1500</b>				FWD	REV
Mon 02/01/2021	to	Sat 02/06/2021	<b><u>CANCELLED</u></b> <b><u>by ConEd</u></b> <b><u>10/13/2020</u></b>	(Import)	(Export)
0001	Continuous	0200		SCH - PJ - NY	<b>1250 MW 1200 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	1650 MW 650 MW
				TTC with All Lines In Service	2900 MW 1850 MW
<b>RAMAPO__500_345_BK 1500</b>				FWD	
Mon 02/01/2021	to	Sat 02/06/2021	<b><u>CANCELLED</u></b> <b><u>by ConEd</u></b> <b><u>10/13/2020</u></b>	(Import)	
0001	Continuous	0200		UPNY CONED	<b>6025 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	195 MW
				TTC with All Lines In Service	6220 MW
<b>PORTER__-ROTTDAM_230_31</b>				FWD	
Mon 02/01/2021	to	Sat 02/27/2021		(Import)	
0600	Continuous	1830		CENTRAL EAST - VC	<b>2805 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability	170 MW
				TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 18, 2020 to Tuesday ,April 19, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>6220MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>PLSNTVLY-WOOD_ST__345_F30</b>					FWD	
Sun 02/14/2021	to	Tue 02/16/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>09/28/2020</u>	(Import)
2000	Continuous	0200				UPNY CONED <b>4000 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 2220 MW	
					TTC with All Lines In Service 6220 MW	
<b>PLSNTVLY_345KV_RNS5</b>					FWD	
Sun 02/14/2021	to	Tue 02/16/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>09/28/2020</u>	(Import)
2000	Continuous	0200				UPNY CONED <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 2420 MW	
					TTC with All Lines In Service 6220 MW	
<b>BERKSHIR-ALPS____345_393</b>					FWD	REV
Wed 02/17/2021	to	Fri 02/19/2021				(Import) (Export)
0730	Continuous	1600				SCH - NE - NY <b>1150 MW 1700 MW</b>
Work scheduled by: NGrid			<b>ARR: 78</b>			Impacts Total Transfer Capability 250 MW 0 MW
					TTC with All Lines In Service 1400 MW 1700 MW	
<b>BERKSHIR-ALPS____345_393</b>					FWD	REV
Wed 02/17/2021	to	Fri 02/19/2021				(Import) (Export)
0730	Continuous	1600				SCH - NPX_1385 <b>100 MW 100 MW</b>
Work scheduled by: NGrid			<b>ARR: 78</b>			Impacts Total Transfer Capability 100 MW 100 MW
					TTC with All Lines In Service 200 MW 200 MW	
<b>EFISHKIL-WOOD_ST__345_F39</b>					FWD	
Thu 02/18/2021	to	Sat 02/20/2021	<u>UPDATED</u>	<u>by CE</u>	<u>04/01/2020</u>	(Import)
2100	Continuous	0200				UPNY CONED <b>4000 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 2220 MW	
					TTC with All Lines In Service 6220 MW	
<b>WOOD_ST_-PLSNTVLE_345_Y87</b>					FWD	
Thu 02/18/2021	to	Sat 02/20/2021	<u>UPDATED</u>	<u>by CE</u>	<u>04/01/2020</u>	(Import)
2100	Continuous	0200				UPNY CONED <b>5905 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 315 MW	
					TTC with All Lines In Service 6220 MW	
<b>CHATGUAY-MASSENA__765_7040</b>					FWD	
Sun 02/28/2021	to	Mon 03/01/2021				(Import)
0500	Continuous	1730				MOSES SOUTH <b>1550 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 1600 MW	
					TTC with All Lines In Service 3150 MW	

# NYISO TRANSFER LIMITATIONS

Sunday ,October 18, 2020 to Tuesday ,April 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Zone	Start	End	Time	Day	Direction	Impact	TTC
CHATGUAY-MASSENA 765_7040	Sun 02/28/2021	Mon 03/01/2021	0500 - 1730	Continuous	FWD (Import)	SCH - HQ - NY	0 MW
						Impacts Total Transfer Capability	1500 MW
						TTC with All Lines In Service	1500 MW
Work scheduled by: NYPA							
MASSENA -MARCY 765_MSU1	Sun 02/28/2021	Mon 03/01/2021	0500 - 1730	Continuous	FWD (Import)	CENTRAL EAST - VC	2265 MW
						Impacts Total Transfer Capability	710 MW
						TTC with All Lines In Service	2975 MW
Work scheduled by: NYPA							
MASSENA -MARCY 765_MSU1	Sun 02/28/2021	Mon 03/01/2021	0500 - 1730	Continuous	FWD (Import)	MOSES SOUTH	500 MW
						Impacts Total Transfer Capability	2650 MW
						TTC with All Lines In Service	3150 MW
Work scheduled by: NYPA							
MASSENA -MARCY 765_MSU1	Sun 02/28/2021	Mon 03/01/2021	0500 - 1730	Continuous	FWD (Import) (Export)	SCH - HQ - NY	475 MW / 1000 MW
						Impacts Total Transfer Capability	1025 MW / 0 MW
						TTC with All Lines In Service	1500 MW / 1000 MW
Work scheduled by: NYPA							
MASSENA -MARCY 765_MSU1	Sun 02/28/2021	Mon 03/01/2021	0500 - 1730	Continuous	FWD (Import)	SCH - HQ_CEDARS	90 MW
						Impacts Total Transfer Capability	109 MW
						TTC with All Lines In Service	199 MW
Work scheduled by: NYPA							
MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040	Sun 02/28/2021	Mon 03/01/2021	0500 - 1730	Continuous	FWD (Import)	MOSES SOUTH	500 MW
						Impacts Total Transfer Capability	2650 MW
						TTC with All Lines In Service	3150 MW
Work scheduled by:							
STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1	Sun 02/28/2021	Mon 03/01/2021	0500 - 1730	Continuous	FWD (Import)	SCH - HQ_CEDARS	90 MW
						Impacts Total Transfer Capability	109 MW
						TTC with All Lines In Service	199 MW
Work scheduled by:							

# NYISO TRANSFER LIMITATIONS

Sunday ,October 18, 2020 to Tuesday ,April 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>DUNWODIE_345KV_3</b>				FWD
Mon 03/01/2021	to	Mon 03/01/2021		(Import)
0001	Continuous	0030	SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
<b>DUNWODIE_345KV_5</b>				FWD
Mon 03/01/2021	to	Mon 03/01/2021		(Import)
0001	Continuous	0030	SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
<b>EASTVIEW-SPRNBK__345_W64</b>				FWD
Mon 03/01/2021	to	Mon 03/01/2021	<b>UPDATED by CONED 01/23/2020</b>	(Import)
0001	Continuous	0030	UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 1870 MW
				TTC with All Lines In Service 6220 MW
<b>SPRNBK__345KV_RNS5</b>				FWD
Mon 03/01/2021	to	Mon 03/01/2021	<b>UPDATED by CONED 01/23/2020</b>	(Import)
0001	Continuous	0030	SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW
<b>MILLWOOD-EASTVIEW_345_W99</b>				FWD
Mon 03/01/2021	to	Mon 03/22/2021	<b>UPDATED by CONED 01/23/2020</b>	(Import)
0001	Continuous	0200	UPNY CONED	<b>5985 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 235 MW
				TTC with All Lines In Service 6220 MW
<b>DUNWODIE-MOTTHAVN_345_71</b>				FWD
Mon 03/01/2021	to	Mon 04/05/2021		(Import)
0001	Continuous	0300	SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
<b>MOTTHAVN-RAINEY__345_Q11</b>				FWD
Mon 03/01/2021	to	Tue 04/06/2021		(Import)
0001	Continuous	0700	SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW



# NYISO TRANSFER LIMITATIONS

Sunday ,October 18, 2020 to Tuesday ,April 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>EDIC -N.SCTLND_345_14</b>					FWD
Tue 03/02/2021	to	Mon 05/31/2021			(Import)
0600	Continuous	1830		CENTRAL EAST - VC	<b>2240 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability 735 MW
					TTC with All Lines In Service 2975 MW
<b>PORTER -ROTRDAM_230_31</b>					FWD
Tue 03/02/2021	to	Mon 05/31/2021			(Import)
0600	Continuous	1830		CENTRAL EAST - VC	<b>2805 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability 170 MW
					TTC with All Lines In Service 2975 MW
<b>MOSES -ADIRNDCK_230_MA1</b>					FWD
Tue 03/02/2021	to	Mon 05/31/2021			(Import)
0700	Continuous	1300		MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 850 MW
					TTC with All Lines In Service 3150 MW
<b>NIAGARA -ROBNSNRD_230_64</b>					REV
Fri 03/12/2021	to	Fri 03/12/2021			(Export)
0500	Continuous	1700		SCH - OH - NY	<b>1900 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 0 MW
					TTC with All Lines In Service 1900 MW
<b>MARCY 345KV_CSC</b>					FWD
Sat 03/13/2021	to	Sat 03/13/2021	<b>UPDATED</b>	<b>by NYPA</b>	<b>07/29/2020</b>
0700	Continuous	1730			(Import)
Work scheduled by: NYPA					CENTRAL EAST - VC
					<b>2925 MW</b>
					Impacts Total Transfer Capability 50 MW
					TTC with All Lines In Service 2975 MW
<b>EASTVIEW-SPRNBK_345_W64</b>					FWD
Mon 03/22/2021	to	Mon 03/22/2021	<b>UPDATED</b>	<b>by CONED</b>	<b>01/23/2020</b>
0130	Continuous	0200			(Import)
Work scheduled by: ConEd					UPNY CONED
					<b>4350 MW</b>
					Impacts Total Transfer Capability 1870 MW
					TTC with All Lines In Service 6220 MW
<b>SPRNBK_345KV_RNS5</b>					FWD
Mon 03/22/2021	to	Mon 03/22/2021	<b>UPDATED</b>	<b>by CONED</b>	<b>01/23/2020</b>
0130	Continuous	0200			(Import)
Work scheduled by: ConEd					SPR/DUN-SOUTH
					<b>3200 MW</b>
					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 18, 2020 to Tuesday ,April 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>W49TH_ST_345KV_5</b>				FWD
Fri 03/26/2021	to	Wed 05/05/2021	<b>UPDATED by CONED 10/06/2020</b>	(Import)
0001	Continuous	0300		<b>SCH - PJM_HTP 300 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 360 MW
				TTC with All Lines In Service 660 MW
<b>CLAY -EDIC 345 2-15</b>				FWD
Mon 03/29/2021	to	Fri 04/16/2021	<b>09/12/2020</b>	(Import)
0800	Continuous	1730		<b>OSWEGO EXPORT 4850 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability 400 MW
				TTC with All Lines In Service 5250 MW
<b>ROCHESTR-PANNELL 345 RP2</b>				FWD
Wed 03/31/2021	to	Mon 04/12/2021		(Import)
0500	Continuous	1700		<b>DYSINGER EAST 2300 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW
<b>LINDN_CG-LNDVFT 345 V-3022</b>				FWD      REV
Sun 04/04/2021	to	Sat 04/10/2021		(Import) (Export)
1400	Continuous	1400		<b>SCH - PJM_VFT 0 MW 0 MW</b>
Work scheduled by: PJM				Impacts Total Transfer Capability 315 MW 315 MW
				TTC with All Lines In Service 315 MW 315 MW
<b>DUNWODIE_345KV_3</b>				FWD
Mon 04/05/2021	to	Mon 04/05/2021		(Import)
0230	Continuous	0300		<b>SPR/DUN-SOUTH 3800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
<b>DUNWODIE_345KV_5</b>				FWD
Mon 04/05/2021	to	Mon 04/05/2021		(Import)
0230	Continuous	0300		<b>SPR/DUN-SOUTH 3800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
<b>PLSNTVLY-WOOD_ST 345 F31</b>				FWD
Tue 04/27/2021	to	Wed 04/28/2021		(Import)
0001	Continuous	0159		<b>UPNY CONED 4000 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 2220 MW
				TTC with All Lines In Service 6220 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 18, 2020 to Tuesday ,April 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**PLSNTVLY\_345KV\_RNS4**

Tue 04/27/2021 to Wed 04/28/2021  
 0001 Continuous 0159  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 2420 MW  
 TTC with All Lines In Service 6220 MW

**SPRNBRK\_345KV\_RNS4**

Sat 05/01/2021 to Sat 05/01/2021 UPDATED by CONED 10/06/2020  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

**SPRNBRK\_-W49TH\_ST\_345\_M52**

Sat 05/01/2021 to Tue 05/04/2021 UPDATED by CONED 10/06/2020  
 0001 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

**W49TH\_ST\_345KV\_7**

Sat 05/01/2021 to Tue 05/04/2021 UPDATED by CONED 10/06/2020  
 0001 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

**SCH-IMO-NYISO\_LIMIT\_1600**

Sat 05/01/2021 to Sun 10/31/2021 UPDATED by IESO 05/03/2019  
 0001 Continuous 2359  
 Work scheduled by: IESO

FWD  
 (Import)  
 SCH - OH - NY **1900 MW**  
 Impacts Total Transfer Capability 50 MW  
 TTC with All Lines In Service 1950 MW

**CLAY\_-EDIC\_345\_2-15**

Mon 05/03/2021 to Fri 05/07/2021  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 OSWEGO EXPORT **4850 MW**  
 Impacts Total Transfer Capability 400 MW  
 TTC with All Lines In Service 5250 MW

**PANNELL\_-CLAY\_345\_2**

Mon 05/03/2021 to Sun 05/30/2021  
 0700 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
 WEST CENTRAL **1300 MW**  
 Impacts Total Transfer Capability 950 MW  
 TTC with All Lines In Service 2250 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 18, 2020 to Tuesday ,April 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>HURLYAVE-ROSETON__345_303</b>				FWD	
Mon 05/03/2021	to	Fri 05/21/2021		(Import)	
0800	Continuous	1600	UPNY CONED	<b>4100 MW</b>	
Work scheduled by: CHGE			Impacts Total Transfer Capability	2120 MW	
			TTC with All Lines In Service	6220 MW	
<b>SPRNBRK__345KV_RNS4</b>				FWD	
Tue 05/04/2021	to	Tue 05/04/2021	<u>UPDATED</u> <u>by CONED</u> <u>10/06/2020</u>	(Import)	
0230	Continuous	0300	SPR/DUN-SOUTH	<b>3200 MW</b>	
Work scheduled by: ConEd			Impacts Total Transfer Capability	1400 MW	
			TTC with All Lines In Service	4600 MW	
<b>NIAGARA__345KV_3102</b>				FWD	REV
Thu 05/06/2021	to	Fri 05/07/2021		(Import)	(Export)
0500	Continuous	1700	SCH - OH - NY	<b>1700 MW</b>	<b>1400 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	250 MW	300 MW
			TTC with All Lines In Service	1950 MW	1700 MW
<b>NIAGARA__345KV_3302</b>				FWD	REV
Mon 05/10/2021	to	Wed 05/12/2021		(Import)	(Export)
0500	Continuous	1700	SCH - OH - NY	<b>1000 MW</b>	<b>1600 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	950 MW	100 MW
			TTC with All Lines In Service	1950 MW	1700 MW
<b>CLAY____-EDIC____345_1-16</b>				FWD	
Mon 05/10/2021	to	Fri 05/14/2021		(Import)	
0700	Continuous	1530	OSWEGO EXPORT	<b>4850 MW</b>	
Work scheduled by: NYPA			Impacts Total Transfer Capability	400 MW	
			TTC with All Lines In Service	5250 MW	
<b>NIAGARA__345KV_3108</b>					REV
Thu 05/13/2021	to	Fri 05/14/2021			(Export)
0500	Continuous	1700	SCH - OH - NY		<b>1500 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability		200 MW
			TTC with All Lines In Service		1700 MW
<b>VOLNEY__-MARCY____345_19</b>				FWD	
Tue 06/01/2021	to	Wed 06/02/2021		(Import)	
0700	Continuous	1730	CENTRAL EAST - VC	<b>2825 MW</b>	
Work scheduled by: NYPA			Impacts Total Transfer Capability	150 MW	
			TTC with All Lines In Service	2975 MW	

ARR: 19

# NYISO TRANSFER LIMITATIONS

Sunday ,October 18, 2020 to Tuesday ,April 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**VOLNEY\_\_-MARCY\_\_\_345\_19**

Tue 06/01/2021 to Wed 06/02/2021  
0700 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
OSWEGO EXPORT **4900 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 5250 MW

**FRASER\_\_-GILBOA\_\_\_345\_GF5-35**

Tue 06/01/2021 to Mon 06/07/2021  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

**MOSES\_\_-ADIRNDCK\_230\_MA2**

Tue 06/01/2021 to Sun 11/14/2021  
0700 Continuous 1300

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

**PORTER\_\_-ROTTRDAM\_230\_30**

Thu 06/03/2021 to Wed 09/15/2021  
0600 Continuous 0559

Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC **2805 MW**  
Impacts Total Transfer Capability 170 MW  
TTC with All Lines In Service 2975 MW

**MARCY\_\_-EDIC\_\_\_345\_UE1-7**

Thu 06/03/2021 to Fri 06/04/2021  
0700 Continuous 1730

Work scheduled by: NYPA

**ARR: 19&16**

FWD  
(Import)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

**MARCY\_\_\_345KV\_CSC**

Sat 06/05/2021 to Sat 06/05/2021  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2925 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

**MOSES\_\_-ADIRNDCK\_230\_MA2 & MARCY\_\_\_345KV\_3102 & MARCY\_\_\_345KV\_3202 & MARCY\_\_\_345KV\_3302**

Sat 06/05/2021 to Sat 06/05/2021  
0700 Continuous 1730

Work scheduled by:

FWD  
(Import)  
MOSES SOUTH **1800 MW**  
Impacts Total Transfer Capability 1350 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 18, 2020 to Tuesday ,April 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SAND\_BAR-PLATSBRG\_115\_PV20

Tue 08/03/2021 to Tue 08/03/2021  
 0700 Continuous 1830  
 Work scheduled by: NYPA

SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FRASANNX-COOPERS\_345\_UCC2-41

Tue 09/07/2021 to Wed 09/15/2021  
 0700 Continuous 1730  
 Work scheduled by: NYPA

ARR: 19

FWD  
 (Import)  
 CENTRAL EAST - VC **2500 MW**  
 Impacts Total Transfer Capability 475 MW  
 TTC with All Lines In Service 2975 MW

MARCY\_-FRASANNX\_345\_UCC2-41

Tue 09/07/2021 to Wed 09/15/2021  
 0700 Continuous 1730  
 Work scheduled by: NYPA

ARR: 19

FWD  
 (Import)  
 CENTRAL EAST - VC **2500 MW**  
 Impacts Total Transfer Capability 475 MW  
 TTC with All Lines In Service 2975 MW

NIAGARA\_-KINTIGH\_345\_NS1-38

Mon 09/13/2021 to Fri 09/17/2021  
 0500 Continuous 1700  
 Work scheduled by: NYPA

FWD  
 (Import)  
 DYSINGER EAST **1400 MW**  
 Impacts Total Transfer Capability 1750 MW  
 TTC with All Lines In Service 3150 MW

PORTER\_-ROTRDAM\_230\_30

Wed 09/15/2021 to Tue 11/30/2021  
 0600 Continuous 1830  
 Work scheduled by: NGrid

FWD  
 (Import)  
 CENTRAL EAST - VC **2805 MW**  
 Impacts Total Transfer Capability 170 MW  
 TTC with All Lines In Service 2975 MW

EDIC\_-N.SCTLND\_345\_14

Thu 09/16/2021 to Sun 11/14/2021  
 0600 Continuous 1830  
 Work scheduled by: NGrid

FWD  
 (Import)  
 CENTRAL EAST - VC **2240 MW**  
 Impacts Total Transfer Capability 735 MW  
 TTC with All Lines In Service 2975 MW

HURLYAVE-ROSETON\_345\_303

Thu 09/16/2021 to Sun 10/17/2021  
 0800 Continuous 1600  
 Work scheduled by: CHGE

UPDATED by CHGE 09/22/2020

FWD  
 (Import)  
 UPNY CONED **4100 MW**  
 Impacts Total Transfer Capability 2120 MW  
 TTC with All Lines In Service 6220 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 18, 2020 to Tuesday ,April 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**PANNELL\_-CLAY\_\_\_\_\_345\_1**

Mon 09/20/2021 to Fri 09/24/2021  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 WEST CENTRAL **1300 MW**  
 Impacts Total Transfer Capability 950 MW  
 TTC with All Lines In Service 2250 MW

**PANNELL\_-CLAY\_\_\_\_\_345\_2**

Mon 09/27/2021 to Fri 10/01/2021  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 WEST CENTRAL **1300 MW**  
 Impacts Total Transfer Capability 950 MW  
 TTC with All Lines In Service 2250 MW

**W49TH\_ST\_345KV\_6**

Tue 09/28/2021 to Tue 09/28/2021  
 0100 Continuous 0130  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

**E13THSTA-FARRAGUT\_345\_46**

Tue 09/28/2021 to Tue 10/26/2021  
 0100 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**W49TH\_ST-E13THSTA\_345\_M55**

Tue 09/28/2021 to Tue 10/26/2021  
 0100 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**LEEDS\_-HURLYAVE\_345\_301**

Mon 10/18/2021 to Fri 11/19/2021  
 0800 Continuous 1600  
 Work scheduled by: CHGE

FWD  
 (Import)  
 UPNY CONED **4100 MW**  
 Impacts Total Transfer Capability 2120 MW  
 TTC with All Lines In Service 6220 MW

**W49TH\_ST\_345KV\_6**

Tue 10/26/2021 to Tue 10/26/2021  
 0230 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 18, 2020 to Tuesday ,April 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO-NYISO\_LIMIT\_1750

FWD

Mon 11/01/2021 to Fri 12/31/2021 UPDATED by IESO 05/03/2019  
 0001 Continuous 2359

(Import)

Work scheduled by: IESO

SCH - OH - NY **2050 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 2050 MW

SCH-NYISO-IMO\_LIMIT\_1600

REV

Mon 11/01/2021 to Fri 12/31/2021 UPDATED by IESO 05/03/2019  
 0001 Continuous 2359

(Export)

Work scheduled by: IESO

SCH - OH - NY **1900 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 1900 MW

MOSES\_\_-ADIRNDCK\_230\_MAL

FWD

Wed 12/01/2021 to Tue 05/31/2022  
 0700 Continuous 1300

(Import)

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW