

NYISO TRANSFER LIMITATIONS

Tuesday ,January 12, 2021 to Thursday ,July 14, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Wed 06/30/2021 **EXT FORCE by CONED 08/28/2020**
 0001 Continuous 2359
 Work scheduled by: ConEd

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Wed 06/30/2021
 0001 2359
 Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2550 MW	1900 MW
Impacts Total Transfer Capability	250 MW	50 MW
TTC with All Lines In Service	2800 MW	1950 MW

MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Wed 06/30/2021 **EXT FORCE by CONED 08/28/2020**
 0001 Continuous 2359
 Work scheduled by: ConEd

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

STLAWRNC-MOSES_230_L33P

Mon 04/30/2018 to Mon 10/31/2022 **EXT FORCE by IESO 10/01/2020**
 0456 Continuous 1600
 Work scheduled by: IESO

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

NEWBRDGE_345_138_BK_1

Wed 09/02/2020 to Tue 02/01/2022 **EXT FORCE by LI 01/12/2021**
 1807 Continuous 2359
 Work scheduled by: LI

	FWD
	(Import)
SCH - PJM_NEPTUNE	375 MW
Impacts Total Transfer Capability	285 MW
TTC with All Lines In Service	660 MW

SPRNBK_-EGRDNCTR_345_Y49

Thu 10/01/2020 to Fri 02/19/2021 **EXT FORCE by LI 12/16/2020**
 0404 Continuous 2359
 Work scheduled by: LI

	FWD
	(Import)
CONED - LIPA	775 MW
Impacts Total Transfer Capability	725 MW
TTC with All Lines In Service	1500 MW

EGRDNCTY_345_138_AT2

Sat 10/10/2020 to Fri 02/19/2021 **EXT FORCE by LI 12/16/2020**
 1815 Continuous 2359
 Work scheduled by: LI

	FWD
	(Import)
CONED - LIPA	1250 MW
Impacts Total Transfer Capability	250 MW
TTC with All Lines In Service	1500 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,January 12, 2021 to Thursday ,July 14, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EGRDNCTY_345_138_AT1						FWD
Sat 10/10/2020	to	Fri 02/19/2021	<u>EXT FORCE</u>	<u>by LI</u>	<u>12/16/2020</u>	(Import)
1856	Continuous	2359				1250 MW
Work scheduled by: LI						CONED - LIPA
						Impacts Total Transfer Capability 250 MW
						TTC with All Lines In Service 1500 MW
SCH-IMO-NYISO_LIMIT_1750						FWD
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Import)
0001	Continuous	2359				2050 MW
Work scheduled by: IESO						SCH - OH - NY
						Impacts Total Transfer Capability 250 MW
						TTC with All Lines In Service 2300 MW
SCH-NYISO-IMO_LIMIT_1600						REV
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Export)
0001	Continuous	2359				1900 MW
Work scheduled by: IESO						SCH - OH - NY
						Impacts Total Transfer Capability 100 MW
						TTC with All Lines In Service 2000 MW
SHOR_NPX-SHOREHAM_138_CSC						FWD REV
Sun 11/08/2020	to	Fri 01/15/2021	<u>EXT FORCE</u>	<u>by ISONE</u>	<u>12/23/2020</u>	(Import) (Export)
1341	Continuous	2000				0 MW 0 MW
Work scheduled by: LI						SCH - NPX_CSC
						Impacts Total Transfer Capability 330 MW 330 MW
						TTC with All Lines In Service 330 MW 330 MW
PLSNTVLE-DUNWODIE_345_W89						FWD
Mon 11/30/2020	to	Mon 01/18/2021	<u>EXT FORCE</u>	<u>by CONED</u>	<u>12/23/2020</u>	(Import)
1840	Continuous	0259				4000 MW
Work scheduled by: ConEd						UPNY CONED
						Impacts Total Transfer Capability 2220 MW
						TTC with All Lines In Service 6220 MW
SHORE_RD_345_138_BK_2						FWD
Sat 12/19/2020	to	Fri 03/05/2021	<u>EXTENDED</u>	<u>by LIPA</u>	<u>12/23/2020</u>	(Import)
1452	Continuous	2359				1350 MW
Work scheduled by: LI						CONED - LIPA
						Impacts Total Transfer Capability 150 MW
						TTC with All Lines In Service 1500 MW
NEPTUNE_-DUFFYAVE_345_NEPTUNE						FWD
Thu 12/31/2020	to	Wed 01/27/2021	<u>EXT FORCE</u>	<u>by PJM</u>	<u>01/04/2021</u>	(Import)
1100	Continuous	2359				0 MW
Work scheduled by: PJM						SCH - PJM_NEPTUNE
						Impacts Total Transfer Capability 660 MW
						TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,January 12, 2021 to Thursday ,July 14, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE-DUFFYAVE_345_501						FWD
Thu 12/31/2020	to	Wed 01/27/2021	<u>EXT FORCE</u>	<u>by PJM</u>	<u>01/04/2021</u>	(Import)
1102	Continuous	2359				0 MW
Work scheduled by: PJM						SCH - PJM_NEPTUNE
						Impacts Total Transfer Capability 660 MW
						TTC with All Lines In Service 660 MW
NEWBRDGE_345_138_BK_2						FWD
Thu 12/31/2020	to	Wed 01/27/2021	<u>EXT FORCE</u>	<u>by PJM</u>	<u>01/04/2021</u>	(Import)
1102	Continuous	2359				375 MW
Work scheduled by: PJM						SCH - PJM_NEPTUNE
						Impacts Total Transfer Capability 285 MW
						TTC with All Lines In Service 660 MW
MOSES__-ADIRNDCK_230_MAL						FWD
Mon 01/04/2021	to	Sat 02/27/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>11/30/2020</u>	(Import)
0700	Continuous	1730				2300 MW
Work scheduled by: NYPA						MOSES SOUTH
						Impacts Total Transfer Capability 850 MW
						TTC with All Lines In Service 3150 MW
SCH-IMO-NYISO_LIMIT_1100						FWD
Tue 01/05/2021	to	Sat 01/09/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>01/09/2021</u>	(Import)
0600	Continuous	1700				1400 MW
Work scheduled by: IESO						SCH - OH - NY
						Impacts Total Transfer Capability 900 MW
						TTC with All Lines In Service 2300 MW
SCH-NYISO-IMO_LIMIT_800						REV
Tue 01/05/2021	to	Sat 01/09/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>01/09/2021</u>	(Export)
0600	Continuous	1700				1100 MW
Work scheduled by: IESO						SCH - OH - NY
						Impacts Total Transfer Capability 900 MW
						TTC with All Lines In Service 2000 MW
SCRIBA__-VOLNEY__345_21						FWD
Thu 01/07/2021	to	Thu 01/07/2021				(Import)
0600	Daily(No Weekends)	1630				5250 MW
Work scheduled by: NGrid						OSWEGO EXPORT
						Impacts Total Transfer Capability 0 MW
						TTC with All Lines In Service 5250 MW
SCH-NYISO-IMO_LIMIT_1200						REV
Sun 01/10/2021	to	Tue 01/12/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>01/11/2021</u>	(Export)
0855	Continuous	1059				1500 MW
Work scheduled by: IESO						SCH - OH - NY
						Impacts Total Transfer Capability 500 MW
						TTC with All Lines In Service 2000 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,January 12, 2021 to Thursday ,July 14, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO-NYISO_LIMIT_1450						FWD
Sun 01/10/2021	to	Tue 01/12/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>01/11/2021</u>	(Import)
0855	Continuous	2359				1750 MW
Work scheduled by: IESO						SCH - OH - NY
						Impacts Total Transfer Capability 550 MW
						TTC with All Lines In Service 2300 MW
CHASLAKE-PORTER_230_11						FWD
Mon 01/11/2021	to	Mon 01/11/2021				(Import)
0700	Daily(No Weekends)	1600				2300 MW
Work scheduled by: NGrid						MOSES SOUTH
						Impacts Total Transfer Capability 850 MW
						TTC with All Lines In Service 3150 MW
SCH-NYISO-IMO_LIMIT_1100						REV
Tue 01/12/2021	to	Thu 01/14/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>01/11/2021</u>	(Export)
1100	Continuous	1600				1400 MW
Work scheduled by: IESO						SCH - OH - NY
						Impacts Total Transfer Capability 600 MW
						TTC with All Lines In Service 2000 MW
SCH-IMO-NYISO_LIMIT_1150						FWD
Wed 01/13/2021	to	Thu 01/14/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>01/11/2021</u>	(Import)
0001	Continuous	1600				1450 MW
Work scheduled by: IESO						SCH - OH - NY
						Impacts Total Transfer Capability 850 MW
						TTC with All Lines In Service 2300 MW
BECK_-NIAGARA_230_PA27						FWD
Thu 01/14/2021	to	Thu 01/14/2021				(Import)
0800	Continuous	1600				2100 MW
Work scheduled by: IESO						SCH - OH - NY
						Impacts Total Transfer Capability 200 MW
						TTC with All Lines In Service 2300 MW
SCH-IMO-NYISO_LIMIT_700						FWD
Thu 01/14/2021	to	Thu 01/14/2021				(Import)
0800	Continuous	1600				1000 MW
Work scheduled by: IESO						SCH - OH - NY
						Impacts Total Transfer Capability 1300 MW
						TTC with All Lines In Service 2300 MW
SCH-NYISO-IMO_LIMIT_900						REV
Thu 01/14/2021	to	Thu 01/14/2021				(Export)
0800	Continuous	1600				1200 MW
Work scheduled by: IESO						SCH - OH - NY
						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 2000 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,January 12, 2021 to Thursday ,July 14, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LADENTWN-BUCHAN_S_345_Y88						FWD
Mon 01/18/2021	to	Fri 03/05/2021	<u>UPDATED</u>	<u>by CE</u>	<u>11/10/2020</u>	(Import)
0300	Continuous	0300				UPNY CONED 5930 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 290 MW
						TTC with All Lines In Service 6220 MW
SPRNBRK_-W49TH_ST_345_M52						FWD
Sat 01/23/2021	to	Sun 01/24/2021				(Import)
0001	Continuous	0059				SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 1400 MW
						TTC with All Lines In Service 4600 MW
W49TH_ST_345KV_5						FWD
Sat 01/23/2021	to	Sun 01/24/2021				(Import)
0001	Continuous	0059				SCH - PJM_HTP 300 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 360 MW
						TTC with All Lines In Service 660 MW
MOTTHAVN-RAINEY___345_Q12						FWD
Mon 01/25/2021	to	Sat 02/13/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>12/22/2020</u>	(Import)
0001	Continuous	0200				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
PORTER__-ROTTRDAM_230_31						FWD
Mon 02/01/2021	to	Sat 02/27/2021				(Import)
0600	Continuous	1830				CENTRAL EAST - VC 2805 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability 170 MW
						TTC with All Lines In Service 2975 MW
W49TH_ST_345KV_5						FWD
Mon 02/08/2021	to	Tue 02/09/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>01/11/2021</u>	(Import)
0001	Continuous	0200				SCH - PJM_HTP 300 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 360 MW
						TTC with All Lines In Service 660 MW
W49TH_ST_345KV_7						FWD
Mon 02/08/2021	to	Tue 02/09/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>01/11/2021</u>	(Import)
0001	Continuous	0200				SCH - PJM_HTP 300 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 360 MW
						TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,January 12, 2021 to Thursday ,July 14, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

RAMAPO__345_345_PAR3500					FWD	REV
Mon 02/08/2021	to	Mon 02/15/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>12/09/2020</u>	(Import) (Export)
0001	Continuous	0200				
Work scheduled by: ConEd					SCH - PJ - NY	2350 MW 1250 MW
					Impacts Total Transfer Capability	450 MW 700 MW
					TTC with All Lines In Service	2800 MW 1950 MW
RAMAPO__345_345_PAR4500					FWD	REV
Mon 02/08/2021	to	Mon 02/15/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>12/09/2020</u>	(Import) (Export)
0001	Continuous	0200				
Work scheduled by: ConEd					SCH - PJ - NY	2350 MW 1250 MW
					Impacts Total Transfer Capability	450 MW 700 MW
					TTC with All Lines In Service	2800 MW 1950 MW
RAMAPO__500_345_BK 1500					FWD	REV
Mon 02/08/2021	to	Mon 02/15/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>12/09/2020</u>	(Import) (Export)
0001	Continuous	0200				
Work scheduled by: ConEd					SCH - PJ - NY	1450 MW 1200 MW
					Impacts Total Transfer Capability	1350 MW 750 MW
					TTC with All Lines In Service	2800 MW 1950 MW
RAMAPO__500_345_BK 1500					FWD	
Mon 02/08/2021	to	Mon 02/15/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>12/09/2020</u>	(Import)
0001	Continuous	0200				
Work scheduled by: ConEd					UPNY CONED	6025 MW
					Impacts Total Transfer Capability	195 MW
					TTC with All Lines In Service	6220 MW
HOPATCON-RAMAPO__500_5018					FWD	REV
Mon 02/08/2021	to	Mon 02/15/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>12/09/2020</u>	(Import) (Export)
0001	Continuous	1900				
Work scheduled by: ConEd					SCH - PJ - NY	1450 MW 1200 MW
					Impacts Total Transfer Capability	1350 MW 750 MW
					TTC with All Lines In Service	2800 MW 1950 MW
HOPATCON-RAMAPO__500_5018					FWD	
Mon 02/08/2021	to	Mon 02/15/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>12/09/2020</u>	(Import)
0001	Continuous	1900				
Work scheduled by: ConEd					UPNY CONED	6025 MW
					Impacts Total Transfer Capability	195 MW
					TTC with All Lines In Service	6220 MW
WATRCURE-OAKDALE__345_31						
Mon 02/15/2021	to	Thu 02/18/2021				
0800	Daily	1500				
Work scheduled by: NYSEG					SCH - PJ - NY	
					Impacts Total Transfer Capability	
					TTC with All Lines In Service	

NYISO TRANSFER LIMITATIONS

Tuesday ,January 12, 2021 to Thursday ,July 14, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

E13THSTA-FARRAGUT_345_46					FWD	
Tue 02/16/2021	to	Wed 02/17/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>12/21/2020</u>	(Import)
0001	Continuous	2100				3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW	
					TTC with All Lines In Service 4600 MW	
W49TH_ST_345KV_8					FWD	
Tue 02/16/2021	to	Sun 03/28/2021				(Import)
0201	Continuous	0200				300 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 360 MW	
					TTC with All Lines In Service 660 MW	
BERKSHIR-ALPS_____345_393					FWD	
Wed 02/17/2021	to	Fri 02/19/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>12/29/2020</u>	(Import) (Export)
0600	Continuous	1700				1100 MW 1700 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 300 MW 0 MW	
					TTC with All Lines In Service 1400 MW 1700 MW	
BERKSHIR-ALPS_____345_393					FWD	
Wed 02/17/2021	to	Fri 02/19/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>12/29/2020</u>	(Import) (Export)
0600	Continuous	1700				100 MW 100 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 100 MW 100 MW	
					TTC with All Lines In Service 200 MW 200 MW	
BERKSHIR-ALPS_____345_393 & BERKSHIR-NORTHFLD_345_312					FWD	
Wed 02/17/2021	to	Fri 02/19/2021				(Import) (Export)
0600		1700				1100 MW 1700 MW
Work scheduled by:					Impacts Total Transfer Capability 300 MW 0 MW	
					TTC with All Lines In Service 1400 MW 1700 MW	
BERKSHIR-NORTHFLD_345_312					FWD	
Wed 02/17/2021	to	Fri 02/19/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>12/29/2020</u>	(Import)
0600	Continuous	1700				1300 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 100 MW	
					TTC with All Lines In Service 1400 MW	
BERKSHIR-NORTHFLD_345_312					FWD	
Wed 02/17/2021	to	Fri 02/19/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>12/29/2020</u>	(Import) (Export)
0600	Continuous	1700				100 MW 100 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 100 MW 100 MW	
					TTC with All Lines In Service 200 MW 200 MW	

NYISO TRANSFER LIMITATIONS

Tuesday ,January 12, 2021 to Thursday ,July 14, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_800				FWD
Wed 02/17/2021	to	Fri 02/19/2021	<u>UPDATED</u> <u>by ISONE</u> <u>12/29/2020</u>	(Import)
0600	Continuous	1700		1000 MW
Work scheduled by: NGrid				SCH - NE - NY
				Impacts Total Transfer Capability 400 MW
				TTC with All Lines In Service 1400 MW
SCH-NYISO-NE_LIMIT_700				REV
Wed 02/17/2021	to	Fri 02/19/2021	<u>UPDATED</u> <u>by ISONE</u> <u>12/29/2020</u>	(Export)
0600	Continuous	1700		900 MW
Work scheduled by: NGrid				SCH - NE - NY
				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 1700 MW
SAND_BAR-PLATSBURG_115_PV20				
Mon 02/22/2021	to	Fri 02/26/2021		SCH - NE - NY
0600	Daily	1800		Impacts Total Transfer Capability
Work scheduled by: ISONE				TTC with All Lines In Service
BRANCHBG-HOPATCON_500_5060				FWD
Wed 02/24/2021	to	Wed 02/24/2021		(Import)
0200	Continuous	2200		6025 MW
Work scheduled by: PJM				UPNY CONED
				Impacts Total Transfer Capability 195 MW
				TTC with All Lines In Service 6220 MW
CHATGUAY-MASSENA_765_7040				FWD
Sun 02/28/2021	to	Mon 03/01/2021		(Import)
0500	Continuous	1730		1550 MW
Work scheduled by: NYPA				MOSES SOUTH
				Impacts Total Transfer Capability 1600 MW
				TTC with All Lines In Service 3150 MW
CHATGUAY-MASSENA_765_7040				FWD
Sun 02/28/2021	to	Mon 03/01/2021		(Import) (Export)
0500	Continuous	1730		0 MW 0 MW
Work scheduled by: NYPA				SCH - HQ - NY
				Impacts Total Transfer Capability 1500 MW 1000 MW
				TTC with All Lines In Service 1500 MW 1000 MW
MASSENA_-MARCY_765_MSU1				FWD
Sun 02/28/2021	to	Mon 03/01/2021		(Import)
0500	Continuous	1730		2265 MW
Work scheduled by: NYPA				CENTRAL EAST - VC
				Impacts Total Transfer Capability 710 MW
				TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,January 12, 2021 to Thursday ,July 14, 2022

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>MASSENA -MARCY 765_MSU1</p> <p>Sun 02/28/2021 to Mon 03/01/2021 0500 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import) MOSES SOUTH 500 MW Impacts Total Transfer Capability 2650 MW TTC with All Lines In Service 3150 MW</p>
<p>MASSENA -MARCY 765_MSU1</p> <p>Sun 02/28/2021 to Mon 03/01/2021 0500 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p>FWD REV (Import) (Export) SCH - HQ - NY 475 MW 1000 MW Impacts Total Transfer Capability 1025 MW 0 MW TTC with All Lines In Service 1500 MW 1000 MW</p>
<p>MASSENA -MARCY 765_MSU1</p> <p>Sun 02/28/2021 to Mon 03/01/2021 0500 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import) SCH - HQ_CEDARS 90 MW Impacts Total Transfer Capability 109 MW TTC with All Lines In Service 199 MW</p>
<p>MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040</p> <p>Sun 02/28/2021 to Mon 03/01/2021 0500 1730</p> <p>Work scheduled by:</p>	<p>FWD (Import) MOSES SOUTH 500 MW Impacts Total Transfer Capability 2650 MW TTC with All Lines In Service 3150 MW</p>
<p>STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1</p> <p>Sun 02/28/2021 to Mon 03/01/2021 0500 1730</p> <p>Work scheduled by:</p>	<p>FWD (Import) SCH - HQ_CEDARS 90 MW Impacts Total Transfer Capability 109 MW TTC with All Lines In Service 199 MW</p>
<p>MOTTHAVN-RAINEY 345_Q11</p> <p>Mon 03/01/2021 to Tue 04/06/2021 0001 Continuous 0700</p> <p>Work scheduled by: ConEd</p>	<p>FWD (Import) SPR/DUN-SOUTH 3800 MW Impacts Total Transfer Capability 800 MW TTC with All Lines In Service 4600 MW</p>
<p>BERKSHIR-ALPS 345_393</p> <p>Mon 03/01/2021 to Sat 03/20/2021 0700 Continuous 1600</p> <p>Work scheduled by: NGrid</p>	<p>FWD REV (Import) (Export) SCH - NE - NY 1100 MW 1700 MW Impacts Total Transfer Capability 300 MW 0 MW TTC with All Lines In Service 1400 MW 1700 MW</p>

ARR: 78

NYISO TRANSFER LIMITATIONS

Tuesday ,January 12, 2021 to Thursday ,July 14, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-ALPS _____ 345_393				FWD	REV
Mon 03/01/2021	to	Sat 03/20/2021	UPDATED	by NGRID	12/14/2020
0700	Continuous	1600			
Work scheduled by: NGrid					
				(Import)	(Export)
				100 MW	100 MW
				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	200 MW
				ARR: 78	
SCH-NYISO-NE_LIMIT _____ 900					REV
Mon 03/01/2021	to	Sat 03/20/2021	UPDATED	by NGRID	12/14/2020
0700	Continuous	1600			
Work scheduled by: NGrid					
				(Export)	
				1100 MW	
				Impacts Total Transfer Capability	600 MW
				TTC with All Lines In Service	1700 MW
EDIC _____ -N.SCTLND_345_14				FWD	
Tue 03/02/2021	to	Mon 05/31/2021			
0600	Continuous	1830			
Work scheduled by: NGrid					
				(Import)	
				2240 MW	
				CENTRAL EAST - VC	
				Impacts Total Transfer Capability	735 MW
				TTC with All Lines In Service	2975 MW
PORTER _____ -ROTRDAM_230_31				FWD	
Tue 03/02/2021	to	Mon 05/31/2021			
0600	Continuous	1830			
Work scheduled by: NGrid					
				(Import)	
				2805 MW	
				CENTRAL EAST - VC	
				Impacts Total Transfer Capability	170 MW
				TTC with All Lines In Service	2975 MW
MOSES _____ -ADIRNDCK_230_MA1				FWD	
Tue 03/02/2021	to	Mon 05/31/2021			
0700	Continuous	1300			
Work scheduled by: NYPA					
				(Import)	
				2300 MW	
				MOSES SOUTH	
				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
W49TH_ST_345KV_6				FWD	
Wed 03/03/2021	to	Wed 03/03/2021			
0001	Continuous	0030			
Work scheduled by: ConEd					
				(Import)	
				300 MW	
				SCH - PJM_HTP	
				Impacts Total Transfer Capability	360 MW
				TTC with All Lines In Service	660 MW
SPRNBK _____ -TREMONT_345_X28				FWD	
Mon 03/08/2021	to	Tue 03/09/2021			
0001	Continuous	0300			
Work scheduled by: ConEd					
				(Import)	
				4200 MW	
				SPR/DUN-SOUTH	
				Impacts Total Transfer Capability	400 MW
				TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,January 12, 2021 to Thursday ,July 14, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BUCHAN_N-EASTVIEW_345_W93

Tue 03/09/2021 to Tue 03/09/2021
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1870 MW
 TTC with All Lines In Service 6220 MW

EASTVIEW-SPRNBK__345_W79

Tue 03/09/2021 to Wed 03/10/2021
 0001 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1870 MW
 TTC with All Lines In Service 6220 MW

ELBRIDGE-LAFAYTTE_345_17-LE

Tue 03/09/2021 to Tue 03/09/2021
 0800 Daily(No Weekends) 1630
 Work scheduled by: NGrid

ARR: 75

FWD
 (Import)
 OSWEGO EXPORT **5250 MW**
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 5250 MW

BUCHAN_N-EASTVIEW_345_W93

Wed 03/10/2021 to Wed 03/10/2021
 0230 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1870 MW
 TTC with All Lines In Service 6220 MW

PLSNTVLE-DUNWODIE_345_W90

Wed 03/10/2021 to Wed 03/10/2021
 0301 Continuous 0330
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 2220 MW
 TTC with All Lines In Service 6220 MW

PLSNTVLE-DUNWODIE_345_W90

Wed 03/10/2021 to Wed 03/10/2021
 1730 Continuous 1800
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 2220 MW
 TTC with All Lines In Service 6220 MW

PLSNTVLY-WOOD_ST__345_F30

Wed 03/10/2021 to Fri 03/12/2021
 2000 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 2220 MW
 TTC with All Lines In Service 6220 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,January 12, 2021 to Thursday ,July 14, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RNS5

FWD

Wed 03/10/2021 to Fri 03/12/2021
 2000 Continuous 0200

(Import)

Work scheduled by: ConEd

UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 2420 MW
 TTC with All Lines In Service 6220 MW

NIAGARA -ROBNSNRD_230_64

REV

Fri 03/12/2021 to Fri 03/12/2021
 0500 Continuous 1700

(Export)

Work scheduled by: NYPA

SCH - OH - NY **1900 MW**
 Impacts Total Transfer Capability 100 MW
 TTC with All Lines In Service 2000 MW

MARCY___345KV_CSC

FWD

Sat 03/13/2021 to Sat 03/13/2021 **UPDATED by NYPA 07/29/2020**
 0700 Continuous 1730

(Import)

Work scheduled by: NYPA

CENTRAL EAST - VC **2925 MW**
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 2975 MW

MILLWOOD_345KV_18

FWD

Mon 03/22/2021 to Tue 03/30/2021
 0001 Continuous 1800

(Import)

Work scheduled by: ConEd

UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1870 MW
 TTC with All Lines In Service 6220 MW

HUDSONTP-W49TH_ST_345_Y56

FWD

Tue 03/23/2021 to Fri 03/26/2021
 0001 Continuous 0200

(Import)

Work scheduled by: ConEd

SCH - PJM_HTP **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

W49TH_ST_345KV_6

FWD

Tue 03/23/2021 to Fri 03/26/2021
 0001 Continuous 0200

(Import)

Work scheduled by: ConEd

SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

W49TH_ST_345KV_7

FWD

Tue 03/23/2021 to Fri 03/26/2021
 0001 Continuous 0200

(Import)

Work scheduled by: ConEd

SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,January 12, 2021 to Thursday ,July 14, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_5

Fri 03/26/2021 to Wed 05/05/2021
0001 Continuous 0300

Work scheduled by: ConEd

CANCELLED by ConEd 01/07/2021

FWD
(Import)
SCH - PJM_HTP **300 MW**
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

CLAY -EDIC 345 2-15

Mon 03/29/2021 to Fri 04/16/2021
0800 Continuous 1730

Work scheduled by: NYPA

09/12/2020

FWD
(Import)
OSWEGO EXPORT **4850 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 5250 MW

W49TH_ST_345KV_6

Tue 03/30/2021 to Tue 03/30/2021
0230 Continuous 0300

Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **300 MW**
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

W49TH_ST-E13THSTA_345_M55

Tue 03/30/2021 to Wed 03/31/2021
0301 Continuous 2200

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

W49TH_ST_345KV_6

Tue 03/30/2021 to Wed 03/31/2021
0301 Continuous 2200

Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **300 MW**
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

BRANCHBG-HOPATCON_500_5060

Wed 03/31/2021 to Wed 03/31/2021
0200 Continuous 1500

Work scheduled by: PJM

UPDATED by PJM 11/30/2020

FWD
(Import)
UPNY CONED **6025 MW**
Impacts Total Transfer Capability 195 MW
TTC with All Lines In Service 6220 MW

ROCHESTR-PANNELL_345_RP2

Wed 03/31/2021 to Mon 04/12/2021
0500 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,January 12, 2021 to Thursday ,July 14, 2022

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK__345KV_RNS3

Thu 04/01/2021 to Thu 04/01/2021 **UPDATED** **by CONED** **12/16/2020**
 0001 Continuous 0030

Work scheduled by: ConEd

FWD
 (Import)
3800 MW
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

EASTVIEW-SPRNBK__345_W78

Thu 04/01/2021 to Thu 04/01/2021 **UPDATED** **by CONED** **12/16/2020**
 0001 Continuous 1830

Work scheduled by: ConEd

FWD
 (Import)
4350 MW
 Impacts Total Transfer Capability 1870 MW
 TTC with All Lines In Service 6220 MW

MILLWOOD-EASTVIEW_345_W85

Thu 04/01/2021 to Thu 04/01/2021 **UPDATED** **by CONED** **12/16/2020**
 0001 Continuous 1830

Work scheduled by: ConEd

FWD
 (Import)
5985 MW
 Impacts Total Transfer Capability 235 MW
 TTC with All Lines In Service 6220 MW

SPRNBK__345KV_RNS3

Thu 04/01/2021 to Thu 04/01/2021 **UPDATED** **by CONED** **12/16/2020**
 1800 Continuous 1830

Work scheduled by: ConEd

FWD
 (Import)
3800 MW
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

LINDN_CG-LNDVFT__345_V-3022

Sun 04/04/2021 to Sat 04/10/2021
 1400 Continuous 1400

Work scheduled by: PJM

FWD REV
 (Import) (Export)
0 MW 0 MW
 SCH - PJM_VFT
 Impacts Total Transfer Capability 315 MW 315 MW
 TTC with All Lines In Service 315 MW 315 MW

BUCHAN_N-EASTVIEW_345_W93

Mon 04/05/2021 to Thu 04/08/2021 **EXTENDED** **by CE** **01/06/2021**
 0001 Continuous 0200

Work scheduled by: ConEd

FWD
 (Import)
4350 MW
 Impacts Total Transfer Capability 1870 MW
 TTC with All Lines In Service 6220 MW

EASTVIEW-SPRNBK__345_W79

Mon 04/05/2021 to Thu 04/08/2021
 0001 Continuous 0200

Work scheduled by: ConEd

FWD
 (Import)
4350 MW
 Impacts Total Transfer Capability 1870 MW
 TTC with All Lines In Service 6220 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,January 12, 2021 to Thursday ,July 14, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

RAMAPO__-BUCHAN_N_345_Y94					FWD
Mon 04/05/2021	to	Thu 04/08/2021	<u>EXTENDED</u>	<u>by CE</u>	(Import)
0001	Continuous	0200		<u>01/06/2021</u>	5765 MW
Work scheduled by: ConEd					UPNY CONED
					Impacts Total Transfer Capability 455 MW
					TTC with All Lines In Service 6220 MW
SPRNBRK_-TREMONT__345_X28					FWD
Thu 04/08/2021	to	Wed 04/14/2021			(Import)
0201	Continuous	0200			4200 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH
					Impacts Total Transfer Capability 400 MW
					TTC with All Lines In Service 4600 MW
GOETHALS_345KV_5					
Sat 04/10/2021	to	Mon 05/10/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>12/29/2020</u>
0200	Continuous	0200			STATEN ISLAND
Work scheduled by: PJM					Impacts Total Transfer Capability
					TTC with All Lines In Service
LINDEN_-GOETHALS_230_A2253					
Sat 04/10/2021	to	Mon 05/10/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>12/29/2020</u>
0200	Continuous	0200			SCH - PJ - NY
Work scheduled by: PJM					Impacts Total Transfer Capability
					TTC with All Lines In Service
LINDEN_-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402					FWD REV
Sat 04/10/2021	to	Mon 05/10/2021			(Import) (Export)
0200		0200			2550 MW 1900 MW
Work scheduled by:					SCH - PJ - NY
					Impacts Total Transfer Capability 250 MW 50 MW
					TTC with All Lines In Service 2800 MW 1950 MW
LINDEN_-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403					FWD REV
Sat 04/10/2021	to	Mon 05/10/2021			(Import) (Export)
0200		0200			2550 MW 1900 MW
Work scheduled by:					SCH - PJ - NY
					Impacts Total Transfer Capability 250 MW 50 MW
					TTC with All Lines In Service 2800 MW 1950 MW
LINDEN_-GOETHALS_230_A2253 & MARION_-FARRAGUT_345_C3403					FWD REV
Sat 04/10/2021	to	Mon 05/10/2021			(Import) (Export)
0200		0200			2550 MW 1900 MW
Work scheduled by:					SCH - PJ - NY
					Impacts Total Transfer Capability 250 MW 50 MW
					TTC with All Lines In Service 2800 MW 1950 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,January 12, 2021 to Thursday ,July 14, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-STA_255__345_NH2

Fri 04/16/2021 to Fri 04/16/2021
 0500 Continuous 1700
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **2350 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 3150 MW

KINTIGH_-STA_255__345_SH1-39

Mon 04/26/2021 to Fri 04/30/2021
 0700 Continuous 1700
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **2350 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 3150 MW

NIAGARA_-KINTIGH__345_NS1-38

Mon 04/26/2021 to Fri 04/30/2021
 0700 Continuous 1700
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

PLSNTVLY-WOOD_ST__345_F31

Tue 04/27/2021 to Wed 04/28/2021
 0001 Continuous 0159
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 2220 MW
 TTC with All Lines In Service 6220 MW

PLSNTVLY_345KV_RNS4

Tue 04/27/2021 to Wed 04/28/2021
 0001 Continuous 0159
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 2420 MW
 TTC with All Lines In Service 6220 MW

MILLWOOD_345KV_18

Fri 04/30/2021 to Sat 05/01/2021
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1870 MW
 TTC with All Lines In Service 6220 MW

PLSNTVLY-WOOD_ST__345_F30

Fri 04/30/2021 to Tue 05/11/2021
 0001 Continuous 2200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 2220 MW
 TTC with All Lines In Service 6220 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,January 12, 2021 to Thursday ,July 14, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RNS5

Fri 04/30/2021 to Tue 05/11/2021
 0001 Continuous 2200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 2420 MW
 TTC with All Lines In Service 6220 MW

SPRNBRK_345KV_RNS4

Sat 05/01/2021 to Sat 05/01/2021 **CANCELLED by ConEd 01/07/2021**
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

SPRNBRK_-W49TH_ST_345_M52

Sat 05/01/2021 to Tue 05/04/2021 **CANCELLED by ConEd 01/07/2021**
 0001 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

W49TH_ST_345KV_7

Sat 05/01/2021 to Tue 05/04/2021 **CANCELLED by ConEd 01/07/2021**
 0001 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

SCH-IMO-NYISO_LIMIT_1600

Sat 05/01/2021 to Sun 10/31/2021 **UPDATED by IESO 05/03/2019**
 0001 Continuous 2359
 Work scheduled by: IESO

FWD
 (Import)
 SCH - OH - NY **1900 MW**
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 1950 MW

CLAY_-EDIC_345_2-15

Mon 05/03/2021 to Fri 05/07/2021
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 OSWEGO EXPORT **4850 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 5250 MW

PANNELL_-CLAY_345_2

Mon 05/03/2021 to Sun 05/30/2021
 0700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 WEST CENTRAL **1300 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,January 12, 2021 to Thursday ,July 14, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HURLYAVE-ROSETON__345_303			FWD	
Mon 05/03/2021	to	Fri 05/21/2021	(Import)	
0800	Continuous	1600	UPNY CONED	4100 MW
Work scheduled by: CHGE			Impacts Total Transfer Capability	2120 MW
			TTC with All Lines In Service	6220 MW
SHOR_NPX-SHOREHAM_138_CSC			FWD	REV
Mon 05/03/2021	to	Fri 05/07/2021	(Import)	(Export)
0900	Continuous	1500	SCH - NPX_CSC	0 MW 0 MW
Work scheduled by: LI			Impacts Total Transfer Capability	330 MW 330 MW
			TTC with All Lines In Service	330 MW 330 MW
SPRNBRK__345KV_RNS4			FWD	
Tue 05/04/2021	to	Tue 05/04/2021	(Import)	
0230	Continuous	0300	CANCELLED by ConEd 01/07/2021	
Work scheduled by: ConEd			SPR/DUN-SOUTH	3200 MW
			Impacts Total Transfer Capability	1400 MW
			TTC with All Lines In Service	4600 MW
CLAY__-EDIC__345_1-16			FWD	
Mon 05/10/2021	to	Fri 05/14/2021	(Import)	
0700	Continuous	1530	OSWEGO EXPORT	4850 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	400 MW
			TTC with All Lines In Service	5250 MW
DUNWODIE_345KV_5			FWD	
Wed 05/12/2021	to	Thu 05/13/2021	(Import)	
0001	Continuous	0200	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_7			FWD	
Wed 05/12/2021	to	Thu 05/13/2021	(Import)	
0001	Continuous	0200	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW
SPRNBRK_-DUNWODIE_345_W75			FWD	
Wed 05/12/2021	to	Thu 05/13/2021	(Import)	
0001	Continuous	0200	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,January 12, 2021 to Thursday ,July 14, 2022

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK__345KV_RNS3

Wed 05/12/2021 to Thu 05/13/2021
0001 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

NIAGARA_-STA_255__345_NH2

Mon 05/24/2021 to Fri 05/28/2021
0500 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **2350 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 3150 MW

VOLNEY_-MARCY__345_19

Tue 06/01/2021 to Wed 06/02/2021
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2825 MW**
Impacts Total Transfer Capability 150 MW
TTC with All Lines In Service 2975 MW

VOLNEY_-MARCY__345_19

Tue 06/01/2021 to Wed 06/02/2021
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
OSWEGO EXPORT **4900 MW**
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 5250 MW

FRASER_-GILBOA__345_GF5-35

Tue 06/01/2021 to Mon 06/07/2021
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2650 MW**
Impacts Total Transfer Capability 325 MW
TTC with All Lines In Service 2975 MW

MOSES_-ADIRNDCK_230_MA2

Tue 06/01/2021 to Sun 11/14/2021
0700 Continuous 1300

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

PORTER_-ROTTDAM_230_30

Thu 06/03/2021 to Wed 09/15/2021
0600 Continuous 0559

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **2805 MW**
Impacts Total Transfer Capability 170 MW
TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,January 12, 2021 to Thursday ,July 14, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>MARCY -EDIC 345 UE1-7</p> <p>Thu 06/03/2021 to Fri 06/04/2021 0700 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import)</p> <p>OSWEGO EXPORT 5250 MW</p> <p>Impacts Total Transfer Capability 0 MW</p> <p>TTC with All Lines In Service 5250 MW</p>
ARR: 19&16	
<p>MARCY 345KV_CSC</p> <p>Sat 06/05/2021 to Sat 06/05/2021 0700 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import)</p> <p>CENTRAL EAST - VC 2925 MW</p> <p>Impacts Total Transfer Capability 50 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p>FRASANNX-COOPERS 345_UCC2-41</p> <p>Fri 06/25/2021 to Tue 08/10/2021 0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import)</p> <p>CENTRAL EAST - VC 2500 MW</p> <p>Impacts Total Transfer Capability 475 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p>MARCY -FRASANNX 345_UCC2-41</p> <p>Fri 06/25/2021 to Tue 08/10/2021 0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import)</p> <p>CENTRAL EAST - VC 2500 MW</p> <p>Impacts Total Transfer Capability 475 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p>NIAGARA 345_230_AT4</p> <p>Mon 07/12/2021 to Fri 07/23/2021 0500 Continuous 1700</p> <p>Work scheduled by: NYPA</p>	<p>FWD REV (Import) (Export)</p> <p>SCH - OH - NY 1900 MW 1400 MW</p> <p>Impacts Total Transfer Capability 50 MW 300 MW</p> <p>TTC with All Lines In Service 1950 MW 1700 MW</p>
<p>SAND_BAR-PLATSBRG 115_PV20</p> <p>Tue 08/03/2021 to Tue 08/03/2021 0700 Continuous 1830</p> <p>Work scheduled by: NYPA</p>	<p>SCH - NE - NY</p> <p>Impacts Total Transfer Capability</p> <p>TTC with All Lines In Service</p>
<p>FRASANNX-COOPERS 345_UCC2-41</p> <p>Tue 09/07/2021 to Wed 09/15/2021 0700 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import)</p> <p>CENTRAL EAST - VC 2500 MW</p> <p>Impacts Total Transfer Capability 475 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
ARR: 19	

NYISO TRANSFER LIMITATIONS

Tuesday ,January 12, 2021 to Thursday ,July 14, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___-FRASANNX_345_UCC2-41

Tue 09/07/2021 to Wed 09/15/2021
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

KINTIGH_-STA_255__345_SH1-39

Mon 09/13/2021 to Fri 09/17/2021
0500 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **2350 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 3150 MW

NIAGARA_-KINTIGH__345_NS1-38

Mon 09/13/2021 to Fri 09/17/2021
0500 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

PORTER___-ROTTRDAM_230_30

Wed 09/15/2021 to Tue 11/30/2021
0600 Continuous 1830

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **2805 MW**
Impacts Total Transfer Capability 170 MW
TTC with All Lines In Service 2975 MW

EDIC___-N.SCTLND_345_14

Thu 09/16/2021 to Sun 11/14/2021
0600 Continuous 1830

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **2240 MW**
Impacts Total Transfer Capability 735 MW
TTC with All Lines In Service 2975 MW

HURLYAVE-ROSETON__345_303

Thu 09/16/2021 to Sun 10/17/2021 **UPDATED by CHGE 09/22/2020**
0800 Continuous 1600

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 2120 MW
TTC with All Lines In Service 6220 MW

PANNELL_-CLAY_____345_1

Mon 09/20/2021 to Fri 09/24/2021
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,January 12, 2021 to Thursday ,July 14, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CLAY -EDIC 345_2-15

Mon 09/20/2021 to Sat 10/16/2021
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
OSWEGO EXPORT **4850 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 5250 MW

PANNELL -CLAY 345_2

Mon 09/27/2021 to Fri 10/01/2021
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

W49TH_ST_345KV_6

Tue 09/28/2021 to Tue 09/28/2021
0100 Continuous 0130

Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **300 MW**
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

E13THSTA-FARRAGUT_345_46

Tue 09/28/2021 to Tue 10/26/2021
0100 Continuous 0300

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

W49TH_ST-E13THSTA_345_M55

Tue 09/28/2021 to Tue 10/26/2021
0100 Continuous 0300

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

LEEDS -HURLYAVE_345_301

Mon 10/18/2021 to Fri 11/19/2021
0800 Continuous 1600

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 2120 MW
TTC with All Lines In Service 6220 MW

GOETHALS_345KV_5

Thu 10/21/2021 to Sat 11/20/2021
0001 Continuous 0200

Work scheduled by: ConEd

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Tuesday ,January 12, 2021 to Thursday ,July 14, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_6

Tue 10/26/2021 to Tue 10/26/2021
 0230 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

MOTTHAVN-RAINEY__345_Q11

Wed 10/27/2021 to Wed 12/01/2021
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

SCH-IMO-NYISO_LIMIT_1750

Mon 11/01/2021 to Fri 12/31/2021 **UPDATED by IESO 05/03/2019**
 0001 Continuous 2359
 Work scheduled by: IESO

FWD
 (Import)
 SCH - OH - NY **2050 MW**
 Impacts Total Transfer Capability 250 MW
 TTC with All Lines In Service 2300 MW

SCH-NYISO-IMO_LIMIT_1600

Mon 11/01/2021 to Fri 12/31/2021 **UPDATED by IESO 05/03/2019**
 0001 Continuous 2359
 Work scheduled by: IESO

REV
 (Export)
 SCH - OH - NY **1900 MW**
 Impacts Total Transfer Capability 100 MW
 TTC with All Lines In Service 2000 MW

W49TH_ST_345KV_6

Mon 11/15/2021 to Sat 01/15/2022
 0001 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

W49TH_ST_345KV_8

Mon 11/15/2021 to Sat 01/15/2022
 0001 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

CHATGUAY-MASSENA__765_7040

Mon 11/15/2021 to Tue 11/30/2021
 0100 Continuous 1859
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **1550 MW**
 Impacts Total Transfer Capability 1600 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,January 12, 2021 to Thursday ,July 14, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
CHATGUAY-MASSENA_765_7040					
Mon 11/15/2021	to	Tue 11/30/2021			
0100	Continuous	1859	SCH - HQ - NY	0 MW	0 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1500 MW 1000 MW
				TTC with All Lines In Service	1500 MW 1000 MW
MARCY_765_345_AT1				FWD	
Mon 11/15/2021	to	Tue 11/30/2021		(Import)	
0100	Continuous	1859	MOSES SOUTH	1750 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	3150 MW
					ARR: 19
MARCY_765_345_AT2				FWD	
Mon 11/15/2021	to	Tue 11/30/2021		(Import)	
0100	Continuous	1859	MOSES SOUTH	1700 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	1450 MW
				TTC with All Lines In Service	3150 MW
					ARR: 19
MASSENA_-MARCY_765_MSU1				FWD	
Mon 11/15/2021	to	Tue 11/30/2021		(Import)	
0100	Continuous	1859	CENTRAL EAST - VC	2265 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	710 MW
				TTC with All Lines In Service	2975 MW
MASSENA_-MARCY_765_MSU1				FWD	
Mon 11/15/2021	to	Tue 11/30/2021		(Import)	
0100	Continuous	1859	MOSES SOUTH	500 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	2650 MW
				TTC with All Lines In Service	3150 MW
MASSENA_-MARCY_765_MSU1				FWD	REV
Mon 11/15/2021	to	Tue 11/30/2021		(Import)	(Export)
0100	Continuous	1859	SCH - HQ - NY	475 MW	1000 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1025 MW 0 MW
				TTC with All Lines In Service	1500 MW 1000 MW
MASSENA_-MARCY_765_MSU1				FWD	
Mon 11/15/2021	to	Tue 11/30/2021		(Import)	
0100	Continuous	1859	SCH - HQ_CEDARS	90 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	109 MW
				TTC with All Lines In Service	199 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,January 12, 2021 to Thursday ,July 14, 2022

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040

Mon 11/15/2021 to Tue 11/30/2021
0100 1859

Work scheduled by:

FWD
(Import)
MOSES SOUTH 500 MW
Impacts Total Transfer Capability 2650 MW
TTC with All Lines In Service 3150 MW

MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2

Mon 11/15/2021 to Tue 11/30/2021
0100 1859

Work scheduled by:

FWD REV
(Import) (Export)
SCH - HQ - NY 850 MW 0 MW
Impacts Total Transfer Capability 650 MW 1000 MW
TTC with All Lines In Service 1500 MW 1000 MW

MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2

Mon 11/15/2021 to Tue 11/30/2021
0100 1859

Work scheduled by:

FWD
(Import)
SCH - HQ_CEDARS 90 MW
Impacts Total Transfer Capability 109 MW
TTC with All Lines In Service 199 MW

STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1

Mon 11/15/2021 to Tue 11/30/2021
0100 1859

Work scheduled by:

FWD
(Import)
SCH - HQ_CEDARS 90 MW
Impacts Total Transfer Capability 109 MW
TTC with All Lines In Service 199 MW

STLAWRNC-MOSES 230_L33P & MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2

Mon 11/15/2021 to Tue 11/30/2021
0100 1859

Work scheduled by:

FWD
(Import)
SCH - HQ_CEDARS 90 MW
Impacts Total Transfer Capability 109 MW
TTC with All Lines In Service 199 MW

FRASER 345_FRASER SVC

Wed 12/01/2021 to Mon 02/28/2022
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC 2935 MW
Impacts Total Transfer Capability 40 MW
TTC with All Lines In Service 2975 MW

MOSES -ADIRNDCK 230_MA1

Wed 12/01/2021 to Tue 05/31/2022
0700 Continuous 1300

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH 2300 MW
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,January 12, 2021 to Thursday ,July 14, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

N. SCTLND-ALPS_____345_2					FWD
Mon 05/02/2022	to	Mon 05/09/2022			(Import)
0600	Daily	1800			SCH - NE - NY 750 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 650 MW
					TTC with All Lines In Service 1400 MW
N. SCTLND-ALPS_____345_2					FWD
Mon 05/02/2022	to	Mon 05/09/2022			(Import) (Export)
0600	Daily	1800			SCH - NPX_1385 100 MW 100 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 100 MW 100 MW
					TTC with All Lines In Service 200 MW 200 MW
HOMRC_NY-MAINS_NY_345_47					
Fri 05/20/2022	to	Fri 05/27/2022	UPDATED	by PJM	11/19/2020
0800	Continuous	1600			SCH - PJ - NY
Work scheduled by: PJM					Impacts Total Transfer Capability
					TTC with All Lines In Service
HOMR_NYW-PIERC_NY_345_48					
Fri 05/20/2022	to	Fri 05/27/2022	UPDATED	by PJM	11/19/2020
0800	Continuous	1600			SCH - PJ - NY
Work scheduled by: PJM					Impacts Total Transfer Capability
					TTC with All Lines In Service
MOSES___-ADIRNDCK_230_MA2					FWD
Wed 06/01/2022	to	Mon 11/14/2022			(Import)
0700	Continuous	1300			MOSES SOUTH 2100 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 1050 MW
					TTC with All Lines In Service 3150 MW