

NYISO TRANSFER LIMITATIONS

Saturday ,January 16, 2021 to Monday ,July 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Wed 06/30/2021 **EXT FORCE** **by CONED** **08/28/2020**
 0001 Continuous 2359
 Work scheduled by: ConEd

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Wed 06/30/2021
 0001 2359
 Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2550 MW	1900 MW
Impacts Total Transfer Capability	250 MW	50 MW
TTC with All Lines In Service	2800 MW	1950 MW

MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Wed 06/30/2021 **EXT FORCE** **by CONED** **08/28/2020**
 0001 Continuous 2359
 Work scheduled by: ConEd

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

STLAWRNC-MOSES_230_L33P

Mon 04/30/2018 to Mon 10/31/2022 **EXT FORCE** **by IESO** **10/01/2020**
 0456 Continuous 1600
 Work scheduled by: IESO

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

NEWBRDGE_345_138_BK_1

Wed 09/02/2020 to Tue 02/01/2022 **EXT FORCE** **by LI** **01/12/2021**
 1807 Continuous 2359
 Work scheduled by: LI

	FWD
	(Import)
SCH - PJM_NEPTUNE	375 MW
Impacts Total Transfer Capability	285 MW
TTC with All Lines In Service	660 MW

SPRNBK_-EGRDNCTR_345_Y49

Thu 10/01/2020 to Fri 02/19/2021 **EXT FORCE** **by LI** **12/16/2020**
 0404 Continuous 2359
 Work scheduled by: LI

	FWD
	(Import)
CONED - LIPA	775 MW
Impacts Total Transfer Capability	725 MW
TTC with All Lines In Service	1500 MW

EGRDNCTY_345_138_AT2

Sat 10/10/2020 to Fri 02/19/2021 **EXT FORCE** **by LI** **12/16/2020**
 1815 Continuous 2359
 Work scheduled by: LI

	FWD
	(Import)
CONED - LIPA	1250 MW
Impacts Total Transfer Capability	250 MW
TTC with All Lines In Service	1500 MW

NYISO TRANSFER LIMITATIONS

Saturday ,January 16, 2021 to Monday ,July 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						FWD
EGRDNCTY_345_138_AT1						(Import)
Sat 10/10/2020	to	Fri 02/19/2021	<u>EXT FORCE</u>	<u>by LI</u>	<u>12/16/2020</u>	1250 MW
1856	Continuous	2359				CONED - LIPA
Work scheduled by: LI						Impacts Total Transfer Capability 250 MW
						TTC with All Lines In Service 1500 MW
<hr/>						FWD
SCH-IMO-NYISO_LIMIT_1750						(Import)
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	2050 MW
0001	Continuous	2359				SCH - OH - NY
Work scheduled by: IESO						Impacts Total Transfer Capability 250 MW
						TTC with All Lines In Service 2300 MW
<hr/>						REV
SCH-NYISO-IMO_LIMIT_1600						(Export)
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	1900 MW
0001	Continuous	2359				SCH - OH - NY
Work scheduled by: IESO						Impacts Total Transfer Capability 100 MW
						TTC with All Lines In Service 2000 MW
<hr/>						FWD
SHOR_NPX-SHOREHAM_138_CSC						REV
Sun 11/08/2020	to	Sat 01/16/2021	<u>EXT FORCE</u>	<u>by ISONE</u>	<u>12/23/2020</u>	(Import) (Export)
1341	Continuous	2359				0 MW 0 MW
Work scheduled by: LI						SCH - NPX_CSC
						Impacts Total Transfer Capability 330 MW 330 MW
						TTC with All Lines In Service 330 MW 330 MW
<hr/>						FWD
PLSNTVLE-DUNWODIE_345_W89						(Import)
Mon 11/30/2020	to	Wed 02/10/2021	<u>EXT FORCE</u>	<u>by CONED</u>	<u>01/15/2021</u>	4000 MW
1840	Continuous	2359				UPNY CONED
Work scheduled by: ConEd						Impacts Total Transfer Capability 2220 MW
						TTC with All Lines In Service 6220 MW
<hr/>						FWD
SHORE_RD_345_138_BK 2						(Import)
Sat 12/19/2020	to	Fri 03/05/2021	<u>EXTENDED</u>	<u>by LIPA</u>	<u>12/23/2020</u>	1350 MW
1452	Continuous	2359				CONED - LIPA
Work scheduled by: LI						Impacts Total Transfer Capability 150 MW
						TTC with All Lines In Service 1500 MW
<hr/>						FWD
NEPTUNE_-DUFFYAVE_345_NEPTUNE						(Import)
Thu 12/31/2020	to	Wed 01/27/2021	<u>EXT FORCE</u>	<u>by PJM</u>	<u>01/04/2021</u>	0 MW
1100	Continuous	2359				SCH - PJM_NEPTUNE
Work scheduled by: PJM						Impacts Total Transfer Capability 660 MW
						TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Saturday ,January 16, 2021 to Monday ,July 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE-DUFFYAVE_345_501					FWD	
Thu 12/31/2020	to	Wed 01/27/2021	<u>EXT FORCE</u>	<u>by PJM</u>	<u>01/04/2021</u>	(Import)
1102	Continuous	2359				0 MW
Work scheduled by: PJM					SCH - PJM_NEPTUNE	660 MW
					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	660 MW
NEWBRDGE_345_138_BK_2					FWD	
Thu 12/31/2020	to	Wed 01/27/2021	<u>EXT FORCE</u>	<u>by PJM</u>	<u>01/04/2021</u>	(Import)
1102	Continuous	2359				375 MW
Work scheduled by: PJM					SCH - PJM_NEPTUNE	285 MW
					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	660 MW
MOSES__-ADIRNDCK_230_MA1					FWD	
Mon 01/04/2021	to	Sat 02/27/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>11/30/2020</u>	(Import)
0700	Continuous	1730				2300 MW
Work scheduled by: NYPA					MOSES SOUTH	850 MW
					Impacts Total Transfer Capability	3150 MW
					TTC with All Lines In Service	3150 MW
SCH-NYISO-IMO_LIMIT_1200					REV	
Sun 01/10/2021	to	Tue 01/12/2021	<u>EXTENDED</u>	<u>by IESO</u>	<u>01/13/2021</u>	(Export)
0855	Continuous	1059				1500 MW
Work scheduled by: IESO					SCH - OH - NY	500 MW
					Impacts Total Transfer Capability	2000 MW
					TTC with All Lines In Service	2000 MW
SCH-IMO-NYISO_LIMIT_1450					FWD	
Sun 01/10/2021	to	Tue 01/12/2021	<u>EXTENDED</u>	<u>by IESO</u>	<u>01/13/2021</u>	(Import)
0855	Continuous	2359				1750 MW
Work scheduled by: IESO					SCH - OH - NY	550 MW
					Impacts Total Transfer Capability	2300 MW
					TTC with All Lines In Service	2300 MW
CHASLAKE-PORTER__230_11					FWD	
Mon 01/11/2021	to	Mon 01/11/2021				(Import)
0700	Daily(No Weekends)	1600				2300 MW
Work scheduled by: NGrid					MOSES SOUTH	850 MW
					Impacts Total Transfer Capability	3150 MW
					TTC with All Lines In Service	3150 MW
SCH-NYISO-IMO_LIMIT_1100					REV	
Tue 01/12/2021	to	Fri 01/22/2021	<u>EXTENDED</u>	<u>by IESO</u>	<u>01/13/2021</u>	(Export)
1100	Continuous	1700				1400 MW
Work scheduled by: IESO					SCH - OH - NY	600 MW
					Impacts Total Transfer Capability	2000 MW
					TTC with All Lines In Service	2000 MW

NYISO TRANSFER LIMITATIONS

Saturday ,January 16, 2021 to Monday ,July 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO-NYISO_LIMIT_1150					FWD	
Wed 01/13/2021	to	Fri 01/22/2021	EXTENDED	by IESO	01/13/2021	(Import)
0001	Continuous	1700				SCH - OH - NY 1450 MW
Work scheduled by: IESO					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	2300 MW
BECK -NIAGARA_230_PA27					FWD	
Thu 01/14/2021	to	Thu 01/14/2021	CANCELLED	by IESO	01/14/2021	(Import)
0800	Continuous	1600				SCH - OH - NY 2100 MW
Work scheduled by: IESO					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	2300 MW
SCH-IMO-NYISO_LIMIT_700					FWD	
Thu 01/14/2021	to	Thu 01/14/2021	CANCELLED	by IESO	01/14/2021	(Import)
0800	Continuous	1600				SCH - OH - NY 1000 MW
Work scheduled by: IESO					Impacts Total Transfer Capability	1300 MW
					TTC with All Lines In Service	2300 MW
SCH-NYISO-IMO_LIMIT_900					REV	
Thu 01/14/2021	to	Thu 01/14/2021	CANCELLED	by IESO	01/14/2021	(Export)
0800	Continuous	1600				SCH - OH - NY 1200 MW
Work scheduled by: IESO					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	2000 MW
SCH-NYISO-HQ_CEDARS_LIMIT_0					REV	
Mon 01/18/2021	to	Wed 01/20/2021				(Export)
0600	Continuous	0700				SCH - HQ_CEDARS 0 MW
Work scheduled by: HQ					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	100 MW
SPRNBK_-W49TH_ST_345_M52					FWD	
Sat 01/23/2021	to	Sun 01/24/2021				(Import)
0001	Continuous	0059				SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
W49TH_ST_345KV_5					FWD	
Sat 01/23/2021	to	Sun 01/24/2021				(Import)
0001	Continuous	0059				SCH - PJM_HTP 300 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	360 MW
					TTC with All Lines In Service	660 MW

NYISO TRANSFER LIMITATIONS

Saturday ,January 16, 2021 to Monday ,July 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RNS5				FWD	
Sat 01/23/2021	to	Sat 01/23/2021		(Import)	
0800	Daily	0830	UPNY CONED	3800 MW	
Work scheduled by: NGrid				Impacts Total Transfer Capability	2420 MW
				TTC with All Lines In Service	6220 MW
LEEDS___-PLSNTVLY_345_92				FWD	
Sat 01/23/2021	to	Sat 01/23/2021		(Import)	
0800	Daily	1400	UPNY CONED	3800 MW	
Work scheduled by: NGrid				Impacts Total Transfer Capability	2420 MW
				TTC with All Lines In Service	6220 MW
PLSNTVLY_345KV_RNS5				FWD	
Sat 01/23/2021	to	Sat 01/23/2021		(Import)	
1330	Daily	1400	UPNY CONED	3800 MW	
Work scheduled by: NGrid				Impacts Total Transfer Capability	2420 MW
				TTC with All Lines In Service	6220 MW
MOTTHAVN-RAINEY___345_Q12				FWD	
Mon 01/25/2021	to	Sat 02/13/2021	UPDATED	by CONED	12/22/2020
0001	Continuous	0200		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
W49TH_ST_345KV_5				FWD	
Mon 02/08/2021	to	Tue 02/09/2021	UPDATED	by CONED	01/11/2021
0001	Continuous	0200		SCH - PJM_HTP	300 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	360 MW
				TTC with All Lines In Service	660 MW
W49TH_ST_345KV_7				FWD	
Mon 02/08/2021	to	Tue 02/09/2021	UPDATED	by CONED	01/11/2021
0001	Continuous	0200		SCH - PJM_HTP	300 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	360 MW
				TTC with All Lines In Service	660 MW
RAMAPO___345_345_PAR3500				FWD	REV
Mon 02/08/2021	to	Mon 02/15/2021	UPDATED	by CONED	12/09/2020
0001	Continuous	0200		SCH - PJ - NY	2350 MW 1250 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	450 MW 700 MW
				TTC with All Lines In Service	2800 MW 1950 MW

NYISO TRANSFER LIMITATIONS

Saturday ,January 16, 2021 to Monday ,July 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					FWD	REV
RAMAPO__345_345_PAR4500					(Import)	(Export)
Mon 02/08/2021	to	Mon 02/15/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>12/09/2020</u>	
0001	Continuous	0200				
Work scheduled by: ConEd					SCH - PJ - NY	2350 MW
					Impacts Total Transfer Capability	450 MW
					TTC with All Lines In Service	2800 MW
<hr/>					FWD	REV
RAMAPO__500_345_BK 1500					(Import)	(Export)
Mon 02/08/2021	to	Mon 02/15/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>12/09/2020</u>	
0001	Continuous	0200				
Work scheduled by: ConEd					SCH - PJ - NY	1450 MW
					Impacts Total Transfer Capability	1350 MW
					TTC with All Lines In Service	2800 MW
<hr/>					FWD	REV
RAMAPO__500_345_BK 1500					(Import)	
Mon 02/08/2021	to	Mon 02/15/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>12/09/2020</u>	
0001	Continuous	0200				
Work scheduled by: ConEd					UPNY CONED	6025 MW
					Impacts Total Transfer Capability	195 MW
					TTC with All Lines In Service	6220 MW
<hr/>					FWD	REV
HOPATCON-RAMAPO__500_5018					(Import)	(Export)
Mon 02/08/2021	to	Mon 02/15/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>12/09/2020</u>	
0001	Continuous	1900				
Work scheduled by: ConEd					SCH - PJ - NY	1450 MW
					Impacts Total Transfer Capability	1350 MW
					TTC with All Lines In Service	2800 MW
<hr/>					FWD	REV
HOPATCON-RAMAPO__500_5018					(Import)	
Mon 02/08/2021	to	Mon 02/15/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>12/09/2020</u>	
0001	Continuous	1900				
Work scheduled by: ConEd					UPNY CONED	6025 MW
					Impacts Total Transfer Capability	195 MW
					TTC with All Lines In Service	6220 MW
<hr/>					FWD	REV
PORTER__-ROTTRDAM_230_31					(Import)	
Mon 02/08/2021	to	Sat 02/27/2021	<u>UPDATED</u>	<u>by NGRID</u>	<u>01/15/2021</u>	
0600	Continuous	1730				
Work scheduled by: NGrid					CENTRAL EAST - VC	2805 MW
					Impacts Total Transfer Capability	170 MW
					TTC with All Lines In Service	2975 MW
<hr/>					FWD	REV
WATRCURE-OAKDALE__345_31					(Import)	
Mon 02/15/2021	to	Thu 02/18/2021				
0800	Daily	1500				
Work scheduled by: NYSEG					SCH - PJ - NY	
					Impacts Total Transfer Capability	
					TTC with All Lines In Service	

NYISO TRANSFER LIMITATIONS

Saturday ,January 16, 2021 to Monday ,July 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						FWD
E13THSTA-FARRAGUT_345_46						(Import)
Tue 02/16/2021	to	Wed 02/17/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>12/21/2020</u>	
0001	Continuous	2100				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	800 MW
					Impacts Total Transfer Capability	4600 MW
					TTC with All Lines In Service	4600 MW
<hr/>						
W49TH_ST_345KV_8						FWD
						(Import)
Tue 02/16/2021	to	Sun 03/28/2021				
0201	Continuous	0200				300 MW
Work scheduled by: ConEd					SCH - PJM_HTP	360 MW
					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	660 MW
<hr/>						
BERKSHIR-ALPS_____345_393						FWD REV
						(Import) (Export)
Wed 02/17/2021	to	Fri 02/19/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>12/29/2020</u>	
0600	Continuous	1700				1100 MW 1700 MW
Work scheduled by: NGrid					SCH - NE - NY	300 MW 0 MW
					Impacts Total Transfer Capability	1400 MW 1700 MW
					TTC with All Lines In Service	1400 MW 1700 MW
<hr/>						
BERKSHIR-ALPS_____345_393						FWD REV
						(Import) (Export)
Wed 02/17/2021	to	Fri 02/19/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>12/29/2020</u>	
0600	Continuous	1700				100 MW 100 MW
Work scheduled by: NGrid					SCH - NPX_1385	100 MW 100 MW
					Impacts Total Transfer Capability	200 MW 200 MW
					TTC with All Lines In Service	200 MW 200 MW
<hr/>						
BERKSHIR-ALPS_____345_393 & BERKSHIR-NORTHFLD_345_312						FWD REV
						(Import) (Export)
Wed 02/17/2021	to	Fri 02/19/2021				
0600		1700				1100 MW 1700 MW
Work scheduled by:					SCH - NE - NY	300 MW 0 MW
					Impacts Total Transfer Capability	1400 MW 1700 MW
					TTC with All Lines In Service	1400 MW 1700 MW
<hr/>						
BERKSHIR-NORTHFLD_345_312						FWD
						(Import)
Wed 02/17/2021	to	Fri 02/19/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>12/29/2020</u>	
0600	Continuous	1700				1300 MW
Work scheduled by: NGrid					SCH - NE - NY	100 MW
					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	1400 MW
<hr/>						
BERKSHIR-NORTHFLD_345_312						FWD REV
						(Import) (Export)
Wed 02/17/2021	to	Fri 02/19/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>12/29/2020</u>	
0600	Continuous	1700				100 MW 100 MW
Work scheduled by: NGrid					SCH - NPX_1385	100 MW 100 MW
					Impacts Total Transfer Capability	200 MW 200 MW
					TTC with All Lines In Service	200 MW 200 MW

NYISO TRANSFER LIMITATIONS

Saturday ,January 16, 2021 to Monday ,July 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_800					FWD	
Wed 02/17/2021	to	Fri 02/19/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>12/29/2020</u>	(Import)
0600	Continuous	1700				1000 MW
Work scheduled by: NGrid					SCH - NE - NY	
					Impacts Total Transfer Capability	400 MW
					TTC with All Lines In Service	1400 MW
SCH-NYISO-NE_LIMIT_700					REV	
Wed 02/17/2021	to	Fri 02/19/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>12/29/2020</u>	(Export)
0600	Continuous	1700				900 MW
Work scheduled by: NGrid					SCH - NE - NY	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	1700 MW
SAND_BAR-PLATSBURG_115_PV20						
Mon 02/22/2021	to	Fri 02/26/2021				
0600	Daily	1800				
Work scheduled by: ISONE					SCH - NE - NY	
					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
NIAGARA_-ROBNSNRD_230_64					REV	
Mon 02/22/2021	to	Wed 02/24/2021				(Export)
0700	Continuous	1800				1900 MW
Work scheduled by: NYSEG					SCH - OH - NY	
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	2000 MW
BRANCHBG-HOPATCON_500_5060					FWD	
Wed 02/24/2021	to	Wed 02/24/2021				(Import)
0200	Continuous	2200				6025 MW
Work scheduled by: PJM					UPNY CONED	
					Impacts Total Transfer Capability	195 MW
					TTC with All Lines In Service	6220 MW
LADENTWN-BUCHAN_S_345_Y88					FWD	
Sun 02/28/2021	to	Tue 03/30/2021	<u>UPDATED</u>	<u>by CE</u>	<u>11/10/2020</u>	(Import)
0001	Continuous	0200				5930 MW
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	290 MW
					TTC with All Lines In Service	6220 MW
CHATGUAY-MASSENA__765_7040					FWD	
Sun 02/28/2021	to	Mon 03/01/2021				(Import)
0500	Continuous	1730				1550 MW
Work scheduled by: NYPA					MOSES SOUTH	
					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Saturday, January 16, 2021 to Monday, July 18, 2022

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Transfer Capability	Start Date	End Date	Time	Work Scheduled by	SCH	FWD	REV
CHATGUAY-MASSENA 765_7040	Sun 02/28/2021	Mon 03/01/2021	0500 - 1730	NYPA	HQ - NY	(Import)	(Export)
Impacts Total Transfer Capability						1500 MW	1000 MW
TTC with All Lines In Service						1500 MW	1000 MW
MASSENA -MARCY 765_MSU1	Sun 02/28/2021	Mon 03/01/2021	0500 - 1730	NYPA	CENTRAL EAST - VC	(Import)	
Impacts Total Transfer Capability						2265 MW	
TTC with All Lines In Service						2975 MW	
MASSENA -MARCY 765_MSU1	Sun 02/28/2021	Mon 03/01/2021	0500 - 1730	NYPA	MOSES SOUTH	(Import)	
Impacts Total Transfer Capability						500 MW	
TTC with All Lines In Service						2650 MW	
MASSENA -MARCY 765_MSU1	Sun 02/28/2021	Mon 03/01/2021	0500 - 1730	NYPA	HQ - NY	(Import)	(Export)
Impacts Total Transfer Capability						475 MW	1000 MW
TTC with All Lines In Service						1025 MW	0 MW
MASSENA -MARCY 765_MSU1	Sun 02/28/2021	Mon 03/01/2021	0500 - 1730	NYPA	HQ_CEDARS	(Import)	
Impacts Total Transfer Capability						90 MW	
TTC with All Lines In Service						109 MW	
MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040	Sun 02/28/2021	Mon 03/01/2021	0500 - 1730		MOSES SOUTH	(Import)	
Impacts Total Transfer Capability						500 MW	
TTC with All Lines In Service						2650 MW	
STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1	Sun 02/28/2021	Mon 03/01/2021	0500 - 1730		HQ_CEDARS	(Import)	
Impacts Total Transfer Capability						90 MW	
TTC with All Lines In Service						109 MW	

NYISO TRANSFER LIMITATIONS

Saturday ,January 16, 2021 to Monday ,July 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
BERKSHIR-ALPS_345_393						
Mon 03/01/2021	to	Sat 03/20/2021	<u>UPDATED</u>	<u>by NGRID</u>	<u>12/14/2020</u>	
0700	Continuous	1600				
Work scheduled by: NGrid				ARR: 78		
					SCH - NE - NY	1100 MW
					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	1400 MW
						1700 MW
BERKSHIR-ALPS_345_393						
Mon 03/01/2021	to	Sat 03/20/2021	<u>UPDATED</u>	<u>by NGRID</u>	<u>12/14/2020</u>	
0700	Continuous	1600				
Work scheduled by: NGrid				ARR: 78		
					SCH - NPX_1385	100 MW
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
						100 MW
SCH-NYISO-NE_LIMIT_900						
Mon 03/01/2021	to	Sat 03/20/2021	<u>UPDATED</u>	<u>by NGRID</u>	<u>12/14/2020</u>	
0700	Continuous	1600				
Work scheduled by: NGrid						
					SCH - NE - NY	1100 MW
					Impacts Total Transfer Capability	600 MW
					TTC with All Lines In Service	1700 MW
EDIC_-N.SCTLND_345_14						
Tue 03/02/2021	to	Mon 05/31/2021				
0600	Continuous	1830				
Work scheduled by: NGrid						
					CENTRAL EAST - VC	2240 MW
					Impacts Total Transfer Capability	735 MW
					TTC with All Lines In Service	2975 MW
PORTER_-ROTTDAM_230_31						
Tue 03/02/2021	to	Mon 05/31/2021				
0600	Continuous	1830				
Work scheduled by: NGrid						
					CENTRAL EAST - VC	2805 MW
					Impacts Total Transfer Capability	170 MW
					TTC with All Lines In Service	2975 MW
MOSES_-ADIRNDCK_230_MA1						
Tue 03/02/2021	to	Mon 05/31/2021				
0700	Continuous	1300				
Work scheduled by: NYPA						
					MOSES SOUTH	2300 MW
					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
DUNWODIE_345KV_7						
Wed 03/03/2021	to	Wed 03/03/2021				
0001	Continuous	0030				
Work scheduled by: ConEd						
					SPR/DUN-SOUTH	3800 MW
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Saturday ,January 16, 2021 to Monday ,July 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_8			FWD
Wed 03/03/2021	to	Wed 03/03/2021	(Import)
0001	Continuous	0030	
Work scheduled by: ConEd			
			SPR/DUN-SOUTH 3800 MW
			Impacts Total Transfer Capability 800 MW
			TTC with All Lines In Service 4600 MW
W49TH_ST_345KV_6			FWD
Wed 03/03/2021	to	Wed 03/03/2021	(Import)
0001	Continuous	0030	
Work scheduled by: ConEd			
			SCH - PJM_HTP 300 MW
			Impacts Total Transfer Capability 360 MW
			TTC with All Lines In Service 660 MW
DUNWODIE-MOTTHAVN_345_72			FWD
Wed 03/03/2021	to	Wed 03/03/2021	(Import)
0001	Continuous	1800	
Work scheduled by: ConEd			
			SPR/DUN-SOUTH 3800 MW
			Impacts Total Transfer Capability 800 MW
			TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_7			FWD
Wed 03/03/2021	to	Wed 03/03/2021	(Import)
1730	Continuous	1800	
Work scheduled by: ConEd			
			SPR/DUN-SOUTH 3800 MW
			Impacts Total Transfer Capability 800 MW
			TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_8			FWD
Wed 03/03/2021	to	Wed 03/03/2021	(Import)
1730	Continuous	1800	
Work scheduled by: ConEd			
			SPR/DUN-SOUTH 3800 MW
			Impacts Total Transfer Capability 800 MW
			TTC with All Lines In Service 4600 MW
SPRNBK_-TREMONT_345_X28			FWD
Mon 03/08/2021	to	Tue 03/09/2021	(Import)
0001	Continuous	0300	
Work scheduled by: ConEd			
			SPR/DUN-SOUTH 4200 MW
			Impacts Total Transfer Capability 400 MW
			TTC with All Lines In Service 4600 MW
BUCHAN_N-EASTVIEW_345_W93			FWD
Tue 03/09/2021	to	Tue 03/09/2021	(Import)
0001	Continuous	0030	
Work scheduled by: ConEd			
			UPNY CONED 4350 MW
			Impacts Total Transfer Capability 1870 MW
			TTC with All Lines In Service 6220 MW

NYISO TRANSFER LIMITATIONS

Saturday ,January 16, 2021 to Monday ,July 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EASTVIEW-SPRNBRK__345_W79				FWD
Tue 03/09/2021	to	Wed 03/10/2021		(Import)
0001	Continuous	0300	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1870 MW
				TTC with All Lines In Service 6220 MW
ELBRIDGE-LAFAYTTE_345_17-LE				FWD
Tue 03/09/2021	to	Tue 03/09/2021		(Import)
0800	Daily(No Weekends)	1630	OSWEGO EXPORT	5250 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 0 MW
				TTC with All Lines In Service 5250 MW
BUCHAN_N-EASTVIEW_345_W93				FWD
Wed 03/10/2021	to	Wed 03/10/2021		(Import)
0230	Continuous	0300	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1870 MW
				TTC with All Lines In Service 6220 MW
PLSNTVLE-DUNWODIE_345_W90				FWD
Wed 03/10/2021	to	Wed 03/10/2021		(Import)
0301	Continuous	0330	UPNY CONED	4000 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 2220 MW
				TTC with All Lines In Service 6220 MW
PLSNTVLE-DUNWODIE_345_W90				FWD
Wed 03/10/2021	to	Wed 03/10/2021		(Import)
1730	Continuous	1800	UPNY CONED	4000 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 2220 MW
				TTC with All Lines In Service 6220 MW
PLSNTVLY-WOOD_ST__345_F30				FWD
Wed 03/10/2021	to	Fri 03/12/2021	CANCELLED by ConEd 01/15/2021	(Import)
2000	Continuous	0200	UPNY CONED	4000 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 2220 MW
				TTC with All Lines In Service 6220 MW
PLSNTVLY_345KV_RNS5				FWD
Wed 03/10/2021	to	Fri 03/12/2021	CANCELLED by ConEd 01/15/2021	(Import)
2000	Continuous	0200	UPNY CONED	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 2420 MW
				TTC with All Lines In Service 6220 MW

NYISO TRANSFER LIMITATIONS

Saturday ,January 16, 2021 to Monday ,July 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-ROBNSNRD_230_64					REV
Fri 03/12/2021	to	Fri 03/12/2021			(Export)
0500	Continuous	1700		SCH - OH - NY	1900 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 100 MW
					TTC with All Lines In Service 2000 MW
MARCY_345KV_CSC					FWD
Sat 03/13/2021	to	Sat 03/13/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>07/29/2020</u>
0700	Continuous	1730		CENTRAL EAST - VC	2925 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 50 MW
					TTC with All Lines In Service 2975 MW
MILLWOOD_345KV_18					FWD
Mon 03/22/2021	to	Tue 03/30/2021			(Import)
0001	Continuous	1800		UPNY CONED	4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1870 MW
					TTC with All Lines In Service 6220 MW
HUDSONTP-W49TH_ST_345_Y56					FWD
Tue 03/23/2021	to	Fri 03/26/2021			(Import)
0001	Continuous	0200		SCH - PJM_HTP	0 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 660 MW
					TTC with All Lines In Service 660 MW
W49TH_ST_345KV_6					FWD
Tue 03/23/2021	to	Fri 03/26/2021			(Import)
0001	Continuous	0200		SCH - PJM_HTP	300 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 360 MW
					TTC with All Lines In Service 660 MW
W49TH_ST_345KV_7					FWD
Tue 03/23/2021	to	Fri 03/26/2021			(Import)
0001	Continuous	0200		SCH - PJM_HTP	300 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 360 MW
					TTC with All Lines In Service 660 MW
CLAY_-EDIC_345_2-15					FWD
Mon 03/29/2021	to	Fri 04/16/2021		<u>09/12/2020</u>	(Import)
0800	Continuous	1730		OSWEGO EXPORT	4850 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 400 MW
					TTC with All Lines In Service 5250 MW

NYISO TRANSFER LIMITATIONS

Saturday ,January 16, 2021 to Monday ,July 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_6

Tue 03/30/2021 to Tue 03/30/2021
 0230 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

W49TH_ST-E13THSTA_345_M55

Tue 03/30/2021 to Wed 03/31/2021
 0301 Continuous 2200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

W49TH_ST_345KV_6

Tue 03/30/2021 to Wed 03/31/2021
 0301 Continuous 2200
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

BRANCHBG-HOPATCON_500_5060

Wed 03/31/2021 to Wed 03/31/2021 **UPDATED by PJM 11/30/2020**
 0200 Continuous 1500
 Work scheduled by: PJM

FWD
 (Import)
 UPNY CONED **6025 MW**
 Impacts Total Transfer Capability 195 MW
 TTC with All Lines In Service 6220 MW

ROCHESTR-PANNELL_345_RP2

Wed 03/31/2021 to Mon 04/12/2021
 0500 Continuous 1700
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

SPRNBK_345KV_RNS3

Thu 04/01/2021 to Thu 04/01/2021 **UPDATED by CONED 12/16/2020**
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

EASTVIEW-SPRNBK_345_W78

Thu 04/01/2021 to Thu 04/01/2021 **UPDATED by CONED 12/16/2020**
 0001 Continuous 1830
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1870 MW
 TTC with All Lines In Service 6220 MW

NYISO TRANSFER LIMITATIONS

Saturday ,January 16, 2021 to Monday ,July 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD-EASTVIEW_345_W85					FWD	
Thu 04/01/2021	to	Thu 04/01/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>12/16/2020</u>	(Import)
0001	Continuous	1830				UPNY CONED 5985 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 235 MW	
					TTC with All Lines In Service 6220 MW	
SPRNBRK__345KV_RNS3					FWD	
Thu 04/01/2021	to	Thu 04/01/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>12/16/2020</u>	(Import)
1800	Continuous	1830				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW	
					TTC with All Lines In Service 4600 MW	
LINDN_CG-LNDVFT__345_V-3022					FWD	
Sun 04/04/2021	to	Sat 04/10/2021				REV (Export)
1400	Continuous	1400				SCH - PJM_VFT 0 MW 0 MW
Work scheduled by: PJM					Impacts Total Transfer Capability 315 MW 315 MW	
					TTC with All Lines In Service 315 MW 315 MW	
BUCHAN_N-EASTVIEW_345_W93					FWD	
Mon 04/05/2021	to	Thu 04/08/2021	<u>EXTENDED</u>	<u>by CE</u>	<u>01/06/2021</u>	(Import)
0001	Continuous	0200				UPNY CONED 4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1870 MW	
					TTC with All Lines In Service 6220 MW	
EASTVIEW-SPRNBRK__345_W79					FWD	
Mon 04/05/2021	to	Thu 04/08/2021				(Import)
0001	Continuous	0200				UPNY CONED 4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1870 MW	
					TTC with All Lines In Service 6220 MW	
RAMAPO__-BUCHAN_N_345_Y94					FWD	
Mon 04/05/2021	to	Thu 04/08/2021	<u>EXTENDED</u>	<u>by CE</u>	<u>01/06/2021</u>	(Import)
0001	Continuous	0200				UPNY CONED 5765 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 455 MW	
					TTC with All Lines In Service 6220 MW	
SPRNBRK_-TREMONT__345_X28					FWD	
Thu 04/08/2021	to	Wed 04/14/2021				(Import)
0201	Continuous	0200				SPR/DUN-SOUTH 4200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 400 MW	
					TTC with All Lines In Service 4600 MW	

NYISO TRANSFER LIMITATIONS

Saturday ,January 16, 2021 to Monday ,July 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

GOETHALS_345KV_5

Sat 04/10/2021 to Mon 05/10/2021 **UPDATED** **by CONED** **12/29/2020**
 0200 Continuous 0200

Work scheduled by: PJM

STATEN ISLAND
 Impacts Total Transfer Capability
 TTC with All Lines In Service

LINDEN__-GOETHALS_230_A2253

Sat 04/10/2021 to Mon 05/10/2021 **UPDATED** **by CONED** **12/29/2020**
 0200 Continuous 0200

Work scheduled by: PJM

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

LINDEN__-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402

Sat 04/10/2021 to Mon 05/10/2021
 0200 0200

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2550 MW	1900 MW
Impacts Total Transfer Capability	250 MW	50 MW
TTC with All Lines In Service	2800 MW	1950 MW

LINDEN__-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402 & MARION__-FARRAGUT_345_C3403

Sat 04/10/2021 to Mon 05/10/2021
 0200 0200

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2550 MW	1900 MW
Impacts Total Transfer Capability	250 MW	50 MW
TTC with All Lines In Service	2800 MW	1950 MW

LINDEN__-GOETHALS_230_A2253 & MARION__-FARRAGUT_345_C3403

Sat 04/10/2021 to Mon 05/10/2021
 0200 0200

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2550 MW	1900 MW
Impacts Total Transfer Capability	250 MW	50 MW
TTC with All Lines In Service	2800 MW	1950 MW

NIAGARA_-STA_255__345_NH2

Fri 04/16/2021 to Fri 04/16/2021
 0500 Continuous 1700

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	2350 MW
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	3150 MW

KINTIGH_-STA_255__345_SH1-39

Mon 04/26/2021 to Fri 04/30/2021
 0700 Continuous 1700

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	2350 MW
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Saturday ,January 16, 2021 to Monday ,July 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-KINTIGH__345_NS1-38

Mon 04/26/2021 to Fri 04/30/2021
 0700 Continuous 1700

Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

PLSNTVLY-WOOD_ST__345_F31

Tue 04/27/2021 to Wed 04/28/2021
 0001 Continuous 0159

Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 2220 MW
 TTC with All Lines In Service 6220 MW

PLSNTVLY_345KV_RNS4

Tue 04/27/2021 to Wed 04/28/2021
 0001 Continuous 0159

Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 2420 MW
 TTC with All Lines In Service 6220 MW

MILLWOOD_345KV_18

Fri 04/30/2021 to Sat 05/01/2021
 0001 Continuous 0200

Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1870 MW
 TTC with All Lines In Service 6220 MW

PLSNTVLY-WOOD_ST__345_F30

Fri 04/30/2021 to Tue 05/11/2021
 0001 Continuous 2200

Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 2220 MW
 TTC with All Lines In Service 6220 MW

PLSNTVLY_345KV_RNS5

Fri 04/30/2021 to Tue 05/11/2021
 0001 Continuous 2200

Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 2420 MW
 TTC with All Lines In Service 6220 MW

SCH-IMO-NYISO_LIMIT_1600

Sat 05/01/2021 to Sun 10/31/2021
 0001 Continuous 2359

Work scheduled by: IESO

UPDATED by IESO 05/03/2019

FWD
 (Import)
 SCH - OH - NY **1900 MW**
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 1950 MW

NYISO TRANSFER LIMITATIONS

Saturday ,January 16, 2021 to Monday ,July 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>CLAY -EDIC 345_2-15</p> <p>Mon 05/03/2021 to Fri 05/07/2021</p> <p style="padding-left: 40px;">0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>OSWEGO EXPORT 4850 MW</p> <p>Impacts Total Transfer Capability 400 MW</p> <p>TTC with All Lines In Service 5250 MW</p>															
<p>PANNELL -CLAY 345_2</p> <p>Mon 05/03/2021 to Sun 05/30/2021</p> <p style="padding-left: 40px;">0700 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>WEST CENTRAL 1300 MW</p> <p>Impacts Total Transfer Capability 950 MW</p> <p>TTC with All Lines In Service 2250 MW</p>															
<p>HURLYAVE-ROSETON 345_303</p> <p>Mon 05/03/2021 to Fri 05/21/2021</p> <p style="padding-left: 40px;">0800 Continuous 1600</p> <p>Work scheduled by: CHGE</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>UPNY CONED 4100 MW</p> <p>Impacts Total Transfer Capability 2120 MW</p> <p>TTC with All Lines In Service 6220 MW</p>															
<p>SHOR_NPX-SHOREHAM_138_CSC</p> <p>Mon 05/03/2021 to Fri 05/07/2021</p> <p style="padding-left: 40px;">0900 Continuous 1500</p> <p>Work scheduled by: LI</p>	<table style="width: 100%; border: none;"> <tr> <td style="width: 60%;"></td> <td style="width: 20%; text-align: right;">FWD</td> <td style="width: 20%; text-align: right;">REV</td> </tr> <tr> <td></td> <td style="text-align: right;">(Import)</td> <td style="text-align: right;">(Export)</td> </tr> <tr> <td>SCH - NPX_CSC</td> <td style="text-align: right;">0 MW</td> <td style="text-align: right;">0 MW</td> </tr> <tr> <td>Impacts Total Transfer Capability</td> <td style="text-align: right;">330 MW</td> <td style="text-align: right;">330 MW</td> </tr> <tr> <td>TTC with All Lines In Service</td> <td style="text-align: right;">330 MW</td> <td style="text-align: right;">330 MW</td> </tr> </table>		FWD	REV		(Import)	(Export)	SCH - NPX_CSC	0 MW	0 MW	Impacts Total Transfer Capability	330 MW	330 MW	TTC with All Lines In Service	330 MW	330 MW
	FWD	REV														
	(Import)	(Export)														
SCH - NPX_CSC	0 MW	0 MW														
Impacts Total Transfer Capability	330 MW	330 MW														
TTC with All Lines In Service	330 MW	330 MW														
<p>CLAY -EDIC 345_1-16</p> <p>Mon 05/10/2021 to Fri 05/14/2021</p> <p style="padding-left: 40px;">0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>OSWEGO EXPORT 4850 MW</p> <p>Impacts Total Transfer Capability 400 MW</p> <p>TTC with All Lines In Service 5250 MW</p>															
<p>DUNWODIE_345KV_5</p> <p>Wed 05/12/2021 to Thu 05/13/2021</p> <p style="padding-left: 40px;">0001 Continuous 0200</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>SPR/DUN-SOUTH 3800 MW</p> <p>Impacts Total Transfer Capability 800 MW</p> <p>TTC with All Lines In Service 4600 MW</p>															
<p>DUNWODIE_345KV_7</p> <p>Wed 05/12/2021 to Thu 05/13/2021</p> <p style="padding-left: 40px;">0001 Continuous 0200</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>SPR/DUN-SOUTH 3800 MW</p> <p>Impacts Total Transfer Capability 800 MW</p> <p>TTC with All Lines In Service 4600 MW</p>															

NYISO TRANSFER LIMITATIONS

Saturday ,January 16, 2021 to Monday ,July 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_-DUNWODIE_345_W75			FWD
Wed 05/12/2021	to	Thu 05/13/2021	(Import)
0001	Continuous	0200	SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 800 MW
			TTC with All Lines In Service 4600 MW
SPRNBK_345KV_RNS3			FWD
Wed 05/12/2021	to	Thu 05/13/2021	(Import)
0001	Continuous	0200	SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 800 MW
			TTC with All Lines In Service 4600 MW
NIAGARA_-STA_255_345_NH2			FWD
Mon 05/24/2021	to	Fri 05/28/2021	(Import)
0500	Continuous	1700	DYSINGER EAST 2350 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 800 MW
			TTC with All Lines In Service 3150 MW
VOLNEY_-MARCY_345_19			FWD
Tue 06/01/2021	to	Wed 06/02/2021	(Import)
0700	Continuous	1730	CENTRAL EAST - VC 2825 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 150 MW
ARR: 19			TTC with All Lines In Service 2975 MW
VOLNEY_-MARCY_345_19			FWD
Tue 06/01/2021	to	Wed 06/02/2021	(Import)
0700	Continuous	1730	OSWEGO EXPORT 4900 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 350 MW
ARR: 19			TTC with All Lines In Service 5250 MW
FRASER_-GILBOA_345_GF5-35			FWD
Tue 06/01/2021	to	Mon 06/07/2021	(Import)
0700	Continuous	1730	CENTRAL EAST - VC 2650 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 325 MW
			TTC with All Lines In Service 2975 MW
MOSES_-ADIRNDCK_230_MA2			FWD
Tue 06/01/2021	to	Sun 11/14/2021	(Import)
0700	Continuous	1300	MOSES SOUTH 2100 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 1050 MW
			TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Saturday ,January 16, 2021 to Monday ,July 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
PORTER__-ROTTRDAM_230_30			FWD
Thu 06/03/2021	to	Wed 09/15/2021	(Import)
0600	Continuous	0559	CENTRAL EAST - VC
Work scheduled by: NGrid			2805 MW
			Impacts Total Transfer Capability 170 MW
			TTC with All Lines In Service 2975 MW
<hr/>			
MARCY__-EDIC__345_UE1-7			FWD
Thu 06/03/2021	to	Fri 06/04/2021	(Import)
0700	Continuous	1730	OSWEGO EXPORT
Work scheduled by: NYPA			5250 MW
ARR: 19&16			Impacts Total Transfer Capability 0 MW
			TTC with All Lines In Service 5250 MW
<hr/>			
MARCY__345KV_CSC			FWD
Sat 06/05/2021	to	Sat 06/05/2021	(Import)
0700	Continuous	1730	CENTRAL EAST - VC
Work scheduled by: NYPA			2925 MW
			Impacts Total Transfer Capability 50 MW
			TTC with All Lines In Service 2975 MW
<hr/>			
FRASANX-COOPERS__345_UCC2-41			FWD
Fri 06/25/2021	to	Tue 08/10/2021	(Import)
0700	Continuous	1530	CENTRAL EAST - VC
Work scheduled by: NYPA			2500 MW
ARR: 19			Impacts Total Transfer Capability 475 MW
			TTC with All Lines In Service 2975 MW
<hr/>			
MARCY__-FRASANX_345_UCC2-41			FWD
Fri 06/25/2021	to	Tue 08/10/2021	(Import)
0700	Continuous	1530	CENTRAL EAST - VC
Work scheduled by: NYPA			2500 MW
ARR: 19			Impacts Total Transfer Capability 475 MW
			TTC with All Lines In Service 2975 MW
<hr/>			
NIAGARA__345_230_AT4			FWD REV
Mon 07/12/2021	to	Fri 07/23/2021	(Import) (Export)
0500	Continuous	1700	SCH - OH - NY
Work scheduled by: NYPA			1900 MW 1400 MW
			Impacts Total Transfer Capability 50 MW 300 MW
			TTC with All Lines In Service 1950 MW 1700 MW
<hr/>			
SAND_BAR-PLATSBRG_115_PV20			
Tue 08/03/2021	to	Tue 08/03/2021	
0700	Continuous	1830	SCH - NE - NY
Work scheduled by: NYPA			Impacts Total Transfer Capability
			TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Saturday ,January 16, 2021 to Monday ,July 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASANX-COOPERS__345_UCC2-41

Tue 09/07/2021 to Wed 09/15/2021
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

MARCY__-FRASANX_345_UCC2-41

Tue 09/07/2021 to Wed 09/15/2021
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

KINTIGH_-STA_255__345_SH1-39

Mon 09/13/2021 to Fri 09/17/2021
0500 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **2350 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 3150 MW

NIAGARA_-KINTIGH__345_NS1-38

Mon 09/13/2021 to Fri 09/17/2021
0500 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

PORTER__-ROTTRDAM_230_30

Wed 09/15/2021 to Tue 11/30/2021
0600 Continuous 1830

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **2805 MW**
Impacts Total Transfer Capability 170 MW
TTC with All Lines In Service 2975 MW

EDIC__-N.SCTLND_345_14

Thu 09/16/2021 to Sun 11/14/2021
0600 Continuous 1830

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **2240 MW**
Impacts Total Transfer Capability 735 MW
TTC with All Lines In Service 2975 MW

HURLYAVE-ROSETON__345_303

Thu 09/16/2021 to Sun 10/17/2021
0800 Continuous 1600

Work scheduled by: CHGE

UPDATED by CHGE 09/22/2020

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 2120 MW
TTC with All Lines In Service 6220 MW

NYISO TRANSFER LIMITATIONS

Saturday ,January 16, 2021 to Monday ,July 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HOMRC_NY-MAINS_NY_345_47

Sat 09/18/2021 to Fri 11/05/2021
 0800 Continuous 1600
 Work scheduled by: PJM

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

PANNELL_-CLAY_345_1

Mon 09/20/2021 to Fri 09/24/2021
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 WEST CENTRAL **1300 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

CLAY_-EDIC_345_2-15

Mon 09/20/2021 to Sat 10/16/2021
 0700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 OSWEGO EXPORT **4850 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 5250 MW

PANNELL_-CLAY_345_2

Mon 09/27/2021 to Fri 10/01/2021
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 WEST CENTRAL **1300 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

W49TH_ST_345KV_6

Tue 09/28/2021 to Tue 09/28/2021 **UPDATED by CONED 01/15/2021**
 0100 Continuous 0130
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

E13THSTA-FARRAGUT_345_46

Tue 09/28/2021 to Tue 10/26/2021 **UPDATED by CONED 01/15/2021**
 0100 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

W49TH_ST-E13THSTA_345_M55

Tue 09/28/2021 to Tue 10/26/2021 **UPDATED by CONED 01/15/2021**
 0100 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Saturday, January 16, 2021 to Monday, July 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LEEDS ___-HURLYAVE_345_301

FWD

Mon 10/18/2021 to Fri 11/19/2021

(Import)

0800 Continuous 1600

UPNY CONED

4100 MW

Work scheduled by: CHGE

Impacts Total Transfer Capability 2120 MW

TTC with All Lines In Service 6220 MW

GOETHALS_345KV_5

Thu 10/21/2021 to Sat 11/20/2021

0001 Continuous 0200

Work scheduled by: ConEd

STATEN ISLAND

Impacts Total Transfer Capability

TTC with All Lines In Service

W49TH_ST_345KV_6

FWD

Tue 10/26/2021 to Tue 10/26/2021

(Import)

0230 Continuous 0300

UPDATED by CONED 01/15/2021

SCH - PJM_HTP

300 MW

Work scheduled by: ConEd

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

MOTTHAVN-RAINEY___345_Q11

FWD

Wed 10/27/2021 to Wed 12/01/2021

(Import)

0001 Continuous 0200

Work scheduled by: ConEd

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

SCH-IMO-NYISO_LIMIT_1750

FWD

Mon 11/01/2021 to Fri 12/31/2021

(Import)

0001 Continuous 2359

UPDATED by IESO 05/03/2019

SCH - OH - NY

2050 MW

Work scheduled by: IESO

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 2300 MW

SCH-NYISO-IMO_LIMIT_1600

REV

Mon 11/01/2021 to Fri 12/31/2021

(Export)

0001 Continuous 2359

UPDATED by IESO 05/03/2019

SCH - OH - NY

1900 MW

Work scheduled by: IESO

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 2000 MW

W49TH_ST_345KV_6

FWD

Mon 11/15/2021 to Sat 01/15/2022

(Import)

0001 Continuous 0300

SCH - PJM_HTP

300 MW

Work scheduled by: ConEd

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Saturday ,January 16, 2021 to Monday ,July 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_8

Mon 11/15/2021 to Sat 01/15/2022
 0001 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

CHATGUAY-MASSENA__765_7040

Mon 11/15/2021 to Tue 11/30/2021
 0100 Continuous 1859
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **1550 MW**
 Impacts Total Transfer Capability 1600 MW
 TTC with All Lines In Service 3150 MW

CHATGUAY-MASSENA__765_7040

Mon 11/15/2021 to Tue 11/30/2021
 0100 Continuous 1859
 Work scheduled by: NYPA

FWD REV
 (Import) (Export)
 SCH - HQ - NY **0 MW 0 MW**
 Impacts Total Transfer Capability 1500 MW 1000 MW
 TTC with All Lines In Service 1500 MW 1000 MW

MARCY___765_345_AT1

Mon 11/15/2021 to Tue 11/30/2021
 0100 Continuous 1859
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1750 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 3150 MW

MARCY___765_345_AT2

Mon 11/15/2021 to Tue 11/30/2021
 0100 Continuous 1859
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

MASSENA_-MARCY___765_MSU1

Mon 11/15/2021 to Tue 11/30/2021
 0100 Continuous 1859
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2265 MW**
 Impacts Total Transfer Capability 710 MW
 TTC with All Lines In Service 2975 MW

MASSENA_-MARCY___765_MSU1

Mon 11/15/2021 to Tue 11/30/2021
 0100 Continuous 1859
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **500 MW**
 Impacts Total Transfer Capability 2650 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Saturday ,January 16, 2021 to Monday ,July 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA -MARCY 765_MSU1			FWD	REV
			(Import)	(Export)
Mon 11/15/2021	to	Tue 11/30/2021		
0100	Continuous	1859	SCH - HQ - NY	475 MW 1000 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1025 MW 0 MW
			TTC with All Lines In Service	1500 MW 1000 MW
MASSENA -MARCY 765_MSU1			FWD	
			(Import)	
Mon 11/15/2021	to	Tue 11/30/2021		
0100	Continuous	1859	SCH - HQ_CEDARS	90 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	109 MW
			TTC with All Lines In Service	199 MW
MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040			FWD	
			(Import)	
Mon 11/15/2021	to	Tue 11/30/2021		
0100		1859	MOSES SOUTH	500 MW
Work scheduled by:			Impacts Total Transfer Capability	2650 MW
			TTC with All Lines In Service	3150 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2			FWD	REV
			(Import)	(Export)
Mon 11/15/2021	to	Tue 11/30/2021		
0100		1859	SCH - HQ - NY	850 MW 0 MW
Work scheduled by:			Impacts Total Transfer Capability	650 MW 1000 MW
			TTC with All Lines In Service	1500 MW 1000 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2			FWD	
			(Import)	
Mon 11/15/2021	to	Tue 11/30/2021		
0100		1859	SCH - HQ_CEDARS	90 MW
Work scheduled by:			Impacts Total Transfer Capability	109 MW
			TTC with All Lines In Service	199 MW
STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1			FWD	
			(Import)	
Mon 11/15/2021	to	Tue 11/30/2021		
0100		1859	SCH - HQ_CEDARS	90 MW
Work scheduled by:			Impacts Total Transfer Capability	109 MW
			TTC with All Lines In Service	199 MW
STLAWRNC-MOSES 230_L33P & MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2			FWD	
			(Import)	
Mon 11/15/2021	to	Tue 11/30/2021		
0100		1859	SCH - HQ_CEDARS	90 MW
Work scheduled by:			Impacts Total Transfer Capability	109 MW
			TTC with All Lines In Service	199 MW

NYISO TRANSFER LIMITATIONS

Saturday ,January 16, 2021 to Monday ,July 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASER___345_FRASER SVC				FWD	
Wed 12/01/2021	to	Mon 02/28/2022		(Import)	
0700	Continuous	1730	CENTRAL EAST - VC	2935 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	40 MW	
			TTC with All Lines In Service	2975 MW	
MOSES___-ADIRNDCK_230_MAI				FWD	
Wed 12/01/2021	to	Tue 05/31/2022		(Import)	
0700	Continuous	1300	MOSES SOUTH	2300 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW	
			TTC with All Lines In Service	3150 MW	
MOTTHAVN-RAINEY___345_Q12				FWD	
Thu 12/02/2021	to	Wed 12/22/2021		(Import)	
0201	Continuous	0200	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
N.SCTLND-ALPS_____345_2				FWD	
Mon 05/02/2022	to	Mon 05/09/2022		(Import)	
0600	Daily	1800	SCH - NE - NY	750 MW	
Work scheduled by: NGrid			Impacts Total Transfer Capability	650 MW	
			TTC with All Lines In Service	1400 MW	
N.SCTLND-ALPS_____345_2				FWD	REV
Mon 05/02/2022	to	Mon 05/09/2022		(Import)	(Export)
0600	Daily	1800	SCH - NPX_1385	100 MW	100 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	100 MW	100 MW
			TTC with All Lines In Service	200 MW	200 MW
HOMRC_NY-MAINS_NY_345_47					
Fri 05/20/2022	to	Fri 05/27/2022	UPDATED	by PJM	11/19/2020
0800	Continuous	1600	SCH - PJ - NY		
Work scheduled by: PJM			Impacts Total Transfer Capability		
			TTC with All Lines In Service		
HOMR_NYW-PIERC_NY_345_48					
Fri 05/20/2022	to	Fri 05/27/2022	UPDATED	by PJM	11/19/2020
0800	Continuous	1600	SCH - PJ - NY		
Work scheduled by: PJM			Impacts Total Transfer Capability		
			TTC with All Lines In Service		

NYISO TRANSFER LIMITATIONS

Saturday ,January 16, 2021 to Monday ,July 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA2

FWD

Wed 06/01/2022 to Mon 11/14/2022
 0700 Continuous 1300

(Import)

Work scheduled by: NYPA

MOSES SOUTH **2100 MW**
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW