

NYISO TRANSFER LIMITATIONS

Monday ,January 18, 2021 to Wednesday, July 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Wed 06/30/2021 EXT FORCE by CONED 08/28/2020
 0001 Continuous 2359
 Work scheduled by: ConEd

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Wed 06/30/2021
 0001 2359
 Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2550 MW	1900 MW
Impacts Total Transfer Capability	250 MW	50 MW
TTC with All Lines In Service	2800 MW	1950 MW

MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Wed 06/30/2021 EXT FORCE by CONED 08/28/2020
 0001 Continuous 2359
 Work scheduled by: ConEd

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

STLAWRNC-MOSES_230_L33P

Mon 04/30/2018 to Mon 10/31/2022 EXT FORCE by IESO 10/01/2020
 0456 Continuous 1600
 Work scheduled by: IESO

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

NEWBRDGE_345_138_BK_1

Wed 09/02/2020 to Tue 02/01/2022 EXT FORCE by LI 01/12/2021
 1807 Continuous 2359
 Work scheduled by: LI

	FWD
	(Import)
SCH - PJM_NEPTUNE	375 MW
Impacts Total Transfer Capability	285 MW
TTC with All Lines In Service	660 MW

SPRNBK_-EGRDNCTR_345_Y49

Thu 10/01/2020 to Fri 02/19/2021 EXT FORCE by LI 12/16/2020
 0404 Continuous 2359
 Work scheduled by: LI

	FWD
	(Import)
CONED - LIPA	775 MW
Impacts Total Transfer Capability	725 MW
TTC with All Lines In Service	1500 MW

EGRDNCTY_345_138_AT2

Sat 10/10/2020 to Fri 02/19/2021 EXT FORCE by LI 12/16/2020
 1815 Continuous 2359
 Work scheduled by: LI

	FWD
	(Import)
CONED - LIPA	1250 MW
Impacts Total Transfer Capability	250 MW
TTC with All Lines In Service	1500 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 18, 2021 to Wednesday, July 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EGRDNCTY_345_138_AT1

Sat 10/10/2020 to Fri 02/19/2021
1856 Continuous 2359

EXT FORCE by **LI** 12/16/2020

Work scheduled by: LI

FWD
(Import)
CONED - LIPA **1250 MW**
Impacts Total Transfer Capability 250 MW
TTC with All Lines In Service 1500 MW

SCH-IMO-NYISO_LIMIT_1750

Sun 11/01/2020 to Fri 04/30/2021
0001 Continuous 2359

UPDATED by **IESO** 05/03/2019

Work scheduled by: IESO

FWD
(Import)
SCH - OH - NY **2050 MW**
Impacts Total Transfer Capability 250 MW
TTC with All Lines In Service 2300 MW

SCH-NYISO-IMO_LIMIT_1600

Sun 11/01/2020 to Fri 04/30/2021
0001 Continuous 2359

UPDATED by **IESO** 05/03/2019

Work scheduled by: IESO

REV
(Export)
SCH - OH - NY **1900 MW**
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 2000 MW

SHOR_NPX-SHOREHAM_138_CSC

Sun 11/08/2020 to Sat 01/16/2021
1341 Continuous 2359

EXT FORCE by **ISONE** 12/23/2020

Work scheduled by: LI

FWD REV
(Import) (Export)
SCH - NPX_CSC **0 MW 0 MW**
Impacts Total Transfer Capability 330 MW 330 MW
TTC with All Lines In Service 330 MW 330 MW

PLSNTVLE-DUNWODIE_345_W89

Mon 11/30/2020 to Wed 02/10/2021
1840 Continuous 2359

EXT FORCE by **CONED** 01/15/2021

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4000 MW**
Impacts Total Transfer Capability 2220 MW
TTC with All Lines In Service 6220 MW

SHORE_RD_345_138_BK 2

Sat 12/19/2020 to Fri 03/05/2021
1452 Continuous 2359

EXTENDED by **LIPA** 12/23/2020

Work scheduled by: LI

FWD
(Import)
CONED - LIPA **1350 MW**
Impacts Total Transfer Capability 150 MW
TTC with All Lines In Service 1500 MW

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Thu 12/31/2020 to Wed 01/27/2021
1100 Continuous 2359

EXT FORCE by **PJM** 01/04/2021

Work scheduled by: PJM

FWD
(Import)
SCH - PJM_NEPTUNE **0 MW**
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 18, 2021 to Wednesday, July 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE-DUFFYAVE_345_501					FWD	
Thu 12/31/2020	to	Wed 01/27/2021	<u>EXT FORCE</u>	<u>by PJM</u>	<u>01/04/2021</u>	(Import)
1102	Continuous	2359				SCH - PJM_NEPTUNE Impacts Total Transfer Capability TTC with All Lines In Service
Work scheduled by: PJM					0 MW	660 MW 660 MW
NEWBRDGE_345_138_BK_2					FWD	
Thu 12/31/2020	to	Wed 01/27/2021	<u>EXT FORCE</u>	<u>by PJM</u>	<u>01/04/2021</u>	(Import)
1102	Continuous	2359				SCH - PJM_NEPTUNE Impacts Total Transfer Capability TTC with All Lines In Service
Work scheduled by: PJM					375 MW	285 MW 660 MW
MOSES__-ADIRNDCK_230_MAL					FWD	
Mon 01/04/2021	to	Sat 02/27/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>11/30/2020</u>	(Import)
0700	Continuous	1730				MOSES SOUTH Impacts Total Transfer Capability TTC with All Lines In Service
Work scheduled by: NYPA					2300 MW	850 MW 3150 MW
SCH-NYISO-IMO_LIMIT_1100					REV	
Tue 01/12/2021	to	Fri 01/22/2021	<u>EXTENDED</u>	<u>by IESO</u>	<u>01/13/2021</u>	(Export)
1100	Continuous	1700				SCH - OH - NY Impacts Total Transfer Capability TTC with All Lines In Service
Work scheduled by: IESO					1400 MW	600 MW 2000 MW
SCH-IMO-NYISO_LIMIT_1150					FWD	
Wed 01/13/2021	to	Fri 01/22/2021	<u>EXTENDED</u>	<u>by IESO</u>	<u>01/13/2021</u>	(Import)
0001	Continuous	1700				SCH - OH - NY Impacts Total Transfer Capability TTC with All Lines In Service
Work scheduled by: IESO					1450 MW	850 MW 2300 MW
BECK__-NIAGARA_230_PA27					FWD	
Thu 01/14/2021	to	Thu 01/14/2021	<u>CANCELLED</u>	<u>by IESO</u>	<u>01/14/2021</u>	(Import)
0800	Continuous	1600				SCH - OH - NY Impacts Total Transfer Capability TTC with All Lines In Service
Work scheduled by: IESO					2100 MW	200 MW 2300 MW
SCH-IMO-NYISO_LIMIT_700					FWD	
Thu 01/14/2021	to	Thu 01/14/2021	<u>CANCELLED</u>	<u>by IESO</u>	<u>01/14/2021</u>	(Import)
0800	Continuous	1600				SCH - OH - NY Impacts Total Transfer Capability TTC with All Lines In Service
Work scheduled by: IESO					1000 MW	1300 MW 2300 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 18, 2021 to Wednesday, July 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					
SCH-NYISO-IMO_LIMIT_900				REV	
Thu 01/14/2021	to	Thu 01/14/2021	CANCELLED by IESO 01/14/2021	(Export)	
0800	Continuous	1600		1200 MW	
Work scheduled by: IESO				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	2000 MW
<hr/>					
SCH-NYISO-HQ_CEDARS_LIMIT_0				REV	
Mon 01/18/2021	to	Wed 01/20/2021		(Export)	
0600	Continuous	0700		0 MW	
Work scheduled by: HQ				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	100 MW
<hr/>					
SPRNBK_-W49TH_ST_345_M52				FWD	
Sat 01/23/2021	to	Sun 01/24/2021		(Import)	
0001	Continuous	0059		3200 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	4600 MW
<hr/>					
W49TH_ST_345KV_5				FWD	
Sat 01/23/2021	to	Sun 01/24/2021		(Import)	
0001	Continuous	0059		300 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	360 MW
				TTC with All Lines In Service	660 MW
<hr/>					
PLSNTVLY_345KV_RNS5				FWD	
Sat 01/23/2021	to	Sat 01/23/2021		(Import)	
0800	Daily	0830		3800 MW	
Work scheduled by: NGrid				Impacts Total Transfer Capability	2420 MW
				TTC with All Lines In Service	6220 MW
<hr/>					
LEEDS_-PLSNTVLY_345_92				FWD	
Sat 01/23/2021	to	Sat 01/23/2021		(Import)	
0800	Daily	1400		3800 MW	
Work scheduled by: NGrid				Impacts Total Transfer Capability	2420 MW
				TTC with All Lines In Service	6220 MW
<hr/>					
PLSNTVLY_345KV_RNS5				FWD	
Sat 01/23/2021	to	Sat 01/23/2021		(Import)	
1330	Daily	1400		3800 MW	
Work scheduled by: NGrid				Impacts Total Transfer Capability	2420 MW
				TTC with All Lines In Service	6220 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 18, 2021 to Wednesday, July 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOTTHAVN-RAINEY ___ 345_Q12						FWD	
Mon 01/25/2021	to	Sat 02/13/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>12/22/2020</u>	(Import)	
0001	Continuous	0200				3800 MW	
Work scheduled by: ConEd						SPR/DUN-SOUTH	
						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
W49TH_ST_345KV_5						FWD	
Mon 02/08/2021	to	Tue 02/09/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>01/11/2021</u>	(Import)	
0001	Continuous	0200				300 MW	
Work scheduled by: ConEd						SCH - PJM_HTP	
						Impacts Total Transfer Capability	360 MW
						TTC with All Lines In Service	660 MW
W49TH_ST_345KV_7						FWD	
Mon 02/08/2021	to	Tue 02/09/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>01/11/2021</u>	(Import)	
0001	Continuous	0200				300 MW	
Work scheduled by: ConEd						SCH - PJM_HTP	
						Impacts Total Transfer Capability	360 MW
						TTC with All Lines In Service	660 MW
RAMAPO ___ 345_345_PAR3500						FWD	REV
Mon 02/08/2021	to	Mon 02/15/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>12/09/2020</u>	(Import)	(Export)
0001	Continuous	0200				2350 MW	1250 MW
Work scheduled by: ConEd						SCH - PJ - NY	
						Impacts Total Transfer Capability	450 MW 700 MW
						TTC with All Lines In Service	2800 MW 1950 MW
RAMAPO ___ 345_345_PAR4500						FWD	REV
Mon 02/08/2021	to	Mon 02/15/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>12/09/2020</u>	(Import)	(Export)
0001	Continuous	0200				2350 MW	1250 MW
Work scheduled by: ConEd						SCH - PJ - NY	
						Impacts Total Transfer Capability	450 MW 700 MW
						TTC with All Lines In Service	2800 MW 1950 MW
RAMAPO ___ 500_345_BK 1500						FWD	REV
Mon 02/08/2021	to	Mon 02/15/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>12/09/2020</u>	(Import)	(Export)
0001	Continuous	0200				1450 MW	1200 MW
Work scheduled by: ConEd						SCH - PJ - NY	
						Impacts Total Transfer Capability	1350 MW 750 MW
						TTC with All Lines In Service	2800 MW 1950 MW
RAMAPO ___ 500_345_BK 1500						FWD	
Mon 02/08/2021	to	Mon 02/15/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>12/09/2020</u>	(Import)	
0001	Continuous	0200				6025 MW	
Work scheduled by: ConEd						UPNY CONED	
						Impacts Total Transfer Capability	195 MW
						TTC with All Lines In Service	6220 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 18, 2021 to Wednesday, July 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HOPATCON-RAMAPO ___ 500_5018					FWD	REV
Mon 02/08/2021	to	Mon 02/15/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>12/09/2020</u>	(Import) (Export)
0001	Continuous	1900				1450 MW 1200 MW
Work scheduled by: ConEd					SCH - PJ - NY	
					Impacts Total Transfer Capability	1350 MW 750 MW
					TTC with All Lines In Service	2800 MW 1950 MW
HOPATCON-RAMAPO ___ 500_5018					FWD	
Mon 02/08/2021	to	Mon 02/15/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>12/09/2020</u>	(Import)
0001	Continuous	1900				6025 MW
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	195 MW
					TTC with All Lines In Service	6220 MW
PORTER ___-ROTTRDAM_230_31					FWD	
Mon 02/08/2021	to	Sat 02/27/2021	<u>UPDATED</u>	<u>by NGRID</u>	<u>01/15/2021</u>	(Import)
0600	Continuous	1730				2805 MW
Work scheduled by: NGrid					CENTRAL EAST - VC	
					Impacts Total Transfer Capability	170 MW
					TTC with All Lines In Service	2975 MW
WATRCURE-OAKDALE ___ 345_31						
Mon 02/15/2021	to	Thu 02/18/2021				
0800	Daily	1500				
Work scheduled by: NYSEG					SCH - PJ - NY	
					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
E13THSTA-FARRAGUT _345_46					FWD	
Tue 02/16/2021	to	Wed 02/17/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>12/21/2020</u>	(Import)
0001	Continuous	2100				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
W49TH_ST_345KV_8					FWD	
Tue 02/16/2021	to	Sun 03/28/2021				(Import)
0201	Continuous	0200				300 MW
Work scheduled by: ConEd					SCH - PJM_HTP	
					Impacts Total Transfer Capability	360 MW
					TTC with All Lines In Service	660 MW
BERKSHIR-ALPS ___ 345_393					FWD	REV
Wed 02/17/2021	to	Fri 02/19/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>12/29/2020</u>	(Import) (Export)
0600	Continuous	1700				1100 MW 1700 MW
Work scheduled by: NGrid					SCH - NE - NY	
					Impacts Total Transfer Capability	300 MW 0 MW
					TTC with All Lines In Service	1400 MW 1700 MW

ARR: 78

NYISO TRANSFER LIMITATIONS

Monday ,January 18, 2021 to Wednesday, July 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-ALPS_____345_393					FWD	REV
Wed 02/17/2021	to	Fri 02/19/2021	UPDATED	by ISONE 12/29/2020	(Import)	(Export)
0600	Continuous	1700			100 MW	100 MW
Work scheduled by: NGrid					SCH - NPX_1385	
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
					ARR: 78	200 MW
<hr/>						
BERKSHIR-ALPS_____345_393 & BERKSHIR-NORTHFLD_345_312					FWD	REV
Wed 02/17/2021	to	Fri 02/19/2021			(Import)	(Export)
0600		1700			1100 MW	1700 MW
Work scheduled by:					SCH - NE - NY	
					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	1400 MW
					ARR: 78	1700 MW
<hr/>						
BERKSHIR-NORTHFLD_345_312					FWD	
Wed 02/17/2021	to	Fri 02/19/2021	UPDATED	by ISONE 12/29/2020	(Import)	
0600	Continuous	1700			1300 MW	
Work scheduled by: NGrid					SCH - NE - NY	
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	1400 MW
<hr/>						
BERKSHIR-NORTHFLD_345_312					FWD	REV
Wed 02/17/2021	to	Fri 02/19/2021	UPDATED	by ISONE 12/29/2020	(Import)	(Export)
0600	Continuous	1700			100 MW	100 MW
Work scheduled by: NGrid					SCH - NPX_1385	
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
<hr/>						
SCH-NE-NYISO_LIMIT_800					FWD	
Wed 02/17/2021	to	Fri 02/19/2021	UPDATED	by ISONE 12/29/2020	(Import)	
0600	Continuous	1700			1000 MW	
Work scheduled by: NGrid					SCH - NE - NY	
					Impacts Total Transfer Capability	400 MW
					TTC with All Lines In Service	1400 MW
<hr/>						
SCH-NYISO-NE_LIMIT_700						REV
Wed 02/17/2021	to	Fri 02/19/2021	UPDATED	by ISONE 12/29/2020		(Export)
0600	Continuous	1700				900 MW
Work scheduled by: NGrid					SCH - NE - NY	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	1700 MW
<hr/>						
SAND_BAR-PLATSBRG_115_PV20						
Mon 02/22/2021	to	Fri 02/26/2021				
0600	Daily	1800			SCH - NE - NY	
Work scheduled by: ISONE					Impacts Total Transfer Capability	
					TTC with All Lines In Service	

NYISO TRANSFER LIMITATIONS

Monday ,January 18, 2021 to Wednesday, July 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-ROBNSNRD_230_64					REV
Mon 02/22/2021	to	Wed 02/24/2021			(Export)
0700	Continuous	1800		SCH - OH - NY	1900 MW
Work scheduled by: NYSEG					Impacts Total Transfer Capability 100 MW
					TTC with All Lines In Service 2000 MW
BRANCHBG-HOPATCON_500_5060					FWD
Wed 02/24/2021	to	Wed 02/24/2021			(Import)
0200	Continuous	2200		UPNY CONED	6025 MW
Work scheduled by: PJM					Impacts Total Transfer Capability 195 MW
					TTC with All Lines In Service 6220 MW
LADENTWN-BUCHAN_S_345_Y88					FWD
Sun 02/28/2021	to	Tue 03/30/2021	UPDATED	by CE	11/10/2020
0001	Continuous	0200			(Import)
Work scheduled by: ConEd					UPNY CONED 5930 MW
					Impacts Total Transfer Capability 290 MW
					TTC with All Lines In Service 6220 MW
CHATGUAY-MASSENA__765_7040					FWD
Sun 02/28/2021	to	Mon 03/01/2021			(Import)
0500	Continuous	1730		MOSES SOUTH	1550 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 1600 MW
					TTC with All Lines In Service 3150 MW
CHATGUAY-MASSENA__765_7040					FWD
Sun 02/28/2021	to	Mon 03/01/2021			(Import) (Export)
0500	Continuous	1730		SCH - HQ - NY	0 MW 0 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 1500 MW 1000 MW
					TTC with All Lines In Service 1500 MW 1000 MW
MASSENA_-MARCY____765_MSU1					FWD
Sun 02/28/2021	to	Mon 03/01/2021			(Import)
0500	Continuous	1730		CENTRAL EAST - VC	2265 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 710 MW
					TTC with All Lines In Service 2975 MW
MASSENA_-MARCY____765_MSU1					FWD
Sun 02/28/2021	to	Mon 03/01/2021			(Import)
0500	Continuous	1730		MOSES SOUTH	500 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 2650 MW
					TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 18, 2021 to Wednesday, July 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Zone	Start	End	Time	Day	Notes	SCH	FWD	REV
MASSENA -MARCY 765_MSU1	Sun 02/28/2021	Mon 03/01/2021	0500 - 1730	Continuous		SCH - HQ - NY	475 MW	1000 MW
					Work scheduled by: NYPA	Impacts Total Transfer Capability	1025 MW	0 MW
						TTC with All Lines In Service	1500 MW	1000 MW
MASSENA -MARCY 765_MSU1	Sun 02/28/2021	Mon 03/01/2021	0500 - 1730	Continuous		SCH - HQ_CEDARS	90 MW	
					Work scheduled by: NYPA	Impacts Total Transfer Capability	109 MW	
						TTC with All Lines In Service	199 MW	
MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040	Sun 02/28/2021	Mon 03/01/2021	0500 - 1730			MOSES SOUTH	500 MW	
					Work scheduled by:	Impacts Total Transfer Capability	2650 MW	
						TTC with All Lines In Service	3150 MW	
STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1	Sun 02/28/2021	Mon 03/01/2021	0500 - 1730			SCH - HQ_CEDARS	90 MW	
					Work scheduled by:	Impacts Total Transfer Capability	109 MW	
						TTC with All Lines In Service	199 MW	
BERKSHIR-ALPS 345_393	Mon 03/01/2021	Sat 03/20/2021	0700 - 1600	Continuous	UPDATED by NGRID 12/14/2020	SCH - NE - NY	1100 MW	1700 MW
					Work scheduled by: NGrid	Impacts Total Transfer Capability	300 MW	0 MW
					ARR: 78	TTC with All Lines In Service	1400 MW	1700 MW
BERKSHIR-ALPS 345_393	Mon 03/01/2021	Sat 03/20/2021	0700 - 1600	Continuous	UPDATED by NGRID 12/14/2020	SCH - NPX_1385	100 MW	100 MW
					Work scheduled by: NGrid	Impacts Total Transfer Capability	100 MW	100 MW
					ARR: 78	TTC with All Lines In Service	200 MW	200 MW
SCH-NYISO-NE_LIMIT_900	Mon 03/01/2021	Sat 03/20/2021	0700 - 1600	Continuous	UPDATED by NGRID 12/14/2020	SCH - NE - NY		1100 MW
					Work scheduled by: NGrid	Impacts Total Transfer Capability		600 MW
						TTC with All Lines In Service		1700 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 18, 2021 to Wednesday, July 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EDIC -N.SCTLND_345_14

Tue 03/02/2021 to Mon 05/31/2021
 0600 Continuous 1830
 Work scheduled by: NGrid

FWD
 (Import)
 CENTRAL EAST - VC **2240 MW**
 Impacts Total Transfer Capability 735 MW
 TTC with All Lines In Service 2975 MW

PORTER -ROTRDAM_230_31

Tue 03/02/2021 to Mon 05/31/2021
 0600 Continuous 1830
 Work scheduled by: NGrid

FWD
 (Import)
 CENTRAL EAST - VC **2805 MW**
 Impacts Total Transfer Capability 170 MW
 TTC with All Lines In Service 2975 MW

MOSES -ADIRNDCK_230_MA1

Tue 03/02/2021 to Mon 05/31/2021
 0700 Continuous 1300
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

DUNWODIE_345KV_7

Wed 03/03/2021 to Wed 03/03/2021
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_8

Wed 03/03/2021 to Wed 03/03/2021
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

W49TH_ST_345KV_6

Wed 03/03/2021 to Wed 03/03/2021
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

DUNWODIE-MOTTHAVN_345_72

Wed 03/03/2021 to Wed 03/03/2021
 0001 Continuous 1800
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 18, 2021 to Wednesday,July 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>				
DUNWODIE_345KV_7			FWD	
Wed 03/03/2021	to	Wed 03/03/2021	(Import)	
1730	Continuous	1800		SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW
<hr/>				
DUNWODIE_345KV_8			FWD	
Wed 03/03/2021	to	Wed 03/03/2021	(Import)	
1730	Continuous	1800		SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW
<hr/>				
SPRNBK_-TREMONT__345_X28			FWD	
Mon 03/08/2021	to	Tue 03/09/2021	(Import)	
0001	Continuous	0300		SPR/DUN-SOUTH 4200 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	400 MW
			TTC with All Lines In Service	4600 MW
<hr/>				
BUCHAN_N-EASTVIEW_345_W93			FWD	
Tue 03/09/2021	to	Tue 03/09/2021	(Import)	
0001	Continuous	0030		UPNY CONED 4350 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	1870 MW
			TTC with All Lines In Service	6220 MW
<hr/>				
EASTVIEW-SPRNBK__345_W79			FWD	
Tue 03/09/2021	to	Wed 03/10/2021	(Import)	
0001	Continuous	0300		UPNY CONED 4350 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	1870 MW
			TTC with All Lines In Service	6220 MW
<hr/>				
ELBRIDGE-LAFAYTTE_345_17-LE			FWD	
Tue 03/09/2021	to	Tue 03/09/2021	(Import)	
0800	Daily(No Weekends)	1630		OSWEGO EXPORT 5250 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	0 MW
			TTC with All Lines In Service	5250 MW
<hr/>				
BUCHAN_N-EASTVIEW_345_W93			FWD	
Wed 03/10/2021	to	Wed 03/10/2021	(Import)	
0230	Continuous	0300		UPNY CONED 4350 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	1870 MW
			TTC with All Lines In Service	6220 MW

ARR: 75

NYISO TRANSFER LIMITATIONS

Monday ,January 18, 2021 to Wednesday, July 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLE-DUNWODIE_345_W90				FWD
Wed 03/10/2021	to	Wed 03/10/2021		(Import)
0301	Continuous	0330	UPNY CONED	4000 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 2220 MW
				TTC with All Lines In Service 6220 MW
PLSNTVLE-DUNWODIE_345_W90				FWD
Wed 03/10/2021	to	Wed 03/10/2021		(Import)
1730	Continuous	1800	UPNY CONED	4000 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 2220 MW
				TTC with All Lines In Service 6220 MW
PLSNTVLY-WOOD_ST_345_F30				FWD
Wed 03/10/2021	to	Fri 03/12/2021	CANCELLED by ConEd 01/15/2021	(Import)
2000	Continuous	0200	UPNY CONED	4000 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 2220 MW
				TTC with All Lines In Service 6220 MW
PLSNTVLY_345KV_RNS5				FWD
Wed 03/10/2021	to	Fri 03/12/2021	CANCELLED by ConEd 01/15/2021	(Import)
2000	Continuous	0200	UPNY CONED	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 2420 MW
				TTC with All Lines In Service 6220 MW
NIAGARA_-ROBNSNRD_230_64				REV
Fri 03/12/2021	to	Fri 03/12/2021		(Export)
0500	Continuous	1700	SCH - OH - NY	1900 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 100 MW
				TTC with All Lines In Service 2000 MW
MARCY_345KV_CSC				FWD
Sat 03/13/2021	to	Sat 03/13/2021	UPDATED by NYPA 07/29/2020	(Import)
0700	Continuous	1730	CENTRAL EAST - VC	2925 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 50 MW
				TTC with All Lines In Service 2975 MW
MILLWOOD_345KV_18				FWD
Mon 03/22/2021	to	Tue 03/30/2021		(Import)
0001	Continuous	1800	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1870 MW
				TTC with All Lines In Service 6220 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 18, 2021 to Wednesday, July 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONTP-W49TH_ST_345_Y56

Tue 03/23/2021 to Fri 03/26/2021
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

W49TH_ST_345KV_6

Tue 03/23/2021 to Fri 03/26/2021
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

W49TH_ST_345KV_7

Tue 03/23/2021 to Fri 03/26/2021
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

CLAY -EDIC 345_2-15

Mon 03/29/2021 to Fri 04/16/2021
 0800 Continuous 1730
 Work scheduled by: NYPA

09/12/2020

FWD
 (Import)
 OSWEGO EXPORT **4850 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 5250 MW

W49TH_ST_345KV_6

Tue 03/30/2021 to Tue 03/30/2021
 0230 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

W49TH_ST-E13THSTA_345_M55

Tue 03/30/2021 to Wed 03/31/2021
 0301 Continuous 2200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

W49TH_ST_345KV_6

Tue 03/30/2021 to Wed 03/31/2021
 0301 Continuous 2200
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 18, 2021 to Wednesday, July 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						FWD
BRANCHBG-HOPATCON_500_5060						(Import)
Wed 03/31/2021	to	Wed 03/31/2021	<u>UPDATED</u>	<u>by PJM</u>	<u>11/30/2020</u>	
0200	Continuous	1500				6025 MW
Work scheduled by: PJM						Impacts Total Transfer Capability 195 MW
						TTC with All Lines In Service 6220 MW
<hr/>						FWD
ROCHESTR-PANNELL_345_RP2						(Import)
Wed 03/31/2021	to	Mon 04/12/2021				
0500	Continuous	1700				2300 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 850 MW
						TTC with All Lines In Service 3150 MW
<hr/>						FWD
SPRNBK_345KV_RNS3						(Import)
Thu 04/01/2021	to	Thu 04/01/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>12/16/2020</u>	
0001	Continuous	0030				3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
<hr/>						FWD
EASTVIEW-SPRNBK_345_W78						(Import)
Thu 04/01/2021	to	Thu 04/01/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>12/16/2020</u>	
0001	Continuous	1830				4350 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 1870 MW
						TTC with All Lines In Service 6220 MW
<hr/>						FWD
MILLWOOD-EASTVIEW_345_W85						(Import)
Thu 04/01/2021	to	Thu 04/01/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>12/16/2020</u>	
0001	Continuous	1830				5985 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 235 MW
						TTC with All Lines In Service 6220 MW
<hr/>						FWD
SPRNBK_345KV_RNS3						(Import)
Thu 04/01/2021	to	Thu 04/01/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>12/16/2020</u>	
1800	Continuous	1830				3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
<hr/>						FWD
LINDN_CG-LNDVFT_345_V-3022						REV
Sun 04/04/2021	to	Sat 04/10/2021				(Import) (Export)
1400	Continuous	1400				0 MW 0 MW
Work scheduled by: PJM						SCH - PJM_VFT
						Impacts Total Transfer Capability 315 MW 315 MW
						TTC with All Lines In Service 315 MW 315 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 18, 2021 to Wednesday, July 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BUCHAN_N-EASTVIEW_345_W93

Mon 04/05/2021 to Thu 04/08/2021
0001 Continuous 0200

EXTENDED by CE 01/06/2021

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1870 MW
TTC with All Lines In Service 6220 MW

EASTVIEW-SPRNBK__345_W79

Mon 04/05/2021 to Thu 04/08/2021
0001 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1870 MW
TTC with All Lines In Service 6220 MW

RAMAPO__-BUCHAN_N_345_Y94

Mon 04/05/2021 to Thu 04/08/2021
0001 Continuous 0200

EXTENDED by CE 01/06/2021

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **5765 MW**
Impacts Total Transfer Capability 455 MW
TTC with All Lines In Service 6220 MW

SPRNBK_-TREMONT__345_X28

Thu 04/08/2021 to Wed 04/14/2021
0201 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **4200 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 4600 MW

GOETHALS_345KV_5

Sat 04/10/2021 to Mon 05/10/2021
0200 Continuous 0200

UPDATED by CONED 12/29/2020

Work scheduled by: PJM

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

LINDEN__-GOETHALS_230_A2253

Sat 04/10/2021 to Mon 05/10/2021
0200 Continuous 0200

UPDATED by CONED 12/29/2020

Work scheduled by: PJM

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

LINDEN__-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402

Sat 04/10/2021 to Mon 05/10/2021
0200 Continuous 0200

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2550 MW	1900 MW
Impacts Total Transfer Capability	250 MW	50 MW
TTC with All Lines In Service	2800 MW	1950 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 18, 2021 to Wednesday, July 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LINDEN__-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402 & MARION__-FARRAGUT_345_C3403

Sat 04/10/2021 to Mon 05/10/2021
0200 0200

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2550 MW	1900 MW
Impacts Total Transfer Capability	250 MW	50 MW
TTC with All Lines In Service	2800 MW	1950 MW

LINDEN__-GOETHALS_230_A2253 & MARION__-FARRAGUT_345_C3403

Sat 04/10/2021 to Mon 05/10/2021
0200 0200

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2550 MW	1900 MW
Impacts Total Transfer Capability	250 MW	50 MW
TTC with All Lines In Service	2800 MW	1950 MW

NIAGARA_-STA_255__345_NH2

Fri 04/16/2021 to Fri 04/16/2021
0500 Continuous 1700

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	2350 MW
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	3150 MW

KINTIGH_-STA_255__345_SH1-39

Mon 04/26/2021 to Fri 04/30/2021
0700 Continuous 1700

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	2350 MW
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	3150 MW

NIAGARA_-KINTIGH__345_NS1-38

Mon 04/26/2021 to Fri 04/30/2021
0700 Continuous 1700

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	1700 MW
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

PLSNTVLY-WOOD_ST__345_F31

Tue 04/27/2021 to Wed 04/28/2021
0001 Continuous 0159

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	4000 MW
Impacts Total Transfer Capability	2220 MW
TTC with All Lines In Service	6220 MW

PLSNTVLY_345KV_RNS4

Tue 04/27/2021 to Wed 04/28/2021
0001 Continuous 0159

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	3800 MW
Impacts Total Transfer Capability	2420 MW
TTC with All Lines In Service	6220 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 18, 2021 to Wednesday, July 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD_345KV_18

Fri 04/30/2021 to Sat 05/01/2021
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1870 MW
 TTC with All Lines In Service 6220 MW

PLSNTVLY-WOOD_ST_345_F30

Fri 04/30/2021 to Tue 05/11/2021
 0001 Continuous 2200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 2220 MW
 TTC with All Lines In Service 6220 MW

PLSNTVLY_345KV_RNS5

Fri 04/30/2021 to Tue 05/11/2021
 0001 Continuous 2200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 2420 MW
 TTC with All Lines In Service 6220 MW

SCH-IMO-NYISO_LIMIT_1600

Sat 05/01/2021 to Sun 10/31/2021 **UPDATED by IESO 05/03/2019**
 0001 Continuous 2359
 Work scheduled by: IESO

FWD
 (Import)
 SCH - OH - NY **1900 MW**
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 1950 MW

CLAY__-EDIC__345_2-15

Mon 05/03/2021 to Fri 05/07/2021
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 OSWEGO EXPORT **4850 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 5250 MW

PANNELL_-CLAY__345_2

Mon 05/03/2021 to Sun 05/30/2021
 0700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 WEST CENTRAL **1300 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

HURLYAVE-ROSETON__345_303

Mon 05/03/2021 to Fri 05/21/2021
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4100 MW**
 Impacts Total Transfer Capability 2120 MW
 TTC with All Lines In Service 6220 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 18, 2021 to Wednesday, July 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

			FWD	REV
			(Import)	(Export)
SHOR_NPX-SHOREHAM_138_CSC				
Mon 05/03/2021	to	Fri 05/07/2021		
0900	Continuous	1500	SCH - NPX_CSC	0 MW 0 MW
Work scheduled by: LI			Impacts Total Transfer Capability	330 MW 330 MW
			TTC with All Lines In Service	330 MW 330 MW
CLAY -EDIC 345 1-16				
Mon 05/10/2021	to	Fri 05/14/2021		
0700	Continuous	1530	OSWEGO EXPORT	4850 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	400 MW
			TTC with All Lines In Service	5250 MW
DUNWODIE_345KV_5				
Wed 05/12/2021	to	Thu 05/13/2021		
0001	Continuous	0200	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_7				
Wed 05/12/2021	to	Thu 05/13/2021		
0001	Continuous	0200	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW
SPRNBK_-DUNWODIE_345_W75				
Wed 05/12/2021	to	Thu 05/13/2021		
0001	Continuous	0200	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW
SPRNBK_345KV_RNS3				
Wed 05/12/2021	to	Thu 05/13/2021		
0001	Continuous	0200	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW
NIAGARA -STA_255_345_NH2				
Mon 05/24/2021	to	Fri 05/28/2021		
0500	Continuous	1700	DYSINGER EAST	2350 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 18, 2021 to Wednesday, July 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

VOLNEY -MARCY 345_19

Tue 06/01/2021 to Wed 06/02/2021
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2825 MW**
Impacts Total Transfer Capability 150 MW
TTC with All Lines In Service 2975 MW

VOLNEY -MARCY 345_19

Tue 06/01/2021 to Wed 06/02/2021
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
OSWEGO EXPORT **4900 MW**
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 5250 MW

FRASER -GILBOA 345_GF5-35

Tue 06/01/2021 to Mon 06/07/2021
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2650 MW**
Impacts Total Transfer Capability 325 MW
TTC with All Lines In Service 2975 MW

MOSES -ADIRNDCK 230_MA2

Tue 06/01/2021 to Sun 11/14/2021
0700 Continuous 1300

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

PORTER -ROTTRDAM 230_30

Thu 06/03/2021 to Wed 09/15/2021
0600 Continuous 0559

Work scheduled by: NGrid

UPDATED by NGRID 01/15/2021

FWD
(Import)
CENTRAL EAST - VC **2805 MW**
Impacts Total Transfer Capability 170 MW
TTC with All Lines In Service 2975 MW

MARCY -EDIC 345_UE1-7

Thu 06/03/2021 to Fri 06/04/2021
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19&16

FWD
(Import)
OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

MARCY 345KV_CSC

Sat 06/05/2021 to Sat 06/05/2021
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2925 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 18, 2021 to Wednesday, July 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASANX-COOPERS__345_UCC2-41

Fri 06/25/2021 to Tue 08/10/2021
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

MARCY__-FRASANX_345_UCC2-41

Fri 06/25/2021 to Tue 08/10/2021
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

NIAGARA__345_230_AT4

Mon 07/12/2021 to Fri 07/23/2021
0500 Continuous 1700

Work scheduled by: NYPA

FWD

REV

(Import) (Export)

SCH - OH - NY **1900 MW 1400 MW**
Impacts Total Transfer Capability 50 MW 300 MW
TTC with All Lines In Service 1950 MW 1700 MW

SAND_BAR-PLATSBRG_115_PV20

Tue 08/03/2021 to Tue 08/03/2021
0700 Continuous 1830

Work scheduled by: NYPA

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FRASANX-COOPERS__345_UCC2-41

Tue 09/07/2021 to Wed 09/15/2021
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

MARCY__-FRASANX_345_UCC2-41

Tue 09/07/2021 to Wed 09/15/2021
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

KINTIGH_-STA_255__345_SH1-39

Mon 09/13/2021 to Fri 09/17/2021
0500 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **2350 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 18, 2021 to Wednesday, July 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-KINTIGH__345_NS1-38

Mon 09/13/2021 to Fri 09/17/2021
0500 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

PORTER_-ROTTDAM_230_30

Wed 09/15/2021 to Tue 11/30/2021
0600 Continuous 1830

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **2805 MW**
Impacts Total Transfer Capability 170 MW
TTC with All Lines In Service 2975 MW

EDIC_-N.SCTLND_345_14

Thu 09/16/2021 to Sun 11/14/2021
0600 Continuous 1830

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **2240 MW**
Impacts Total Transfer Capability 735 MW
TTC with All Lines In Service 2975 MW

HURLYAVE-ROSETON__345_303

Thu 09/16/2021 to Sun 10/17/2021
0800 Continuous 1600

Work scheduled by: CHGE

UPDATED by CHGE 09/22/2020

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 2120 MW
TTC with All Lines In Service 6220 MW

HOMRC_NY-MAINS_NY_345_47

Sat 09/18/2021 to Fri 11/05/2021
0800 Continuous 1600

Work scheduled by: PJM

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

PANNELL_-CLAY__345_1

Mon 09/20/2021 to Fri 09/24/2021
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

CLAY_-EDIC__345_2-15

Mon 09/20/2021 to Sat 10/16/2021
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
OSWEGO EXPORT **4850 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 5250 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 18, 2021 to Wednesday, July 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PANNELL_-CLAY_345_2

Mon 09/27/2021 to Fri 10/01/2021
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

W49TH_ST_345KV_6

Tue 09/28/2021 to Tue 09/28/2021 UPDATED by CONED 01/15/2021
0100 Continuous 0130

Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **300 MW**
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

E13THSTA-FARRAGUT_345_46

Tue 09/28/2021 to Tue 10/26/2021 UPDATED by CONED 01/15/2021
0100 Continuous 0300

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

W49TH_ST-E13THSTA_345_M55

Tue 09/28/2021 to Tue 10/26/2021 UPDATED by CONED 01/15/2021
0100 Continuous 0300

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

LEEDS_-HURLYAVE_345_301

Mon 10/18/2021 to Fri 11/19/2021
0800 Continuous 1600

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 2120 MW
TTC with All Lines In Service 6220 MW

GOETHALS_345KV_5

Thu 10/21/2021 to Sat 11/20/2021
0001 Continuous 0200

Work scheduled by: ConEd

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

W49TH_ST_345KV_6

Tue 10/26/2021 to Tue 10/26/2021 UPDATED by CONED 01/15/2021
0230 Continuous 0300

Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **300 MW**
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 18, 2021 to Wednesday, July 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOTTHAVN-RAINEY__345_Q11					FWD	
Wed 10/27/2021	to	Wed 12/01/2021			(Import)	
0001	Continuous	0200		SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
SCH-IMO-NYISO_LIMIT_1750					FWD	
Mon 11/01/2021	to	Fri 12/31/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Import)
0001	Continuous	2359				SCH - OH - NY
Work scheduled by: IESO					Impacts Total Transfer Capability	250 MW
					TTC with All Lines In Service	2300 MW
SCH-NYISO-IMO_LIMIT_1600						REV
Mon 11/01/2021	to	Fri 12/31/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Export)
0001	Continuous	2359				SCH - OH - NY
Work scheduled by: IESO					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	2000 MW
W49TH_ST_345KV_6					FWD	
Mon 11/15/2021	to	Sat 01/15/2022			(Import)	
0001	Continuous	0300				SCH - PJM_HTP
Work scheduled by: ConEd					Impacts Total Transfer Capability	360 MW
					TTC with All Lines In Service	660 MW
W49TH_ST_345KV_8					FWD	
Mon 11/15/2021	to	Sat 01/15/2022			(Import)	
0001	Continuous	0300				SCH - PJM_HTP
Work scheduled by: ConEd					Impacts Total Transfer Capability	360 MW
					TTC with All Lines In Service	660 MW
CHATGUAY-MASSENA__765_7040					FWD	
Mon 11/15/2021	to	Tue 11/30/2021			(Import)	
0100	Continuous	1859				MOSES SOUTH
Work scheduled by: NYPA					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	3150 MW
CHATGUAY-MASSENA__765_7040					FWD	REV
Mon 11/15/2021	to	Tue 11/30/2021			(Import)	(Export)
0100	Continuous	1859				SCH - HQ - NY
Work scheduled by: NYPA					Impacts Total Transfer Capability	1500 MW
					TTC with All Lines In Service	1500 MW
						1000 MW
						1000 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 18, 2021 to Wednesday, July 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT1		FWD
Mon 11/15/2021	to Tue 11/30/2021	(Import)
0100	Continuous 1859	MOSES SOUTH 1750 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability 1400 MW
ARR: 19		TTC with All Lines In Service 3150 MW
MARCY___765_345_AT2		FWD
Mon 11/15/2021	to Tue 11/30/2021	(Import)
0100	Continuous 1859	MOSES SOUTH 1700 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability 1450 MW
ARR: 19		TTC with All Lines In Service 3150 MW
MASSENA_-MARCY___765_MSU1		FWD
Mon 11/15/2021	to Tue 11/30/2021	(Import)
0100	Continuous 1859	CENTRAL EAST - VC 2265 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability 710 MW
		TTC with All Lines In Service 2975 MW
MASSENA_-MARCY___765_MSU1		FWD
Mon 11/15/2021	to Tue 11/30/2021	(Import)
0100	Continuous 1859	MOSES SOUTH 500 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability 2650 MW
		TTC with All Lines In Service 3150 MW
MASSENA_-MARCY___765_MSU1		FWD
Mon 11/15/2021	to Tue 11/30/2021	(Import) (Export)
0100	Continuous 1859	SCH - HQ - NY 475 MW 1000 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability 1025 MW 0 MW
		TTC with All Lines In Service 1500 MW 1000 MW
MASSENA_-MARCY___765_MSU1		FWD
Mon 11/15/2021	to Tue 11/30/2021	(Import)
0100	Continuous 1859	SCH - HQ_CEDARS 90 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability 109 MW
		TTC with All Lines In Service 199 MW
MASSENA_-MARCY___765_MSU1 & CHATGUAY-MASSENA_765_7040		FWD
Mon 11/15/2021	to Tue 11/30/2021	(Import)
0100	Continuous 1859	MOSES SOUTH 500 MW
Work scheduled by:		Impacts Total Transfer Capability 2650 MW
		TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 18, 2021 to Wednesday, July 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2

Mon 11/15/2021 to Tue 11/30/2021
 0100 1859

Work scheduled by:

FWD (Import) (Export)
 SCH - HQ - NY **850 MW 0 MW**
 Impacts Total Transfer Capability 650 MW 1000 MW
 TTC with All Lines In Service 1500 MW 1000 MW

MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2

Mon 11/15/2021 to Tue 11/30/2021
 0100 1859

Work scheduled by:

FWD (Import)
 SCH - HQ_CEDARS **90 MW**
 Impacts Total Transfer Capability 109 MW
 TTC with All Lines In Service 199 MW

STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1

Mon 11/15/2021 to Tue 11/30/2021
 0100 1859

Work scheduled by:

FWD (Import)
 SCH - HQ_CEDARS **90 MW**
 Impacts Total Transfer Capability 109 MW
 TTC with All Lines In Service 199 MW

STLAWRNC-MOSES 230_L33P & MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2

Mon 11/15/2021 to Tue 11/30/2021
 0100 1859

Work scheduled by:

FWD (Import)
 SCH - HQ_CEDARS **90 MW**
 Impacts Total Transfer Capability 109 MW
 TTC with All Lines In Service 199 MW

FRASER 345_FRASER SVC

Wed 12/01/2021 to Mon 02/28/2022
 0700 Continuous 1730

Work scheduled by: NYPA

FWD (Import)
 CENTRAL EAST - VC **2935 MW**
 Impacts Total Transfer Capability 40 MW
 TTC with All Lines In Service 2975 MW

MOSES -ADIRNDCK 230_MAI

Wed 12/01/2021 to Tue 05/31/2022
 0700 Continuous 1300

Work scheduled by: NYPA

FWD (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MOTTHAVN-RAINEY 345_Q12

Thu 12/02/2021 to Wed 12/22/2021
 0201 Continuous 0200

Work scheduled by: ConEd

FWD (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Monday ,January 18, 2021 to Wednesday,July 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

N. SCTLND-ALPS_____345_2					FWD	
Mon 05/02/2022	to	Mon 05/09/2022			(Import)	
0600	Daily	1800		SCH - NE - NY	750 MW	
Work scheduled by: NGrid					Impacts Total Transfer Capability	650 MW
					TTC with All Lines In Service	1400 MW
N. SCTLND-ALPS_____345_2					FWD	REV
Mon 05/02/2022	to	Mon 05/09/2022			(Import)	(Export)
0600	Daily	1800		SCH - NPX_1385	100 MW	100 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
HOMRC_NY-MAINS_NY_345_47						
Fri 05/20/2022	to	Fri 05/27/2022	<u>UPDATED</u>	<u>by PJM</u>	<u>11/19/2020</u>	
0800	Continuous	1600			SCH - PJ - NY	
Work scheduled by: PJM					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
HOMR_NYW-PIERC_NY_345_48						
Fri 05/20/2022	to	Fri 05/27/2022	<u>UPDATED</u>	<u>by PJM</u>	<u>11/19/2020</u>	
0800	Continuous	1600			SCH - PJ - NY	
Work scheduled by: PJM					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
MOSES___-ADIRNDCK_230_MA2					FWD	
Wed 06/01/2022	to	Mon 11/14/2022			(Import)	
0700	Continuous	1300		MOSES SOUTH	2100 MW	
Work scheduled by: NYPA					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	3150 MW