

NYISO TRANSFER LIMITATIONS

Wednesday, January 20, 2021 to Friday, July 22, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Wed 06/30/2021 EXT FORCE by CONED 08/28/2020
 0001 Continuous 2359
 Work scheduled by: ConEd

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Wed 06/30/2021
 0001 2359
 Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2550 MW	1900 MW
Impacts Total Transfer Capability	250 MW	50 MW
TTC with All Lines In Service	2800 MW	1950 MW

MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Wed 06/30/2021 EXT FORCE by CONED 08/28/2020
 0001 Continuous 2359
 Work scheduled by: ConEd

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

STLAWRNC-MOSES_230_L33P

Mon 04/30/2018 to Mon 10/31/2022 EXT FORCE by IESO 10/01/2020
 0456 Continuous 1600
 Work scheduled by: IESO

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

NEWBRDGE_345_138_BK_1

Wed 09/02/2020 to Tue 02/01/2022 EXT FORCE by LI 01/12/2021
 1807 Continuous 2359
 Work scheduled by: LI

	FWD
	(Import)
SCH - PJM_NEPTUNE	375 MW
Impacts Total Transfer Capability	285 MW
TTC with All Lines In Service	660 MW

SPRNBK_-EGRDNCTR_345_Y49

Thu 10/01/2020 to Fri 02/19/2021 EXT FORCE by LI 12/16/2020
 0404 Continuous 2359
 Work scheduled by: LI

	FWD
	(Import)
CONED - LIPA	775 MW
Impacts Total Transfer Capability	725 MW
TTC with All Lines In Service	1500 MW

EGRDNCTY_345_138_AT2

Sat 10/10/2020 to Fri 02/19/2021 EXT FORCE by LI 12/16/2020
 1815 Continuous 2359
 Work scheduled by: LI

	FWD
	(Import)
CONED - LIPA	1250 MW
Impacts Total Transfer Capability	250 MW
TTC with All Lines In Service	1500 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 20, 2021 to Friday, July 22, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						
EGRDNCTY_345_138_AT1					FWD	
Sat 10/10/2020	to	Fri 02/19/2021	<u>EXT FORCE</u>	<u>by LI</u>	<u>12/16/2020</u>	(Import)
1856	Continuous	2359				1250 MW
Work scheduled by: LI						Impacts Total Transfer Capability 250 MW
						TTC with All Lines In Service 1500 MW
<hr/>						
SCH-IMO-NYISO_LIMIT_1750					FWD	
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Import)
0001	Continuous	2359				2050 MW
Work scheduled by: IESO						Impacts Total Transfer Capability 250 MW
						TTC with All Lines In Service 2300 MW
<hr/>						
SCH-NYISO-IMO_LIMIT_1600					REV	
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Export)
0001	Continuous	2359				1900 MW
Work scheduled by: IESO						Impacts Total Transfer Capability 100 MW
						TTC with All Lines In Service 2000 MW
<hr/>						
SHOR_NPX-SHOREHAM_138_CSC					FWD	REV
Sun 11/08/2020	to	Sat 01/16/2021	<u>EXT FORCE</u>	<u>by ISONE</u>	<u>12/23/2020</u>	(Import) (Export)
1341	Continuous	2359				0 MW 0 MW
Work scheduled by: LI						Impacts Total Transfer Capability 330 MW 330 MW
						TTC with All Lines In Service 330 MW 330 MW
<hr/>						
PLSNTVLE-DUNWODIE_345_W89					FWD	
Mon 11/30/2020	to	Wed 02/10/2021	<u>EXT FORCE</u>	<u>by CONED</u>	<u>01/15/2021</u>	(Import)
1840	Continuous	2359				4000 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 2220 MW
						TTC with All Lines In Service 6220 MW
<hr/>						
SHORE_RD_345_138_BK_2					FWD	
Sat 12/19/2020	to	Fri 03/05/2021	<u>EXTENDED</u>	<u>by LIPA</u>	<u>12/23/2020</u>	(Import)
1452	Continuous	2359				1350 MW
Work scheduled by: LI						Impacts Total Transfer Capability 150 MW
						TTC with All Lines In Service 1500 MW
<hr/>						
NEPTUNE_-DUFFYAVE_345_NEPTUNE					FWD	
Thu 12/31/2020	to	Wed 01/27/2021	<u>EXT FORCE</u>	<u>by PJM</u>	<u>01/04/2021</u>	(Import)
1100	Continuous	2359				0 MW
Work scheduled by: PJM						Impacts Total Transfer Capability 660 MW
						TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 20, 2021 to Friday, July 22, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE-DUFFYAVE_345_501						FWD
Thu 12/31/2020	to	Wed 01/27/2021	EXT FORCE	by PJM	01/04/2021	(Import)
1102	Continuous	2359				0 MW
Work scheduled by: PJM						Impacts Total Transfer Capability 660 MW
						TTC with All Lines In Service 660 MW
NEWBRDGE_345_138_BK_2						FWD
Thu 12/31/2020	to	Wed 01/27/2021	EXT FORCE	by PJM	01/04/2021	(Import)
1102	Continuous	2359				375 MW
Work scheduled by: PJM						Impacts Total Transfer Capability 285 MW
						TTC with All Lines In Service 660 MW
MOSES__-ADIRNDCK_230_MAL						FWD
Mon 01/04/2021	to	Sat 02/27/2021	UPDATED	by NYPA	11/30/2020	(Import)
0700	Continuous	1730				2300 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 850 MW
						TTC with All Lines In Service 3150 MW
SCH-NYISO-IMO_LIMIT_1100						REV
Tue 01/12/2021	to	Fri 01/22/2021	EXTENDED	by IESO	01/13/2021	(Export)
1100	Continuous	1700				1400 MW
Work scheduled by: IESO						Impacts Total Transfer Capability 600 MW
						TTC with All Lines In Service 2000 MW
SCH-IMO-NYISO_LIMIT_1150						FWD
Wed 01/13/2021	to	Fri 01/22/2021	EXTENDED	by IESO	01/13/2021	(Import)
0001	Continuous	1700				1450 MW
Work scheduled by: IESO						Impacts Total Transfer Capability 850 MW
						TTC with All Lines In Service 2300 MW
SCH-NYISO-HQ_CEDARS_LIMIT_0						REV
Mon 01/18/2021	to	Wed 01/20/2021				(Export)
0600	Continuous	0700				0 MW
Work scheduled by: HQ						Impacts Total Transfer Capability 100 MW
						TTC with All Lines In Service 100 MW
SCH-NYISO-HQ_CEDARS_LIMIT_0						REV
Thu 01/21/2021	to	Thu 01/21/2021				(Export)
0900	Continuous	1700				0 MW
Work scheduled by: HQ						Impacts Total Transfer Capability 100 MW
						TTC with All Lines In Service 100 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 20, 2021 to Friday, July 22, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_-W49TH_ST_345_M52				FWD
Sat 01/23/2021	to	Sun 01/24/2021		(Import)
0001	Continuous	0059	SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW
W49TH_ST_345KV_5				FWD
Sat 01/23/2021	to	Sun 01/24/2021		(Import)
0001	Continuous	0059	SCH - PJM_HTP	300 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 360 MW
				TTC with All Lines In Service 660 MW
SCH-IMO-NYISO_LIMIT_1550				FWD
Sat 01/23/2021	to	Sat 01/23/2021		(Import)
0700	Continuous	1600	SCH - OH - NY	1850 MW
Work scheduled by: IESO				Impacts Total Transfer Capability 450 MW
				TTC with All Lines In Service 2300 MW
PLSNTVLY_345KV_RNS5				FWD
Sat 01/23/2021	to	Sat 01/23/2021		(Import)
0800	Daily	0830	UPNY CONED	3800 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 2420 MW
				TTC with All Lines In Service 6220 MW
LEEDS___-PLSNTVLY_345_92				FWD
Sat 01/23/2021	to	Sat 01/23/2021		(Import)
0800	Daily	1400	UPNY CONED	3800 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 2420 MW
				TTC with All Lines In Service 6220 MW
PLSNTVLY_345KV_RNS5				FWD
Sat 01/23/2021	to	Sat 01/23/2021		(Import)
1330	Daily	1400	UPNY CONED	3800 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 2420 MW
				TTC with All Lines In Service 6220 MW
MOTTHAVN-RAINEY___345_Q12				FWD
Mon 01/25/2021	to	Sat 02/13/2021	UPDATED by CONED 12/22/2020	(Import)
0001	Continuous	0200	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 20, 2021 to Friday, July 22, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_5						FWD	
Mon 02/08/2021	to	Tue 02/09/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>01/11/2021</u>	(Import)	
0001	Continuous	0200				300 MW	
Work scheduled by: ConEd						SCH - PJM_HTP	
						Impacts Total Transfer Capability	360 MW
						TTC with All Lines In Service	660 MW
W49TH_ST_345KV_7						FWD	
Mon 02/08/2021	to	Tue 02/09/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>01/11/2021</u>	(Import)	
0001	Continuous	0200				300 MW	
Work scheduled by: ConEd						SCH - PJM_HTP	
						Impacts Total Transfer Capability	360 MW
						TTC with All Lines In Service	660 MW
RAMAPO__345_345_PAR3500						FWD	REV
Mon 02/08/2021	to	Mon 02/15/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>12/09/2020</u>	(Import)	(Export)
0001	Continuous	0200				2350 MW	1250 MW
Work scheduled by: ConEd						SCH - PJ - NY	
						Impacts Total Transfer Capability	450 MW 700 MW
						TTC with All Lines In Service	2800 MW 1950 MW
RAMAPO__345_345_PAR4500						FWD	REV
Mon 02/08/2021	to	Mon 02/15/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>12/09/2020</u>	(Import)	(Export)
0001	Continuous	0200				2350 MW	1250 MW
Work scheduled by: ConEd						SCH - PJ - NY	
						Impacts Total Transfer Capability	450 MW 700 MW
						TTC with All Lines In Service	2800 MW 1950 MW
RAMAPO__500_345_BK 1500						FWD	REV
Mon 02/08/2021	to	Mon 02/15/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>12/09/2020</u>	(Import)	(Export)
0001	Continuous	0200				1450 MW	1200 MW
Work scheduled by: ConEd						SCH - PJ - NY	
						Impacts Total Transfer Capability	1350 MW 750 MW
						TTC with All Lines In Service	2800 MW 1950 MW
RAMAPO__500_345_BK 1500						FWD	
Mon 02/08/2021	to	Mon 02/15/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>12/09/2020</u>	(Import)	
0001	Continuous	0200				6025 MW	
Work scheduled by: ConEd						UPNY CONED	
						Impacts Total Transfer Capability	195 MW
						TTC with All Lines In Service	6220 MW
HOPATCON-RAMAPO__500_5018						FWD	REV
Mon 02/08/2021	to	Mon 02/15/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>12/09/2020</u>	(Import)	(Export)
0001	Continuous	1900				1450 MW	1200 MW
Work scheduled by: ConEd						SCH - PJ - NY	
						Impacts Total Transfer Capability	1350 MW 750 MW
						TTC with All Lines In Service	2800 MW 1950 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 20, 2021 to Friday, July 22, 2022

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HOPATCON-RAMAPO ___ 500_5018					FWD
Mon 02/08/2021	to	Mon 02/15/2021	UPDATED	by CONED	(Import)
0001	Continuous	1900		<u>12/09/2020</u>	6025 MW
Work scheduled by: ConEd					UPNY CONED
					Impacts Total Transfer Capability 195 MW
					TTC with All Lines In Service 6220 MW
PORTER ___-ROTTRDAM_230_31					FWD
Mon 02/08/2021	to	Sat 02/27/2021	UPDATED	by NGRID	(Import)
0600	Continuous	1730		<u>01/15/2021</u>	2805 MW
Work scheduled by: NGrid					CENTRAL EAST - VC
					Impacts Total Transfer Capability 170 MW
					TTC with All Lines In Service 2975 MW
WATRCURE-OAKDALE ___ 345_31					
Mon 02/15/2021	to	Thu 02/18/2021			
0800	Daily	1500			
Work scheduled by: NYSEG					SCH - PJ - NY
					Impacts Total Transfer Capability
					TTC with All Lines In Service
E13THSTA-FARRAGUT ___ 345_46					FWD
Tue 02/16/2021	to	Wed 02/17/2021	UPDATED	by CONED	(Import)
0001	Continuous	2100		<u>12/21/2020</u>	3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
W49TH_ST_345KV_8					FWD
Tue 02/16/2021	to	Sun 03/28/2021	UPDATED	by CE	(Import)
0301	Continuous	0200		<u>01/19/2021</u>	300 MW
Work scheduled by: ConEd					SCH - PJM_HTP
					Impacts Total Transfer Capability 360 MW
					TTC with All Lines In Service 660 MW
BERKSHIR-ALPS ___ 345_393					FWD
Wed 02/17/2021	to	Fri 02/19/2021	UPDATED	by ISONE	(Import) (Export)
0600	Continuous	1700		<u>12/29/2020</u>	1100 MW 1700 MW
Work scheduled by: NGrid					SCH - NE - NY
					Impacts Total Transfer Capability 300 MW 0 MW
					TTC with All Lines In Service 1400 MW 1700 MW
BERKSHIR-ALPS ___ 345_393					FWD
Wed 02/17/2021	to	Fri 02/19/2021	UPDATED	by ISONE	(Import) (Export)
0600	Continuous	1700		<u>12/29/2020</u>	100 MW 100 MW
Work scheduled by: NGrid					SCH - NPX_1385
					Impacts Total Transfer Capability 100 MW 100 MW
					TTC with All Lines In Service 200 MW 200 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 20, 2021 to Friday, July 22, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					FWD	REV
BERKSHIR-ALPS 345_393 & BERKSHIR-NORTHFLD_345_312					(Import)	(Export)
Wed 02/17/2021	to	Fri 02/19/2021			1100 MW	1700 MW
0600		1700		SCH - NE - NY		
Work scheduled by:					Impacts Total Transfer Capability	300 MW 0 MW
ARR: 78					TTC with All Lines In Service	1400 MW 1700 MW
<hr/>					FWD	
BERKSHIR-NORTHFLD_345_312					(Import)	
Wed 02/17/2021	to	Fri 02/19/2021	UPDATED	by ISONE 12/29/2020	1300 MW	
0600	Continuous	1700		SCH - NE - NY		
Work scheduled by: NGrid					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	1400 MW
<hr/>					FWD	REV
BERKSHIR-NORTHFLD_345_312					(Import)	(Export)
Wed 02/17/2021	to	Fri 02/19/2021	UPDATED	by ISONE 12/29/2020	100 MW	100 MW
0600	Continuous	1700		SCH - NPX_1385		
Work scheduled by: NGrid					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW
<hr/>					FWD	
SCH-NE-NYISO_LIMIT_800					(Import)	
Wed 02/17/2021	to	Fri 02/19/2021	UPDATED	by ISONE 12/29/2020	1000 MW	
0600	Continuous	1700		SCH - NE - NY		
Work scheduled by: NGrid					Impacts Total Transfer Capability	400 MW
					TTC with All Lines In Service	1400 MW
<hr/>						REV
SCH-NYISO-NE_LIMIT_700						(Export)
Wed 02/17/2021	to	Fri 02/19/2021	UPDATED	by ISONE 12/29/2020	900 MW	
0600	Continuous	1700		SCH - NE - NY		
Work scheduled by: NGrid					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	1700 MW
<hr/>						
SAND_BAR-PLATSBURG_115_PV20						
Mon 02/22/2021	to	Fri 02/26/2021				
0600	Daily	1800		SCH - NE - NY		
Work scheduled by: ISONE					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
<hr/>						REV
NIAGARA_-ROBNSNRD_230_64						(Export)
Mon 02/22/2021	to	Wed 02/24/2021			1900 MW	
0700	Continuous	1800		SCH - OH - NY		
Work scheduled by: NYSEG					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	2000 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 20, 2021 to Friday, July 22, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						FWD	
BRANCHBG-HOPATCON_500_5060						(Import)	
Wed 02/24/2021	to	Wed 02/24/2021	CANCELLED	by PJM	01/19/2021		
0200	Continuous	2200				UPNY CONED	6025 MW
Work scheduled by: PJM						Impacts Total Transfer Capability	195 MW
						TTC with All Lines In Service	6220 MW
<hr/>							
LADENTWN-BUCHAN_S_345_Y88						FWD	
						(Import)	
Sun 02/28/2021	to	Tue 03/30/2021	UPDATED	by CE	11/10/2020		
0001	Continuous	0200				UPNY CONED	5930 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	290 MW
						TTC with All Lines In Service	6220 MW
<hr/>							
CHATGUAY-MASSENA_765_7040						FWD	
						(Import)	
Sun 02/28/2021	to	Mon 03/01/2021				MOSES SOUTH	1550 MW
0500	Continuous	1730				Impacts Total Transfer Capability	1600 MW
Work scheduled by: NYPA						TTC with All Lines In Service	3150 MW
<hr/>							
CHATGUAY-MASSENA_765_7040						FWD	REV
						(Import)	(Export)
Sun 02/28/2021	to	Mon 03/01/2021				SCH - HQ - NY	0 MW 0 MW
0500	Continuous	1730				Impacts Total Transfer Capability	1500 MW 1000 MW
Work scheduled by: NYPA						TTC with All Lines In Service	1500 MW 1000 MW
<hr/>							
MASSENA_-MARCY___765_MSU1						FWD	
						(Import)	
Sun 02/28/2021	to	Mon 03/01/2021				CENTRAL EAST - VC	2265 MW
0500	Continuous	1730				Impacts Total Transfer Capability	710 MW
Work scheduled by: NYPA						TTC with All Lines In Service	2975 MW
<hr/>							
MASSENA_-MARCY___765_MSU1						FWD	
						(Import)	
Sun 02/28/2021	to	Mon 03/01/2021				MOSES SOUTH	500 MW
0500	Continuous	1730				Impacts Total Transfer Capability	2650 MW
Work scheduled by: NYPA						TTC with All Lines In Service	3150 MW
<hr/>							
MASSENA_-MARCY___765_MSU1						FWD	REV
						(Import)	(Export)
Sun 02/28/2021	to	Mon 03/01/2021				SCH - HQ - NY	475 MW 1000 MW
0500	Continuous	1730				Impacts Total Transfer Capability	1025 MW 0 MW
Work scheduled by: NYPA						TTC with All Lines In Service	1500 MW 1000 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 20, 2021 to Friday, July 22, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA -MARCY 765_MSU1				FWD	
Sun 02/28/2021	to	Mon 03/01/2021		(Import)	
0500	Continuous	1730		SCH - HQ_CEDARS	90 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	109 MW
				TTC with All Lines In Service	199 MW
MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040				FWD	
Sun 02/28/2021	to	Mon 03/01/2021		(Import)	
0500		1730		MOSES SOUTH	500 MW
Work scheduled by:				Impacts Total Transfer Capability	2650 MW
				TTC with All Lines In Service	3150 MW
STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1				FWD	
Sun 02/28/2021	to	Mon 03/01/2021		(Import)	
0500		1730		SCH - HQ_CEDARS	90 MW
Work scheduled by:				Impacts Total Transfer Capability	109 MW
				TTC with All Lines In Service	199 MW
BERKSHIR-ALPS 345_393				FWD	REV
Mon 03/01/2021	to	Sat 03/20/2021	UPDATED by NGRID 12/14/2020	(Import)	(Export)
0700	Continuous	1600		SCH - NE - NY	1100 MW 1700 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	300 MW 0 MW
				TTC with All Lines In Service	1400 MW 1700 MW
BERKSHIR-ALPS 345_393				FWD	REV
Mon 03/01/2021	to	Sat 03/20/2021	UPDATED by NGRID 12/14/2020	(Import)	(Export)
0700	Continuous	1600		SCH - NPX_1385	100 MW 100 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	100 MW 100 MW
				TTC with All Lines In Service	200 MW 200 MW
SCH-NYISO-NE_LIMIT_900					REV
Mon 03/01/2021	to	Sat 03/20/2021	UPDATED by NGRID 12/14/2020		(Export)
0700	Continuous	1600		SCH - NE - NY	1100 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	600 MW
				TTC with All Lines In Service	1700 MW
MOSES -ADIRNDCK_230_MAI				FWD	
Tue 03/02/2021	to	Mon 05/31/2021		(Import)	
0700	Continuous	1300		MOSES SOUTH	2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 20, 2021 to Friday, July 22, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EDIC -N.SCTLND_345_14					FWD	
Tue 03/02/2021	to	Mon 05/31/2021	UPDATED	by NGRID	01/19/2021	(Import)
0700	Continuous	1730				CENTRAL EAST - VC 2240 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	735 MW
					TTC with All Lines In Service	2975 MW
PORTER -ROTTDAM_230_31					FWD	
Tue 03/02/2021	to	Mon 05/31/2021	UPDATED	by NGRID	01/19/2021	(Import)
0700	Continuous	1730				CENTRAL EAST - VC 2805 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	170 MW
					TTC with All Lines In Service	2975 MW
DUNWODIE_345KV_7					FWD	
Wed 03/03/2021	to	Wed 03/03/2021				(Import)
0001	Continuous	0030				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_8					FWD	
Wed 03/03/2021	to	Wed 03/03/2021				(Import)
0001	Continuous	0030				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
W49TH_ST_345KV_6					FWD	
Wed 03/03/2021	to	Wed 03/03/2021	UPDATED	by CE	01/19/2021	(Import)
0001	Continuous	0030				SCH - PJM_HTP 300 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	360 MW
					TTC with All Lines In Service	660 MW
DUNWODIE-MOTTHAVN_345_72					FWD	
Wed 03/03/2021	to	Wed 03/03/2021				(Import)
0001	Continuous	1800				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_7					FWD	
Wed 03/03/2021	to	Wed 03/03/2021				(Import)
1730	Continuous	1800				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 20, 2021 to Friday, July 22, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_8			FWD
Wed 03/03/2021	to	Wed 03/03/2021	(Import)
1730	Continuous	1800	
Work scheduled by: ConEd			
			SPR/DUN-SOUTH 3800 MW
			Impacts Total Transfer Capability 800 MW
			TTC with All Lines In Service 4600 MW
SPRNBRK_-TREMONT__345_X28			FWD
Mon 03/08/2021	to	Tue 03/09/2021	(Import)
0001	Continuous	0300	
Work scheduled by: ConEd			
			SPR/DUN-SOUTH 4200 MW
			Impacts Total Transfer Capability 400 MW
			TTC with All Lines In Service 4600 MW
BUCHAN_N-EASTVIEW_345_W93			FWD
Tue 03/09/2021	to	Tue 03/09/2021	(Import)
0001	Continuous	0030	
Work scheduled by: ConEd			
			UPNY CONED 4350 MW
			Impacts Total Transfer Capability 1870 MW
			TTC with All Lines In Service 6220 MW
EASTVIEW-SPRNBRK__345_W79			FWD
Tue 03/09/2021	to	Wed 03/10/2021	(Import)
0001	Continuous	0300	
Work scheduled by: ConEd			
			UPNY CONED 4350 MW
			Impacts Total Transfer Capability 1870 MW
			TTC with All Lines In Service 6220 MW
ELBRIDGE-LAFAYTTE_345_17-LE			FWD
Tue 03/09/2021	to	Tue 03/09/2021	(Import)
0800	Daily(No Weekends)	1630	
Work scheduled by: NGrid			
			OSWEGO EXPORT 5250 MW
			Impacts Total Transfer Capability 0 MW
			TTC with All Lines In Service 5250 MW
BUCHAN_N-EASTVIEW_345_W93			FWD
Wed 03/10/2021	to	Wed 03/10/2021	(Import)
0230	Continuous	0300	
Work scheduled by: ConEd			
			UPNY CONED 4350 MW
			Impacts Total Transfer Capability 1870 MW
			TTC with All Lines In Service 6220 MW
PLSNTVLY-WOOD_ST__345_F30			FWD
Wed 03/10/2021	to	Fri 03/12/2021	(Import)
2000	Continuous	0200	
Work scheduled by: ConEd			
			UPNY CONED 4000 MW
			Impacts Total Transfer Capability 2220 MW
			TTC with All Lines In Service 6220 MW

ARR: 75

CANCELLED by ConEd 01/15/2021

NYISO TRANSFER LIMITATIONS

Wednesday, January 20, 2021 to Friday, July 22, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RNS5

FWD

Wed 03/10/2021 to Fri 03/12/2021 **CANCELLED by ConEd 01/15/2021**
 2000 Continuous 0200

(Import)

Work scheduled by: ConEd

UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 2420 MW
 TTC with All Lines In Service 6220 MW

NIAGARA -ROBNSNRD_230_64

REV

Fri 03/12/2021 to Fri 03/12/2021
 0500 Continuous 1700

(Export)

Work scheduled by: NYPA

SCH - OH - NY **1900 MW**
 Impacts Total Transfer Capability 100 MW
 TTC with All Lines In Service 2000 MW

MARCY_345KV_CSC

FWD

Sat 03/13/2021 to Sat 03/13/2021 **UPDATED by NYPA 07/29/2020**
 0700 Continuous 1730

(Import)

Work scheduled by: NYPA

CENTRAL EAST - VC **2925 MW**
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 2975 MW

NINEMILE-CLAY_345_8

FWD

Mon 03/22/2021 to Mon 03/22/2021
 0001 Daily(No Weekends) 0400

(Import)

Work scheduled by: NGrid

OSWEGO EXPORT **5150 MW**
 Impacts Total Transfer Capability 100 MW
 TTC with All Lines In Service 5250 MW

MILLWOOD_345KV_18

FWD

Mon 03/22/2021 to Tue 03/30/2021 **CANCELLED by ConEd 01/20/2021**
 0001 Continuous 1800

(Import)

Work scheduled by: ConEd

UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1870 MW
 TTC with All Lines In Service 6220 MW

HUDSONTP-W49TH_ST_345_Y56

FWD

Tue 03/23/2021 to Fri 03/26/2021 **UPDATED by CE 01/19/2021**
 0001 Continuous 0200

(Import)

Work scheduled by: ConEd

SCH - PJM_HTP **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

W49TH_ST_345KV_6

FWD

Tue 03/23/2021 to Fri 03/26/2021 **UPDATED by CE 01/19/2021**
 0001 Continuous 0200

(Import)

Work scheduled by: ConEd

SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 20, 2021 to Friday, July 22, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_7

Tue 03/23/2021 to Fri 03/26/2021
0001 Continuous 0200

UPDATED by CE 01/19/2021

Work scheduled by: ConEd

FWD
(Import)
300 MW
SCH - PJM_HTP
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

NINEMILE-CLAY 345_8

Wed 03/24/2021 to Wed 03/24/2021
1300 Daily(No Weekends) 1700

Work scheduled by: NGrid

FWD
(Import)
5150 MW
OSWEGO EXPORT
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 5250 MW

NINEMILE-CLAY 345_8

Sat 03/27/2021 to Sat 04/03/2021
1300 Continuous 1700

UPDATED by NGRID 01/19/2021

Work scheduled by: NGrid

FWD
(Import)
5150 MW
OSWEGO EXPORT
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 5250 MW

CLAY -EDIC 345_2-15

Mon 03/29/2021 to Fri 04/16/2021
0800 Continuous 1730

Work scheduled by: NYPA

09/12/2020

FWD
(Import)
4850 MW
OSWEGO EXPORT
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 5250 MW

NINEMILE-CLAY 345_8

Mon 03/29/2021 to Fri 04/02/2021
1300 Daily(No Weekends) 1700

CANCELLED by NGrid 01/19/2021

Work scheduled by: NGrid

FWD
(Import)
5150 MW
OSWEGO EXPORT
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 5250 MW

W49TH_ST_345KV_6

Tue 03/30/2021 to Tue 03/30/2021
0230 Continuous 0300

UPDATED by CE 01/19/2021

Work scheduled by: ConEd

FWD
(Import)
300 MW
SCH - PJM_HTP
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

W49TH_ST-E13THSTA_345_M55

Tue 03/30/2021 to Wed 03/31/2021
0301 Continuous 2200

Work scheduled by: ConEd

FWD
(Import)
3800 MW
SPR/DUN-SOUTH
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 20, 2021 to Friday, July 22, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_6

Tue 03/30/2021 to Wed 03/31/2021
 0301 Continuous 2200
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

BRANCHBG-HOPATCON_500_5060

Wed 03/31/2021 to Wed 03/31/2021 **UPDATED by PJM 11/30/2020**
 0200 Continuous 1500
 Work scheduled by: PJM

FWD
 (Import)
 UPNY CONED **6025 MW**
 Impacts Total Transfer Capability 195 MW
 TTC with All Lines In Service 6220 MW

ROCHESTR-PANNELL_345_RP2

Wed 03/31/2021 to Mon 04/12/2021
 0500 Continuous 1700
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

SPRNBRK_345KV_RNS3

Thu 04/01/2021 to Thu 04/01/2021 **UPDATED by CONED 12/16/2020**
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

EASTVIEW-SPRNBRK_345_W78

Thu 04/01/2021 to Thu 04/01/2021 **UPDATED by CONED 12/16/2020**
 0001 Continuous 1830
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1870 MW
 TTC with All Lines In Service 6220 MW

MILLWOOD-EASTVIEW_345_W85

Thu 04/01/2021 to Thu 04/01/2021 **UPDATED by CONED 12/16/2020**
 0001 Continuous 1830
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **5985 MW**
 Impacts Total Transfer Capability 235 MW
 TTC with All Lines In Service 6220 MW

SPRNBRK_345KV_RNS3

Thu 04/01/2021 to Thu 04/01/2021 **UPDATED by CONED 12/16/2020**
 1800 Continuous 1830
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 20, 2021 to Friday, July 22, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>				
<p>LINDN_CG-LNDVFT___345_V-3022</p> <p>Sun 04/04/2021 to Sat 04/10/2021</p> <p style="padding-left: 40px;">1400 Continuous 1400</p> <p>Work scheduled by: PJM</p>	<p>SCH - PJM_VFT</p> <p>Impacts Total Transfer Capability 315 MW</p> <p>TTC with All Lines In Service 315 MW</p>	<p>FWD</p> <p>(Import)</p> <p>0 MW</p> <p>315 MW</p> <p>315 MW</p>		<p>REV</p> <p>(Export)</p> <p>0 MW</p> <p>315 MW</p> <p>315 MW</p>
<hr/>				
<p>NINEMILE-CLAY___345_8</p> <p>Sun 04/04/2021 to Sun 04/04/2021</p> <p style="padding-left: 40px;">1800 Daily 2000</p> <p>Work scheduled by: NGrid</p>	<p>OSWEGO EXPORT</p> <p>Impacts Total Transfer Capability 100 MW</p> <p>TTC with All Lines In Service 5250 MW</p>	<p>FWD</p> <p>(Import)</p> <p>5150 MW</p> <p>100 MW</p> <p>5250 MW</p>		
<hr/>				
<p>NINEMILE-CLAY___345_8</p> <p>Sun 04/04/2021 to Mon 04/05/2021</p> <p style="padding-left: 40px;">2001 Continuous 0300</p> <p>Work scheduled by: NGrid</p>	<p>OSWEGO EXPORT</p> <p>Impacts Total Transfer Capability 100 MW</p> <p>TTC with All Lines In Service 5250 MW</p>	<p>FWD</p> <p>(Import)</p> <p>5150 MW</p> <p>100 MW</p> <p>5250 MW</p>		
<hr/>				
<p>BUCHAN_N-EASTVIEW_345_W93</p> <p>Mon 04/05/2021 to Thu 04/08/2021</p> <p style="padding-left: 40px;">0001 Continuous 0200</p> <p>Work scheduled by: ConEd</p>	<p><u>EXTENDED</u> <u>by CE</u> <u>01/06/2021</u></p> <p>UPNY CONED</p> <p>Impacts Total Transfer Capability 1870 MW</p> <p>TTC with All Lines In Service 6220 MW</p>	<p>FWD</p> <p>(Import)</p> <p>4350 MW</p> <p>1870 MW</p> <p>6220 MW</p>		
<hr/>				
<p>EASTVIEW-SPRNBK___345_W79</p> <p>Mon 04/05/2021 to Thu 04/08/2021</p> <p style="padding-left: 40px;">0001 Continuous 0200</p> <p>Work scheduled by: ConEd</p>	<p>UPNY CONED</p> <p>Impacts Total Transfer Capability 1870 MW</p> <p>TTC with All Lines In Service 6220 MW</p>	<p>FWD</p> <p>(Import)</p> <p>4350 MW</p> <p>1870 MW</p> <p>6220 MW</p>		
<hr/>				
<p>RAMAPO___-BUCHAN_N_345_Y94</p> <p>Mon 04/05/2021 to Thu 04/08/2021</p> <p style="padding-left: 40px;">0001 Continuous 0200</p> <p>Work scheduled by: ConEd</p>	<p><u>EXTENDED</u> <u>by CE</u> <u>01/06/2021</u></p> <p>UPNY CONED</p> <p>Impacts Total Transfer Capability 455 MW</p> <p>TTC with All Lines In Service 6220 MW</p>	<p>FWD</p> <p>(Import)</p> <p>5765 MW</p> <p>455 MW</p> <p>6220 MW</p>		
<hr/>				
<p>SPRNBK_-TREMONT___345_X28</p> <p>Thu 04/08/2021 to Wed 04/14/2021</p> <p style="padding-left: 40px;">0201 Continuous 0200</p> <p>Work scheduled by: ConEd</p>	<p>SPR/DUN-SOUTH</p> <p>Impacts Total Transfer Capability 400 MW</p> <p>TTC with All Lines In Service 4600 MW</p>	<p>FWD</p> <p>(Import)</p> <p>4200 MW</p> <p>400 MW</p> <p>4600 MW</p>		

NYISO TRANSFER LIMITATIONS

Wednesday, January 20, 2021 to Friday, July 22, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

GOETHALS_345KV_5

Sat 04/10/2021 to Mon 05/10/2021 **UPDATED** by CONED 12/29/2020
 0200 Continuous 0200
 Work scheduled by: PJM

STATEN ISLAND
 Impacts Total Transfer Capability
 TTC with All Lines In Service

LINDEN__-GOETHALS_230_A2253

Sat 04/10/2021 to Mon 05/10/2021 **UPDATED** by CONED 12/29/2020
 0200 Continuous 0200
 Work scheduled by: PJM

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

LINDEN__-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402

Sat 04/10/2021 to Mon 05/10/2021
 0200 0200

	FWD	REV
	(Import)	(Export)
	2550 MW	1900 MW
Impacts Total Transfer Capability	250 MW	50 MW
TTC with All Lines In Service	2800 MW	1950 MW

Work scheduled by:

LINDEN__-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402 & MARION__-FARRAGUT_345_C3403

Sat 04/10/2021 to Mon 05/10/2021
 0200 0200

	FWD	REV
	(Import)	(Export)
	2550 MW	1900 MW
Impacts Total Transfer Capability	250 MW	50 MW
TTC with All Lines In Service	2800 MW	1950 MW

Work scheduled by:

LINDEN__-GOETHALS_230_A2253 & MARION__-FARRAGUT_345_C3403

Sat 04/10/2021 to Mon 05/10/2021
 0200 0200

	FWD	REV
	(Import)	(Export)
	2550 MW	1900 MW
Impacts Total Transfer Capability	250 MW	50 MW
TTC with All Lines In Service	2800 MW	1950 MW

Work scheduled by:

NIAGARA_-STA_255_345_NH2

Fri 04/16/2021 to Fri 04/16/2021
 0500 Continuous 1700

FWD
 (Import)

DYSINGER EAST
2350 MW

Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

PLSNTVLE-DUNWODIE_345_W90

Tue 04/20/2021 to Tue 04/20/2021 **UPDATED** by CONED 01/20/2021
 0001 Continuous 0030

FWD
 (Import)

UPNY CONED
4000 MW

Impacts Total Transfer Capability 2220 MW
 TTC with All Lines In Service 6220 MW

Work scheduled by: ConEd

NYISO TRANSFER LIMITATIONS

Wednesday, January 20, 2021 to Friday, July 22, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLE-DUNWODIE_345_W90

Fri 04/23/2021 to Fri 04/23/2021
 0130 Continuous 0159

Work scheduled by: ConEd

UPDATED by CONED 01/20/2021

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 2220 MW
 TTC with All Lines In Service 6220 MW

KINTIGH -STA_255_345_SH1-39

Mon 04/26/2021 to Fri 04/30/2021
 0700 Continuous 1700

Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **2350 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 3150 MW

NIAGARA -KINTIGH_345_NS1-38

Mon 04/26/2021 to Fri 04/30/2021
 0700 Continuous 1700

Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

FRASER -COOPERS_345_33

Mon 04/26/2021 to Fri 04/30/2021
 0830 Continuous 1500

Work scheduled by: NYSEG

FWD
 (Import)
 CENTRAL EAST - VC **2395 MW**
 Impacts Total Transfer Capability 580 MW
 TTC with All Lines In Service 2975 MW

PLSNTVLY-WOOD_ST_345_F31

Tue 04/27/2021 to Wed 04/28/2021
 0001 Continuous 0159

Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 2220 MW
 TTC with All Lines In Service 6220 MW

PLSNTVLY_345KV_RNS4

Tue 04/27/2021 to Wed 04/28/2021
 0001 Continuous 0159

Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 2420 MW
 TTC with All Lines In Service 6220 MW

MILLWOOD_345KV_18

Fri 04/30/2021 to Sat 05/01/2021
 0001 Continuous 0200

Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1870 MW
 TTC with All Lines In Service 6220 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 20, 2021 to Friday, July 22, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
PLSNTVLY-WOOD_ST_345_F30			FWD
Fri 04/30/2021	to	Tue 05/11/2021	(Import)
0001	Continuous	2200	UPNY CONED 4000 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 2220 MW
			TTC with All Lines In Service 6220 MW
<hr/>			
PLSNTVLY_345KV_RNS5			FWD
Fri 04/30/2021	to	Tue 05/11/2021	(Import)
0001	Continuous	2200	UPNY CONED 3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 2420 MW
			TTC with All Lines In Service 6220 MW
<hr/>			
SCH-IMO-NYISO_LIMIT_1600			FWD
Sat 05/01/2021	to	Sun 10/31/2021	(Import)
0001	Continuous	2359	UPDATED by IESO 05/03/2019 SCH - OH - NY 1900 MW
Work scheduled by: IESO			Impacts Total Transfer Capability 50 MW
			TTC with All Lines In Service 1950 MW
<hr/>			
CLAY -EDIC 345_2-15			FWD
Mon 05/03/2021	to	Fri 05/07/2021	(Import)
0700	Continuous	1530	OSWEGO EXPORT 4850 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 400 MW
			TTC with All Lines In Service 5250 MW
<hr/>			
PANNELL -CLAY 345_2			FWD
Mon 05/03/2021	to	Sun 05/30/2021	(Import)
0700	Continuous	1730	WEST CENTRAL 1300 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 950 MW
			TTC with All Lines In Service 2250 MW
<hr/>			
HURLYAVE-ROSETON 345_303			FWD
Mon 05/03/2021	to	Fri 05/21/2021	(Import)
0800	Continuous	1600	UPNY CONED 4100 MW
Work scheduled by: CHGE			Impacts Total Transfer Capability 2120 MW
			TTC with All Lines In Service 6220 MW
<hr/>			
SHOR_NPX-SHOREHAM_138_CSC			FWD REV
Mon 05/03/2021	to	Fri 05/07/2021	(Import) (Export)
0900	Continuous	1500	SCH - NPX_CSC 0 MW 0 MW
Work scheduled by: LI			Impacts Total Transfer Capability 330 MW 330 MW
			TTC with All Lines In Service 330 MW 330 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 20, 2021 to Friday, July 22, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CLAY - EDIC 345_1-16

Mon 05/10/2021 to Fri 05/14/2021
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
OSWEGO EXPORT **4850 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 5250 MW

DUNWODIE_345KV_5

Wed 05/12/2021 to Thu 05/13/2021
0001 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_7

Wed 05/12/2021 to Thu 05/13/2021
0001 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

SPRNBRK - DUNWODIE_345_W75

Wed 05/12/2021 to Thu 05/13/2021
0001 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

SPRNBRK_345KV_RNS3

Wed 05/12/2021 to Thu 05/13/2021
0001 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

NIAGARA - STA_255_345_NH2

Mon 05/24/2021 to Fri 05/28/2021
0500 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **2350 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 3150 MW

VOLNEY - MARCY 345_19

Tue 06/01/2021 to Wed 06/02/2021
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2825 MW**
Impacts Total Transfer Capability 150 MW
TTC with All Lines In Service 2975 MW

ARR: 19

NYISO TRANSFER LIMITATIONS

Wednesday, January 20, 2021 to Friday, July 22, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

VOLNEY -MARCY 345_19

Tue 06/01/2021 to Wed 06/02/2021
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
OSWEGO EXPORT **4900 MW**
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 5250 MW

FRASER -GILBOA 345_GF5-35

Tue 06/01/2021 to Mon 06/07/2021
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2650 MW**
Impacts Total Transfer Capability 325 MW
TTC with All Lines In Service 2975 MW

MOSES -ADIRNDCK 230_MA2

Tue 06/01/2021 to Sun 11/14/2021
0700 Continuous 1300

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

MARCY -EDIC 345_UE1-7

Thu 06/03/2021 to Fri 06/04/2021
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19&16

FWD
(Import)
OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

PORTER -ROTTRDAM 230_30

Thu 06/03/2021 to Wed 09/15/2021 **UPDATED by NGRID 01/19/2021**
0700 Continuous 0659

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **2805 MW**
Impacts Total Transfer Capability 170 MW
TTC with All Lines In Service 2975 MW

MARCY 345KV_CSC

Sat 06/05/2021 to Sat 06/05/2021
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2925 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

FRASANX-COOPERS 345_UCC2-41

Fri 06/25/2021 to Tue 08/10/2021
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 20, 2021 to Friday, July 22, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY__-FRASANNX_345_UCC2-41			FWD	
Fri 06/25/2021	to	Tue 08/10/2021	(Import)	
0700	Continuous	1530	CENTRAL EAST - VC	2500 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	475 MW
			TTC with All Lines In Service	2975 MW
ARR: 19				
NIAGARA_345_230_AT4			FWD	REV
Mon 07/12/2021	to	Fri 07/23/2021	(Import)	(Export)
0500	Continuous	1700	SCH - OH - NY	1900 MW 1400 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	50 MW 300 MW
			TTC with All Lines In Service	1950 MW 1700 MW
SAND_BAR-PLATSBRG_115_PV20				
Tue 08/03/2021	to	Tue 08/03/2021	SCH - NE - NY	
0700	Continuous	1830	Impacts Total Transfer Capability	
Work scheduled by: NYPA			TTC with All Lines In Service	
FRASANNX-COOPERS__345_UCC2-41			FWD	
Tue 09/07/2021	to	Wed 09/15/2021	(Import)	
0700	Continuous	1730	CENTRAL EAST - VC	2500 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	475 MW
			TTC with All Lines In Service	2975 MW
ARR: 19				
MARCY__-FRASANNX_345_UCC2-41			FWD	
Tue 09/07/2021	to	Wed 09/15/2021	(Import)	
0700	Continuous	1730	CENTRAL EAST - VC	2500 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	475 MW
			TTC with All Lines In Service	2975 MW
ARR: 19				
KINTIGH_-STA_255_345_SH1-39			FWD	
Mon 09/13/2021	to	Fri 09/17/2021	(Import)	
0500	Continuous	1700	DYSINGER EAST	2350 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	3150 MW
NIAGARA_-KINTIGH_345_NS1-38			FWD	
Mon 09/13/2021	to	Fri 09/17/2021	(Import)	
0500	Continuous	1700	DYSINGER EAST	1400 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1750 MW
			TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 20, 2021 to Friday, July 22, 2022

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PORTER__-ROTTRDAM_230_30

Wed 09/15/2021 to Tue 11/30/2021
 0700 Continuous 1730

Work scheduled by: NGrid

FWD

(Import)

CENTRAL EAST - VC **2805 MW**
 Impacts Total Transfer Capability 170 MW
 TTC with All Lines In Service 2975 MW

EDIC___-N.SCTLND_345_14

Thu 09/16/2021 to Sun 11/14/2021
 0700 Continuous 1730

Work scheduled by: NGrid

FWD

(Import)

CENTRAL EAST - VC **2240 MW**
 Impacts Total Transfer Capability 735 MW
 TTC with All Lines In Service 2975 MW

HURLYAVE-ROSETON__345_303

Thu 09/16/2021 to Sun 10/17/2021
 0800 Continuous 1600

Work scheduled by: CHGE

UPDATED by CHGE 09/22/2020

FWD

(Import)

UPNY CONED **4100 MW**
 Impacts Total Transfer Capability 2120 MW
 TTC with All Lines In Service 6220 MW

HOMRC_NY-MAINS_NY_345_47

Sat 09/18/2021 to Fri 11/05/2021
 0800 Continuous 1600

Work scheduled by: PJM

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

PANNELL_-CLAY_____345_1

Mon 09/20/2021 to Fri 09/24/2021
 0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

WEST CENTRAL **1300 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

CLAY___-EDIC_____345_2-15

Mon 09/20/2021 to Sat 10/16/2021
 0700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

OSWEGO EXPORT **4850 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 5250 MW

PANNELL_-CLAY_____345_2

Mon 09/27/2021 to Fri 10/01/2021
 0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

WEST CENTRAL **1300 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 20, 2021 to Friday, July 22, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_6

Tue 09/28/2021 to Tue 09/28/2021
 0100 Continuous 0130
 Work scheduled by: ConEd

UPDATED by CONED 01/15/2021

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

E13THSTA-FARRAGUT_345_46

Tue 09/28/2021 to Tue 10/26/2021
 0100 Continuous 0300
 Work scheduled by: ConEd

UPDATED by CONED 01/15/2021

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

W49TH_ST-E13THSTA_345_M55

Tue 09/28/2021 to Tue 10/26/2021
 0100 Continuous 0300
 Work scheduled by: ConEd

UPDATED by CONED 01/15/2021

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

LEEDS__-HURLYAVE_345_301

Mon 10/18/2021 to Fri 11/19/2021
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4100 MW**
 Impacts Total Transfer Capability 2120 MW
 TTC with All Lines In Service 6220 MW

GOETHALS_345KV_5

Thu 10/21/2021 to Sat 11/20/2021
 0001 Continuous 0200
 Work scheduled by: ConEd

STATEN ISLAND
 Impacts Total Transfer Capability
 TTC with All Lines In Service

W49TH_ST_345KV_6

Tue 10/26/2021 to Tue 10/26/2021
 0230 Continuous 0300
 Work scheduled by: ConEd

UPDATED by CONED 01/15/2021

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

MOTTHAVN-RAINEY__345_Q11

Wed 10/27/2021 to Wed 12/01/2021
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 20, 2021 to Friday, July 22, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO-NYISO_LIMIT_1750						FWD
Mon 11/01/2021	to	Fri 12/31/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Import)
0001	Continuous	2359				2050 MW
Work scheduled by: IESO						Impacts Total Transfer Capability 250 MW
						TTC with All Lines In Service 2300 MW
SCH-NYISO-IMO_LIMIT_1600						REV
Mon 11/01/2021	to	Fri 12/31/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Export)
0001	Continuous	2359				1900 MW
Work scheduled by: IESO						Impacts Total Transfer Capability 100 MW
						TTC with All Lines In Service 2000 MW
W49TH_ST_345KV_6						FWD
Mon 11/15/2021	to	Sat 01/15/2022				(Import)
0001	Continuous	0300				300 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 360 MW
						TTC with All Lines In Service 660 MW
W49TH_ST_345KV_8						FWD
Mon 11/15/2021	to	Sat 01/15/2022				(Import)
0001	Continuous	0300				300 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 360 MW
						TTC with All Lines In Service 660 MW
CHATGUAY-MASSENA__765_7040						FWD
Mon 11/15/2021	to	Tue 11/30/2021				(Import)
0100	Continuous	1859				1550 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 1600 MW
						TTC with All Lines In Service 3150 MW
CHATGUAY-MASSENA__765_7040						FWD
Mon 11/15/2021	to	Tue 11/30/2021				(Import) (Export)
0100	Continuous	1859				0 MW 0 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 1500 MW 1000 MW
						TTC with All Lines In Service 1500 MW 1000 MW
MARCY__765_345_AT1						FWD
Mon 11/15/2021	to	Tue 11/30/2021				(Import)
0100	Continuous	1859				1750 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 1400 MW
						TTC with All Lines In Service 3150 MW

ARR: 19

NYISO TRANSFER LIMITATIONS

Wednesday, January 20, 2021 to Friday, July 22, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT2			FWD
Mon 11/15/2021	to	Tue 11/30/2021	(Import)
0100	Continuous	1859	MOSES SOUTH 1700 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 1450 MW
			TTC with All Lines In Service 3150 MW
MASSENA_-MARCY___765_MSU1			FWD
Mon 11/15/2021	to	Tue 11/30/2021	(Import)
0100	Continuous	1859	CENTRAL EAST - VC 2265 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 710 MW
			TTC with All Lines In Service 2975 MW
MASSENA_-MARCY___765_MSU1			FWD
Mon 11/15/2021	to	Tue 11/30/2021	(Import)
0100	Continuous	1859	MOSES SOUTH 500 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 2650 MW
			TTC with All Lines In Service 3150 MW
MASSENA_-MARCY___765_MSU1			FWD REV
Mon 11/15/2021	to	Tue 11/30/2021	(Import) (Export)
0100	Continuous	1859	SCH - HQ - NY 475 MW 1000 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 1025 MW 0 MW
			TTC with All Lines In Service 1500 MW 1000 MW
MASSENA_-MARCY___765_MSU1			FWD
Mon 11/15/2021	to	Tue 11/30/2021	(Import)
0100	Continuous	1859	SCH - HQ_CEDARS 90 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 109 MW
			TTC with All Lines In Service 199 MW
MASSENA_-MARCY___765_MSU1 & CHATGUAY-MASSENA_765_7040			FWD
Mon 11/15/2021	to	Tue 11/30/2021	(Import)
0100		1859	MOSES SOUTH 500 MW
Work scheduled by:			Impacts Total Transfer Capability 2650 MW
			TTC with All Lines In Service 3150 MW
MOSES___-MASSENA_230_MMS1 & MOSES___-MASSENA_230_MMS2			FWD REV
Mon 11/15/2021	to	Tue 11/30/2021	(Import) (Export)
0100		1859	SCH - HQ - NY 850 MW 0 MW
Work scheduled by:			Impacts Total Transfer Capability 650 MW 1000 MW
			TTC with All Lines In Service 1500 MW 1000 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 20, 2021 to Friday, July 22, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2

Mon 11/15/2021 to Tue 11/30/2021
 0100 1859

Work scheduled by:

FWD
 (Import)
 SCH - HQ_CEDARS **90 MW**
 Impacts Total Transfer Capability 109 MW
 TTC with All Lines In Service 199 MW

STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1

Mon 11/15/2021 to Tue 11/30/2021
 0100 1859

Work scheduled by:

FWD
 (Import)
 SCH - HQ_CEDARS **90 MW**
 Impacts Total Transfer Capability 109 MW
 TTC with All Lines In Service 199 MW

STLAWRNC-MOSES 230_L33P & MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2

Mon 11/15/2021 to Tue 11/30/2021
 0100 1859

Work scheduled by:

FWD
 (Import)
 SCH - HQ_CEDARS **90 MW**
 Impacts Total Transfer Capability 109 MW
 TTC with All Lines In Service 199 MW

FRASER 345_FRASER SVC

Wed 12/01/2021 to Mon 02/28/2022
 0700 Continuous 1730

Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2935 MW**
 Impacts Total Transfer Capability 40 MW
 TTC with All Lines In Service 2975 MW

MOSES -ADIRNDCK 230_MA1

Wed 12/01/2021 to Tue 05/31/2022
 0700 Continuous 1300

Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MOTTHAVN-RAINEY 345_Q12

Thu 12/02/2021 to Wed 12/22/2021
 0201 Continuous 0200

Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

N. SCTLND-ALPS 345_2

Mon 05/02/2022 to Mon 05/09/2022
 0600 Daily 1800

Work scheduled by: NGrid

FWD
 (Import)
 SCH - NE - NY **750 MW**
 Impacts Total Transfer Capability 650 MW
 TTC with All Lines In Service 1400 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 20, 2021 to Friday, July 22, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

N. SCTLND-ALPS_____345_2

Mon 05/02/2022 to Mon 05/09/2022
0600 Daily 1800

Work scheduled by: NGrid

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

HOMRC_NY-MAINS_NY_345_47

Fri 05/20/2022 to Fri 05/27/2022 UPDATED by PJM 11/19/2020
0800 Continuous 1600

Work scheduled by: PJM

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

HOMR_NYW-PIERC_NY_345_48

Fri 05/20/2022 to Fri 05/27/2022 UPDATED by PJM 11/19/2020
0800 Continuous 1600

Work scheduled by: PJM

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

MOSES____-ADIRNDCK_230_MA2

Wed 06/01/2022 to Mon 11/14/2022
0700 Continuous 1300

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2100 MW
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	3150 MW