

NYISO TRANSFER LIMITATIONS

Monday ,April 12, 2021 to Wednesday,October 12, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Wed 06/30/2021 **EXT FORCE by CONED 08/28/2020**
 0001 Continuous 2359
 Work scheduled by: ConEd

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Wed 06/30/2021
 0001 2359
 Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2550 MW	1900 MW
Impacts Total Transfer Capability	250 MW	50 MW
TTC with All Lines In Service	2800 MW	1950 MW

MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Wed 06/30/2021 **EXT FORCE by CONED 08/28/2020**
 0001 Continuous 2359
 Work scheduled by: ConEd

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

STLAWRNC-MOSES_230_L33P

Mon 04/30/2018 to Mon 10/31/2022 **EXT FORCE by IESO 10/01/2020**
 0456 Continuous 1600
 Work scheduled by: IESO

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

NEWBRDGE_345_138_BK_1

Wed 09/02/2020 to Tue 02/01/2022 **EXT FORCE by LI 01/12/2021**
 1807 Continuous 2359
 Work scheduled by: LI

	FWD
	(Import)
SCH - PJM_NEPTUNE	375 MW
Impacts Total Transfer Capability	285 MW
TTC with All Lines In Service	660 MW

SPRNBK_-EGRDNCTR_345_Y49

Thu 10/01/2020 to Mon 04/19/2021 **EXT FORCE by LI 02/23/2021**
 0404 Continuous 2359
 Work scheduled by: LI

	FWD
	(Import)
CONED - LIPA	775 MW
Impacts Total Transfer Capability	725 MW
TTC with All Lines In Service	1500 MW

EGRDNCTY_345_138_AT2

Sat 10/10/2020 to Mon 04/19/2021 **EXT FORCE by LI 02/23/2021**
 1815 Continuous 2359
 Work scheduled by: LI

	FWD
	(Import)
CONED - LIPA	1250 MW
Impacts Total Transfer Capability	250 MW
TTC with All Lines In Service	1500 MW

NYISO TRANSFER LIMITATIONS

Monday ,April 12, 2021 to Wednesday,October 12, 2022

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					
EGRDNCTY_345_138_AT1					FWD
Sat 10/10/2020	to	Mon 04/19/2021	<u>EXT FORCE</u>	<u>by LI</u>	<u>02/23/2021</u>
1856	Continuous	2359			
Work scheduled by: LI					
					(Import)
					CONED - LIPA 1250 MW
					Impacts Total Transfer Capability 250 MW
					TTC with All Lines In Service 1500 MW
<hr/>					
SCH-IMO-NYISO_LIMIT_1750					FWD
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>
0001	Continuous	2359			
Work scheduled by: IESO					
					(Import)
					SCH - OH - NY 2050 MW
					Impacts Total Transfer Capability 250 MW
					TTC with All Lines In Service 2300 MW
<hr/>					
SCH-NYISO-IMO_LIMIT_1600					REV
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>
0001	Continuous	2359			
Work scheduled by: IESO					
					(Export)
					SCH - OH - NY 1900 MW
					Impacts Total Transfer Capability 100 MW
					TTC with All Lines In Service 2000 MW
<hr/>					
SAND_BAR-PLATSBRG_115_PV20					
Tue 02/23/2021	to	Mon 05/17/2021	<u>UPDATED</u>	<u>by NYISO</u>	<u>03/16/2021</u>
1801	Continuous	0559			
Work scheduled by: ISONE					
					SCH - NE - NY
					Impacts Total Transfer Capability
					TTC with All Lines In Service
<hr/>					
W49TH_ST_345KV_8					FWD
Tue 03/02/2021	to	Sun 05/02/2021	<u>EXTENDED</u>	<u>by CONED</u>	<u>04/10/2021</u>
0201	Continuous	0200			
Work scheduled by: ConEd					
					(Import)
					SCH - PJM_HTP 300 MW
					Impacts Total Transfer Capability 360 MW
					TTC with All Lines In Service 660 MW
<hr/>					
PORTER__-ROTTRDAM_230_31					FWD
Tue 03/02/2021	to	Mon 05/31/2021	<u>UPDATED</u>	<u>by NGRID</u>	<u>03/10/2021</u>
0600	Continuous	1730			
Work scheduled by: NGrid					
					(Import)
					CENTRAL EAST - VC 2805 MW
					Impacts Total Transfer Capability 170 MW
					TTC with All Lines In Service 2975 MW
<hr/>					
MOSES__-ADIRNDCK_230_MAL					FWD
Tue 03/02/2021	to	Mon 05/10/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>02/11/2021</u>
0700	Continuous	1159			
Work scheduled by: NYPA					
					(Import)
					MOSES SOUTH 2300 MW
					Impacts Total Transfer Capability 850 MW
					TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Monday ,April 12, 2021 to Wednesday,October 12, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LADENTWN-BUCHAN_S_345_Y88

Tue 03/09/2021 to Fri 04/09/2021
0001 Continuous 0200

EXTENDED by CE 04/02/2021

Work scheduled by: ConEd

FWD
(Import)
5930 MW
UPNY CONED
Impacts Total Transfer Capability 290 MW
TTC with All Lines In Service 6220 MW

SCH-NYISO-HQ_CEDARS_LIMIT_0

Mon 03/15/2021 to Thu 04/08/2021
0500 Continuous 2000

UPDATED by HQ 04/08/2021

Work scheduled by: HQ

REV
(Export)
0 MW
SCH - HQ_CEDARS
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 100 MW

W49TH_ST_345KV_6

Sun 03/21/2021 to Sun 05/02/2021
0001 Continuous 0200

EXTENDED by CONED 04/10/2021

Work scheduled by: ConEd

FWD
(Import)
300 MW
SCH - PJM_HTP
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

EDIC__-N.SCTLND_345_14 & PORTER__-ROTTRDAM_230_31

Mon 03/22/2021 to Mon 05/31/2021
0600 1730

Work scheduled by:

FWD
(Import)
1500 MW
CENTRAL EAST - VC
Impacts Total Transfer Capability 1475 MW
TTC with All Lines In Service 2975 MW

EDIC__-N.SCTLND_345_14

Mon 03/22/2021 to Mon 05/31/2021
0600 Continuous 1830

UPDATED by NGRID 03/10/2021

Work scheduled by: NGrid

FWD
(Import)
1670 MW
CENTRAL EAST - VC
Impacts Total Transfer Capability 1305 MW
TTC with All Lines In Service 2975 MW

S.RIPLEY-DUNKIRK_230_68

Mon 03/29/2021 to Fri 04/09/2021
1129 Continuous 1700

UPDATED by NYISO 03/30/2021

Work scheduled by: NGrid

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

ROCHESTR-PANNELL_345_RP2

Wed 03/31/2021 to Sat 04/10/2021
0500 Continuous 2016

Work scheduled by: NYPA

FWD
(Import)
2300 MW
DYSINGER EAST
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Monday ,April 12, 2021 to Wednesday,October 12, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Line ID	Start Date	End Date	Time	Duration	Work Scheduling	Transfer Direction	Value
LINDN_CG-LNDVFT_345_V-3022	Sun 04/04/2021	Sat 04/10/2021	1400	Continuous	1400	SCH - PJM_VFT	0 MW
						Impacts Total Transfer Capability	315 MW
						TTC with All Lines In Service	315 MW
WATRCURE-OAKDALE_345_31	Mon 04/05/2021	Thu 04/08/2021	0800	Daily(No Weekends)	1500	SCH - PJ - NY	
						Impacts Total Transfer Capability	
						TTC with All Lines In Service	
NINEMILE-CLAY_345_8	Tue 04/06/2021	Sun 04/11/2021	1600	Daily	0500	OSWEGO EXPORT	5150 MW
						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	5250 MW
N.SCTLND-LEEDS_345_93	Wed 04/07/2021	Wed 04/07/2021	0700	Daily(No Weekends)	1600	CENTRAL EAST - VC	2650 MW
						Impacts Total Transfer Capability	325 MW
						TTC with All Lines In Service	2975 MW
DUNWODIE_345KV_3	Wed 04/07/2021	Wed 04/07/2021	2230	Continuous	2300	SPR/DUN-SOUTH	3800 MW
						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_4	Wed 04/07/2021	Wed 04/07/2021	2230	Continuous	2300	SPR/DUN-SOUTH	3800 MW
						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
PLSNTVLE-DUNWODIE_345_W89	Wed 04/07/2021	Wed 04/07/2021	2230	Continuous	2300	UPNY CONED	4000 MW
						Impacts Total Transfer Capability	2220 MW
						TTC with All Lines In Service	6220 MW

NYISO TRANSFER LIMITATIONS

Monday ,April 12, 2021 to Wednesday,October 12, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>LEEDS___345KV_R94301</p> <p>Thu 04/08/2021 to Thu 04/08/2021 0700 Daily(No Weekends) 0800</p> <p>Work scheduled by: NGrid</p>	<p>FWD (Import)</p> <p>UPNY CONED 3800 MW</p> <p>Impacts Total Transfer Capability 2420 MW</p> <p>TTC with All Lines In Service 6220 MW</p>
<p>N. SCTLND-LEEDS___345_94</p> <p>Thu 04/08/2021 to Thu 04/08/2021 0700 Daily(No Weekends) 1600</p> <p>Work scheduled by: NGrid</p>	<p>FWD (Import)</p> <p>CENTRAL EAST - VC 2650 MW</p> <p>Impacts Total Transfer Capability 325 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p>MARCY___345KV_CSC</p> <p>Thu 04/08/2021 to Thu 04/08/2021 0700 Continuous 1830</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import)</p> <p>CENTRAL EAST - VC 2925 MW</p> <p>Impacts Total Transfer Capability 50 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p>LEEDS___345KV_R94301</p> <p>Thu 04/08/2021 to Thu 04/08/2021 1500 Daily(No Weekends) 1600</p> <p>Work scheduled by: NGrid</p>	<p>FWD (Import)</p> <p>UPNY CONED 3800 MW</p> <p>Impacts Total Transfer Capability 2420 MW</p> <p>TTC with All Lines In Service 6220 MW</p>
<p>MOTTHAVN-RAINEY___345_Q11</p> <p>Thu 04/08/2021 to Mon 04/12/2021 2309 Continuous 2359</p> <p>Work scheduled by: ConEd</p>	<p>FWD (Import)</p> <p>EXT FORCE by CONED 04/11/2021</p> <p>SPR/DUN-SOUTH 3800 MW</p> <p>Impacts Total Transfer Capability 800 MW</p> <p>TTC with All Lines In Service 4600 MW</p>
<p>CHAT_DC_GC1</p> <p>Sat 04/10/2021 to Sat 04/10/2021 0600 Continuous 1600</p> <p>Work scheduled by: HQ</p>	<p>FWD (Import)</p> <p>MOSES SOUTH 2850 MW</p> <p>Impacts Total Transfer Capability 300 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>CHAT_DC_GC1</p> <p>Sat 04/10/2021 to Sat 04/10/2021 0600 Continuous 1600</p> <p>Work scheduled by: HQ</p>	<p>REV (Export)</p> <p>SCH - HQ - NY 500 MW</p> <p>Impacts Total Transfer Capability 500 MW</p> <p>TTC with All Lines In Service 1000 MW</p>

NYISO TRANSFER LIMITATIONS

Monday ,April 12, 2021 to Wednesday,October 12, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

S.RIPLEY-DUNKIRK__230_68

Mon 04/12/2021 to Fri 04/23/2021 **UPDATED** by **NGRID** **04/12/2021**
 0630 Continuous 1700
 Work scheduled by: NGrid
 SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

LEEDS__345KV_R94301

Mon 04/12/2021 to Mon 04/12/2021 **UPDATED** by **NGRID** **02/01/2021**
 0800 Continuous 0830
 Work scheduled by: CHGE
 FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 2420 MW
 TTC with All Lines In Service 6220 MW

LEEDS__-HURLYAVE_345_301

Mon 04/12/2021 to Fri 04/16/2021 **UPDATED** by **NGRID** **02/01/2021**
 0800 Continuous 1600
 Work scheduled by: CHGE
 FWD
 (Import)
 UPNY CONED **4100 MW**
 Impacts Total Transfer Capability 2120 MW
 TTC with All Lines In Service 6220 MW

NIAGARA_-STA_255__345_NH2

Fri 04/16/2021 to Fri 04/16/2021 **CANCELLED** by **NYPA** **04/08/2021**
 0500 Continuous 1700
 Work scheduled by: NYPA
 FWD
 (Import)
 DYSINGER EAST **2350 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 3150 MW

LEEDS__345KV_R94301

Fri 04/16/2021 to Fri 04/16/2021 **UPDATED** by **NGRID** **02/01/2021**
 1530 Continuous 1600
 Work scheduled by: CHGE
 FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 2420 MW
 TTC with All Lines In Service 6220 MW

DUNWODIE_345KV_6

Tue 04/20/2021 to Tue 04/20/2021 **UPDATED** by **CONED** **02/19/2021**
 0201 Continuous 0230
 Work scheduled by: ConEd
 FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_8

Tue 04/20/2021 to Tue 04/20/2021 **UPDATED** by **CONED** **02/19/2021**
 0201 Continuous 0230
 Work scheduled by: ConEd
 FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Monday ,April 12, 2021 to Wednesday,October 12, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

WOOD_ST_-PLSNTVLE_345_Y87

Tue 04/20/2021 to Tue 04/20/2021
0201 Continuous 0230

UPDATED by CONED 02/19/2021

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **5905 MW**
Impacts Total Transfer Capability 315 MW
TTC with All Lines In Service 6220 MW

PLSNTVLE-DUNWODIE_345_W90

Tue 04/20/2021 to Fri 04/23/2021
0201 Continuous 0159

UPDATED by CONED 02/19/2021

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4000 MW**
Impacts Total Transfer Capability 2220 MW
TTC with All Lines In Service 6220 MW

MAINESBG-WATRCURE_345_30

Tue 04/20/2021 to Wed 04/21/2021
0800 Continuous 1530

Work scheduled by: NYSEG

FWD
(Import)
SCH - PJ - NY **2300 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 2800 MW

DUNWODIE_345KV_6

Fri 04/23/2021 to Fri 04/23/2021
0130 Continuous 0159

UPDATED by CONED 02/19/2021

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_8

Fri 04/23/2021 to Fri 04/23/2021
0130 Continuous 0159

UPDATED by CONED 02/19/2021

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

WOOD_ST_-PLSNTVLE_345_Y87

Fri 04/23/2021 to Fri 04/23/2021
0130 Continuous 0159

UPDATED by CONED 02/19/2021

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **5905 MW**
Impacts Total Transfer Capability 315 MW
TTC with All Lines In Service 6220 MW

PLSNTVLY-WOOD_ST__345_F30

Fri 04/23/2021 to Fri 04/23/2021
0201 Continuous 0230

UPDATED by CONED 04/02/2021

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4000 MW**
Impacts Total Transfer Capability 2220 MW
TTC with All Lines In Service 6220 MW

NYISO TRANSFER LIMITATIONS

Monday ,April 12, 2021 to Wednesday,October 12, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RNS5					FWD	
Fri 04/23/2021	to	Fri 04/23/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>04/02/2021</u>	(Import)
0201	Continuous	0230				3800 MW
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	2420 MW
					TTC with All Lines In Service	6220 MW
MILLWOOD-EASTVIEW_345_W82					FWD	
Fri 04/23/2021	to	Fri 04/23/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>04/02/2021</u>	(Import)
0201	Continuous	1800				5985 MW
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	235 MW
					TTC with All Lines In Service	6220 MW
MILLWOOD_345KV_18					FWD	
Fri 04/23/2021	to	Sat 04/24/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>04/02/2021</u>	(Import)
0201	Continuous	2200				4350 MW
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	1870 MW
					TTC with All Lines In Service	6220 MW
CHAT_DC_GC1					FWD	
Sat 04/24/2021	to	Sun 04/25/2021				(Import)
2000	Continuous	0500				2850 MW
Work scheduled by: HQ					MOSES SOUTH	
					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW
CHAT_DC_GC1					REV	
Sat 04/24/2021	to	Sun 04/25/2021				(Export)
2000	Continuous	0500				500 MW
Work scheduled by: HQ					SCH - HQ - NY	
					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1000 MW
PLSNTVLY-WOOD_ST_345_F30					FWD	
Mon 04/26/2021	to	Tue 04/27/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>04/02/2021</u>	(Import)
0001	Continuous	0200				4000 MW
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	2220 MW
					TTC with All Lines In Service	6220 MW
PLSNTVLY_345KV_RNS5					FWD	
Mon 04/26/2021	to	Tue 04/27/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>04/02/2021</u>	(Import)
0001	Continuous	0200				3800 MW
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	2420 MW
					TTC with All Lines In Service	6220 MW

NYISO TRANSFER LIMITATIONS

Monday ,April 12, 2021 to Wednesday,October 12, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

KINTIGH_-STA_255__345_SH1-39

Mon 04/26/2021 to Fri 04/30/2021
0700 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **2350 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 3150 MW

NIAGARA_-KINTIGH__345_NS1-38

Mon 04/26/2021 to Fri 04/30/2021
0700 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

HOMRC_NY-MAINS_NY_345_47

Mon 04/26/2021 to Sat 05/29/2021 **EXTENDED by NYSEG 03/10/2021**
0800 Continuous 1900

Work scheduled by: NYSEG

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FRASER_-COOPERS__345_33

Mon 04/26/2021 to Fri 04/30/2021
0830 Continuous 1500

Work scheduled by: NYSEG

FWD

(Import)

CENTRAL EAST - VC **2395 MW**
Impacts Total Transfer Capability 580 MW
TTC with All Lines In Service 2975 MW

ALCOA_PA_115KV_R8105

Tue 04/27/2021 to Thu 04/29/2021
0630 Continuous 1830

Work scheduled by: NGrid

FWD

(Import)

MOSES SOUTH **3100 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 3150 MW

MOTTHAVN-RAINEY__345_Q11

Wed 04/28/2021 to Sat 05/08/2021
0001 Continuous 0200

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

W49TH_ST_345KV_5

Fri 04/30/2021 to Fri 04/30/2021
0201 Continuous 0231

Work scheduled by: ConEd

FWD

(Import)

SCH - PJM_HTP **300 MW**
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Monday ,April 12, 2021 to Wednesday,October 12, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_7

Fri 04/30/2021 to Fri 04/30/2021
0201 Continuous 0231

Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **300 MW**
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

BUCHAN_N-EASTVIEW_345_W93

Fri 04/30/2021 to Sun 05/09/2021 **UPDATED by CONED 04/07/2021**
0700 Continuous 2359

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1870 MW
TTC with All Lines In Service 6220 MW

SCH-IMO-NYISO_LIMIT_1600

Sat 05/01/2021 to Sun 10/31/2021 **UPDATED by IESO 05/03/2019**
0001 Continuous 2359

Work scheduled by: IESO

FWD
(Import)
SCH - OH - NY **1900 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 1950 MW

NRTH1385-NOR HBR__138_601

Mon 05/03/2021 to Mon 05/24/2021
0600 Continuous 2359

Work scheduled by: LI

FWD REV
(Import) (Export)
SCH - NPX_1385 **100 MW 100 MW**
Impacts Total Transfer Capability 100 MW 100 MW
TTC with All Lines In Service 200 MW 200 MW

NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_602

Mon 05/03/2021 to Mon 05/24/2021
0600 2359

Work scheduled by:

FWD REV
(Import) (Export)
SCH - NPX_1385 **0 MW 0 MW**
Impacts Total Transfer Capability 200 MW 200 MW
TTC with All Lines In Service 200 MW 200 MW

NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_603

Mon 05/03/2021 to Mon 05/24/2021
0600 2359

Work scheduled by:

FWD REV
(Import) (Export)
SCH - NPX_1385 **0 MW 0 MW**
Impacts Total Transfer Capability 200 MW 200 MW
TTC with All Lines In Service 200 MW 200 MW

NRTH1385-NOR HBR__138_602

Mon 05/03/2021 to Mon 05/24/2021
0600 Continuous 2359

Work scheduled by: LI

FWD REV
(Import) (Export)
SCH - NPX_1385 **100 MW 100 MW**
Impacts Total Transfer Capability 100 MW 100 MW
TTC with All Lines In Service 200 MW 200 MW

NYISO TRANSFER LIMITATIONS

Monday ,April 12, 2021 to Wednesday,October 12, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NOR HBR__138_602 & NRTH1385-NOR HBR__138_603

Mon 05/03/2021 to Mon 05/24/2021
 0600 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

NRTH1385-NOR HBR__138_603

Mon 05/03/2021 to Mon 05/24/2021
 0600 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

NRTH1385-NRTHPORT_138_NNC

Mon 05/03/2021 to Mon 05/24/2021
 0600 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

CLAY__-EDIC__345_2-15

Mon 05/03/2021 to Fri 05/07/2021
 0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
OSWEGO EXPORT	4850 MW
Impacts Total Transfer Capability	400 MW
TTC with All Lines In Service	5250 MW

FIVEMILE-STOLLERD_345_29

Mon 05/03/2021 to Fri 05/14/2021
 0700 Continuous 1400

Work scheduled by: NYSEG

SCH - PJ - NY	
Impacts Total Transfer Capability	
TTC with All Lines In Service	

PANNELL_-CLAY__345_2

Mon 05/03/2021 to Sun 05/30/2021
 0700 Continuous 1730

Work scheduled by: NYPA

	FWD
	(Import)
WEST CENTRAL	1300 MW
Impacts Total Transfer Capability	950 MW
TTC with All Lines In Service	2250 MW

HURLYAVE-ROSETON__345_303

Mon 05/03/2021 to Fri 05/21/2021
 0800 Continuous 1600

Work scheduled by: CHGE

	FWD
	(Import)
UPNY CONED	4100 MW
Impacts Total Transfer Capability	2120 MW
TTC with All Lines In Service	6220 MW

NYISO TRANSFER LIMITATIONS

Monday ,April 12, 2021 to Wednesday,October 12, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
SHOR_NPX-SHOREHAM_138_CSC						
Mon 05/03/2021	to	Sat 05/08/2021	<u>EXTENDED</u>	<u>by ISONE 03/15/2021</u>		
0900	Continuous	1600			SCH - NPX_CSC	0 MW
Work scheduled by: LI					Impacts Total Transfer Capability	330 MW
					TTC with All Lines In Service	330 MW
ROTTRDAM-EASTOVER_230_38						REV
Tue 05/04/2021	to	Tue 05/04/2021			SCH - NE - NY	1400 MW
0830	Daily(No Weekends)	1130			Impacts Total Transfer Capability	200 MW
Work scheduled by: NGrid					TTC with All Lines In Service	1600 MW
RAMAPO__-BUCHAN_N_345_Y94						FWD
Fri 05/07/2021	to	Sun 05/09/2021	<u>UPDATED</u>	<u>by CONED 04/07/2021</u>		(Import)
0001	Continuous	2359			UPNY CONED	5765 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	455 MW
					TTC with All Lines In Service	6220 MW
W49TH_ST_345KV_5						FWD
Fri 05/07/2021	to	Fri 05/07/2021				(Import)
0130	Continuous	0200			SCH - PJM_HTP	300 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	360 MW
					TTC with All Lines In Service	660 MW
W49TH_ST_345KV_7						FWD
Fri 05/07/2021	to	Fri 05/07/2021				(Import)
0130	Continuous	0200			SCH - PJM_HTP	300 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	360 MW
					TTC with All Lines In Service	660 MW
EASTVIEW-SPRNBK__345_W79						FWD
Sat 05/08/2021	to	Sun 05/09/2021	<u>UPDATED</u>	<u>by CONED 04/07/2021</u>		(Import)
0700	Continuous	2359			UPNY CONED	4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1870 MW
					TTC with All Lines In Service	6220 MW
W49TH_ST_345KV_7						FWD
Mon 05/10/2021	to	Mon 05/10/2021				(Import)
0001	Continuous	0030			SCH - PJM_HTP	300 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	360 MW
					TTC with All Lines In Service	660 MW

NYISO TRANSFER LIMITATIONS

Monday ,April 12, 2021 to Wednesday,October 12, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_8

Mon 05/10/2021 to Mon 05/10/2021
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **450 MW**
 Impacts Total Transfer Capability 210 MW
 TTC with All Lines In Service 660 MW

HUDSONTP-W49TH_ST_345_Y56

Mon 05/10/2021 to Thu 05/13/2021
 0001 Continuous 2300
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

SPRNBK_-TREMONT_345_X28

Mon 05/10/2021 to Wed 05/26/2021 **UPDATED by CONED 03/18/2021**
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **4200 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 4600 MW

CLAY_-EDIC_345_1-16

Mon 05/10/2021 to Fri 05/14/2021
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 OSWEGO EXPORT **4850 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 5250 MW

MOSES_-ADIRNDCK_230_MA2

Mon 05/10/2021 to Tue 06/01/2021
 1200 Continuous 0659
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2100 MW**
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW

W49TH_ST_345KV_7

Thu 05/13/2021 to Thu 05/13/2021
 2230 Continuous 2300
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

W49TH_ST_345KV_8

Thu 05/13/2021 to Thu 05/13/2021
 2230 Continuous 2300
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **450 MW**
 Impacts Total Transfer Capability 210 MW
 TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Monday ,April 12, 2021 to Wednesday,October 12, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CRICKVLY-PLSNTVLY_345_F83	FWD	REV
Fri 05/14/2021 to Fri 05/14/2021	(Import)	(Export)
0001 Continuous 2200	SCH - NE - NY 350 MW	
Work scheduled by: ConEd	Impacts Total Transfer Capability 1050 MW	
	TTC with All Lines In Service 1400 MW	
CRICKVLY-PLSNTVLY_345_F83	FWD	REV
Fri 05/14/2021 to Fri 05/14/2021	(Import)	(Export)
0001 Continuous 2200	SCH - NPX_1385 100 MW	100 MW
Work scheduled by: ConEd	Impacts Total Transfer Capability 100 MW	100 MW
	TTC with All Lines In Service 200 MW	200 MW
NRTH1385-NOR HBR_138_601 & CRICKVLY-PLSNTVLY_345_F83	FWD	REV
Fri 05/14/2021 to Fri 05/14/2021	(Import)	(Export)
0001 2200	SCH - NPX_1385 0 MW	0 MW
Work scheduled by:	Impacts Total Transfer Capability 200 MW	200 MW
	TTC with All Lines In Service 200 MW	200 MW
NRTH1385-NOR HBR_138_602 & CRICKVLY-PLSNTVLY_345_F83	FWD	REV
Fri 05/14/2021 to Fri 05/14/2021	(Import)	(Export)
0001 2200	SCH - NPX_1385 0 MW	0 MW
Work scheduled by:	Impacts Total Transfer Capability 200 MW	200 MW
	TTC with All Lines In Service 200 MW	200 MW
NRTH1385-NOR HBR_138_603 & CRICKVLY-PLSNTVLY_345_F83	FWD	REV
Fri 05/14/2021 to Fri 05/14/2021	(Import)	(Export)
0001 2200	SCH - NPX_1385 0 MW	0 MW
Work scheduled by:	Impacts Total Transfer Capability 200 MW	200 MW
	TTC with All Lines In Service 200 MW	200 MW
BUCHAN_N-EASTVIEW_345_W93	FWD	
Fri 05/14/2021 to Sat 05/15/2021	(Import)	
0001 Continuous 0200	UPNY CONED 4350 MW	
Work scheduled by: ConEd	Impacts Total Transfer Capability 1870 MW	
	TTC with All Lines In Service 6220 MW	
RAMAPO_-BUCHAN_N_345_Y94	FWD	
Fri 05/14/2021 to Sat 05/15/2021	(Import)	
0001 Continuous 0200	UPNY CONED 5765 MW	
Work scheduled by: ConEd	Impacts Total Transfer Capability 455 MW	
	TTC with All Lines In Service 6220 MW	

NYISO TRANSFER LIMITATIONS

Monday ,April 12, 2021 to Wednesday,October 12, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK__345KV_RS3 & SPRNBK__345KV_RS4
 Sat 05/15/2021 to Sat 05/15/2021
 0301 2230

Work scheduled by:

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_5
 Mon 05/17/2021 to Tue 05/18/2021
 0201 Continuous 0200

Work scheduled by: ConEd

UPDATED by CE 03/15/2021

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_7
 Mon 05/17/2021 to Tue 05/18/2021
 0201 Continuous 0200

Work scheduled by: ConEd

UPDATED by CE 03/15/2021

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

SPRNBK_-DUNWODIE_345_W75
 Mon 05/17/2021 to Tue 05/18/2021
 0201 Continuous 0200

Work scheduled by: ConEd

UPDATED by CE 03/15/2021

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

SPRNBK__345KV_RNS3
 Mon 05/17/2021 to Tue 05/18/2021
 0201 Continuous 0200

Work scheduled by: ConEd

UPDATED by CE 03/15/2021

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

NIAGARA_-STA_255_345_NH2
 Mon 05/17/2021 to Fri 05/21/2021
 0500 Continuous 1700

Work scheduled by: NYPA

UPDATED by NYPA 03/23/2021

FWD
 (Import)
 DYSINGER EAST **2350 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 3150 MW

SAND_BAR-PLATSBRG_115_PV20
 Mon 05/17/2021 to Fri 07/02/2021
 0600 Continuous 1800

Work scheduled by: ISONE

SCH - NE - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Monday ,April 12, 2021 to Wednesday,October 12, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

GOETHALS_345KV_5

Wed 05/19/2021 to Mon 05/24/2021 **EXTENDED** by **CE** 04/05/2021
 0100 Continuous 0200
 Work scheduled by: ConEd
 STATEN ISLAND
 Impacts Total Transfer Capability
 TTC with All Lines In Service

LINDEN__-GOETHALS_230_A2253

Wed 05/19/2021 to Mon 05/24/2021 **EXTENDED** by **CE** 04/05/2021
 0100 Continuous 0200
 Work scheduled by: ConEd
 FWD REV
 (Import) (Export)
 SCH - PJ - NY **2050 MW 1150 MW**
 Impacts Total Transfer Capability 150 MW 100 MW
 TTC with All Lines In Service 2200 MW 1250 MW

LINDEN__-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402

Wed 05/19/2021 to Mon 05/24/2021
 0100 0200
 Work scheduled by:
 FWD REV
 (Import) (Export)
 SCH - PJ - NY **2000 MW 1000 MW**
 Impacts Total Transfer Capability 200 MW 250 MW
 TTC with All Lines In Service 2200 MW 1250 MW

LINDEN__-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402 & MARION__-FARRAGUT_345_C3403

Wed 05/19/2021 to Mon 05/24/2021
 0100 0200
 Work scheduled by:
 FWD REV
 (Import) (Export)
 SCH - PJ - NY **2000 MW 1000 MW**
 Impacts Total Transfer Capability 200 MW 250 MW
 TTC with All Lines In Service 2200 MW 1250 MW

LINDEN__-GOETHALS_230_A2253 & MARION__-FARRAGUT_345_C3403

Wed 05/19/2021 to Mon 05/24/2021
 0100 0200
 Work scheduled by:
 FWD REV
 (Import) (Export)
 SCH - PJ - NY **2000 MW 1000 MW**
 Impacts Total Transfer Capability 200 MW 250 MW
 TTC with All Lines In Service 2200 MW 1250 MW

BUCHAN_S-MILLWOOD_345_W97

Thu 05/20/2021 to Sat 05/22/2021
 0001 Continuous 0200
 Work scheduled by: ConEd
 FWD
 (Import)
 UPNY CONED **6135 MW**
 Impacts Total Transfer Capability 85 MW
 TTC with All Lines In Service 6220 MW

W49TH_ST_345KV_6

Thu 05/20/2021 to Sat 05/22/2021 **UPDATED** by **CONED** 03/30/2021
 0001 Continuous 0200
 Work scheduled by: ConEd
 FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Monday ,April 12, 2021 to Wednesday,October 12, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST-E13THSTA_345_M55

Thu 05/20/2021 to Mon 05/24/2021
0001 Continuous 0200

Work scheduled by: ConEd

UPDATED by CONED 03/30/2021

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD
(Import)

E13THSTA-FARRAGUT_345_46

Sat 05/22/2021 to Mon 05/24/2021
0001 Continuous 0200

Work scheduled by: ConEd

UPDATED by CONED 03/30/2021

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD
(Import)

PLSNTVLY-WOOD_ST_345_F31

Mon 05/24/2021 to Tue 05/25/2021
0001 Continuous 0159

Work scheduled by: ConEd

UPNY CONED **4000 MW**
Impacts Total Transfer Capability 2220 MW
TTC with All Lines In Service 6220 MW

FWD
(Import)

PLSNTVLY_345KV_RNS4

Mon 05/24/2021 to Tue 05/25/2021
0001 Continuous 0159

Work scheduled by: ConEd

UPNY CONED **3800 MW**
Impacts Total Transfer Capability 2420 MW
TTC with All Lines In Service 6220 MW

FWD
(Import)

W49TH_ST_345KV_6

Mon 05/24/2021 to Mon 05/24/2021
0130 Continuous 0200

Work scheduled by: ConEd

UPDATED by CONED 03/30/2021

SCH - PJM_HTP **300 MW**
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

FWD
(Import)

ROSETON_-EFISHKIL_345_RFK305

Wed 05/26/2021 to Thu 05/27/2021
0001 Continuous 0200

Work scheduled by: ConEd

UPNY CONED **5990 MW**
Impacts Total Transfer Capability 230 MW
TTC with All Lines In Service 6220 MW

FWD
(Import)

VOLNEY_-MARCY_345_19

Tue 06/01/2021 to Wed 06/02/2021
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC **2825 MW**
Impacts Total Transfer Capability 150 MW
TTC with All Lines In Service 2975 MW

FWD
(Import)

NYISO TRANSFER LIMITATIONS

Monday ,April 12, 2021 to Wednesday,October 12, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

VOLNEY -MARCY 345_19

Tue 06/01/2021 to Wed 06/02/2021
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
OSWEGO EXPORT **4900 MW**
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 5250 MW

FRASER -GILBOA 345_GF5-35

Tue 06/01/2021 to Mon 06/07/2021
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2650 MW**
Impacts Total Transfer Capability 325 MW
TTC with All Lines In Service 2975 MW

MOSES -ADIRNDCK 230_MA2

Tue 06/01/2021 to Sun 11/14/2021
0700 Continuous 1300

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

MARCY -EDIC 345_UE1-7

Thu 06/03/2021 to Fri 06/04/2021
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19&16

FWD
(Import)
OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

PORTER -ROTTRDAM 230_30

Thu 06/03/2021 to Wed 09/15/2021 **UPDATED by NGRID 01/19/2021**
0700 Continuous 0659

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **2805 MW**
Impacts Total Transfer Capability 170 MW
TTC with All Lines In Service 2975 MW

MARCY 345KV_CSC

Sat 06/05/2021 to Sat 06/05/2021
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2925 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

ATHENS -PLSNTVLY 345_91

Tue 06/08/2021 to Wed 06/16/2021
0600 Continuous 2000

Work scheduled by: NGrid

FWD
(Import)
UPNY CONED **3800 MW**
Impacts Total Transfer Capability 2420 MW
TTC with All Lines In Service 6220 MW

NYISO TRANSFER LIMITATIONS

Monday ,April 12, 2021 to Wednesday,October 12, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

GILBOA__-N.SCTLND_345_GNS-1			FWD	
Wed 06/09/2021	to	Wed 06/09/2021	(Import)	
0800	Daily	1200	CENTRAL EAST - VC	2520 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	455 MW
			TTC with All Lines In Service	2975 MW
BECK____-NIAGARA_345_PA301			FWD	REV
Wed 06/16/2021	to	Thu 06/17/2021	(Import)	(Export)
0500	Continuous	2330	SCH - OH - NY	900 MW 800 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1050 MW 900 MW
			TTC with All Lines In Service	1950 MW 1700 MW
LEEDS__-PLSNTVLY_345_92			FWD	
Thu 06/17/2021	to	Thu 06/24/2021	(Import)	
0600	Continuous	2000	UPNY CONED	3800 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	2420 MW
			TTC with All Lines In Service	6220 MW
BECK____-NIAGARA_345_PA301			FWD	REV
Fri 06/25/2021	to	Fri 06/25/2021	(Import)	(Export)
0500	Continuous	1700	SCH - OH - NY	900 MW 800 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1050 MW 900 MW
			TTC with All Lines In Service	1950 MW 1700 MW
FRASANX-COOPERS__345_UCC2-41			FWD	
Fri 06/25/2021	to	Tue 08/10/2021	(Import)	
0700	Continuous	1530	CENTRAL EAST - VC	2500 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	475 MW
			TTC with All Lines In Service	2975 MW
				ARR: 19
MARCY__-FRASANX_345_UCC2-41			FWD	
Fri 06/25/2021	to	Tue 08/10/2021	(Import)	
0700	Continuous	1530	CENTRAL EAST - VC	2500 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	475 MW
			TTC with All Lines In Service	2975 MW
				ARR: 19
BECK____-NIAGARA_345_PA302			FWD	REV
Mon 07/12/2021	to	Fri 07/16/2021	(Import)	(Export)
0500	Continuous	1700	SCH - OH - NY	900 MW 800 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1050 MW 900 MW
			TTC with All Lines In Service	1950 MW 1700 MW

NYISO TRANSFER LIMITATIONS

Monday ,April 12, 2021 to Wednesday,October 12, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA__345_230_AT4

Mon 07/19/2021 to Fri 07/30/2021
0500 Continuous 1700

UPDATED by NYPA 02/19/2021

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	1900 MW	1400 MW
Impacts Total Transfer Capability	50 MW	300 MW
TTC with All Lines In Service	1950 MW	1700 MW

NIAGARA_-STA_255__345_NH2

Mon 07/26/2021 to Fri 07/30/2021
0500 Continuous 1900

UPDATED by NYPA 02/19/2021

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	2350 MW
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	3150 MW

SAND_BAR-PLATSBRG_115_PV20

Tue 08/03/2021 to Tue 08/03/2021
0700 Continuous 1830

Work scheduled by: NYPA

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

KINTIGH_-STA_255__345_SH1-39

Mon 08/09/2021 to Sun 08/15/2021
0500 Continuous 1900

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	2350 MW
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	3150 MW

NIAGARA_-KINTIGH__345_NS1-38

Mon 08/09/2021 to Sun 08/15/2021
0500 Continuous 1900

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	1400 MW
Impacts Total Transfer Capability	1750 MW
TTC with All Lines In Service	3150 MW

KINTIGH_-STA_255__345_SH1-39

Mon 08/16/2021 to Sun 08/22/2021
0500 Continuous 1900

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	2350 MW
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	3150 MW

NIAGARA_-KINTIGH__345_NS1-38

Mon 08/16/2021 to Sun 08/22/2021
0500 Continuous 1900

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	1400 MW
Impacts Total Transfer Capability	1750 MW
TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Monday ,April 12, 2021 to Wednesday,October 12, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-STA_255__345_NH2

Wed 09/01/2021 to Tue 09/21/2021
 0500 Continuous 1900
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **2350 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 3150 MW

FRASANX-COOPERS__345_UCC2-41

Tue 09/07/2021 to Wed 09/15/2021 **UPDATED by NYISO 02/03/2021**
 0700 Continuous 1730
 Work scheduled by: NYPA **ARR: 19**

FWD
 (Import)
 CENTRAL EAST - VC **2500 MW**
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

MARCY_-FRASANX_345_UCC2-41

Tue 09/07/2021 to Wed 09/15/2021 **UPDATED by NYISO 02/03/2021**
 0700 Continuous 1730
 Work scheduled by: NYPA **ARR: 19**

FWD
 (Import)
 CENTRAL EAST - VC **2500 MW**
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

PORTER_-ROTTRDAM_230_30

Wed 09/15/2021 to Tue 11/30/2021
 0700 Continuous 1730
 Work scheduled by: NGrid

FWD
 (Import)
 CENTRAL EAST - VC **2805 MW**
 Impacts Total Transfer Capability 170 MW
 TTC with All Lines In Service 2975 MW

EDIC_-N.SCTLND_345_14

Thu 09/16/2021 to Sun 11/14/2021
 0700 Continuous 1730
 Work scheduled by: NGrid

FWD
 (Import)
 CENTRAL EAST - VC **1670 MW**
 Impacts Total Transfer Capability 1305 MW
 TTC with All Lines In Service 2975 MW

EDIC_-N.SCTLND_345_14 & PORTER_-ROTTRDAM_230_30

Thu 09/16/2021 to Sun 11/14/2021
 0700 1730
 Work scheduled by:

FWD
 (Import)
 CENTRAL EAST - VC **1500 MW**
 Impacts Total Transfer Capability 1475 MW
 TTC with All Lines In Service 2975 MW

HURLYAVE-ROSETON__345_303

Thu 09/16/2021 to Sun 10/17/2021 **UPDATED by CHGE 09/22/2020**
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4100 MW**
 Impacts Total Transfer Capability 2120 MW
 TTC with All Lines In Service 6220 MW

NYISO TRANSFER LIMITATIONS

Monday ,April 12, 2021 to Wednesday,October 12, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HOMRC_NY-MAINS_NY_345_47

Sat 09/18/2021 to Fri 11/05/2021
 0800 Continuous 1600
 Work scheduled by: PJM

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

PANNELL_-CLAY_345_1

Mon 09/20/2021 to Fri 09/24/2021
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 WEST CENTRAL **1300 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

CLAY_-EDIC_345_2-15

Mon 09/20/2021 to Sat 10/16/2021
 0700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 OSWEGO EXPORT **4850 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 5250 MW

KINTIGH_-STA_255_345_SH1-39

Mon 09/27/2021 to Wed 09/29/2021 **UPDATED by NYPA 03/04/2021**
 0500 Continuous 0459
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **2350 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 3150 MW

NIAGARA_-KINTIGH_345_NS1-38

Mon 09/27/2021 to Wed 09/29/2021 **UPDATED by NYPA 03/04/2021**
 0500 Continuous 0459
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **1400 MW**
 Impacts Total Transfer Capability 1750 MW
 TTC with All Lines In Service 3150 MW

PANNELL_-CLAY_345_2

Mon 09/27/2021 to Fri 10/01/2021
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 WEST CENTRAL **1300 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

W49TH_ST_345KV_6

Tue 09/28/2021 to Tue 09/28/2021 **UPDATED by CONED 01/15/2021**
 0100 Continuous 0130
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Monday ,April 12, 2021 to Wednesday,October 12, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						FWD
E13THSTA-FARRAGUT_345_46						(Import)
Tue 09/28/2021	to	Tue 10/26/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>01/15/2021</u>	
0100	Continuous	0300				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
<hr/>						FWD
W49TH_ST-E13THSTA_345_M55						(Import)
Tue 09/28/2021	to	Tue 10/26/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>01/15/2021</u>	
0100	Continuous	0300				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
<hr/>						FWD
KINTIGH_-STA_255__345_SH1-39						(Import)
Wed 09/29/2021	to	Wed 12/01/2021				
0500	Continuous	1900				DYSINGER EAST 2350 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 3150 MW
<hr/>						FWD
NIAGARA_-KINTIGH__345_NS1-38						(Import)
Wed 09/29/2021	to	Wed 12/01/2021				
0500	Continuous	1900				DYSINGER EAST 1400 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 1750 MW
						TTC with All Lines In Service 3150 MW
<hr/>						FWD
LEEDS___-HURLYAVE_345_301						(Import)
Mon 10/18/2021	to	Fri 11/19/2021				
0800	Continuous	1600				UPNY CONED 4100 MW
Work scheduled by: CHGE						Impacts Total Transfer Capability 2120 MW
						TTC with All Lines In Service 6220 MW
<hr/>						FWD
GOETHALS_345KV_5						(Import)
Thu 10/21/2021	to	Sat 11/20/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>03/05/2021</u>	
0001	Continuous	0200				STATEN ISLAND
Work scheduled by: ConEd						Impacts Total Transfer Capability
						TTC with All Lines In Service
<hr/>						FWD
W49TH_ST_345KV_6						(Import)
Tue 10/26/2021	to	Tue 10/26/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>01/15/2021</u>	
0230	Continuous	0300				SCH - PJM_HTP 300 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 360 MW
						TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Monday ,April 12, 2021 to Wednesday,October 12, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO-NYISO_LIMIT_1750					FWD	
Mon 11/01/2021	to	Fri 12/31/2021	UPDATED	by IESO	05/03/2019	(Import)
0001	Continuous	2359				2050 MW
Work scheduled by: IESO					Impacts Total Transfer Capability 250 MW	
					TTC with All Lines In Service 2300 MW	
SCH-NYISO-IMO_LIMIT_1600					REV	
Mon 11/01/2021	to	Fri 12/31/2021	UPDATED	by IESO	05/03/2019	(Export)
0001	Continuous	2359				1900 MW
Work scheduled by: IESO					Impacts Total Transfer Capability 100 MW	
					TTC with All Lines In Service 2000 MW	
LINDN_CG-LNDVFT___345_V-3022					FWD	
Tue 11/02/2021	to	Fri 11/05/2021				(Import) (Export)
0800	Continuous	1500				0 MW 0 MW
Work scheduled by: PJM					Impacts Total Transfer Capability 315 MW 315 MW	
					TTC with All Lines In Service 315 MW 315 MW	
MASSENA_-MARCY___765_MSU1 & PORTER_-ROTTDAM_230_30					FWD	
Mon 11/15/2021	to	Tue 11/30/2021				(Import)
0100		1730				1500 MW
Work scheduled by:					Impacts Total Transfer Capability 1475 MW	
					TTC with All Lines In Service 2975 MW	
CHATGUAY-MASSENA___765_7040					FWD	
Mon 11/15/2021	to	Tue 11/30/2021				(Import)
0100	Continuous	1859				1550 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 1600 MW	
					TTC with All Lines In Service 3150 MW	
CHATGUAY-MASSENA___765_7040					FWD	
Mon 11/15/2021	to	Tue 11/30/2021				(Import) (Export)
0100	Continuous	1859				0 MW 0 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 1500 MW 1000 MW	
					TTC with All Lines In Service 1500 MW 1000 MW	
MARCY___765_345_AT1					FWD	
Mon 11/15/2021	to	Tue 11/30/2021				(Import)
0100	Continuous	1859				1750 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 1400 MW	
					TTC with All Lines In Service 3150 MW	

ARR: 19

NYISO TRANSFER LIMITATIONS

Monday ,April 12, 2021 to Wednesday,October 12, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT2			FWD	
Mon 11/15/2021	to	Tue 11/30/2021	(Import)	
0100	Continuous	1859	MOSES SOUTH	1700 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1450 MW
			TTC with All Lines In Service	3150 MW
MASSENA_-MARCY___765_MSU1			FWD	
Mon 11/15/2021	to	Tue 11/30/2021	(Import)	
0100	Continuous	1859	CENTRAL EAST - VC	1670 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1305 MW
			TTC with All Lines In Service	2975 MW
MASSENA_-MARCY___765_MSU1			FWD	
Mon 11/15/2021	to	Tue 11/30/2021	(Import)	
0100	Continuous	1859	MOSES SOUTH	500 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	2650 MW
			TTC with All Lines In Service	3150 MW
MASSENA_-MARCY___765_MSU1			FWD	REV
Mon 11/15/2021	to	Tue 11/30/2021	(Import)	(Export)
0100	Continuous	1859	SCH - HQ - NY	475 MW 1000 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1025 MW 0 MW
			TTC with All Lines In Service	1500 MW 1000 MW
MASSENA_-MARCY___765_MSU1			FWD	
Mon 11/15/2021	to	Tue 11/30/2021	(Import)	
0100	Continuous	1859	SCH - HQ_CEDARS	90 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	109 MW
			TTC with All Lines In Service	199 MW
MASSENA_-MARCY___765_MSU1 & CHATGUAY-MASSENA_765_7040			FWD	
Mon 11/15/2021	to	Tue 11/30/2021	(Import)	
0100		1859	MOSES SOUTH	500 MW
Work scheduled by:			Impacts Total Transfer Capability	2650 MW
			TTC with All Lines In Service	3150 MW
MOSES___-MASSENA_230_MMS1 & MOSES___-MASSENA_230_MMS2			FWD	REV
Mon 11/15/2021	to	Tue 11/30/2021	(Import)	(Export)
0100		1859	SCH - HQ - NY	850 MW 0 MW
Work scheduled by:			Impacts Total Transfer Capability	650 MW 1000 MW
			TTC with All Lines In Service	1500 MW 1000 MW

NYISO TRANSFER LIMITATIONS

Monday ,April 12, 2021 to Wednesday,October 12, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2		FWD
Mon 11/15/2021	to Tue 11/30/2021	(Import)
0100	1859	SCH - HQ_CEDARS 90 MW
Work scheduled by:		Impacts Total Transfer Capability 109 MW
		TTC with All Lines In Service 199 MW
STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1		FWD
Mon 11/15/2021	to Tue 11/30/2021	(Import)
0100	1859	SCH - HQ_CEDARS 90 MW
Work scheduled by:		Impacts Total Transfer Capability 109 MW
		TTC with All Lines In Service 199 MW
STLAWRNC-MOSES 230_L33P & MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2		FWD
Mon 11/15/2021	to Tue 11/30/2021	(Import)
0100	1859	SCH - HQ_CEDARS 90 MW
Work scheduled by:		Impacts Total Transfer Capability 109 MW
		TTC with All Lines In Service 199 MW
FRASER 345_FRASER SVC		FWD
Wed 12/01/2021	to Mon 02/28/2022	(Import)
0700	Continuous 1730	CENTRAL EAST - VC 2935 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability 40 MW
		TTC with All Lines In Service 2975 MW
MOSES -ADIRNDCK 230_MA1		FWD
Wed 12/01/2021	to Tue 05/31/2022	(Import)
0700	Continuous 1300	MOSES SOUTH 2300 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability 850 MW
		TTC with All Lines In Service 3150 MW
NIAGARA -STA_255_345_NH2		FWD
Thu 12/02/2021	to Thu 01/13/2022	(Import)
0500	Continuous 1900	DYSINGER EAST 2350 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability 800 MW
		TTC with All Lines In Service 3150 MW
MOTTHAVN-RAINEY 345_Q12		FWD
Sun 12/05/2021	to Sat 12/25/2021	(Import)
0001	Continuous 0159	SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability 800 MW
		TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Monday ,April 12, 2021 to Wednesday,October 12, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LEEDS___-PLSNTVLY_345_92

Thu 02/17/2022 to Mon 02/21/2022
0600 Continuous 1900

UPDATED by NGRID 03/31/2021

Work scheduled by: NGrid

FWD
(Import)
3800 MW
Impacts Total Transfer Capability 2420 MW
TTC with All Lines In Service 6220 MW

GOETHALS_345KV_5

Sat 03/05/2022 to Mon 04/04/2022
0001 Continuous 0200

UPDATED by CONED 03/26/2021

Work scheduled by: ConEd

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

LINDEN__-GOETHALS_230_A2253

Sat 03/05/2022 to Mon 04/04/2022
0001 Continuous 0200

UPDATED by CONED 03/26/2021

Work scheduled by: ConEd

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

N.SCTLND-ALPS_____345_2

Mon 05/02/2022 to Mon 05/09/2022
0600 Daily 1800

UPDATED by CONED 03/26/2021

Work scheduled by: NGrid

FWD
(Import)
750 MW
Impacts Total Transfer Capability 650 MW
TTC with All Lines In Service 1400 MW

N.SCTLND-ALPS_____345_2

Mon 05/02/2022 to Mon 05/09/2022
0600 Daily 1800

UPDATED by CONED 03/26/2021

Work scheduled by: NGrid

FWD REV
(Import) (Export)
100 MW 100 MW
Impacts Total Transfer Capability 100 MW 100 MW
TTC with All Lines In Service 200 MW 200 MW

HOMRC_NY-MAINS_NY_345_47

Fri 05/20/2022 to Fri 05/27/2022
0800 Continuous 1600

UPDATED by PJM 11/19/2020

Work scheduled by: PJM

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

HOMR_NYW-PIERC_NY_345_48

Fri 05/20/2022 to Fri 05/27/2022
0800 Continuous 1600

UPDATED by PJM 11/19/2020

Work scheduled by: PJM

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Monday ,April 12, 2021 to Wednesday,October 12, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	6220MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES__-ADIRNDCK_230_MA2

Wed 06/01/2022 to Mon 11/14/2022
 0700 Continuous 1300
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2100 MW**
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW

SPRNBRK__345KV_RNS5

Mon 09/19/2022 to Mon 09/19/2022 **UPDATED by CONED 09/17/2020**
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

SPRNBRK_-W49TH_ST_345_M51

Mon 09/19/2022 to Wed 09/21/2022 **UPDATED by CONED 09/17/2020**
 0001 Continuous 2200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

SPRNBRK__345KV_RNS5

Wed 09/21/2022 to Wed 09/21/2022 **UPDATED by CONED 09/17/2020**
 2130 Continuous 2200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

SPRNBRK_-W49TH_ST_345_M51

Sat 10/01/2022 to Mon 10/17/2022 **UPDATED by CONED 08/01/2020**
 0001 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

SPRNBRK__345KV_RNS5

Sat 10/01/2022 to Mon 10/17/2022 **UPDATED by CONED 08/01/2020**
 0001 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW