

NYISO TRANSFER LIMITATIONS

Tuesday ,April 13, 2021 to Thursday ,October 13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Wed 06/30/2021 **EXT FORCE by CONED 08/28/2020**
 0001 Continuous 2359
 Work scheduled by: ConEd

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Wed 06/30/2021
 0001 2359
 Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2550 MW	1900 MW
Impacts Total Transfer Capability	250 MW	50 MW
TTC with All Lines In Service	2800 MW	1950 MW

MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Wed 06/30/2021 **EXT FORCE by CONED 08/28/2020**
 0001 Continuous 2359
 Work scheduled by: ConEd

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

STLAWRNC-MOSES_230_L33P

Mon 04/30/2018 to Mon 10/31/2022 **EXT FORCE by IESO 10/01/2020**
 0456 Continuous 1600
 Work scheduled by: IESO

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

NEWBRDGE_345_138_BK_1

Wed 09/02/2020 to Tue 02/01/2022 **EXT FORCE by LI 01/12/2021**
 1807 Continuous 2359
 Work scheduled by: LI

	FWD
	(Import)
SCH - PJM_NEPTUNE	375 MW
Impacts Total Transfer Capability	285 MW
TTC with All Lines In Service	660 MW

SPRNBK_-EGRDNCTR_345_Y49

Thu 10/01/2020 to Mon 04/19/2021 **EXT FORCE by LI 02/23/2021**
 0404 Continuous 2359
 Work scheduled by: LI

	FWD
	(Import)
CONED - LIPA	775 MW
Impacts Total Transfer Capability	725 MW
TTC with All Lines In Service	1500 MW

EGRDNCTY_345_138_AT2

Sat 10/10/2020 to Mon 04/19/2021 **EXT FORCE by LI 02/23/2021**
 1815 Continuous 2359
 Work scheduled by: LI

	FWD
	(Import)
CONED - LIPA	1250 MW
Impacts Total Transfer Capability	250 MW
TTC with All Lines In Service	1500 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 13, 2021 to Thursday ,October 13, 2022

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EGRDNCTY_345_138_AT1

Sat 10/10/2020 to Mon 04/19/2021
1856 Continuous 2359

EXT FORCE by LI 02/23/2021

Work scheduled by: LI

FWD
(Import)
1250 MW
CONED - LIPA
Impacts Total Transfer Capability 250 MW
TTC with All Lines In Service 1500 MW

SCH-IMO-NYISO_LIMIT_1750

Sun 11/01/2020 to Fri 04/30/2021
0001 Continuous 2359

UPDATED by IESO 05/03/2019

Work scheduled by: IESO

FWD
(Import)
2050 MW
SCH - OH - NY
Impacts Total Transfer Capability 250 MW
TTC with All Lines In Service 2300 MW

SCH-NYISO-IMO_LIMIT_1600

Sun 11/01/2020 to Fri 04/30/2021
0001 Continuous 2359

UPDATED by IESO 05/03/2019

Work scheduled by: IESO

REV
(Export)
1900 MW
SCH - OH - NY
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 2000 MW

SAND_BAR-PLATSBRG_115_PV20

Tue 02/23/2021 to Mon 05/17/2021
1801 Continuous 0559

UPDATED by NYISO 03/16/2021

Work scheduled by: ISONE

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

W49TH_ST_345KV_8

Tue 03/02/2021 to Sun 05/02/2021
0201 Continuous 0200

EXTENDED by CONED 04/10/2021

Work scheduled by: ConEd

FWD
(Import)
300 MW
SCH - PJM_HTP
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

PORTER_-ROTTRDAM_230_31

Tue 03/02/2021 to Mon 05/31/2021
0600 Continuous 1730

UPDATED by NGRID 03/10/2021

Work scheduled by: NGrid

FWD
(Import)
2805 MW
CENTRAL EAST - VC
Impacts Total Transfer Capability 170 MW
TTC with All Lines In Service 2975 MW

MOSES_-ADIRNDCK_230_MAL

Tue 03/02/2021 to Mon 05/10/2021
0700 Continuous 1159

UPDATED by NYPA 02/11/2021

Work scheduled by: NYPA

FWD
(Import)
2300 MW
MOSES SOUTH
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 13, 2021 to Thursday ,October 13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LADENTWN-BUCHAN_S_345_Y88

Tue 03/09/2021 to Fri 04/09/2021
0001 Continuous 0200

EXTENDED by CE 04/02/2021

Work scheduled by: ConEd

FWD
(Import)
5930 MW
UPNY CONED
Impacts Total Transfer Capability 290 MW
TTC with All Lines In Service 6220 MW

SCH-NYISO-HQ_CEDARS_LIMIT_0

Mon 03/15/2021 to Thu 04/08/2021
0500 Continuous 2000

UPDATED by HQ 04/08/2021

Work scheduled by: HQ

REV
(Export)
0 MW
SCH - HQ_CEDARS
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 100 MW

W49TH_ST_345KV_6

Sun 03/21/2021 to Sun 05/02/2021
0001 Continuous 0200

EXTENDED by CONED 04/10/2021

Work scheduled by: ConEd

FWD
(Import)
300 MW
SCH - PJM_HTP
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

EDIC__-N.SCTLND_345_14 & PORTER__-ROTTRDAM_230_31

Mon 03/22/2021 to Mon 05/31/2021
0600 1730

EXTENDED by CONED 04/10/2021

Work scheduled by:

FWD
(Import)
1500 MW
CENTRAL EAST - VC
Impacts Total Transfer Capability 1475 MW
TTC with All Lines In Service 2975 MW

EDIC__-N.SCTLND_345_14

Mon 03/22/2021 to Mon 05/31/2021
0600 Continuous 1830

UPDATED by NGRID 03/10/2021

Work scheduled by: NGrid

FWD
(Import)
1670 MW
CENTRAL EAST - VC
Impacts Total Transfer Capability 1305 MW
TTC with All Lines In Service 2975 MW

S.RIPLEY-DUNKIRK_230_68

Mon 03/29/2021 to Fri 04/09/2021
1129 Continuous 1700

UPDATED by NYISO 03/30/2021

Work scheduled by: NGrid

FWD
(Import)
2300 MW
SCH - PJ - NY
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

ROCHESTR-PANNELL_345_RP2

Wed 03/31/2021 to Sat 04/10/2021
0500 Continuous 2016

EXTENDED by NYISO 03/30/2021

Work scheduled by: NYPA

FWD
(Import)
2300 MW
DYSINGER EAST
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 13, 2021 to Thursday ,October 13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Line ID	Start Date	End Date	Time	Work by	SCH	FWD	REV
LINDN_CG-LNDVFT___345_V-3022	Sun 04/04/2021	Sat 04/10/2021	1400 Continuous 1400	PJM	PJM_VFT	(Import)	(Export)
						0 MW	0 MW
					Impacts Total Transfer Capability	315 MW	315 MW
					TTC with All Lines In Service	315 MW	315 MW
WATRCURE-OAKDALE___345_31	Mon 04/05/2021	Thu 04/08/2021	0800 Daily(No Weekends) 1500	NYSEG	PJ - NY		
					Impacts Total Transfer Capability		
					TTC with All Lines In Service		
NINEMILE-CLAY___345_8	Tue 04/06/2021	Sun 04/11/2021	1600 Daily 0500	NGrid	OSWEGO EXPORT	(Import)	
						5150 MW	
					Impacts Total Transfer Capability	100 MW	
					TTC with All Lines In Service	5250 MW	
LEEDS___345KV_R94301	Thu 04/08/2021	Thu 04/08/2021	0700 Daily(No Weekends) 0800	NGrid	UPNY CONED	(Import)	
						3800 MW	
					Impacts Total Transfer Capability	2420 MW	
					TTC with All Lines In Service	6220 MW	
N.SCTLND-LEEDS___345_94	Thu 04/08/2021	Thu 04/08/2021	0700 Daily(No Weekends) 1600	NGrid	CENTRAL EAST - VC	(Import)	
						2650 MW	
					Impacts Total Transfer Capability	325 MW	
					TTC with All Lines In Service	2975 MW	
MARCY___345KV_CSC	Thu 04/08/2021	Thu 04/08/2021	0700 Continuous 1830	NYPA	CENTRAL EAST - VC	(Import)	
						2925 MW	
					Impacts Total Transfer Capability	50 MW	
					TTC with All Lines In Service	2975 MW	
LEEDS___345KV_R94301	Thu 04/08/2021	Thu 04/08/2021	1500 Daily(No Weekends) 1600	NGrid	UPNY CONED	(Import)	
						3800 MW	
					Impacts Total Transfer Capability	2420 MW	
					TTC with All Lines In Service	6220 MW	

NYISO TRANSFER LIMITATIONS

Tuesday ,April 13, 2021 to Thursday ,October 13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOTTHAVN-RAINEY ___ 345_Q11				FWD
Thu 04/08/2021	to	Mon 04/12/2021	EXT FORCE by CONED 04/11/2021	(Import)
2309	Continuous	2359		SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
CHAT_DC_GC1				FWD
Sat 04/10/2021	to	Sat 04/10/2021		(Import)
0600	Continuous	1600		MOSES SOUTH 2850 MW
Work scheduled by: HQ				Impacts Total Transfer Capability 300 MW
				TTC with All Lines In Service 3150 MW
CHAT_DC_GC1				REV
Sat 04/10/2021	to	Sat 04/10/2021		(Export)
0600	Continuous	1600		SCH - HQ - NY 500 MW
Work scheduled by: HQ				Impacts Total Transfer Capability 500 MW
				TTC with All Lines In Service 1000 MW
S.RIPLEY-DUNKIRK ___ 230_68				
Mon 04/12/2021	to	Fri 04/23/2021	UPDATED by NGRID 04/12/2021	
0630	Continuous	1700		SCH - PJ - NY
Work scheduled by: NGrid				Impacts Total Transfer Capability
				TTC with All Lines In Service
LEEDS ___ 345KV_R94301				FWD
Mon 04/12/2021	to	Mon 04/12/2021	UPDATED by NGRID 02/01/2021	(Import)
0800	Continuous	0830		UPNY CONED 3800 MW
Work scheduled by: CHGE				Impacts Total Transfer Capability 2420 MW
				TTC with All Lines In Service 6220 MW
LEEDS ___ -HURLYAVE_345_301				FWD
Mon 04/12/2021	to	Fri 04/16/2021	UPDATED by NGRID 02/01/2021	(Import)
0800	Continuous	1600		UPNY CONED 4100 MW
Work scheduled by: CHGE				Impacts Total Transfer Capability 2120 MW
				TTC with All Lines In Service 6220 MW
NIAGARA _-STA_255__345_NH2				FWD
Fri 04/16/2021	to	Fri 04/16/2021	CANCELLED by NYPA 04/08/2021	(Import)
0500	Continuous	1700		DYSINGER EAST 1700 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 1450 MW
				TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 13, 2021 to Thursday ,October 13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LEEDS_345KV_R94301					FWD	
Fri 04/16/2021	to	Fri 04/16/2021	<u>UPDATED</u>	<u>by NGRID</u>	<u>02/01/2021</u>	(Import)
1530	Continuous	1600				UPNY CONED 3800 MW
Work scheduled by: CHGE					Impacts Total Transfer Capability	2420 MW
					TTC with All Lines In Service	6220 MW
DUNWODIE_345KV_6					FWD	
Tue 04/20/2021	to	Tue 04/20/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>02/19/2021</u>	(Import)
0201	Continuous	0230				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_8					FWD	
Tue 04/20/2021	to	Tue 04/20/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>02/19/2021</u>	(Import)
0201	Continuous	0230				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
WOOD_ST_-PLSNTVLE_345_Y87					FWD	
Tue 04/20/2021	to	Tue 04/20/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>02/19/2021</u>	(Import)
0201	Continuous	0230				UPNY CONED 5905 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	315 MW
					TTC with All Lines In Service	6220 MW
PLSNTVLE-DUNWODIE_345_W90					FWD	
Tue 04/20/2021	to	Fri 04/23/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>02/19/2021</u>	(Import)
0201	Continuous	0159				UPNY CONED 4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	2220 MW
					TTC with All Lines In Service	6220 MW
MAINESBG-WATRCURE_345_30					FWD	
Tue 04/20/2021	to	Wed 04/21/2021				(Import)
0800	Continuous	1530				SCH - PJ - NY 2300 MW
Work scheduled by: NYSEG					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	2800 MW
DUNWODIE_345KV_6					FWD	
Fri 04/23/2021	to	Fri 04/23/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>02/19/2021</u>	(Import)
0130	Continuous	0159				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 13, 2021 to Thursday ,October 13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						FWD
DUNWODIE_345KV_8						(Import)
Fri 04/23/2021	to	Fri 04/23/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>02/19/2021</u>	
0130	Continuous	0159				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<hr/>						
WOOD_ST_-PLSNTVLE_345_Y87						FWD
						(Import)
Fri 04/23/2021	to	Fri 04/23/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>02/19/2021</u>	
0130	Continuous	0159				5905 MW
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	315 MW
					TTC with All Lines In Service	6220 MW
<hr/>						
PLSNTVLY-WOOD_ST__345_F30						FWD
						(Import)
Fri 04/23/2021	to	Fri 04/23/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>04/02/2021</u>	
0201	Continuous	0230				4000 MW
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	2220 MW
					TTC with All Lines In Service	6220 MW
<hr/>						
PLSNTVLY_345KV_RNS5						FWD
						(Import)
Fri 04/23/2021	to	Fri 04/23/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>04/02/2021</u>	
0201	Continuous	0230				3800 MW
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	2420 MW
					TTC with All Lines In Service	6220 MW
<hr/>						
MILLWOOD-EASTVIEW_345_W82						FWD
						(Import)
Fri 04/23/2021	to	Fri 04/23/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>04/02/2021</u>	
0201	Continuous	1800				5985 MW
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	235 MW
					TTC with All Lines In Service	6220 MW
<hr/>						
MILLWOOD_345KV_18						FWD
						(Import)
Fri 04/23/2021	to	Sat 04/24/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>04/02/2021</u>	
0201	Continuous	2200				4350 MW
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	1870 MW
					TTC with All Lines In Service	6220 MW
<hr/>						
CHAT_DC_GC1						FWD
						(Import)
Sat 04/24/2021	to	Sun 04/25/2021				
2000	Continuous	0500				2850 MW
Work scheduled by: HQ					MOSES SOUTH	
					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 13, 2021 to Thursday ,October 13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC1					REV
Sat 04/24/2021	to	Sun 04/25/2021			(Export)
2000	Continuous	0500		SCH - HQ - NY	500 MW
Work scheduled by: HQ					Impacts Total Transfer Capability
					TTC with All Lines In Service
					1000 MW
PLSNTVLY-WOOD_ST__345_F30					FWD
Mon 04/26/2021	to	Tue 04/27/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>04/02/2021</u>
0001	Continuous	0200		UPNY CONED	4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability
					TTC with All Lines In Service
					2220 MW
					6220 MW
PLSNTVLY_345KV_RNS5					FWD
Mon 04/26/2021	to	Tue 04/27/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>04/02/2021</u>
0001	Continuous	0200		UPNY CONED	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability
					TTC with All Lines In Service
					2420 MW
					6220 MW
KINTIGH_-STA_255__345_SH1-39					FWD
Mon 04/26/2021	to	Fri 04/30/2021			(Import)
0700	Continuous	1700		DYSINGER EAST	1700 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability
					TTC with All Lines In Service
					1450 MW
					3150 MW
NIAGARA_-KINTIGH__345_NS1-38					FWD
Mon 04/26/2021	to	Fri 04/30/2021			(Import)
0700	Continuous	1700		DYSINGER EAST	1700 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability
					TTC with All Lines In Service
					1450 MW
					3150 MW
HOMRC_NY-MAINS_NY_345_47					
Mon 04/26/2021	to	Sat 05/29/2021	<u>EXTENDED</u>	<u>by NYSEG</u>	<u>03/10/2021</u>
0800	Continuous	1900		SCH - PJ - NY	
Work scheduled by: NYSEG					Impacts Total Transfer Capability
					TTC with All Lines In Service
FRASER_-COOPERS__345_33					FWD
Mon 04/26/2021	to	Fri 04/30/2021			(Import)
0830	Continuous	1500		CENTRAL EAST - VC	2395 MW
Work scheduled by: NYSEG					Impacts Total Transfer Capability
					TTC with All Lines In Service
					580 MW
					2975 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 13, 2021 to Thursday ,October 13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ALCOA_PA_115KV_R8105					FWD	
Tue 04/27/2021	to	Thu 04/29/2021			(Import)	
0630	Continuous	1830		MOSES SOUTH	3100 MW	
Work scheduled by: NGrid					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	3150 MW
MOTTHAVN-RAINEY_345_Q11					FWD	
Wed 04/28/2021	to	Sat 05/08/2021			(Import)	
0001	Continuous	0200		SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
BUCHAN_N-EASTVIEW_345_W93					FWD	
Fri 04/30/2021	to	Sun 05/09/2021	UPDATED	by CONED	04/07/2021	
0700	Continuous	2359		UPNY CONED	4350 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability	1870 MW
					TTC with All Lines In Service	6220 MW
SCH-IMO-NYISO_LIMIT_1600					FWD	
Sat 05/01/2021	to	Sun 10/31/2021	UPDATED	by IESO	05/03/2019	
0001	Continuous	2359		SCH - OH - NY	1900 MW	
Work scheduled by: IESO					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	1950 MW
W49TH_ST_345KV_5					FWD	
Sun 05/02/2021	to	Sun 05/02/2021	UPDATED	by CONED	04/13/2021	
0201	Continuous	0231		SCH - PJM_HTP	300 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability	360 MW
					TTC with All Lines In Service	660 MW
W49TH_ST_345KV_7					FWD	
Sun 05/02/2021	to	Sun 05/02/2021	UPDATED	by CONED	04/13/2021	
0201	Continuous	0231		SCH - PJM_HTP	300 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability	360 MW
					TTC with All Lines In Service	660 MW
NRTH1385-NOR_HBR_138_601					FWD	REV
Mon 05/03/2021	to	Mon 05/24/2021			(Import)	(Export)
0600	Continuous	2359		SCH - NPX_1385	100 MW	100 MW
Work scheduled by: LI					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 13, 2021 to Thursday ,October 13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Work Period			SCH	FWD	REV
Start	End	Notes		(Import)	(Export)
NRTH1385-NOR HBR_138_601 & NRTH1385-NOR HBR_138_602					
Mon 05/03/2021	to	Mon 05/24/2021			
0600		2359	SCH - NPX_1385	0 MW	0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW	200 MW
			TTC with All Lines In Service	200 MW	200 MW
NRTH1385-NOR HBR_138_601 & NRTH1385-NOR HBR_138_603					
Mon 05/03/2021	to	Mon 05/24/2021			
0600		2359	SCH - NPX_1385	0 MW	0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW	200 MW
			TTC with All Lines In Service	200 MW	200 MW
NRTH1385-NOR HBR_138_602					
Mon 05/03/2021	to	Mon 05/24/2021			
0600	Continuous	2359	SCH - NPX_1385	100 MW	100 MW
Work scheduled by: LI			Impacts Total Transfer Capability	100 MW	100 MW
			TTC with All Lines In Service	200 MW	200 MW
NRTH1385-NOR HBR_138_602 & NRTH1385-NOR HBR_138_603					
Mon 05/03/2021	to	Mon 05/24/2021			
0600		2359	SCH - NPX_1385	0 MW	0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW	200 MW
			TTC with All Lines In Service	200 MW	200 MW
NRTH1385-NOR HBR_138_603					
Mon 05/03/2021	to	Mon 05/24/2021			
0600	Continuous	2359	SCH - NPX_1385	100 MW	100 MW
Work scheduled by: LI			Impacts Total Transfer Capability	100 MW	100 MW
			TTC with All Lines In Service	200 MW	200 MW
NRTH1385-NRTHPORT_138_NNC					
Mon 05/03/2021	to	Mon 05/24/2021			
0600	Continuous	2359	SCH - NPX_1385	0 MW	0 MW
Work scheduled by: LI			Impacts Total Transfer Capability	200 MW	200 MW
			TTC with All Lines In Service	200 MW	200 MW
CLAY -EDIC 345_2-15					
Mon 05/03/2021	to	Fri 05/07/2021			
0700	Continuous	1530	OSWEGO EXPORT	4850 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	400 MW	
			TTC with All Lines In Service	5250 MW	

NYISO TRANSFER LIMITATIONS

Tuesday ,April 13, 2021 to Thursday ,October 13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FIVEMILE-STOLLERD_345_29

Mon 05/03/2021 to Fri 05/14/2021
 0700 Continuous 1400
 Work scheduled by: NYSEG

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

PANNELL -CLAY_345_2

Mon 05/03/2021 to Sun 05/30/2021
 0700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 WEST CENTRAL **1300 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

HURLYAVE-ROSETON_345_303

Mon 05/03/2021 to Fri 05/21/2021
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4100 MW**
 Impacts Total Transfer Capability 3715 MW
 TTC with All Lines In Service 7815 MW

SHOR_NPX-SHOREHAM_138_CSC

Mon 05/03/2021 to Sat 05/08/2021 **EXTENDED by ISONE 03/15/2021**
 0900 Continuous 1600
 Work scheduled by: LI

FWD REV
 (Import) (Export)
 SCH - NPX_CSC **0 MW 0 MW**
 Impacts Total Transfer Capability 330 MW 330 MW
 TTC with All Lines In Service 330 MW 330 MW

ROTTDAM-EASTOVER_230_38

Tue 05/04/2021 to Tue 05/04/2021
 0830 Daily(No Weekends) 1130
 Work scheduled by: NGrid

REV
 (Export)
 SCH - NE - NY **1400 MW**
 Impacts Total Transfer Capability 200 MW
 TTC with All Lines In Service 1600 MW

ARR: 77

RAMAPO -BUCHAN_N_345_Y94

Fri 05/07/2021 to Sun 05/09/2021 **UPDATED by CONED 04/07/2021**
 0001 Continuous 2359
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **7580 MW**
 Impacts Total Transfer Capability 235 MW
 TTC with All Lines In Service 7815 MW

EASTVIEW-SPRNBK_345_W79

Sat 05/08/2021 to Sun 05/09/2021 **UPDATED by CONED 04/07/2021**
 0700 Continuous 2359
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 13, 2021 to Thursday ,October 13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_5		FWD
Sun 05/09/2021 to Sun 05/09/2021	UPDATED by CONED 04/13/2021	(Import)
0130 Continuous 0200		SCH - PJM_HTP 300 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability 360 MW
		TTC with All Lines In Service 660 MW
<hr/>		
W49TH_ST_345KV_7		FWD
Sun 05/09/2021 to Sun 05/09/2021	UPDATED by CONED 04/13/2021	(Import)
0130 Continuous 0200		SCH - PJM_HTP 300 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability 360 MW
		TTC with All Lines In Service 660 MW
<hr/>		
W49TH_ST_345KV_7		FWD
Mon 05/10/2021 to Mon 05/10/2021		(Import)
0001 Continuous 0030		SCH - PJM_HTP 300 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability 360 MW
		TTC with All Lines In Service 660 MW
<hr/>		
W49TH_ST_345KV_8		FWD
Mon 05/10/2021 to Mon 05/10/2021		(Import)
0001 Continuous 0030		SCH - PJM_HTP 450 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability 210 MW
		TTC with All Lines In Service 660 MW
<hr/>		
HUDSONTP-W49TH_ST_345_Y56		FWD
Mon 05/10/2021 to Thu 05/13/2021		(Import)
0001 Continuous 2300		SCH - PJM_HTP 0 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability 660 MW
		TTC with All Lines In Service 660 MW
<hr/>		
SPRNBK_-TREMONT_345_X28		FWD
Mon 05/10/2021 to Wed 05/26/2021	UPDATED by CONED 03/18/2021	(Import)
0001 Continuous 0200		SPR/DUN-SOUTH 4200 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability 400 MW
		TTC with All Lines In Service 4600 MW
<hr/>		
CLAY_-EDIC_345_1-16		FWD
Mon 05/10/2021 to Fri 05/14/2021		(Import)
0700 Continuous 1530		OSWEGO EXPORT 4850 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability 400 MW
		TTC with All Lines In Service 5250 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 13, 2021 to Thursday ,October 13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Work Scheduled	Work Scheduled by	MOSES SOUTH	Impacts Total Transfer Capability	TTC with All Lines In Service	FWD	REV
MOSES -ADIRNDCK_230_MA2						
Mon 05/10/2021 to Tue 06/01/2021					FWD	
1200 Continuous 0659		MOSES SOUTH	2100 MW		(Import)	
Work scheduled by: NYPA		Impacts Total Transfer Capability	1050 MW			
		TTC with All Lines In Service	3150 MW			
ALCOA_PA_115KV_R8105						
Tue 05/11/2021 to Thu 06/03/2021					FWD	
0630 Continuous 1630		MOSES SOUTH	3100 MW		(Import)	
Work scheduled by: NGrid		Impacts Total Transfer Capability	50 MW			
		TTC with All Lines In Service	3150 MW			
DENNISON-ROSEMNTB_115_2/22						
Wed 05/12/2021 to Wed 05/12/2021					FWD	REV
0630 Daily(No Weekends) 1830		SCH - HQ_CEDARS	95 MW	40 MW	(Import)	(Export)
Work scheduled by: NGrid		Impacts Total Transfer Capability	95 MW	0 MW		
		TTC with All Lines In Service	190 MW	40 MW		
W49TH_ST_345KV_7						
Thu 05/13/2021 to Thu 05/13/2021					FWD	
2230 Continuous 2300		SCH - PJM_HTP	300 MW		(Import)	
Work scheduled by: ConEd		Impacts Total Transfer Capability	360 MW			
		TTC with All Lines In Service	660 MW			
W49TH_ST_345KV_8						
Thu 05/13/2021 to Thu 05/13/2021					FWD	
2230 Continuous 2300		SCH - PJM_HTP	450 MW		(Import)	
Work scheduled by: ConEd		Impacts Total Transfer Capability	210 MW			
		TTC with All Lines In Service	660 MW			
CRICKVLY-PLSNTVLY_345_F83						
Fri 05/14/2021 to Fri 05/14/2021					FWD	
0001 Continuous 2200		SCH - NE - NY	350 MW		(Import)	
Work scheduled by: ConEd		Impacts Total Transfer Capability	1050 MW			
		TTC with All Lines In Service	1400 MW			
CRICKVLY-PLSNTVLY_345_F83						
Fri 05/14/2021 to Fri 05/14/2021					FWD	REV
0001 Continuous 2200		SCH - NPX_1385	100 MW	100 MW	(Import)	(Export)
Work scheduled by: ConEd		Impacts Total Transfer Capability	100 MW	100 MW		
		TTC with All Lines In Service	200 MW	200 MW		

NYISO TRANSFER LIMITATIONS

Tuesday ,April 13, 2021 to Thursday ,October 13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NOR HBR_138_601 & CRICKVLY-PLSNTVLY_345_F83

Fri 05/14/2021 to Fri 05/14/2021
 0001 2200

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

NRTH1385-NOR HBR_138_602 & CRICKVLY-PLSNTVLY_345_F83

Fri 05/14/2021 to Fri 05/14/2021
 0001 2200

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

NRTH1385-NOR HBR_138_603 & CRICKVLY-PLSNTVLY_345_F83

Fri 05/14/2021 to Fri 05/14/2021
 0001 2200

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

BUCHAN_N-EASTVIEW_345_W93

Fri 05/14/2021 to Sat 05/15/2021
 0001 Continuous 0200

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	4350 MW
Impacts Total Transfer Capability	3465 MW
TTC with All Lines In Service	7815 MW

RAMAPO_-BUCHAN_N_345_Y94

Fri 05/14/2021 to Sat 05/15/2021
 0001 Continuous 0200

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	7580 MW
Impacts Total Transfer Capability	235 MW
TTC with All Lines In Service	7815 MW

SPRNBK_345KV_RS3 & SPRNBK_345KV_RS4

Sat 05/15/2021 to Sat 05/15/2021
 0301 2230

Work scheduled by:

	FWD
	(Import)
SPR/DUN-SOUTH	3200 MW
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	4600 MW

DUNWODIE_345KV_5

Mon 05/17/2021 to Tue 05/18/2021 **UPDATED by CE 03/15/2021**
 0201 Continuous 0200

Work scheduled by: ConEd

	FWD
	(Import)
SPR/DUN-SOUTH	3800 MW
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 13, 2021 to Thursday ,October 13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						FWD
DUNWODIE_345KV_7						(Import)
Mon 05/17/2021	to	Tue 05/18/2021	<u>UPDATED</u>	<u>by CE</u>	<u>03/15/2021</u>	3800 MW
0201	Continuous	0200				Impacts Total Transfer Capability 800 MW
Work scheduled by: ConEd						TTC with All Lines In Service 4600 MW
<hr/>						FWD
SPRNBRK_-DUNWODIE_345_W75						(Import)
Mon 05/17/2021	to	Tue 05/18/2021	<u>UPDATED</u>	<u>by CE</u>	<u>03/15/2021</u>	3800 MW
0201	Continuous	0200				Impacts Total Transfer Capability 800 MW
Work scheduled by: ConEd						TTC with All Lines In Service 4600 MW
<hr/>						FWD
SPRNBRK__345KV_RNS3						(Import)
Mon 05/17/2021	to	Tue 05/18/2021	<u>UPDATED</u>	<u>by CE</u>	<u>03/15/2021</u>	3800 MW
0201	Continuous	0200				Impacts Total Transfer Capability 800 MW
Work scheduled by: ConEd						TTC with All Lines In Service 4600 MW
<hr/>						FWD
NIAGARA_-STA_255__345_NH2						(Import)
Mon 05/17/2021	to	Fri 05/21/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>03/23/2021</u>	1400 MW
0500	Continuous	1700				Impacts Total Transfer Capability 1750 MW
Work scheduled by: NYPA						TTC with All Lines In Service 3150 MW
<hr/>						FWD
SAND_BAR-PLATSBRG_115_PV20						SCH - NE - NY
Mon 05/17/2021	to	Fri 07/02/2021				Impacts Total Transfer Capability
0600	Continuous	1800				TTC with All Lines In Service
Work scheduled by: ISONE						
<hr/>						FWD
GOETHALS_345KV_5						(Import)
Wed 05/19/2021	to	Mon 05/24/2021	<u>EXTENDED</u>	<u>by CE</u>	<u>04/05/2021</u>	1750 MW
0100	Continuous	0200				Impacts Total Transfer Capability
Work scheduled by: ConEd						TTC with All Lines In Service
<hr/>						FWD
LINDEN_-GOETHALS_230_A2253						REV
Wed 05/19/2021	to	Mon 05/24/2021	<u>EXTENDED</u>	<u>by CE</u>	<u>04/05/2021</u>	(Import) (Export)
0100	Continuous	0200				2050 MW 1150 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 150 MW 100 MW
						TTC with All Lines In Service 2200 MW 1250 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 13, 2021 to Thursday ,October 13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LINDEN__-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402				FWD	REV
Wed 05/19/2021	to	Mon 05/24/2021		(Import)	(Export)
0100		0200			
Work scheduled by:				SCH - PJ - NY	2000 MW 1000 MW
				Impacts Total Transfer Capability	200 MW 250 MW
				TTC with All Lines In Service	2200 MW 1250 MW
LINDEN__-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402 & MARION__-FARRAGUT_345_C3403				FWD	REV
Wed 05/19/2021	to	Mon 05/24/2021		(Import)	(Export)
0100		0200			
Work scheduled by:				SCH - PJ - NY	2000 MW 1000 MW
				Impacts Total Transfer Capability	200 MW 250 MW
				TTC with All Lines In Service	2200 MW 1250 MW
LINDEN__-GOETHALS_230_A2253 & MARION__-FARRAGUT_345_C3403				FWD	REV
Wed 05/19/2021	to	Mon 05/24/2021		(Import)	(Export)
0100		0200			
Work scheduled by:				SCH - PJ - NY	2000 MW 1000 MW
				Impacts Total Transfer Capability	200 MW 250 MW
				TTC with All Lines In Service	2200 MW 1250 MW
BUCHAN_S-MILLWOOD_345_W97				FWD	
Thu 05/20/2021	to	Sat 05/22/2021		(Import)	
0001	Continuous	0200			
Work scheduled by: ConEd				UPNY CONED	7680 MW
				Impacts Total Transfer Capability	135 MW
				TTC with All Lines In Service	7815 MW
W49TH_ST_345KV_6				FWD	
Thu 05/20/2021	to	Sat 05/22/2021	UPDATED by CONED 03/30/2021	(Import)	
0001	Continuous	0200			
Work scheduled by: ConEd				SCH - PJM_HTP	300 MW
				Impacts Total Transfer Capability	360 MW
				TTC with All Lines In Service	660 MW
W49TH_ST-E13THSTA_345_M55				FWD	
Thu 05/20/2021	to	Mon 05/24/2021	UPDATED by CONED 03/30/2021	(Import)	
0001	Continuous	0200			
Work scheduled by: ConEd				SPR/DUN-SOUTH	3800 MW
				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
E13THSTA-FARRAGUT_345_46				FWD	
Sat 05/22/2021	to	Mon 05/24/2021	UPDATED by CONED 03/30/2021	(Import)	
0001	Continuous	0200			
Work scheduled by: ConEd				SPR/DUN-SOUTH	3800 MW
				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 13, 2021 to Thursday ,October 13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY-WOOD_ST_345_F31

Mon 05/24/2021 to Tue 05/25/2021
 0001 Continuous 0159
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 3815 MW
 TTC with All Lines In Service 7815 MW

PLSNTVLY_345KV_RNS4

Mon 05/24/2021 to Tue 05/25/2021
 0001 Continuous 0159
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

W49TH_ST_345KV_6

Mon 05/24/2021 to Mon 05/24/2021 **UPDATED by CONED 03/30/2021**
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

ROSETON_-EFISHKIL_345_RFK305

Wed 05/26/2021 to Thu 05/27/2021
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **6680 MW**
 Impacts Total Transfer Capability 1135 MW
 TTC with All Lines In Service 7815 MW

VOLNEY_-MARCY_345_19

Tue 06/01/2021 to Wed 06/02/2021
 0700 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 CENTRAL EAST - VC **2825 MW**
 Impacts Total Transfer Capability 150 MW
 TTC with All Lines In Service 2975 MW

VOLNEY_-MARCY_345_19

Tue 06/01/2021 to Wed 06/02/2021
 0700 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 OSWEGO EXPORT **4900 MW**
 Impacts Total Transfer Capability 350 MW
 TTC with All Lines In Service 5250 MW

FRASER_-GILBOA_345_GF5-35

Tue 06/01/2021 to Mon 06/07/2021
 0700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2650 MW**
 Impacts Total Transfer Capability 325 MW
 TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 13, 2021 to Thursday ,October 13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -ADIRNDCK_230_MA2

Tue 06/01/2021 to Sun 11/14/2021
0700 Continuous 1300

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH 2100 MW
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

MARCY -EDIC_345_UE1-7

Thu 06/03/2021 to Fri 06/04/2021
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19&16

FWD
(Import)
OSWEGO EXPORT 5250 MW
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

PORTER -ROTTRDAM_230_30

Thu 06/03/2021 to Wed 09/15/2021 **UPDATED by NGRID 01/19/2021**
0700 Continuous 0659

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC 2805 MW
Impacts Total Transfer Capability 170 MW
TTC with All Lines In Service 2975 MW

MARCY_345KV_CSC

Sat 06/05/2021 to Sat 06/05/2021
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC 2925 MW
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

ATHENS -PLSNTVLY_345_91

Tue 06/08/2021 to Wed 06/16/2021
0600 Continuous 2000

Work scheduled by: NGrid

FWD
(Import)
UPNY CONED 3800 MW
Impacts Total Transfer Capability 4015 MW
TTC with All Lines In Service 7815 MW

GILBOA -N.SCTLND_345_GNS-1

Wed 06/09/2021 to Wed 06/09/2021
0800 Daily 1200

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC 2520 MW
Impacts Total Transfer Capability 455 MW
TTC with All Lines In Service 2975 MW

BECK -NIAGARA_345_PA301

Wed 06/16/2021 to Thu 06/17/2021
0500 Continuous 2330

Work scheduled by: NYPA

FWD REV
(Import) (Export)
SCH - OH - NY 900 MW 800 MW
Impacts Total Transfer Capability 1050 MW 900 MW
TTC with All Lines In Service 1950 MW 1700 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 13, 2021 to Thursday ,October 13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LEEDS___-PLSNTVLY_345_92					FWD
Thu 06/17/2021 to Thu 06/24/2021					(Import)
0600	Continuous	2000			UPNY CONED 3800 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 4015 MW
					TTC with All Lines In Service 7815 MW
BECK___-NIAGARA_345_PA301					FWD REV
Fri 06/25/2021 to Fri 06/25/2021					(Import) (Export)
0500	Continuous	1700			SCH - OH - NY 900 MW 800 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 1050 MW 900 MW
					TTC with All Lines In Service 1950 MW 1700 MW
FRASANX-COOPERS_345_UCC2-41					FWD
Fri 06/25/2021 to Tue 08/10/2021					(Import)
0700	Continuous	1530			CENTRAL EAST - VC 2500 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 475 MW
ARR: 19					TTC with All Lines In Service 2975 MW
MARCY___-FRASANX_345_UCC2-41					FWD
Fri 06/25/2021 to Tue 08/10/2021					(Import)
0700	Continuous	1530			CENTRAL EAST - VC 2500 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 475 MW
ARR: 19					TTC with All Lines In Service 2975 MW
BECK___-NIAGARA_345_PA302					FWD REV
Mon 07/12/2021 to Fri 07/16/2021					(Import) (Export)
0500	Continuous	1700			SCH - OH - NY 900 MW 800 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 1050 MW 900 MW
					TTC with All Lines In Service 1950 MW 1700 MW
NIAGARA_345_230_AT4					FWD REV
Mon 07/19/2021 to Fri 07/30/2021					(Import) (Export)
0500	Continuous	1700	UPDATED	by NYPA	02/19/2021
Work scheduled by: NYPA					SCH - OH - NY 1900 MW 1400 MW
					Impacts Total Transfer Capability 50 MW 300 MW
					TTC with All Lines In Service 1950 MW 1700 MW
NIAGARA_-STA_255_345_NH2					FWD
Mon 07/26/2021 to Fri 07/30/2021					(Import)
0500	Continuous	1900	UPDATED	by NYPA	02/19/2021
Work scheduled by: NYPA					DYSINGER EAST 1400 MW
					Impacts Total Transfer Capability 1750 MW
					TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 13, 2021 to Thursday ,October 13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SAND_BAR-PLATSBURG_115_PV20

Tue 08/03/2021 to Tue 08/03/2021
 0700 Continuous 1830
 Work scheduled by: NYPA

SCH - NE - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

KINTIGH_-STA_255_345_SH1-39

Mon 08/09/2021 to Sun 08/15/2021
 0500 Continuous 1900
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **1400 MW**
 Impacts Total Transfer Capability 1750 MW
 TTC with All Lines In Service 3150 MW

NIAGARA_-KINTIGH_345_NS1-38

Mon 08/09/2021 to Sun 08/15/2021
 0500 Continuous 1900
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **1400 MW**
 Impacts Total Transfer Capability 1750 MW
 TTC with All Lines In Service 3150 MW

KINTIGH_-STA_255_345_SH1-39

Mon 08/16/2021 to Sun 08/22/2021
 0500 Continuous 1900
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **1400 MW**
 Impacts Total Transfer Capability 1750 MW
 TTC with All Lines In Service 3150 MW

NIAGARA_-KINTIGH_345_NS1-38

Mon 08/16/2021 to Sun 08/22/2021
 0500 Continuous 1900
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **1400 MW**
 Impacts Total Transfer Capability 1750 MW
 TTC with All Lines In Service 3150 MW

NIAGARA_-STA_255_345_NH2

Wed 09/01/2021 to Tue 09/21/2021
 0500 Continuous 1900
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **1400 MW**
 Impacts Total Transfer Capability 1750 MW
 TTC with All Lines In Service 3150 MW

FRASANNX-COOPERS_345_UCC2-41

Tue 09/07/2021 to Wed 09/15/2021 **UPDATED by NYISO 02/03/2021**
 0700 Continuous 1730
 Work scheduled by: NYPA **ARR: 19**

FWD
 (Import)
 CENTRAL EAST - VC **2500 MW**
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 13, 2021 to Thursday ,October 13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY -FRASANNX_345_UCC2-41

Tue 09/07/2021 to Wed 09/15/2021
0700 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYISO 02/03/2021

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

PORTER -ROTTDAM_230_30

Wed 09/15/2021 to Tue 11/30/2021
0700 Continuous 1730

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **2805 MW**
Impacts Total Transfer Capability 170 MW
TTC with All Lines In Service 2975 MW

EDIC -N.SCTLND_345_14

Thu 09/16/2021 to Sun 11/14/2021
0700 Continuous 1730

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **1670 MW**
Impacts Total Transfer Capability 1305 MW
TTC with All Lines In Service 2975 MW

EDIC -N.SCTLND_345_14 & PORTER -ROTTDAM_230_30

Thu 09/16/2021 to Sun 11/14/2021
0700 1730

Work scheduled by:

FWD
(Import)
CENTRAL EAST - VC **1500 MW**
Impacts Total Transfer Capability 1475 MW
TTC with All Lines In Service 2975 MW

HURLYAVE-ROSETON_345_303

Thu 09/16/2021 to Sun 10/17/2021
0800 Continuous 1600

Work scheduled by: CHGE

UPDATED by CHGE 09/22/2020

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 3715 MW
TTC with All Lines In Service 7815 MW

HOMRC_NY-MAINS_NY_345_47

Sat 09/18/2021 to Fri 11/05/2021
0800 Continuous 1600

Work scheduled by: PJM

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

PANNELL -CLAY_345_1

Mon 09/20/2021 to Fri 09/24/2021
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 13, 2021 to Thursday ,October 13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CLAY -EDIC 345_2-15					FWD
Mon 09/20/2021	to	Sat 10/16/2021			(Import)
0700	Continuous	1730		OSWEGO EXPORT	4850 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 400 MW
					TTC with All Lines In Service 5250 MW
KINTIGH -STA_255_345_SH1-39					FWD
Mon 09/27/2021	to	Wed 09/29/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>03/04/2021</u>
0500	Continuous	0459		DYSINGER EAST	1400 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 1750 MW
					TTC with All Lines In Service 3150 MW
NIAGARA -KINTIGH_345_NS1-38					FWD
Mon 09/27/2021	to	Wed 09/29/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>03/04/2021</u>
0500	Continuous	0459		DYSINGER EAST	1400 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 1750 MW
					TTC with All Lines In Service 3150 MW
PANNELL -CLAY_345_2					FWD
Mon 09/27/2021	to	Fri 10/01/2021			(Import)
0700	Continuous	1530		WEST CENTRAL	1300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 950 MW
					TTC with All Lines In Service 2250 MW
W49TH_ST_345KV_6					FWD
Tue 09/28/2021	to	Tue 09/28/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>01/15/2021</u>
0100	Continuous	0130		SCH - PJM_HTP	300 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 360 MW
					TTC with All Lines In Service 660 MW
E13THSTA-FARRAGUT_345_46					FWD
Tue 09/28/2021	to	Tue 10/26/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>01/15/2021</u>
0100	Continuous	0300		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
W49TH_ST-E13THSTA_345_M55					FWD
Tue 09/28/2021	to	Tue 10/26/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>01/15/2021</u>
0100	Continuous	0300		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 13, 2021 to Thursday ,October 13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

KINTIGH_-STA_255__345_SH1-39

Wed 09/29/2021 to Wed 12/01/2021
0500 Continuous 1900

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

NIAGARA_-KINTIGH__345_NS1-38

Wed 09/29/2021 to Wed 12/01/2021
0500 Continuous 1900

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

LEEDS_-HURLYAVE_345_301

Mon 10/18/2021 to Fri 11/19/2021
0800 Continuous 1600

Work scheduled by: CHGE

FWD

(Import)

UPNY CONED **4100 MW**
Impacts Total Transfer Capability 3715 MW
TTC with All Lines In Service 7815 MW

GOETHALS_345KV_5

Thu 10/21/2021 to Sat 11/20/2021 **UPDATED by CONED 03/05/2021**
0001 Continuous 0200

Work scheduled by: ConEd

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

W49TH_ST_345KV_6

Tue 10/26/2021 to Tue 10/26/2021 **UPDATED by CONED 01/15/2021**
0230 Continuous 0300

Work scheduled by: ConEd

FWD

(Import)

SCH - PJM_HTP **300 MW**
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

SCH-IMO-NYISO_LIMIT_1750

Mon 11/01/2021 to Fri 12/31/2021 **UPDATED by IESO 05/03/2019**
0001 Continuous 2359

Work scheduled by: IESO

FWD

(Import)

SCH - OH - NY **2050 MW**
Impacts Total Transfer Capability 250 MW
TTC with All Lines In Service 2300 MW

SCH-NYISO-IMO_LIMIT_1600

Mon 11/01/2021 to Fri 12/31/2021 **UPDATED by IESO 05/03/2019**
0001 Continuous 2359

Work scheduled by: IESO

REV

(Export)

SCH - OH - NY **1900 MW**
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 2000 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 13, 2021 to Thursday ,October 13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LINDN_CG-LNDVFT___345_V-3022				
Tue 11/02/2021	to	Fri 11/05/2021		FWD
0800	Continuous	1500		(Import) (Export)
Work scheduled by: PJM			SCH - PJM_VFT	0 MW 0 MW
			Impacts Total Transfer Capability	315 MW 315 MW
			TTC with All Lines In Service	315 MW 315 MW
PORTER_-ROTTDAM_230_30 & MASSENA_-MARCY___765_MSU1				
Mon 11/15/2021	to	Tue 11/30/2021		FWD
0100		1730		(Import)
Work scheduled by:			CENTRAL EAST - VC	1500 MW
			Impacts Total Transfer Capability	1475 MW
			TTC with All Lines In Service	2975 MW
CHATGUAY-MASSENA___765_7040				
Mon 11/15/2021	to	Tue 11/30/2021		FWD
0100	Continuous	1859		(Import)
Work scheduled by: NYPA			MOSES SOUTH	1550 MW
			Impacts Total Transfer Capability	1600 MW
			TTC with All Lines In Service	3150 MW
CHATGUAY-MASSENA___765_7040				
Mon 11/15/2021	to	Tue 11/30/2021		FWD
0100	Continuous	1859		(Import) (Export)
Work scheduled by: NYPA			SCH - HQ - NY	0 MW 0 MW
			Impacts Total Transfer Capability	1500 MW 1000 MW
			TTC with All Lines In Service	1500 MW 1000 MW
MARCY___765_345_AT1				
Mon 11/15/2021	to	Tue 11/30/2021		FWD
0100	Continuous	1859		(Import)
Work scheduled by: NYPA			MOSES SOUTH	1750 MW
			Impacts Total Transfer Capability	1400 MW
			TTC with All Lines In Service	3150 MW
ARR: 19				
MARCY___765_345_AT2				
Mon 11/15/2021	to	Tue 11/30/2021		FWD
0100	Continuous	1859		(Import)
Work scheduled by: NYPA			MOSES SOUTH	1700 MW
			Impacts Total Transfer Capability	1450 MW
			TTC with All Lines In Service	3150 MW
ARR: 19				
MASSENA_-MARCY___765_MSU1				
Mon 11/15/2021	to	Tue 11/30/2021		FWD
0100	Continuous	1859		(Import)
Work scheduled by: NYPA			CENTRAL EAST - VC	1670 MW
			Impacts Total Transfer Capability	1305 MW
			TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 13, 2021 to Thursday ,October 13, 2022

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA -MARCY 765_MSU1			FWD	
Mon 11/15/2021	to	Tue 11/30/2021	(Import)	
0100	Continuous	1859	MOSES SOUTH	500 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	2650 MW
			TTC with All Lines In Service	3150 MW
MASSENA -MARCY 765_MSU1			FWD	REV
Mon 11/15/2021	to	Tue 11/30/2021	(Import)	(Export)
0100	Continuous	1859	SCH - HQ - NY	475 MW 1000 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1025 MW 0 MW
			TTC with All Lines In Service	1500 MW 1000 MW
MASSENA -MARCY 765_MSU1			FWD	
Mon 11/15/2021	to	Tue 11/30/2021	(Import)	
0100	Continuous	1859	SCH - HQ_CEDARS	90 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	109 MW
			TTC with All Lines In Service	199 MW
MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040			FWD	
Mon 11/15/2021	to	Tue 11/30/2021	(Import)	
0100		1859	MOSES SOUTH	500 MW
Work scheduled by:			Impacts Total Transfer Capability	2650 MW
			TTC with All Lines In Service	3150 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2			FWD	REV
Mon 11/15/2021	to	Tue 11/30/2021	(Import)	(Export)
0100		1859	SCH - HQ - NY	850 MW 0 MW
Work scheduled by:			Impacts Total Transfer Capability	650 MW 1000 MW
			TTC with All Lines In Service	1500 MW 1000 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2			FWD	
Mon 11/15/2021	to	Tue 11/30/2021	(Import)	
0100		1859	SCH - HQ_CEDARS	90 MW
Work scheduled by:			Impacts Total Transfer Capability	109 MW
			TTC with All Lines In Service	199 MW
STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1			FWD	
Mon 11/15/2021	to	Tue 11/30/2021	(Import)	
0100		1859	SCH - HQ_CEDARS	90 MW
Work scheduled by:			Impacts Total Transfer Capability	109 MW
			TTC with All Lines In Service	199 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 13, 2021 to Thursday ,October 13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STLAWRNC-MOSES___230_L33P & MOSES___-MASSENA_230_MMS1 & MOSES___-			FWD
MASSENA_230_MMS2			(Import)
Mon 11/15/2021	to	Tue 11/30/2021	SCH - HQ_CEDARS 90 MW
0100		1859	Impacts Total Transfer Capability 109 MW
Work scheduled by:			TTC with All Lines In Service 199 MW
FRASER___345_FRASER SVC			FWD
			(Import)
Wed 12/01/2021	to	Mon 02/28/2022	CENTRAL EAST - VC 2935 MW
0700	Continuous	1730	Impacts Total Transfer Capability 40 MW
Work scheduled by: NYPA			TTC with All Lines In Service 2975 MW
MOSES___-ADIRNDCK_230_MAI			FWD
			(Import)
Wed 12/01/2021	to	Tue 05/31/2022	MOSES SOUTH 2300 MW
0700	Continuous	1300	Impacts Total Transfer Capability 850 MW
Work scheduled by: NYPA			TTC with All Lines In Service 3150 MW
NIAGARA_-STA_255__345_NH2			FWD
			(Import)
Thu 12/02/2021	to	Thu 01/13/2022	DYSINGER EAST 1700 MW
0500	Continuous	1900	Impacts Total Transfer Capability 1450 MW
Work scheduled by: NYPA			TTC with All Lines In Service 3150 MW
MOTTHAVN-RAINEY___345_Q12			FWD
			(Import)
Sun 12/05/2021	to	Sat 12/25/2021	UPDATED by CONED 03/25/2021
0001	Continuous	0159	SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 800 MW
			TTC with All Lines In Service 4600 MW
LEEDS___-PLSNTVLY_345_92			FWD
			(Import)
Thu 02/17/2022	to	Mon 02/21/2022	UPDATED by NGRID 03/31/2021
0600	Continuous	1900	UPNY CONED 3800 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability 2420 MW
			TTC with All Lines In Service 6220 MW
GOETHALS_345KV_5			
Sat 03/05/2022	to	Mon 04/04/2022	UPDATED by CONED 03/26/2021
0001	Continuous	0200	STATEN ISLAND
Work scheduled by: ConEd			Impacts Total Transfer Capability
			TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Tuesday ,April 13, 2021 to Thursday ,October 13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LINDEN__-GOETHALS_230_A2253

Sat 03/05/2022 to Mon 04/04/2022
0001 Continuous 0200

UPDATED by CONED 03/26/2021

Work scheduled by: ConEd

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

N. SCTLND-ALPS_____345_2

Mon 05/02/2022 to Mon 05/09/2022
0600 Daily 1800

Work scheduled by: NGrid

FWD
(Import)
SCH - NE - NY **750 MW**
Impacts Total Transfer Capability 650 MW
TTC with All Lines In Service 1400 MW

N. SCTLND-ALPS_____345_2

Mon 05/02/2022 to Mon 05/09/2022
0600 Daily 1800

Work scheduled by: NGrid

FWD REV
(Import) (Export)
SCH - NPX_1385 **100 MW 100 MW**
Impacts Total Transfer Capability 100 MW 100 MW
TTC with All Lines In Service 200 MW 200 MW

HOMRC_NY-MAINS_NY_345_47

Fri 05/20/2022 to Fri 05/27/2022
0800 Continuous 1600

Work scheduled by: PJM

UPDATED by PJM 11/19/2020

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

HOMR_NYW-PIERC_NY_345_48

Fri 05/20/2022 to Fri 05/27/2022
0800 Continuous 1600

Work scheduled by: PJM

UPDATED by PJM 11/19/2020

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

MOSES__-ADIRNDCK_230_MA2

Wed 06/01/2022 to Mon 11/14/2022
0700 Continuous 1300

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

SPRNBRK__345KV_RNS5

Mon 09/19/2022 to Mon 09/19/2022
0001 Continuous 0030

Work scheduled by: ConEd

UPDATED by CONED 09/17/2020

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 13, 2021 to Thursday ,October 13, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK_-W49TH_ST_345_M51

Mon 09/19/2022 to Wed 09/21/2022
 0001 Continuous 2200
 Work scheduled by: ConEd

UPDATED by CONED 09/17/2020

SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

FWD
 (Import)

SPRNBRK_345KV_RNS5

Wed 09/21/2022 to Wed 09/21/2022
 2130 Continuous 2200
 Work scheduled by: ConEd

UPDATED by CONED 09/17/2020

SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

FWD
 (Import)

SPRNBRK_-W49TH_ST_345_M51

Sat 10/01/2022 to Mon 10/17/2022
 0001 Continuous 0300
 Work scheduled by: ConEd

UPDATED by CONED 08/01/2020

SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

FWD
 (Import)

SPRNBRK_345KV_RNS5

Sat 10/01/2022 to Mon 10/17/2022
 0001 Continuous 0300
 Work scheduled by: ConEd

UPDATED by CONED 08/01/2020

SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

FWD
 (Import)