

NYISO TRANSFER LIMITATIONS

Friday ,April 16, 2021 to Sunday ,October 16, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Wed 06/30/2021 **EXT FORCE** **by CONED** **08/28/2020**
 0001 Continuous 2359
 Work scheduled by: ConEd

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Wed 06/30/2021
 0001 2359
 Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2550 MW	1900 MW
Impacts Total Transfer Capability	250 MW	50 MW
TTC with All Lines In Service	2800 MW	1950 MW

MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Wed 06/30/2021 **EXT FORCE** **by CONED** **08/28/2020**
 0001 Continuous 2359
 Work scheduled by: ConEd

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

STLAWRNC-MOSES_230_L33P

Mon 04/30/2018 to Mon 10/31/2022 **EXT FORCE** **by IESO** **10/01/2020**
 0456 Continuous 1600
 Work scheduled by: IESO

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

NEWBRDGE_345_138_BK_1

Wed 09/02/2020 to Tue 02/01/2022 **EXT FORCE** **by LI** **01/12/2021**
 1807 Continuous 2359
 Work scheduled by: LI

	FWD
	(Import)
SCH - PJM_NEPTUNE	375 MW
Impacts Total Transfer Capability	285 MW
TTC with All Lines In Service	660 MW

SPRNBK_-EGRDNCTR_345_Y49

Thu 10/01/2020 to Mon 04/19/2021 **EXT FORCE** **by LI** **02/23/2021**
 0404 Continuous 2359
 Work scheduled by: LI

	FWD
	(Import)
CONED - LIPA	775 MW
Impacts Total Transfer Capability	725 MW
TTC with All Lines In Service	1500 MW

EGRDNCTY_345_138_AT2

Sat 10/10/2020 to Mon 04/19/2021 **EXT FORCE** **by LI** **02/23/2021**
 1815 Continuous 2359
 Work scheduled by: LI

	FWD
	(Import)
CONED - LIPA	1250 MW
Impacts Total Transfer Capability	250 MW
TTC with All Lines In Service	1500 MW

NYISO TRANSFER LIMITATIONS

Friday ,April 16, 2021 to Sunday ,October 16, 2022

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EGRDNCTY_345_138_AT1						FWD
Sat 10/10/2020	to	Mon 04/19/2021	<u>EXT FORCE</u>	<u>by LI</u>	<u>02/23/2021</u>	(Import)
1856	Continuous	2359				CONED - LIPA 1250 MW
Work scheduled by: LI						Impacts Total Transfer Capability 250 MW
						TTC with All Lines In Service 1500 MW
SCH-IMO-NYISO_LIMIT_1750						FWD
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Import)
0001	Continuous	2359				SCH - OH - NY 2050 MW
Work scheduled by: IESO						Impacts Total Transfer Capability 250 MW
						TTC with All Lines In Service 2300 MW
SCH-NYISO-IMO_LIMIT_1600						REV
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Export)
0001	Continuous	2359				SCH - OH - NY 1900 MW
Work scheduled by: IESO						Impacts Total Transfer Capability 100 MW
						TTC with All Lines In Service 2000 MW
SAND_BAR-PLATSBRG_115_PV20						
Tue 02/23/2021	to	Mon 05/17/2021	<u>UPDATED</u>	<u>by NYISO</u>	<u>03/16/2021</u>	
1801	Continuous	0559				SCH - NE - NY
Work scheduled by: ISONE						Impacts Total Transfer Capability
						TTC with All Lines In Service
W49TH_ST_345KV_8						FWD
Tue 03/02/2021	to	Sun 05/02/2021	<u>EXTENDED</u>	<u>by CONED</u>	<u>04/10/2021</u>	(Import)
0201	Continuous	0200				SCH - PJM_HTP 300 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 360 MW
						TTC with All Lines In Service 660 MW
PORTER__-ROTTRDAM_230_31						FWD
Tue 03/02/2021	to	Mon 05/31/2021	<u>UPDATED</u>	<u>by NGRID</u>	<u>03/10/2021</u>	(Import)
0600	Continuous	1730				CENTRAL EAST - VC 2805 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability 170 MW
						TTC with All Lines In Service 2975 MW
MOSES__-ADIRNDCK_230_MAL						FWD
Tue 03/02/2021	to	Mon 05/10/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>02/11/2021</u>	(Import)
0700	Continuous	1159				MOSES SOUTH 2300 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 850 MW
						TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,April 16, 2021 to Sunday ,October 16, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_6

Sun 03/21/2021 to Sun 05/02/2021 **EXTENDED** **by CONED** **04/10/2021**
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

EDIC -N.SCTLND_345_14 & PORTER -ROTTDAM_230_31

Mon 03/22/2021 to Mon 05/31/2021
 0600 1730
 Work scheduled by:

FWD
 (Import)
 CENTRAL EAST - VC **1500 MW**
 Impacts Total Transfer Capability 1475 MW
 TTC with All Lines In Service 2975 MW

EDIC -N.SCTLND_345_14

Mon 03/22/2021 to Mon 05/31/2021 **UPDATED** **by NGRID** **03/10/2021**
 0600 Continuous 1830
 Work scheduled by: NGrid

FWD
 (Import)
 CENTRAL EAST - VC **1670 MW**
 Impacts Total Transfer Capability 1305 MW
 TTC with All Lines In Service 2975 MW

NINEMILE-CLAY_345_8

Tue 04/06/2021 to Sun 04/11/2021 **UPDATED** **by NGRID** **04/03/2021**
 1600 Daily 0500
 Work scheduled by: NGrid

FWD
 (Import)
 OSWEGO EXPORT **5150 MW**
 Impacts Total Transfer Capability 100 MW
 TTC with All Lines In Service 5250 MW

MOTTHAVN-RAINEY_345_Q11

Thu 04/08/2021 to Mon 04/12/2021 **EXT FORCE** **by CONED** **04/11/2021**
 2309 Continuous 2359
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

S.RIPLEY-DUNKIRK_230_68

Mon 04/12/2021 to Fri 04/23/2021 **UPDATED** **by NGRID** **04/12/2021**
 0630 Continuous 1700
 Work scheduled by: NGrid

FWD
 (Import)
 SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

LEEDS_345KV_R94301

Mon 04/12/2021 to Mon 04/12/2021 **UPDATED** **by NGRID** **02/01/2021**
 0800 Continuous 0830
 Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 2420 MW
 TTC with All Lines In Service 6220 MW

NYISO TRANSFER LIMITATIONS

Friday ,April 16, 2021 to Sunday ,October 16, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						FWD
LEEDS___-HURLYAVE_345_301						(Import)
Mon 04/12/2021	to	Wed 04/14/2021	<u>UPDATED</u>	<u>by NGRID</u>	<u>02/01/2021</u>	
0800	Continuous	1825				UPNY CONED 4100 MW
Work scheduled by: CHGE						Impacts Total Transfer Capability 2120 MW
						TTC with All Lines In Service 6220 MW
<hr/>						FWD
SPRNBRK_-W49TH_ST_345_M51						(Import)
Wed 04/14/2021	to	Mon 04/26/2021	<u>EXTENDED</u>	<u>by CONED</u>	<u>04/16/2021</u>	
1124	Continuous	2359				SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 1400 MW
						TTC with All Lines In Service 4600 MW
<hr/>						FWD
DUNWODIE_345KV_6						(Import)
Tue 04/20/2021	to	Tue 04/20/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>02/19/2021</u>	
0201	Continuous	0230				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
<hr/>						FWD
DUNWODIE_345KV_8						(Import)
Tue 04/20/2021	to	Tue 04/20/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>02/19/2021</u>	
0201	Continuous	0230				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
<hr/>						FWD
WOOD_ST_-PLSNTVLE_345_Y87						(Import)
Tue 04/20/2021	to	Tue 04/20/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>02/19/2021</u>	
0201	Continuous	0230				UPNY CONED 5905 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 315 MW
						TTC with All Lines In Service 6220 MW
<hr/>						FWD
PLSNTVLE-DUNWODIE_345_W90						(Import)
Tue 04/20/2021	to	Fri 04/23/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>02/19/2021</u>	
0201	Continuous	0159				UPNY CONED 4000 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 2220 MW
						TTC with All Lines In Service 6220 MW
<hr/>						FWD
MAINESBG-WATRCURE_345_30						(Import)
Tue 04/20/2021	to	Wed 04/21/2021				SCH - PJ - NY 2300 MW
0800	Continuous	1530				Impacts Total Transfer Capability 500 MW
Work scheduled by: NYSEG						TTC with All Lines In Service 2800 MW

NYISO TRANSFER LIMITATIONS

Friday ,April 16, 2021 to Sunday ,October 16, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

			FWD	REV
			(Import)	(Export)
NRTH1385-NOR HBR__138_601				
Wed 04/21/2021	to	Wed 04/21/2021		
0800	Continuous	1600	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_602				
Wed 04/21/2021	to	Wed 04/21/2021		
0800		1600	SCH - NPX_1385	0 MW 0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_603				
Wed 04/21/2021	to	Wed 04/21/2021		
0800		1600	SCH - NPX_1385	0 MW 0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_602				
Wed 04/21/2021	to	Wed 04/21/2021		
0800	Continuous	1600	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_602 & NRTH1385-NOR HBR__138_603				
Wed 04/21/2021	to	Wed 04/21/2021		
0800		1600	SCH - NPX_1385	0 MW 0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_603				
Wed 04/21/2021	to	Wed 04/21/2021		
0800	Continuous	1600	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NRTHPORT_138_NNC				
Wed 04/21/2021	to	Wed 04/21/2021		
0800	Continuous	1600	SCH - NPX_1385	0 MW 0 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW

NYISO TRANSFER LIMITATIONS

Friday ,April 16, 2021 to Sunday ,October 16, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_6					FWD	
Fri 04/23/2021	to	Fri 04/23/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>02/19/2021</u>	(Import)
0130	Continuous	0159				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_8					FWD	
Fri 04/23/2021	to	Fri 04/23/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>02/19/2021</u>	(Import)
0130	Continuous	0159				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
WOOD_ST_-PLSNTVLE_345_Y87					FWD	
Fri 04/23/2021	to	Fri 04/23/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>02/19/2021</u>	(Import)
0130	Continuous	0159				UPNY CONED 5905 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	315 MW
					TTC with All Lines In Service	6220 MW
PLSNTVLY-WOOD_ST__345_F30					FWD	
Fri 04/23/2021	to	Fri 04/23/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>04/02/2021</u>	(Import)
0201	Continuous	0230				UPNY CONED 4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	2220 MW
					TTC with All Lines In Service	6220 MW
PLSNTVLY_345KV_RNS5					FWD	
Fri 04/23/2021	to	Fri 04/23/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>04/02/2021</u>	(Import)
0201	Continuous	0230				UPNY CONED 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	2420 MW
					TTC with All Lines In Service	6220 MW
MILLWOOD-EASTVIEW_345_W82					FWD	
Fri 04/23/2021	to	Fri 04/23/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>04/02/2021</u>	(Import)
0201	Continuous	1800				UPNY CONED 5985 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	235 MW
					TTC with All Lines In Service	6220 MW
MILLWOOD_345KV_18					FWD	
Fri 04/23/2021	to	Sat 04/24/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>04/02/2021</u>	(Import)
0201	Continuous	2200				UPNY CONED 4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1870 MW
					TTC with All Lines In Service	6220 MW

NYISO TRANSFER LIMITATIONS

Friday ,April 16, 2021 to Sunday ,October 16, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					FWD
CHAT_DC_GC1					(Import)
Sat 04/24/2021	to	Sun 04/25/2021			
2000	Continuous	0500		MOSES SOUTH	2850 MW
Work scheduled by: HQ					Impacts Total Transfer Capability 300 MW
					TTC with All Lines In Service 3150 MW
<hr/>					
CHAT_DC_GC1					REV
					(Export)
Sat 04/24/2021	to	Sun 04/25/2021			
2000	Continuous	0500		SCH - HQ - NY	500 MW
Work scheduled by: HQ					Impacts Total Transfer Capability 500 MW
					TTC with All Lines In Service 1000 MW
<hr/>					
PLSNTVLY-WOOD_ST_345_F30					FWD
					(Import)
Mon 04/26/2021	to	Tue 04/27/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>04/02/2021</u>
0001	Continuous	0200		UPNY CONED	4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 2220 MW
					TTC with All Lines In Service 6220 MW
<hr/>					
PLSNTVLY_345KV_RNS5					FWD
					(Import)
Mon 04/26/2021	to	Tue 04/27/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>04/02/2021</u>
0001	Continuous	0200		UPNY CONED	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 2420 MW
					TTC with All Lines In Service 6220 MW
<hr/>					
KINTIGH_-STA_255_345_SH1-39					FWD
					(Import)
Mon 04/26/2021	to	Fri 04/30/2021			
0700	Continuous	1700		DYSINGER EAST	1700 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 1450 MW
					TTC with All Lines In Service 3150 MW
<hr/>					
NIAGARA_-KINTIGH_345_NS1-38					FWD
					(Import)
Mon 04/26/2021	to	Fri 04/30/2021			
0700	Continuous	1700		DYSINGER EAST	1700 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 1450 MW
					TTC with All Lines In Service 3150 MW
<hr/>					
HOMRC_NY-MAINS_NY_345_47					
Mon 04/26/2021	to	Sat 05/29/2021	<u>EXTENDED</u>	<u>by NYSEG</u>	<u>03/10/2021</u>
0800	Continuous	1900		SCH - PJ - NY	
Work scheduled by: NYSEG					Impacts Total Transfer Capability
					TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Friday ,April 16, 2021 to Sunday ,October 16, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASER__-COOPERS__345_33

Mon 04/26/2021 to Fri 04/30/2021
 0830 Continuous 1500
 Work scheduled by: NYSEG

FWD
 (Import)
 CENTRAL EAST - VC **2395 MW**
 Impacts Total Transfer Capability 580 MW
 TTC with All Lines In Service 2975 MW

ALCOA_PA_115KV_R8105

Tue 04/27/2021 to Thu 04/29/2021
 0630 Continuous 1830
 Work scheduled by: NGrid

FWD
 (Import)
 MOSES SOUTH **3100 MW**
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 3150 MW

MOTTHAVN-RAINEY__345_Q11

Wed 04/28/2021 to Sat 05/08/2021
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

BUCHAN_N-EASTVIEW_345_W93

Fri 04/30/2021 to Sun 05/09/2021 **UPDATED by CONED 04/07/2021**
 0700 Continuous 2359
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1870 MW
 TTC with All Lines In Service 6220 MW

SCH-IMO-NYISO_LIMIT_1600

Sat 05/01/2021 to Sun 10/31/2021 **UPDATED by IESO 05/03/2019**
 0001 Continuous 2359
 Work scheduled by: IESO

FWD
 (Import)
 SCH - OH - NY **1900 MW**
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 1950 MW

W49TH_ST_345KV_5

Sun 05/02/2021 to Sun 05/02/2021 **UPDATED by CONED 04/13/2021**
 0201 Continuous 0231
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

W49TH_ST_345KV_7

Sun 05/02/2021 to Sun 05/02/2021 **UPDATED by CONED 04/13/2021**
 0201 Continuous 0231
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Friday ,April 16, 2021 to Sunday ,October 16, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event ID	Start Date	End Date	Time	Duration	Work Scheduled by	Transfer Direction	Impact	TTC with All Lines In Service
CHAT_DC_GC2	Sun 05/02/2021	Fri 05/28/2021	0500	Continuous	1700	HQ	FWD (Import)	MOSES SOUTH 2850 MW
							Impacts Total Transfer Capability	300 MW
							TTC with All Lines In Service	3150 MW
CHAT_DC_GC2	Sun 05/02/2021	Fri 05/28/2021	0500	Continuous	1700	HQ	REV (Export)	SCH - HQ - NY 500 MW
							Impacts Total Transfer Capability	500 MW
							TTC with All Lines In Service	1000 MW
DUNWODIE_345KV_7	Mon 05/03/2021	Mon 05/03/2021	0001	Continuous	0030	ConEd	FWD (Import)	SPR/DUN-SOUTH 3800 MW
							Impacts Total Transfer Capability	800 MW
							TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_8	Mon 05/03/2021	Mon 05/03/2021	0001	Continuous	0030	ConEd	FWD (Import)	SPR/DUN-SOUTH 3800 MW
							Impacts Total Transfer Capability	800 MW
							TTC with All Lines In Service	4600 MW
DUNWODIE-MOTTHAVN_345_72	Mon 05/03/2021	Mon 05/03/2021	0001	Continuous	1800	ConEd	FWD (Import)	SPR/DUN-SOUTH 3800 MW
							Impacts Total Transfer Capability	800 MW
							TTC with All Lines In Service	4600 MW
NRTH1385-NOR HBR_138_601	Mon 05/03/2021	Mon 05/24/2021	0600	Continuous	2359	LI	FWD (Import) / REV (Export)	SCH - NPX_1385 100 MW / 100 MW
							Impacts Total Transfer Capability	100 MW / 100 MW
							TTC with All Lines In Service	200 MW / 200 MW
NRTH1385-NOR HBR_138_601 & NRTH1385-NOR HBR_138_602	Mon 05/03/2021	Mon 05/24/2021	0600	Continuous	2359		FWD (Import) / REV (Export)	SCH - NPX_1385 0 MW / 0 MW
							Impacts Total Transfer Capability	200 MW / 200 MW
							TTC with All Lines In Service	200 MW / 200 MW

NYISO TRANSFER LIMITATIONS

Friday ,April 16, 2021 to Sunday ,October 16, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_603

Mon 05/03/2021 to Mon 05/24/2021
 0600 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

NRTH1385-NOR HBR__138_602

Mon 05/03/2021 to Mon 05/24/2021
 0600 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

NRTH1385-NOR HBR__138_602 & NRTH1385-NOR HBR__138_603

Mon 05/03/2021 to Mon 05/24/2021
 0600 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

NRTH1385-NOR HBR__138_603

Mon 05/03/2021 to Mon 05/24/2021
 0600 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

NRTH1385-NRTHPORT_138_NNC

Mon 05/03/2021 to Mon 05/24/2021
 0600 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

CLAY__-EDIC__345_2-15

Mon 05/03/2021 to Fri 05/07/2021
 0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
OSWEGO EXPORT	4850 MW
Impacts Total Transfer Capability	400 MW
TTC with All Lines In Service	5250 MW

FIVEMILE-STOLLERD_345_29

Mon 05/03/2021 to Fri 05/14/2021
 0700 Continuous 1400

Work scheduled by: NYSEG

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Friday ,April 16, 2021 to Sunday ,October 16, 2022

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-HQ-NYISO_LIMIT_1400				FWD	
Mon 05/03/2021	to	Fri 05/14/2021		(Import)	
0700	Continuous	1530	SCH - HQ - NY	1400 MW	
Work scheduled by: HQ			Impacts Total Transfer Capability	100 MW	
			TTC with All Lines In Service	1500 MW	
PANNELL -CLAY_345_2				FWD	
Mon 05/03/2021	to	Sun 05/30/2021		(Import)	
0700	Continuous	1730	WEST CENTRAL	1300 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	950 MW	
			TTC with All Lines In Service	2250 MW	
HURLYAVE-ROSETON_345_303				FWD	
Mon 05/03/2021	to	Fri 05/21/2021		(Import)	
0800	Continuous	1600	UPNY CONED	4100 MW	
Work scheduled by: CHGE			Impacts Total Transfer Capability	3715 MW	
			TTC with All Lines In Service	7815 MW	
SHOR_NPX-SHOREHAM_138_CSC				FWD	REV
Mon 05/03/2021	to	Sat 05/08/2021	EXTENDED by ISONE 03/15/2021	(Import)	(Export)
0900	Continuous	1600	SCH - NPX_CSC	0 MW	0 MW
Work scheduled by: LI			Impacts Total Transfer Capability	330 MW	330 MW
			TTC with All Lines In Service	330 MW	330 MW
DUNWODIE_345KV_7				FWD	
Mon 05/03/2021	to	Mon 05/03/2021		(Import)	
1730	Continuous	1800	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
DUNWODIE_345KV_8				FWD	
Mon 05/03/2021	to	Mon 05/03/2021		(Import)	
1730	Continuous	1800	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
ROTTDAM-EASTOVER_230_38					REV
Tue 05/04/2021	to	Tue 05/04/2021		(Export)	
0830	Daily(No Weekends)	1130	SCH - NE - NY		1400 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	200 MW	
			TTC with All Lines In Service	1600 MW	

ARR: 77

NYISO TRANSFER LIMITATIONS

Friday ,April 16, 2021 to Sunday ,October 16, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

RAMAPO__-BUCHAN_N_345_Y94					FWD
Fri 05/07/2021	to	Sun 05/09/2021	<u>UPDATED</u>	<u>by CONED</u> <u>04/07/2021</u>	(Import)
0001	Continuous	2359			UPNY CONED 7580 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 235 MW
					TTC with All Lines In Service 7815 MW
EASTVIEW-SPRNBK__345_W79					FWD
Sat 05/08/2021	to	Sun 05/09/2021	<u>UPDATED</u>	<u>by CONED</u> <u>04/07/2021</u>	(Import)
0700	Continuous	2359			UPNY CONED 4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 3465 MW
					TTC with All Lines In Service 7815 MW
W49TH_ST_345KV_5					FWD
Sun 05/09/2021	to	Sun 05/09/2021	<u>UPDATED</u>	<u>by CONED</u> <u>04/13/2021</u>	(Import)
0130	Continuous	0200			SCH - PJM_HTP 300 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 360 MW
					TTC with All Lines In Service 660 MW
W49TH_ST_345KV_7					FWD
Sun 05/09/2021	to	Sun 05/09/2021	<u>UPDATED</u>	<u>by CONED</u> <u>04/13/2021</u>	(Import)
0130	Continuous	0200			SCH - PJM_HTP 300 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 360 MW
					TTC with All Lines In Service 660 MW
W49TH_ST_345KV_7					FWD
Mon 05/10/2021	to	Mon 05/10/2021			(Import)
0001	Continuous	0030			SCH - PJM_HTP 300 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 360 MW
					TTC with All Lines In Service 660 MW
W49TH_ST_345KV_8					FWD
Mon 05/10/2021	to	Mon 05/10/2021			(Import)
0001	Continuous	0030			SCH - PJM_HTP 450 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 210 MW
					TTC with All Lines In Service 660 MW
HUDSONTP-W49TH_ST_345_Y56					FWD
Mon 05/10/2021	to	Thu 05/13/2021			(Import)
0001	Continuous	2300			SCH - PJM_HTP 0 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 660 MW
					TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Friday ,April 16, 2021 to Sunday ,October 16, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_-TREMONT__345_X28					FWD	
Mon 05/10/2021	to	Wed 05/26/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>03/18/2021</u>	(Import)
0001	Continuous	0200				SPR/DUN-SOUTH 4200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	400 MW
					TTC with All Lines In Service	4600 MW
CLAY_-EDIC__345_1-16					FWD	
Mon 05/10/2021	to	Fri 05/14/2021				(Import)
0700	Continuous	1530				OSWEGO EXPORT 4850 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	400 MW
					TTC with All Lines In Service	5250 MW
MOSES_-ADIRNDCK_230_MA2					FWD	
Mon 05/10/2021	to	Tue 06/01/2021				(Import)
1200	Continuous	0659				MOSES SOUTH 2100 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	3150 MW
ALCOA_PA_115KV_R8105					FWD	
Tue 05/11/2021	to	Thu 06/03/2021				(Import)
0630	Continuous	1630				MOSES SOUTH 3100 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	3150 MW
DENNISON-ROSEMNTB_115_2/22					FWD	REV
Wed 05/12/2021	to	Wed 05/12/2021	<u>UPDATED</u>	<u>by HQ</u>	<u>04/16/2021</u>	(Import) (Export)
0630	Daily(No Weekends)	1830				SCH - HQ_CEDARS 95 MW 40 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	95 MW 0 MW
					TTC with All Lines In Service	190 MW 40 MW
SCH-HQ_CEDARS-NYISO_LIMIT_80					FWD	
Wed 05/12/2021	to	Wed 05/12/2021	<u>UPDATED</u>	<u>by HQ</u>	<u>04/16/2021</u>	(Import)
0630	Daily(No Weekends)	1830				SCH - HQ_CEDARS 80 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	110 MW
					TTC with All Lines In Service	190 MW
W49TH_ST_345KV_7					FWD	
Thu 05/13/2021	to	Thu 05/13/2021				(Import)
2230	Continuous	2300				SCH - PJM_HTP 300 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	360 MW
					TTC with All Lines In Service	660 MW

NYISO TRANSFER LIMITATIONS

Friday ,April 16, 2021 to Sunday ,October 16, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_8			FWD	
Thu 05/13/2021	to	Thu 05/13/2021	(Import)	
2230	Continuous	2300	SCH - PJM_HTP	450 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	210 MW
			TTC with All Lines In Service	660 MW
CRICKVLY-PLSNTVLY_345_F83			FWD	
Fri 05/14/2021	to	Fri 05/14/2021	(Import)	
0001	Continuous	2200	SCH - NE - NY	350 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	1050 MW
			TTC with All Lines In Service	1400 MW
CRICKVLY-PLSNTVLY_345_F83			FWD	REV
Fri 05/14/2021	to	Fri 05/14/2021	(Import)	(Export)
0001	Continuous	2200	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR_138_601 & CRICKVLY-PLSNTVLY_345_F83			FWD	REV
Fri 05/14/2021	to	Fri 05/14/2021	(Import)	(Export)
0001		2200	SCH - NPX_1385	0 MW 0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR_138_602 & CRICKVLY-PLSNTVLY_345_F83			FWD	REV
Fri 05/14/2021	to	Fri 05/14/2021	(Import)	(Export)
0001		2200	SCH - NPX_1385	0 MW 0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR_138_603 & CRICKVLY-PLSNTVLY_345_F83			FWD	REV
Fri 05/14/2021	to	Fri 05/14/2021	(Import)	(Export)
0001		2200	SCH - NPX_1385	0 MW 0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
BUCHAN_N-EASTVIEW_345_W93			FWD	
Fri 05/14/2021	to	Sat 05/15/2021	(Import)	
0001	Continuous	0200	UPNY CONED	4350 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	3465 MW
			TTC with All Lines In Service	7815 MW

NYISO TRANSFER LIMITATIONS

Friday ,April 16, 2021 to Sunday ,October 16, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

RAMAPO__-BUCHAN_N_345_Y94					FWD
Fri 05/14/2021	to	Sat 05/15/2021			(Import)
0001	Continuous	0200		UPNY CONED	7580 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 235 MW
					TTC with All Lines In Service 7815 MW
SPRNBRK__345KV_RS3 & SPRNBRK__345KV_RS4					FWD
Sat 05/15/2021	to	Sat 05/15/2021			(Import)
0301		2230		SPR/DUN-SOUTH	3200 MW
Work scheduled by:					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_5					FWD
Mon 05/17/2021	to	Tue 05/18/2021	UPDATED	by CE	03/15/2021
0201	Continuous	0200			SPR/DUN-SOUTH
Work scheduled by: ConEd					3800 MW
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_7					FWD
Mon 05/17/2021	to	Tue 05/18/2021	UPDATED	by CE	03/15/2021
0201	Continuous	0200			SPR/DUN-SOUTH
Work scheduled by: ConEd					3800 MW
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
SPRNBRK_-DUNWODIE_345_W75					FWD
Mon 05/17/2021	to	Tue 05/18/2021	UPDATED	by CE	03/15/2021
0201	Continuous	0200			SPR/DUN-SOUTH
Work scheduled by: ConEd					3800 MW
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
SPRNBRK__345KV_RNS3					FWD
Mon 05/17/2021	to	Tue 05/18/2021	UPDATED	by CE	03/15/2021
0201	Continuous	0200			SPR/DUN-SOUTH
Work scheduled by: ConEd					3800 MW
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
NIAGARA_-STA_255__345_NH2					FWD
Mon 05/17/2021	to	Fri 05/21/2021	UPDATED	by NYPA	03/23/2021
0500	Continuous	1700			DYSINGER EAST
Work scheduled by: NYPA					1400 MW
					Impacts Total Transfer Capability 1750 MW
					TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,April 16, 2021 to Sunday ,October 16, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SAND_BAR-PLATSBURG_115_PV20

Mon 05/17/2021 to Fri 07/02/2021
 0600 Continuous 1800
 Work scheduled by: ISONE

SCH - NE - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

GOETHALS_345KV_5

Wed 05/19/2021 to Mon 05/24/2021 **EXTENDED** **by CE** **04/05/2021**
 0100 Continuous 0200
 Work scheduled by: ConEd

STATEN ISLAND
 Impacts Total Transfer Capability
 TTC with All Lines In Service

LINDEN__-GOETHALS_230_A2253

Wed 05/19/2021 to Mon 05/24/2021 **EXTENDED** **by CE** **04/05/2021**
 0100 Continuous 0200
 Work scheduled by: ConEd

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2050 MW	1150 MW
Impacts Total Transfer Capability	150 MW	100 MW
TTC with All Lines In Service	2200 MW	1250 MW

LINDEN__-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402

Wed 05/19/2021 to Mon 05/24/2021
 0100 Continuous 0200
 Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2000 MW	1000 MW
Impacts Total Transfer Capability	200 MW	250 MW
TTC with All Lines In Service	2200 MW	1250 MW

LINDEN__-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402 & MARION__-FARRAGUT_345_C3403

Wed 05/19/2021 to Mon 05/24/2021
 0100 Continuous 0200
 Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2000 MW	1000 MW
Impacts Total Transfer Capability	200 MW	250 MW
TTC with All Lines In Service	2200 MW	1250 MW

LINDEN__-GOETHALS_230_A2253 & MARION__-FARRAGUT_345_C3403

Wed 05/19/2021 to Mon 05/24/2021
 0100 Continuous 0200
 Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2000 MW	1000 MW
Impacts Total Transfer Capability	200 MW	250 MW
TTC with All Lines In Service	2200 MW	1250 MW

BUCHAN_S-MILLWOOD_345_W97

Thu 05/20/2021 to Sat 05/22/2021
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **7680 MW**
 Impacts Total Transfer Capability 135 MW
 TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Friday ,April 16, 2021 to Sunday ,October 16, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_6					FWD		
Thu 05/20/2021	to	Sat 05/22/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>03/30/2021</u>	(Import)	
0001	Continuous	0200				300 MW	
Work scheduled by: ConEd					SCH - PJM_HTP	360 MW	
					Impacts Total Transfer Capability	660 MW	
					TTC with All Lines In Service	660 MW	
W49TH_ST-E13THSTA_345_M55					FWD		
Thu 05/20/2021	to	Mon 05/24/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>03/30/2021</u>	(Import)	
0001	Continuous	0200				3800 MW	
Work scheduled by: ConEd					SPR/DUN-SOUTH	800 MW	
					Impacts Total Transfer Capability	4600 MW	
					TTC with All Lines In Service	4600 MW	
E13THSTA-FARRAGUT_345_46					FWD		
Sat 05/22/2021	to	Mon 05/24/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>03/30/2021</u>	(Import)	
0001	Continuous	0200				3800 MW	
Work scheduled by: ConEd					SPR/DUN-SOUTH	800 MW	
					Impacts Total Transfer Capability	4600 MW	
					TTC with All Lines In Service	4600 MW	
PLSNTVLY-WOOD_ST__345_F31					FWD		
Mon 05/24/2021	to	Tue 05/25/2021				(Import)	
0001	Continuous	0159				4000 MW	
Work scheduled by: ConEd					UPNY CONED	3815 MW	
					Impacts Total Transfer Capability	7815 MW	
					TTC with All Lines In Service	7815 MW	
PLSNTVLY_345KV_RNS4					FWD		
Mon 05/24/2021	to	Tue 05/25/2021				(Import)	
0001	Continuous	0159				3800 MW	
Work scheduled by: ConEd					UPNY CONED	4015 MW	
					Impacts Total Transfer Capability	7815 MW	
					TTC with All Lines In Service	7815 MW	
W49TH_ST_345KV_6					FWD		
Mon 05/24/2021	to	Mon 05/24/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>03/30/2021</u>	(Import)	
0130	Continuous	0200				300 MW	
Work scheduled by: ConEd					SCH - PJM_HTP	360 MW	
					Impacts Total Transfer Capability	660 MW	
					TTC with All Lines In Service	660 MW	
DENNISON-ROSEMNTB_115_2/22					FWD	REV	
Mon 05/24/2021	to	Wed 05/26/2021				(Import)	(Export)
0630	Continuous	1900				95 MW	40 MW
Work scheduled by: NGrid					SCH - HQ_CEDARS	95 MW	0 MW
					Impacts Total Transfer Capability	190 MW	40 MW
					TTC with All Lines In Service	190 MW	40 MW

NYISO TRANSFER LIMITATIONS

Friday ,April 16, 2021 to Sunday ,October 16, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-HQ_CEDARS-NYISO_LIMIT_80

Mon 05/24/2021 to Wed 05/26/2021
 0630 Continuous 1900
 Work scheduled by: NGrid

FWD
 (Import)
 SCH - HQ_CEDARS **80 MW**
 Impacts Total Transfer Capability 110 MW
 TTC with All Lines In Service 190 MW

ROSETON_-EFISHKIL_345_RFK305

Wed 05/26/2021 to Thu 05/27/2021
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **6680 MW**
 Impacts Total Transfer Capability 1135 MW
 TTC with All Lines In Service 7815 MW

DENNISON-ROSEMNTA_115_1/11

Thu 05/27/2021 to Fri 05/28/2021
 0630 Continuous 1900
 Work scheduled by: NGrid

FWD REV
 (Import) (Export)
 SCH - HQ_CEDARS **95 MW 40 MW**
 Impacts Total Transfer Capability 95 MW 0 MW
 TTC with All Lines In Service 190 MW 40 MW

SCH-HQ_CEDARS-NYISO_LIMIT_80

Thu 05/27/2021 to Fri 05/28/2021
 0630 Continuous 1900
 Work scheduled by: NGrid

FWD
 (Import)
 SCH - HQ_CEDARS **80 MW**
 Impacts Total Transfer Capability 110 MW
 TTC with All Lines In Service 190 MW

VOLNEY_-MARCY___345_19

Tue 06/01/2021 to Wed 06/02/2021
 0700 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 CENTRAL EAST - VC **2825 MW**
 Impacts Total Transfer Capability 150 MW
 TTC with All Lines In Service 2975 MW

VOLNEY_-MARCY___345_19

Tue 06/01/2021 to Wed 06/02/2021
 0700 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 OSWEGO EXPORT **4900 MW**
 Impacts Total Transfer Capability 350 MW
 TTC with All Lines In Service 5250 MW

FRASER_-GILBOA___345_GF5-35

Tue 06/01/2021 to Mon 06/07/2021
 0700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2650 MW**
 Impacts Total Transfer Capability 325 MW
 TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Friday ,April 16, 2021 to Sunday ,October 16, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -ADIRNDCK_230_MA2

Tue 06/01/2021 to Sun 11/14/2021
 0700 Continuous 1300
 Work scheduled by: NYPA

FWD
 (Import)
MOSES SOUTH 2100 MW
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW

MARCY -EDIC 345 UE1-7

Thu 06/03/2021 to Fri 06/04/2021
 0700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
OSWEGO EXPORT 5250 MW
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 5250 MW

ARR: 19&16

PORTER -ROTTRDAM_230_30

Thu 06/03/2021 to Wed 09/15/2021 **UPDATED by NGRID 01/19/2021**
 0700 Continuous 0659
 Work scheduled by: NGrid

FWD
 (Import)
CENTRAL EAST - VC 2805 MW
 Impacts Total Transfer Capability 170 MW
 TTC with All Lines In Service 2975 MW

MARCY 345KV_CSC

Sat 06/05/2021 to Sat 06/05/2021
 0700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
CENTRAL EAST - VC 2925 MW
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 2975 MW

ATHENS -PLSNTVLY_345_91

Tue 06/08/2021 to Wed 06/16/2021
 0600 Continuous 2000
 Work scheduled by: NGrid

FWD
 (Import)
UPNY CONED 3800 MW
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

GILBOA -N.SCTLND_345_GNS-1

Wed 06/09/2021 to Wed 06/09/2021
 0800 Daily 1200
 Work scheduled by: NGrid

FWD
 (Import)
CENTRAL EAST - VC 2520 MW
 Impacts Total Transfer Capability 455 MW
 TTC with All Lines In Service 2975 MW

BECK -NIAGARA_345_PA301

Wed 06/16/2021 to Thu 06/17/2021
 0500 Continuous 2330
 Work scheduled by: NYPA

FWD REV
 (Import) (Export)
SCH - OH - NY 900 MW 800 MW
 Impacts Total Transfer Capability 1050 MW 900 MW
 TTC with All Lines In Service 1950 MW 1700 MW

NYISO TRANSFER LIMITATIONS

Friday ,April 16, 2021 to Sunday ,October 16, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LEEDS___-PLSNTVLY_345_92				FWD
Thu 06/17/2021	to	Thu 06/24/2021		(Import)
0600	Continuous	2000		UPNY CONED 3800 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 4015 MW
				TTC with All Lines In Service 7815 MW
BECK___-NIAGARA_345_PA301				FWD REV
Fri 06/25/2021	to	Fri 06/25/2021		(Import) (Export)
0500	Continuous	1700		SCH - OH - NY 900 MW 800 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 1050 MW 900 MW
				TTC with All Lines In Service 1950 MW 1700 MW
FRASANX-COOPERS_345_UCC2-41				FWD
Fri 06/25/2021	to	Tue 08/10/2021		(Import)
0700	Continuous	1530		CENTRAL EAST - VC 2500 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 475 MW
ARR: 19				TTC with All Lines In Service 2975 MW
MARCY___-FRASANX_345_UCC2-41				FWD
Fri 06/25/2021	to	Tue 08/10/2021		(Import)
0700	Continuous	1530		CENTRAL EAST - VC 2500 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 475 MW
ARR: 19				TTC with All Lines In Service 2975 MW
BECK___-NIAGARA_345_PA302				FWD REV
Mon 07/12/2021	to	Fri 07/16/2021		(Import) (Export)
0500	Continuous	1700		SCH - OH - NY 900 MW 800 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 1050 MW 900 MW
				TTC with All Lines In Service 1950 MW 1700 MW
NIAGARA_345_230_AT4				FWD REV
Mon 07/19/2021	to	Fri 07/30/2021	UPDATED by NYPA 02/19/2021	(Import) (Export)
0500	Continuous	1700		SCH - OH - NY 1900 MW 1400 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 50 MW 300 MW
				TTC with All Lines In Service 1950 MW 1700 MW
NIAGARA_-STA_255_345_NH2				FWD
Mon 07/26/2021	to	Fri 07/30/2021	UPDATED by NYPA 02/19/2021	(Import)
0500	Continuous	1900		DYSINGER EAST 1400 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 1750 MW
				TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,April 16, 2021 to Sunday ,October 16, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SAND_BAR-PLATSBURG_115_PV20

Tue 08/03/2021 to Tue 08/03/2021
 0700 Continuous 1830
 Work scheduled by: NYPA

SCH - NE - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

KINTIGH_-STA_255_345_SH1-39

Mon 08/09/2021 to Sun 08/15/2021
 0500 Continuous 1900
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **1400 MW**
 Impacts Total Transfer Capability 1750 MW
 TTC with All Lines In Service 3150 MW

NIAGARA_-KINTIGH_345_NS1-38

Mon 08/09/2021 to Sun 08/15/2021
 0500 Continuous 1900
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **1400 MW**
 Impacts Total Transfer Capability 1750 MW
 TTC with All Lines In Service 3150 MW

KINTIGH_-STA_255_345_SH1-39

Mon 08/16/2021 to Sun 08/22/2021
 0500 Continuous 1900
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **1400 MW**
 Impacts Total Transfer Capability 1750 MW
 TTC with All Lines In Service 3150 MW

NIAGARA_-KINTIGH_345_NS1-38

Mon 08/16/2021 to Sun 08/22/2021
 0500 Continuous 1900
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **1400 MW**
 Impacts Total Transfer Capability 1750 MW
 TTC with All Lines In Service 3150 MW

NIAGARA_-STA_255_345_NH2

Wed 09/01/2021 to Tue 09/21/2021
 0500 Continuous 1900
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **1400 MW**
 Impacts Total Transfer Capability 1750 MW
 TTC with All Lines In Service 3150 MW

FRASANNX-COOPERS_345_UCC2-41

Tue 09/07/2021 to Wed 09/15/2021 **UPDATED by NYISO 02/03/2021**
 0700 Continuous 1730
 Work scheduled by: NYPA **ARR: 19**

FWD
 (Import)
 CENTRAL EAST - VC **2500 MW**
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Friday ,April 16, 2021 to Sunday ,October 16, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY -FRASANNX_345_UCC2-41

Tue 09/07/2021 to Wed 09/15/2021
0700 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYISO 02/03/2021

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

PORTER -ROTTRDAM_230_30

Wed 09/15/2021 to Tue 11/30/2021
0700 Continuous 1730

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **2805 MW**
Impacts Total Transfer Capability 170 MW
TTC with All Lines In Service 2975 MW

EDIC -N.SCTLND_345_14

Thu 09/16/2021 to Sun 11/14/2021
0700 Continuous 1730

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **1670 MW**
Impacts Total Transfer Capability 1305 MW
TTC with All Lines In Service 2975 MW

EDIC -N.SCTLND_345_14 & PORTER -ROTTRDAM_230_30

Thu 09/16/2021 to Sun 11/14/2021
0700 1730

Work scheduled by:

FWD
(Import)
CENTRAL EAST - VC **1500 MW**
Impacts Total Transfer Capability 1475 MW
TTC with All Lines In Service 2975 MW

HURLYAVE-ROSETON_345_303

Thu 09/16/2021 to Sun 10/17/2021
0800 Continuous 1600

Work scheduled by: CHGE

UPDATED by CHGE 09/22/2020

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 3715 MW
TTC with All Lines In Service 7815 MW

HOMRC_NY-MAINS_NY_345_47

Sat 09/18/2021 to Fri 11/05/2021
0800 Continuous 1600

Work scheduled by: PJM

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

PANNELL -CLAY_345_1

Mon 09/20/2021 to Fri 09/24/2021
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

NYISO TRANSFER LIMITATIONS

Friday ,April 16, 2021 to Sunday ,October 16, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CLAY -EDIC 345_2-15					FWD
Mon 09/20/2021	to	Sat 10/16/2021			(Import)
0700	Continuous	1730		OSWEGO EXPORT	4850 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 400 MW
					TTC with All Lines In Service 5250 MW
KINTIGH -STA 255_345_SH1-39					FWD
Mon 09/27/2021	to	Wed 09/29/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>03/04/2021</u>
0500	Continuous	0459		DYSINGER EAST	1400 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 1750 MW
					TTC with All Lines In Service 3150 MW
NIAGARA -KINTIGH 345_NS1-38					FWD
Mon 09/27/2021	to	Wed 09/29/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>03/04/2021</u>
0500	Continuous	0459		DYSINGER EAST	1400 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 1750 MW
					TTC with All Lines In Service 3150 MW
PANNELL -CLAY 345_2					FWD
Mon 09/27/2021	to	Fri 10/01/2021			(Import)
0700	Continuous	1530		WEST CENTRAL	1300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 950 MW
					TTC with All Lines In Service 2250 MW
W49TH_ST_345KV_6					FWD
Tue 09/28/2021	to	Tue 09/28/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>01/15/2021</u>
0100	Continuous	0130		SCH - PJM_HTP	300 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 360 MW
					TTC with All Lines In Service 660 MW
E13THSTA-FARRAGUT_345_46					FWD
Tue 09/28/2021	to	Tue 10/26/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>01/15/2021</u>
0100	Continuous	0300		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
W49TH_ST-E13THSTA_345_M55					FWD
Tue 09/28/2021	to	Tue 10/26/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>01/15/2021</u>
0100	Continuous	0300		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Friday ,April 16, 2021 to Sunday ,October 16, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

KINTIGH_-STA_255__345_SH1-39				FWD
Wed 09/29/2021	to	Wed 12/01/2021		(Import)
0500	Continuous	1900	DYSINGER EAST	1400 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 1750 MW
				TTC with All Lines In Service 3150 MW
NIAGARA_-KINTIGH__345_NS1-38				FWD
Wed 09/29/2021	to	Wed 12/01/2021		(Import)
0500	Continuous	1900	DYSINGER EAST	1400 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 1750 MW
				TTC with All Lines In Service 3150 MW
LEEDS__-HURLYAVE_345_301				FWD
Mon 10/18/2021	to	Fri 11/19/2021		(Import)
0800	Continuous	1600	UPNY CONED	4100 MW
Work scheduled by: CHGE				Impacts Total Transfer Capability 3715 MW
				TTC with All Lines In Service 7815 MW
GOETHALS_345KV_5				
Thu 10/21/2021	to	Sat 11/20/2021	UPDATED by CONED 03/05/2021	
0001	Continuous	0200		STATEN ISLAND
Work scheduled by: ConEd				Impacts Total Transfer Capability
				TTC with All Lines In Service
W49TH_ST_345KV_6				FWD
Tue 10/26/2021	to	Tue 10/26/2021	UPDATED by CONED 01/15/2021	(Import)
0230	Continuous	0300		SCH - PJM_HTP
Work scheduled by: ConEd				300 MW
				Impacts Total Transfer Capability 360 MW
				TTC with All Lines In Service 660 MW
SCH-IMO-NYISO_LIMIT_1750				FWD
Mon 11/01/2021	to	Fri 12/31/2021	UPDATED by IESO 05/03/2019	(Import)
0001	Continuous	2359		SCH - OH - NY
Work scheduled by: IESO				2050 MW
				Impacts Total Transfer Capability 250 MW
				TTC with All Lines In Service 2300 MW
SCH-NYISO-IMO_LIMIT_1600				REV
Mon 11/01/2021	to	Fri 12/31/2021	UPDATED by IESO 05/03/2019	(Export)
0001	Continuous	2359		SCH - OH - NY
Work scheduled by: IESO				1900 MW
				Impacts Total Transfer Capability 100 MW
				TTC with All Lines In Service 2000 MW

NYISO TRANSFER LIMITATIONS

Friday ,April 16, 2021 to Sunday ,October 16, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LINDN_CG-LNDVFT___345_V-3022			
Tue 11/02/2021	to	Fri 11/05/2021	FWD
0800	Continuous	1500	(Import) (Export)
Work scheduled by: PJM			SCH - PJM_VFT 0 MW 0 MW
			Impacts Total Transfer Capability 315 MW 315 MW
			TTC with All Lines In Service 315 MW 315 MW
PORTER_-ROTTDAM_230_30 & MASSENA_-MARCY___765_MSU1			
Mon 11/15/2021	to	Tue 11/30/2021	FWD
0100		1730	(Import)
Work scheduled by:			CENTRAL EAST - VC 1500 MW
			Impacts Total Transfer Capability 1475 MW
			TTC with All Lines In Service 2975 MW
CHATGUAY-MASSENA___765_7040			
Mon 11/15/2021	to	Tue 11/30/2021	FWD
0100	Continuous	1859	(Import)
Work scheduled by: NYPA			MOSES SOUTH 1550 MW
			Impacts Total Transfer Capability 1600 MW
			TTC with All Lines In Service 3150 MW
CHATGUAY-MASSENA___765_7040			
Mon 11/15/2021	to	Tue 11/30/2021	FWD
0100	Continuous	1859	(Import) (Export)
Work scheduled by: NYPA			SCH - HQ - NY 0 MW 0 MW
			Impacts Total Transfer Capability 1500 MW 1000 MW
			TTC with All Lines In Service 1500 MW 1000 MW
MARCY___765_345_AT1			
Mon 11/15/2021	to	Tue 11/30/2021	FWD
0100	Continuous	1859	(Import)
Work scheduled by: NYPA			MOSES SOUTH 1750 MW
			Impacts Total Transfer Capability 1400 MW
			TTC with All Lines In Service 3150 MW
			ARR: 19
MARCY___765_345_AT2			
Mon 11/15/2021	to	Tue 11/30/2021	FWD
0100	Continuous	1859	(Import)
Work scheduled by: NYPA			MOSES SOUTH 1700 MW
			Impacts Total Transfer Capability 1450 MW
			TTC with All Lines In Service 3150 MW
			ARR: 19
MASSENA_-MARCY___765_MSU1			
Mon 11/15/2021	to	Tue 11/30/2021	FWD
0100	Continuous	1859	(Import)
Work scheduled by: NYPA			CENTRAL EAST - VC 1670 MW
			Impacts Total Transfer Capability 1305 MW
			TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Friday ,April 16, 2021 to Sunday ,October 16, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Zone	Start	End	Day	Time	Duration	Impact	TTC	FWD	REV
MASSENA -MARCY 765_MSU1	Mon 11/15/2021	Tue 11/30/2021		0100	Continuous	1859		FWD	
								(Import)	
							MOSES SOUTH	500 MW	
							Impacts Total Transfer Capability	2650 MW	
							TTC with All Lines In Service	3150 MW	
Work scheduled by: NYPA									
MASSENA -MARCY 765_MSU1	Mon 11/15/2021	Tue 11/30/2021		0100	Continuous	1859		FWD	REV
								(Import)	(Export)
							SCH - HQ - NY	475 MW	1000 MW
							Impacts Total Transfer Capability	1025 MW	0 MW
							TTC with All Lines In Service	1500 MW	1000 MW
Work scheduled by: NYPA									
MASSENA -MARCY 765_MSU1	Mon 11/15/2021	Tue 11/30/2021		0100	Continuous	1859		FWD	
								(Import)	
							SCH - HQ_CEDARS	90 MW	
							Impacts Total Transfer Capability	109 MW	
							TTC with All Lines In Service	199 MW	
Work scheduled by: NYPA									
MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040	Mon 11/15/2021	Tue 11/30/2021		0100		1859		FWD	
								(Import)	
							MOSES SOUTH	500 MW	
							Impacts Total Transfer Capability	2650 MW	
							TTC with All Lines In Service	3150 MW	
Work scheduled by:									
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2	Mon 11/15/2021	Tue 11/30/2021		0100		1859		FWD	REV
								(Import)	(Export)
							SCH - HQ - NY	850 MW	0 MW
							Impacts Total Transfer Capability	650 MW	1000 MW
							TTC with All Lines In Service	1500 MW	1000 MW
Work scheduled by:									
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2	Mon 11/15/2021	Tue 11/30/2021		0100		1859		FWD	
								(Import)	
							SCH - HQ_CEDARS	90 MW	
							Impacts Total Transfer Capability	109 MW	
							TTC with All Lines In Service	199 MW	
Work scheduled by:									
STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1	Mon 11/15/2021	Tue 11/30/2021		0100		1859		FWD	
								(Import)	
							SCH - HQ_CEDARS	90 MW	
							Impacts Total Transfer Capability	109 MW	
							TTC with All Lines In Service	199 MW	
Work scheduled by:									

NYISO TRANSFER LIMITATIONS

Friday ,April 16, 2021 to Sunday ,October 16, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>STLAWRNC-MOSES__230_L33P & MOSES__-MASSENA_230_MMS1 & MOSES__- MASSENA_230_MMS2</p> <p>Mon 11/15/2021 to Tue 11/30/2021 0100 1859</p> <p>Work scheduled by:</p>	<p>FWD (Import) 90 MW SCH - HQ_CEDARS Impacts Total Transfer Capability 109 MW TTC with All Lines In Service 199 MW</p>
<p>FRASER__345_FRASER SVC</p> <p>Wed 12/01/2021 to Mon 02/28/2022 0700 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import) 2935 MW CENTRAL EAST - VC Impacts Total Transfer Capability 40 MW TTC with All Lines In Service 2975 MW</p>
<p>MOSES__-ADIRNDCK_230_MAI</p> <p>Wed 12/01/2021 to Tue 05/31/2022 0700 Continuous 1300</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import) 2300 MW MOSES SOUTH Impacts Total Transfer Capability 850 MW TTC with All Lines In Service 3150 MW</p>
<p>NIAGARA_-STA_255__345_NH2</p> <p>Thu 12/02/2021 to Thu 01/13/2022 0500 Continuous 1900</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import) 1700 MW DYSINGER EAST Impacts Total Transfer Capability 1450 MW TTC with All Lines In Service 3150 MW</p>
<p>MOTTHAVN-RAINEY__345_Q12</p> <p>Sun 12/05/2021 to Sat 12/25/2021 UPDATED by CONED 03/25/2021 0001 Continuous 0159</p> <p>Work scheduled by: ConEd</p>	<p>FWD (Import) 3800 MW SPR/DUN-SOUTH Impacts Total Transfer Capability 800 MW TTC with All Lines In Service 4600 MW</p>
<p>LEEDS__-PLSNTVLY_345_92</p> <p>Thu 02/17/2022 to Mon 02/21/2022 UPDATED by NGRID 03/31/2021 0600 Continuous 1900</p> <p>Work scheduled by: NGrid</p>	<p>FWD (Import) 3800 MW UPNY CONED Impacts Total Transfer Capability 2420 MW TTC with All Lines In Service 6220 MW</p>
<p>GOETHALS_345KV_5</p> <p>Sat 03/05/2022 to Mon 04/04/2022 UPDATED by CONED 03/26/2021 0001 Continuous 0200</p> <p>Work scheduled by: ConEd</p>	<p>FWD (Import) 3800 MW STATEN ISLAND Impacts Total Transfer Capability TTC with All Lines In Service</p>

NYISO TRANSFER LIMITATIONS

Friday ,April 16, 2021 to Sunday ,October 16, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LINDEN__-GOETHALS_230_A2253

Sat 03/05/2022 to Mon 04/04/2022 **UPDATED by CONED 03/26/2021**
 0001 Continuous 0200
 Work scheduled by: ConEd
 SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

N. SCTLND-ALPS_____345_2

Mon 05/02/2022 to Mon 05/09/2022
 0600 Daily 1800
 Work scheduled by: NGrid
 FWD (Import)
 SCH - NE - NY **750 MW**
 Impacts Total Transfer Capability 650 MW
 TTC with All Lines In Service 1400 MW

N. SCTLND-ALPS_____345_2

Mon 05/02/2022 to Mon 05/09/2022
 0600 Daily 1800
 Work scheduled by: NGrid
 FWD REV (Import) (Export)
 SCH - NPX_1385 **100 MW 100 MW**
 Impacts Total Transfer Capability 100 MW 100 MW
 TTC with All Lines In Service 200 MW 200 MW

HOMRC_NY-MAINS_NY_345_47

Fri 05/20/2022 to Fri 05/27/2022 **UPDATED by PJM 11/19/2020**
 0800 Continuous 1600
 Work scheduled by: PJM
 SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

HOMR_NYW-PIERC_NY_345_48

Fri 05/20/2022 to Fri 05/27/2022 **UPDATED by PJM 11/19/2020**
 0800 Continuous 1600
 Work scheduled by: PJM
 SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

MOSES__-ADIRNDCK_230_MA2

Wed 06/01/2022 to Mon 11/14/2022
 0700 Continuous 1300
 Work scheduled by: NYPA
 FWD (Import)
 MOSES SOUTH **2100 MW**
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW

SPRNBRK__345KV_RNS5

Mon 09/19/2022 to Mon 09/19/2022 **UPDATED by CONED 09/17/2020**
 0001 Continuous 0030
 Work scheduled by: ConEd
 FWD (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Friday ,April 16, 2021 to Sunday ,October 16, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK_-W49TH_ST_345_M51

Mon 09/19/2022 to Wed 09/21/2022
 0001 Continuous 2200

UPDATED **by CONED** **09/17/2020**

Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

FWD
 (Import)

SPRNBRK_345KV_RNS5

Wed 09/21/2022 to Wed 09/21/2022
 2130 Continuous 2200

UPDATED **by CONED** **09/17/2020**

Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

FWD
 (Import)

SPRNBRK_-W49TH_ST_345_M51

Sat 10/01/2022 to Mon 10/17/2022
 0001 Continuous 0300

UPDATED **by CONED** **08/01/2020**

Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

FWD
 (Import)

SPRNBRK_345KV_RNS5

Sat 10/01/2022 to Mon 10/17/2022
 0001 Continuous 0300

UPDATED **by CONED** **08/01/2020**

Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

FWD
 (Import)