

NYISO TRANSFER LIMITATIONS

Sunday ,April 18, 2021 to Tuesday ,October 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Wed 06/30/2021 EXT FORCE by CONED 08/28/2020
 0001 Continuous 2359
 Work scheduled by: ConEd

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Wed 06/30/2021
 0001 2359
 Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2550 MW	1900 MW
Impacts Total Transfer Capability	250 MW	50 MW
TTC with All Lines In Service	2800 MW	1950 MW

MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Wed 06/30/2021 EXT FORCE by CONED 08/28/2020
 0001 Continuous 2359
 Work scheduled by: ConEd

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

STLAWRNC-MOSES_230_L33P

Mon 04/30/2018 to Mon 10/31/2022 EXT FORCE by IESO 10/01/2020
 0456 Continuous 1600
 Work scheduled by: IESO

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

NEWBRDGE_345_138_BK_1

Wed 09/02/2020 to Tue 02/01/2022 EXT FORCE by LI 01/12/2021
 1807 Continuous 2359
 Work scheduled by: LI

	FWD
	(Import)
SCH - PJM_NEPTUNE	375 MW
Impacts Total Transfer Capability	285 MW
TTC with All Lines In Service	660 MW

SPRNBK_-EGRDNCTR_345_Y49

Thu 10/01/2020 to Mon 04/19/2021 EXT FORCE by LI 02/23/2021
 0404 Continuous 2359
 Work scheduled by: LI

	FWD
	(Import)
CONED - LIPA	775 MW
Impacts Total Transfer Capability	725 MW
TTC with All Lines In Service	1500 MW

EGRDNCTY_345_138_AT2

Sat 10/10/2020 to Mon 04/19/2021 EXT FORCE by LI 02/23/2021
 1815 Continuous 2359
 Work scheduled by: LI

	FWD
	(Import)
CONED - LIPA	1250 MW
Impacts Total Transfer Capability	250 MW
TTC with All Lines In Service	1500 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 18, 2021 to Tuesday ,October 18, 2022

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EGRDNCTY_345_138_AT1						FWD
Sat 10/10/2020	to	Mon 04/19/2021	<u>EXT FORCE</u>	<u>by LI</u>	<u>02/23/2021</u>	(Import)
1856	Continuous	2359				CONED - LIPA 1250 MW
Work scheduled by: LI						Impacts Total Transfer Capability 250 MW
						TTC with All Lines In Service 1500 MW
SCH-IMO-NYISO_LIMIT_1750						FWD
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Import)
0001	Continuous	2359				SCH - OH - NY 2050 MW
Work scheduled by: IESO						Impacts Total Transfer Capability 250 MW
						TTC with All Lines In Service 2300 MW
SCH-NYISO-IMO_LIMIT_1600						REV
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Export)
0001	Continuous	2359				SCH - OH - NY 1900 MW
Work scheduled by: IESO						Impacts Total Transfer Capability 100 MW
						TTC with All Lines In Service 2000 MW
SAND_BAR-PLATSBRG_115_PV20						
Tue 02/23/2021	to	Mon 05/17/2021	<u>UPDATED</u>	<u>by NYISO</u>	<u>03/16/2021</u>	
1801	Continuous	0559				SCH - NE - NY
Work scheduled by: ISONE						Impacts Total Transfer Capability
						TTC with All Lines In Service
W49TH_ST_345KV_8						FWD
Tue 03/02/2021	to	Sun 05/02/2021	<u>EXTENDED</u>	<u>by CONED</u>	<u>04/10/2021</u>	(Import)
0201	Continuous	0200				SCH - PJM_HTP 300 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 360 MW
						TTC with All Lines In Service 660 MW
PORTER__-ROTTRDAM_230_31						FWD
Tue 03/02/2021	to	Mon 05/31/2021	<u>UPDATED</u>	<u>by NGRID</u>	<u>03/10/2021</u>	(Import)
0600	Continuous	1730				CENTRAL EAST - VC 2805 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability 170 MW
						TTC with All Lines In Service 2975 MW
MOSES__-ADIRNDCK_230_MAL						FWD
Tue 03/02/2021	to	Mon 05/10/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>02/11/2021</u>	(Import)
0700	Continuous	1159				MOSES SOUTH 2300 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 850 MW
						TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 18, 2021 to Tuesday ,October 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_6

Sun 03/21/2021 to Sun 05/02/2021 **EXTENDED** **by CONED** **04/10/2021**
 0001 Continuous 0200

Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

EDIC -N.SCTLND_345_14 & PORTER -ROTTDAM_230_31

Mon 03/22/2021 to Mon 05/31/2021
 0600 1730

Work scheduled by:

FWD
 (Import)
 CENTRAL EAST - VC **1500 MW**
 Impacts Total Transfer Capability 1475 MW
 TTC with All Lines In Service 2975 MW

EDIC -N.SCTLND_345_14

Mon 03/22/2021 to Mon 05/31/2021 **UPDATED** **by NGRID** **03/10/2021**
 0600 Continuous 1830

Work scheduled by: NGrid

FWD
 (Import)
 CENTRAL EAST - VC **1670 MW**
 Impacts Total Transfer Capability 1305 MW
 TTC with All Lines In Service 2975 MW

S.RIPLEY-DUNKIRK_230_68

Mon 04/12/2021 to Fri 04/23/2021 **UPDATED** **by NGRID** **04/12/2021**
 0630 Continuous 1700

Work scheduled by: NGrid

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

LEEDS -HURLYAVE_345_301

Mon 04/12/2021 to Wed 04/14/2021 **UPDATED** **by NGRID** **02/01/2021**
 0800 Continuous 1825

Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4100 MW**
 Impacts Total Transfer Capability 2120 MW
 TTC with All Lines In Service 6220 MW

SPRNBRK -W49TH_ST_345_M51

Wed 04/14/2021 to Mon 04/26/2021 **EXTENDED** **by CONED** **04/16/2021**
 1124 Continuous 2359

Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

SCH-NPX_1385-NYISO_LIMIT_150

Mon 04/19/2021 to Thu 04/29/2021 **FORCED** **by ISONE** **04/17/2021**
 0001 Continuous 1600

Work scheduled by: ISONE

FWD
 (Import)
 SCH - NPX_1385 **150 MW**
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 200 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 18, 2021 to Tuesday ,October 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_6					FWD		
Tue 04/20/2021	to	Tue 04/20/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>02/19/2021</u>	(Import)	
0201	Continuous	0230				3800 MW	
Work scheduled by: ConEd					SPR/DUN-SOUTH		
					Impacts Total Transfer Capability	800 MW	
					TTC with All Lines In Service	4600 MW	
DUNWODIE_345KV_8					FWD		
Tue 04/20/2021	to	Tue 04/20/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>02/19/2021</u>	(Import)	
0201	Continuous	0230				3800 MW	
Work scheduled by: ConEd					SPR/DUN-SOUTH		
					Impacts Total Transfer Capability	800 MW	
					TTC with All Lines In Service	4600 MW	
WOOD_ST_-PLSNTVLE_345_Y87					FWD		
Tue 04/20/2021	to	Tue 04/20/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>02/19/2021</u>	(Import)	
0201	Continuous	0230				5905 MW	
Work scheduled by: ConEd					UPNY CONED		
					Impacts Total Transfer Capability	315 MW	
					TTC with All Lines In Service	6220 MW	
PLSNTVLE-DUNWODIE_345_W90					FWD		
Tue 04/20/2021	to	Fri 04/23/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>02/19/2021</u>	(Import)	
0201	Continuous	0159				4000 MW	
Work scheduled by: ConEd					UPNY CONED		
					Impacts Total Transfer Capability	2220 MW	
					TTC with All Lines In Service	6220 MW	
MAINESBG-WATRCURE_345_30					FWD		
Tue 04/20/2021	to	Wed 04/21/2021				(Import)	
0800	Continuous	1530				2300 MW	
Work scheduled by: NYSEG					SCH - PJ - NY		
					Impacts Total Transfer Capability	500 MW	
					TTC with All Lines In Service	2800 MW	
NRTH1385-NOR HBR_138_601					FWD	REV	
Wed 04/21/2021	to	Wed 04/21/2021				(Import)	(Export)
0800	Continuous	1600				100 MW	100 MW
Work scheduled by: ISONE					SCH - NPX_1385		
					Impacts Total Transfer Capability	100 MW	100 MW
					TTC with All Lines In Service	200 MW	200 MW
NRTH1385-NOR HBR_138_601 & NRTH1385-NOR HBR_138_602					FWD	REV	
Wed 04/21/2021	to	Wed 04/21/2021				(Import)	(Export)
0800		1600				0 MW	0 MW
Work scheduled by:					SCH - NPX_1385		
					Impacts Total Transfer Capability	200 MW	200 MW
					TTC with All Lines In Service	200 MW	200 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 18, 2021 to Tuesday ,October 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_603				FWD	REV
Wed 04/21/2021	to	Wed 04/21/2021		(Import)	(Export)
0800		1600	SCH - NPX_1385	0 MW	0 MW
Work scheduled by:				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR__138_602				FWD	REV
Wed 04/21/2021	to	Wed 04/21/2021		(Import)	(Export)
0800	Continuous	1600	SCH - NPX_1385	100 MW	100 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR__138_602 & NRTH1385-NOR HBR__138_603				FWD	REV
Wed 04/21/2021	to	Wed 04/21/2021		(Import)	(Export)
0800		1600	SCH - NPX_1385	0 MW	0 MW
Work scheduled by:				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR__138_603				FWD	REV
Wed 04/21/2021	to	Wed 04/21/2021		(Import)	(Export)
0800	Continuous	1600	SCH - NPX_1385	100 MW	100 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	200 MW
NRTH1385-NRTHPORT_138_NNC				FWD	REV
Wed 04/21/2021	to	Wed 04/21/2021		(Import)	(Export)
0800	Continuous	1600	SCH - NPX_1385	0 MW	0 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	200 MW
DUNWODIE_345KV_6				FWD	
Fri 04/23/2021	to	Fri 04/23/2021	UPDATED by CONED 02/19/2021	(Import)	
0130	Continuous	0159		3800 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_8				FWD	
Fri 04/23/2021	to	Fri 04/23/2021	UPDATED by CONED 02/19/2021	(Import)	
0130	Continuous	0159		3800 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 18, 2021 to Tuesday ,October 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

WOOD_ST_-PLSNTVLE_345_Y87					FWD
Fri 04/23/2021	to	Fri 04/23/2021	<u>UPDATED</u>	<u>by CONED</u> <u>02/19/2021</u>	(Import)
0130	Continuous	0159			5905 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 315 MW
					TTC with All Lines In Service 6220 MW
PLSNTVLY-WOOD_ST__345_F30					FWD
Fri 04/23/2021	to	Fri 04/23/2021	<u>UPDATED</u>	<u>by CONED</u> <u>04/17/2021</u>	(Import)
0201	Continuous	0230			4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 2220 MW
					TTC with All Lines In Service 6220 MW
PLSNTVLY_345KV_RNS5					FWD
Fri 04/23/2021	to	Fri 04/23/2021	<u>UPDATED</u>	<u>by CONED</u> <u>04/17/2021</u>	(Import)
0201	Continuous	0230			3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 2420 MW
					TTC with All Lines In Service 6220 MW
MILLWOOD-EASTVIEW_345_W82					FWD
Fri 04/23/2021	to	Fri 04/23/2021	<u>UPDATED</u>	<u>by CONED</u> <u>04/02/2021</u>	(Import)
0201	Continuous	1800			5985 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 235 MW
					TTC with All Lines In Service 6220 MW
MILLWOOD_345KV_18					FWD
Fri 04/23/2021	to	Sat 04/24/2021	<u>UPDATED</u>	<u>by CONED</u> <u>04/02/2021</u>	(Import)
0201	Continuous	2200			4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1870 MW
					TTC with All Lines In Service 6220 MW
CHAT_DC_GC1					FWD
Sat 04/24/2021	to	Sun 04/25/2021			(Import)
2000	Continuous	0500			2850 MW
Work scheduled by: HQ					Impacts Total Transfer Capability 300 MW
					TTC with All Lines In Service 3150 MW
CHAT_DC_GC1					REV
Sat 04/24/2021	to	Sun 04/25/2021			(Export)
2000	Continuous	0500			500 MW
Work scheduled by: HQ					Impacts Total Transfer Capability 500 MW
					TTC with All Lines In Service 1000 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 18, 2021 to Tuesday ,October 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY-WOOD_ST__345_F30

Mon 04/26/2021 to Tue 04/27/2021
 0001 Continuous 0200

Work scheduled by: ConEd

UPDATED by CONED 04/17/2021

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 2220 MW
 TTC with All Lines In Service 6220 MW

PLSNTVLY_345KV_RNS5

Mon 04/26/2021 to Tue 04/27/2021
 0001 Continuous 0200

Work scheduled by: ConEd

UPDATED by CONED 04/17/2021

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 2420 MW
 TTC with All Lines In Service 6220 MW

KINTIGH_-STA_255__345_SH1-39

Mon 04/26/2021 to Fri 04/30/2021
 0700 Continuous 1700

Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

NIAGARA_-KINTIGH__345_NS1-38

Mon 04/26/2021 to Fri 04/30/2021
 0700 Continuous 1700

Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

HOMRC_NY-MAINS_NY_345_47

Mon 04/26/2021 to Sat 05/29/2021
 0800 Continuous 1900

Work scheduled by: NYSEG

EXTENDED by NYSEG 03/10/2021

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FRASER_-COOPERS__345_33

Mon 04/26/2021 to Fri 04/30/2021
 0830 Continuous 1500

Work scheduled by: NYSEG

FWD
 (Import)
 CENTRAL EAST - VC **2395 MW**
 Impacts Total Transfer Capability 580 MW
 TTC with All Lines In Service 2975 MW

ALCOA_PA_115KV_R8105

Tue 04/27/2021 to Thu 04/29/2021
 0630 Continuous 1830

Work scheduled by: NGrid

FWD
 (Import)
 MOSES SOUTH **3100 MW**
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 18, 2021 to Tuesday ,October 18, 2022

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOTTHAVN-RAINEY___345_Q11

Wed 04/28/2021 to Sat 05/08/2021
0001 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

BUCHAN_N-EASTVIEW_345_W93

Fri 04/30/2021 to Sun 05/09/2021
0700 Continuous 2359

Work scheduled by: ConEd

UPDATED by CONED 04/07/2021

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 1870 MW
TTC with All Lines In Service 6220 MW

SCH-IMO-NYISO_LIMIT_1600

Sat 05/01/2021 to Sun 10/31/2021
0001 Continuous 2359

Work scheduled by: IESO

UPDATED by IESO 05/03/2019

FWD
(Import)
SCH - OH - NY **1900 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 1950 MW

W49TH_ST_345KV_5

Sun 05/02/2021 to Sun 05/02/2021
0201 Continuous 0231

Work scheduled by: ConEd

UPDATED by CONED 04/13/2021

FWD
(Import)
SCH - PJM_HTP **300 MW**
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

W49TH_ST_345KV_7

Sun 05/02/2021 to Sun 05/02/2021
0201 Continuous 0231

Work scheduled by: ConEd

UPDATED by CONED 04/13/2021

FWD
(Import)
SCH - PJM_HTP **300 MW**
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

CHAT_DC_GC2

Sun 05/02/2021 to Fri 05/28/2021
0500 Continuous 1700

Work scheduled by: HQ

FWD
(Import)
MOSES SOUTH **2850 MW**
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 3150 MW

CHAT_DC_GC2

Sun 05/02/2021 to Fri 05/28/2021
0500 Continuous 1700

Work scheduled by: HQ

REV
(Export)
SCH - HQ - NY **500 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1000 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 18, 2021 to Tuesday ,October 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event ID	Start Date	End Date	Time	Work Scheduled by	Location	Direction	Impact	TTC
DUNWODIE_345KV_7	Mon 05/03/2021	Mon 05/03/2021	0001 Continuous 0030	ConEd	SPR/DUN-SOUTH	FWD (Import)	3800 MW	4600 MW
						Impacts Total Transfer Capability	800 MW	
						TTC with All Lines In Service	4600 MW	
DUNWODIE_345KV_8	Mon 05/03/2021	Mon 05/03/2021	0001 Continuous 0030	ConEd	SPR/DUN-SOUTH	FWD (Import)	3800 MW	4600 MW
						Impacts Total Transfer Capability	800 MW	
						TTC with All Lines In Service	4600 MW	
DUNWODIE-MOTTHAVN_345_72	Mon 05/03/2021	Mon 05/03/2021	0001 Continuous 1800	ConEd	SPR/DUN-SOUTH	FWD (Import)	3800 MW	4600 MW
						Impacts Total Transfer Capability	800 MW	
						TTC with All Lines In Service	4600 MW	
NRTH1385-NOR HBR__138_601	Mon 05/03/2021	Mon 05/24/2021	0600 Continuous 2359	LI	SCH - NPX_1385	FWD (Import) REV (Export)	100 MW	100 MW
						Impacts Total Transfer Capability	100 MW	100 MW
						TTC with All Lines In Service	200 MW	200 MW
NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_602	Mon 05/03/2021	Mon 05/24/2021	0600 2359		SCH - NPX_1385	FWD (Import) REV (Export)	0 MW	0 MW
						Impacts Total Transfer Capability	200 MW	200 MW
						TTC with All Lines In Service	200 MW	200 MW
NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_603	Mon 05/03/2021	Mon 05/24/2021	0600 2359		SCH - NPX_1385	FWD (Import) REV (Export)	0 MW	0 MW
						Impacts Total Transfer Capability	200 MW	200 MW
						TTC with All Lines In Service	200 MW	200 MW
NRTH1385-NOR HBR__138_602	Mon 05/03/2021	Mon 05/24/2021	0600 Continuous 2359	LI	SCH - NPX_1385	FWD (Import) REV (Export)	100 MW	100 MW
						Impacts Total Transfer Capability	100 MW	100 MW
						TTC with All Lines In Service	200 MW	200 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 18, 2021 to Tuesday ,October 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NOR HBR__138_602 & NRTH1385-NOR HBR__138_603

Mon 05/03/2021 to Mon 05/24/2021
0600 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

NRTH1385-NOR HBR__138_603

Mon 05/03/2021 to Mon 05/24/2021
0600 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

NRTH1385-NRTHPORT_138_NNC

Mon 05/03/2021 to Mon 05/24/2021
0600 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

CLAY__-EDIC__345_2-15

Mon 05/03/2021 to Fri 05/07/2021
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
OSWEGO EXPORT	4850 MW
Impacts Total Transfer Capability	400 MW
TTC with All Lines In Service	5250 MW

FIVEMILE-STOLLERD_345_29

Mon 05/03/2021 to Fri 05/14/2021
0700 Continuous 1400

Work scheduled by: NYSEG

SCH - PJ - NY	
Impacts Total Transfer Capability	
TTC with All Lines In Service	

SCH-HQ-NYISO_LIMIT_1400

Mon 05/03/2021 to Fri 05/14/2021
0700 Continuous 1530

Work scheduled by: HQ

	FWD
	(Import)
SCH - HQ - NY	1400 MW
Impacts Total Transfer Capability	100 MW
TTC with All Lines In Service	1500 MW

PANNELL_-CLAY__345_2

Mon 05/03/2021 to Sun 05/30/2021
0700 Continuous 1730

Work scheduled by: NYPA

	FWD
	(Import)
WEST CENTRAL	1300 MW
Impacts Total Transfer Capability	950 MW
TTC with All Lines In Service	2250 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 18, 2021 to Tuesday ,October 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HURLYAVE-ROSETON__345_303				FWD
Mon 05/03/2021	to	Fri 05/21/2021		(Import)
0800	Continuous	1600	UPNY CONED	4100 MW
Work scheduled by: CHGE				Impacts Total Transfer Capability 3715 MW
				TTC with All Lines In Service 7815 MW
SHOR_NPX-SHOREHAM_138_CSC				FWD REV
Mon 05/03/2021	to	Sat 05/08/2021	<u>EXTENDED</u> by ISONE <u>03/15/2021</u>	(Import) (Export)
0900	Continuous	1600	SCH - NPX_CSC	0 MW 0 MW
Work scheduled by: LI				Impacts Total Transfer Capability 330 MW 330 MW
				TTC with All Lines In Service 330 MW 330 MW
DUNWODIE_345KV_7				FWD
Mon 05/03/2021	to	Mon 05/03/2021		(Import)
1730	Continuous	1800	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_8				FWD
Mon 05/03/2021	to	Mon 05/03/2021		(Import)
1730	Continuous	1800	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
ROTTRDAM-EASTOVER_230_38				REV
Tue 05/04/2021	to	Tue 05/04/2021		(Export)
0830	Daily(No Weekends)	1130	SCH - NE - NY	1400 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 200 MW
ARR: 77				TTC with All Lines In Service 1600 MW
RAMAPO__-BUCHAN_N_345_Y94				FWD
Fri 05/07/2021	to	Sun 05/09/2021	<u>UPDATED</u> by CONED <u>04/07/2021</u>	(Import)
0001	Continuous	2359	UPNY CONED	7580 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 235 MW
				TTC with All Lines In Service 7815 MW
EASTVIEW-SPRNBK__345_W79				FWD
Sat 05/08/2021	to	Sun 05/09/2021	<u>UPDATED</u> by CONED <u>04/07/2021</u>	(Import)
0700	Continuous	2359	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 3465 MW
				TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 18, 2021 to Tuesday ,October 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_5					FWD	
Sun 05/09/2021	to	Sun 05/09/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>04/13/2021</u>	(Import)
0130	Continuous	0200				SCH - PJM_HTP 300 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 360 MW	
					TTC with All Lines In Service 660 MW	
W49TH_ST_345KV_7					FWD	
Sun 05/09/2021	to	Sun 05/09/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>04/13/2021</u>	(Import)
0130	Continuous	0200				SCH - PJM_HTP 300 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 360 MW	
					TTC with All Lines In Service 660 MW	
W49TH_ST_345KV_7					FWD	
Mon 05/10/2021	to	Mon 05/10/2021				(Import)
0001	Continuous	0030				SCH - PJM_HTP 300 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 360 MW	
					TTC with All Lines In Service 660 MW	
W49TH_ST_345KV_8					FWD	
Mon 05/10/2021	to	Mon 05/10/2021				(Import)
0001	Continuous	0030				SCH - PJM_HTP 450 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 210 MW	
					TTC with All Lines In Service 660 MW	
HUDSONTP-W49TH_ST_345_Y56					FWD	
Mon 05/10/2021	to	Thu 05/13/2021				(Import)
0001	Continuous	2300				SCH - PJM_HTP 0 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 660 MW	
					TTC with All Lines In Service 660 MW	
SPRNBK_-TREMONT_345_X28					FWD	
Mon 05/10/2021	to	Wed 05/26/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>03/18/2021</u>	(Import)
0001	Continuous	0200				SPR/DUN-SOUTH 4200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 400 MW	
					TTC with All Lines In Service 4600 MW	
CLAY_-EDIC_345_1-16					FWD	
Mon 05/10/2021	to	Fri 05/14/2021				(Import)
0700	Continuous	1530				OSWEGO EXPORT 4850 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 400 MW	
					TTC with All Lines In Service 5250 MW	

NYISO TRANSFER LIMITATIONS

Sunday ,April 18, 2021 to Tuesday ,October 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -ADIRNDCK_230_MA2

Mon 05/10/2021 to Tue 06/01/2021
1200 Continuous 0659

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

ALCOA_PA_115KV_R8105

Tue 05/11/2021 to Thu 06/03/2021
0630 Continuous 1630

Work scheduled by: NGrid

FWD

(Import)

MOSES SOUTH **3100 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 3150 MW

DENNISON-ROSEMNTB_115_2/22

Wed 05/12/2021 to Wed 05/12/2021 **UPDATED by HQ 04/16/2021**
0630 Daily(No Weekends) 1830

Work scheduled by: NGrid

FWD

REV

(Import) (Export)

SCH - HQ_CEDARS **95 MW 40 MW**
Impacts Total Transfer Capability 95 MW 0 MW
TTC with All Lines In Service 190 MW 40 MW

SCH-HQ_CEDARS-NYISO_LIMIT_80

Wed 05/12/2021 to Wed 05/12/2021 **UPDATED by HQ 04/16/2021**
0630 Daily(No Weekends) 1830

Work scheduled by: NGrid

FWD

(Import)

SCH - HQ_CEDARS **80 MW**
Impacts Total Transfer Capability 110 MW
TTC with All Lines In Service 190 MW

W49TH_ST_345KV_7

Thu 05/13/2021 to Thu 05/13/2021
2230 Continuous 2300

Work scheduled by: ConEd

FWD

(Import)

SCH - PJM_HTP **300 MW**
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

W49TH_ST_345KV_8

Thu 05/13/2021 to Thu 05/13/2021
2230 Continuous 2300

Work scheduled by: ConEd

FWD

(Import)

SCH - PJM_HTP **450 MW**
Impacts Total Transfer Capability 210 MW
TTC with All Lines In Service 660 MW

CRICKVLY-PLSNTVLY_345_F83

Fri 05/14/2021 to Fri 05/14/2021
0001 Continuous 2200

Work scheduled by: ConEd

FWD

(Import)

SCH - NE - NY **350 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 1400 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 18, 2021 to Tuesday ,October 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CRICKVLY-PLSNTVLY_345_F83			FWD	REV
Fri 05/14/2021 to Fri 05/14/2021			(Import) (Export)	
0001	Continuous	2200	SCH - NPX_1385	100 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	100 MW
			TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR_138_601 & CRICKVLY-PLSNTVLY_345_F83			FWD	REV
Fri 05/14/2021 to Fri 05/14/2021			(Import) (Export)	
0001		2200	SCH - NPX_1385	0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW
			TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR_138_602 & CRICKVLY-PLSNTVLY_345_F83			FWD	REV
Fri 05/14/2021 to Fri 05/14/2021			(Import) (Export)	
0001		2200	SCH - NPX_1385	0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW
			TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR_138_603 & CRICKVLY-PLSNTVLY_345_F83			FWD	REV
Fri 05/14/2021 to Fri 05/14/2021			(Import) (Export)	
0001		2200	SCH - NPX_1385	0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW
			TTC with All Lines In Service	200 MW
BUCHAN_N-EASTVIEW_345_W93			FWD	
Fri 05/14/2021 to Sat 05/15/2021			(Import)	
0001	Continuous	0200	UPNY CONED	4350 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	3465 MW
			TTC with All Lines In Service	7815 MW
RAMAPO_-BUCHAN_N_345_Y94			FWD	
Fri 05/14/2021 to Sat 05/15/2021			(Import)	
0001	Continuous	0200	UPNY CONED	7580 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	235 MW
			TTC with All Lines In Service	7815 MW
SPRNBK_345KV_RS3 & SPRNBK_345KV_RS4			FWD	
Sat 05/15/2021 to Sat 05/15/2021			(Import)	
0301		2230	SPR/DUN-SOUTH	3200 MW
Work scheduled by:			Impacts Total Transfer Capability	1400 MW
			TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 18, 2021 to Tuesday ,October 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						FWD
DUNWODIE_345KV_5						(Import)
Mon 05/17/2021	to	Tue 05/18/2021	<u>UPDATED</u>	<u>by CE</u>	<u>03/15/2021</u>	3800 MW
0201	Continuous	0200				Impacts Total Transfer Capability 800 MW
Work scheduled by: ConEd						TTC with All Lines In Service 4600 MW
<hr/>						FWD
DUNWODIE_345KV_7						(Import)
Mon 05/17/2021	to	Tue 05/18/2021	<u>UPDATED</u>	<u>by CE</u>	<u>03/15/2021</u>	3800 MW
0201	Continuous	0200				Impacts Total Transfer Capability 800 MW
Work scheduled by: ConEd						TTC with All Lines In Service 4600 MW
<hr/>						FWD
SPRNBRK_-DUNWODIE_345_W75						(Import)
Mon 05/17/2021	to	Tue 05/18/2021	<u>UPDATED</u>	<u>by CE</u>	<u>03/15/2021</u>	3800 MW
0201	Continuous	0200				Impacts Total Transfer Capability 800 MW
Work scheduled by: ConEd						TTC with All Lines In Service 4600 MW
<hr/>						FWD
SPRNBRK__345KV_RNS3						(Import)
Mon 05/17/2021	to	Tue 05/18/2021	<u>UPDATED</u>	<u>by CE</u>	<u>03/15/2021</u>	3800 MW
0201	Continuous	0200				Impacts Total Transfer Capability 800 MW
Work scheduled by: ConEd						TTC with All Lines In Service 4600 MW
<hr/>						FWD
NIAGARA_-STA_255__345_NH2						(Import)
Mon 05/17/2021	to	Fri 05/21/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>03/23/2021</u>	1400 MW
0500	Continuous	1700				Impacts Total Transfer Capability 1750 MW
Work scheduled by: NYPA						TTC with All Lines In Service 3150 MW
<hr/>						FWD
SAND_BAR-PLATSBRG_115_PV20						SCH - NE - NY
Mon 05/17/2021	to	Fri 07/02/2021				Impacts Total Transfer Capability
0600	Continuous	1800				TTC with All Lines In Service
Work scheduled by: ISONE						
<hr/>						FWD
GOETHALS_345KV_5						(Import)
Wed 05/19/2021	to	Mon 05/24/2021	<u>EXTENDED</u>	<u>by CE</u>	<u>04/05/2021</u>	3800 MW
0100	Continuous	0200				Impacts Total Transfer Capability
Work scheduled by: ConEd						TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Sunday ,April 18, 2021 to Tuesday ,October 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LINDEN__-GOETHALS_230_A2253					FWD	REV
Wed 05/19/2021	to	Mon 05/24/2021	EXTENDED	by CE	04/05/2021	(Import) (Export)
0100	Continuous	0200				
Work scheduled by: ConEd					SCH - PJ - NY	2050 MW 1150 MW
					Impacts Total Transfer Capability	150 MW 100 MW
					TTC with All Lines In Service	2200 MW 1250 MW
<hr/>						
LINDEN__-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402					FWD	REV
Wed 05/19/2021	to	Mon 05/24/2021				(Import) (Export)
0100		0200				
Work scheduled by:					SCH - PJ - NY	2000 MW 1000 MW
					Impacts Total Transfer Capability	200 MW 250 MW
					TTC with All Lines In Service	2200 MW 1250 MW
<hr/>						
LINDEN__-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402 & MARION__-FARRAGUT_345_C3403					FWD	REV
Wed 05/19/2021	to	Mon 05/24/2021				(Import) (Export)
0100		0200				
Work scheduled by:					SCH - PJ - NY	2000 MW 1000 MW
					Impacts Total Transfer Capability	200 MW 250 MW
					TTC with All Lines In Service	2200 MW 1250 MW
<hr/>						
LINDEN__-GOETHALS_230_A2253 & MARION__-FARRAGUT_345_C3403					FWD	REV
Wed 05/19/2021	to	Mon 05/24/2021				(Import) (Export)
0100		0200				
Work scheduled by:					SCH - PJ - NY	2000 MW 1000 MW
					Impacts Total Transfer Capability	200 MW 250 MW
					TTC with All Lines In Service	2200 MW 1250 MW
<hr/>						
BUCHAN_S-MILLWOOD_345_W97					FWD	
Thu 05/20/2021	to	Sat 05/22/2021				(Import)
0001	Continuous	0200				
Work scheduled by: ConEd					UPNY CONED	7680 MW
					Impacts Total Transfer Capability	135 MW
					TTC with All Lines In Service	7815 MW
<hr/>						
W49TH_ST_345KV_6					FWD	
Thu 05/20/2021	to	Sat 05/22/2021	UPDATED	by CONED	03/30/2021	(Import)
0001	Continuous	0200				
Work scheduled by: ConEd					SCH - PJM_HTP	300 MW
					Impacts Total Transfer Capability	360 MW
					TTC with All Lines In Service	660 MW
<hr/>						
W49TH_ST-E13THSTA_345_M55					FWD	
Thu 05/20/2021	to	Mon 05/24/2021	UPDATED	by CONED	03/30/2021	(Import)
0001	Continuous	0200				
Work scheduled by: ConEd					SPR/DUN-SOUTH	3800 MW
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 18, 2021 to Tuesday ,October 18, 2022

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

E13THSTA-FARRAGUT_345_46				FWD	
Sat 05/22/2021	to	Mon 05/24/2021	<u>UPDATED</u> <u>by CONED</u> <u>03/30/2021</u>	(Import)	
0001	Continuous	0200		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
PLSNTVLY-WOOD_ST_345_F31				FWD	
Mon 05/24/2021	to	Tue 05/25/2021		(Import)	
0001	Continuous	0159		UPNY CONED	4000 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	3815 MW
				TTC with All Lines In Service	7815 MW
PLSNTVLY_345KV_RNS4				FWD	
Mon 05/24/2021	to	Tue 05/25/2021		(Import)	
0001	Continuous	0159		UPNY CONED	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	4015 MW
				TTC with All Lines In Service	7815 MW
W49TH_ST_345KV_6				FWD	
Mon 05/24/2021	to	Mon 05/24/2021	<u>UPDATED</u> <u>by CONED</u> <u>03/30/2021</u>	(Import)	
0130	Continuous	0200		SCH - PJM_HTP	300 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	360 MW
				TTC with All Lines In Service	660 MW
DENNISON-ROSEMNTB_115_2/22				FWD	REV
Mon 05/24/2021	to	Wed 05/26/2021		(Import)	(Export)
0630	Continuous	1900		SCH - HQ_CEDARS	95 MW 40 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	95 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
SCH-HQ_CEDARS-NYISO_LIMIT_80				FWD	
Mon 05/24/2021	to	Wed 05/26/2021		(Import)	
0630	Continuous	1900		SCH - HQ_CEDARS	80 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	110 MW
				TTC with All Lines In Service	190 MW
ROSETON_-EFISHRIL_345_RFK305				FWD	
Wed 05/26/2021	to	Thu 05/27/2021		(Import)	
0001	Continuous	0200		UPNY CONED	6680 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	1135 MW
				TTC with All Lines In Service	7815 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 18, 2021 to Tuesday ,October 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event Name	Start	End	Time	Work by	Notes	FWD	REV
DENNISON-ROSEMNTA_115_1/11	Thu 05/27/2021	Fri 05/28/2021	0630 - 1900	NGrid		(Import)	(Export)
					SCH - HQ_CEDARS	95 MW	40 MW
					Impacts Total Transfer Capability	95 MW	0 MW
					TTC with All Lines In Service	190 MW	40 MW
SCH-HQ_CEDARS-NYISO_LIMIT_80	Thu 05/27/2021	Fri 05/28/2021	0630 - 1900	NGrid		(Import)	
					SCH - HQ_CEDARS	80 MW	
					Impacts Total Transfer Capability	110 MW	
					TTC with All Lines In Service	190 MW	
VOLNEY_-MARCY_345_19	Tue 06/01/2021	Wed 06/02/2021	0700 - 1730	NYPA	ARR: 19	(Import)	
					CENTRAL EAST - VC	2825 MW	
					Impacts Total Transfer Capability	150 MW	
					TTC with All Lines In Service	2975 MW	
VOLNEY_-MARCY_345_19	Tue 06/01/2021	Wed 06/02/2021	0700 - 1730	NYPA	ARR: 19	(Import)	
					OSWEGO EXPORT	4900 MW	
					Impacts Total Transfer Capability	350 MW	
					TTC with All Lines In Service	5250 MW	
FRASER_-GILBOA_345_GF5-35	Tue 06/01/2021	Mon 06/07/2021	0700 - 1730	NYPA		(Import)	
					CENTRAL EAST - VC	2650 MW	
					Impacts Total Transfer Capability	325 MW	
					TTC with All Lines In Service	2975 MW	
MOSES_-ADIRNDCK_230_MA2	Tue 06/01/2021	Sun 11/14/2021	0700 - 1300	NYPA		(Import)	
					MOSES SOUTH	2100 MW	
					Impacts Total Transfer Capability	1050 MW	
					TTC with All Lines In Service	3150 MW	
MARCY_-EDIC_345_UE1-7	Thu 06/03/2021	Fri 06/04/2021	0700 - 1730	NYPA	ARR: 19&16	(Import)	
					OSWEGO EXPORT	5250 MW	
					Impacts Total Transfer Capability	0 MW	
					TTC with All Lines In Service	5250 MW	

NYISO TRANSFER LIMITATIONS

Sunday ,April 18, 2021 to Tuesday ,October 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
PORTER	-ROTTRDAM_230_30		FWD
Thu 06/03/2021	to	Wed 09/15/2021	(Import)
0700	Continuous	0659	
Work scheduled by: NGrid			
		UPDATED by NGRID 01/19/2021	
		CENTRAL EAST - VC	2805 MW
		Impacts Total Transfer Capability	170 MW
		TTC with All Lines In Service	2975 MW
<hr/>			
MARCY	345KV_CSC		FWD
Sat 06/05/2021	to	Sat 06/05/2021	(Import)
0700	Continuous	1730	
Work scheduled by: NYPA			
		CENTRAL EAST - VC	2925 MW
		Impacts Total Transfer Capability	50 MW
		TTC with All Lines In Service	2975 MW
<hr/>			
ATHENS	-PLSNTVLY_345_91		FWD
Tue 06/08/2021	to	Wed 06/16/2021	(Import)
0600	Continuous	2000	
Work scheduled by: NGrid			
		UPNY CONED	3800 MW
		Impacts Total Transfer Capability	4015 MW
		TTC with All Lines In Service	7815 MW
<hr/>			
GILBOA	-N.SCTLND_345_GNS-1		FWD
Wed 06/09/2021	to	Wed 06/09/2021	(Import)
0800	Daily	1200	
Work scheduled by: NGrid			
		CENTRAL EAST - VC	2520 MW
		Impacts Total Transfer Capability	455 MW
		TTC with All Lines In Service	2975 MW
<hr/>			
BECK	-NIAGARA_345_PA301		FWD
Wed 06/16/2021	to	Thu 06/17/2021	(Import) (Export)
0500	Continuous	2330	
Work scheduled by: NYPA			
		SCH - OH - NY	900 MW 800 MW
		Impacts Total Transfer Capability	1050 MW 900 MW
		TTC with All Lines In Service	1950 MW 1700 MW
<hr/>			
LEEDS	-PLSNTVLY_345_92		FWD
Thu 06/17/2021	to	Thu 06/24/2021	(Import)
0600	Continuous	2000	
Work scheduled by: NGrid			
		UPNY CONED	3800 MW
		Impacts Total Transfer Capability	4015 MW
		TTC with All Lines In Service	7815 MW
<hr/>			
BECK	-NIAGARA_345_PA301		FWD
Fri 06/25/2021	to	Fri 06/25/2021	(Import) (Export)
0500	Continuous	1700	
Work scheduled by: NYPA			
		SCH - OH - NY	900 MW 800 MW
		Impacts Total Transfer Capability	1050 MW 900 MW
		TTC with All Lines In Service	1950 MW 1700 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 18, 2021 to Tuesday ,October 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASANX-COOPERS__345_UCC2-41				FWD
Fri 06/25/2021	to	Tue 08/10/2021		(Import)
0700	Continuous	1530		CENTRAL EAST - VC 2500 MW
Work scheduled by: NYPA			ARR: 19	Impacts Total Transfer Capability 475 MW
				TTC with All Lines In Service 2975 MW
MARCY__-FRASANX_345_UCC2-41				FWD
Fri 06/25/2021	to	Tue 08/10/2021		(Import)
0700	Continuous	1530		CENTRAL EAST - VC 2500 MW
Work scheduled by: NYPA			ARR: 19	Impacts Total Transfer Capability 475 MW
				TTC with All Lines In Service 2975 MW
BECK__-NIAGARA_345_PA302				FWD
Mon 07/12/2021	to	Fri 07/16/2021		(Import) (Export)
0500	Continuous	1700		SCH - OH - NY 900 MW 800 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 1050 MW 900 MW
				TTC with All Lines In Service 1950 MW 1700 MW
NIAGARA_345_230_AT4				FWD
Mon 07/19/2021	to	Fri 07/30/2021	UPDATED by NYPA 02/19/2021	(Import) (Export)
0500	Continuous	1700		SCH - OH - NY 1900 MW 1400 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 50 MW 300 MW
				TTC with All Lines In Service 1950 MW 1700 MW
NIAGARA_-STA_255_345_NH2				FWD
Mon 07/26/2021	to	Fri 07/30/2021	UPDATED by NYPA 02/19/2021	(Import)
0500	Continuous	1900		DYSINGER EAST 1400 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 1750 MW
				TTC with All Lines In Service 3150 MW
SAND_BAR-PLATSBRG_115_PV20				
Tue 08/03/2021	to	Tue 08/03/2021		
0700	Continuous	1830		SCH - NE - NY
Work scheduled by: NYPA				Impacts Total Transfer Capability
				TTC with All Lines In Service
KINTIGH_-STA_255_345_SH1-39				FWD
Mon 08/09/2021	to	Sun 08/15/2021		(Import)
0500	Continuous	1900		DYSINGER EAST 1400 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 1750 MW
				TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 18, 2021 to Tuesday ,October 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-KINTIGH__345_NS1-38

Mon 08/09/2021 to Sun 08/15/2021
 0500 Continuous 1900
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **1400 MW**
 Impacts Total Transfer Capability 1750 MW
 TTC with All Lines In Service 3150 MW

KINTIGH_-STA_255__345_SH1-39

Mon 08/16/2021 to Sun 08/22/2021
 0500 Continuous 1900
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **1400 MW**
 Impacts Total Transfer Capability 1750 MW
 TTC with All Lines In Service 3150 MW

NIAGARA_-KINTIGH__345_NS1-38

Mon 08/16/2021 to Sun 08/22/2021
 0500 Continuous 1900
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **1400 MW**
 Impacts Total Transfer Capability 1750 MW
 TTC with All Lines In Service 3150 MW

NIAGARA_-STA_255__345_NH2

Wed 09/01/2021 to Tue 09/21/2021
 0500 Continuous 1900
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **1400 MW**
 Impacts Total Transfer Capability 1750 MW
 TTC with All Lines In Service 3150 MW

FRASANNX-COOPERS__345_UCC2-41

Tue 09/07/2021 to Wed 09/15/2021 **UPDATED by NYISO 02/03/2021**
 0700 Continuous 1730
 Work scheduled by: NYPA **ARR: 19**

FWD
 (Import)
 CENTRAL EAST - VC **2500 MW**
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

MARCY_-FRASANNX_345_UCC2-41

Tue 09/07/2021 to Wed 09/15/2021 **UPDATED by NYISO 02/03/2021**
 0700 Continuous 1730
 Work scheduled by: NYPA **ARR: 19**

FWD
 (Import)
 CENTRAL EAST - VC **2500 MW**
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

PORTER_-ROTTDAM_230_30

Wed 09/15/2021 to Tue 11/30/2021
 0700 Continuous 1730
 Work scheduled by: NGrid

FWD
 (Import)
 CENTRAL EAST - VC **2805 MW**
 Impacts Total Transfer Capability 170 MW
 TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 18, 2021 to Tuesday ,October 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EDIC -N.SCTLND_345_14

Thu 09/16/2021 to Sun 11/14/2021
 0700 Continuous 1730
 Work scheduled by: NGrid

FWD
 (Import)

CENTRAL EAST - VC **1670 MW**
 Impacts Total Transfer Capability 1305 MW
 TTC with All Lines In Service 2975 MW

EDIC -N.SCTLND_345_14 & PORTER -ROTTDAM_230_30

Thu 09/16/2021 to Sun 11/14/2021
 0700 Continuous 1730
 Work scheduled by:

FWD
 (Import)

CENTRAL EAST - VC **1500 MW**
 Impacts Total Transfer Capability 1475 MW
 TTC with All Lines In Service 2975 MW

HURLYAVE-ROSETON_345_303

Thu 09/16/2021 to Sun 10/17/2021 **UPDATED by CHGE 09/22/2020**
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)

UPNY CONED **4100 MW**
 Impacts Total Transfer Capability 3715 MW
 TTC with All Lines In Service 7815 MW

HOMRC_NY-MAINS_NY_345_47

Sat 09/18/2021 to Fri 11/05/2021
 0800 Continuous 1600
 Work scheduled by: PJM

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

PANNELL -CLAY_345_1

Mon 09/20/2021 to Fri 09/24/2021
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)

WEST CENTRAL **1300 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

CLAY -EDIC_345_2-15

Mon 09/20/2021 to Sat 10/16/2021
 0700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)

OSWEGO EXPORT **4850 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 5250 MW

KINTIGH -STA_255_345_SH1-39

Mon 09/27/2021 to Wed 09/29/2021 **UPDATED by NYPA 03/04/2021**
 0500 Continuous 0459
 Work scheduled by: NYPA

FWD
 (Import)

DYSINGER EAST **1400 MW**
 Impacts Total Transfer Capability 1750 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 18, 2021 to Tuesday ,October 18, 2022

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-KINTIGH__345_NS1-38

Mon 09/27/2021 to Wed 09/29/2021
0500 Continuous 0459

UPDATED by NYPA 03/04/2021

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

PANNELL_-CLAY____345_2

Mon 09/27/2021 to Fri 10/01/2021
0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

W49TH_ST_345KV_6

Tue 09/28/2021 to Tue 09/28/2021
0100 Continuous 0130

UPDATED by CONED 01/15/2021

Work scheduled by: ConEd

FWD

(Import)

SCH - PJM_HTP **300 MW**
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

E13THSTA-FARRAGUT_345_46

Tue 09/28/2021 to Tue 10/26/2021
0100 Continuous 0300

UPDATED by CONED 01/15/2021

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

W49TH_ST-E13THSTA_345_M55

Tue 09/28/2021 to Tue 10/26/2021
0100 Continuous 0300

UPDATED by CONED 01/15/2021

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

KINTIGH_-STA_255__345_SH1-39

Wed 09/29/2021 to Wed 12/01/2021
0500 Continuous 1900

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

NIAGARA_-KINTIGH__345_NS1-38

Wed 09/29/2021 to Wed 12/01/2021
0500 Continuous 1900

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 18, 2021 to Tuesday ,October 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LEEDS___-HURLYAVE_345_301

Mon 10/18/2021 to Fri 11/19/2021
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4100 MW**
 Impacts Total Transfer Capability 3715 MW
 TTC with All Lines In Service 7815 MW

GOETHALS_345KV_5

Thu 10/21/2021 to Sat 11/20/2021 **UPDATED by CONED 03/05/2021**
 0001 Continuous 0200
 Work scheduled by: ConEd

STATEN ISLAND
 Impacts Total Transfer Capability
 TTC with All Lines In Service

W49TH_ST_345KV_6

Tue 10/26/2021 to Tue 10/26/2021 **UPDATED by CONED 01/15/2021**
 0230 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

SCH-IMO-NYISO_LIMIT_1750

Mon 11/01/2021 to Fri 12/31/2021 **UPDATED by IESO 05/03/2019**
 0001 Continuous 2359
 Work scheduled by: IESO

FWD
 (Import)
 SCH - OH - NY **2050 MW**
 Impacts Total Transfer Capability 250 MW
 TTC with All Lines In Service 2300 MW

SCH-NYISO-IMO_LIMIT_1600

Mon 11/01/2021 to Fri 12/31/2021 **UPDATED by IESO 05/03/2019**
 0001 Continuous 2359
 Work scheduled by: IESO

REV
 (Export)
 SCH - OH - NY **1900 MW**
 Impacts Total Transfer Capability 100 MW
 TTC with All Lines In Service 2000 MW

LINDN_CG-LNDVFT___345_V-3022

Tue 11/02/2021 to Fri 11/05/2021
 0800 Continuous 1500
 Work scheduled by: PJM

FWD REV
 (Import) (Export)
 SCH - PJM_VFT **0 MW 0 MW**
 Impacts Total Transfer Capability 315 MW 315 MW
 TTC with All Lines In Service 315 MW 315 MW

PORTER___-ROTTRDAM_230_30 & MASSENA_-MARCY___765_MSU1

Mon 11/15/2021 to Tue 11/30/2021
 0100 1730
 Work scheduled by:

FWD
 (Import)
 CENTRAL EAST - VC **1500 MW**
 Impacts Total Transfer Capability 1475 MW
 TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 18, 2021 to Tuesday ,October 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHATGUAY-MASSENA__765_7040

Mon 11/15/2021 to Tue 11/30/2021
 0100 Continuous 1859

Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **1550 MW**
 Impacts Total Transfer Capability 1600 MW
 TTC with All Lines In Service 3150 MW

CHATGUAY-MASSENA__765_7040

Mon 11/15/2021 to Tue 11/30/2021
 0100 Continuous 1859

Work scheduled by: NYPA

FWD REV
 (Import) (Export)
 SCH - HQ - NY **0 MW 0 MW**
 Impacts Total Transfer Capability 1500 MW 1000 MW
 TTC with All Lines In Service 1500 MW 1000 MW

MARCY__765_345_AT1

Mon 11/15/2021 to Tue 11/30/2021
 0100 Continuous 1859

Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1750 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 3150 MW

MARCY__765_345_AT2

Mon 11/15/2021 to Tue 11/30/2021
 0100 Continuous 1859

Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

MASSENA_-MARCY__765_MSU1

Mon 11/15/2021 to Tue 11/30/2021
 0100 Continuous 1859

Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **1670 MW**
 Impacts Total Transfer Capability 1305 MW
 TTC with All Lines In Service 2975 MW

MASSENA_-MARCY__765_MSU1

Mon 11/15/2021 to Tue 11/30/2021
 0100 Continuous 1859

Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **500 MW**
 Impacts Total Transfer Capability 2650 MW
 TTC with All Lines In Service 3150 MW

MASSENA_-MARCY__765_MSU1

Mon 11/15/2021 to Tue 11/30/2021
 0100 Continuous 1859

Work scheduled by: NYPA

FWD REV
 (Import) (Export)
 SCH - HQ - NY **475 MW 1000 MW**
 Impacts Total Transfer Capability 1025 MW 0 MW
 TTC with All Lines In Service 1500 MW 1000 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 18, 2021 to Tuesday ,October 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA -MARCY 765_MSU1			FWD	
Mon 11/15/2021	to	Tue 11/30/2021	(Import)	
0100	Continuous	1859	SCH - HQ_CEDARS	90 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	109 MW
			TTC with All Lines In Service	199 MW
MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040			FWD	
Mon 11/15/2021	to	Tue 11/30/2021	(Import)	
0100		1859	MOSES SOUTH	500 MW
Work scheduled by:			Impacts Total Transfer Capability	2650 MW
			TTC with All Lines In Service	3150 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2			FWD	REV
Mon 11/15/2021	to	Tue 11/30/2021	(Import)	(Export)
0100		1859	SCH - HQ - NY	850 MW 0 MW
Work scheduled by:			Impacts Total Transfer Capability	650 MW 1000 MW
			TTC with All Lines In Service	1500 MW 1000 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2			FWD	
Mon 11/15/2021	to	Tue 11/30/2021	(Import)	
0100		1859	SCH - HQ_CEDARS	90 MW
Work scheduled by:			Impacts Total Transfer Capability	109 MW
			TTC with All Lines In Service	199 MW
STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1			FWD	
Mon 11/15/2021	to	Tue 11/30/2021	(Import)	
0100		1859	SCH - HQ_CEDARS	90 MW
Work scheduled by:			Impacts Total Transfer Capability	109 MW
			TTC with All Lines In Service	199 MW
STLAWRNC-MOSES 230_L33P & MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2			FWD	
Mon 11/15/2021	to	Tue 11/30/2021	(Import)	
0100		1859	SCH - HQ_CEDARS	90 MW
Work scheduled by:			Impacts Total Transfer Capability	109 MW
			TTC with All Lines In Service	199 MW
FRASER 345_FRASER SVC			FWD	
Wed 12/01/2021	to	Mon 02/28/2022	(Import)	
0700	Continuous	1730	CENTRAL EAST - VC	2935 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	40 MW
			TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 18, 2021 to Tuesday ,October 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA1

Wed 12/01/2021 to Tue 05/31/2022
0700 Continuous 1300

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

NIAGARA_-STA_255_345_NH2

Thu 12/02/2021 to Thu 01/13/2022
0500 Continuous 1900

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

MOTTHAVN-RAINEY___345_Q12

Sun 12/05/2021 to Sat 12/25/2021 **UPDATED by CONED 03/25/2021**
0001 Continuous 0159

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

LEEDS___-PLSNTVLY_345_92

Thu 02/17/2022 to Mon 02/21/2022 **UPDATED by NGRID 03/31/2021**
0600 Continuous 1900

Work scheduled by: NGrid

FWD

(Import)

UPNY CONED **3800 MW**
Impacts Total Transfer Capability 2420 MW
TTC with All Lines In Service 6220 MW

GOETHALS_345KV_5

Sat 03/05/2022 to Mon 04/04/2022 **UPDATED by CONED 03/26/2021**
0001 Continuous 0200

Work scheduled by: ConEd

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

LINDEN___-GOETHALS_230_A2253

Sat 03/05/2022 to Mon 04/04/2022 **UPDATED by CONED 03/26/2021**
0001 Continuous 0200

Work scheduled by: ConEd

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

N.SCTLND-ALPS_____345_2

Mon 05/02/2022 to Mon 05/09/2022
0600 Daily 1800

Work scheduled by: NGrid

FWD

(Import)

SCH - NE - NY **750 MW**
Impacts Total Transfer Capability 650 MW
TTC with All Lines In Service 1400 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 18, 2021 to Tuesday ,October 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
N. SCTLND-ALPS_____345_2						
Mon 05/02/2022	to	Mon 05/09/2022				
0600	Daily	1800			SCH - NPX_1385	100 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
HOMRC_NY-MAINS_NY_345_47						
Fri 05/20/2022	to	Fri 05/27/2022	<u>UPDATED</u>	<u>by PJM</u>	<u>11/19/2020</u>	
0800	Continuous	1600			SCH - PJ - NY	
Work scheduled by: PJM					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
HOMR_NYW-PIERC_NY_345_48						
Fri 05/20/2022	to	Fri 05/27/2022	<u>UPDATED</u>	<u>by PJM</u>	<u>11/19/2020</u>	
0800	Continuous	1600			SCH - PJ - NY	
Work scheduled by: PJM					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
MOSES___-ADIRNDCK_230_MA2						
Wed 06/01/2022	to	Mon 11/14/2022				FWD
0700	Continuous	1300			MOSES SOUTH	2100 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	3150 MW
SPRNBRK__345KV_RNS5						
Mon 09/19/2022	to	Mon 09/19/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>09/17/2020</u>	FWD
0001	Continuous	0030			SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
SPRNBRK_-W49TH_ST_345_M51						
Mon 09/19/2022	to	Wed 09/21/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>09/17/2020</u>	FWD
0001	Continuous	2200			SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
SPRNBRK__345KV_RNS5						
Wed 09/21/2022	to	Wed 09/21/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>09/17/2020</u>	FWD
2130	Continuous	2200			SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 18, 2021 to Tuesday ,October 18, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK_-W49TH_ST_345_M51

Sat 10/01/2022 to Mon 10/17/2022
 0001 Continuous 0300

Work scheduled by: ConEd

UPDATED by CONED 08/01/2020

SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

FWD
 (Import)

SPRNBRK_345KV_RNS5

Sat 10/01/2022 to Mon 10/17/2022
 0001 Continuous 0300

Work scheduled by: ConEd

UPDATED by CONED 08/01/2020

SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

FWD
 (Import)