

# NYISO TRANSFER LIMITATIONS

Monday ,April 19, 2021 to Wednesday,October 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**HUDSONP\_-FARRAGUT\_345\_B3402**

Mon 01/15/2018 to Wed 06/30/2021 **EXT FORCE by CONED 08/28/2020**  
 0001 Continuous 2359  
 Work scheduled by: ConEd

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_-FARRAGUT\_345\_C3403**

Mon 01/15/2018 to Wed 06/30/2021  
 0001 2359  
 Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2550 MW</b>	<b>1900 MW</b>
Impacts Total Transfer Capability	250 MW	50 MW
TTC with All Lines In Service	2800 MW	1950 MW

**MARION\_-FARRAGUT\_345\_C3403**

Mon 01/15/2018 to Wed 06/30/2021 **EXT FORCE by CONED 08/28/2020**  
 0001 Continuous 2359  
 Work scheduled by: ConEd

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**STLAWRNC-MOSES\_230\_L33P**

Mon 04/30/2018 to Mon 10/31/2022 **EXT FORCE by IESO 10/01/2020**  
 0456 Continuous 1600  
 Work scheduled by: IESO

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**NEWBRDGE\_345\_138\_BK\_1**

Wed 09/02/2020 to Tue 02/01/2022 **EXT FORCE by LI 01/12/2021**  
 1807 Continuous 2359  
 Work scheduled by: LI

	FWD
	(Import)
SCH - PJM_NEPTUNE	<b>375 MW</b>
Impacts Total Transfer Capability	285 MW
TTC with All Lines In Service	660 MW

**SPRNBK\_-EGRDNCTR\_345\_Y49**

Thu 10/01/2020 to Mon 04/19/2021 **EXT FORCE by LI 02/23/2021**  
 0404 Continuous 2359  
 Work scheduled by: LI

	FWD
	(Import)
CONED - LIPA	<b>775 MW</b>
Impacts Total Transfer Capability	725 MW
TTC with All Lines In Service	1500 MW

**EGRDNCTY\_345\_138\_AT2**

Sat 10/10/2020 to Mon 04/19/2021 **EXT FORCE by LI 02/23/2021**  
 1815 Continuous 2359  
 Work scheduled by: LI

	FWD
	(Import)
CONED - LIPA	<b>1250 MW</b>
Impacts Total Transfer Capability	250 MW
TTC with All Lines In Service	1500 MW

# NYISO TRANSFER LIMITATIONS

Monday ,April 19, 2021 to Wednesday,October 19, 2022

Seasonal Limits

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**EGRDNCTY\_345\_138\_AT1**

Sat 10/10/2020 to Mon 04/19/2021  
1856 Continuous 2359

**EXT FORCE by LI 02/23/2021**

Work scheduled by: LI

FWD  
(Import)  
**1250 MW**  
CONED - LIPA  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1500 MW

**SCH-IMO-NYISO\_LIMIT\_1750**

Sun 11/01/2020 to Fri 04/30/2021  
0001 Continuous 2359

**UPDATED by IESO 05/03/2019**

Work scheduled by: IESO

FWD  
(Import)  
**2050 MW**  
SCH - OH - NY  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 2300 MW

**SCH-NYISO-IMO\_LIMIT\_1600**

Sun 11/01/2020 to Fri 04/30/2021  
0001 Continuous 2359

**UPDATED by IESO 05/03/2019**

Work scheduled by: IESO

REV  
(Export)  
**1900 MW**  
SCH - OH - NY  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 2000 MW

**SAND\_BAR-PLATSBRG\_115\_PV20**

Tue 02/23/2021 to Mon 05/17/2021  
1801 Continuous 0559

**UPDATED by NYISO 03/16/2021**

Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**W49TH\_ST\_345KV\_8**

Tue 03/02/2021 to Sun 05/02/2021  
0201 Continuous 0200

**EXTENDED by CONED 04/10/2021**

Work scheduled by: ConEd

FWD  
(Import)  
**300 MW**  
SCH - PJM\_HTP  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

**PORTER\_\_-ROTTRDAM\_230\_31**

Tue 03/02/2021 to Mon 05/31/2021  
0600 Continuous 1730

**UPDATED by NGRID 03/10/2021**

Work scheduled by: NGrid

FWD  
(Import)  
**2805 MW**  
CENTRAL EAST - VC  
Impacts Total Transfer Capability 170 MW  
TTC with All Lines In Service 2975 MW

**MOSES\_\_-ADIRNDCK\_230\_MAL**

Tue 03/02/2021 to Mon 05/10/2021  
0700 Continuous 1159

**UPDATED by NYPA 02/11/2021**

Work scheduled by: NYPA

FWD  
(Import)  
**2300 MW**  
MOSES SOUTH  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Monday ,April 19, 2021 to Wednesday,October 19, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST\_345KV\_6**

Sun 03/21/2021 to Sun 05/02/2021 **EXTENDED** **by CONED** **04/10/2021**  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
**300 MW**  
 SCH - PJM\_HTP  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

**EDIC -N.SCTLND\_345\_14 & PORTER -ROTRDAM\_230\_31**

Mon 03/22/2021 to Mon 05/31/2021  
 0600 1730  
 Work scheduled by:

FWD  
 (Import)  
**1500 MW**  
 CENTRAL EAST - VC  
 Impacts Total Transfer Capability 1475 MW  
 TTC with All Lines In Service 2975 MW

**EDIC -N.SCTLND\_345\_14**

Mon 03/22/2021 to Mon 05/31/2021 **UPDATED** **by NGRID** **03/10/2021**  
 0600 Continuous 1830  
 Work scheduled by: NGrid

FWD  
 (Import)  
**1670 MW**  
 CENTRAL EAST - VC  
 Impacts Total Transfer Capability 1305 MW  
 TTC with All Lines In Service 2975 MW

**S.RIPLEY-DUNKIRK\_230\_68**

Mon 04/12/2021 to Fri 04/23/2021 **UPDATED** **by NGRID** **04/12/2021**  
 0630 Continuous 1700  
 Work scheduled by: NGrid

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**LEEDS -HURLYAVE\_345\_301**

Mon 04/12/2021 to Wed 04/14/2021 **UPDATED** **by NGRID** **02/01/2021**  
 0800 Continuous 1825  
 Work scheduled by: CHGE

FWD  
 (Import)  
**4100 MW**  
 UPNY CONED  
 Impacts Total Transfer Capability 2120 MW  
 TTC with All Lines In Service 6220 MW

**SPRNBRK -W49TH\_ST\_345\_M51**

Wed 04/14/2021 to Mon 04/26/2021 **EXTENDED** **by CONED** **04/16/2021**  
 1124 Continuous 2359  
 Work scheduled by: ConEd

FWD  
 (Import)  
**3200 MW**  
 SPR/DUN-SOUTH  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

**SCH-NPX\_1385-NYISO\_LIMIT\_150**

Mon 04/19/2021 to Thu 04/29/2021 **FORCED** **by ISONE** **04/17/2021**  
 0001 Continuous 1600  
 Work scheduled by: ISONE

FWD  
 (Import)  
**150 MW**  
 SCH - NPX\_1385  
 Impacts Total Transfer Capability 50 MW  
 TTC with All Lines In Service 200 MW

# NYISO TRANSFER LIMITATIONS

Monday ,April 19, 2021 to Wednesday,October 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>N. SCTLND-ALPS</b> _____ <b>345_2</b>					FWD	
Mon 04/19/2021	to	Mon 04/26/2021	<b>EXTENDED</b>	<b>by NGRID</b>	<b>04/19/2021</b>	(Import)
0841	Continuous	1800				<b>900 MW</b>
Work scheduled by: NGrid					SCH - NE - NY	Impacts Total Transfer Capability
						500 MW
					TTC with All Lines In Service	1400 MW
<b>N. SCTLND-ALPS</b> _____ <b>345_2</b>					FWD	REV
Mon 04/19/2021	to	Mon 04/26/2021	<b>EXTENDED</b>	<b>by NGRID</b>	<b>04/19/2021</b>	(Import) (Export)
0841	Continuous	1800				<b>100 MW 100 MW</b>
Work scheduled by: NGrid					SCH - NPX_1385	Impacts Total Transfer Capability
						100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW
<b>N. SCTLND-LEEDS</b> _____ <b>345_93</b>					FWD	
Mon 04/19/2021	to	Mon 04/26/2021	<b>EXTENDED</b>	<b>by NGRID</b>	<b>04/19/2021</b>	(Import)
0841	Continuous	1800				<b>2650 MW</b>
Work scheduled by: NGrid					CENTRAL EAST - VC	Impacts Total Transfer Capability
						325 MW
					TTC with All Lines In Service	2975 MW
<b>DUNWODIE_345KV_6</b>					FWD	
Tue 04/20/2021	to	Tue 04/20/2021	<b>CANCELLED</b>	<b>by ConEd</b>	<b>04/19/2021</b>	(Import)
0201	Continuous	0230				<b>3800 MW</b>
Work scheduled by: ConEd					SPR/DUN-SOUTH	Impacts Total Transfer Capability
						800 MW
					TTC with All Lines In Service	4600 MW
<b>DUNWODIE_345KV_8</b>					FWD	
Tue 04/20/2021	to	Tue 04/20/2021	<b>CANCELLED</b>	<b>by ConEd</b>	<b>04/19/2021</b>	(Import)
0201	Continuous	0230				<b>3800 MW</b>
Work scheduled by: ConEd					SPR/DUN-SOUTH	Impacts Total Transfer Capability
						800 MW
					TTC with All Lines In Service	4600 MW
<b>WOOD_ST_-PLSNTVLE_345_Y87</b>					FWD	
Tue 04/20/2021	to	Tue 04/20/2021	<b>CANCELLED</b>	<b>by ConEd</b>	<b>04/19/2021</b>	(Import)
0201	Continuous	0230				<b>5905 MW</b>
Work scheduled by: ConEd					UPNY CONED	Impacts Total Transfer Capability
						315 MW
					TTC with All Lines In Service	6220 MW
<b>PLSNTVLE-DUNWODIE_345_W90</b>					FWD	
Tue 04/20/2021	to	Fri 04/23/2021	<b>CANCELLED</b>	<b>by ConEd</b>	<b>04/19/2021</b>	(Import)
0201	Continuous	0159				<b>4000 MW</b>
Work scheduled by: ConEd					UPNY CONED	Impacts Total Transfer Capability
						2220 MW
					TTC with All Lines In Service	6220 MW

# NYISO TRANSFER LIMITATIONS

Monday ,April 19, 2021 to Wednesday,October 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Main Event			FWD	REV
<b>MAINESBG-WATRCURE_345_30</b>			(Import)	
Tue 04/20/2021	to	Wed 04/21/2021		
0800	Continuous	1530	SCH - PJ - NY	<b>2300 MW</b>
Work scheduled by: NYSEG			Impacts Total Transfer Capability	500 MW
			TTC with All Lines In Service	2800 MW
<b>N.SCTLND-ALPS_345_2 &amp; NRTH1385-NOR HBR_138_601</b>			(Import)	(Export)
Wed 04/21/2021	to	Wed 04/21/2021		
0800		1600	SCH - NPX_1385	<b>0 MW 0 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
<b>N.SCTLND-ALPS_345_2 &amp; NRTH1385-NOR HBR_138_602</b>			(Import)	(Export)
Wed 04/21/2021	to	Wed 04/21/2021		
0800		1600	SCH - NPX_1385	<b>0 MW 0 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
<b>N.SCTLND-ALPS_345_2 &amp; NRTH1385-NOR HBR_138_603</b>			(Import)	(Export)
Wed 04/21/2021	to	Wed 04/21/2021		
0800		1600	SCH - NPX_1385	<b>0 MW 0 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
<b>NRTH1385-NOR HBR_138_601</b>			(Import)	(Export)
Wed 04/21/2021	to	Wed 04/21/2021		
0800	Continuous	1600	SCH - NPX_1385	<b>100 MW 100 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
<b>NRTH1385-NOR HBR_138_601 &amp; NRTH1385-NOR HBR_138_602</b>			(Import)	(Export)
Wed 04/21/2021	to	Wed 04/21/2021		
0800		1600	SCH - NPX_1385	<b>0 MW 0 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
<b>NRTH1385-NOR HBR_138_601 &amp; NRTH1385-NOR HBR_138_603</b>			(Import)	(Export)
Wed 04/21/2021	to	Wed 04/21/2021		
0800		1600	SCH - NPX_1385	<b>0 MW 0 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW

# NYISO TRANSFER LIMITATIONS

Monday ,April 19, 2021 to Wednesday,October 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
<b>NRTH1385-NOR HBR__138_602</b>					
Wed 04/21/2021	to	Wed 04/21/2021			
0800	Continuous	1600	SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: ISONE				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR HBR__138_602 &amp; NRTH1385-NOR HBR__138_603</b>					
Wed 04/21/2021	to	Wed 04/21/2021			
0800		1600	SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR HBR__138_603</b>					
Wed 04/21/2021	to	Wed 04/21/2021			
0800	Continuous	1600	SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: ISONE				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	200 MW
<b>NRTH1385-NRTHPORT_138_NNC</b>					
Wed 04/21/2021	to	Wed 04/21/2021			
0800	Continuous	1600	SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Work scheduled by: ISONE				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	200 MW
<b>DUNWODIE_345KV_6</b>					
Fri 04/23/2021	to	Fri 04/23/2021	<b>CANCELLED by ConEd 04/19/2021</b>		
0130	Continuous	0159	SPR/DUN-SOUTH	<b>3800 MW</b>	
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
<b>DUNWODIE_345KV_8</b>					
Fri 04/23/2021	to	Fri 04/23/2021	<b>CANCELLED by ConEd 04/19/2021</b>		
0130	Continuous	0159	SPR/DUN-SOUTH	<b>3800 MW</b>	
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
<b>WOOD_ST_-PLSNTVLE_345_Y87</b>					
Fri 04/23/2021	to	Fri 04/23/2021	<b>CANCELLED by ConEd 04/19/2021</b>		
0130	Continuous	0159	UPNY CONED	<b>5905 MW</b>	
Work scheduled by: ConEd				Impacts Total Transfer Capability	315 MW
				TTC with All Lines In Service	6220 MW

# NYISO TRANSFER LIMITATIONS

Monday ,April 19, 2021 to Wednesday,October 19, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						FWD
PLSNTVLY-WOOD_ST__345_F30						(Import)
Fri 04/23/2021	to	Fri 04/23/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>04/17/2021</u>	
0201	Continuous	0230				UPNY CONED <b>4000 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 2220 MW
						TTC with All Lines In Service 6220 MW
<hr/>						FWD
PLSNTVLY_345KV_RNS5						(Import)
Fri 04/23/2021	to	Fri 04/23/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>04/17/2021</u>	
0201	Continuous	0230				UPNY CONED <b>3800 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 2420 MW
						TTC with All Lines In Service 6220 MW
<hr/>						FWD
MILLWOOD-EASTVIEW_345_W82						(Import)
Fri 04/23/2021	to	Fri 04/23/2021	<u>CANCELLED</u>	<u>by ConEd</u>	<u>04/19/2021</u>	
0201	Continuous	1800				UPNY CONED <b>5985 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 235 MW
						TTC with All Lines In Service 6220 MW
<hr/>						FWD
MILLWOOD_345KV_18						(Import)
Fri 04/23/2021	to	Sat 04/24/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>04/02/2021</u>	
0201	Continuous	2200				UPNY CONED <b>4350 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 1870 MW
						TTC with All Lines In Service 6220 MW
<hr/>						FWD
CHAT_DC_GC1						(Import)
Sat 04/24/2021	to	Sun 04/25/2021				MOSES SOUTH <b>2850 MW</b>
2000	Continuous	0500				Impacts Total Transfer Capability 300 MW
Work scheduled by: HQ						TTC with All Lines In Service 3150 MW
<hr/>						REV
CHAT_DC_GC1						(Export)
Sat 04/24/2021	to	Sun 04/25/2021				SCH - HQ - NY <b>500 MW</b>
2000	Continuous	0500				Impacts Total Transfer Capability 500 MW
Work scheduled by: HQ						TTC with All Lines In Service 1000 MW
<hr/>						FWD
PLSNTVLY-WOOD_ST__345_F30						(Import)
Mon 04/26/2021	to	Tue 04/27/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>04/17/2021</u>	
0001	Continuous	0200				UPNY CONED <b>4000 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 2220 MW
						TTC with All Lines In Service 6220 MW

# NYISO TRANSFER LIMITATIONS

Monday ,April 19, 2021 to Wednesday,October 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY\_345KV\_RNS5

FWD

Mon 04/26/2021 to Tue 04/27/2021 **UPDATED** **by CONED** **04/17/2021**  
 0001 Continuous 0200

(Import)

Work scheduled by: ConEd

UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 2420 MW  
 TTC with All Lines In Service 6220 MW

KINTIGH\_-STA\_255\_345\_SH1-39

FWD

Mon 04/26/2021 to Fri 04/30/2021  
 0700 Continuous 1700

(Import)

Work scheduled by: NYPA

DYSINGER EAST **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

NIAGARA\_-KINTIGH\_345\_NS1-38

FWD

Mon 04/26/2021 to Fri 04/30/2021  
 0700 Continuous 1700

(Import)

Work scheduled by: NYPA

DYSINGER EAST **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

HOMRC\_NY-MAINS\_NY\_345\_47

Mon 04/26/2021 to Sat 05/29/2021 **EXTENDED** **by NYSEG** **03/10/2021**  
 0800 Continuous 1900

Work scheduled by: NYSEG

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FRASER\_-COOPERS\_345\_33

FWD

Mon 04/26/2021 to Fri 04/30/2021  
 0830 Continuous 1500

(Import)

Work scheduled by: NYSEG

CENTRAL EAST - VC **2395 MW**  
 Impacts Total Transfer Capability 580 MW  
 TTC with All Lines In Service 2975 MW

ALCOA\_PA\_115KV\_R8105

FWD

Tue 04/27/2021 to Thu 04/29/2021  
 0630 Continuous 1830

(Import)

Work scheduled by: NGrid

MOSES SOUTH **3100 MW**  
 Impacts Total Transfer Capability 50 MW  
 TTC with All Lines In Service 3150 MW

MOTTHAVN-RAINEY\_345\_Q11

FWD

Wed 04/28/2021 to Sat 05/08/2021  
 0001 Continuous 0200

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW



# NYISO TRANSFER LIMITATIONS

Monday ,April 19, 2021 to Wednesday,October 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BUCHAN_N-EASTVIEW_345_W93</b>					FWD	
Fri 04/30/2021	to	Mon 05/10/2021	<u>EXTENDED</u>	<u>by CONED</u>	<u>04/19/2021</u>	(Import)
0700	Continuous	0159				UPNY CONED <b>4350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	1870 MW
					TTC with All Lines In Service	6220 MW
<b>SCH-IMO-NYISO_LIMIT_1600</b>					FWD	
Sat 05/01/2021	to	Sun 10/31/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Import)
0001	Continuous	2359				SCH - OH - NY <b>1900 MW</b>
Work scheduled by: IESO					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	1950 MW
<b>W49TH_ST_345KV_5</b>					FWD	
Sun 05/02/2021	to	Sun 05/02/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>04/13/2021</u>	(Import)
0201	Continuous	0231				SCH - PJM_HTP <b>300 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	360 MW
					TTC with All Lines In Service	660 MW
<b>W49TH_ST_345KV_7</b>					FWD	
Sun 05/02/2021	to	Sun 05/02/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>04/13/2021</u>	(Import)
0201	Continuous	0231				SCH - PJM_HTP <b>300 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	360 MW
					TTC with All Lines In Service	660 MW
<b>CHAT_DC_GC2</b>					FWD	
Sun 05/02/2021	to	Fri 05/28/2021				(Import)
0500	Continuous	1700				MOSES SOUTH <b>2850 MW</b>
Work scheduled by: HQ					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW
<b>CHAT_DC_GC2</b>					REV	
Sun 05/02/2021	to	Fri 05/28/2021				(Export)
0500	Continuous	1700				SCH - HQ - NY <b>500 MW</b>
Work scheduled by: HQ					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1000 MW
<b>DUNWODIE_345KV_7</b>					FWD	
Mon 05/03/2021	to	Mon 05/03/2021				(Import)
0001	Continuous	0030				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW

# NYISO TRANSFER LIMITATIONS

Monday ,April 19, 2021 to Wednesday,October 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Work Scheduled	Start	End	Area	Impact	TTC	FWD	REV
<b>DUNWODIE_345KV_8</b>							
Mon 05/03/2021	to	Mon 05/03/2021				FWD	
0001	Continuous	0030	SPR/DUN-SOUTH	Impacts Total Transfer Capability	800 MW	(Import)	
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW		
<hr/>							
<b>DUNWODIE-MOTTHAVN_345_72</b>							
Mon 05/03/2021	to	Mon 05/03/2021				FWD	
0001	Continuous	1800	SPR/DUN-SOUTH	Impacts Total Transfer Capability	800 MW	(Import)	
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW		
<hr/>							
<b>NRTH1385-NOR HBR_138_601</b>							
Mon 05/03/2021	to	Mon 05/24/2021				FWD	REV
0600	Continuous	2359	SCH - NPX_1385	Impacts Total Transfer Capability	100 MW	(Import)	(Export)
Work scheduled by: LI				TTC with All Lines In Service	200 MW		100 MW
<hr/>							
<b>NRTH1385-NOR HBR_138_601 &amp; NRTH1385-NOR HBR_138_602</b>							
Mon 05/03/2021	to	Mon 05/24/2021				FWD	REV
0600		2359	SCH - NPX_1385	Impacts Total Transfer Capability	0 MW	(Import)	(Export)
Work scheduled by:				TTC with All Lines In Service	200 MW		200 MW
<hr/>							
<b>NRTH1385-NOR HBR_138_601 &amp; NRTH1385-NOR HBR_138_603</b>							
Mon 05/03/2021	to	Mon 05/24/2021				FWD	REV
0600		2359	SCH - NPX_1385	Impacts Total Transfer Capability	0 MW	(Import)	(Export)
Work scheduled by:				TTC with All Lines In Service	200 MW		200 MW
<hr/>							
<b>NRTH1385-NOR HBR_138_602</b>							
Mon 05/03/2021	to	Mon 05/24/2021				FWD	REV
0600	Continuous	2359	SCH - NPX_1385	Impacts Total Transfer Capability	100 MW	(Import)	(Export)
Work scheduled by: LI				TTC with All Lines In Service	200 MW		200 MW
<hr/>							
<b>NRTH1385-NOR HBR_138_602 &amp; NRTH1385-NOR HBR_138_603</b>							
Mon 05/03/2021	to	Mon 05/24/2021				FWD	REV
0600		2359	SCH - NPX_1385	Impacts Total Transfer Capability	0 MW	(Import)	(Export)
Work scheduled by:				TTC with All Lines In Service	200 MW		200 MW

# NYISO TRANSFER LIMITATIONS

Monday ,April 19, 2021 to Wednesday,October 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event ID	Start Date	End Date	Time	Duration	Work Scheduled by	SCH	FWD	REV
<b>NRTH1385-NOR HBR__138_603</b>	Mon 05/03/2021	Mon 05/24/2021	0600	Continuous	LI	SCH - NPX_1385	(Import)	(Export)
						Impacts Total Transfer Capability	100 MW	100 MW
						TTC with All Lines In Service	200 MW	200 MW
<b>NRTH1385-NRTHPORT_138_NNC</b>	Mon 05/03/2021	Mon 05/24/2021	0600	Continuous	LI	SCH - NPX_1385	(Import)	(Export)
						Impacts Total Transfer Capability	0 MW	0 MW
						TTC with All Lines In Service	200 MW	200 MW
<b>CLAY__-EDIC__345_2-15</b>	Mon 05/03/2021	Fri 05/07/2021	0700	Continuous	NYPA	OSWEGO EXPORT	(Import)	
						Impacts Total Transfer Capability	4850 MW	
						TTC with All Lines In Service	400 MW	5250 MW
<b>FIVEMILE-STOLLERD_345_29</b>	Mon 05/03/2021	Fri 05/14/2021	0700	Continuous	NYSEG	SCH - PJ - NY		
						Impacts Total Transfer Capability		
						TTC with All Lines In Service		
<b>SCH-HQ-NYISO_LIMIT_1400</b>	Mon 05/03/2021	Fri 05/14/2021	0700	Continuous	HQ	SCH - HQ - NY	(Import)	
						Impacts Total Transfer Capability	1400 MW	
						TTC with All Lines In Service	100 MW	1500 MW
<b>PANNELL_-CLAY__345_2</b>	Mon 05/03/2021	Sun 05/30/2021	0700	Continuous	NYPA	WEST CENTRAL	(Import)	
						Impacts Total Transfer Capability	1300 MW	
						TTC with All Lines In Service	950 MW	2250 MW
<b>HURLYAVE-ROSETON__345_303</b>	Mon 05/03/2021	Fri 05/21/2021	0800	Continuous	CHGE	UPNY CONED	(Import)	
						Impacts Total Transfer Capability	4100 MW	
						TTC with All Lines In Service	3715 MW	7815 MW

# NYISO TRANSFER LIMITATIONS

Monday ,April 19, 2021 to Wednesday,October 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event Name	Start Date	End Date	Time	Duration	Notes	Impact	FWD	REV	
<b>SHOR_NPX-SHOREHAM_138_CSC</b>	Mon 05/03/2021	Sat 05/08/2021	0900	Continuous	1600	<b>EXTENDED by ISONE 03/15/2021</b>	SCH - NPX_CSC Impacts Total Transfer Capability TTC with All Lines In Service	FWD (Import) <b>0 MW</b> 330 MW 330 MW	REV (Export) <b>0 MW</b> 330 MW 330 MW
Work scheduled by: LI									
<b>DUNWODIE_345KV_7</b>	Mon 05/03/2021	Mon 05/03/2021	1730	Continuous	1800		SPR/DUN-SOUTH Impacts Total Transfer Capability TTC with All Lines In Service	FWD (Import) <b>3800 MW</b> 800 MW 4600 MW	
Work scheduled by: ConEd									
<b>DUNWODIE_345KV_8</b>	Mon 05/03/2021	Mon 05/03/2021	1730	Continuous	1800		SPR/DUN-SOUTH Impacts Total Transfer Capability TTC with All Lines In Service	FWD (Import) <b>3800 MW</b> 800 MW 4600 MW	
Work scheduled by: ConEd									
<b>ROTTRDAM-EASTOVER_230_38</b>	Tue 05/04/2021	Tue 05/04/2021	0830	Daily(No Weekends)	1130		SCH - NE - NY Impacts Total Transfer Capability TTC with All Lines In Service	REV (Export) <b>1400 MW</b> 200 MW 1600 MW	
Work scheduled by: NGrid <span style="float: right;"><b>ARR: 77</b></span>									
<b>RAMAPO__-BUCHAN_N_345_Y94</b>	Fri 05/07/2021	Mon 05/10/2021	0001	Continuous	0159	<b>EXTENDED by CONED 04/19/2021</b>	UPNY CONED Impacts Total Transfer Capability TTC with All Lines In Service	FWD (Import) <b>7580 MW</b> 235 MW 7815 MW	
Work scheduled by: ConEd									
<b>EASTVIEW-SPRNBRK__345_W79</b>	Sat 05/08/2021	Sun 05/09/2021	0700	Continuous	2359	<b>EXTENDED by CONED 04/19/2021</b>	UPNY CONED Impacts Total Transfer Capability TTC with All Lines In Service	FWD (Import) <b>4350 MW</b> 3465 MW 7815 MW	
Work scheduled by: ConEd									
<b>W49TH_ST_345KV_5</b>	Sun 05/09/2021	Sun 05/09/2021	0130	Continuous	0200	<b>UPDATED by CONED 04/13/2021</b>	SCH - PJM_HTP Impacts Total Transfer Capability TTC with All Lines In Service	FWD (Import) <b>300 MW</b> 360 MW 660 MW	
Work scheduled by: ConEd									

# NYISO TRANSFER LIMITATIONS

Monday ,April 19, 2021 to Wednesday,October 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST\_345KV\_7**

Sun 05/09/2021 to Sun 05/09/2021  
 0130 Continuous 0200  
 Work scheduled by: ConEd

UPDATED by CONED 04/13/2021

SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

FWD  
 (Import)

**W49TH\_ST\_345KV\_7**

Mon 05/10/2021 to Mon 05/10/2021  
 0001 Continuous 0030  
 Work scheduled by: ConEd

SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

FWD  
 (Import)

**W49TH\_ST\_345KV\_8**

Mon 05/10/2021 to Mon 05/10/2021  
 0001 Continuous 0030  
 Work scheduled by: ConEd

SCH - PJM\_HTP **450 MW**  
 Impacts Total Transfer Capability 210 MW  
 TTC with All Lines In Service 660 MW

FWD  
 (Import)

**HUDSONTP-W49TH\_ST\_345\_Y56**

Mon 05/10/2021 to Thu 05/13/2021  
 0001 Continuous 2300  
 Work scheduled by: ConEd

SCH - PJM\_HTP **0 MW**  
 Impacts Total Transfer Capability 660 MW  
 TTC with All Lines In Service 660 MW

FWD  
 (Import)

**SPRNBK\_-TREMONT\_345\_X28**

Mon 05/10/2021 to Wed 05/26/2021  
 0001 Continuous 0200  
 Work scheduled by: ConEd

UPDATED by CONED 03/18/2021

SPR/DUN-SOUTH **4200 MW**  
 Impacts Total Transfer Capability 400 MW  
 TTC with All Lines In Service 4600 MW

FWD  
 (Import)

**CLAY\_-EDIC\_345\_1-16**

Mon 05/10/2021 to Fri 05/14/2021  
 0700 Continuous 1530  
 Work scheduled by: NYPA

OSWEGO EXPORT **4850 MW**  
 Impacts Total Transfer Capability 400 MW  
 TTC with All Lines In Service 5250 MW

FWD  
 (Import)

**MOSES\_-ADIRNDCK\_230\_MA2**

Mon 05/10/2021 to Tue 06/01/2021  
 1200 Continuous 0659  
 Work scheduled by: NYPA

MOSES SOUTH **2100 MW**  
 Impacts Total Transfer Capability 1050 MW  
 TTC with All Lines In Service 3150 MW

FWD  
 (Import)

# NYISO TRANSFER LIMITATIONS

Monday ,April 19, 2021 to Wednesday,October 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>ALCOA_PA_115KV_R8105</b>					FWD	
Tue 05/11/2021	to	Thu 06/03/2021			(Import)	
0630	Continuous	1630		MOSES SOUTH	<b>3100 MW</b>	
Work scheduled by: NGrid					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	3150 MW
<b>DENNISON-ROSEMNTB_115_2/22</b>					FWD	REV
Wed 05/12/2021	to	Wed 05/12/2021	<u>UPDATED</u>	<u>by HQ</u>	<u>04/16/2021</u>	(Import) (Export)
0630	Daily(No Weekends)	1830				
Work scheduled by: NGrid					SCH - HQ_CEDARS	<b>95 MW 40 MW</b>
					Impacts Total Transfer Capability	95 MW 0 MW
					TTC with All Lines In Service	190 MW 40 MW
<b>SCH-HQ_CEDARS-NYISO_LIMIT_80</b>					FWD	
Wed 05/12/2021	to	Wed 05/12/2021	<u>UPDATED</u>	<u>by HQ</u>	<u>04/16/2021</u>	(Import)
0630	Daily(No Weekends)	1830				
Work scheduled by: NGrid					SCH - HQ_CEDARS	<b>80 MW</b>
					Impacts Total Transfer Capability	110 MW
					TTC with All Lines In Service	190 MW
<b>W49TH_ST_345KV_7</b>					FWD	
Thu 05/13/2021	to	Thu 05/13/2021			(Import)	
2230	Continuous	2300		SCH - PJM_HTP	<b>300 MW</b>	
Work scheduled by: ConEd					Impacts Total Transfer Capability	360 MW
					TTC with All Lines In Service	660 MW
<b>W49TH_ST_345KV_8</b>					FWD	
Thu 05/13/2021	to	Thu 05/13/2021			(Import)	
2230	Continuous	2300		SCH - PJM_HTP	<b>450 MW</b>	
Work scheduled by: ConEd					Impacts Total Transfer Capability	210 MW
					TTC with All Lines In Service	660 MW
<b>CRICKVLY-PLSNTVLY_345_F83</b>					FWD	
Fri 05/14/2021	to	Fri 05/14/2021			(Import)	
0001	Continuous	2200		SCH - NE - NY	<b>350 MW</b>	
Work scheduled by: ConEd					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	1400 MW
<b>CRICKVLY-PLSNTVLY_345_F83</b>					FWD	REV
Fri 05/14/2021	to	Fri 05/14/2021			(Import) (Export)	
0001	Continuous	2200		SCH - NPX_1385	<b>100 MW 100 MW</b>	
Work scheduled by: ConEd					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW

# NYISO TRANSFER LIMITATIONS

Monday ,April 19, 2021 to Wednesday,October 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**NRTH1385-NOR HBR\_\_138\_601 & CRICKVLY-PLSNTVLY\_345\_F83**

Fri 05/14/2021 to Fri 05/14/2021  
 0001 2200

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

-----  
**NRTH1385-NOR HBR\_\_138\_602 & CRICKVLY-PLSNTVLY\_345\_F83**

Fri 05/14/2021 to Fri 05/14/2021  
 0001 2200

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

-----  
**NRTH1385-NOR HBR\_\_138\_603 & CRICKVLY-PLSNTVLY\_345\_F83**

Fri 05/14/2021 to Fri 05/14/2021  
 0001 2200

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

-----  
**BUCHAN\_N-EASTVIEW\_345\_W93**

Fri 05/14/2021 to Sat 05/15/2021  
 0001 Continuous 0200

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	<b>4350 MW</b>
Impacts Total Transfer Capability	3465 MW
TTC with All Lines In Service	7815 MW

-----  
**RAMAPO\_\_-BUCHAN\_N\_345\_Y94**

Fri 05/14/2021 to Sat 05/15/2021  
 0001 Continuous 0200

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	<b>7580 MW</b>
Impacts Total Transfer Capability	235 MW
TTC with All Lines In Service	7815 MW

-----  
**SPRNBK\_\_345KV\_RS3 & SPRNBK\_\_345KV\_RS4**

Sat 05/15/2021 to Sat 05/15/2021  
 0301 2230

Work scheduled by:

	FWD
	(Import)
SPR/DUN-SOUTH	<b>3200 MW</b>
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	4600 MW

-----  
**DUNWODIE\_345KV\_5**

Mon 05/17/2021 to Tue 05/18/2021 **UPDATED by CE 03/15/2021**  
 0201 Continuous 0200

Work scheduled by: ConEd

	FWD
	(Import)
SPR/DUN-SOUTH	<b>3800 MW</b>
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

# NYISO TRANSFER LIMITATIONS

Monday ,April 19, 2021 to Wednesday,October 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>DUNWODIE_345KV_7</b>						FWD	
Mon 05/17/2021	to	Tue 05/18/2021	<u>UPDATED</u>	<u>by CE</u>	<u>03/15/2021</u>	(Import)	
0201	Continuous	0200					
Work scheduled by: ConEd						SPR/DUN-SOUTH	<b>3800 MW</b>
						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
<b>SPRNBRK_-DUNWODIE_345_W75</b>						FWD	
Mon 05/17/2021	to	Tue 05/18/2021	<u>UPDATED</u>	<u>by CE</u>	<u>03/15/2021</u>	(Import)	
0201	Continuous	0200					
Work scheduled by: ConEd						SPR/DUN-SOUTH	<b>3800 MW</b>
						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
<b>SPRNBRK__345KV_RNS3</b>						FWD	
Mon 05/17/2021	to	Tue 05/18/2021	<u>UPDATED</u>	<u>by CE</u>	<u>03/15/2021</u>	(Import)	
0201	Continuous	0200					
Work scheduled by: ConEd						SPR/DUN-SOUTH	<b>3800 MW</b>
						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
<b>NIAGARA_-STA_255__345_NH2</b>						FWD	
Mon 05/17/2021	to	Fri 05/21/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>03/23/2021</u>	(Import)	
0500	Continuous	1700					
Work scheduled by: NYPA						DYSINGER EAST	<b>1400 MW</b>
						Impacts Total Transfer Capability	1750 MW
						TTC with All Lines In Service	3150 MW
<b>SAND_BAR-PLATSBRG_115_PV20</b>							
Mon 05/17/2021	to	Fri 07/02/2021					
0600	Continuous	1800					
Work scheduled by: ISONE						SCH - NE - NY	
						Impacts Total Transfer Capability	
						TTC with All Lines In Service	
<b>GOETHALS_345KV_5</b>							
Wed 05/19/2021	to	Mon 05/24/2021	<u>EXTENDED</u>	<u>by CE</u>	<u>04/05/2021</u>		
0100	Continuous	0200					
Work scheduled by: ConEd						STATEN ISLAND	
						Impacts Total Transfer Capability	
						TTC with All Lines In Service	
<b>LINDEN_-GOETHALS_230_A2253</b>						FWD	REV
Wed 05/19/2021	to	Mon 05/24/2021	<u>EXTENDED</u>	<u>by CE</u>	<u>04/05/2021</u>	(Import)	(Export)
0100	Continuous	0200					
Work scheduled by: ConEd						SCH - PJ - NY	<b>2050 MW</b>
						Impacts Total Transfer Capability	150 MW
						TTC with All Lines In Service	2200 MW
							100 MW
							1250 MW



# NYISO TRANSFER LIMITATIONS

Monday ,April 19, 2021 to Wednesday,October 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>LINDEN__-GOETHALS_230_A2253 &amp; HUDSONP_-FARRAGUT_345_B3402</b>				FWD	REV
Wed 05/19/2021	to	Mon 05/24/2021		(Import)	(Export)
0100		0200	SCH - PJ - NY	<b>2000 MW</b>	<b>1000 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	200 MW 250 MW
				TTC with All Lines In Service	2200 MW 1250 MW
<b>LINDEN__-GOETHALS_230_A2253 &amp; HUDSONP_-FARRAGUT_345_B3402 &amp; MARION__-FARRAGUT_345_C3403</b>				FWD	REV
Wed 05/19/2021	to	Mon 05/24/2021		(Import)	(Export)
0100		0200	SCH - PJ - NY	<b>2000 MW</b>	<b>1000 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	200 MW 250 MW
				TTC with All Lines In Service	2200 MW 1250 MW
<b>LINDEN__-GOETHALS_230_A2253 &amp; MARION__-FARRAGUT_345_C3403</b>				FWD	REV
Wed 05/19/2021	to	Mon 05/24/2021		(Import)	(Export)
0100		0200	SCH - PJ - NY	<b>2000 MW</b>	<b>1000 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	200 MW 250 MW
				TTC with All Lines In Service	2200 MW 1250 MW
<b>BUCHAN_S-MILLWOOD_345_W97</b>				FWD	
Thu 05/20/2021	to	Sat 05/22/2021		(Import)	
0001	Continuous	0200	UPNY CONED	<b>7680 MW</b>	
Work scheduled by: ConEd				Impacts Total Transfer Capability	135 MW
				TTC with All Lines In Service	7815 MW
<b>W49TH_ST_345KV_6</b>				FWD	
Thu 05/20/2021	to	Sat 05/22/2021	<b>UPDATED by CONED 03/30/2021</b>	(Import)	
0001	Continuous	0200		SCH - PJM_HTP	<b>300 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	360 MW
				TTC with All Lines In Service	660 MW
<b>W49TH_ST-E13THSTA_345_M55</b>				FWD	
Thu 05/20/2021	to	Mon 05/24/2021	<b>UPDATED by CONED 03/30/2021</b>	(Import)	
0001	Continuous	0200		SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
<b>E13THSTA-FARRAGUT_345_46</b>				FWD	
Sat 05/22/2021	to	Mon 05/24/2021	<b>UPDATED by CONED 03/30/2021</b>	(Import)	
0001	Continuous	0200		SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW

# NYISO TRANSFER LIMITATIONS

Monday, April 19, 2021 to Wednesday, October 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>PLSNTVLY-WOOD_ST_345_F31</b>				FWD	
Mon 05/24/2021	to	Tue 05/25/2021		(Import)	
0001	Continuous	0159	UPNY CONED	<b>4000 MW</b>	
Work scheduled by: ConEd				Impacts Total Transfer Capability	3815 MW
				TTC with All Lines In Service	7815 MW
<b>PLSNTVLY_345KV_RNS4</b>				FWD	
Mon 05/24/2021	to	Tue 05/25/2021		(Import)	
0001	Continuous	0159	UPNY CONED	<b>3800 MW</b>	
Work scheduled by: ConEd				Impacts Total Transfer Capability	4015 MW
				TTC with All Lines In Service	7815 MW
<b>W49TH_ST_345KV_6</b>				FWD	
Mon 05/24/2021	to	Mon 05/24/2021	<b>UPDATED by CONED 03/30/2021</b>	(Import)	
0130	Continuous	0200	SCH - PJM_HTP	<b>300 MW</b>	
Work scheduled by: ConEd				Impacts Total Transfer Capability	360 MW
				TTC with All Lines In Service	660 MW
<b>DENNISON-ROSEMNTB_115_2/22</b>				FWD	REV
Mon 05/24/2021	to	Wed 05/26/2021		(Import)	(Export)
0630	Continuous	1900	SCH - HQ_CEDARS	<b>95 MW</b>	<b>40 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability	95 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
<b>SCH-HQ_CEDARS-NYISO_LIMIT_80</b>				FWD	
Mon 05/24/2021	to	Wed 05/26/2021		(Import)	
0630	Continuous	1900	SCH - HQ_CEDARS	<b>80 MW</b>	
Work scheduled by: NGrid				Impacts Total Transfer Capability	110 MW
				TTC with All Lines In Service	190 MW
<b>ROSETON_-EFISHKIL_345_RFK305</b>				FWD	
Wed 05/26/2021	to	Thu 05/27/2021		(Import)	
0001	Continuous	0200	UPNY CONED	<b>6680 MW</b>	
Work scheduled by: ConEd				Impacts Total Transfer Capability	1135 MW
				TTC with All Lines In Service	7815 MW
<b>DENNISON-ROSEMNTA_115_1/11</b>				FWD	REV
Thu 05/27/2021	to	Fri 05/28/2021		(Import)	(Export)
0630	Continuous	1900	SCH - HQ_CEDARS	<b>95 MW</b>	<b>40 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability	95 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW

# NYISO TRANSFER LIMITATIONS

Monday ,April 19, 2021 to Wednesday,October 19, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SCH-HQ\_CEDARS-NYISO\_LIMIT\_80**

Thu 05/27/2021 to Fri 05/28/2021  
 0630 Continuous 1900  
 Work scheduled by: NGrid

FWD  
 (Import)  
 SCH - HQ\_CEDARS **80 MW**  
 Impacts Total Transfer Capability 110 MW  
 TTC with All Lines In Service 190 MW

**VOLNEY -MARCY 345\_19**

Tue 06/01/2021 to Wed 06/02/2021  
 0700 Continuous 1730  
 Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
 CENTRAL EAST - VC **2825 MW**  
 Impacts Total Transfer Capability 150 MW  
 TTC with All Lines In Service 2975 MW

**VOLNEY -MARCY 345\_19**

Tue 06/01/2021 to Wed 06/02/2021  
 0700 Continuous 1730  
 Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
 OSWEGO EXPORT **4900 MW**  
 Impacts Total Transfer Capability 350 MW  
 TTC with All Lines In Service 5250 MW

**FRASER -GILBOA 345\_GF5-35**

Tue 06/01/2021 to Mon 06/07/2021  
 0700 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2650 MW**  
 Impacts Total Transfer Capability 325 MW  
 TTC with All Lines In Service 2975 MW

**MOSES -ADIRNDCK\_230\_MA2**

Tue 06/01/2021 to Sun 11/14/2021  
 0700 Continuous 1300  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2100 MW**  
 Impacts Total Transfer Capability 1050 MW  
 TTC with All Lines In Service 3150 MW

**MARCY -EDIC 345\_UE1-7**

Thu 06/03/2021 to Fri 06/04/2021  
 0700 Continuous 1730  
 Work scheduled by: NYPA

**ARR: 19&16**

FWD  
 (Import)  
 OSWEGO EXPORT **5250 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 5250 MW

**PORTER -ROTTRDAM\_230\_30**

Thu 06/03/2021 to Wed 09/15/2021  
 0700 Continuous 0659  
 Work scheduled by: NGrid

**UPDATED by NGRID 01/19/2021**

FWD  
 (Import)  
 CENTRAL EAST - VC **2805 MW**  
 Impacts Total Transfer Capability 170 MW  
 TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Monday ,April 19, 2021 to Wednesday,October 19, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p><b>MARCY</b>___345KV_CSC</p> <p>Sat 06/05/2021 to Sat 06/05/2021</p> <p style="padding-left: 40px;">0700 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>CENTRAL EAST - VC <b>2925 MW</b></p> <p>Impacts Total Transfer Capability 50 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p><b>ATHENS</b>__-PLSNTVLY_345_91</p> <p>Tue 06/08/2021 to Wed 06/16/2021</p> <p style="padding-left: 40px;">0600 Continuous 2000</p> <p>Work scheduled by: NGrid</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>UPNY CONED <b>3800 MW</b></p> <p>Impacts Total Transfer Capability 4015 MW</p> <p>TTC with All Lines In Service 7815 MW</p>
<p><b>GILBOA</b>__-N.SCTLND_345_GNS-1</p> <p>Wed 06/09/2021 to Wed 06/09/2021</p> <p style="padding-left: 40px;">0800 Daily 1200</p> <p>Work scheduled by: NGrid</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>CENTRAL EAST - VC <b>2520 MW</b></p> <p>Impacts Total Transfer Capability 455 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p><b>BECK</b>___-NIAGARA_345_PA301</p> <p>Wed 06/16/2021 to Thu 06/17/2021</p> <p style="padding-left: 40px;">0500 Continuous 2330</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD REV</p> <p style="text-align: right;">(Import) (Export)</p> <p>SCH - OH - NY <b>900 MW 800 MW</b></p> <p>Impacts Total Transfer Capability 1050 MW 900 MW</p> <p>TTC with All Lines In Service 1950 MW 1700 MW</p>
<p><b>PLSNTVLY_345KV_RNS5</b></p> <p>Thu 06/17/2021 to Thu 06/17/2021 <b>UPDATED by CONED 04/19/2021</b></p> <p style="padding-left: 40px;">0001 Continuous 0030</p> <p>Work scheduled by: NGrid</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>UPNY CONED <b>3800 MW</b></p> <p>Impacts Total Transfer Capability 4015 MW</p> <p>TTC with All Lines In Service 7815 MW</p>
<p><b>LEEDS</b>___-PLSNTVLY_345_92</p> <p>Thu 06/17/2021 to Thu 06/24/2021 <b>UPDATED by CONED 04/19/2021</b></p> <p style="padding-left: 40px;">0001 Continuous 2000</p> <p>Work scheduled by: NGrid</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>UPNY CONED <b>3800 MW</b></p> <p>Impacts Total Transfer Capability 4015 MW</p> <p>TTC with All Lines In Service 7815 MW</p>
<p><b>PLSNTVLY_345KV_RNS5</b></p> <p>Thu 06/24/2021 to Thu 06/24/2021 <b>UPDATED by CONED 04/19/2021</b></p> <p style="padding-left: 40px;">1930 Continuous 2000</p> <p>Work scheduled by: NGrid</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>UPNY CONED <b>3800 MW</b></p> <p>Impacts Total Transfer Capability 4015 MW</p> <p>TTC with All Lines In Service 7815 MW</p>

# NYISO TRANSFER LIMITATIONS

Monday ,April 19, 2021 to Wednesday,October 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BECK	-NIAGARA	345	PA301			FWD	REV
						(Import)	(Export)
Fri 06/25/2021	to	Fri 06/25/2021					
0500	Continuous	1700			SCH - OH - NY	900 MW	800 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	1050 MW 900 MW
						TTC with All Lines In Service	1950 MW 1700 MW
-----							
FRASANX-COOPERS	345	UCC2-41				FWD	
						(Import)	
Fri 06/25/2021	to	Tue 08/10/2021					
0700	Continuous	1530			CENTRAL EAST - VC	2500 MW	
Work scheduled by: NYPA						Impacts Total Transfer Capability	475 MW
						TTC with All Lines In Service	2975 MW
ARR: 19							
-----							
MARCY	-FRASANX	345	UCC2-41			FWD	
						(Import)	
Fri 06/25/2021	to	Tue 08/10/2021					
0700	Continuous	1530			CENTRAL EAST - VC	2500 MW	
Work scheduled by: NYPA						Impacts Total Transfer Capability	475 MW
						TTC with All Lines In Service	2975 MW
ARR: 19							
-----							
BECK	-NIAGARA	345	PA302			FWD	REV
						(Import)	(Export)
Mon 07/12/2021	to	Fri 07/16/2021					
0500	Continuous	1700			SCH - OH - NY	900 MW	800 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	1050 MW 900 MW
						TTC with All Lines In Service	1950 MW 1700 MW
-----							
NIAGARA	345	230	AT4			FWD	REV
						(Import)	(Export)
Mon 07/19/2021	to	Fri 07/30/2021					
0500	Continuous	1700			SCH - OH - NY	1900 MW	1400 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	50 MW 300 MW
						TTC with All Lines In Service	1950 MW 1700 MW
-----							
NIAGARA	-STA 255	345	NH2			FWD	
						(Import)	
Mon 07/26/2021	to	Fri 07/30/2021					
0500	Continuous	1900			DYSINGER EAST	1400 MW	
Work scheduled by: NYPA						Impacts Total Transfer Capability	1750 MW
						TTC with All Lines In Service	3150 MW
-----							
SAND_BAR-PLATSBRG	115	PV20					
Tue 08/03/2021	to	Tue 08/03/2021					
0700	Continuous	1830			SCH - NE - NY		
Work scheduled by: NYPA						Impacts Total Transfer Capability	
						TTC with All Lines In Service	

# NYISO TRANSFER LIMITATIONS

Monday ,April 19, 2021 to Wednesday,October 19, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
<b>KINTIGH_-STA_255__345_SH1-39</b>			FWD
Mon 08/09/2021	to	Sun 08/15/2021	(Import)
0500	Continuous	1900	
Work scheduled by: NYPA			
		DYSINGER EAST	<b>1400 MW</b>
		Impacts Total Transfer Capability	1750 MW
		TTC with All Lines In Service	3150 MW
<hr/>			
<b>NIAGARA_-KINTIGH__345_NS1-38</b>			FWD
Mon 08/09/2021	to	Sun 08/15/2021	(Import)
0500	Continuous	1900	
Work scheduled by: NYPA			
		DYSINGER EAST	<b>1400 MW</b>
		Impacts Total Transfer Capability	1750 MW
		TTC with All Lines In Service	3150 MW
<hr/>			
<b>KINTIGH_-STA_255__345_SH1-39</b>			FWD
Mon 08/16/2021	to	Sun 08/22/2021	(Import)
0500	Continuous	1900	
Work scheduled by: NYPA			
		DYSINGER EAST	<b>1400 MW</b>
		Impacts Total Transfer Capability	1750 MW
		TTC with All Lines In Service	3150 MW
<hr/>			
<b>NIAGARA_-KINTIGH__345_NS1-38</b>			FWD
Mon 08/16/2021	to	Sun 08/22/2021	(Import)
0500	Continuous	1900	
Work scheduled by: NYPA			
		DYSINGER EAST	<b>1400 MW</b>
		Impacts Total Transfer Capability	1750 MW
		TTC with All Lines In Service	3150 MW
<hr/>			
<b>NIAGARA_-STA_255__345_NH2</b>			FWD
Wed 09/01/2021	to	Tue 09/21/2021	(Import)
0500	Continuous	1900	
Work scheduled by: NYPA			
		DYSINGER EAST	<b>1400 MW</b>
		Impacts Total Transfer Capability	1750 MW
		TTC with All Lines In Service	3150 MW
<hr/>			
<b>FRASANNX-COOPERS__345_UCC2-41</b>			FWD
Tue 09/07/2021	to	Wed 09/15/2021	(Import)
0700	Continuous	1730	
Work scheduled by: NYPA			
		<b>UPDATED</b>	
		<b>by NYISO</b>	
		<b>02/03/2021</b>	
		<b>ARR: 19</b>	
		CENTRAL EAST - VC	<b>2500 MW</b>
		Impacts Total Transfer Capability	475 MW
		TTC with All Lines In Service	2975 MW
<hr/>			
<b>MARCY__-FRASANNX_345_UCC2-41</b>			FWD
Tue 09/07/2021	to	Wed 09/15/2021	(Import)
0700	Continuous	1730	
Work scheduled by: NYPA			
		<b>UPDATED</b>	
		<b>by NYISO</b>	
		<b>02/03/2021</b>	
		<b>ARR: 19</b>	
		CENTRAL EAST - VC	<b>2500 MW</b>
		Impacts Total Transfer Capability	475 MW
		TTC with All Lines In Service	2975 MW
<hr/>			

# NYISO TRANSFER LIMITATIONS

Monday ,April 19, 2021 to Wednesday,October 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**PORTER\_\_-ROTTRDAM\_230\_30**

Wed 09/15/2021 to Tue 11/30/2021  
 0700 Continuous 1730  
 Work scheduled by: NGrid

FWD  
 (Import)  
 CENTRAL EAST - VC **2805 MW**  
 Impacts Total Transfer Capability 170 MW  
 TTC with All Lines In Service 2975 MW

**EDIC\_\_\_-N.SCTLND\_345\_14**

Thu 09/16/2021 to Sun 11/14/2021  
 0700 Continuous 1730  
 Work scheduled by: NGrid

FWD  
 (Import)  
 CENTRAL EAST - VC **1670 MW**  
 Impacts Total Transfer Capability 1305 MW  
 TTC with All Lines In Service 2975 MW

**EDIC\_\_\_-N.SCTLND\_345\_14 & PORTER\_\_-ROTTRDAM\_230\_30**

Thu 09/16/2021 to Sun 11/14/2021  
 0700 1730  
 Work scheduled by:

FWD  
 (Import)  
 CENTRAL EAST - VC **1500 MW**  
 Impacts Total Transfer Capability 1475 MW  
 TTC with All Lines In Service 2975 MW

**HURLYAVE-ROSETON\_\_345\_303**

Thu 09/16/2021 to Sun 10/17/2021 **UPDATED by CHGE 09/22/2020**  
 0800 Continuous 1600  
 Work scheduled by: CHGE

FWD  
 (Import)  
 UPNY CONED **4100 MW**  
 Impacts Total Transfer Capability 3715 MW  
 TTC with All Lines In Service 7815 MW

**HOMRC\_NY-MAINS\_NY\_345\_47**

Sat 09/18/2021 to Fri 11/05/2021  
 0800 Continuous 1600  
 Work scheduled by: PJM

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**PANNELL\_-CLAY\_\_\_\_\_345\_1**

Mon 09/20/2021 to Fri 09/24/2021  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 WEST CENTRAL **1300 MW**  
 Impacts Total Transfer Capability 950 MW  
 TTC with All Lines In Service 2250 MW

**CLAY\_\_\_-EDIC\_\_\_\_\_345\_2-15**

Mon 09/20/2021 to Sat 10/16/2021  
 0700 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
 OSWEGO EXPORT **4850 MW**  
 Impacts Total Transfer Capability 400 MW  
 TTC with All Lines In Service 5250 MW

# NYISO TRANSFER LIMITATIONS

Monday ,April 19, 2021 to Wednesday,October 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**KINTIGH\_-STA\_255\_\_345\_SH1-39**

Mon 09/27/2021 to Wed 09/29/2021  
0500 Continuous 0459

Work scheduled by: NYPA

**UPDATED by NYPA 03/04/2021**

FWD  
(Import)  
DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

**NIAGARA\_-KINTIGH\_\_345\_NS1-38**

Mon 09/27/2021 to Wed 09/29/2021  
0500 Continuous 0459

Work scheduled by: NYPA

**UPDATED by NYPA 03/04/2021**

FWD  
(Import)  
DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

**PANNELL\_-CLAY\_\_\_\_345\_2**

Mon 09/27/2021 to Fri 10/01/2021  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

**W49TH\_ST\_345KV\_6**

Tue 09/28/2021 to Tue 09/28/2021  
0100 Continuous 0130

Work scheduled by: ConEd

**UPDATED by CONED 01/15/2021**

FWD  
(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

**E13THSTA-FARRAGUT\_345\_46**

Tue 09/28/2021 to Tue 10/26/2021  
0100 Continuous 0300

Work scheduled by: ConEd

**UPDATED by CONED 01/15/2021**

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**W49TH\_ST-E13THSTA\_345\_M55**

Tue 09/28/2021 to Tue 10/26/2021  
0100 Continuous 0300

Work scheduled by: ConEd

**UPDATED by CONED 01/15/2021**

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**KINTIGH\_-STA\_255\_\_345\_SH1-39**

Wed 09/29/2021 to Wed 12/01/2021  
0500 Continuous 1900

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW



# NYISO TRANSFER LIMITATIONS

Monday ,April 19, 2021 to Wednesday,October 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>NIAGARA_-KINTIGH__345_NS1-38</b>				FWD	
Wed 09/29/2021	to	Wed 12/01/2021		(Import)	
0500	Continuous	1900	DYSINGER EAST	<b>1400 MW</b>	
Work scheduled by: NYPA				Impacts Total Transfer Capability	1750 MW
				TTC with All Lines In Service	3150 MW
<b>LEEDS_-HURLYAVE_345_301</b>				FWD	
Mon 10/18/2021	to	Fri 11/19/2021		(Import)	
0800	Continuous	1600	UPNY CONED	<b>4100 MW</b>	
Work scheduled by: CHGE				Impacts Total Transfer Capability	3715 MW
				TTC with All Lines In Service	7815 MW
<b>GOETHALS_345KV_5</b>					
Thu 10/21/2021	to	Sat 11/20/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>03/05/2021</u>
0001	Continuous	0200	STATEN ISLAND		
Work scheduled by: ConEd				Impacts Total Transfer Capability	
				TTC with All Lines In Service	
<b>W49TH_ST_345KV_6</b>				FWD	
Tue 10/26/2021	to	Tue 10/26/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>01/15/2021</u>
0230	Continuous	0300	SCH - PJM_HTP		
Work scheduled by: ConEd				Impacts Total Transfer Capability	360 MW
				TTC with All Lines In Service	660 MW
<b>SCH-IMO-NYISO_LIMIT_1750</b>				FWD	
Mon 11/01/2021	to	Fri 12/31/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>
0001	Continuous	2359	SCH - OH - NY		
Work scheduled by: IESO				Impacts Total Transfer Capability	250 MW
				TTC with All Lines In Service	2300 MW
<b>SCH-NYISO-IMO_LIMIT_1600</b>					REV
Mon 11/01/2021	to	Fri 12/31/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>
0001	Continuous	2359	SCH - OH - NY		
Work scheduled by: IESO				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	2000 MW
<b>LINDN_CG-LNDVFT__345_V-3022</b>				FWD	REV
Tue 11/02/2021	to	Fri 11/05/2021		(Import)	(Export)
0800	Continuous	1500	SCH - PJM_VFT		
Work scheduled by: PJM				Impacts Total Transfer Capability	315 MW
				TTC with All Lines In Service	315 MW

# NYISO TRANSFER LIMITATIONS

Monday ,April 19, 2021 to Wednesday,October 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**PORTER\_\_-ROTTRDAM\_230\_30 & MASSENA\_-MARCY\_\_\_\_765\_MSU1**

Mon 11/15/2021 to Tue 11/30/2021  
 0100 1730

Work scheduled by:

FWD  
 (Import)  
 CENTRAL EAST - VC **1500 MW**  
 Impacts Total Transfer Capability 1475 MW  
 TTC with All Lines In Service 2975 MW

-----  
**CHATGUAY-MASSENA\_\_765\_7040**

Mon 11/15/2021 to Tue 11/30/2021  
 0100 Continuous 1859

Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **1550 MW**  
 Impacts Total Transfer Capability 1600 MW  
 TTC with All Lines In Service 3150 MW

-----  
**CHATGUAY-MASSENA\_\_765\_7040**

Mon 11/15/2021 to Tue 11/30/2021  
 0100 Continuous 1859

Work scheduled by: NYPA

FWD REV  
 (Import) (Export)  
 SCH - HQ - NY **0 MW 0 MW**  
 Impacts Total Transfer Capability 1500 MW 1000 MW  
 TTC with All Lines In Service 1500 MW 1000 MW

-----  
**MARCY\_\_\_\_765\_345\_AT1**

Mon 11/15/2021 to Tue 11/30/2021  
 0100 Continuous 1859

Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
 MOSES SOUTH **1750 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 3150 MW

-----  
**MARCY\_\_\_\_765\_345\_AT2**

Mon 11/15/2021 to Tue 11/30/2021  
 0100 Continuous 1859

Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
 MOSES SOUTH **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

-----  
**MASSENA\_-MARCY\_\_\_\_765\_MSU1**

Mon 11/15/2021 to Tue 11/30/2021  
 0100 Continuous 1859

Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **1670 MW**  
 Impacts Total Transfer Capability 1305 MW  
 TTC with All Lines In Service 2975 MW

-----  
**MASSENA\_-MARCY\_\_\_\_765\_MSU1**

Mon 11/15/2021 to Tue 11/30/2021  
 0100 Continuous 1859

Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **500 MW**  
 Impacts Total Transfer Capability 2650 MW  
 TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Monday ,April 19, 2021 to Wednesday,October 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Transfer Capability			FWD	REV
From	To	Time	(Import)	(Export)
<b>MASSENA -MARCY 765_MSU1</b>				
Mon 11/15/2021	to	Tue 11/30/2021		
0100	Continuous	1859		
Work scheduled by: NYPA				
			SCH - HQ - NY	<b>475 MW</b>
			Impacts Total Transfer Capability	1025 MW
			TTC with All Lines In Service	1500 MW
<b>MASSENA -MARCY 765_MSU1</b>				
Mon 11/15/2021	to	Tue 11/30/2021		
0100	Continuous	1859		
Work scheduled by: NYPA				
			SCH - HQ_CEDARS	<b>90 MW</b>
			Impacts Total Transfer Capability	109 MW
			TTC with All Lines In Service	199 MW
<b>MASSENA -MARCY 765_MSU1 &amp; CHATGUAY-MASSENA 765_7040</b>				
Mon 11/15/2021	to	Tue 11/30/2021		
0100		1859		
Work scheduled by:				
			MOSES SOUTH	<b>500 MW</b>
			Impacts Total Transfer Capability	2650 MW
			TTC with All Lines In Service	3150 MW
<b>MOSES -MASSENA 230_MMS1 &amp; MOSES -MASSENA 230_MMS2</b>				
Mon 11/15/2021	to	Tue 11/30/2021		
0100		1859		
Work scheduled by:				
			SCH - HQ - NY	<b>850 MW</b>
			Impacts Total Transfer Capability	650 MW
			TTC with All Lines In Service	1500 MW
<b>MOSES -MASSENA 230_MMS1 &amp; MOSES -MASSENA 230_MMS2</b>				
Mon 11/15/2021	to	Tue 11/30/2021		
0100		1859		
Work scheduled by:				
			SCH - HQ_CEDARS	<b>90 MW</b>
			Impacts Total Transfer Capability	109 MW
			TTC with All Lines In Service	199 MW
<b>STLAWRNC-MOSES 230_L33P &amp; MASSENA -MARCY 765_MSU1</b>				
Mon 11/15/2021	to	Tue 11/30/2021		
0100		1859		
Work scheduled by:				
			SCH - HQ_CEDARS	<b>90 MW</b>
			Impacts Total Transfer Capability	109 MW
			TTC with All Lines In Service	199 MW
<b>STLAWRNC-MOSES 230_L33P &amp; MOSES -MASSENA 230_MMS1 &amp; MOSES -MASSENA 230_MMS2</b>				
Mon 11/15/2021	to	Tue 11/30/2021		
0100		1859		
Work scheduled by:				
			SCH - HQ_CEDARS	<b>90 MW</b>
			Impacts Total Transfer Capability	109 MW
			TTC with All Lines In Service	199 MW

# NYISO TRANSFER LIMITATIONS

Monday ,April 19, 2021 to Wednesday,October 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**FRASER\_\_\_345\_FRASER SVC**

Wed 12/01/2021 to Mon 02/28/2022  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2935 MW**  
Impacts Total Transfer Capability 40 MW  
TTC with All Lines In Service 2975 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MAI**

Wed 12/01/2021 to Tue 05/31/2022  
0700 Continuous 1300

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**NIAGARA\_-STA\_255\_\_345\_NH2**

Thu 12/02/2021 to Thu 01/13/2022  
0500 Continuous 1900

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

**MOTTHAVN-RAINEY\_\_\_345\_Q12**

Sun 12/05/2021 to Sat 12/25/2021 **UPDATED by CONED 03/25/2021**  
0001 Continuous 0159

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**LEEDS\_\_\_-PLSNTVLY\_345\_92**

Thu 02/17/2022 to Mon 02/21/2022 **UPDATED by NGRID 03/31/2021**  
0600 Continuous 1900

Work scheduled by: NGrid

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 2420 MW  
TTC with All Lines In Service 6220 MW

**GOETHALS\_345KV\_5**

Sat 03/05/2022 to Mon 04/04/2022 **UPDATED by CONED 03/26/2021**  
0001 Continuous 0200

Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**LINDEN\_\_\_-GOETHALS\_230\_A2253**

Sat 03/05/2022 to Mon 04/04/2022 **UPDATED by CONED 03/26/2021**  
0001 Continuous 0200

Work scheduled by: ConEd

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

Monday ,April 19, 2021 to Wednesday,October 19, 2022

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>N. SCTLND-ALPS_____345_2</b>					FWD
Mon 05/02/2022	to	Mon 05/09/2022			(Import)
0600	Daily	1800		SCH - NE - NY	<b>750 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability 650 MW
					TTC with All Lines In Service 1400 MW
<b>N. SCTLND-ALPS_____345_2</b>					FWD
Mon 05/02/2022	to	Mon 05/09/2022			(Import) (Export)
0600	Daily	1800		SCH - NPX_1385	<b>100 MW 100 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability 100 MW 100 MW
					TTC with All Lines In Service 200 MW 200 MW
<b>HOMRC_NY-MAINS_NY_345_47</b>					
Fri 05/20/2022	to	Fri 05/27/2022	<b>UPDATED</b>	<b>by PJM</b>	<b>11/19/2020</b>
0800	Continuous	1600			SCH - PJ - NY
Work scheduled by: PJM					Impacts Total Transfer Capability
					TTC with All Lines In Service
<b>HOMR_NYW-PIERC_NY_345_48</b>					
Fri 05/20/2022	to	Fri 05/27/2022	<b>UPDATED</b>	<b>by PJM</b>	<b>11/19/2020</b>
0800	Continuous	1600			SCH - PJ - NY
Work scheduled by: PJM					Impacts Total Transfer Capability
					TTC with All Lines In Service
<b>MOSES___-ADIRNDCK_230_MA2</b>					FWD
Wed 06/01/2022	to	Mon 11/14/2022			(Import)
0700	Continuous	1300		MOSES SOUTH	<b>2100 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 1050 MW
					TTC with All Lines In Service 3150 MW
<b>SPRNBRK__345KV_RNS5</b>					FWD
Mon 09/19/2022	to	Mon 09/19/2022	<b>UPDATED</b>	<b>by CONED</b>	<b>09/17/2020</b>
0001	Continuous	0030			(Import)
Work scheduled by: ConEd					SPR/DUN-SOUTH <b>3200 MW</b>
					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW
<b>SPRNBRK_-W49TH_ST_345_M51</b>					FWD
Mon 09/19/2022	to	Wed 09/21/2022	<b>UPDATED</b>	<b>by CONED</b>	<b>09/17/2020</b>
0001	Continuous	2200			(Import)
Work scheduled by: ConEd					SPR/DUN-SOUTH <b>3200 MW</b>
					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Monday, April 19, 2021 to Wednesday, October 19, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**SPRNBRK\_\_345KV\_RNS5**

FWD

Wed 09/21/2022 to Wed 09/21/2022 **UPDATED** **by CONED** **09/17/2020**  
 2130 Continuous 2200

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

-----  
**SPRNBRK\_-W49TH\_ST\_345\_M51**

FWD

Sat 10/01/2022 to Mon 10/17/2022 **UPDATED** **by CONED** **08/01/2020**  
 0001 Continuous 0300

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

-----  
**SPRNBRK\_\_345KV\_RNS5**

FWD

Sat 10/01/2022 to Mon 10/17/2022 **UPDATED** **by CONED** **08/01/2020**  
 0001 Continuous 0300

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW