

NYISO TRANSFER LIMITATIONS

Tuesday ,April 20, 2021 to Thursday ,October 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Wed 06/30/2021 **EXT FORCE** **by CONED** **08/28/2020**
 0001 Continuous 2359
 Work scheduled by: ConEd

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Wed 06/30/2021
 0001 2359
 Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2550 MW	1900 MW
Impacts Total Transfer Capability	250 MW	50 MW
TTC with All Lines In Service	2800 MW	1950 MW

MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Wed 06/30/2021 **EXT FORCE** **by CONED** **08/28/2020**
 0001 Continuous 2359
 Work scheduled by: ConEd

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

STLAWRNC-MOSES_230_L33P

Mon 04/30/2018 to Mon 10/31/2022 **EXT FORCE** **by IESO** **10/01/2020**
 0456 Continuous 1600
 Work scheduled by: IESO

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

NEWBRDGE_345_138_BK_1

Wed 09/02/2020 to Tue 02/01/2022 **EXT FORCE** **by LI** **01/12/2021**
 1807 Continuous 2359
 Work scheduled by: LI

	FWD
	(Import)
SCH - PJM_NEPTUNE	375 MW
Impacts Total Transfer Capability	285 MW
TTC with All Lines In Service	660 MW

SPRNBK_-EGRDNCTR_345_Y49

Thu 10/01/2020 to Mon 04/19/2021 **EXT FORCE** **by LI** **02/23/2021**
 0404 Continuous 2359
 Work scheduled by: LI

	FWD
	(Import)
CONED - LIPA	775 MW
Impacts Total Transfer Capability	725 MW
TTC with All Lines In Service	1500 MW

EGRDNCTY_345_138_AT2

Sat 10/10/2020 to Mon 04/19/2021 **EXT FORCE** **by LI** **02/23/2021**
 1815 Continuous 2359
 Work scheduled by: LI

	FWD
	(Import)
CONED - LIPA	1250 MW
Impacts Total Transfer Capability	250 MW
TTC with All Lines In Service	1500 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 20, 2021 to Thursday ,October 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EGRDNCTY_345_138_AT1					FWD	
Sat 10/10/2020	to	Mon 04/19/2021	<u>EXT FORCE</u>	<u>by LI</u>	<u>02/23/2021</u>	(Import)
1856	Continuous	2359				CONED - LIPA 1250 MW
Work scheduled by: LI					Impacts Total Transfer Capability 250 MW	
					TTC with All Lines In Service 1500 MW	
SCH-IMO-NYISO_LIMIT_1750					FWD	
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Import)
0001	Continuous	2359				SCH - OH - NY 2050 MW
Work scheduled by: IESO					Impacts Total Transfer Capability 250 MW	
					TTC with All Lines In Service 2300 MW	
SCH-NYISO-IMO_LIMIT_1600					REV	
Sun 11/01/2020	to	Fri 04/30/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Export)
0001	Continuous	2359				SCH - OH - NY 1900 MW
Work scheduled by: IESO					Impacts Total Transfer Capability 100 MW	
					TTC with All Lines In Service 2000 MW	
SAND_BAR-PLATSBRG_115_PV20						
Tue 02/23/2021	to	Mon 05/17/2021	<u>UPDATED</u>	<u>by NYISO</u>	<u>03/16/2021</u>	
1801	Continuous	0559				SCH - NE - NY
Work scheduled by: ISONE					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
W49TH_ST_345KV_8					FWD	
Tue 03/02/2021	to	Sun 05/02/2021	<u>EXTENDED</u>	<u>by CONED</u>	<u>04/10/2021</u>	(Import)
0201	Continuous	0200				SCH - PJM_HTP 300 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 360 MW	
					TTC with All Lines In Service 660 MW	
PORTER__-ROTTRDAM_230_31					FWD	
Tue 03/02/2021	to	Mon 05/31/2021	<u>UPDATED</u>	<u>by NGRID</u>	<u>03/10/2021</u>	(Import)
0600	Continuous	1730				CENTRAL EAST - VC 2805 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 170 MW	
					TTC with All Lines In Service 2975 MW	
MOSES__-ADIRNDCK_230_MAL					FWD	
Tue 03/02/2021	to	Mon 05/10/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>02/11/2021</u>	(Import)
0700	Continuous	1159				MOSES SOUTH 2300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 850 MW	
					TTC with All Lines In Service 3150 MW	

NYISO TRANSFER LIMITATIONS

Tuesday ,April 20, 2021 to Thursday ,October 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_6

Sun 03/21/2021 to Sun 05/02/2021 **EXTENDED** by **CONED** **04/10/2021**
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

EDIC -N.SCTLND_345_14 & PORTER -ROTRDAM_230_31

Mon 03/22/2021 to Mon 05/31/2021
 0600 1730
 Work scheduled by:

FWD
 (Import)
 CENTRAL EAST - VC **1500 MW**
 Impacts Total Transfer Capability 1475 MW
 TTC with All Lines In Service 2975 MW

EDIC -N.SCTLND_345_14

Mon 03/22/2021 to Mon 05/31/2021 **UPDATED** by **NGRID** **03/10/2021**
 0600 Continuous 1830
 Work scheduled by: NGrid

FWD
 (Import)
 CENTRAL EAST - VC **1670 MW**
 Impacts Total Transfer Capability 1305 MW
 TTC with All Lines In Service 2975 MW

S.RIPLEY-DUNKIRK_230_68

Mon 04/12/2021 to Fri 04/23/2021 **UPDATED** by **NGRID** **04/12/2021**
 0630 Continuous 1700
 Work scheduled by: NGrid

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

SPRNBK -W49TH_ST_345_M51

Wed 04/14/2021 to Mon 04/26/2021 **EXTENDED** by **CONED** **04/16/2021**
 1124 Continuous 2359
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

SCH-NPX_1385-NYISO_LIMIT_150

Mon 04/19/2021 to Thu 04/29/2021 **FORCED** by **ISONE** **04/17/2021**
 0001 Continuous 1600
 Work scheduled by: ISONE

FWD
 (Import)
 SCH - NPX_1385 **150 MW**
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 200 MW

N.SCTLND-ALPS_345_2

Mon 04/19/2021 to Mon 04/26/2021 **UPDATED** by **NGRID** **04/20/2021**
 0841 Continuous 1800
 Work scheduled by: NGrid

FWD
 (Import)
 SCH - NE - NY **900 MW**
 Impacts Total Transfer Capability 500 MW
 TTC with All Lines In Service 1400 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 20, 2021 to Thursday ,October 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

N. SCTLND-ALPS _____ 345_2	FWD	REV
Mon 04/19/2021 to Mon 04/26/2021 UPDATED by NGRID <u>04/20/2021</u>	(Import)	(Export)
0841 Continuous 1800	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: NGrid	Impacts Total Transfer Capability	100 MW 100 MW
	TTC with All Lines In Service	200 MW 200 MW
<hr/>		
N. SCTLND-LEEDS _____ 345_93	FWD	
Mon 04/19/2021 to Mon 04/26/2021 UPDATED by NGRID <u>04/20/2021</u>	(Import)	
0841 Continuous 1800	CENTRAL EAST - VC	2650 MW
Work scheduled by: NGrid	Impacts Total Transfer Capability	325 MW
	TTC with All Lines In Service	2975 MW
<hr/>		
DUNWODIE_345KV_6	FWD	
Tue 04/20/2021 to Tue 04/20/2021 CANCELLED by ConEd <u>04/19/2021</u>	(Import)	
0201 Continuous 0230	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd	Impacts Total Transfer Capability	800 MW
	TTC with All Lines In Service	4600 MW
<hr/>		
DUNWODIE_345KV_8	FWD	
Tue 04/20/2021 to Tue 04/20/2021 CANCELLED by ConEd <u>04/19/2021</u>	(Import)	
0201 Continuous 0230	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd	Impacts Total Transfer Capability	800 MW
	TTC with All Lines In Service	4600 MW
<hr/>		
WOOD_ST_-PLSNTVLE_345_Y87	FWD	
Tue 04/20/2021 to Tue 04/20/2021 CANCELLED by ConEd <u>04/19/2021</u>	(Import)	
0201 Continuous 0230	UPNY CONED	5905 MW
Work scheduled by: ConEd	Impacts Total Transfer Capability	315 MW
	TTC with All Lines In Service	6220 MW
<hr/>		
PLSNTVLE-DUNWODIE_345_W90	FWD	
Tue 04/20/2021 to Fri 04/23/2021 CANCELLED by ConEd <u>04/19/2021</u>	(Import)	
0201 Continuous 0159	UPNY CONED	4000 MW
Work scheduled by: ConEd	Impacts Total Transfer Capability	2220 MW
	TTC with All Lines In Service	6220 MW
<hr/>		
MAINESBG-WATRCURE_345_30	FWD	
Tue 04/20/2021 to Tue 04/20/2021 UPDATED by NYSEG <u>04/20/2021</u>	(Import)	
0800 Continuous 1504	SCH - PJ - NY	2300 MW
Work scheduled by: NYSEG	Impacts Total Transfer Capability	500 MW
	TTC with All Lines In Service	2800 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 20, 2021 to Thursday ,October 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

N.SCTLND-ALPS_____345_2 & NRTH1385-NOR HBR__138_601			FWD	REV
Wed 04/21/2021 to Wed 04/21/2021			(Import)	(Export)
0800		1600	SCH - NPX_1385	0 MW 0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
N.SCTLND-ALPS_____345_2 & NRTH1385-NOR HBR__138_602			FWD	REV
Wed 04/21/2021 to Wed 04/21/2021			(Import)	(Export)
0800		1600	SCH - NPX_1385	0 MW 0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
N.SCTLND-ALPS_____345_2 & NRTH1385-NOR HBR__138_603			FWD	REV
Wed 04/21/2021 to Wed 04/21/2021			(Import)	(Export)
0800		1600	SCH - NPX_1385	0 MW 0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_601			FWD	REV
Wed 04/21/2021 to Wed 04/21/2021			(Import)	(Export)
0800	Continuous	1600	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_602			FWD	REV
Wed 04/21/2021 to Wed 04/21/2021			(Import)	(Export)
0800		1600	SCH - NPX_1385	0 MW 0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_603			FWD	REV
Wed 04/21/2021 to Wed 04/21/2021			(Import)	(Export)
0800		1600	SCH - NPX_1385	0 MW 0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_602			FWD	REV
Wed 04/21/2021 to Wed 04/21/2021			(Import)	(Export)
0800	Continuous	1600	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 20, 2021 to Thursday ,October 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
NRTH1385-NOR HBR__138_602 & NRTH1385-NOR HBR__138_603					
Wed 04/21/2021	to	Wed 04/21/2021			
0800		1600	SCH - NPX_1385	0 MW	0 MW
Work scheduled by:				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR__138_603					
Wed 04/21/2021	to	Wed 04/21/2021			
0800	Continuous	1600	SCH - NPX_1385	100 MW	100 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	200 MW
NRTH1385-NRTHPORT_138_NNC					
Wed 04/21/2021	to	Wed 04/21/2021			
0800	Continuous	1600	SCH - NPX_1385	0 MW	0 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	200 MW
DUNWODIE_345KV_6					
Fri 04/23/2021	to	Fri 04/23/2021	CANCELLED by ConEd 04/19/2021		
0130	Continuous	0159	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_8					
Fri 04/23/2021	to	Fri 04/23/2021	CANCELLED by ConEd 04/19/2021		
0130	Continuous	0159	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
WOOD_ST_-PLSNTVLE_345_Y87					
Fri 04/23/2021	to	Fri 04/23/2021	CANCELLED by ConEd 04/19/2021		
0130	Continuous	0159	UPNY CONED	5905 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	315 MW
				TTC with All Lines In Service	6220 MW
PLSNTVLY-WOOD_ST__345_F30					
Fri 04/23/2021	to	Fri 04/23/2021	UPDATED by CONED 04/17/2021		
0201	Continuous	0230	UPNY CONED	4000 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	2220 MW
				TTC with All Lines In Service	6220 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 20, 2021 to Thursday ,October 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RNS5

Fri 04/23/2021 to Fri 04/23/2021
 0201 Continuous 0230
 Work scheduled by: ConEd

UPDATED by CONED 04/17/2021

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 2420 MW
 TTC with All Lines In Service 6220 MW

MILLWOOD-EASTVIEW_345_W82

Fri 04/23/2021 to Fri 04/23/2021
 0201 Continuous 1800
 Work scheduled by: ConEd

CANCELLED by ConEd 04/19/2021

FWD
 (Import)
 UPNY CONED **5985 MW**
 Impacts Total Transfer Capability 235 MW
 TTC with All Lines In Service 6220 MW

MILLWOOD_345KV_18

Fri 04/23/2021 to Sat 04/24/2021
 0201 Continuous 2200
 Work scheduled by: ConEd

UPDATED by CONED 04/02/2021

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1870 MW
 TTC with All Lines In Service 6220 MW

SCH-NYISO-NE_LIMIT_900

Sat 04/24/2021 to Sat 05/01/2021
 0801 Continuous 0800
 Work scheduled by: ISONE

UPDATED by ISONE 04/20/2021

REV
 (Export)
 SCH - NE - NY **1100 MW**
 Impacts Total Transfer Capability 600 MW
 TTC with All Lines In Service 1700 MW

CHAT_DC_GC1

Sat 04/24/2021 to Sun 04/25/2021
 2000 Continuous 0500
 Work scheduled by: HQ

FWD
 (Import)
 MOSES SOUTH **2850 MW**
 Impacts Total Transfer Capability 300 MW
 TTC with All Lines In Service 3150 MW

CHAT_DC_GC1

Sat 04/24/2021 to Sun 04/25/2021
 2000 Continuous 0500
 Work scheduled by: HQ

REV
 (Export)
 SCH - HQ - NY **500 MW**
 Impacts Total Transfer Capability 500 MW
 TTC with All Lines In Service 1000 MW

PLSNTVLY-WOOD_ST_345_F30

Mon 04/26/2021 to Tue 04/27/2021
 0001 Continuous 0200
 Work scheduled by: ConEd

UPDATED by CONED 04/17/2021

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 2220 MW
 TTC with All Lines In Service 6220 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 20, 2021 to Thursday ,October 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RNS5

FWD

Mon 04/26/2021 to Tue 04/27/2021 **UPDATED** **by CONED** **04/17/2021**
 0001 Continuous 0200

(Import)

Work scheduled by: ConEd

UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 2420 MW
 TTC with All Lines In Service 6220 MW

KINTIGH_-STA_255_345_SH1-39

FWD

Mon 04/26/2021 to Fri 04/30/2021
 0700 Continuous 1700

(Import)

Work scheduled by: NYPA

DYSINGER EAST **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

NIAGARA_-KINTIGH_345_NS1-38

FWD

Mon 04/26/2021 to Fri 04/30/2021
 0700 Continuous 1700

(Import)

Work scheduled by: NYPA

DYSINGER EAST **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

HOMRC_NY-MAINS_NY_345_47

Mon 04/26/2021 to Sat 05/29/2021 **EXTENDED** **by NYSEG** **03/10/2021**
 0800 Continuous 1900

Work scheduled by: NYSEG

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FRASER_-COOPERS_345_33

FWD

Mon 04/26/2021 to Fri 04/30/2021
 0830 Continuous 1500

(Import)

Work scheduled by: NYSEG

CENTRAL EAST - VC **2395 MW**
 Impacts Total Transfer Capability 580 MW
 TTC with All Lines In Service 2975 MW

ALCOA_PA_115KV_R8105

FWD

Tue 04/27/2021 to Thu 04/29/2021
 0630 Continuous 1830

(Import)

Work scheduled by: NGrid

MOSES SOUTH **3100 MW**
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 3150 MW

MOTTHAVN-RAINEY_345_Q11

FWD

Wed 04/28/2021 to Sat 05/08/2021
 0001 Continuous 0200

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 20, 2021 to Thursday ,October 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BUCHAN_N-EASTVIEW_345_W93					FWD	
Fri 04/30/2021	to	Mon 05/10/2021	<u>EXTENDED</u>	<u>by CONED</u>	<u>04/19/2021</u>	(Import)
0700	Continuous	0159				4350 MW
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	1870 MW
					TTC with All Lines In Service	6220 MW
SCH-IMO-NYISO_LIMIT_1600					FWD	
Sat 05/01/2021	to	Sun 10/31/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Import)
0001	Continuous	2359				1900 MW
Work scheduled by: IESO					SCH - OH - NY	
					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	1950 MW
W49TH_ST_345KV_5					FWD	
Sun 05/02/2021	to	Sun 05/02/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>04/13/2021</u>	(Import)
0201	Continuous	0231				300 MW
Work scheduled by: ConEd					SCH - PJM_HTP	
					Impacts Total Transfer Capability	360 MW
					TTC with All Lines In Service	660 MW
W49TH_ST_345KV_7					FWD	
Sun 05/02/2021	to	Sun 05/02/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>04/13/2021</u>	(Import)
0201	Continuous	0231				300 MW
Work scheduled by: ConEd					SCH - PJM_HTP	
					Impacts Total Transfer Capability	360 MW
					TTC with All Lines In Service	660 MW
CHAT_DC_GC2					FWD	
Sun 05/02/2021	to	Fri 05/28/2021				(Import)
0500	Continuous	1700				2850 MW
Work scheduled by: HQ					MOSES SOUTH	
					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW
CHAT_DC_GC2					REV	
Sun 05/02/2021	to	Fri 05/28/2021				(Export)
0500	Continuous	1700				500 MW
Work scheduled by: HQ					SCH - HQ - NY	
					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1000 MW
DUNWODIE_345KV_7					FWD	
Mon 05/03/2021	to	Mon 05/03/2021				(Import)
0001	Continuous	0030				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 20, 2021 to Thursday ,October 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Work Scheduled	Start	End	Zone	Impact	TTC	FWD	REV
DUNWODIE_345KV_8	Mon 05/03/2021	Mon 05/03/2021	SPR/DUN-SOUTH	800 MW	4600 MW	(Import)	
0001 Continuous 0030							
Work scheduled by: ConEd							
DUNWODIE-MOTTHAVN_345_72	Mon 05/03/2021	Mon 05/03/2021	SPR/DUN-SOUTH	800 MW	4600 MW	(Import)	
0001 Continuous 1800							
Work scheduled by: ConEd							
NRTH1385-NOR_HBR_138_601	Mon 05/03/2021	Mon 05/24/2021	SCH - NPX_1385	100 MW	200 MW	(Import)	(Export)
0600 Continuous 2359							
Work scheduled by: LI							
NRTH1385-NOR_HBR_138_601 & NRTH1385-NOR_HBR_138_602	Mon 05/03/2021	Mon 05/24/2021	SCH - NPX_1385	0 MW	200 MW	(Import)	(Export)
0600 2359							
Work scheduled by:							
NRTH1385-NOR_HBR_138_601 & NRTH1385-NOR_HBR_138_603	Mon 05/03/2021	Mon 05/24/2021	SCH - NPX_1385	0 MW	200 MW	(Import)	(Export)
0600 2359							
Work scheduled by:							
NRTH1385-NOR_HBR_138_602	Mon 05/03/2021	Mon 05/24/2021	SCH - NPX_1385	100 MW	200 MW	(Import)	(Export)
0600 Continuous 2359							
Work scheduled by: LI							
NRTH1385-NOR_HBR_138_602 & NRTH1385-NOR_HBR_138_603	Mon 05/03/2021	Mon 05/24/2021	SCH - NPX_1385	0 MW	200 MW	(Import)	(Export)
0600 2359							
Work scheduled by:							

NYISO TRANSFER LIMITATIONS

Tuesday ,April 20, 2021 to Thursday ,October 20, 2022

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NOR HBR__138_603

Mon 05/03/2021 to Mon 05/24/2021
 0600 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

NRTH1385-NRTHPORT_138_NNC

Mon 05/03/2021 to Mon 05/24/2021
 0600 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

CLAY__-EDIC__345_2-15

Mon 05/03/2021 to Fri 05/07/2021
 0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
OSWEGO EXPORT	4850 MW
Impacts Total Transfer Capability	400 MW
TTC with All Lines In Service	5250 MW

FIVEMILE-STOLLERD_345_29

Mon 05/03/2021 to Fri 05/14/2021
 0700 Continuous 1400

Work scheduled by: NYSEG

SCH - PJ - NY	
Impacts Total Transfer Capability	
TTC with All Lines In Service	

SCH-HQ-NYISO_LIMIT_1400

Mon 05/03/2021 to Fri 05/14/2021
 0700 Continuous 1530

Work scheduled by: HQ

	FWD
	(Import)
SCH - HQ - NY	1400 MW
Impacts Total Transfer Capability	100 MW
TTC with All Lines In Service	1500 MW

PANNELL_-CLAY__345_2

Mon 05/03/2021 to Sun 05/30/2021
 0700 Continuous 1730

Work scheduled by: NYPA

	FWD
	(Import)
WEST CENTRAL	1300 MW
Impacts Total Transfer Capability	950 MW
TTC with All Lines In Service	2250 MW

HURLYAVE-ROSETON__345_303

Mon 05/03/2021 to Fri 05/21/2021
 0800 Continuous 1600

Work scheduled by: CHGE

	FWD
	(Import)
UPNY CONED	4100 MW
Impacts Total Transfer Capability	3715 MW
TTC with All Lines In Service	7815 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 20, 2021 to Thursday ,October 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
SHOR_NPX-SHOREHAM_138_CSC						
Mon 05/03/2021	to	Sat 05/08/2021	EXTENDED	by ISONE 03/15/2021		
0900	Continuous	1600			SCH - NPX_CSC	0 MW
Work scheduled by: LI					Impacts Total Transfer Capability	330 MW
					TTC with All Lines In Service	330 MW
DUNWODIE_345KV_7						
Mon 05/03/2021	to	Mon 05/03/2021			SPR/DUN-SOUTH	3800 MW
1730	Continuous	1800			Impacts Total Transfer Capability	800 MW
Work scheduled by: ConEd					TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_8						
Mon 05/03/2021	to	Mon 05/03/2021			SPR/DUN-SOUTH	3800 MW
1730	Continuous	1800			Impacts Total Transfer Capability	800 MW
Work scheduled by: ConEd					TTC with All Lines In Service	4600 MW
ROTTRDAM-EASTOVER_230_38						
Tue 05/04/2021	to	Tue 05/04/2021			SCH - NE - NY	1400 MW
0830	Daily(No Weekends)	1130			Impacts Total Transfer Capability	200 MW
Work scheduled by: NGrid					TTC with All Lines In Service	1600 MW
					ARR: 77	
RAMAPO__-BUCHAN_N_345_Y94						
Fri 05/07/2021	to	Mon 05/10/2021	EXTENDED	by CONED 04/19/2021		
0001	Continuous	0159			UPNY CONED	7580 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	235 MW
					TTC with All Lines In Service	7815 MW
EASTVIEW-SPRNBRK__345_W79						
Sat 05/08/2021	to	Sun 05/09/2021	EXTENDED	by CONED 04/19/2021		
0700	Continuous	2359			UPNY CONED	4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	3465 MW
					TTC with All Lines In Service	7815 MW
W49TH_ST_345KV_5						
Sun 05/09/2021	to	Sun 05/09/2021	UPDATED	by CONED 04/13/2021		
0130	Continuous	0200			SCH - PJM_HTP	300 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	360 MW
					TTC with All Lines In Service	660 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 20, 2021 to Thursday ,October 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_7

Sun 05/09/2021 to Sun 05/09/2021 **UPDATED by CONED 04/13/2021**
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

W49TH_ST_345KV_7

Mon 05/10/2021 to Mon 05/10/2021
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

W49TH_ST_345KV_8

Mon 05/10/2021 to Mon 05/10/2021
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **450 MW**
 Impacts Total Transfer Capability 210 MW
 TTC with All Lines In Service 660 MW

HUDSONTP-W49TH_ST_345_Y56

Mon 05/10/2021 to Thu 05/13/2021
 0001 Continuous 2300
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

SPRNBK_-TREMONT_345_X28

Mon 05/10/2021 to Wed 05/26/2021 **UPDATED by CONED 03/18/2021**
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **4200 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 4600 MW

CLAY_-EDIC_345_1-16

Mon 05/10/2021 to Fri 05/14/2021
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 OSWEGO EXPORT **4850 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 5250 MW

MOSES_-ADIRNDCK_230_MA2

Mon 05/10/2021 to Tue 06/01/2021
 1200 Continuous 0659
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2100 MW**
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 20, 2021 to Thursday ,October 20, 2022

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ALCOA_PA_115KV_R8105

Tue 05/11/2021 to Thu 06/03/2021
0630 Continuous 1630

Work scheduled by: NGrid

FWD
(Import)
MOSES SOUTH **3100 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 3150 MW

DENNISON-ROSEMNTB_115_2/22

Wed 05/12/2021 to Wed 05/12/2021
0630 Daily(No Weekends) 1830

Work scheduled by: NGrid

UPDATED by HQ 04/16/2021

FWD REV
(Import) (Export)
SCH - HQ_CEDARS **95 MW 40 MW**
Impacts Total Transfer Capability 95 MW 0 MW
TTC with All Lines In Service 190 MW 40 MW

SCH-HQ_CEDARS-NYISO_LIMIT_80

Wed 05/12/2021 to Wed 05/12/2021
0630 Daily(No Weekends) 1830

Work scheduled by: NGrid

UPDATED by HQ 04/16/2021

FWD
(Import)
SCH - HQ_CEDARS **80 MW**
Impacts Total Transfer Capability 110 MW
TTC with All Lines In Service 190 MW

W49TH_ST_345KV_7

Thu 05/13/2021 to Thu 05/13/2021
2230 Continuous 2300

Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **300 MW**
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

W49TH_ST_345KV_8

Thu 05/13/2021 to Thu 05/13/2021
2230 Continuous 2300

Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **450 MW**
Impacts Total Transfer Capability 210 MW
TTC with All Lines In Service 660 MW

CRICKVLY-PLSNTVLY_345_F83

Fri 05/14/2021 to Fri 05/14/2021
0001 Continuous 2200

Work scheduled by: ConEd

FWD
(Import)
SCH - NE - NY **350 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 1400 MW

CRICKVLY-PLSNTVLY_345_F83

Fri 05/14/2021 to Fri 05/14/2021
0001 Continuous 2200

Work scheduled by: ConEd

FWD REV
(Import) (Export)
SCH - NPX_1385 **100 MW 100 MW**
Impacts Total Transfer Capability 100 MW 100 MW
TTC with All Lines In Service 200 MW 200 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 20, 2021 to Thursday ,October 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NOR HBR_138_601 & CRICKVLY-PLSNTVLY_345_F83

Fri 05/14/2021 to Fri 05/14/2021
 0001 2200

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

NRTH1385-NOR HBR_138_602 & CRICKVLY-PLSNTVLY_345_F83

Fri 05/14/2021 to Fri 05/14/2021
 0001 2200

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

NRTH1385-NOR HBR_138_603 & CRICKVLY-PLSNTVLY_345_F83

Fri 05/14/2021 to Fri 05/14/2021
 0001 2200

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

BUCHAN_N-EASTVIEW_345_W93

Fri 05/14/2021 to Sat 05/15/2021
 0001 Continuous 0200

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	4350 MW
Impacts Total Transfer Capability	3465 MW
TTC with All Lines In Service	7815 MW

RAMAPO_-BUCHAN_N_345_Y94

Fri 05/14/2021 to Sat 05/15/2021
 0001 Continuous 0200

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	7580 MW
Impacts Total Transfer Capability	235 MW
TTC with All Lines In Service	7815 MW

SPRNBK_345KV_RS3 & SPRNBK_345KV_RS4

Sat 05/15/2021 to Sat 05/15/2021
 0301 2230

Work scheduled by:

	FWD
	(Import)
SPR/DUN-SOUTH	3200 MW
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	4600 MW

DUNWODIE_345KV_5

Mon 05/17/2021 to Tue 05/18/2021 **CANCELLED by ConEd 04/20/2021**
 0201 Continuous 0200

Work scheduled by: ConEd

	FWD
	(Import)
SPR/DUN-SOUTH	3800 MW
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 20, 2021 to Thursday ,October 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_7					FWD		
Mon 05/17/2021	to	Tue 05/18/2021	CANCELLED	by ConEd	04/20/2021	(Import)	
0201	Continuous	0200				3800 MW	
Work scheduled by: ConEd					SPR/DUN-SOUTH	Impacts Total Transfer Capability 800 MW	
						TTC with All Lines In Service 4600 MW	
SPRNBRK_-DUNWODIE_345_W75					FWD		
Mon 05/17/2021	to	Tue 05/18/2021	CANCELLED	by ConEd	04/20/2021	(Import)	
0201	Continuous	0200				3800 MW	
Work scheduled by: ConEd					SPR/DUN-SOUTH	Impacts Total Transfer Capability 800 MW	
						TTC with All Lines In Service 4600 MW	
SPRNBRK__345KV_RNS3					FWD		
Mon 05/17/2021	to	Tue 05/18/2021	CANCELLED	by ConEd	04/20/2021	(Import)	
0201	Continuous	0200				3800 MW	
Work scheduled by: ConEd					SPR/DUN-SOUTH	Impacts Total Transfer Capability 800 MW	
						TTC with All Lines In Service 4600 MW	
NIAGARA_-STA_255__345_NH2					FWD		
Mon 05/17/2021	to	Fri 05/21/2021	UPDATED	by NYPA	03/23/2021	(Import)	
0500	Continuous	1700				1400 MW	
Work scheduled by: NYPA					DYSINGER EAST	Impacts Total Transfer Capability 1750 MW	
						TTC with All Lines In Service 3150 MW	
SAND_BAR-PLATSBRG_115_PV20							
Mon 05/17/2021	to	Fri 07/02/2021				SCH - NE - NY	
0600	Continuous	1800				Impacts Total Transfer Capability	
Work scheduled by: ISONE						TTC with All Lines In Service	
GOETHALS_345KV_5							
Wed 05/19/2021	to	Mon 05/24/2021	EXTENDED	by CE	04/05/2021		
0100	Continuous	0200				STATEN ISLAND	
Work scheduled by: ConEd						Impacts Total Transfer Capability	
						TTC with All Lines In Service	
LINDEN_-GOETHALS_230_A2253					FWD	REV	
Wed 05/19/2021	to	Mon 05/24/2021	EXTENDED	by CE	04/05/2021	(Import)	(Export)
0100	Continuous	0200				2050 MW	1150 MW
Work scheduled by: ConEd					SCH - PJ - NY	Impacts Total Transfer Capability 150 MW	100 MW
						TTC with All Lines In Service 2200 MW	1250 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 20, 2021 to Thursday ,October 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LINDEN__-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402		FWD	REV
Wed 05/19/2021	to Mon 05/24/2021	(Import)	(Export)
0100	0200	SCH - PJ - NY	2000 MW 1000 MW
Work scheduled by:		Impacts Total Transfer Capability	200 MW 250 MW
		TTC with All Lines In Service	2200 MW 1250 MW
LINDEN__-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402 & MARION__-FARRAGUT_345_C3403		FWD	REV
Wed 05/19/2021	to Mon 05/24/2021	(Import)	(Export)
0100	0200	SCH - PJ - NY	2000 MW 1000 MW
Work scheduled by:		Impacts Total Transfer Capability	200 MW 250 MW
		TTC with All Lines In Service	2200 MW 1250 MW
LINDEN__-GOETHALS_230_A2253 & MARION__-FARRAGUT_345_C3403		FWD	REV
Wed 05/19/2021	to Mon 05/24/2021	(Import)	(Export)
0100	0200	SCH - PJ - NY	2000 MW 1000 MW
Work scheduled by:		Impacts Total Transfer Capability	200 MW 250 MW
		TTC with All Lines In Service	2200 MW 1250 MW
BUCHAN_S-MILLWOOD_345_W97		FWD	
Thu 05/20/2021	to Sat 05/22/2021	(Import)	
0001	Continuous 0200	UPNY CONED	7680 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability	135 MW
		TTC with All Lines In Service	7815 MW
W49TH_ST_345KV_6		FWD	
Thu 05/20/2021	to Sat 05/22/2021	(Import)	
0001	Continuous 0200	UPDATED by CONED 03/30/2021	SCH - PJM_HTP
Work scheduled by: ConEd			300 MW
		Impacts Total Transfer Capability	360 MW
		TTC with All Lines In Service	660 MW
W49TH_ST-E13THSTA_345_M55		FWD	
Thu 05/20/2021	to Mon 05/24/2021	(Import)	
0001	Continuous 0200	UPDATED by CONED 03/30/2021	SPR/DUN-SOUTH
Work scheduled by: ConEd			3800 MW
		Impacts Total Transfer Capability	800 MW
		TTC with All Lines In Service	4600 MW
E13THSTA-FARRAGUT_345_46		FWD	
Sat 05/22/2021	to Mon 05/24/2021	(Import)	
0001	Continuous 0200	UPDATED by CONED 03/30/2021	SPR/DUN-SOUTH
Work scheduled by: ConEd			3800 MW
		Impacts Total Transfer Capability	800 MW
		TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 20, 2021 to Thursday ,October 20, 2022

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY-WOOD_ST_345_F31				FWD	
Mon 05/24/2021	to	Tue 05/25/2021		(Import)	
0001	Continuous	0159	UPNY CONED	4000 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	3815 MW
				TTC with All Lines In Service	7815 MW
PLSNTVLY_345KV_RNS4				FWD	
Mon 05/24/2021	to	Tue 05/25/2021		(Import)	
0001	Continuous	0159	UPNY CONED	3800 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	4015 MW
				TTC with All Lines In Service	7815 MW
W49TH_ST_345KV_6				FWD	
Mon 05/24/2021	to	Mon 05/24/2021	UPDATED by CONED 03/30/2021	(Import)	
0130	Continuous	0200	SCH - PJM_HTP	300 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	360 MW
				TTC with All Lines In Service	660 MW
DENNISON-ROSEMNTB_115_2/22				FWD	REV
Mon 05/24/2021	to	Wed 05/26/2021		(Import)	(Export)
0630	Continuous	1900	SCH - HQ_CEDARS	95 MW	40 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	95 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
SCH-HQ_CEDARS-NYISO_LIMIT_80				FWD	
Mon 05/24/2021	to	Wed 05/26/2021		(Import)	
0630	Continuous	1900	SCH - HQ_CEDARS	80 MW	
Work scheduled by: NGrid				Impacts Total Transfer Capability	110 MW
				TTC with All Lines In Service	190 MW
ROSETON_-EFISHKIL_345_RFK305				FWD	
Wed 05/26/2021	to	Thu 05/27/2021		(Import)	
0001	Continuous	0200	UPNY CONED	6680 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	1135 MW
				TTC with All Lines In Service	7815 MW
DENNISON-ROSEMNTA_115_1/11				FWD	REV
Thu 05/27/2021	to	Fri 05/28/2021		(Import)	(Export)
0630	Continuous	1900	SCH - HQ_CEDARS	95 MW	40 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	95 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 20, 2021 to Thursday ,October 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-HQ_CEDARS-NYISO_LIMIT_80

Thu 05/27/2021 to Fri 05/28/2021
 0630 Continuous 1900
 Work scheduled by: NGrid

FWD
 (Import)
 SCH - HQ_CEDARS **80 MW**
 Impacts Total Transfer Capability 110 MW
 TTC with All Lines In Service 190 MW

VOLNEY -MARCY 345_19

Tue 06/01/2021 to Wed 06/02/2021
 0700 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 CENTRAL EAST - VC **2825 MW**
 Impacts Total Transfer Capability 150 MW
 TTC with All Lines In Service 2975 MW

VOLNEY -MARCY 345_19

Tue 06/01/2021 to Wed 06/02/2021
 0700 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 OSWEGO EXPORT **4900 MW**
 Impacts Total Transfer Capability 350 MW
 TTC with All Lines In Service 5250 MW

FRASER -GILBOA 345_GF5-35

Tue 06/01/2021 to Mon 06/07/2021
 0700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2650 MW**
 Impacts Total Transfer Capability 325 MW
 TTC with All Lines In Service 2975 MW

MOSES -ADIRNDCK_230_MA2

Tue 06/01/2021 to Sun 11/14/2021
 0700 Continuous 1300
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2100 MW**
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW

MARCY -EDIC 345_UE1-7

Thu 06/03/2021 to Fri 06/04/2021
 0700 Continuous 1730
 Work scheduled by: NYPA

ARR: 19&16

FWD
 (Import)
 OSWEGO EXPORT **5250 MW**
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 5250 MW

PORTER -ROTTRDAM_230_30

Thu 06/03/2021 to Wed 09/15/2021
 0700 Continuous 0659
 Work scheduled by: NGrid

UPDATED by NGRID 01/19/2021

FWD
 (Import)
 CENTRAL EAST - VC **2805 MW**
 Impacts Total Transfer Capability 170 MW
 TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 20, 2021 to Thursday ,October 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___345KV_CSC				FWD	
Sat 06/05/2021	to	Sat 06/05/2021		(Import)	
0700	Continuous	1730	CENTRAL EAST - VC	2925 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	50 MW
				TTC with All Lines In Service	2975 MW
ATHENS__-PLSNTVLY_345_91				FWD	
Tue 06/08/2021	to	Wed 06/16/2021		(Import)	
0600	Continuous	2000	UPNY CONED	3800 MW	
Work scheduled by: NGrid				Impacts Total Transfer Capability	4015 MW
				TTC with All Lines In Service	7815 MW
GILBOA__-N.SCTLND_345_GNS-1				FWD	
Wed 06/09/2021	to	Wed 06/09/2021		(Import)	
0800	Daily	1200	CENTRAL EAST - VC	2520 MW	
Work scheduled by: NGrid				Impacts Total Transfer Capability	455 MW
				TTC with All Lines In Service	2975 MW
BECK___-NIAGARA_345_PA301				FWD	REV
Wed 06/16/2021	to	Thu 06/17/2021		(Import)	(Export)
0500	Continuous	2330	SCH - OH - NY	900 MW	800 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1050 MW
				TTC with All Lines In Service	1950 MW
PLSNTVLY_345KV_RNS5				FWD	
Thu 06/17/2021	to	Thu 06/17/2021	UPDATED	by CONED	04/19/2021
0001	Continuous	0030		UPNY CONED	3800 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	4015 MW
				TTC with All Lines In Service	7815 MW
LEEDS__-PLSNTVLY_345_92				FWD	
Thu 06/17/2021	to	Thu 06/24/2021	UPDATED	by CONED	04/19/2021
0001	Continuous	2000		UPNY CONED	3800 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	4015 MW
				TTC with All Lines In Service	7815 MW
PLSNTVLY_345KV_RNS5				FWD	
Thu 06/24/2021	to	Thu 06/24/2021	UPDATED	by CONED	04/19/2021
1930	Continuous	2000		UPNY CONED	3800 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	4015 MW
				TTC with All Lines In Service	7815 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 20, 2021 to Thursday ,October 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BECK ___ -NIAGARA ___ 345_PA301	FWD	REV
	(Import)	(Export)
Fri 06/25/2021 to Fri 06/25/2021		
0500 Continuous 1700	SCH - OH - NY	900 MW 800 MW
Work scheduled by: NYPA	Impacts Total Transfer Capability	1050 MW 900 MW
	TTC with All Lines In Service	1950 MW 1700 MW
<hr/>		
FRASANX-COOPERS ___ 345_UCC2-41	FWD	
	(Import)	
Fri 06/25/2021 to Tue 08/10/2021		
0700 Continuous 1530	CENTRAL EAST - VC	2500 MW
Work scheduled by: NYPA	Impacts Total Transfer Capability	475 MW
	TTC with All Lines In Service	2975 MW
		ARR: 19
<hr/>		
MARCY ___ -FRASANX 345_UCC2-41	FWD	
	(Import)	
Fri 06/25/2021 to Tue 08/10/2021		
0700 Continuous 1530	CENTRAL EAST - VC	2500 MW
Work scheduled by: NYPA	Impacts Total Transfer Capability	475 MW
	TTC with All Lines In Service	2975 MW
		ARR: 19
<hr/>		
BECK ___ -NIAGARA ___ 345_PA302	FWD	REV
	(Import)	(Export)
Mon 07/12/2021 to Fri 07/16/2021		
0500 Continuous 1700	SCH - OH - NY	900 MW 800 MW
Work scheduled by: NYPA	Impacts Total Transfer Capability	1050 MW 900 MW
	TTC with All Lines In Service	1950 MW 1700 MW
<hr/>		
NIAGARA ___ 345_230_AT4	FWD	REV
	(Import)	(Export)
Mon 07/19/2021 to Fri 07/30/2021		
0500 Continuous 1700	SCH - OH - NY	1900 MW 1400 MW
Work scheduled by: NYPA	Impacts Total Transfer Capability	50 MW 300 MW
	TTC with All Lines In Service	1950 MW 1700 MW
		UPDATED by NYPA 02/19/2021
<hr/>		
NIAGARA -STA 255 ___ 345_NH2	FWD	
	(Import)	
Mon 07/26/2021 to Fri 07/30/2021		
0500 Continuous 1900	DYSINGER EAST	1400 MW
Work scheduled by: NYPA	Impacts Total Transfer Capability	1750 MW
	TTC with All Lines In Service	3150 MW
		UPDATED by NYPA 02/19/2021
<hr/>		
SAND_BAR-PLATSBRG 115_PV20		
Tue 08/03/2021 to Tue 08/03/2021		
0700 Continuous 1830	SCH - NE - NY	
Work scheduled by: NYPA	Impacts Total Transfer Capability	
	TTC with All Lines In Service	

NYISO TRANSFER LIMITATIONS

Tuesday ,April 20, 2021 to Thursday ,October 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

KINTIGH_-STA_255__345_SH1-39

Mon 08/09/2021 to Sun 08/15/2021
0500 Continuous 1900

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

NIAGARA_-KINTIGH__345_NS1-38

Mon 08/09/2021 to Sun 08/15/2021
0500 Continuous 1900

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

KINTIGH_-STA_255__345_SH1-39

Mon 08/16/2021 to Sun 08/22/2021
0500 Continuous 1900

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

NIAGARA_-KINTIGH__345_NS1-38

Mon 08/16/2021 to Sun 08/22/2021
0500 Continuous 1900

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

NIAGARA_-STA_255__345_NH2

Wed 09/01/2021 to Tue 09/21/2021
0500 Continuous 1900

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

FRASANNX-COOPERS__345_UCC2-41

Tue 09/07/2021 to Wed 09/15/2021 **UPDATED by NYISO 02/03/2021**
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

MARCY_-FRASANNX_345_UCC2-41

Tue 09/07/2021 to Wed 09/15/2021 **UPDATED by NYISO 02/03/2021**
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 20, 2021 to Thursday ,October 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PORTER__-ROTTRDAM_230_30

Wed 09/15/2021 to Tue 11/30/2021
0700 Continuous 1730

Work scheduled by: NGrid

FWD

(Import)

CENTRAL EAST - VC **2805 MW**
Impacts Total Transfer Capability 170 MW
TTC with All Lines In Service 2975 MW

EDIC___-N.SCTLND_345_14

Thu 09/16/2021 to Sun 11/14/2021
0700 Continuous 1730

Work scheduled by: NGrid

FWD

(Import)

CENTRAL EAST - VC **1670 MW**
Impacts Total Transfer Capability 1305 MW
TTC with All Lines In Service 2975 MW

EDIC___-N.SCTLND_345_14 & PORTER__-ROTTRDAM_230_30

Thu 09/16/2021 to Sun 11/14/2021
0700 1730

Work scheduled by:

FWD

(Import)

CENTRAL EAST - VC **1500 MW**
Impacts Total Transfer Capability 1475 MW
TTC with All Lines In Service 2975 MW

HURLYAVE-ROSETON__345_303

Thu 09/16/2021 to Sun 10/17/2021
0800 Continuous 1600

Work scheduled by: CHGE

UPDATED by CHGE 09/22/2020

FWD

(Import)

UPNY CONED **4100 MW**
Impacts Total Transfer Capability 3715 MW
TTC with All Lines In Service 7815 MW

HOMRC_NY-MAINS_NY_345_47

Sat 09/18/2021 to Fri 11/05/2021
0800 Continuous 1600

Work scheduled by: PJM

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

PANNELL_-CLAY_____345_1

Mon 09/20/2021 to Fri 09/24/2021
0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

CLAY___-EDIC_____345_2-15

Mon 09/20/2021 to Sat 10/16/2021
0700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

OSWEGO EXPORT **4850 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 5250 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 20, 2021 to Thursday ,October 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

KINTIGH_-STA_255__345_SH1-39

Mon 09/27/2021 to Wed 09/29/2021
0500 Continuous 0459

Work scheduled by: NYPA

UPDATED by NYPA 03/04/2021

FWD
(Import)
DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

NIAGARA_-KINTIGH__345_NS1-38

Mon 09/27/2021 to Wed 09/29/2021
0500 Continuous 0459

Work scheduled by: NYPA

UPDATED by NYPA 03/04/2021

FWD
(Import)
DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

PANNELL_-CLAY____345_2

Mon 09/27/2021 to Fri 10/01/2021
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

W49TH_ST_345KV_6

Tue 09/28/2021 to Tue 09/28/2021
0100 Continuous 0130

Work scheduled by: ConEd

UPDATED by CONED 01/15/2021

FWD
(Import)
SCH - PJM_HTP **300 MW**
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

E13THSTA-FARRAGUT_345_46

Tue 09/28/2021 to Tue 10/26/2021
0100 Continuous 0300

Work scheduled by: ConEd

UPDATED by CONED 01/15/2021

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

W49TH_ST-E13THSTA_345_M55

Tue 09/28/2021 to Tue 10/26/2021
0100 Continuous 0300

Work scheduled by: ConEd

UPDATED by CONED 01/15/2021

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

KINTIGH_-STA_255__345_SH1-39

Wed 09/29/2021 to Wed 12/01/2021
0500 Continuous 1900

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 20, 2021 to Thursday ,October 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-KINTIGH__345_NS1-38				FWD	
Wed 09/29/2021	to	Wed 12/01/2021		(Import)	
0500	Continuous	1900	DYSINGER EAST	1400 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1750 MW	
			TTC with All Lines In Service	3150 MW	
LEEDS_-HURLYAVE_345_301				FWD	
Mon 10/18/2021	to	Fri 11/19/2021		(Import)	
0800	Continuous	1600	UPNY CONED	4100 MW	
Work scheduled by: CHGE			Impacts Total Transfer Capability	3715 MW	
			TTC with All Lines In Service	7815 MW	
GOETHALS_345KV_5					
Thu 10/21/2021	to	Sat 11/20/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>03/05/2021</u>
0001	Continuous	0200	STATEN ISLAND		
Work scheduled by: ConEd			Impacts Total Transfer Capability		
			TTC with All Lines In Service		
W49TH_ST_345KV_6				FWD	
Tue 10/26/2021	to	Tue 10/26/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>01/15/2021</u>
0230	Continuous	0300	SCH - PJM_HTP		
Work scheduled by: ConEd			Impacts Total Transfer Capability	360 MW	
			TTC with All Lines In Service	660 MW	
SCH-IMO-NYISO_LIMIT_1750				FWD	
Mon 11/01/2021	to	Fri 12/31/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>
0001	Continuous	2359	SCH - OH - NY		
Work scheduled by: IESO			Impacts Total Transfer Capability	250 MW	
			TTC with All Lines In Service	2300 MW	
SCH-NYISO-IMO_LIMIT_1600					REV
Mon 11/01/2021	to	Fri 12/31/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>
0001	Continuous	2359	SCH - OH - NY		
Work scheduled by: IESO			Impacts Total Transfer Capability	100 MW	
			TTC with All Lines In Service	2000 MW	
LINDN_CG-LNDVFT__345_V-3022				FWD	REV
Tue 11/02/2021	to	Fri 11/05/2021		(Import)	(Export)
0800	Continuous	1500	SCH - PJM_VFT		
Work scheduled by: PJM			Impacts Total Transfer Capability	315 MW	315 MW
			TTC with All Lines In Service	315 MW	315 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 20, 2021 to Thursday ,October 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PORTER__-ROTTRDAM_230_30 & MASSENA_-MARCY_____765_MSU1

Mon 11/15/2021 to Tue 11/30/2021
 0100 1730

Work scheduled by:

FWD
 (Import)
 CENTRAL EAST - VC **1500 MW**
 Impacts Total Transfer Capability 1475 MW
 TTC with All Lines In Service 2975 MW

CHATGUAY-MASSENA__765_7040

Mon 11/15/2021 to Tue 11/30/2021
 0100 Continuous 1859

Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **1550 MW**
 Impacts Total Transfer Capability 1600 MW
 TTC with All Lines In Service 3150 MW

CHATGUAY-MASSENA__765_7040

Mon 11/15/2021 to Tue 11/30/2021
 0100 Continuous 1859

Work scheduled by: NYPA

FWD REV
 (Import) (Export)
 SCH - HQ - NY **0 MW 0 MW**
 Impacts Total Transfer Capability 1500 MW 1000 MW
 TTC with All Lines In Service 1500 MW 1000 MW

MARCY_____765_345_AT1

Mon 11/15/2021 to Tue 11/30/2021
 0100 Continuous 1859

Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1750 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 3150 MW

MARCY_____765_345_AT2

Mon 11/15/2021 to Tue 11/30/2021
 0100 Continuous 1859

Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

MASSENA_-MARCY_____765_MSU1

Mon 11/15/2021 to Tue 11/30/2021
 0100 Continuous 1859

Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **1670 MW**
 Impacts Total Transfer Capability 1305 MW
 TTC with All Lines In Service 2975 MW

MASSENA_-MARCY_____765_MSU1

Mon 11/15/2021 to Tue 11/30/2021
 0100 Continuous 1859

Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **500 MW**
 Impacts Total Transfer Capability 2650 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 20, 2021 to Thursday ,October 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----			FWD	REV
			(Import)	(Export)
MASSENA -MARCY 765_MSU1				
Mon 11/15/2021	to	Tue 11/30/2021		
0100	Continuous	1859	SCH - HQ - NY	475 MW 1000 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1025 MW 0 MW
			TTC with All Lines In Service	1500 MW 1000 MW
-----			FWD	
MASSENA -MARCY 765_MSU1			(Import)	
Mon 11/15/2021	to	Tue 11/30/2021	SCH - HQ_CEDARS	90 MW
0100	Continuous	1859	Impacts Total Transfer Capability	109 MW
Work scheduled by: NYPA			TTC with All Lines In Service	199 MW
-----			FWD	
MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040			(Import)	
Mon 11/15/2021	to	Tue 11/30/2021	MOSES SOUTH	500 MW
0100		1859	Impacts Total Transfer Capability	2650 MW
Work scheduled by:			TTC with All Lines In Service	3150 MW
-----			FWD	REV
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2			(Import)	(Export)
Mon 11/15/2021	to	Tue 11/30/2021	SCH - HQ - NY	850 MW 0 MW
0100		1859	Impacts Total Transfer Capability	650 MW 1000 MW
Work scheduled by:			TTC with All Lines In Service	1500 MW 1000 MW
-----			FWD	
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2			(Import)	
Mon 11/15/2021	to	Tue 11/30/2021	SCH - HQ_CEDARS	90 MW
0100		1859	Impacts Total Transfer Capability	109 MW
Work scheduled by:			TTC with All Lines In Service	199 MW
-----			FWD	
STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1			(Import)	
Mon 11/15/2021	to	Tue 11/30/2021	SCH - HQ_CEDARS	90 MW
0100		1859	Impacts Total Transfer Capability	109 MW
Work scheduled by:			TTC with All Lines In Service	199 MW
-----			FWD	
STLAWRNC-MOSES 230_L33P & MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2			(Import)	
Mon 11/15/2021	to	Tue 11/30/2021	SCH - HQ_CEDARS	90 MW
0100		1859	Impacts Total Transfer Capability	109 MW
Work scheduled by:			TTC with All Lines In Service	199 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 20, 2021 to Thursday ,October 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASER___345_FRASER SVC

Wed 12/01/2021 to Mon 02/28/2022
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)

CENTRAL EAST - VC **2935 MW**
Impacts Total Transfer Capability 40 MW
TTC with All Lines In Service 2975 MW

MOSES___-ADIRNDCK_230_MAI

Wed 12/01/2021 to Tue 05/31/2022
0700 Continuous 1300

Work scheduled by: NYPA

FWD
(Import)

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

NIAGARA_-STA_255__345_NH2

Thu 12/02/2021 to Thu 01/13/2022
0500 Continuous 1900

Work scheduled by: NYPA

FWD
(Import)

DYSINGER EAST **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

MOTTHAVN-RAINEY___345_Q12

Sun 12/05/2021 to Sat 12/25/2021 **UPDATED by CONED 03/25/2021**
0001 Continuous 0159

Work scheduled by: ConEd

FWD
(Import)

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

LEEDS___-PLSNTVLY_345_92

Thu 02/17/2022 to Mon 02/21/2022 **UPDATED by NGRID 03/31/2021**
0600 Continuous 1900

Work scheduled by: NGrid

FWD
(Import)

UPNY CONED **3800 MW**
Impacts Total Transfer Capability 2420 MW
TTC with All Lines In Service 6220 MW

GOETHALS_345KV_5

Sat 03/05/2022 to Mon 04/04/2022 **UPDATED by CONED 03/26/2021**
0001 Continuous 0200

Work scheduled by: ConEd

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

LINDEN___-GOETHALS_230_A2253

Sat 03/05/2022 to Mon 04/04/2022 **UPDATED by CONED 03/26/2021**
0001 Continuous 0200

Work scheduled by: ConEd

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Tuesday ,April 20, 2021 to Thursday ,October 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

N. SCTLND-ALPS	_____345_2					
Mon 05/02/2022	to	Mon 05/09/2022				FWD
0600	Daily	1800				(Import)
Work scheduled by: NGrid			SCH - NE - NY			750 MW
			Impacts Total Transfer Capability			650 MW
			TTC with All Lines In Service			1400 MW
<hr/>						
N. SCTLND-ALPS	_____345_2					FWD
Mon 05/02/2022	to	Mon 05/09/2022				(Import) (Export)
0600	Daily	1800				
Work scheduled by: NGrid			SCH - NPX_1385			100 MW
			Impacts Total Transfer Capability			100 MW
			TTC with All Lines In Service			200 MW
<hr/>						
HOMRC_NY-MAINS_NY	_____345_47					
Fri 05/20/2022	to	Fri 05/27/2022	UPDATED	by PJM	11/19/2020	
0800	Continuous	1600				
Work scheduled by: PJM			SCH - PJ - NY			
			Impacts Total Transfer Capability			
			TTC with All Lines In Service			
<hr/>						
HOMR_NYW-PIERC_NY	_____345_48					
Fri 05/20/2022	to	Fri 05/27/2022	UPDATED	by PJM	11/19/2020	
0800	Continuous	1600				
Work scheduled by: PJM			SCH - PJ - NY			
			Impacts Total Transfer Capability			
			TTC with All Lines In Service			
<hr/>						
MOSES_-ADIRNDCK_230_MA2						FWD
Wed 06/01/2022	to	Mon 11/14/2022				(Import)
0700	Continuous	1300				
Work scheduled by: NYPA			MOSES SOUTH			2100 MW
			Impacts Total Transfer Capability			1050 MW
			TTC with All Lines In Service			3150 MW
<hr/>						
SPRNBRK_345KV_RNS5						FWD
Mon 09/19/2022	to	Mon 09/19/2022	UPDATED	by CONED	09/17/2020	(Import)
0001	Continuous	0030				
Work scheduled by: ConEd			SPR/DUN-SOUTH			3200 MW
			Impacts Total Transfer Capability			1400 MW
			TTC with All Lines In Service			4600 MW
<hr/>						
SPRNBRK_-W49TH_ST_345_M51						FWD
Mon 09/19/2022	to	Wed 09/21/2022	UPDATED	by CONED	09/17/2020	(Import)
0001	Continuous	2200				
Work scheduled by: ConEd			SPR/DUN-SOUTH			3200 MW
			Impacts Total Transfer Capability			1400 MW
			TTC with All Lines In Service			4600 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 20, 2021 to Thursday ,October 20, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK__345KV_RNS5

FWD

Wed 09/21/2022 to Wed 09/21/2022 UPDATED by CONED 09/17/2020
 2130 Continuous 2200

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

SPRNBRK_-W49TH_ST_345_M51

FWD

Sat 10/01/2022 to Mon 10/17/2022 UPDATED by CONED 08/01/2020
 0001 Continuous 0300

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

SPRNBRK__345KV_RNS5

FWD

Sat 10/01/2022 to Mon 10/17/2022 UPDATED by CONED 08/01/2020
 0001 Continuous 0300

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW