

NYISO TRANSFER LIMITATIONS

Wednesday, April 21, 2021 to Friday ,October 21, 2022

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Wed 06/30/2021 **EXT FORCE** **by CONED** **08/28/2020**

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Wed 06/30/2021

0001 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2550 MW	1900 MW
Impacts Total Transfer Capability	250 MW	50 MW
TTC with All Lines In Service	2800 MW	1950 MW

MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Wed 06/30/2021 **EXT FORCE** **by CONED** **08/28/2020**

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

STLAWRNC-MOSES_230_L33P

Mon 04/30/2018 to Mon 10/31/2022 **EXT FORCE** **by IESO** **10/01/2020**

0456 Continuous 1600

Work scheduled by: IESO

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

NEWBRDGE_345_138_BK_1

Wed 09/02/2020 to Tue 02/01/2022 **EXT FORCE** **by LI** **01/12/2021**

1807 Continuous 2359

Work scheduled by: LI

	FWD
	(Import)
SCH - PJM_NEPTUNE	375 MW
Impacts Total Transfer Capability	285 MW
TTC with All Lines In Service	660 MW

SPRNBK_-EGRDNCTR_345_Y49

Thu 10/01/2020 to Mon 04/19/2021 **EXT FORCE** **by LI** **02/23/2021**

0404 Continuous 2359

Work scheduled by: LI

	FWD
	(Import)
CONED - LIPA	775 MW
Impacts Total Transfer Capability	725 MW
TTC with All Lines In Service	1500 MW

EGRDNCTY_345_138_AT2

Sat 10/10/2020 to Mon 04/19/2021 **EXT FORCE** **by LI** **02/23/2021**

1815 Continuous 2359

Work scheduled by: LI

	FWD
	(Import)
CONED - LIPA	1250 MW
Impacts Total Transfer Capability	250 MW
TTC with All Lines In Service	1500 MW

NYISO TRANSFER LIMITATIONS

Wednesday, April 21, 2021 to Friday, October 21, 2022

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EGRDNCTY_345_138_AT1

Sat 10/10/2020 to Mon 04/19/2021
1856 Continuous 2359

EXT FORCE by LI 02/23/2021

Work scheduled by: LI

FWD
(Import)
1250 MW
CONED - LIPA
Impacts Total Transfer Capability 250 MW
TTC with All Lines In Service 1500 MW

SCH-IMO-NYISO_LIMIT_1750

Sun 11/01/2020 to Fri 04/30/2021
0001 Continuous 2359

UPDATED by IESO 05/03/2019

Work scheduled by: IESO

FWD
(Import)
2050 MW
SCH - OH - NY
Impacts Total Transfer Capability 250 MW
TTC with All Lines In Service 2300 MW

SCH-NYISO-IMO_LIMIT_1600

Sun 11/01/2020 to Fri 04/30/2021
0001 Continuous 2359

UPDATED by IESO 05/03/2019

Work scheduled by: IESO

REV
(Export)
1900 MW
SCH - OH - NY
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 2000 MW

SAND_BAR-PLATSBRG_115_PV20

Tue 02/23/2021 to Mon 05/17/2021
1801 Continuous 0559

UPDATED by NYISO 03/16/2021

Work scheduled by: ISONE

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

W49TH_ST_345KV_8

Tue 03/02/2021 to Sun 05/02/2021
0201 Continuous 0200

EXTENDED by CONED 04/10/2021

Work scheduled by: ConEd

FWD
(Import)
300 MW
SCH - PJM_HTP
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

PORTER_-ROTTRDAM_230_31

Tue 03/02/2021 to Mon 05/31/2021
0600 Continuous 1730

UPDATED by NGRID 03/10/2021

Work scheduled by: NGrid

FWD
(Import)
2805 MW
CENTRAL EAST - VC
Impacts Total Transfer Capability 170 MW
TTC with All Lines In Service 2975 MW

MOSES_-ADIRNDCK_230_MAL

Tue 03/02/2021 to Mon 05/10/2021
0700 Continuous 1159

UPDATED by NYPA 02/11/2021

Work scheduled by: NYPA

FWD
(Import)
2300 MW
MOSES SOUTH
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Wednesday, April 21, 2021 to Friday ,October 21, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_6

Sun 03/21/2021 to Sun 05/02/2021 **EXTENDED** **by CONED** **04/10/2021**
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
300 MW
 SCH - PJM_HTP
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

EDIC -N.SCTLND_345_14 & PORTER -ROTTDAM_230_31

Mon 03/22/2021 to Mon 05/31/2021
 0600 1730
 Work scheduled by:

FWD
 (Import)
1500 MW
 CENTRAL EAST - VC
 Impacts Total Transfer Capability 1475 MW
 TTC with All Lines In Service 2975 MW

EDIC -N.SCTLND_345_14

Mon 03/22/2021 to Mon 05/31/2021 **UPDATED** **by NGRID** **03/10/2021**
 0600 Continuous 1830
 Work scheduled by: NGrid

FWD
 (Import)
1670 MW
 CENTRAL EAST - VC
 Impacts Total Transfer Capability 1305 MW
 TTC with All Lines In Service 2975 MW

S.RIPLEY-DUNKIRK_230_68

Mon 04/12/2021 to Fri 04/23/2021 **UPDATED** **by NGRID** **04/12/2021**
 0630 Continuous 1700
 Work scheduled by: NGrid

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

SPRNBRK -W49TH_ST_345_M51

Wed 04/14/2021 to Mon 04/26/2021 **EXTENDED** **by CONED** **04/16/2021**
 1124 Continuous 2359
 Work scheduled by: ConEd

FWD
 (Import)
3200 MW
 SPR/DUN-SOUTH
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

SCH-NPX_1385-NYISO_LIMIT_150

Mon 04/19/2021 to Thu 04/29/2021 **FORCED** **by ISONE** **04/17/2021**
 0001 Continuous 1600
 Work scheduled by: ISONE

FWD
 (Import)
150 MW
 SCH - NPX_1385
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 200 MW

N.SCTLND-ALPS_345_2

Mon 04/19/2021 to Mon 04/26/2021 **UPDATED** **by NGRID** **04/20/2021**
 0841 Continuous 1800
 Work scheduled by: NGrid

FWD
 (Import)
900 MW
 SCH - NE - NY
 Impacts Total Transfer Capability 500 MW
 TTC with All Lines In Service 1400 MW

NYISO TRANSFER LIMITATIONS

Wednesday, April 21, 2021 to Friday, October 21, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
N. SCTLND-ALPS 345_2						
Mon 04/19/2021	to	Mon 04/26/2021	<u>UPDATED</u>	<u>by NGRID</u>	<u>04/20/2021</u>	
0841	Continuous	1800				
Work scheduled by: NGrid					SCH - NPX_1385	100 MW
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
N. SCTLND-LEEDS 345_93						
Mon 04/19/2021	to	Mon 04/26/2021	<u>UPDATED</u>	<u>by NGRID</u>	<u>04/20/2021</u>	
0841	Continuous	1800				
Work scheduled by: NGrid					CENTRAL EAST - VC	2650 MW
					Impacts Total Transfer Capability	325 MW
					TTC with All Lines In Service	2975 MW
DUNWODIE_345KV_6						
Tue 04/20/2021	to	Tue 04/20/2021	<u>CANCELLED</u>	<u>by ConEd</u>	<u>04/19/2021</u>	
0201	Continuous	0230				
Work scheduled by: ConEd					SPR/DUN-SOUTH	3800 MW
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_8						
Tue 04/20/2021	to	Tue 04/20/2021	<u>CANCELLED</u>	<u>by ConEd</u>	<u>04/19/2021</u>	
0201	Continuous	0230				
Work scheduled by: ConEd					SPR/DUN-SOUTH	3800 MW
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
WOOD_ST_-PLSNTVLE_345_Y87						
Tue 04/20/2021	to	Tue 04/20/2021	<u>CANCELLED</u>	<u>by ConEd</u>	<u>04/19/2021</u>	
0201	Continuous	0230				
Work scheduled by: ConEd					UPNY CONED	5905 MW
					Impacts Total Transfer Capability	315 MW
					TTC with All Lines In Service	6220 MW
PLSNTVLE-DUNWODIE_345_W90						
Tue 04/20/2021	to	Fri 04/23/2021	<u>CANCELLED</u>	<u>by ConEd</u>	<u>04/19/2021</u>	
0201	Continuous	0159				
Work scheduled by: ConEd					UPNY CONED	4000 MW
					Impacts Total Transfer Capability	2220 MW
					TTC with All Lines In Service	6220 MW
MAINESEBG-WATRCURE_345_30						
Tue 04/20/2021	to	Tue 04/20/2021	<u>UPDATED</u>	<u>by NYSEG</u>	<u>04/20/2021</u>	
0800	Continuous	1504				
Work scheduled by: NYSEG					SCH - PJ - NY	2300 MW
					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	2800 MW

NYISO TRANSFER LIMITATIONS

Wednesday, April 21, 2021 to Friday, October 21, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
NRTH1385-NOR HBR_138_601						
Wed 04/21/2021	to	Wed 04/21/2021	CANCELLED	by ISONE	04/21/2021	
0800	Continuous	1600				
Work scheduled by: ISONE					SCH - NPX_1385	100 MW
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR_138_602						
Wed 04/21/2021	to	Wed 04/21/2021	CANCELLED	by ISONE	04/21/2021	
0800	Continuous	1600				
Work scheduled by: ISONE					SCH - NPX_1385	100 MW
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR_138_603						
Wed 04/21/2021	to	Wed 04/21/2021	CANCELLED	by ISONE	04/21/2021	
0800	Continuous	1600				
Work scheduled by: ISONE					SCH - NPX_1385	100 MW
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
NRTH1385-NRTHPORT_138_NNC						
Wed 04/21/2021	to	Wed 04/21/2021	CANCELLED	by ISONE	04/21/2021	
0800	Continuous	1600				
Work scheduled by: ISONE					SCH - NPX_1385	0 MW
					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	200 MW
DUNWODIE_345KV_6						
Fri 04/23/2021	to	Fri 04/23/2021	CANCELLED	by ConEd	04/19/2021	
0130	Continuous	0159				
Work scheduled by: ConEd					SPR/DUN-SOUTH	3800 MW
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_8						
Fri 04/23/2021	to	Fri 04/23/2021	CANCELLED	by ConEd	04/19/2021	
0130	Continuous	0159				
Work scheduled by: ConEd					SPR/DUN-SOUTH	3800 MW
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
WOOD_ST_-PLSNTVLE_345_Y87						
Fri 04/23/2021	to	Fri 04/23/2021	CANCELLED	by ConEd	04/19/2021	
0130	Continuous	0159				
Work scheduled by: ConEd					UPNY CONED	5905 MW
					Impacts Total Transfer Capability	315 MW
					TTC with All Lines In Service	6220 MW

NYISO TRANSFER LIMITATIONS

Wednesday, April 21, 2021 to Friday ,October 21, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					FWD		
PLSNTVLY-WOOD_ST__345_F30					(Import)		
Fri 04/23/2021	to	Fri 04/23/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>04/17/2021</u>	UPNY CONED	4000 MW
0201	Continuous	0230				Impacts Total Transfer Capability	2220 MW
Work scheduled by: ConEd					TTC with All Lines In Service	6220 MW	
<hr/>					FWD		
PLSNTVLY_345KV_RNS5					(Import)		
Fri 04/23/2021	to	Fri 04/23/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>04/17/2021</u>	UPNY CONED	3800 MW
0201	Continuous	0230				Impacts Total Transfer Capability	2420 MW
Work scheduled by: ConEd					TTC with All Lines In Service	6220 MW	
<hr/>					FWD		
MILLWOOD-EASTVIEW_345_W82					(Import)		
Fri 04/23/2021	to	Fri 04/23/2021	<u>CANCELLED</u>	<u>by ConEd</u>	<u>04/19/2021</u>	UPNY CONED	5985 MW
0201	Continuous	1800				Impacts Total Transfer Capability	235 MW
Work scheduled by: ConEd					TTC with All Lines In Service	6220 MW	
<hr/>					FWD		
MILLWOOD_345KV_18					(Import)		
Fri 04/23/2021	to	Sat 04/24/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>04/02/2021</u>	UPNY CONED	4350 MW
0201	Continuous	2200				Impacts Total Transfer Capability	1870 MW
Work scheduled by: ConEd					TTC with All Lines In Service	6220 MW	
<hr/>					FWD	REV	
N.SCTLND-ALPS____345_2 & NRTH1385-NOR HBR__138_601					(Import)	(Export)	
Fri 04/23/2021	to	Fri 04/23/2021				SCH - NPX_1385	0 MW 0 MW
0800		1600				Impacts Total Transfer Capability	200 MW 200 MW
Work scheduled by:					TTC with All Lines In Service	200 MW 200 MW	
<hr/>					FWD	REV	
N.SCTLND-ALPS____345_2 & NRTH1385-NOR HBR__138_602					(Import)	(Export)	
Fri 04/23/2021	to	Fri 04/23/2021				SCH - NPX_1385	0 MW 0 MW
0800		1600				Impacts Total Transfer Capability	200 MW 200 MW
Work scheduled by:					TTC with All Lines In Service	200 MW 200 MW	
<hr/>					FWD	REV	
N.SCTLND-ALPS____345_2 & NRTH1385-NOR HBR__138_603					(Import)	(Export)	
Fri 04/23/2021	to	Fri 04/23/2021				SCH - NPX_1385	0 MW 0 MW
0800		1600				Impacts Total Transfer Capability	200 MW 200 MW
Work scheduled by:					TTC with All Lines In Service	200 MW 200 MW	

NYISO TRANSFER LIMITATIONS

Wednesday, April 21, 2021 to Friday, October 21, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

			FWD	REV
			(Import)	(Export)
NRTH1385-NOR HBR_138_601				
Fri 04/23/2021	to	Fri 04/23/2021		
0800	Continuous	1600	SCH - NPX_1385	100 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW
			TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR_138_601 & NRTH1385-NOR HBR_138_602				
Fri 04/23/2021	to	Fri 04/23/2021		
0800		1600	SCH - NPX_1385	0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW
			TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR_138_601 & NRTH1385-NOR HBR_138_603				
Fri 04/23/2021	to	Fri 04/23/2021		
0800		1600	SCH - NPX_1385	0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW
			TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR_138_602				
Fri 04/23/2021	to	Fri 04/23/2021		
0800	Continuous	1600	SCH - NPX_1385	100 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW
			TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR_138_602 & NRTH1385-NOR HBR_138_603				
Fri 04/23/2021	to	Fri 04/23/2021		
0800		1600	SCH - NPX_1385	0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW
			TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR_138_603				
Fri 04/23/2021	to	Fri 04/23/2021		
0800	Continuous	1600	SCH - NPX_1385	100 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW
			TTC with All Lines In Service	200 MW
NRTH1385-NRTHPORT_138_NNC				
Fri 04/23/2021	to	Fri 04/23/2021		
0800	Continuous	1600	SCH - NPX_1385	0 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	200 MW
			TTC with All Lines In Service	200 MW

NYISO TRANSFER LIMITATIONS

Wednesday, April 21, 2021 to Friday, October 21, 2022

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-NE_LIMIT_900					REV	
Sat 04/24/2021	to	Sat 05/01/2021	UPDATED	by ISONE	04/20/2021	(Export)
0801	Continuous	0800				1100 MW
Work scheduled by: ISONE					SCH - NE - NY	600 MW
					Impacts Total Transfer Capability	1700 MW
					TTC with All Lines In Service	
CHAT_DC_GC1					FWD	
Sat 04/24/2021	to	Sun 04/25/2021				(Import)
2000	Continuous	0500				2850 MW
Work scheduled by: HQ					MOSES SOUTH	300 MW
					Impacts Total Transfer Capability	3150 MW
					TTC with All Lines In Service	
CHAT_DC_GC1					REV	
Sat 04/24/2021	to	Sun 04/25/2021				(Export)
2000	Continuous	0500				500 MW
Work scheduled by: HQ					SCH - HQ - NY	500 MW
					Impacts Total Transfer Capability	1000 MW
					TTC with All Lines In Service	
PLSNTVLY-WOOD_ST_345_F30					FWD	
Mon 04/26/2021	to	Tue 04/27/2021	UPDATED	by CONED	04/17/2021	(Import)
0001	Continuous	0200				4000 MW
Work scheduled by: ConEd					UPNY CONED	2220 MW
					Impacts Total Transfer Capability	6220 MW
					TTC with All Lines In Service	
PLSNTVLY_345KV_RNS5					FWD	
Mon 04/26/2021	to	Tue 04/27/2021	UPDATED	by CONED	04/17/2021	(Import)
0001	Continuous	0200				3800 MW
Work scheduled by: ConEd					UPNY CONED	2420 MW
					Impacts Total Transfer Capability	6220 MW
					TTC with All Lines In Service	
KINTIGH_-STA_255_345_SH1-39					FWD	
Mon 04/26/2021	to	Fri 04/30/2021				(Import)
0700	Continuous	1700				1700 MW
Work scheduled by: NYPA					DYSINGER EAST	1450 MW
					Impacts Total Transfer Capability	3150 MW
					TTC with All Lines In Service	
NIAGARA_-KINTIGH_345_NS1-38					FWD	
Mon 04/26/2021	to	Fri 04/30/2021				(Import)
0700	Continuous	1700				1700 MW
Work scheduled by: NYPA					DYSINGER EAST	1450 MW
					Impacts Total Transfer Capability	3150 MW
					TTC with All Lines In Service	

NYISO TRANSFER LIMITATIONS

Wednesday, April 21, 2021 to Friday, October 21, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HOMRC_NY-MAINS_NY_345_47

Mon 04/26/2021 to Sat 05/29/2021 **EXTENDED** **by NYSEG** **03/10/2021**
 0800 Continuous 1900
 Work scheduled by: NYSEG

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FRASER_-COOPERS_345_33

Mon 04/26/2021 to Fri 04/30/2021
 0830 Continuous 1500
 Work scheduled by: NYSEG

FWD
 (Import)
 CENTRAL EAST - VC **2395 MW**
 Impacts Total Transfer Capability 580 MW
 TTC with All Lines In Service 2975 MW

ALCOA_PA_115KV_R8105

Tue 04/27/2021 to Thu 04/29/2021
 0630 Continuous 1830
 Work scheduled by: NGrid

FWD
 (Import)
 MOSES SOUTH **3100 MW**
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 3150 MW

MOTTHAVN-RAINEY_345_Q11

Wed 04/28/2021 to Sat 05/08/2021
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

BUCHAN_N-EASTVIEW_345_W93

Fri 04/30/2021 to Mon 05/10/2021 **EXTENDED** **by CONED** **04/19/2021**
 0700 Continuous 0159
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1870 MW
 TTC with All Lines In Service 6220 MW

SCH-IMO-NYISO_LIMIT_1600

Sat 05/01/2021 to Sun 10/31/2021 **UPDATED** **by IESO** **05/03/2019**
 0001 Continuous 2359
 Work scheduled by: IESO

FWD
 (Import)
 SCH - OH - NY **1900 MW**
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 1950 MW

W49TH_ST_345KV_5

Sun 05/02/2021 to Sun 05/02/2021 **UPDATED** **by CONED** **04/13/2021**
 0201 Continuous 0231
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Wednesday, April 21, 2021 to Friday, October 21, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_7

Sun 05/02/2021 to Sun 05/02/2021
0201 Continuous 0231

Work scheduled by: ConEd

UPDATED by CONED 04/13/2021

SCH - PJM_HTP **300 MW**
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

FWD
(Import)

CHAT_DC_GC2

Sun 05/02/2021 to Fri 05/28/2021
0500 Continuous 1700

Work scheduled by: HQ

MOSES SOUTH **2850 MW**
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 3150 MW

FWD
(Import)

CHAT_DC_GC2

Sun 05/02/2021 to Fri 05/28/2021
0500 Continuous 1700

Work scheduled by: HQ

SCH - HQ - NY **500 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1000 MW

REV
(Export)

DUNWODIE_345KV_7

Mon 05/03/2021 to Mon 05/03/2021
0001 Continuous 0030

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD
(Import)

DUNWODIE_345KV_8

Mon 05/03/2021 to Mon 05/03/2021
0001 Continuous 0030

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD
(Import)

DUNWODIE-MOTTHAVN_345_72

Mon 05/03/2021 to Mon 05/03/2021
0001 Continuous 1800

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD
(Import)

NRTH1385-NOR HBR_138_601

Mon 05/03/2021 to Mon 05/24/2021
0600 Continuous 2359

Work scheduled by: LI

SCH - NPX_1385 **100 MW** **100 MW**
Impacts Total Transfer Capability 100 MW 100 MW
TTC with All Lines In Service 200 MW 200 MW

FWD REV
(Import) (Export)

NYISO TRANSFER LIMITATIONS

Wednesday, April 21, 2021 to Friday, October 21, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Work Period			SCH	FWD	REV
Start	End	Notes		(Import)	(Export)
NRTH1385-NOR HBR_138_601 & NRTH1385-NOR HBR_138_602					
Mon 05/03/2021	to	Mon 05/24/2021	SCH - NPX_1385	0 MW	0 MW
0600		2359	Impacts Total Transfer Capability	200 MW	200 MW
Work scheduled by:			TTC with All Lines In Service	200 MW	200 MW
NRTH1385-NOR HBR_138_601 & NRTH1385-NOR HBR_138_603					
Mon 05/03/2021	to	Mon 05/24/2021	SCH - NPX_1385	0 MW	0 MW
0600		2359	Impacts Total Transfer Capability	200 MW	200 MW
Work scheduled by:			TTC with All Lines In Service	200 MW	200 MW
NRTH1385-NOR HBR_138_602					
Mon 05/03/2021	to	Mon 05/24/2021	SCH - NPX_1385	100 MW	100 MW
0600	Continuous	2359	Impacts Total Transfer Capability	100 MW	100 MW
Work scheduled by: LI			TTC with All Lines In Service	200 MW	200 MW
NRTH1385-NOR HBR_138_602 & NRTH1385-NOR HBR_138_603					
Mon 05/03/2021	to	Mon 05/24/2021	SCH - NPX_1385	0 MW	0 MW
0600		2359	Impacts Total Transfer Capability	200 MW	200 MW
Work scheduled by:			TTC with All Lines In Service	200 MW	200 MW
NRTH1385-NOR HBR_138_603					
Mon 05/03/2021	to	Mon 05/24/2021	SCH - NPX_1385	100 MW	100 MW
0600	Continuous	2359	Impacts Total Transfer Capability	100 MW	100 MW
Work scheduled by: LI			TTC with All Lines In Service	200 MW	200 MW
NRTH1385-NRTHPORT_138_NNC					
Mon 05/03/2021	to	Mon 05/24/2021	SCH - NPX_1385	0 MW	0 MW
0600	Continuous	2359	Impacts Total Transfer Capability	200 MW	200 MW
Work scheduled by: LI			TTC with All Lines In Service	200 MW	200 MW
CLAY -EDIC 345_2-15					
Mon 05/03/2021	to	Fri 05/07/2021	OSWEGO EXPORT	4850 MW	
0700	Continuous	1530	Impacts Total Transfer Capability	400 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	5250 MW	

NYISO TRANSFER LIMITATIONS

Wednesday, April 21, 2021 to Friday, October 21, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FIVEMILE-STOLLERD_345_29

Mon 05/03/2021 to Fri 05/14/2021
 0700 Continuous 1400
 Work scheduled by: NYSEG

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

SCH-HQ-NYISO_LIMIT_1400

Mon 05/03/2021 to Fri 05/14/2021
 0700 Continuous 1530
 Work scheduled by: HQ

FWD
 (Import)
 SCH - HQ - NY **1400 MW**
 Impacts Total Transfer Capability 100 MW
 TTC with All Lines In Service 1500 MW

PANNELL -CLAY_345_2

Mon 05/03/2021 to Sun 05/30/2021
 0700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 WEST CENTRAL **1300 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

HURLYAVE-ROSETON_345_303

Mon 05/03/2021 to Fri 05/21/2021
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4100 MW**
 Impacts Total Transfer Capability 3715 MW
 TTC with All Lines In Service 7815 MW

SHOR_NPX-SHOREHAM_138_CSC

Mon 05/03/2021 to Sat 05/08/2021 **EXTENDED by ISONE 03/15/2021**
 0900 Continuous 1600
 Work scheduled by: LI

FWD REV
 (Import) (Export)
 SCH - NPX_CSC **0 MW 0 MW**
 Impacts Total Transfer Capability 330 MW 330 MW
 TTC with All Lines In Service 330 MW 330 MW

DUNWODIE_345KV_7

Mon 05/03/2021 to Mon 05/03/2021
 1730 Continuous 1800
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_8

Mon 05/03/2021 to Mon 05/03/2021
 1730 Continuous 1800
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Wednesday, April 21, 2021 to Friday, October 21, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROTRDAM-EASTOVER_230_38					REV
Tue 05/04/2021	to	Tue 05/04/2021			(Export)
0830	Daily(No Weekends)	1130		SCH - NE - NY	1400 MW
Work scheduled by: NGrid			ARR: 77	Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	1600 MW
RAMAPO_-BUCHAN_N_345_Y94					FWD
Fri 05/07/2021	to	Mon 05/10/2021	EXTENDED	by CONED 04/19/2021	(Import)
0001	Continuous	0159		UPNY CONED	7580 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	235 MW
				TTC with All Lines In Service	7815 MW
EASTVIEW-SPRNBRK_345_W79					FWD
Sat 05/08/2021	to	Sun 05/09/2021	EXTENDED	by CONED 04/19/2021	(Import)
0700	Continuous	2359		UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	3465 MW
				TTC with All Lines In Service	7815 MW
W49TH_ST_345KV_5					FWD
Sun 05/09/2021	to	Sun 05/09/2021	UPDATED	by CONED 04/13/2021	(Import)
0130	Continuous	0200		SCH - PJM_HTP	300 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	360 MW
				TTC with All Lines In Service	660 MW
W49TH_ST_345KV_7					FWD
Sun 05/09/2021	to	Sun 05/09/2021	UPDATED	by CONED 04/13/2021	(Import)
0130	Continuous	0200		SCH - PJM_HTP	300 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	360 MW
				TTC with All Lines In Service	660 MW
W49TH_ST_345KV_7					FWD
Mon 05/10/2021	to	Mon 05/10/2021			(Import)
0001	Continuous	0030		SCH - PJM_HTP	300 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	360 MW
				TTC with All Lines In Service	660 MW
W49TH_ST_345KV_8					FWD
Mon 05/10/2021	to	Mon 05/10/2021			(Import)
0001	Continuous	0030		SCH - PJM_HTP	450 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	210 MW
				TTC with All Lines In Service	660 MW

NYISO TRANSFER LIMITATIONS

Wednesday, April 21, 2021 to Friday, October 21, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONTP-W49TH_ST_345_Y56					FWD	
Mon 05/10/2021	to	Thu 05/13/2021			(Import)	
0001	Continuous	2300		SCH - PJM_HTP	0 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	660 MW
SPRNBRK_-TREMONT_345_X28					FWD	
Mon 05/10/2021	to	Wed 05/26/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>03/18/2021</u>	(Import)
0001	Continuous	0200		SPR/DUN-SOUTH	4200 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability	400 MW
					TTC with All Lines In Service	4600 MW
CLAY_-EDIC_345_1-16					FWD	
Mon 05/10/2021	to	Fri 05/14/2021			(Import)	
0700	Continuous	1530		OSWEGO EXPORT	4850 MW	
Work scheduled by: NYPA					Impacts Total Transfer Capability	400 MW
					TTC with All Lines In Service	5250 MW
MOSES_-ADIRNDCK_230_MA2					FWD	
Mon 05/10/2021	to	Tue 06/01/2021			(Import)	
1200	Continuous	0659		MOSES SOUTH	2100 MW	
Work scheduled by: NYPA					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	3150 MW
ALCOA_PA_115KV_R8105					FWD	
Tue 05/11/2021	to	Thu 06/03/2021			(Import)	
0630	Continuous	1630		MOSES SOUTH	3100 MW	
Work scheduled by: NGrid					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	3150 MW
DENNISON-ROSEMNTB_115_2/22					FWD	REV
Wed 05/12/2021	to	Wed 05/12/2021	<u>UPDATED</u>	<u>by HQ</u>	<u>04/16/2021</u>	(Import) (Export)
0630	Daily(No Weekends)	1830		SCH - HQ_CEDARS	95 MW	40 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	95 MW 0 MW
					TTC with All Lines In Service	190 MW 40 MW
SCH-HQ_CEDARS-NYISO_LIMIT_80					FWD	
Wed 05/12/2021	to	Wed 05/12/2021	<u>UPDATED</u>	<u>by HQ</u>	<u>04/16/2021</u>	(Import)
0630	Daily(No Weekends)	1830		SCH - HQ_CEDARS	80 MW	
Work scheduled by: NGrid					Impacts Total Transfer Capability	110 MW
					TTC with All Lines In Service	190 MW

NYISO TRANSFER LIMITATIONS

Wednesday, April 21, 2021 to Friday ,October 21, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_7			FWD	
Thu 05/13/2021	to	Thu 05/13/2021	(Import)	
2230	Continuous	2300	SCH - PJM_HTP	300 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	360 MW
			TTC with All Lines In Service	660 MW
W49TH_ST_345KV_8			FWD	
Thu 05/13/2021	to	Thu 05/13/2021	(Import)	
2230	Continuous	2300	SCH - PJM_HTP	450 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	210 MW
			TTC with All Lines In Service	660 MW
CRICKVLY-PLSNTVLY_345_F83			FWD	
Fri 05/14/2021	to	Fri 05/14/2021	(Import)	
0001	Continuous	2200	SCH - NE - NY	350 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	1050 MW
			TTC with All Lines In Service	1400 MW
CRICKVLY-PLSNTVLY_345_F83			FWD	REV
Fri 05/14/2021	to	Fri 05/14/2021	(Import)	(Export)
0001	Continuous	2200	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR_138_601 & CRICKVLY-PLSNTVLY_345_F83			FWD	REV
Fri 05/14/2021	to	Fri 05/14/2021	(Import)	(Export)
0001		2200	SCH - NPX_1385	0 MW 0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR_138_602 & CRICKVLY-PLSNTVLY_345_F83			FWD	REV
Fri 05/14/2021	to	Fri 05/14/2021	(Import)	(Export)
0001		2200	SCH - NPX_1385	0 MW 0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR_138_603 & CRICKVLY-PLSNTVLY_345_F83			FWD	REV
Fri 05/14/2021	to	Fri 05/14/2021	(Import)	(Export)
0001		2200	SCH - NPX_1385	0 MW 0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW

NYISO TRANSFER LIMITATIONS

Wednesday, April 21, 2021 to Friday, October 21, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BUCHAN_N-EASTVIEW_345_W93				FWD
Fri 05/14/2021	to	Sat 05/15/2021		(Import)
0001	Continuous	0200	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 3465 MW
				TTC with All Lines In Service 7815 MW
RAMAPO_-BUCHAN_N_345_Y94				FWD
Fri 05/14/2021	to	Sat 05/15/2021		(Import)
0001	Continuous	0200	UPNY CONED	7580 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 235 MW
				TTC with All Lines In Service 7815 MW
SPRNBK__345KV_RS3 & SPRNBK__345KV_RS4				FWD
Sat 05/15/2021	to	Sat 05/15/2021		(Import)
0301		2230	SPR/DUN-SOUTH	3200 MW
Work scheduled by:				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_5				FWD
Mon 05/17/2021	to	Tue 05/18/2021	CANCELLED by ConEd 04/20/2021	(Import)
0201	Continuous	0200	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_7				FWD
Mon 05/17/2021	to	Tue 05/18/2021	CANCELLED by ConEd 04/20/2021	(Import)
0201	Continuous	0200	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
SPRNBK_-DUNWODIE_345_W75				FWD
Mon 05/17/2021	to	Tue 05/18/2021	CANCELLED by ConEd 04/20/2021	(Import)
0201	Continuous	0200	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
SPRNBK__345KV_RNS3				FWD
Mon 05/17/2021	to	Tue 05/18/2021	CANCELLED by ConEd 04/20/2021	(Import)
0201	Continuous	0200	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Wednesday, April 21, 2021 to Friday, October 21, 2022

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-STA_255__345_NH2

FWD

Mon 05/17/2021 to Fri 05/21/2021 **UPDATED by NYPA 03/23/2021**
 0500 Continuous 1700

(Import)

Work scheduled by: NYPA

DYSINGER EAST **1400 MW**
 Impacts Total Transfer Capability 1750 MW
 TTC with All Lines In Service 3150 MW

SAND_BAR-PLATSBRG_115_PV20

Mon 05/17/2021 to Fri 07/02/2021
 0600 Continuous 1800

Work scheduled by: ISONE

SCH - NE - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

GOETHALS_345KV_5

Wed 05/19/2021 to Mon 05/24/2021 **EXTENDED by CE 04/05/2021**
 0100 Continuous 0200

Work scheduled by: ConEd

STATEN ISLAND
 Impacts Total Transfer Capability
 TTC with All Lines In Service

LINDEN_-GOETHALS_230_A2253

FWD

REV

Wed 05/19/2021 to Mon 05/24/2021 **EXTENDED by CE 04/05/2021**
 0100 Continuous 0200

(Import) (Export)

Work scheduled by: ConEd

SCH - PJ - NY **2050 MW 1150 MW**
 Impacts Total Transfer Capability 150 MW 100 MW
 TTC with All Lines In Service 2200 MW 1250 MW

LINDEN_-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402

FWD

REV

Wed 05/19/2021 to Mon 05/24/2021
 0100 0200

(Import) (Export)

Work scheduled by:

SCH - PJ - NY **2000 MW 1000 MW**
 Impacts Total Transfer Capability 200 MW 250 MW
 TTC with All Lines In Service 2200 MW 1250 MW

LINDEN_-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403

FWD

REV

Wed 05/19/2021 to Mon 05/24/2021
 0100 0200

(Import) (Export)

Work scheduled by:

SCH - PJ - NY **2000 MW 1000 MW**
 Impacts Total Transfer Capability 200 MW 250 MW
 TTC with All Lines In Service 2200 MW 1250 MW

LINDEN_-GOETHALS_230_A2253 & MARION_-FARRAGUT_345_C3403

FWD

REV

Wed 05/19/2021 to Mon 05/24/2021
 0100 0200

(Import) (Export)

Work scheduled by:

SCH - PJ - NY **2000 MW 1000 MW**
 Impacts Total Transfer Capability 200 MW 250 MW
 TTC with All Lines In Service 2200 MW 1250 MW

NYISO TRANSFER LIMITATIONS

Wednesday, April 21, 2021 to Friday, October 21, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BUCHAN_S-MILLWOOD_345_W97

Thu 05/20/2021 to Sat 05/22/2021
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **7680 MW**
 Impacts Total Transfer Capability 135 MW
 TTC with All Lines In Service 7815 MW

W49TH_ST_345KV_6

Thu 05/20/2021 to Sat 05/22/2021 **UPDATED by CONED 03/30/2021**
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

W49TH_ST-E13THSTA_345_M55

Thu 05/20/2021 to Mon 05/24/2021 **UPDATED by CONED 03/30/2021**
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

E13THSTA-FARRAGUT_345_46

Sat 05/22/2021 to Mon 05/24/2021 **UPDATED by CONED 03/30/2021**
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

PLSNTVLY-WOOD_ST_345_F31

Mon 05/24/2021 to Tue 05/25/2021
 0001 Continuous 0159
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 3815 MW
 TTC with All Lines In Service 7815 MW

PLSNTVLY_345KV_RNS4

Mon 05/24/2021 to Tue 05/25/2021
 0001 Continuous 0159
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

W49TH_ST_345KV_6

Mon 05/24/2021 to Mon 05/24/2021 **UPDATED by CONED 03/30/2021**
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Wednesday, April 21, 2021 to Friday , October 21, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DENNISON-ROSEMNTB_115_2/22		FWD	REV
		(Import)	(Export)
Mon 05/24/2021	to Wed 05/26/2021		
0630	Continuous 1900	SCH - HQ_CEDARS	95 MW 40 MW
Work scheduled by: NGrid		Impacts Total Transfer Capability	95 MW 0 MW
		TTC with All Lines In Service	190 MW 40 MW
SCH-HQ_CEDARS-NYISO_LIMIT_80		FWD	
		(Import)	
Mon 05/24/2021	to Wed 05/26/2021		
0630	Continuous 1900	SCH - HQ_CEDARS	80 MW
Work scheduled by: NGrid		Impacts Total Transfer Capability	110 MW
		TTC with All Lines In Service	190 MW
ROSETON_-EFISHKIL_345_RFK305		FWD	
		(Import)	
Wed 05/26/2021	to Thu 05/27/2021		
0001	Continuous 0200	UPNY CONED	6680 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability	1135 MW
		TTC with All Lines In Service	7815 MW
DENNISON-ROSEMNTA_115_1/11		FWD	REV
		(Import)	(Export)
Thu 05/27/2021	to Fri 05/28/2021		
0630	Continuous 1900	SCH - HQ_CEDARS	95 MW 40 MW
Work scheduled by: NGrid		Impacts Total Transfer Capability	95 MW 0 MW
		TTC with All Lines In Service	190 MW 40 MW
SCH-HQ_CEDARS-NYISO_LIMIT_80		FWD	
		(Import)	
Thu 05/27/2021	to Fri 05/28/2021		
0630	Continuous 1900	SCH - HQ_CEDARS	80 MW
Work scheduled by: NGrid		Impacts Total Transfer Capability	110 MW
		TTC with All Lines In Service	190 MW
VOLNEY_-MARCY_345_19		FWD	
		(Import)	
Tue 06/01/2021	to Wed 06/02/2021		
0700	Continuous 1730	CENTRAL EAST - VC	2825 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	150 MW
		TTC with All Lines In Service	2975 MW
VOLNEY_-MARCY_345_19		FWD	
		(Import)	
Tue 06/01/2021	to Wed 06/02/2021		
0700	Continuous 1730	OSWEGO EXPORT	4900 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	350 MW
		TTC with All Lines In Service	5250 MW

ARR: 19

ARR: 19

NYISO TRANSFER LIMITATIONS

Wednesday, April 21, 2021 to Friday, October 21, 2022

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASER -GILBOA 345_GF5-35

Tue 06/01/2021 to Mon 06/07/2021
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2650 MW**
Impacts Total Transfer Capability 325 MW
TTC with All Lines In Service 2975 MW

MOSES -ADIRNDCK 230_MA2

Tue 06/01/2021 to Sun 11/14/2021
0700 Continuous 1300

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

MARCY -EDIC 345_UE1-7

Thu 06/03/2021 to Fri 06/04/2021
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19&16

FWD
(Import)
OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

PORTER -ROTRDAM 230_30

Thu 06/03/2021 to Wed 09/15/2021
0700 Continuous 0659

Work scheduled by: NGrid

UPDATED by NGRID 01/19/2021

FWD
(Import)
CENTRAL EAST - VC **2805 MW**
Impacts Total Transfer Capability 170 MW
TTC with All Lines In Service 2975 MW

MARCY 345KV_CSC

Sat 06/05/2021 to Sat 06/05/2021
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2925 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

ATHENS -PLSNTVLY 345_91

Tue 06/08/2021 to Wed 06/16/2021
0600 Continuous 2000

Work scheduled by: NGrid

FWD
(Import)
UPNY CONED **3800 MW**
Impacts Total Transfer Capability 4015 MW
TTC with All Lines In Service 7815 MW

GILBOA -N.SCTLND 345_GNS-1

Wed 06/09/2021 to Wed 06/09/2021
0800 Daily 1200

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **2520 MW**
Impacts Total Transfer Capability 455 MW
TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Wednesday, April 21, 2021 to Friday , October 21, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BECK ___ - NIAGARA ___ 345_PA301	FWD	REV
Wed 06/16/2021 to Thu 06/17/2021	(Import)	(Export)
0500 Continuous 2330	SCH - OH - NY	900 MW 800 MW
Work scheduled by: NYPA	Impacts Total Transfer Capability	1050 MW 900 MW
	TTC with All Lines In Service	1950 MW 1700 MW
<hr/>		
PLSNTVLY_345KV_RNS5	FWD	
Thu 06/17/2021 to Thu 06/17/2021	(Import)	
0001 Continuous 0030	UPNY CONED	3800 MW
Work scheduled by: NGrid	Impacts Total Transfer Capability	4015 MW
	TTC with All Lines In Service	7815 MW
<hr/>		
LEEDS ___ - PLSNTVLY_345_92	FWD	
Thu 06/17/2021 to Thu 06/24/2021	(Import)	
0001 Continuous 2000	UPNY CONED	3800 MW
Work scheduled by: NGrid	Impacts Total Transfer Capability	4015 MW
	TTC with All Lines In Service	7815 MW
<hr/>		
PLSNTVLY_345KV_RNS5	FWD	
Thu 06/24/2021 to Thu 06/24/2021	(Import)	
1930 Continuous 2000	UPNY CONED	3800 MW
Work scheduled by: NGrid	Impacts Total Transfer Capability	4015 MW
	TTC with All Lines In Service	7815 MW
<hr/>		
BECK ___ - NIAGARA ___ 345_PA301	FWD	REV
Fri 06/25/2021 to Fri 06/25/2021	(Import)	(Export)
0500 Continuous 1700	SCH - OH - NY	900 MW 800 MW
Work scheduled by: NYPA	Impacts Total Transfer Capability	1050 MW 900 MW
	TTC with All Lines In Service	1950 MW 1700 MW
<hr/>		
FRASANNX-COOPERS ___ 345_UCC2-41	FWD	
Fri 06/25/2021 to Tue 08/10/2021	(Import)	
0700 Continuous 1530	CENTRAL EAST - VC	2500 MW
Work scheduled by: NYPA	Impacts Total Transfer Capability	475 MW
	TTC with All Lines In Service	2975 MW
		ARR: 19
<hr/>		
MARCY ___ - FRASANNX_345_UCC2-41	FWD	
Fri 06/25/2021 to Tue 08/10/2021	(Import)	
0700 Continuous 1530	CENTRAL EAST - VC	2500 MW
Work scheduled by: NYPA	Impacts Total Transfer Capability	475 MW
	TTC with All Lines In Service	2975 MW
		ARR: 19

NYISO TRANSFER LIMITATIONS

Wednesday, April 21, 2021 to Friday, October 21, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BECK	-NIAGARA	345_PA302				FWD	REV
Mon 07/12/2021	to	Fri 07/16/2021				(Import)	(Export)
0500	Continuous	1700			SCH - OH - NY	900 MW	800 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	1050 MW 900 MW
						TTC with All Lines In Service	1950 MW 1700 MW
NIAGARA	345_230_AT4					FWD	REV
Mon 07/19/2021	to	Fri 07/30/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>02/19/2021</u>	(Import)	(Export)
0500	Continuous	1700			SCH - OH - NY	1900 MW	1400 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	50 MW 300 MW
						TTC with All Lines In Service	1950 MW 1700 MW
NIAGARA	-STA_255_345_NH2					FWD	
Mon 07/26/2021	to	Fri 07/30/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>02/19/2021</u>	(Import)	
0500	Continuous	1900			DYSINGER EAST	1400 MW	
Work scheduled by: NYPA						Impacts Total Transfer Capability	1750 MW
						TTC with All Lines In Service	3150 MW
SAND_BAR	-PLATSBRG_115_PV20						
Tue 08/03/2021	to	Tue 08/03/2021					
0700	Continuous	1830			SCH - NE - NY		
Work scheduled by: NYPA						Impacts Total Transfer Capability	
						TTC with All Lines In Service	
KINTIGH	-STA_255_345_SH1-39					FWD	
Mon 08/09/2021	to	Sun 08/15/2021				(Import)	
0500	Continuous	1900			DYSINGER EAST	1400 MW	
Work scheduled by: NYPA						Impacts Total Transfer Capability	1750 MW
						TTC with All Lines In Service	3150 MW
NIAGARA	-KINTIGH_345_NS1-38					FWD	
Mon 08/09/2021	to	Sun 08/15/2021				(Import)	
0500	Continuous	1900			DYSINGER EAST	1400 MW	
Work scheduled by: NYPA						Impacts Total Transfer Capability	1750 MW
						TTC with All Lines In Service	3150 MW
KINTIGH	-STA_255_345_SH1-39					FWD	
Mon 08/16/2021	to	Sun 08/22/2021				(Import)	
0500	Continuous	1900			DYSINGER EAST	1400 MW	
Work scheduled by: NYPA						Impacts Total Transfer Capability	1750 MW
						TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Wednesday, April 21, 2021 to Friday, October 21, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-KINTIGH_345_NS1-38

Mon 08/16/2021 to Sun 08/22/2021
0500 Continuous 1900

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

NIAGARA_-STA_255_345_NH2

Wed 09/01/2021 to Tue 09/21/2021
0500 Continuous 1900

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

FRASANX-COOPERS_345_UCC2-41

Tue 09/07/2021 to Wed 09/15/2021 **UPDATED by NYISO 02/03/2021**
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

MARCY_-FRASANX_345_UCC2-41

Tue 09/07/2021 to Wed 09/15/2021 **UPDATED by NYISO 02/03/2021**
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

PORTER_-ROTTRDAM_230_30

Wed 09/15/2021 to Tue 11/30/2021
0700 Continuous 1730

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **2805 MW**
Impacts Total Transfer Capability 170 MW
TTC with All Lines In Service 2975 MW

EDIC_-N.SCTLND_345_14

Thu 09/16/2021 to Sun 11/14/2021
0700 Continuous 1730

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **1670 MW**
Impacts Total Transfer Capability 1305 MW
TTC with All Lines In Service 2975 MW

EDIC_-N.SCTLND_345_14 & PORTER_-ROTTRDAM_230_30

Thu 09/16/2021 to Sun 11/14/2021
0700 Continuous 1730

Work scheduled by:

FWD
(Import)
CENTRAL EAST - VC **1500 MW**
Impacts Total Transfer Capability 1475 MW
TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Wednesday, April 21, 2021 to Friday , October 21, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HURLYAVE-ROSETON__345_303

Thu 09/16/2021 to Sun 10/17/2021
0800 Continuous 1600

Work scheduled by: CHGE

UPDATED by CHGE 09/22/2020

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 3715 MW
TTC with All Lines In Service 7815 MW

HOMRC_NY-MAINS_NY_345_47

Sat 09/18/2021 to Fri 11/05/2021
0800 Continuous 1600

Work scheduled by: PJM

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

PANNELL_-CLAY____345_1

Mon 09/20/2021 to Fri 09/24/2021
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

CLAY_-EDIC____345_2-15

Mon 09/20/2021 to Sat 10/16/2021
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
OSWEGO EXPORT **4850 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 5250 MW

KINTIGH_-STA_255__345_SH1-39

Mon 09/27/2021 to Wed 09/29/2021
0500 Continuous 0459

Work scheduled by: NYPA

UPDATED by NYPA 03/04/2021

FWD
(Import)
DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

NIAGARA_-KINTIGH__345_NS1-38

Mon 09/27/2021 to Wed 09/29/2021
0500 Continuous 0459

Work scheduled by: NYPA

UPDATED by NYPA 03/04/2021

FWD
(Import)
DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

PANNELL_-CLAY____345_2

Mon 09/27/2021 to Fri 10/01/2021
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

NYISO TRANSFER LIMITATIONS

Wednesday, April 21, 2021 to Friday, October 21, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_6

Tue 09/28/2021 to Tue 09/28/2021
0100 Continuous 0130

Work scheduled by: ConEd

UPDATED by CONED 01/15/2021

FWD
(Import)
SCH - PJM_HTP **300 MW**
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

E13THSTA-FARRAGUT_345_46

Tue 09/28/2021 to Tue 10/26/2021
0100 Continuous 0300

Work scheduled by: ConEd

UPDATED by CONED 01/15/2021

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

W49TH_ST-E13THSTA_345_M55

Tue 09/28/2021 to Tue 10/26/2021
0100 Continuous 0300

Work scheduled by: ConEd

UPDATED by CONED 01/15/2021

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

KINTIGH_-STA_255_345_SH1-39

Wed 09/29/2021 to Wed 12/01/2021
0500 Continuous 1900

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

NIAGARA_-KINTIGH_345_NS1-38

Wed 09/29/2021 to Wed 12/01/2021
0500 Continuous 1900

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

LEEDS_-HURLYAVE_345_301

Mon 10/18/2021 to Fri 11/19/2021
0800 Continuous 1600

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 3715 MW
TTC with All Lines In Service 7815 MW

GOETHALS_345KV_5

Thu 10/21/2021 to Sat 11/20/2021
0001 Continuous 0200

Work scheduled by: ConEd

UPDATED by CONED 03/05/2021

FWD
(Import)
STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Wednesday, April 21, 2021 to Friday, October 21, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_6

Tue 10/26/2021 to Tue 10/26/2021
 0230 Continuous 0300
 Work scheduled by: ConEd

UPDATED by CONED 01/15/2021

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

SCH-IMO-NYISO_LIMIT_1750

Mon 11/01/2021 to Fri 12/31/2021
 0001 Continuous 2359
 Work scheduled by: IESO

UPDATED by IESO 05/03/2019

FWD
 (Import)
 SCH - OH - NY **2050 MW**
 Impacts Total Transfer Capability 250 MW
 TTC with All Lines In Service 2300 MW

SCH-NYISO-IMO_LIMIT_1600

Mon 11/01/2021 to Fri 12/31/2021
 0001 Continuous 2359
 Work scheduled by: IESO

UPDATED by IESO 05/03/2019

REV
 (Export)
 SCH - OH - NY **1900 MW**
 Impacts Total Transfer Capability 100 MW
 TTC with All Lines In Service 2000 MW

LINDN_CG-LNDVFT___345_V-3022

Tue 11/02/2021 to Fri 11/05/2021
 0800 Continuous 1500
 Work scheduled by: PJM

UPDATED by IESO 05/03/2019

FWD REV
 (Import) (Export)
 SCH - PJM_VFT **0 MW 0 MW**
 Impacts Total Transfer Capability 315 MW 315 MW
 TTC with All Lines In Service 315 MW 315 MW

PORTER__-ROTTRDAM_230_30 & MASSENA_-MARCY___765_MSU1

Mon 11/15/2021 to Tue 11/30/2021
 0100 1730
 Work scheduled by:

UPDATED by IESO 05/03/2019

FWD
 (Import)
 CENTRAL EAST - VC **1500 MW**
 Impacts Total Transfer Capability 1475 MW
 TTC with All Lines In Service 2975 MW

CHATGUAY-MASSENA___765_7040

Mon 11/15/2021 to Tue 11/30/2021
 0100 Continuous 1859
 Work scheduled by: NYPA

UPDATED by IESO 05/03/2019

FWD
 (Import)
 MOSES SOUTH **1550 MW**
 Impacts Total Transfer Capability 1600 MW
 TTC with All Lines In Service 3150 MW

CHATGUAY-MASSENA___765_7040

Mon 11/15/2021 to Tue 11/30/2021
 0100 Continuous 1859
 Work scheduled by: NYPA

UPDATED by IESO 05/03/2019

FWD REV
 (Import) (Export)
 SCH - HQ - NY **0 MW 0 MW**
 Impacts Total Transfer Capability 1500 MW 1000 MW
 TTC with All Lines In Service 1500 MW 1000 MW

NYISO TRANSFER LIMITATIONS

Wednesday, April 21, 2021 to Friday, October 21, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>MARCY___765_345_AT1</p> <p>Mon 11/15/2021 to Tue 11/30/2021 0100 Continuous 1859</p> <p>Work scheduled by: NYPA</p>	<p>ARR: 19</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH 1750 MW</p> <p>Impacts Total Transfer Capability 1400 MW</p> <p>TTC with All Lines In Service 3150 MW</p>															
<p>MARCY___765_345_AT2</p> <p>Mon 11/15/2021 to Tue 11/30/2021 0100 Continuous 1859</p> <p>Work scheduled by: NYPA</p>	<p>ARR: 19</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH 1700 MW</p> <p>Impacts Total Transfer Capability 1450 MW</p> <p>TTC with All Lines In Service 3150 MW</p>															
<p>MASSENA_-MARCY___765_MSU1</p> <p>Mon 11/15/2021 to Tue 11/30/2021 0100 Continuous 1859</p> <p>Work scheduled by: NYPA</p>		<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC 1670 MW</p> <p>Impacts Total Transfer Capability 1305 MW</p> <p>TTC with All Lines In Service 2975 MW</p>															
<p>MASSENA_-MARCY___765_MSU1</p> <p>Mon 11/15/2021 to Tue 11/30/2021 0100 Continuous 1859</p> <p>Work scheduled by: NYPA</p>		<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH 500 MW</p> <p>Impacts Total Transfer Capability 2650 MW</p> <p>TTC with All Lines In Service 3150 MW</p>															
<p>MASSENA_-MARCY___765_MSU1</p> <p>Mon 11/15/2021 to Tue 11/30/2021 0100 Continuous 1859</p> <p>Work scheduled by: NYPA</p>		<table border="0" style="width: 100%;"> <tr> <td style="width: 60%;"></td> <td style="width: 20%; text-align: right;">FWD</td> <td style="width: 20%; text-align: right;">REV</td> </tr> <tr> <td></td> <td style="text-align: right;">(Import)</td> <td style="text-align: right;">(Export)</td> </tr> <tr> <td>SCH - HQ - NY</td> <td style="text-align: right;">475 MW</td> <td style="text-align: right;">1000 MW</td> </tr> <tr> <td>Impacts Total Transfer Capability</td> <td style="text-align: right;">1025 MW</td> <td style="text-align: right;">0 MW</td> </tr> <tr> <td>TTC with All Lines In Service</td> <td style="text-align: right;">1500 MW</td> <td style="text-align: right;">1000 MW</td> </tr> </table>		FWD	REV		(Import)	(Export)	SCH - HQ - NY	475 MW	1000 MW	Impacts Total Transfer Capability	1025 MW	0 MW	TTC with All Lines In Service	1500 MW	1000 MW
	FWD	REV															
	(Import)	(Export)															
SCH - HQ - NY	475 MW	1000 MW															
Impacts Total Transfer Capability	1025 MW	0 MW															
TTC with All Lines In Service	1500 MW	1000 MW															
<p>MASSENA_-MARCY___765_MSU1</p> <p>Mon 11/15/2021 to Tue 11/30/2021 0100 Continuous 1859</p> <p>Work scheduled by: NYPA</p>		<p style="text-align: right;">FWD (Import)</p> <p>SCH - HQ_CEDARS 90 MW</p> <p>Impacts Total Transfer Capability 109 MW</p> <p>TTC with All Lines In Service 199 MW</p>															
<p>MASSENA_-MARCY___765_MSU1 & CHATGUAY-MASSENA_765_7040</p> <p>Mon 11/15/2021 to Tue 11/30/2021 0100 Continuous 1859</p> <p>Work scheduled by:</p>		<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH 500 MW</p> <p>Impacts Total Transfer Capability 2650 MW</p> <p>TTC with All Lines In Service 3150 MW</p>															

NYISO TRANSFER LIMITATIONS

Wednesday, April 21, 2021 to Friday, October 21, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2	FWD	REV
	(Import)	(Export)
Mon 11/15/2021 to Tue 11/30/2021 0100 1859	SCH - HQ - NY Impacts Total Transfer Capability TTC with All Lines In Service	850 MW 0 MW 1000 MW 1000 MW
Work scheduled by:		
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2	FWD	
Mon 11/15/2021 to Tue 11/30/2021 0100 1859	SCH - HQ_CEDARS Impacts Total Transfer Capability TTC with All Lines In Service	90 MW 109 MW 199 MW
Work scheduled by:		
STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1	FWD	
Mon 11/15/2021 to Tue 11/30/2021 0100 1859	SCH - HQ_CEDARS Impacts Total Transfer Capability TTC with All Lines In Service	90 MW 109 MW 199 MW
Work scheduled by:		
STLAWRNC-MOSES 230_L33P & MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2	FWD	
Mon 11/15/2021 to Tue 11/30/2021 0100 1859	SCH - HQ_CEDARS Impacts Total Transfer Capability TTC with All Lines In Service	90 MW 109 MW 199 MW
Work scheduled by:		
FRASER 345_FRASER SVC	FWD	
Wed 12/01/2021 to Mon 02/28/2022 0700 Continuous 1730	CENTRAL EAST - VC Impacts Total Transfer Capability TTC with All Lines In Service	2935 MW 40 MW 2975 MW
Work scheduled by: NYPA		
MOSES -ADIRNDCK 230_MAI	FWD	
Wed 12/01/2021 to Tue 05/31/2022 0700 Continuous 1300	MOSES SOUTH Impacts Total Transfer Capability TTC with All Lines In Service	2300 MW 850 MW 3150 MW
Work scheduled by: NYPA		
NIAGARA -STA 255 345_NH2	FWD	
Thu 12/02/2021 to Thu 01/13/2022 0500 Continuous 1900	DYSINGER EAST Impacts Total Transfer Capability TTC with All Lines In Service	1700 MW 1450 MW 3150 MW
Work scheduled by: NYPA		

NYISO TRANSFER LIMITATIONS

Wednesday, April 21, 2021 to Friday, October 21, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOTTHAVN-RAINEY ___ 345_Q12

Sun 12/05/2021 to Sat 12/25/2021
 0001 Continuous 0159
 Work scheduled by: ConEd

UPDATED by CONED 03/25/2021

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

LEEDS ___-PLSNTVLY_345_92

Thu 02/17/2022 to Mon 02/21/2022
 0600 Continuous 1900
 Work scheduled by: NGrid

UPDATED by NGRID 03/31/2021

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 2420 MW
 TTC with All Lines In Service 6220 MW

PORTER ___-ROTTRDAM_230_31

Tue 03/01/2022 to Tue 12/31/2030
 0600 Continuous 2359
 Work scheduled by: NGrid

FWD
 (Import)
 CENTRAL EAST - VC **2805 MW**
 Impacts Total Transfer Capability 170 MW
 TTC with All Lines In Service 2975 MW

GOETHALS_345KV_5

Sat 03/05/2022 to Mon 04/04/2022
 0001 Continuous 0200
 Work scheduled by: ConEd

UPDATED by CONED 03/26/2021

STATEN ISLAND
 Impacts Total Transfer Capability
 TTC with All Lines In Service

LINDEN ___-GOETHALS_230_A2253

Sat 03/05/2022 to Mon 04/04/2022
 0001 Continuous 0200
 Work scheduled by: ConEd

UPDATED by CONED 03/26/2021

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

PORTER ___-ROTTRDAM_230_30

Wed 04/13/2022 to Tue 12/31/2030
 0600 Continuous 2359
 Work scheduled by: NGrid

FWD
 (Import)
 CENTRAL EAST - VC **2805 MW**
 Impacts Total Transfer Capability 170 MW
 TTC with All Lines In Service 2975 MW

N. SCTLND-ALPS ___ 345_2

Mon 05/02/2022 to Mon 05/09/2022
 0600 Daily 1800
 Work scheduled by: NGrid

FWD
 (Import)
 SCH - NE - NY **750 MW**
 Impacts Total Transfer Capability 650 MW
 TTC with All Lines In Service 1400 MW

NYISO TRANSFER LIMITATIONS

Wednesday, April 21, 2021 to Friday, October 21, 2022

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
N. SCTLND-ALPS_____345_2						
Mon 05/02/2022	to	Mon 05/09/2022				
0600	Daily	1800			SCH - NPX_1385	100 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
HOMRC_NY-MAINS_NY_345_47						
Fri 05/20/2022	to	Fri 05/27/2022	<u>UPDATED</u>	<u>by PJM</u>	<u>11/19/2020</u>	
0800	Continuous	1600			SCH - PJ - NY	
Work scheduled by: PJM					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
HOMR_NYW-PIERC_NY_345_48						
Fri 05/20/2022	to	Fri 05/27/2022	<u>UPDATED</u>	<u>by PJM</u>	<u>11/19/2020</u>	
0800	Continuous	1600			SCH - PJ - NY	
Work scheduled by: PJM					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
MOSES___-ADIRNDCK_230_MA2						
Wed 06/01/2022	to	Mon 11/14/2022				FWD
0700	Continuous	1300			MOSES SOUTH	2100 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	3150 MW
SPRNBRK__345KV_RNS5						
Mon 09/19/2022	to	Mon 09/19/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>09/17/2020</u>	FWD
0001	Continuous	0030			SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
SPRNBRK_-W49TH_ST_345_M51						
Mon 09/19/2022	to	Wed 09/21/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>09/17/2020</u>	FWD
0001	Continuous	2200			SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
SPRNBRK__345KV_RNS5						
Wed 09/21/2022	to	Wed 09/21/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>09/17/2020</u>	FWD
2130	Continuous	2200			SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Wednesday, April 21, 2021 to Friday , October 21, 2022

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK_-W49TH_ST_345_M51

Sat 10/01/2022 to Mon 10/17/2022
 0001 Continuous 0300

UPDATED by CONED 08/01/2020

Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

FWD
 (Import)

SPRNBRK_345KV_RNS5

Sat 10/01/2022 to Mon 10/17/2022
 0001 Continuous 0300

UPDATED by CONED 08/01/2020

Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

FWD
 (Import)